

# NYISO TRANSFER LIMITATIONS

Tuesday ,April 26, 2022 to Thursday ,October 26, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### HUDSONP\_-FARRAGUT\_345\_B3402

Mon 01/15/2018 to Sun 07/31/2022 EXT FORCE by CONED 01/04/2022

0001 Continuous 2359

Work scheduled by: ConEd

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

### HUDSONP\_-FARRAGUT\_345\_B3402 & MARION\_-FARRAGUT\_345\_C3403

Mon 01/15/2018 to Sun 07/31/2022

0001 2359

Work scheduled by:

FWD REV  
(Import) (Export)

SCH - PJ - NY

2550 MW 1900 MW

Impacts Total Transfer Capability 300 MW 300 MW

TTC with All Lines In Service 2850 MW 2200 MW

### MARION\_-FARRAGUT\_345\_C3403

Mon 01/15/2018 to Sun 07/31/2022 EXT FORCE by CONED 01/04/2022

0001 Continuous 2359

Work scheduled by: ConEd

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

### STLAWRNC-MOSES\_230\_L33P

Mon 04/30/2018 to Mon 07/25/2022 EXT FORCE by IESO 11/04/2021

0456 Continuous 0800

Work scheduled by: IESO

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

### NEWBRDGE\_345\_138\_BK\_1

Wed 09/02/2020 to Mon 08/01/2022 EXT FORCE by LI 12/10/2021

1807 Continuous 2359

Work scheduled by: LI

FWD  
(Import)

SCH - PJM\_NEPTUNE

375 MW

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 660 MW

### SCH-IMO-NYISO\_LIMIT\_1750

Mon 11/01/2021 to Sat 04/30/2022 UPDATED by IESO 05/03/2019

0001 Continuous 2359

Work scheduled by: IESO

FWD  
(Import)

SCH - OH - NY

2050 MW

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 2300 MW

### SCH-NYISO-IMO\_LIMIT\_1600

Mon 11/01/2021 to Sat 04/30/2022 UPDATED by IESO 05/03/2019

0001 Continuous 2359

Work scheduled by: IESO

REV  
(Export)

SCH - OH - NY

1900 MW

Impacts Total Transfer Capability 100 MW

TTC with All Lines In Service 2000 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,April 26, 2022 to Thursday ,October 26, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
<b>BECK___-NIAGARA__345_PA301</b>							
Wed 02/09/2022	to	Fri 06/17/2022	<u>UPDATED</u>	<u>by NYISO</u>	<u>03/22/2022</u>		
0700	Continuous	1700				SCH - OH - NY	<b>1100 MW</b>
Work scheduled by: IESO						Impacts Total Transfer Capability	1050 MW
						TTC with All Lines In Service	2000 MW
<b>NIAGARA_-STA_255__345_NH2</b>						FWD	
Mon 02/21/2022	to	Tue 12/31/2030	<u>UPDATED</u>	<u>by NYPA</u>	<u>02/04/2022</u>	(Import)	
0500	Continuous	2359				DYSINGER EAST	<b>1700 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	1450 MW
						TTC with All Lines In Service	3150 MW
<b>MOSES___-ADIRNDCK_230_MA1</b>						FWD	
Mon 02/28/2022	to	Tue 05/31/2022	<u>UPDATED</u>	<u>by NYPA</u>	<u>02/16/2022</u>	(Import)	
0700	Continuous	1300				MOSES SOUTH	<b>2300 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	850 MW
						TTC with All Lines In Service	3150 MW
<b>PORTER___-ROTTRDAM_230_31</b>						FWD	
Tue 03/01/2022	to	Tue 12/31/2030				(Import)	
0600	Continuous	2359				CENTRAL EAST - VC	<b>2805 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability	170 MW
						TTC with All Lines In Service	2975 MW
<b>FRASANNX-COOPERS__345_UCC2-41</b>						FWD	
Tue 03/01/2022	to	Thu 04/21/2022	<u>EXTENDED</u>	<u>by NYPA</u>	<u>04/13/2022</u>	(Import)	
0700	Continuous	1530				CENTRAL EAST - VC	<b>2500 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	475 MW
						TTC with All Lines In Service	2975 MW
<b>MARCY___-FRASANNX_345_UCC2-41</b>						FWD	
Tue 03/01/2022	to	Thu 04/21/2022	<u>EXTENDED</u>	<u>by NYPA</u>	<u>04/13/2022</u>	(Import)	
0700	Continuous	1530				CENTRAL EAST - VC	<b>2500 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability	475 MW
						TTC with All Lines In Service	2975 MW
<b>EDIC___-N.SCTLND_345_14</b>						FWD	
Tue 03/08/2022	to	Tue 05/10/2022	<u>UPDATED</u>	<u>by NGRID</u>	<u>03/09/2022</u>	(Import)	
0700	Continuous	1530				CENTRAL EAST - VC	<b>1670 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability	1305 MW
						TTC with All Lines In Service	2975 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,April 26, 2022 to Thursday ,October 26, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EDIC\_\_\_\_-N.SCTLND\_345\_14 &amp; PORTER\_\_\_\_-ROTTRDAM\_230\_31

FWD

Tue 03/08/2022 to Tue 05/10/2022

(Import)

0700

1530

CENTRAL EAST - VC

1500 MW

Impacts Total Transfer Capability 1475 MW

TTC with All Lines In Service 2975 MW

Work scheduled by:

N.SCTLND-ALPS\_\_\_\_345\_2

FWD

Tue 03/08/2022 to Fri 06/24/2022

(Import)

0700

Continuous

1900

UPDATEDby NGRID 03/09/2022

SCH - NE - NY

900 MW

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 1400 MW

Work scheduled by: NGrid

N.SCTLND-ALPS\_\_\_\_345\_2

FWD

REV

Tue 03/08/2022 to Fri 06/24/2022

(Import) (Export)

0700

Continuous

1900

UPDATEDby NGRID 03/09/2022

SCH - NPX\_1385

100 MW

100 MW

Impacts Total Transfer Capability 100 MW 100 MW

TTC with All Lines In Service 200 MW 200 MW

Work scheduled by: NGrid

EGRDNCTY\_345\_138\_AT1

FWD

Sat 03/12/2022 to Sun 05/15/2022

(Import)

2148

Continuous

2359

FORCEDby CE03/13/2022

CONED - LIPA

1250 MW

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 1500 MW

Work scheduled by: ConEd

EGRDNCTY\_345\_138\_AT2

FWD

Sat 03/12/2022 to Sun 05/15/2022

(Import)

2148

Continuous

2359

FORCEDby CE03/13/2022

CONED - LIPA

1250 MW

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 1500 MW

Work scheduled by: ConEd

SPRNBRK\_-EGRDNCTR\_345\_Y49

FWD

Sat 03/12/2022 to Sun 05/15/2022

(Import)

2148

Continuous

2359

FORCEDby CE03/13/2022

CONED - LIPA

775 MW

Impacts Total Transfer Capability 725 MW

TTC with All Lines In Service 1500 MW

Work scheduled by: ConEd

W49TH\_ST\_345KV\_6

FWD

Mon 03/21/2022 to Sat 04/30/2022

(Import)

0809

Continuous

2359

EXT FORCEby CE04/04/2022

SCH - PJM\_HTP

310 MW

Impacts Total Transfer Capability 350 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

# NYISO TRANSFER LIMITATIONS

Tuesday ,April 26, 2022 to Thursday ,October 26, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### W49TH\_ST\_345KV\_8

FWD

Mon 03/21/2022 to Sat 04/30/2022 EXT FORCE by CE 04/04/2022

(Import)

0811 Continuous 2359

SCH - PJM\_HTP

310 MW

Impacts Total Transfer Capability 350 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

### SCH-IMO-NYISO\_LIMIT\_700

FWD

Fri 03/25/2022 to Sat 04/30/2022 UPDATED by NYISO 03/22/2022

(Import)

0001 Continuous 2359

SCH - OH - NY

1000 MW

Impacts Total Transfer Capability 1300 MW

TTC with All Lines In Service 2300 MW

Work scheduled by: IESO

### SCH-IMO-NYISO\_LIMIT\_400

FWD

Fri 03/25/2022 to Sat 04/30/2022 UPDATED by NYISO 03/22/2022

(Import)

2300 Daily 0500

SCH - OH - NY

700 MW

Impacts Total Transfer Capability 1600 MW

TTC with All Lines In Service 2300 MW

Work scheduled by: NYISO

### FIVEMILE-STOLLERD\_345\_29

Fri 04/01/2022 to Tue 12/31/2030 EXTENDED by NYSEG 04/06/2022

0500 Continuous 2359

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: NYSEG

### ATHENS\_\_-PLSNTVLY\_345\_91

FWD

Mon 04/18/2022 to Sun 05/15/2022 UPDATED by CE 04/07/2022

(Import)

0001 Continuous 2200

UPNY CONED

3800 MW

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

### PLSNTVLY\_345KV\_RNS4

FWD

Mon 04/18/2022 to Sun 05/15/2022 UPDATED by CE 04/07/2022

(Import)

0001 Continuous 2200

UPNY CONED

3800 MW

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

### HUDSONTP-W49TH\_ST\_345\_Y56

FWD

Mon 04/18/2022 to Fri 04/22/2022

(Import)

0600 Continuous 1900

SCH - PJM\_HTP

0 MW

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

# NYISO TRANSFER LIMITATIONS

Tuesday ,April 26, 2022 to Thursday ,October 26, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## SCH-NE-NYISO\_LIMIT\_900

FWD

Mon 04/18/2022 to Thu 04/21/2022

(Import)

0700 Continuous 2259

SCH - NE - NY

1100 MW

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 1400 MW

Work scheduled by: ISONE

## PANNELL -CLAY 345\_2

FWD

Mon 04/18/2022 to Fri 04/22/2022

(Import)

0700 Continuous 1530

WEST CENTRAL

1300 MW

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW

Work scheduled by: NYPA

## SCH-NE-NYISO\_LIMIT\_800

FWD

Mon 04/18/2022 to Fri 04/22/2022

(Import)

2300 Continuous 0659

SCH - NE - NY

1000 MW

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 1400 MW

Work scheduled by: ISONE

## SCH-NE-NYISO\_LIMIT\_300

FWD

Tue 04/19/2022 to Fri 04/22/2022

(Import)

0601 Continuous 0759

UPDATEDby ISONE 04/23/2022

SCH - NE - NY

500 MW

Impacts Total Transfer Capability 900 MW

TTC with All Lines In Service 1400 MW

Work scheduled by: ISONE

## SCH-NYISO-NE\_LIMIT\_1300

REV

Tue 04/19/2022 to Fri 04/22/2022

(Export)

0601 Continuous 0759

UPDATEDby ISONE 04/23/2022

SCH - NE - NY

1500 MW

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 1800 MW

Work scheduled by: ISONE

## SAND\_BAR-PLATSBURG\_115\_PV20

Tue 04/19/2022 to Tue 04/26/2022

UPDATEDby NYPA 04/13/2022

0700 Continuous 1730

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: NYPA

## PLSNTVLY\_345KV\_RN5 &amp; PLSNTVLY\_345KV\_RN4

FWD

Wed 04/20/2022 to Fri 04/22/2022

(Import)

0001 2200

UPNY CONED

3800 MW

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by:

# NYISO TRANSFER LIMITATIONS

Tuesday ,April 26, 2022 to Thursday ,October 26, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_200

FWD

Wed 04/20/2022 to Fri 04/22/2022 UPDATED by CONED 04/06/2022

(Import)

0001 Continuous 2200

Work scheduled by: ConEd

SCH - NE - NY

**400 MW**

Impacts Total Transfer Capability 1000 MW

TTC with All Lines In Service 1400 MW

### GOETHALS\_345KV\_5

Wed 04/20/2022 to Fri 05/20/2022

0301 Continuous 0300

Work scheduled by: ConEd

STATEN ISLAND

Impacts Total Transfer Capability

TTC with All Lines In Service

### LINDEN\_\_GOETHALS\_230\_A2253

Wed 04/20/2022 to Fri 05/20/2022

0301 Continuous 0300

Work scheduled by: ConEd

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

### LINDEN\_\_GOETHALS\_230\_A2253 & HUDSONP\_-FARRAGUT\_345\_B3402

FWD

REV

Wed 04/20/2022 to Fri 05/20/2022

0301 0300

Work scheduled by:

(Import) (Export)

SCH - PJ - NY

**2550 MW 1900 MW**

Impacts Total Transfer Capability 300 MW 300 MW

TTC with All Lines In Service 2850 MW 2200 MW

### LINDEN\_\_GOETHALS\_230\_A2253 & HUDSONP\_-FARRAGUT\_345\_B3402 & MARION\_\_-

FWD

REV

### FARRAGUT\_345\_C3403

(Import) (Export)

Wed 04/20/2022 to Fri 05/20/2022

0301 0300

Work scheduled by:

SCH - PJ - NY

**2550 MW 1900 MW**

Impacts Total Transfer Capability 300 MW 300 MW

TTC with All Lines In Service 2850 MW 2200 MW

### LINDEN\_\_GOETHALS\_230\_A2253 & MARION\_\_-FARRAGUT\_345\_C3403

FWD

REV

Wed 04/20/2022 to Fri 05/20/2022

0301 0300

Work scheduled by:

(Import) (Export)

SCH - PJ - NY

**2550 MW 1900 MW**

Impacts Total Transfer Capability 300 MW 300 MW

TTC with All Lines In Service 2850 MW 2200 MW

### RAMAPO\_\_LADENTWN\_345\_W72

FWD

Wed 04/20/2022 to Thu 04/21/2022

0743 Continuous 1500

Work scheduled by: ORU

EXTENDED by ORU 04/24/2022

UPNY CONED

**4400 MW**

Impacts Total Transfer Capability 3415 MW

TTC with All Lines In Service 7815 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,April 26, 2022 to Thursday ,October 26, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## SCH-NE-NYISO\_LIMIT\_900

Fri 04/22/2022 to Fri 04/22/2022  
0700 Continuous 1800  
Work scheduled by: ISONE

FWD  
(Import)  
SCH - NE - NY **1100 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 1400 MW

## EDIC -FRASER\_345\_EF24-40

Fri 04/22/2022 to Tue 06/14/2022 UPDATED by NJYPA 04/19/2022  
0700 Continuous 1530  
Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

## SCH-NE-NYISO\_LIMIT\_300

Fri 04/22/2022 to Sun 04/24/2022 UPDATED by ISONE 04/23/2022  
1601 Continuous 1800  
Work scheduled by: ISONE

FWD  
(Import)  
SCH - NE - NY **500 MW**  
Impacts Total Transfer Capability 900 MW  
TTC with All Lines In Service 1400 MW

## SCH-NYISO-NE\_LIMIT\_1300

Fri 04/22/2022 to Sun 04/24/2022 UPDATED by ISONE 04/23/2022  
1601 Continuous 1800  
Work scheduled by: ISONE

REV  
(Export)  
SCH - NE - NY **1500 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 1800 MW

## W49TH\_ST\_345KV\_7

Fri 04/22/2022 to Fri 04/22/2022  
1830 Continuous 1900  
Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJM\_HTP **300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

## CHAT\_DC\_GC1

Sat 04/23/2022 to Sat 04/23/2022  
0001 Continuous 0300  
Work scheduled by: HQ

FWD  
(Import)  
MOSES SOUTH **2850 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

## CHAT\_DC\_GC1

Sat 04/23/2022 to Sat 04/23/2022  
0001 Continuous 0300  
Work scheduled by: HQ

REV  
(Export)  
SCH - HQ - NY **500 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1000 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## CHAT\_DC\_GC1 & CHAT\_DC\_GC2

Sat 04/23/2022 to Sat 04/23/2022  
0001 0300

Work scheduled by:

FWD  
(Import)  
MOSES SOUTH **2550 MW**  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 3150 MW

## CHAT\_DC\_GC1 & CHAT\_DC\_GC2

Sat 04/23/2022 to Sat 04/23/2022  
0001 0300

Work scheduled by:

FWD REV  
(Import) (Export)  
SCH - HQ - NY **1370 MW 0 MW**  
Impacts Total Transfer Capability 130 MW 1000 MW  
TTC with All Lines In Service 1500 MW 1000 MW

## CHAT\_DC\_GC2

Sat 04/23/2022 to Sat 04/23/2022  
0001 Continuous 0300

Work scheduled by: HQ

FWD  
(Import)  
MOSES SOUTH **2850 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

## CHAT\_DC\_GC2

Sat 04/23/2022 to Sat 04/23/2022  
0001 Continuous 0300

Work scheduled by: HQ

REV  
(Export)  
SCH - HQ - NY **500 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1000 MW

## SCH-HQ-NYISO\_LIMIT\_1150

Sat 04/23/2022 to Sat 04/23/2022  
0001 Continuous 0300

Work scheduled by: HQ

FWD  
(Import)  
SCH - HQ - NY **1150 MW**  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 1500 MW

## MARCY\_\_\_345KV\_CSC

Sat 04/23/2022 to Sat 04/23/2022  
0500 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2925 MW**  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 2975 MW

## EDIC\_\_\_-N.SCTLND\_345\_14 & PORTER\_\_\_-ROTTRDAM\_230\_30

Sun 04/24/2022 to Mon 04/25/2022  
1800 0800

Work scheduled by:

FWD  
(Import)  
CENTRAL EAST - VC **1500 MW**  
Impacts Total Transfer Capability 1475 MW  
TTC with All Lines In Service 2975 MW



# NYISO TRANSFER LIMITATIONS

Tuesday ,April 26, 2022 to Thursday ,October 26, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## PORTER\_\_-ROTTRDAM\_230\_30

Sun 04/24/2022 to Mon 04/25/2022 UPDATED by NYISO 04/23/2022  
1800 Daily 0800

Work scheduled by: NGrid

FWD

(Import)

CENTRAL EAST - VC **2805 MW**  
Impacts Total Transfer Capability 170 MW  
TTC with All Lines In Service 2975 MW

## PORTER\_\_-ROTTRDAM\_230\_30 & PORTER\_\_-ROTTRDAM\_230\_31

Sun 04/24/2022 to Mon 04/25/2022  
1800 0800

Work scheduled by:

FWD

(Import)

CENTRAL EAST - VC **2635 MW**  
Impacts Total Transfer Capability 340 MW  
TTC with All Lines In Service 2975 MW

## SCH-NYISO-NE\_LIMIT\_100

Sun 04/24/2022 to Mon 04/25/2022 UPDATED by NYISO 04/23/2022  
1800 Daily 0800

Work scheduled by: NGrid

REV

(Export)

SCH - NE - NY **300 MW**  
Impacts Total Transfer Capability 1500 MW  
TTC with All Lines In Service 1800 MW

## BUCHAN\_N-EASTVIEW\_345\_W93

Mon 04/25/2022 to Mon 04/25/2022  
0001 Continuous 0030

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

## RAMAPO\_\_-BUCHAN\_N\_345\_Y94

Mon 04/25/2022 to Mon 04/25/2022  
0001 Continuous 0030

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED **7580 MW**  
Impacts Total Transfer Capability 235 MW  
TTC with All Lines In Service 7815 MW

## ROCHESTR-PANNELL\_\_345\_RP1

Mon 04/25/2022 to Fri 04/29/2022  
0500 Continuous 1700

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

## DYSINGER-STA\_255\_\_345\_DH1

Mon 04/25/2022 to Sat 04/30/2022 UPDATED by NYSEG 04/23/2022  
0600 Continuous 1800

Work scheduled by: NT

FWD

(Import)

DYSINGER EAST **2850 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,April 26, 2022 to Thursday ,October 26, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## NIAGARA\_-STA\_255\_\_345\_NH2 & DYSINGER-STA\_255\_\_345\_DH1

Mon 04/25/2022 to Sat 04/30/2022  
0600 1800

Work scheduled by:

FWD  
(Import)  
DYSINGER EAST **1250 MW**  
Impacts Total Transfer Capability 1900 MW  
TTC with All Lines In Service 3150 MW

## SCH-NE-NYISO\_LIMIT\_700

Tue 04/26/2022 to Sat 04/30/2022  
0801 Continuous 0800

Work scheduled by: ISONE

FWD  
(Import)  
SCH - NE - NY **900 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1400 MW

## SCH-NYISO-NE\_LIMIT\_1100

Tue 04/26/2022 to Sat 04/30/2022  
0801 Continuous 0800

Work scheduled by: ISONE

REV  
(Export)  
SCH - NE - NY **1300 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1800 MW

## SCH-NYISO-HQ\_LIMIT\_800

Wed 04/27/2022 to Thu 04/28/2022  
0500 Continuous 1900

Work scheduled by: HQ

REV  
(Export)  
SCH - HQ - NY **800 MW**  
Impacts Total Transfer Capability 200 MW  
TTC with All Lines In Service 1000 MW

## SCH-NYISO-NE\_LIMIT\_1200

Wed 04/27/2022 to Sat 04/30/2022  
0900 Continuous 2359

Work scheduled by: NGrid

**UPDATED by NGRID 04/01/2022**

REV  
(Export)  
SCH - NE - NY **1400 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 1800 MW

## ROTTRDAM-EASTOVER\_230\_38

Wed 04/27/2022 to Wed 05/04/2022  
0900 Continuous 1600

Work scheduled by: NGrid

**UPDATED by NGRID 04/01/2022**

**ARR: 77**

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

## SAND\_BAR-PLATSBRG\_115\_PV20

Thu 04/28/2022 to Sat 05/07/2022  
0700 Continuous 1730

Work scheduled by: NYPA

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

# NYISO TRANSFER LIMITATIONS

Tuesday ,April 26, 2022 to Thursday ,October 26, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## SCH-NYISO-NE\_LIMIT\_900

Thu 04/28/2022 to Sat 05/07/2022  
0700 Continuous 1730

Work scheduled by: NYPA

SCH - NE - NY  
Impacts Total Transfer Capability 700 MW  
TTC with All Lines In Service 1800 MW

## NIAGARA\_345\_230\_AT4

Fri 04/29/2022 to Fri 04/29/2022  
0500 Continuous 1700

Work scheduled by: NYPA

REV  
(Export)  
SCH - OH - NY  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 2000 MW

## SCH-IMO-NYISO\_LIMIT\_400

Sat 04/30/2022 to Sat 04/30/2022 UPDATED by NYISO 03/22/2022  
2300 Daily 2359

Work scheduled by: NYISO

FWD  
(Import)  
SCH - OH - NY  
Impacts Total Transfer Capability 1600 MW  
TTC with All Lines In Service 2300 MW

## BUCHAN\_N-EASTVIEW\_345\_W93

Mon 05/02/2022 to Mon 05/02/2022  
0130 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

## RAMAPO\_-BUCHAN\_N\_345\_Y94

Mon 05/02/2022 to Mon 05/02/2022  
0130 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED  
Impacts Total Transfer Capability 235 MW  
TTC with All Lines In Service 7815 MW

## SCH-HQ\_CEDARS-NYISO\_LIMIT\_220

Mon 05/02/2022 to Fri 05/20/2022  
0200 Continuous 0200

Work scheduled by: HQ

FWD  
(Import)  
SCH - HQ\_CEDARS  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 270 MW

## ROCHESTR-PANNELL\_345\_RP2

Mon 05/02/2022 to Fri 05/06/2022  
0500 Continuous 1700

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

**NYISO TRANSFER LIMITATIONS**

Tuesday ,April 26, 2022 to Thursday ,October 26, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**SCH-NYISO-NE\_LIMIT\_1000**

Mon 05/02/2022 to Fri 05/06/2022  
0800 Continuous 1800

Work scheduled by: ISONE

REV  
(Export)  
**1200 MW**  
SCH - NE - NY  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 1600 MW

**SCH-NYISO-NE\_LIMIT\_800**

Mon 05/02/2022 to Fri 05/06/2022  
2300 Daily(No Weekends) 0659

Work scheduled by: ISONE

REV  
(Export)  
**1000 MW**  
SCH - NE - NY  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 1600 MW

**BUCHAN\_N-EASTVIEW\_345\_W93**

Tue 05/03/2022 to Tue 05/03/2022  
0001 Continuous 0030

Work scheduled by: ConEd

FWD  
(Import)  
**4350 MW**  
UPNY CONED  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

**EASTVIEW-SPRNBK\_\_345\_W79**

Tue 05/03/2022 to Fri 05/06/2022  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
**4350 MW**  
UPNY CONED  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

**CHATGUAY-MASSENA\_\_765\_7040**

Tue 05/03/2022 to Fri 05/06/2022  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
**1550 MW**  
MOSES SOUTH  
Impacts Total Transfer Capability 1600 MW  
TTC with All Lines In Service 3150 MW

**CHATGUAY-MASSENA\_\_765\_7040**

Tue 05/03/2022 to Fri 05/06/2022  
0700 Continuous 1530

Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
**0 MW 0 MW**  
SCH - HQ - NY  
Impacts Total Transfer Capability 1500 MW 1000 MW  
TTC with All Lines In Service 1500 MW 1000 MW

**LEEDS\_\_345KV\_R395**

Tue 05/03/2022 to Tue 05/03/2022  
0830 Daily(No Weekends) 1100

Work scheduled by: NGrid

**UPDATED by NGRID 04/14/2022**

FWD  
(Import)  
**3800 MW**  
UPNY CONED  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,April 26, 2022 to Thursday ,October 26, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## BUCHAN\_N-EASTVIEW\_345\_W93

FWD

Fri 05/06/2022 to Fri 05/06/2022  
0130 Continuous 0200

(Import)

Work scheduled by: ConEd

UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

## SCH-NYISO-NE\_LIMIT\_800

REV

Fri 05/06/2022 to Fri 05/06/2022  
2300 Daily(No Weekends) 2359

(Export)

Work scheduled by: ISONE

SCH - NE - NY **1000 MW**  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 1600 MW

## PLSNTVLY\_345KV\_RN5 &amp; PLSNTVLY\_345KV\_RN4

FWD

Sat 05/07/2022 to Tue 05/10/2022  
0001 2200

(Import)

Work scheduled by:

UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

## SPRNBK\_-TREMONT\_345\_X28

FWD

Sun 05/08/2022 to Wed 05/11/2022  
0201 Continuous 0300

(Import)

Work scheduled by: ConEd

SPR/DUN-SOUTH **4200 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 4600 MW

## E13THSTA-FARRAGUT\_345\_46

FWD

Mon 05/09/2022 to Tue 05/24/2022  
0301 Continuous 0200

(Import)

Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

## SCH-NYISO-NE\_LIMIT\_1000

REV

Mon 05/09/2022 to Fri 05/13/2022  
0600 Continuous 1600

(Export)

Work scheduled by: ISONE

SCH - NE - NY **1200 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 1600 MW

## S.PERRY\_-MEYER\_230\_87 &amp; NIAGARA\_-STA\_255\_345\_NH2

FWD

Mon 05/09/2022 to Mon 05/09/2022  
0700 1400

(Import)

Work scheduled by:

DYSINGER EAST **1200 MW**  
Impacts Total Transfer Capability 1950 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,April 26, 2022 to Thursday ,October 26, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## WETHSRFD-S.PERRY\_\_230\_85 & NIAGARA\_\_STA\_255\_\_345\_NH2

Mon 05/09/2022 to Mon 05/09/2022  
0700 1400

Work scheduled by:

FWD  
(Import)  
DYSINGER EAST **1200 MW**  
Impacts Total Transfer Capability 1950 MW  
TTC with All Lines In Service 3150 MW

## FRASER\_\_345\_FRASER SVC

Mon 05/09/2022 to Fri 05/13/2022  
0800 Continuous 1700

Work scheduled by: NYSEG

FWD  
(Import)  
CENTRAL EAST - VC **2935 MW**  
Impacts Total Transfer Capability 40 MW  
TTC with All Lines In Service 2975 MW

## SCH-NYISO-NE\_LIMIT\_800

Mon 05/09/2022 to Fri 05/13/2022  
2300 Daily(No Weekends) 0659

Work scheduled by: ISONE

REV  
(Export)  
SCH - NE - NY **1000 MW**  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 1600 MW

## RAMAPO\_\_-LADENTWN\_345\_W72

Tue 05/10/2022 to Wed 05/11/2022  
0700 Continuous 1900

Work scheduled by: ORU

**UPDATED by CE 02/23/2022**

FWD  
(Import)  
UPNY CONED **4400 MW**  
Impacts Total Transfer Capability 3415 MW  
TTC with All Lines In Service 7815 MW

## PLSNTVLY-WOOD\_ST\_\_345\_F31

Wed 05/11/2022 to Fri 05/13/2022  
0001 Continuous 2200

Work scheduled by: ConEd

**UPDATED by CONED 04/07/2022**

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 3815 MW  
TTC with All Lines In Service 7815 MW

## PORTER\_\_-ROTTRDAM\_230\_30

Wed 05/11/2022 to Tue 12/31/2030  
0600 Continuous 2359

Work scheduled by: NGrid

**UPDATED by NGRID 03/09/2022**

FWD  
(Import)  
CENTRAL EAST - VC **2805 MW**  
Impacts Total Transfer Capability 170 MW  
TTC with All Lines In Service 2975 MW

## PORTER\_\_-ROTTRDAM\_230\_30 & PORTER\_\_-ROTTRDAM\_230\_31

Wed 05/11/2022 to Tue 12/31/2030  
0600 2359

Work scheduled by:

FWD  
(Import)  
CENTRAL EAST - VC **2635 MW**  
Impacts Total Transfer Capability 340 MW  
TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,April 26, 2022 to Thursday ,October 26, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## PLSNTVLE-DUNWODIE\_345\_W89

Fri 05/13/2022 to Fri 05/13/2022  
0200 Continuous 0230

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 3815 MW  
TTC with All Lines In Service 7815 MW

## EFISHKIL-WOOD\_ST\_\_345\_F38

Fri 05/13/2022 to Fri 05/13/2022  
0200 Continuous 0430

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 3815 MW  
TTC with All Lines In Service 7815 MW

## WOOD\_ST\_-PLSNTVLE\_345\_Y86

Fri 05/13/2022 to Fri 05/13/2022  
0200 Continuous 0430

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **7210 MW**  
Impacts Total Transfer Capability 605 MW  
TTC with All Lines In Service 7815 MW

## PLSNTVLE-DUNWODIE\_345\_W89

Fri 05/13/2022 to Fri 05/13/2022  
0400 Continuous 0430

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 3815 MW  
TTC with All Lines In Service 7815 MW

## SHOR\_NPX-SHOREHAM\_138\_CSC

Mon 05/16/2022 to Sat 05/21/2022 **UPDATED by LI 02/10/2022**  
0600 Continuous 2000

Work scheduled by: LI

FWD REV  
(Import) (Export)  
SCH - NPX\_CSC **0 MW 0 MW**  
Impacts Total Transfer Capability 330 MW 330 MW  
TTC with All Lines In Service 330 MW 330 MW

## HOMR\_NYW-PIERC\_NY\_345\_48

Mon 05/16/2022 to Fri 05/20/2022  
0800 Continuous 1500

Work scheduled by: PJM

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

## W49TH\_ST\_345KV\_6

Tue 05/17/2022 to Tue 05/17/2022 **UPDATED by CONED 04/26/2022**  
0001 Continuous 0130

Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJM\_HTP **300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**W49TH\_ST-E13THSTA\_345\_M55**

FWD

Tue 05/17/2022 to Mon 05/23/2022

UPDATEDby CONED 04/26/2022

(Import)

0001 Continuous 0300

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**HOPATCON-RAMAPO\_\_\_500\_5018**

FWD

REV

Wed 05/18/2022 to Sun 05/22/2022

(Import) (Export)

0200 Continuous 2300

SCH - PJ - NY

**1100 MW 1000 MW**

Impacts Total Transfer Capability 1150 MW 250 MW

TTC with All Lines In Service 2250 MW 1250 MW

Work scheduled by: PJM

**HOPATCON-RAMAPO\_\_\_500\_5018**

FWD

Wed 05/18/2022 to Sun 05/22/2022

(Import)

0200 Continuous 2300

UPNY CONED

**7480 MW**

Impacts Total Transfer Capability 335 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: PJM

**RAMAPO\_\_\_345\_345\_PAR3500**

FWD

Wed 05/18/2022 to Sun 05/22/2022

(Import)

0200 Continuous 2300

SCH - PJ - NY

**1750 MW**

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 2250 MW

Work scheduled by: PJM

**RAMAPO\_\_\_345\_345\_PAR4500**

FWD

Wed 05/18/2022 to Sun 05/22/2022

(Import)

0200 Continuous 2300

SCH - PJ - NY

**1750 MW**

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 2250 MW

Work scheduled by: PJM

**RAMAPO\_\_\_500\_345\_BK 1500**

FWD

REV

Wed 05/18/2022 to Sun 05/22/2022

(Import) (Export)

0200 Continuous 2300

SCH - PJ - NY

**1100 MW 1000 MW**

Impacts Total Transfer Capability 1150 MW 250 MW

TTC with All Lines In Service 2250 MW 1250 MW

Work scheduled by: PJM

**RAMAPO\_\_\_500\_345\_BK 1500**

FWD

Wed 05/18/2022 to Sun 05/22/2022

(Import)

0200 Continuous 2300

UPNY CONED

**7480 MW**

Impacts Total Transfer Capability 335 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: PJM



**NYISO TRANSFER LIMITATIONS**

Tuesday ,April 26, 2022 to Thursday ,October 26, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**DUNWODIE-MOTTHAVN\_345\_71**

FWD

Thu 05/19/2022 to Fri 05/20/2022

(Import)

0001 Continuous 0200

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**DUNWODIE\_345KV\_3**

FWD

Thu 05/19/2022 to Fri 05/20/2022

(Import)

0001 Continuous 0200

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**DUNWODIE\_345KV\_5**

FWD

Thu 05/19/2022 to Fri 05/20/2022

(Import)

0001 Continuous 0200

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**MOTTHAVN-RAINEY\_345\_Q11**

FWD

Sat 05/21/2022 to Tue 05/24/2022

(Import)

0001 Continuous 0200

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**MARCY\_-EDIC\_345\_UE1-7**

FWD

Sat 05/21/2022 to Sun 05/22/2022

(Import)

0500 Continuous 1730

**UPDATED by NYPA 04/07/2022**

OSWEGO EXPORT

**5250 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NYPA

**ARR: 19&16****PORTER\_-ROTTRDAM\_230\_30 & VOLNEY\_-MARCY\_345\_19**

FWD

Sat 05/21/2022 to Sun 05/22/2022

(Import)

0500 1730

CENTRAL EAST - VC

**2655 MW**

Impacts Total Transfer Capability 320 MW

TTC with All Lines In Service 2975 MW

Work scheduled by:

**PORTER\_-ROTTRDAM\_230\_31 & VOLNEY\_-MARCY\_345\_19**

FWD

Sat 05/21/2022 to Sun 05/22/2022

(Import)

0500 1730

CENTRAL EAST - VC

**2655 MW**

Impacts Total Transfer Capability 320 MW

TTC with All Lines In Service 2975 MW

Work scheduled by:

# NYISO TRANSFER LIMITATIONS

Tuesday ,April 26, 2022 to Thursday ,October 26, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## VOLNEY -MARCY 345\_19

Sat 05/21/2022 to Sun 05/22/2022  
0500 Continuous 1730

UPDATEDby NYPA04/07/2022

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
CENTRAL EAST - VC **2825 MW**  
Impacts Total Transfer Capability 150 MW  
TTC with All Lines In Service 2975 MW

## VOLNEY -MARCY 345\_19

Sat 05/21/2022 to Sun 05/22/2022  
0500 Continuous 1730

UPDATEDby NYPA04/07/2022

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
OSWEGO EXPORT **4900 MW**  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 5250 MW

## DUNWODIE-SHORE\_RD\_345\_Y50

Mon 05/23/2022 to Sun 05/29/2022  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
CONED - LIPA **800 MW**  
Impacts Total Transfer Capability 700 MW  
TTC with All Lines In Service 1500 MW

## DUNWODIE\_345KV\_4

Mon 05/23/2022 to Sun 05/29/2022  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

## DUNWODIE\_345KV\_6

Mon 05/23/2022 to Sun 05/29/2022  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

## SHORE\_RD\_345\_138\_BK 1

Mon 05/23/2022 to Sun 05/29/2022  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
CONED - LIPA **1350 MW**  
Impacts Total Transfer Capability 150 MW  
TTC with All Lines In Service 1500 MW

## SHORE\_RD\_345\_138\_BK 2

Mon 05/23/2022 to Sun 05/29/2022  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
CONED - LIPA **1350 MW**  
Impacts Total Transfer Capability 150 MW  
TTC with All Lines In Service 1500 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,April 26, 2022 to Thursday ,October 26, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## W49TH\_ST\_345KV\_6

FWD

Mon 05/23/2022 to Mon 05/23/2022 UPDATED by CONED 04/26/2022  
0230 Continuous 0300

(Import)

Work scheduled by: ConEd

SCH - PJM\_HTP

300 MW

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

## MOTTHAVN-RAINEY\_345\_Q12

FWD

Tue 05/24/2022 to Sat 05/28/2022  
0201 Continuous 0200

(Import)

Work scheduled by: ConEd

SPR/DUN-SOUTH

3800 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

## CRICKVLY-PLSNTVLY\_345\_F84

FWD

Wed 05/25/2022 to Sun 05/29/2022 UPDATED by CE 04/21/2022  
0001 Continuous 2200

(Import)

Work scheduled by: ConEd

SCH - NE - NY

350 MW

Impacts Total Transfer Capability 1050 MW

TTC with All Lines In Service 1400 MW

## CRICKVLY-PLSNTVLY\_345\_F84

FWD

REV

Wed 05/25/2022 to Sun 05/29/2022 UPDATED by CE 04/21/2022  
0001 Continuous 2200

(Import) (Export)

Work scheduled by: ConEd

SCH - NPX\_1385

100 MW 100 MW

Impacts Total Transfer Capability 100 MW 100 MW

TTC with All Lines In Service 200 MW 200 MW

## BUCHAN\_S-MILLWOOD\_345\_W97

FWD

Fri 05/27/2022 to Sat 05/28/2022  
0001 Continuous 0200

(Import)

Work scheduled by: ConEd

UPNY CONED

7680 MW

Impacts Total Transfer Capability 135 MW

TTC with All Lines In Service 7815 MW

## MARCY\_-EDIC\_345\_UE1-7

FWD

Sat 05/28/2022 to Sun 05/29/2022  
0600 Continuous 1830

(Import)

Work scheduled by: NYPA

ARR: 19&amp;16

OSWEGO EXPORT

5250 MW

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

## DUNWODIE\_345KV\_3

FWD

Sun 05/29/2022 to Sun 05/29/2022 UPDATED by CE 04/12/2022  
0201 Continuous 1800

(Import)

Work scheduled by: ConEd

SPR/DUN-SOUTH

3800 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,April 26, 2022 to Thursday ,October 26, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### DUNWODIE\_345KV\_4

FWD

Sun 05/29/2022 to Sun 05/29/2022 UPDATED by CE 04/12/2022

(Import)

0201 Continuous 1800

SPR/DUN-SOUTH **3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

### PLSNTVLE-DUNWODIE\_345\_W89

FWD

Sun 05/29/2022 to Sun 05/29/2022 UPDATED by CE 04/12/2022

(Import)

0201 Continuous 1800

UPNY CONED **4000 MW**

Impacts Total Transfer Capability 3815 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

### PIERCBRK-FIVEMILE\_345\_37

Tue 05/31/2022 to Wed 06/01/2022

0730 Continuous 1600

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: NGrid

### SCH-NE-NYISO\_LIMIT\_300

FWD

Wed 06/01/2022 to Wed 06/08/2022 UPDATED by ISONE 03/04/2022

(Import)

0700 Continuous 1600

SCH - NE - NY **500 MW**

Impacts Total Transfer Capability 900 MW

TTC with All Lines In Service 1400 MW

Work scheduled by: ISONE

### SCH-NYISO-NE\_LIMIT\_900

REV

Wed 06/01/2022 to Wed 06/08/2022 UPDATED by ISONE 03/04/2022

(Export)

0700 Continuous 1600

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: ISONE

**1100 MW**

500 MW

1600 MW

### MOSES -ADIRNDCK\_230\_MA2

FWD

Wed 06/01/2022 to Tue 11/29/2022

0700 Continuous 1800

MOSES SOUTH **2100 MW**

Impacts Total Transfer Capability 1050 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

### FROST\_BR-LONG\_MTN\_345\_352

FWD

Thu 06/09/2022 to Sat 06/18/2022 UPDATED by ISONE 03/04/2022

(Import)

0700 Continuous 1600

SCH - NE - NY

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 1400 MW

Work scheduled by: ISONE

**1150 MW**

# NYISO TRANSFER LIMITATIONS

Tuesday ,April 26, 2022 to Thursday ,October 26, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## SCH-NE-NYISO\_LIMIT\_200

FWD

Thu 06/09/2022 to Sat 06/18/2022 UPDATED by ISONE 03/04/2022

(Import)

0700 Continuous 1600

Work scheduled by: ISONE

SCH - NE - NY

**400 MW**

Impacts Total Transfer Capability 1000 MW

TTC with All Lines In Service 1400 MW

## NIAGARA\_-DYSINGER\_345\_ND1

FWD

Mon 06/13/2022 to Fri 06/17/2022

(Import)

0500 Continuous 2100

Work scheduled by: NYPA

DYSINGER EAST

**1400 MW**

Impacts Total Transfer Capability 1750 MW

TTC with All Lines In Service 3150 MW

## NIAGARA\_-DYSINGER\_345\_ND1

FWD

Mon 06/13/2022 to Fri 06/17/2022

(Import)

0500 Continuous 2100

Work scheduled by: NYPA

DYSINGER EAST

**2700 MW**

Impacts Total Transfer Capability 450 MW

TTC with All Lines In Service 3150 MW

## OAKDALE\_-FRASER\_\_\_345\_32

FWD

Wed 06/15/2022 to Fri 06/17/2022

(Import)

0800 Continuous 1600

Work scheduled by: NYSEG

CENTRAL EAST - VC

**2650 MW**

Impacts Total Transfer Capability 325 MW

TTC with All Lines In Service 2975 MW

## MARCY\_-EDIC\_\_\_345\_UE1-7

FWD

Sat 06/18/2022 to Sun 06/19/2022

(Import)

0600 Continuous 1830

Work scheduled by: NYPA

ARR: 19&amp;16

OSWEGO EXPORT

**5250 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

## NIAGARA\_-PACKARD\_\_\_230\_62

FWD

REV

Mon 06/20/2022 to Sun 06/26/2022 UPDATED by NYPA 04/19/2022

(Import) (Export)

0500 Continuous 1700

Work scheduled by: NYPA

SCH - OH - NY

**700 MW****1550 MW**

Impacts Total Transfer Capability 1250 MW 150 MW

TTC with All Lines In Service 1950 MW 1700 MW

## FRASER\_-GILBOA\_\_\_345\_GF5-35

FWD

Tue 06/21/2022 to Sun 06/26/2022

(Import)

0700 Continuous 1530

Work scheduled by: NYPA

CENTRAL EAST - VC

**2650 MW**

Impacts Total Transfer Capability 325 MW

TTC with All Lines In Service 2975 MW

CENTRAL EAST 3100MW  
CENTRAL EAST - VC 2975MW  
TOTAL EAST 6500MW  
UPNY CONED 7815MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3150MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**BEAR SWP-EASTOVER\_230\_E205W**

Mon 06/27/2022 to Tue 06/28/2022  
0700 Continuous 0759

Work scheduled by: ISONE

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

**NIAGARA\_345\_230\_AT4**

Tue 06/28/2022 to Wed 06/29/2022  
0500 Continuous 1700

Work scheduled by: NYPA

FWD REV  
(Import) (Export)

SCH - OH - NY

Impacts Total Transfer Capability 1900 MW 1400 MW

TTC with All Lines In Service 50 MW 300 MW

1950 MW 1700 MW

**BEAR SWP-EASTOVER\_230\_E205W**

Tue 06/28/2022 to Tue 06/28/2022  
0800 Daily(No Weekends) 1500

Work scheduled by: NGrid

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

**BEAR SWP-EASTOVER\_230\_E205W**

Tue 06/28/2022 to Thu 06/30/2022  
1501 Continuous 1700

Work scheduled by: ISONE

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

**BECK\_\_\_\_-NIAGARA\_230\_PA27**

Tue 07/05/2022 to Sat 07/09/2022  
0500 Continuous 2100

Work scheduled by: NYPA

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

**NIAGARA\_-DYSINGER\_345\_ND1**

Mon 07/11/2022 to Fri 07/15/2022  
0500 Continuous 1700

Work scheduled by: NYPA

FWD  
(Import)

DYSINGER EAST 1400 MW

Impacts Total Transfer Capability 1750 MW

TTC with All Lines In Service 3150 MW

**NIAGARA\_-DYSINGER\_345\_ND1**

Mon 07/11/2022 to Fri 07/15/2022  
0500 Continuous 1700

Work scheduled by: NYPA

FWD  
(Import)

DYSINGER EAST 2700 MW

Impacts Total Transfer Capability 450 MW

TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,April 26, 2022 to Thursday ,October 26, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**HURLYAVE-ROSETON\_\_345\_303**

FWD

Mon 07/11/2022 to Fri 07/22/2022

02/14/2022

(Import)

0800 Continuous 1600

Work scheduled by: CHGE

UPNY CONED

**4100 MW**

Impacts Total Transfer Capability 3715 MW

TTC with All Lines In Service 7815 MW

**ROCHESTR-PANNELL\_\_345\_RP1**

FWD

Mon 07/25/2022 to Fri 07/29/2022

(Import)

0500 Continuous 2100

Work scheduled by: NYPA

DYSINGER EAST

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

**FRASANNX-COOPERS\_\_345\_UCC2-41**

FWD

Mon 07/25/2022 to Fri 08/05/2022

(Import)

0700 Continuous 1700

Work scheduled by: NYPA

**ARR: 19**

CENTRAL EAST - VC

**2500 MW**

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

**MARCY\_\_-FRASANNX\_345\_UCC2-41**

FWD

Mon 07/25/2022 to Fri 08/05/2022

(Import)

0700 Continuous 1700

Work scheduled by: NYPA

**ARR: 19**

CENTRAL EAST - VC

**2500 MW**

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

**NIAGARA\_-DYSINGER\_345\_ND2**

FWD

Mon 08/01/2022 to Fri 08/05/2022

(Import)

0500 Continuous 1700

Work scheduled by: NYPA

DYSINGER EAST

**2700 MW**

Impacts Total Transfer Capability 450 MW

TTC with All Lines In Service 3150 MW

**MARCY\_\_-EDIC\_\_345\_UE1-7**

FWD

Sat 08/06/2022 to Sun 08/07/2022

UPDATEDby NYPA04/07/2022

(Import)

0500 Continuous 1830

Work scheduled by: NYPA

**ARR: 19&16**

OSWEGO EXPORT

**5250 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

**PORTER\_\_-ROTTRDAM\_230\_30 & VOLNEY\_\_-MARCY\_\_345\_19**

FWD

Sat 08/06/2022 to Sun 08/07/2022

(Import)

0500 1830

Work scheduled by:

CENTRAL EAST - VC

**2655 MW**

Impacts Total Transfer Capability 320 MW

TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,April 26, 2022 to Thursday ,October 26, 2023

CENTRAL EAST 3100MW  
 CENTRAL EAST - VC 2975MW  
 TOTAL EAST 6500MW  
 UPNY CONED 7815MW  
 SPR/DUN-SOUTH 4600MW  
 DYSINGER EAST 3150MW  
 MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PORTER\_\_-ROTTRDAM\_230\_31 &amp; VOLNEY\_\_-MARCY\_\_\_\_345\_19

Sat 08/06/2022 to Sun 08/07/2022  
 0500 1830

Work scheduled by:

FWD  
 (Import)  
 CENTRAL EAST - VC 2655 MW  
 Impacts Total Transfer Capability 320 MW  
 TTC with All Lines In Service 2975 MW

VOLNEY\_\_-MARCY\_\_\_\_345\_19

Sat 08/06/2022 to Sun 08/07/2022  
 0500 Continuous 1830

Work scheduled by: NYPA

UPDATED by NYPA 04/07/2022

ARR: 19

FWD  
 (Import)  
 CENTRAL EAST - VC 2825 MW  
 Impacts Total Transfer Capability 150 MW  
 TTC with All Lines In Service 2975 MW

VOLNEY\_\_-MARCY\_\_\_\_345\_19

Sat 08/06/2022 to Sun 08/07/2022  
 0500 Continuous 1830

Work scheduled by: NYPA

UPDATED by NYPA 04/07/2022

ARR: 19

FWD  
 (Import)  
 OSWEGO EXPORT 4900 MW  
 Impacts Total Transfer Capability 350 MW  
 TTC with All Lines In Service 5250 MW

FRASANNX-COOPERS\_\_345\_UCC2-41

Mon 08/08/2022 to Fri 09/09/2022  
 0700 Continuous 1700

Work scheduled by: NYPA

ARR: 19

FWD  
 (Import)  
 CENTRAL EAST - VC 2500 MW  
 Impacts Total Transfer Capability 475 MW  
 TTC with All Lines In Service 2975 MW

MARCY\_\_-FRASANNX\_345\_UCC2-41

Mon 08/08/2022 to Fri 09/09/2022  
 0700 Continuous 1700

Work scheduled by: NYPA

ARR: 19

FWD  
 (Import)  
 CENTRAL EAST - VC 2500 MW  
 Impacts Total Transfer Capability 475 MW  
 TTC with All Lines In Service 2975 MW

SAND\_BAR-PLATSBRG\_115\_PV20

Mon 08/22/2022 to Fri 08/26/2022  
 0700 Continuous 1530

Work scheduled by: NYPA

SCH - NE - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

ROSETON\_-ROCKTVRN\_345\_311

Mon 08/29/2022 to Fri 09/09/2022  
 0800 Continuous 1600

Work scheduled by: CHGE

FWD  
 (Import)  
 UPNY CONED 4400 MW  
 Impacts Total Transfer Capability 3415 MW  
 TTC with All Lines In Service 7815 MW



# NYISO TRANSFER LIMITATIONS

Tuesday ,April 26, 2022 to Thursday ,October 26, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MOTTHAVN-RAINEY\_\_\_345\_Q12**

FWD

Thu 09/01/2022 to Mon 09/05/2022

(Import)

0001 Continuous 0200

SPR/DUN-SOUTH

**3800 MW**

Work scheduled by: ConEd

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

**FRASER\_\_\_-GILBOA\_\_\_345\_GF5-35**

FWD

Mon 09/12/2022 to Sun 09/18/2022

(Import)

0700 Continuous 1530

CENTRAL EAST - VC

**2650 MW**

Work scheduled by: NYPA

Impacts Total Transfer Capability 325 MW

TTC with All Lines In Service 2975 MW

**MARCY\_\_\_-EDIC\_\_\_345\_UE1-7**

FWD

Mon 09/19/2022 to Sat 10/08/2022

(Import)

0700 Continuous 1530

OSWEGO EXPORT

**5250 MW**

Work scheduled by: NYPA

**ARR: 19&16**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

**LEEDS\_\_\_-HURLYAVE\_345\_301**

FWD

Mon 09/19/2022 to Fri 10/21/2022

10/04/2021

(Import)

0800 Continuous 1600

UPNY CONED

**4100 MW**

Work scheduled by: CHGE

Impacts Total Transfer Capability 3715 MW

TTC with All Lines In Service 7815 MW

**EGRDNCTY\_345\_138\_AT1**

FWD

Sat 10/01/2022 to Wed 05/31/2023

UPDATEDby CONED 03/10/2022

(Import)

0001 Continuous 2359

CONED - LIPA

**1250 MW**

Work scheduled by: LI

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 1500 MW

**EGRDNCTY\_345\_138\_AT2**

FWD

Sat 10/01/2022 to Wed 05/31/2023

UPDATEDby CONED 03/10/2022

(Import)

0001 Continuous 2359

CONED - LIPA

**1250 MW**

Work scheduled by: LI

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 1500 MW

**SPRNBK\_-EGRDNCTR\_345\_Y49**

FWD

Sat 10/01/2022 to Wed 05/31/2023

UPDATEDby CONED 03/10/2022

(Import)

0001 Continuous 2359

CONED - LIPA

**775 MW**

Work scheduled by: LI

Impacts Total Transfer Capability 725 MW

TTC with All Lines In Service 1500 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,April 26, 2022 to Thursday ,October 26, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## CLRKSCRN-OAKDALE\_\_345\_36

FWD

Mon 10/03/2022 to Fri 10/07/2022 UPDATED by NYSEG 04/20/2022

(Import)

0830 Continuous 1530

CENTRAL EAST - VC

**2650 MW**

Impacts Total Transfer Capability 325 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYSEG

## SHOR\_NPX-SHOREHAM\_138\_CSC

FWD

REV

Mon 10/03/2022 to Fri 10/21/2022 UPDATED by LI 01/07/2022

(Import) (Export)

1000 Continuous 1500

SCH - NPX\_CSC

**0 MW****0 MW**

Impacts Total Transfer Capability 330 MW 330 MW

TTC with All Lines In Service 330 MW 330 MW

Work scheduled by: LI

## EDIC\_\_-N.SCTLND\_345\_14

FWD

Mon 10/10/2022 to Mon 10/31/2022

(Import)

0700 Continuous 1530

CENTRAL EAST - VC

**1670 MW**

Impacts Total Transfer Capability 1305 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

## EDIC\_\_-N.SCTLND\_345\_14 & PORTER\_\_-ROTTRDAM\_230\_30

FWD

Mon 10/10/2022 to Mon 10/31/2022

(Import)

0700 1530

CENTRAL EAST - VC

**1500 MW**

Impacts Total Transfer Capability 1475 MW

TTC with All Lines In Service 2975 MW

Work scheduled by:

## EDIC\_\_-N.SCTLND\_345\_14 & PORTER\_\_-ROTTRDAM\_230\_31

FWD

Mon 10/10/2022 to Mon 10/31/2022

(Import)

0700 1530

CENTRAL EAST - VC

**1500 MW**

Impacts Total Transfer Capability 1475 MW

TTC with All Lines In Service 2975 MW

Work scheduled by:

## NIAGARA\_-DYSINGER\_345\_ND1

FWD

Mon 10/17/2022 to Fri 10/21/2022 UPDATED by NYPA 02/10/2022

(Import)

0500 Continuous 1700

DYSINGER EAST

**1400 MW**

Impacts Total Transfer Capability 1750 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

## NIAGARA\_-DYSINGER\_345\_ND1

FWD

Mon 10/17/2022 to Fri 10/21/2022 UPDATED by NYPA 02/10/2022

(Import)

0500 Continuous 1700

DYSINGER EAST

**2700 MW**

Impacts Total Transfer Capability 450 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

# NYISO TRANSFER LIMITATIONS

Tuesday ,April 26, 2022 to Thursday ,October 26, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## PANNELL\_-CLAY\_\_\_\_\_345\_1

Mon 10/24/2022 to Fri 10/28/2022  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

## HURLYAVE-ROSETON\_\_\_345\_303

Mon 10/24/2022 to Fri 11/04/2022  
0800 Continuous 1600

Work scheduled by: CHGE

UPDATED by CH 04/13/2022

FWD  
(Import)  
UPNY CONED **4100 MW**  
Impacts Total Transfer Capability 3715 MW  
TTC with All Lines In Service 7815 MW

## MAINESBG-WATRCURE\_345\_30

Tue 10/25/2022 to Tue 10/25/2022  
0800 Daily 1500

Work scheduled by: NYSEG

FWD  
(Import)  
SCH - PJ - NY **2200 MW**  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 2250 MW

## WATRCURE-OAKDALE\_\_\_345\_31

Thu 10/27/2022 to Thu 10/27/2022  
0800 Daily 1500

Work scheduled by: NYSEG

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

## PANNELL\_-CLAY\_\_\_\_\_345\_2

Mon 10/31/2022 to Fri 11/04/2022  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

## CLAY\_\_\_\_\_-EDIC\_\_\_\_\_345\_1-16

Tue 11/01/2022 to Thu 11/03/2022  
0600 Continuous 1900

Work scheduled by: NGrid

FWD  
(Import)  
OSWEGO EXPORT **4850 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

## GILBOA\_\_\_-N.SCTLND\_345\_GNS-1

Tue 11/01/2022 to Tue 12/06/2022  
0700 Continuous 1900

Work scheduled by: NGrid

UPDATED by NGRID 12/29/2021

FWD  
(Import)  
CENTRAL EAST - VC **2520 MW**  
Impacts Total Transfer Capability 455 MW  
TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,April 26, 2022 to Thursday ,October 26, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>LEEDS____345KV_R94301</b>					FWD	
Tue 11/01/2022	to	Tue 12/06/2022	<u>UPDATED</u>	<u>by NGRID</u> <u>12/29/2021</u>	(Import)	
0700	Continuous	1900			UPNY CONED	<b>3800 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability	4015 MW
					TTC with All Lines In Service	7815 MW
<b>MARCY____-N.SCTLND_345_18</b>					FWD	
Tue 11/01/2022	to	Tue 12/06/2022	<u>UPDATED</u>	<u>by NGRID</u> <u>12/29/2021</u>	(Import)	
0700	Continuous	1900			CENTRAL EAST - VC	<b>1470 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability	1505 MW
					TTC with All Lines In Service	2975 MW
<b>N.SCTLND-LEEDS____345_94</b>					FWD	
Tue 11/01/2022	to	Tue 12/06/2022	<u>UPDATED</u>	<u>by NGRID</u> <u>12/29/2021</u>	(Import)	
0700	Continuous	1900			CENTRAL EAST - VC	<b>2650 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability	325 MW
					TTC with All Lines In Service	2975 MW
<b>PORTER____-ROTTRDAM_230_30 &amp; MARCY____-N.SCTLND_345_18</b>					FWD	
Tue 11/01/2022	to	Tue 12/06/2022			(Import)	
0700		1900			CENTRAL EAST - VC	<b>1300 MW</b>
Work scheduled by:					Impacts Total Transfer Capability	1675 MW
					TTC with All Lines In Service	2975 MW
<b>PORTER____-ROTTRDAM_230_31 &amp; MARCY____-N.SCTLND_345_18</b>					FWD	
Tue 11/01/2022	to	Tue 12/06/2022			(Import)	
0700		1900			CENTRAL EAST - VC	<b>1300 MW</b>
Work scheduled by:					Impacts Total Transfer Capability	1675 MW
					TTC with All Lines In Service	2975 MW
<b>LINDN.CG-LNDVFT____345_V-3022</b>					FWD	REV
Tue 11/01/2022	to	Fri 11/04/2022			(Import)	(Export)
0800	Continuous	1500			SCH - PJM_VFT	<b>0 MW 0 MW</b>
Work scheduled by: PJM					Impacts Total Transfer Capability	315 MW 315 MW
					TTC with All Lines In Service	315 MW 315 MW
<b>LEEDS____-HURLYAVE_345_301</b>					FWD	
Mon 11/07/2022	to	Fri 12/09/2022			(Import)	
0800	Continuous	1600			UPNY CONED	<b>4100 MW</b>
Work scheduled by: CHGE					Impacts Total Transfer Capability	3715 MW
					TTC with All Lines In Service	7815 MW

**NYISO TRANSFER LIMITATIONS**

Tuesday ,April 26, 2022 to Thursday ,October 26, 2023

**CENTRAL EAST 3100MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6500MW**  
**UPNY CONED 7815MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3150MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MOSES\_\_\_-ADIRNDCK\_230\_MA1**

FWD

Wed 11/30/2022 to Wed 03/01/2023

(Import)

0700 Continuous 1100

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**CLAY\_\_\_-EDIC\_\_\_345\_1-16**

FWD

Fri 12/30/2022 to Sat 12/31/2022

(Import)

0600 Continuous 1900

OSWEGO EXPORT

**4850 MW**

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NGrid

**FRASER\_\_\_345\_FRASER SVC**

FWD

Tue 01/03/2023 to Tue 02/28/2023

(Import)

0700 Continuous 1730

**UPDATED****by NYPA****12/30/2021**

CENTRAL EAST - VC

**2935 MW**

Impacts Total Transfer Capability 40 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

**PLSNTVLY\_345KV\_RNS4**

FWD

Sat 04/01/2023 to Sat 04/01/2023

(Import)

0700 Continuous 0730

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: NGrid

**ATHENS\_\_\_-PLSNTVLY\_345\_91**

FWD

Sat 04/01/2023 to Sat 04/15/2023

(Import)

0700 Continuous 1900

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: NGrid

**PLSNTVLY\_345KV\_RNS4**

FWD

Sat 04/15/2023 to Sat 04/15/2023

(Import)

1830 Continuous 1900

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: NGrid

**PLSNTVLY\_345KV\_RNS5**

FWD

Sun 04/16/2023 to Sun 04/16/2023

(Import)

0700 Continuous 0730

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: NGrid

# NYISO TRANSFER LIMITATIONS

Tuesday ,April 26, 2022 to Thursday ,October 26, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### LEEDS\_\_\_-PLSNTVLY\_345\_92

FWD

Sun 04/16/2023 to Sun 04/30/2023

(Import)

0700 Continuous 1900

UPNY CONED

3800 MW

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: NGrid

### PLSNTVLY\_345KV\_RNS5

FWD

Sun 04/30/2023 to Sun 04/30/2023

(Import)

1830 Continuous 1900

UPNY CONED

3800 MW

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: NGrid

### SHOR\_NPX-SHOREHAM\_138\_CSC

FWD

REV

Mon 05/01/2023 to Fri 05/05/2023

(Import) (Export)

0600 Continuous 1800

SCH - NPX\_CSC

0 MW

0 MW

Impacts Total Transfer Capability 330 MW 330 MW

TTC with All Lines In Service 330 MW 330 MW

Work scheduled by: LI

### SHOR\_NPX-SHOREHAM\_138\_CSC

FWD

REV

Mon 10/02/2023 to Fri 10/06/2023

(Import) (Export)

0600 Continuous 1800

SCH - NPX\_CSC

0 MW

0 MW

Impacts Total Transfer Capability 330 MW 330 MW

TTC with All Lines In Service 330 MW 330 MW

Work scheduled by: LI

### NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE

FWD

Mon 10/09/2023 to Fri 10/13/2023

(Import)

0600 Continuous 1600

SCH - PJM\_NEPTUNE

0 MW

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

Work scheduled by: LI

### NEWBRDGE-DUFFYAVE\_345\_501

FWD

Mon 10/09/2023 to Fri 10/13/2023

(Import)

0600 Continuous 1600

SCH - PJM\_NEPTUNE

0 MW

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

Work scheduled by: LI

### NEWBRDGE\_345\_138\_BK\_1

FWD

Mon 10/09/2023 to Fri 10/13/2023

(Import)

0600 Continuous 1600

SCH - PJM\_NEPTUNE

375 MW

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 660 MW

Work scheduled by: LI

# NYISO TRANSFER LIMITATIONS

Tuesday ,April 26, 2022 to Thursday ,October 26, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEWBRIDGE\_345\_138\_BK\_2

FWD

Mon 10/09/2023 to Fri 10/13/2023

( Import )

0600 Continuous 1600

SCH - PJM\_NEPTUNE

**375 MW**

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 660 MW

Work scheduled by: LI