

# NYISO TRANSFER LIMITATIONS

Wednesday, April 27, 2022 to Friday ,October 27, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## HUDSONP\_-FARRAGUT\_345\_B3402

Mon 01/15/2018 to Sun 07/31/2022 EXT FORCE by CONED 01/04/2022

0001 Continuous 2359

Work scheduled by: ConEd

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

## HUDSONP\_-FARRAGUT\_345\_B3402 & MARION\_-FARRAGUT\_345\_C3403

Mon 01/15/2018 to Sun 07/31/2022

0001 2359

Work scheduled by:

FWD REV  
(Import) (Export)

SCH - PJ - NY

**2550 MW 1900 MW**

Impacts Total Transfer Capability 300 MW 300 MW

TTC with All Lines In Service 2850 MW 2200 MW

## MARION\_-FARRAGUT\_345\_C3403

Mon 01/15/2018 to Sun 07/31/2022 EXT FORCE by CONED 01/04/2022

0001 Continuous 2359

Work scheduled by: ConEd

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

## STLAWRNC-MOSES\_230\_L33P

Mon 04/30/2018 to Mon 07/25/2022 EXT FORCE by IESO 11/04/2021

0456 Continuous 0800

Work scheduled by: IESO

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

## NEWBRDGE\_345\_138\_BK\_1

Wed 09/02/2020 to Mon 08/01/2022 EXT FORCE by LI 12/10/2021

1807 Continuous 2359

Work scheduled by: LI

FWD  
(Import)

SCH - PJM\_NEPTUNE

**375 MW**

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 660 MW

## SCH-IMO-NYISO\_LIMIT\_1750

Mon 11/01/2021 to Sat 04/30/2022 UPDATED by IESO 05/03/2019

0001 Continuous 2359

Work scheduled by: IESO

FWD  
(Import)

SCH - OH - NY

**2050 MW**

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 2300 MW

## SCH-NYISO-IMO\_LIMIT\_1600

Mon 11/01/2021 to Sat 04/30/2022 UPDATED by IESO 05/03/2019

0001 Continuous 2359

Work scheduled by: IESO

REV  
(Export)

SCH - OH - NY

**1900 MW**

Impacts Total Transfer Capability 100 MW

TTC with All Lines In Service 2000 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, April 27, 2022 to Friday ,October 27, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## BECK\_\_\_\_-NIAGARA\_\_345\_PA301

Wed 02/09/2022 to Fri 06/17/2022  
0700 Continuous 1700

UPDATED by NYISO 03/22/2022

Work scheduled by: IESO

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	1100 MW	950 MW
Impacts Total Transfer Capability	1200 MW	1050 MW
TTC with All Lines In Service	2300 MW	2000 MW

## MOSES\_\_\_\_-ADIRNDCK\_230\_MAI

Mon 02/28/2022 to Tue 05/31/2022  
0700 Continuous 1300

UPDATED by NYPA 02/16/2022

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	2300 MW
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

## N.SCTLND-ALPS\_\_\_\_345\_2

Tue 03/08/2022 to Fri 06/24/2022  
0700 Continuous 1900

UPDATED by NGRID 03/09/2022

Work scheduled by: NGrid

	FWD
	(Import)
SCH - NE - NY	900 MW
Impacts Total Transfer Capability	500 MW
TTC with All Lines In Service	1400 MW

## N.SCTLND-ALPS\_\_\_\_345\_2

Tue 03/08/2022 to Fri 06/24/2022  
0700 Continuous 1900

UPDATED by NGRID 03/09/2022

Work scheduled by: NGrid

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	100 MW	100 MW
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

## EGRDNCTY\_345\_138\_AT1

Sat 03/12/2022 to Sun 05/15/2022  
2148 Continuous 2359

FORCED by CE 03/13/2022

Work scheduled by: ConEd

	FWD
	(Import)
CONED - LIPA	1250 MW
Impacts Total Transfer Capability	250 MW
TTC with All Lines In Service	1500 MW

## EGRDNCTY\_345\_138\_AT2

Sat 03/12/2022 to Sun 05/15/2022  
2148 Continuous 2359

FORCED by CE 03/13/2022

Work scheduled by: ConEd

	FWD
	(Import)
CONED - LIPA	1250 MW
Impacts Total Transfer Capability	250 MW
TTC with All Lines In Service	1500 MW

## SPRNBK\_-EGRDNCTR\_345\_Y49

Sat 03/12/2022 to Sun 05/15/2022  
2148 Continuous 2359

FORCED by CE 03/13/2022

Work scheduled by: ConEd

	FWD
	(Import)
CONED - LIPA	775 MW
Impacts Total Transfer Capability	725 MW
TTC with All Lines In Service	1500 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, April 27, 2022 to Friday ,October 27, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**W49TH\_ST\_345KV\_6**

FWD

Mon 03/21/2022 to Sat 04/30/2022 EXT FORCE by CE 04/04/2022

(Import)

0809 Continuous 2359

SCH - PJM\_HTP **310 MW**

Impacts Total Transfer Capability 350 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

**W49TH\_ST\_345KV\_8**

FWD

Mon 03/21/2022 to Sat 04/30/2022 EXT FORCE by CE 04/04/2022

(Import)

0811 Continuous 2359

SCH - PJM\_HTP **310 MW**

Impacts Total Transfer Capability 350 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

**SCH-IMO-NYISO\_LIMIT\_700**

FWD

Fri 03/25/2022 to Sat 04/30/2022 UPDATED by NYISO 03/22/2022

(Import)

0001 Continuous 2359

SCH - OH - NY **1000 MW**

Impacts Total Transfer Capability 1300 MW

TTC with All Lines In Service 2300 MW

Work scheduled by: IESO

**SCH-IMO-NYISO\_LIMIT\_400**

FWD

Fri 03/25/2022 to Sat 04/30/2022 UPDATED by NYISO 03/22/2022

(Import)

2300 Daily 0500

SCH - OH - NY **700 MW**

Impacts Total Transfer Capability 1600 MW

TTC with All Lines In Service 2300 MW

Work scheduled by: NYISO

**FIVEMILE-STOLLERD\_345\_29**Fri 04/01/2022 to Tue 12/31/2030 EXTENDED by NYSEG 04/06/2022

0500 Continuous 2359

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: NYSEG

**ATHENS\_\_-PLSNTVLY\_345\_91**

FWD

Mon 04/18/2022 to Sun 05/15/2022 UPDATED by CE 04/07/2022

(Import)

0001 Continuous 2200

UPNY CONED **3800 MW**

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

**PLSNTVLY\_345KV\_RNS4**

FWD

Mon 04/18/2022 to Sun 05/15/2022 UPDATED by CE 04/07/2022

(Import)

0001 Continuous 2200

UPNY CONED **3800 MW**

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

# NYISO TRANSFER LIMITATIONS

Wednesday, April 27, 2022 to Friday ,October 27, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## HUDSONTP-W49TH\_ST\_345\_Y56

Mon 04/18/2022 to Fri 04/22/2022  
0600 Continuous 1900

Work scheduled by: ConEd

FWD  
(Import)  
**0 MW**  
SCH - PJM\_HTP  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

## PANNELL -CLAY 345\_2

Mon 04/18/2022 to Fri 04/22/2022  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
**1300 MW**  
WEST CENTRAL  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

## SCH-NE-NYISO\_LIMIT\_800

Mon 04/18/2022 to Fri 04/22/2022  
2300 Continuous 0659

Work scheduled by: ISONE

FWD  
(Import)  
**1000 MW**  
SCH - NE - NY  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 1400 MW

## SCH-NE-NYISO\_LIMIT\_300

Tue 04/19/2022 to Fri 04/22/2022  
0601 Continuous 0759

Work scheduled by: ISONE

**UPDATED by ISONE 04/23/2022**

FWD  
(Import)  
**500 MW**  
SCH - NE - NY  
Impacts Total Transfer Capability 900 MW  
TTC with All Lines In Service 1400 MW

## SCH-NYISO-NE\_LIMIT\_1300

Tue 04/19/2022 to Fri 04/22/2022  
0601 Continuous 0759

Work scheduled by: ISONE

**UPDATED by ISONE 04/23/2022**

REV  
(Export)  
**1500 MW**  
SCH - NE - NY  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 1800 MW

## SAND\_BAR-PLATSBURG\_115\_PV20

Tue 04/19/2022 to Tue 04/26/2022  
0700 Continuous 1730

Work scheduled by: NYPA

**UPDATED by NYPA 04/13/2022**

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

## PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4

Wed 04/20/2022 to Fri 04/22/2022  
0001 2200

Work scheduled by:

FWD  
(Import)  
**3800 MW**  
UPNY CONED  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, April 27, 2022 to Friday ,October 27, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## SCH-NE-NYISO\_LIMIT\_200

FWD

Wed 04/20/2022 to Fri 04/22/2022 UPDATED by CONED 04/06/2022

(Import)

0001 Continuous 2200

Work scheduled by: ConEd

SCH - NE - NY

**400 MW**

Impacts Total Transfer Capability 1000 MW

TTC with All Lines In Service 1400 MW

## GOETHALS\_345KV\_5

Wed 04/20/2022 to Fri 05/20/2022

0301 Continuous 0300

Work scheduled by: ConEd

STATEN ISLAND

Impacts Total Transfer Capability

TTC with All Lines In Service

## LINDEN\_\_GOETHALS\_230\_A2253

Wed 04/20/2022 to Fri 05/20/2022

0301 Continuous 0300

Work scheduled by: ConEd

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

## LINDEN\_\_GOETHALS\_230\_A2253 &amp; HUDSONP\_-FARRAGUT\_345\_B3402

FWD

REV

Wed 04/20/2022 to Fri 05/20/2022

0301 0300

Work scheduled by:

(Import) (Export)

SCH - PJ - NY

**2550 MW 1900 MW**

Impacts Total Transfer Capability 300 MW 300 MW

TTC with All Lines In Service 2850 MW 2200 MW

## LINDEN\_\_GOETHALS\_230\_A2253 &amp; HUDSONP\_-FARRAGUT\_345\_B3402 &amp; MARION\_\_-FARRAGUT\_345\_C3403

FWD

REV

Wed 04/20/2022 to Fri 05/20/2022

0301 0300

Work scheduled by:

(Import) (Export)

SCH - PJ - NY

**2550 MW 1900 MW**

Impacts Total Transfer Capability 300 MW 300 MW

TTC with All Lines In Service 2850 MW 2200 MW

## LINDEN\_\_GOETHALS\_230\_A2253 &amp; MARION\_\_-FARRAGUT\_345\_C3403

FWD

REV

Wed 04/20/2022 to Fri 05/20/2022

0301 0300

Work scheduled by:

(Import) (Export)

SCH - PJ - NY

**2550 MW 1900 MW**

Impacts Total Transfer Capability 300 MW 300 MW

TTC with All Lines In Service 2850 MW 2200 MW

## SCH-NE-NYISO\_LIMIT\_900

FWD

Fri 04/22/2022 to Fri 04/22/2022

0700 Continuous 1800

Work scheduled by: ISONE

(Import)

SCH - NE - NY

**1100 MW**

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 1400 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, April 27, 2022 to Friday ,October 27, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**EDIC - FRASER 345 EF24-40**

FWD

Fri 04/22/2022 to Tue 06/14/2022 UPDATED by NJYPA 04/19/2022

(Import)

0700 Continuous 1530

Work scheduled by: NYPA

CENTRAL EAST - VC

**2275 MW**

Impacts Total Transfer Capability 310 MW

TTC with All Lines In Service 2585 MW

**SCH-NE-NYISO\_LIMIT\_300**

FWD

Fri 04/22/2022 to Sun 04/24/2022 UPDATED by ISONE 04/23/2022

(Import)

1601 Continuous 1800

Work scheduled by: ISONE

SCH - NE - NY

**500 MW**

Impacts Total Transfer Capability 900 MW

TTC with All Lines In Service 1400 MW

**SCH-NYISO-NE\_LIMIT\_1300**

REV

Fri 04/22/2022 to Sun 04/24/2022 UPDATED by ISONE 04/23/2022

(Export)

1601 Continuous 1800

Work scheduled by: ISONE

SCH - NE - NY

**1500 MW**

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 1800 MW

**W49TH\_ST\_345KV\_7**

FWD

Fri 04/22/2022 to Fri 04/22/2022

(Import)

1830 Continuous 1900

Work scheduled by: ConEd

SCH - PJM\_HTP

**300 MW**

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

**CHAT\_DC\_GC1**

FWD

Sat 04/23/2022 to Sat 04/23/2022

(Import)

0001 Continuous 0300

Work scheduled by: HQ

MOSES SOUTH

**2850 MW**

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 3150 MW

**CHAT\_DC\_GC1**

REV

Sat 04/23/2022 to Sat 04/23/2022

(Export)

0001 Continuous 0300

Work scheduled by: HQ

SCH - HQ - NY

**500 MW**

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 1000 MW

**CHAT\_DC\_GC1 & CHAT\_DC\_GC2**

FWD

Sat 04/23/2022 to Sat 04/23/2022

(Import)

0001 0300

Work scheduled by:

MOSES SOUTH

**2550 MW**

Impacts Total Transfer Capability 600 MW

TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, April 27, 2022 to Friday ,October 27, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## CHAT\_DC\_GC1 & CHAT\_DC\_GC2

Sat 04/23/2022 to Sat 04/23/2022  
0001 0300

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - HQ - NY	<b>1370 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	130 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

## CHAT\_DC\_GC2

Sat 04/23/2022 to Sat 04/23/2022  
0001 Continuous 0300

Work scheduled by: HQ

	FWD
	(Import)
MOSES SOUTH	<b>2850 MW</b>
Impacts Total Transfer Capability	300 MW
TTC with All Lines In Service	3150 MW

## CHAT\_DC\_GC2

Sat 04/23/2022 to Sat 04/23/2022  
0001 Continuous 0300

Work scheduled by: HQ

	REV
	(Export)
SCH - HQ - NY	<b>500 MW</b>
Impacts Total Transfer Capability	500 MW
TTC with All Lines In Service	1000 MW

## SCH-HQ-NYISO\_LIMIT\_1150

Sat 04/23/2022 to Sat 04/23/2022  
0001 Continuous 0300

Work scheduled by: HQ

	FWD
	(Import)
SCH - HQ - NY	<b>1150 MW</b>
Impacts Total Transfer Capability	350 MW
TTC with All Lines In Service	1500 MW

## MARCY\_\_\_\_345KV\_CSC

Sat 04/23/2022 to Sat 04/23/2022  
0500 Continuous 1730

Work scheduled by: NYPA

	FWD
	(Import)
CENTRAL EAST - VC	<b>2535 MW</b>
Impacts Total Transfer Capability	50 MW
TTC with All Lines In Service	2585 MW

## SCH-NYISO-NE\_LIMIT\_100

Sun 04/24/2022 to Mon 04/25/2022 **UPDATED by NYISO 04/23/2022**  
1800 Daily 0800

Work scheduled by: NGrid

	REV
	(Export)
SCH - NE - NY	<b>300 MW</b>
Impacts Total Transfer Capability	1500 MW
TTC with All Lines In Service	1800 MW

## BUCHAN\_N-EASTVIEW\_345\_W93

Mon 04/25/2022 to Mon 04/25/2022  
0001 Continuous 0030

Work scheduled by: ConEd

	FWD
	(Import)
UPNY CONED	<b>4350 MW</b>
Impacts Total Transfer Capability	3465 MW
TTC with All Lines In Service	7815 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, April 27, 2022 to Friday ,October 27, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**RAMAPO\_\_-BUCHAN\_N\_345\_Y94**

FWD

Mon 04/25/2022 to Mon 04/25/2022

(Import)

0001 Continuous 0030

UPNY CONED

**7580 MW**

Work scheduled by: ConEd

Impacts Total Transfer Capability 235 MW

TTC with All Lines In Service 7815 MW

**ROCHESTR-PANNELL\_\_345\_RP1**

FWD

Mon 04/25/2022 to Fri 04/29/2022

(Import)

0500 Continuous 1700

DYSINGER EAST

**2300 MW**

Work scheduled by: NYPA

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

**DYSINGER-STA\_255\_\_345\_DH1**

FWD

Mon 04/25/2022 to Sat 04/30/2022

(Import)

0600 Continuous 1800

UPDATEDby NYSEG 04/23/2022

DYSINGER EAST

**2850 MW**

Work scheduled by: NT

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 3150 MW

**SCH-NE-NYISO\_LIMIT\_700**

FWD

Tue 04/26/2022 to Sat 04/30/2022

(Import)

0801 Continuous 0800

SCH - NE - NY

**900 MW**

Work scheduled by: ISONE

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 1400 MW

**SCH-NYISO-NE\_LIMIT\_1100**

REV

Tue 04/26/2022 to Sat 04/30/2022

(Export)

0801 Continuous 0800

SCH - NE - NY

**1300 MW**

Work scheduled by: ISONE

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 1800 MW

**SCH-NYISO-HQ\_LIMIT\_800**

REV

Wed 04/27/2022 to Thu 04/28/2022

(Export)

0500 Continuous 1900

SCH - HQ - NY

**800 MW**

Work scheduled by: HQ

Impacts Total Transfer Capability 200 MW

TTC with All Lines In Service 1000 MW

**GORDONRD-N.SCTLND\_345\_55**

FWD

Wed 04/27/2022 to Wed 05/25/2022

(Import)

1122 Continuous 2359

CENTRAL EAST - VC

**2045 MW**

Work scheduled by: NYISO

Impacts Total Transfer Capability 540 MW

TTC with All Lines In Service 2585 MW



# NYISO TRANSFER LIMITATIONS

Wednesday, April 27, 2022 to Friday ,October 27, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## GORDONRD-ROTTRDAM\_230\_30

Wed 04/27/2022 to Wed 05/25/2022  
1122 Continuous 2359  
Work scheduled by: NYISO

FWD  
(Import)  
CENTRAL EAST - VC **2535 MW**  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 2585 MW

## EDIC\_\_\_\_-GORDONRD\_345\_14

Wed 04/27/2022 to Tue 05/10/2022  
1130 Continuous 1530  
Work scheduled by: NYISO

FWD  
(Import)  
CENTRAL EAST - VC **1695 MW**  
Impacts Total Transfer Capability 890 MW  
TTC with All Lines In Service 2585 MW

## EDIC\_\_\_\_-GORDONRD\_345\_14 & GORDONRD-ROTTRDAM\_230\_30

Wed 04/27/2022 to Tue 05/10/2022  
1130 1530  
Work scheduled by:

FWD  
(Import)  
CENTRAL EAST - VC **1645 MW**  
Impacts Total Transfer Capability 940 MW  
TTC with All Lines In Service 2585 MW

## EDIC\_\_\_\_-GORDONRD\_345\_14 & GORDONRD-ROTTRDAM\_230\_31

Wed 04/27/2022 to Tue 05/10/2022  
1130 1530  
Work scheduled by:

FWD  
(Import)  
CENTRAL EAST - VC **1645 MW**  
Impacts Total Transfer Capability 940 MW  
TTC with All Lines In Service 2585 MW

## GORDONRD-ROTTRDAM\_230\_30 & GORDONRD-ROTTRDAM\_230\_31

Wed 04/27/2022 to Tue 05/10/2022  
1130 1530  
Work scheduled by:

FWD  
(Import)  
CENTRAL EAST - VC **2485 MW**  
Impacts Total Transfer Capability 100 MW  
TTC with All Lines In Service 2585 MW

## GORDONRD-ROTTRDAM\_230\_31

Wed 04/27/2022 to Tue 05/10/2022  
1130 Continuous 1530  
Work scheduled by: NYISO

FWD  
(Import)  
CENTRAL EAST - VC **2535 MW**  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 2585 MW

## SAND\_BAR-PLATSBURG\_115\_PV20

Thu 04/28/2022 to Sat 05/07/2022  
0700 Continuous 1730  
Work scheduled by: NYPA

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

# NYISO TRANSFER LIMITATIONS

Wednesday, April 27, 2022 to Friday ,October 27, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SCH-NYISO-NE_LIMIT_900</b>					REV
Thu 04/28/2022	to	Sat 05/07/2022			(Export)
0700	Continuous	1730		SCH - NE - NY	<b>1100 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 700 MW
					TTC with All Lines In Service 1800 MW
<b>SCH-NYISO-NE_LIMIT_1200</b>					REV
Thu 04/28/2022	to	Sat 04/30/2022	<b>UPDATED</b>	<b>by NGRID 04/01/2022</b>	(Export)
0900	Continuous	2359			SCH - NE - NY <b>1400 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability 400 MW
					TTC with All Lines In Service 1800 MW
<b>ROTTRDAM-EASTOVER_230_38</b>					
Thu 04/28/2022	to	Wed 05/04/2022	<b>UPDATED</b>	<b>by NGRID 04/01/2022</b>	SCH - NE - NY
0900	Continuous	1600			Impacts Total Transfer Capability
Work scheduled by: NGrid					TTC with All Lines In Service
					<b>ARR: 77</b>
<b>NIAGARA_345_230_AT4</b>					REV
Fri 04/29/2022	to	Fri 04/29/2022			(Export)
0500	Continuous	1700		SCH - OH - NY	<b>1750 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability 250 MW
					TTC with All Lines In Service 2000 MW
<b>SCH-IMO-NYISO_LIMIT_400</b>					FWD
Sat 04/30/2022	to	Sat 04/30/2022	<b>UPDATED</b>	<b>by NYISO 03/22/2022</b>	(Import)
2300	Daily	2359			SCH - OH - NY <b>700 MW</b>
Work scheduled by: NYISO					Impacts Total Transfer Capability 1600 MW
					TTC with All Lines In Service 2300 MW
<b>CHAT_DC_GC2</b>					FWD
Sun 05/01/2022	to	Sat 06/04/2022			(Import)
0500	Continuous	2200		MOSES SOUTH	<b>2850 MW</b>
Work scheduled by: HQ					Impacts Total Transfer Capability 300 MW
					TTC with All Lines In Service 3150 MW
<b>CHAT_DC_GC2</b>					REV
Sun 05/01/2022	to	Sat 06/04/2022			(Export)
0500	Continuous	2200		SCH - HQ - NY	<b>500 MW</b>
Work scheduled by: HQ					Impacts Total Transfer Capability 500 MW
					TTC with All Lines In Service 1000 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, April 27, 2022 to Friday ,October 27, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## SCH-NYISO-HQ\_LIMIT\_500

Sun 05/01/2022 to Sat 06/04/2022  
0500 Continuous 2200  
Work scheduled by: HQ

SCH - HQ - NY  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1000 MW

REV  
(Export)

## BUCHAN\_N-EASTVIEW\_345\_W93

Mon 05/02/2022 to Mon 05/02/2022  
0130 Continuous 0200  
Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED 4350 MW  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

## RAMAPO\_\_-BUCHAN\_N\_345\_Y94

Mon 05/02/2022 to Mon 05/02/2022  
0130 Continuous 0200  
Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED 7580 MW  
Impacts Total Transfer Capability 235 MW  
TTC with All Lines In Service 7815 MW

## SCH-HQ\_CEDARS-NYISO\_LIMIT\_220

Mon 05/02/2022 to Fri 05/20/2022  
0200 Continuous 0200  
Work scheduled by: HQ

FWD  
(Import)  
SCH - HQ\_CEDARS 220 MW  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 270 MW

## ROCHESTR-PANNELL\_\_345\_RP2

Mon 05/02/2022 to Fri 05/06/2022  
0500 Continuous 1700  
Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST 2300 MW  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

## SCH-NYISO-NE\_LIMIT\_1000

Mon 05/02/2022 to Fri 05/06/2022  
0800 Continuous 1800  
Work scheduled by: ISONE

REV  
(Export)  
SCH - NE - NY 1200 MW  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 1600 MW

## SCH-NYISO-NE\_LIMIT\_800

Mon 05/02/2022 to Fri 05/06/2022  
2300 Daily(No Weekends) 0659  
Work scheduled by: ISONE

REV  
(Export)  
SCH - NE - NY 1000 MW  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 1600 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, April 27, 2022 to Friday ,October 27, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**BUCHAN\_N-EASTVIEW\_345\_W93**

Tue 05/03/2022 to Tue 05/03/2022  
0001 Continuous 0030  
Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

**EASTVIEW-SPRNBK\_345\_W79**

Tue 05/03/2022 to Fri 05/06/2022  
0001 Continuous 0200  
Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

**CHATGUAY-MASSENA\_765\_7040**

Tue 05/03/2022 to Fri 05/06/2022  
0700 Continuous 1530  
Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **1550 MW**  
Impacts Total Transfer Capability 1600 MW  
TTC with All Lines In Service 3150 MW

**CHATGUAY-MASSENA\_765\_7040**

Tue 05/03/2022 to Fri 05/06/2022  
0700 Continuous 1530  
Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - HQ - NY	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	1500 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

**LEEDS\_345KV\_R395**

Tue 05/03/2022 to Tue 05/03/2022 **UPDATED by NGRID 04/14/2022**  
0830 Daily(No Weekends) 1100  
Work scheduled by: NGrid

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

**CHAT\_DC\_GC1**

Wed 05/04/2022 to Fri 05/06/2022  
0500 Continuous 1500  
Work scheduled by: HQ

FWD  
(Import)  
MOSES SOUTH **2850 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

**CHAT\_DC\_GC1**

Wed 05/04/2022 to Fri 05/06/2022  
0500 Continuous 1500  
Work scheduled by: HQ

		REV
		(Export)
SCH - HQ - NY		<b>500 MW</b>
Impacts Total Transfer Capability		500 MW
TTC with All Lines In Service		1000 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## CHAT\_DC\_GC1 & CHAT\_DC\_GC2

Wed 05/04/2022 to Fri 05/06/2022  
0500 1500

Work scheduled by:

FWD  
(Import)  
MOSES SOUTH **2550 MW**  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 3150 MW

## CHAT\_DC\_GC1 & CHAT\_DC\_GC2

Wed 05/04/2022 to Fri 05/06/2022  
0500 1500

Work scheduled by:

FWD REV  
(Import) (Export)  
SCH - HQ - NY **1370 MW 0 MW**  
Impacts Total Transfer Capability 130 MW 1000 MW  
TTC with All Lines In Service 1500 MW 1000 MW

## BUCHAN\_N-EASTVIEW\_345\_W93

Fri 05/06/2022 to Fri 05/06/2022  
0130 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

## SCH-NYISO-NE\_LIMIT\_800

Fri 05/06/2022 to Fri 05/06/2022  
2300 Daily(No Weekends) 2359

Work scheduled by: ISONE

REV  
(Export)  
SCH - NE - NY **1000 MW**  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 1600 MW

## PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4

Sat 05/07/2022 to Tue 05/10/2022  
0001 2200

Work scheduled by:

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

## SPRNBK\_-TREMONT\_345\_X28

Sun 05/08/2022 to Wed 05/11/2022 **UPDATED by CONED 04/13/2022**  
0201 Continuous 0300

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **4200 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 4600 MW

## E13THSTA-FARRAGUT\_345\_46

Mon 05/09/2022 to Tue 05/24/2022 **UPDATED by CONED 04/26/2022**  
0301 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, April 27, 2022 to Friday ,October 27, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## SCH-NYISO-NE\_LIMIT\_1000

Mon 05/09/2022 to Fri 05/13/2022  
0600 Continuous 1600

Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 1600 MW

REV  
(Export)

## FRASER\_345\_FRASER SVC

Mon 05/09/2022 to Fri 05/13/2022  
0800 Continuous 1700

Work scheduled by: NYSEG

FWD  
(Import)  
CENTRAL EAST - VC 2550 MW  
Impacts Total Transfer Capability 35 MW  
TTC with All Lines In Service 2585 MW

## SCH-NYISO-NE\_LIMIT\_800

Mon 05/09/2022 to Fri 05/13/2022  
2300 Daily(No Weekends) 0659

Work scheduled by: ISONE

REV  
(Export)  
SCH - NE - NY 1000 MW  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 1600 MW

## RAMAPO\_-LADENTWN\_345\_W72

Tue 05/10/2022 to Wed 05/11/2022  
0700 Continuous 1900

Work scheduled by: ORU

UPDATED by CE 02/23/2022

FWD  
(Import)  
UPNY CONED 4400 MW  
Impacts Total Transfer Capability 3415 MW  
TTC with All Lines In Service 7815 MW

## PLSNTVLY-WOOD\_ST\_345\_F31

Wed 05/11/2022 to Fri 05/13/2022  
0001 Continuous 2200

Work scheduled by: ConEd

UPDATED by CONED 04/07/2022

FWD  
(Import)  
UPNY CONED 4000 MW  
Impacts Total Transfer Capability 3815 MW  
TTC with All Lines In Service 7815 MW

## PLSNTVLE-DUNWODIE\_345\_W89

Fri 05/13/2022 to Fri 05/13/2022  
0200 Continuous 0230

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED 4000 MW  
Impacts Total Transfer Capability 3815 MW  
TTC with All Lines In Service 7815 MW

## EFISHKIL-WOOD\_ST\_345\_F38

Fri 05/13/2022 to Fri 05/13/2022  
0200 Continuous 0430

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED 4000 MW  
Impacts Total Transfer Capability 3815 MW  
TTC with All Lines In Service 7815 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, April 27, 2022 to Friday ,October 27, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## WOOD\_ST\_-PLSNTVLE\_345\_Y86

Fri 05/13/2022 to Fri 05/13/2022  
0200 Continuous 0430

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **7210 MW**  
Impacts Total Transfer Capability 605 MW  
TTC with All Lines In Service 7815 MW

## PLSNTVLE-DUNWODIE\_345\_W89

Fri 05/13/2022 to Fri 05/13/2022  
0400 Continuous 0430

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 3815 MW  
TTC with All Lines In Service 7815 MW

## SHOR\_NPX-SHOREHAM\_138\_CSC

Mon 05/16/2022 to Sat 05/21/2022 UPDATED by LI 02/10/2022  
0600 Continuous 2000

Work scheduled by: LI

FWD REV  
(Import) (Export)  
SCH - NPX\_CSC **0 MW 0 MW**  
Impacts Total Transfer Capability 330 MW 330 MW  
TTC with All Lines In Service 330 MW 330 MW

## HOMR\_NYW-PIERC\_NY\_345\_48

Mon 05/16/2022 to Fri 05/20/2022  
0800 Continuous 1500

Work scheduled by: PJM

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

## W49TH\_ST\_345KV\_6

Tue 05/17/2022 to Tue 05/17/2022 UPDATED by CONED 04/26/2022  
0001 Continuous 0130

Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJM\_HTP **300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

## W49TH\_ST-E13THSTA\_345\_M55

Tue 05/17/2022 to Mon 05/23/2022 UPDATED by CONED 04/26/2022  
0001 Continuous 0300

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

## HOPATCON-RAMAPO\_\_\_500\_5018

Wed 05/18/2022 to Sun 05/22/2022  
0200 Continuous 2300

Work scheduled by: PJM

FWD REV  
(Import) (Export)  
SCH - PJ - NY **1100 MW 1000 MW**  
Impacts Total Transfer Capability 1150 MW 250 MW  
TTC with All Lines In Service 2250 MW 1250 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, April 27, 2022 to Friday ,October 27, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### HOPATCON-RAMAPO\_\_\_500\_5018

Wed 05/18/2022 to Sun 05/22/2022

0200 Continuous 2300

Work scheduled by: PJM

FWD  
(Import)  
TOTAL EAST **5200 MW**  
Impacts Total Transfer Capability 1300 MW  
TTC with All Lines In Service 6500 MW

### HOPATCON-RAMAPO\_\_\_500\_5018

Wed 05/18/2022 to Sun 05/22/2022

0200 Continuous 2300

Work scheduled by: PJM

FWD  
(Import)  
UPNY CONED **7480 MW**  
Impacts Total Transfer Capability 335 MW  
TTC with All Lines In Service 7815 MW

### RAMAPO\_\_\_345\_345\_PAR3500

Wed 05/18/2022 to Sun 05/22/2022

0200 Continuous 2300

Work scheduled by: PJM

FWD  
(Import)  
SCH - PJ - NY **1750 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 2250 MW

### RAMAPO\_\_\_345\_345\_PAR4500

Wed 05/18/2022 to Sun 05/22/2022

0200 Continuous 2300

Work scheduled by: PJM

FWD  
(Import)  
SCH - PJ - NY **1750 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 2250 MW

### RAMAPO\_\_\_500\_345\_BK 1500

Wed 05/18/2022 to Sun 05/22/2022

0200 Continuous 2300

Work scheduled by: PJM

FWD REV  
(Import) (Export)  
SCH - PJ - NY **1100 MW 1000 MW**  
Impacts Total Transfer Capability 1150 MW 250 MW  
TTC with All Lines In Service 2250 MW 1250 MW

### RAMAPO\_\_\_500\_345\_BK 1500

Wed 05/18/2022 to Sun 05/22/2022

0200 Continuous 2300

Work scheduled by: PJM

FWD  
(Import)  
UPNY CONED **7480 MW**  
Impacts Total Transfer Capability 335 MW  
TTC with All Lines In Service 7815 MW

### DUNWODIE-MOTTHAVN\_345\_71

Thu 05/19/2022 to Fri 05/20/2022

0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW



# NYISO TRANSFER LIMITATIONS

Wednesday, April 27, 2022 to Friday ,October 27, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**DUNWODIE\_345KV\_3**

FWD

Thu 05/19/2022 to Fri 05/20/2022

(Import)

0001 Continuous 0200

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**DUNWODIE\_345KV\_5**

FWD

Thu 05/19/2022 to Fri 05/20/2022

(Import)

0001 Continuous 0200

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**MOTTHAVN-RAINEY\_\_\_345\_Q11**

FWD

Sat 05/21/2022 to Tue 05/24/2022

(Import)

0001 Continuous 0200

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**MARCY\_\_\_-EDIC\_\_\_345\_UE1-7**

FWD

Sat 05/21/2022 to Sun 05/22/2022

(Import)

0500 Continuous 1730

**UPDATED****by NYPA 04/07/2022**

OSWEGO EXPORT

**5250 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NYPA

**ARR: 19&16****VOLNEY\_\_\_-MARCY\_\_\_345\_19**

FWD

Sat 05/21/2022 to Sun 05/22/2022

(Import)

0500 Continuous 1730

**UPDATED****by NYPA 04/07/2022**

CENTRAL EAST - VC

**2475 MW**

Impacts Total Transfer Capability 110 MW

TTC with All Lines In Service 2585 MW

Work scheduled by: NYPA

**ARR: 19****VOLNEY\_\_\_-MARCY\_\_\_345\_19**

FWD

Sat 05/21/2022 to Sun 05/22/2022

(Import)

0500 Continuous 1730

**UPDATED****by NYPA 04/07/2022**

OSWEGO EXPORT

**4900 MW**

Impacts Total Transfer Capability 350 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NYPA

**ARR: 19****VOLNEY\_\_\_-MARCY\_\_\_345\_19 & GORDONRD-ROTTRDAM\_230\_30**

FWD

Sat 05/21/2022 to Sun 05/22/2022

(Import)

0500 1730

CENTRAL EAST - VC

**2425 MW**

Impacts Total Transfer Capability 160 MW

TTC with All Lines In Service 2585 MW

Work scheduled by:

**ARR: 19**

# NYISO TRANSFER LIMITATIONS

Wednesday, April 27, 2022 to Friday ,October 27, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**DUNWODIE-SHORE\_RD\_345\_Y50**

FWD

Mon 05/23/2022 to Sun 05/29/2022

(Import)

0001 Continuous 0200

CONED - LIPA

**800 MW**

Impacts Total Transfer Capability 700 MW

Work scheduled by: ConEd

TTC with All Lines In Service 1500 MW

**DUNWODIE\_345KV\_4**

FWD

Mon 05/23/2022 to Sun 05/29/2022

(Import)

0001 Continuous 0200

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

Work scheduled by: ConEd

TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_6**

FWD

Mon 05/23/2022 to Sun 05/29/2022

(Import)

0001 Continuous 0200

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

Work scheduled by: ConEd

TTC with All Lines In Service 4600 MW

**SHORE\_RD\_345\_138\_BK 1**

FWD

Mon 05/23/2022 to Sun 05/29/2022

(Import)

0001 Continuous 0200

CONED - LIPA

**1350 MW**

Impacts Total Transfer Capability 150 MW

Work scheduled by: ConEd

TTC with All Lines In Service 1500 MW

**SHORE\_RD\_345\_138\_BK 2**

FWD

Mon 05/23/2022 to Sun 05/29/2022

(Import)

0001 Continuous 0200

CONED - LIPA

**1350 MW**

Impacts Total Transfer Capability 150 MW

Work scheduled by: ConEd

TTC with All Lines In Service 1500 MW

**W49TH\_ST\_345KV\_6**

FWD

Mon 05/23/2022 to Mon 05/23/2022

(Import)

0230 Continuous 0300

**UPDATED by CONED 04/26/2022**

SCH - PJM\_HTP

**300 MW**

Impacts Total Transfer Capability 360 MW

Work scheduled by: ConEd

TTC with All Lines In Service 660 MW

**MOTTHAVN-RAINEY\_\_\_345\_Q12**

FWD

Tue 05/24/2022 to Sat 05/28/2022

(Import)

0201 Continuous 0200

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

Work scheduled by: ConEd

TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, April 27, 2022 to Friday ,October 27, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>CRICKVLY-PLSNTVLY_345_F84</b>						FWD	
Wed 05/25/2022	to	Sun 05/29/2022	<u>UPDATED</u>	<u>by CE</u>	<u>04/21/2022</u>	(Import)	
0001	Continuous	2200				350 MW	
Work scheduled by: ConEd						Impacts Total Transfer Capability	1050 MW
						TTC with All Lines In Service	1400 MW
<b>CRICKVLY-PLSNTVLY_345_F84</b>						FWD	REV
Wed 05/25/2022	to	Sun 05/29/2022	<u>UPDATED</u>	<u>by CE</u>	<u>04/21/2022</u>	(Import)	(Export)
0001	Continuous	2200				100 MW	100 MW
Work scheduled by: ConEd						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	200 MW
<b>BUCHAN_S-MILLWOOD_345_W97</b>						FWD	
Fri 05/27/2022	to	Sat 05/28/2022				(Import)	
0001	Continuous	0200				7680 MW	
Work scheduled by: ConEd						Impacts Total Transfer Capability	135 MW
						TTC with All Lines In Service	7815 MW
<b>MARCY__-EDIC____345_UE1-7</b>						FWD	
Sat 05/28/2022	to	Sun 05/29/2022				(Import)	
0600	Continuous	1830				5250 MW	
Work scheduled by: NYPA						Impacts Total Transfer Capability	0 MW
						TTC with All Lines In Service	5250 MW
<b>DUNWODIE_345KV_3</b>						FWD	
Sun 05/29/2022	to	Sun 05/29/2022	<u>UPDATED</u>	<u>by CE</u>	<u>04/12/2022</u>	(Import)	
0201	Continuous	1800				3800 MW	
Work scheduled by: ConEd						Impacts Total Transfer Capability	800 MW
						TTC with All Lines In Service	4600 MW
<b>DUNWODIE_345KV_4</b>						FWD	
Sun 05/29/2022	to	Sun 05/29/2022	<u>UPDATED</u>	<u>by CE</u>	<u>04/12/2022</u>	(Import)	
0201	Continuous	1800				3800 MW	
Work scheduled by: ConEd						Impacts Total Transfer Capability	800 MW
						TTC with All Lines In Service	4600 MW
<b>PLSNTVLE-DUNWODIE_345_W89</b>						FWD	
Sun 05/29/2022	to	Sun 05/29/2022	<u>UPDATED</u>	<u>by CE</u>	<u>04/12/2022</u>	(Import)	
0201	Continuous	1800				4000 MW	
Work scheduled by: ConEd						Impacts Total Transfer Capability	3815 MW
						TTC with All Lines In Service	7815 MW

ARR: 19&16

# NYISO TRANSFER LIMITATIONS

Wednesday, April 27, 2022 to Friday ,October 27, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### PIERCBRK-FIVEMILE\_345\_37

Tue 05/31/2022 to Wed 06/01/2022

0730 Continuous 1600

Work scheduled by: NGrid

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

### SCH-NE-NYISO\_LIMIT\_300

Wed 06/01/2022 to Wed 06/08/2022

0700 Continuous 1600

Work scheduled by: ISONE

UPDATED

by ISONE 03/04/2022

SCH - NE - NY

Impacts Total Transfer Capability 900 MW

TTC with All Lines In Service 1400 MW

FWD

(Import)

**500 MW**

### SCH-NYISO-NE\_LIMIT\_900

Wed 06/01/2022 to Wed 06/08/2022

0700 Continuous 1600

Work scheduled by: ISONE

UPDATED

by ISONE 03/04/2022

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

REV

(Export)

**1100 MW**

500 MW

1600 MW

### MOSES\_-ADIRNDCK\_230\_MA2

Wed 06/01/2022 to Tue 11/29/2022

0700 Continuous 1800

Work scheduled by: NYPA

MOSES SOUTH

Impacts Total Transfer Capability 1050 MW

TTC with All Lines In Service 3150 MW

FWD

(Import)

**2100 MW**

### FROST\_BR-LONG\_MTN\_345\_352

Thu 06/09/2022 to Sat 06/18/2022

0700 Continuous 1600

Work scheduled by: ISONE

UPDATED

by ISONE 03/04/2022

SCH - NE - NY

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 1400 MW

FWD

(Import)

**1150 MW**

### SCH-NE-NYISO\_LIMIT\_200

Thu 06/09/2022 to Sat 06/18/2022

0700 Continuous 1600

Work scheduled by: ISONE

UPDATED

by ISONE 03/04/2022

SCH - NE - NY

Impacts Total Transfer Capability 1000 MW

TTC with All Lines In Service 1400 MW

FWD

(Import)

**400 MW**

### NIAGARA\_-DYSINGER\_345\_ND1

Mon 06/13/2022 to Fri 06/17/2022

0500 Continuous 2100

Work scheduled by: NYPA

DYSINGER EAST

Impacts Total Transfer Capability 450 MW

TTC with All Lines In Service 3150 MW

FWD

(Import)

**2700 MW**

# NYISO TRANSFER LIMITATIONS

Wednesday, April 27, 2022 to Friday ,October 27, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## OAKDALE\_-FRASER\_\_\_345\_32

Wed 06/15/2022 to Fri 06/17/2022  
0800 Continuous 1600

Work scheduled by: NYSEG

FWD

(Import)

CENTRAL EAST - VC **2450 MW**

Impacts Total Transfer Capability 135 MW

TTC with All Lines In Service 2585 MW

## MARCY\_-EDIC\_\_\_345\_UE1-7

Sat 06/18/2022 to Sun 06/19/2022  
0600 Continuous 1830

Work scheduled by: NYPA

ARR: 19&amp;16

FWD

(Import)

OSWEGO EXPORT **5250 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

## NIAGARA\_-PACKARD\_\_\_230\_62

Mon 06/20/2022 to Sun 06/26/2022  
0500 Continuous 1700

Work scheduled by: NYPA

UPDATED by NYPA 04/19/2022

FWD

(Import) (Export)

SCH - OH - NY **700 MW 1550 MW**

Impacts Total Transfer Capability 1250 MW 150 MW

TTC with All Lines In Service 1950 MW 1700 MW

## FRASER\_-GILBOA\_\_\_345\_GF5-35

Tue 06/21/2022 to Sun 06/26/2022  
0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

CENTRAL EAST - VC **2450 MW**

Impacts Total Transfer Capability 135 MW

TTC with All Lines In Service 2585 MW

## BEAR SWP-EASTOVER\_230\_E205W

Mon 06/27/2022 to Tue 06/28/2022  
0700 Continuous 0759

Work scheduled by: ISONE

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

## NIAGARA\_\_\_345\_230\_AT4

Tue 06/28/2022 to Wed 06/29/2022  
0500 Continuous 1700

Work scheduled by: NYPA

FWD

(Import) (Export)

SCH - OH - NY **1900 MW 1400 MW**

Impacts Total Transfer Capability 50 MW 300 MW

TTC with All Lines In Service 1950 MW 1700 MW

## BEAR SWP-EASTOVER\_230\_E205W

Tue 06/28/2022 to Tue 06/28/2022  
0800 Daily(No Weekends) 1500

Work scheduled by: NGrid

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

# NYISO TRANSFER LIMITATIONS

Wednesday, April 27, 2022 to Friday ,October 27, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## BEAR SWP-EASTOVER\_230\_E205W

Tue 06/28/2022 to Thu 06/30/2022

1501 Continuous 1700

Work scheduled by: ISONE

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

## BECK\_\_\_\_-NIAGARA\_230\_PA27

Tue 07/05/2022 to Sat 07/09/2022

0500 Continuous 2100

Work scheduled by: NYPA

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

## NIAGARA\_-DYSINGER\_345\_ND1

Mon 07/11/2022 to Fri 07/15/2022

0500 Continuous 1700

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST

**2700 MW**

Impacts Total Transfer Capability 450 MW

TTC with All Lines In Service 3150 MW

## HURLYAVE-ROSETON\_\_345\_303

Mon 07/11/2022 to Fri 07/22/2022

0800 Continuous 1600

Work scheduled by: CHGE

02/14/2022

FWD

(Import)

UPNY CONED

**4100 MW**

Impacts Total Transfer Capability 3715 MW

TTC with All Lines In Service 7815 MW

## ROCHESTR-PANNELL\_\_345\_RP1

Mon 07/25/2022 to Fri 07/29/2022

0500 Continuous 2100

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

## FRASANNX-COOPERS\_\_345\_UCC2-41

Mon 07/25/2022 to Fri 08/05/2022

0700 Continuous 1700

Work scheduled by: NYPA

**ARR: 19**

FWD

(Import)

CENTRAL EAST - VC

**2275 MW**

Impacts Total Transfer Capability 310 MW

TTC with All Lines In Service 2585 MW

## MARCY\_\_\_\_-FRASANNX\_345\_UCC2-41

Mon 07/25/2022 to Fri 08/05/2022

0700 Continuous 1700

Work scheduled by: NYPA

**ARR: 19**

FWD

(Import)

CENTRAL EAST - VC

**2275 MW**

Impacts Total Transfer Capability 310 MW

TTC with All Lines In Service 2585 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, April 27, 2022 to Friday ,October 27, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## NIAGARA\_-DYSINGER\_345\_ND2

Mon 08/01/2022 to Fri 08/05/2022  
0500 Continuous 1700

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **2700 MW**  
Impacts Total Transfer Capability 450 MW  
TTC with All Lines In Service 3150 MW

## MARCY\_-EDIC\_345\_UE1-7

Sat 08/06/2022 to Sun 08/07/2022  
0500 Continuous 1830

Work scheduled by: NYPA

UPDATED by NYPA 04/07/2022  
**ARR: 19&16**

FWD  
(Import)  
OSWEGO EXPORT **5250 MW**  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

## VOLNEY\_-MARCY\_345\_19

Sat 08/06/2022 to Sun 08/07/2022  
0500 Continuous 1830

Work scheduled by: NYPA

UPDATED by NYPA 04/07/2022  
**ARR: 19**

FWD  
(Import)  
CENTRAL EAST - VC **2475 MW**  
Impacts Total Transfer Capability 110 MW  
TTC with All Lines In Service 2585 MW

## VOLNEY\_-MARCY\_345\_19

Sat 08/06/2022 to Sun 08/07/2022  
0500 Continuous 1830

Work scheduled by: NYPA

UPDATED by NYPA 04/07/2022  
**ARR: 19**

FWD  
(Import)  
OSWEGO EXPORT **4900 MW**  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 5250 MW

## FRASANNX-COOPERS\_345\_UCC2-41

Mon 08/08/2022 to Fri 09/09/2022  
0700 Continuous 1700

Work scheduled by: NYPA

**ARR: 19**

FWD  
(Import)  
CENTRAL EAST - VC **2275 MW**  
Impacts Total Transfer Capability 310 MW  
TTC with All Lines In Service 2585 MW

## MARCY\_-FRASANNX\_345\_UCC2-41

Mon 08/08/2022 to Fri 09/09/2022  
0700 Continuous 1700

Work scheduled by: NYPA

**ARR: 19**

FWD  
(Import)  
CENTRAL EAST - VC **2275 MW**  
Impacts Total Transfer Capability 310 MW  
TTC with All Lines In Service 2585 MW

## SAND\_BAR-PLATSBURG\_115\_PV20

Mon 08/22/2022 to Fri 08/26/2022  
0700 Continuous 1530

Work scheduled by: NYPA

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

# NYISO TRANSFER LIMITATIONS

Wednesday, April 27, 2022 to Friday ,October 27, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## ROSETON\_-ROCKTVRN\_345\_311

FWD

Mon 08/29/2022 to Fri 09/09/2022

(Import)

0800 Continuous 1600

UPNY CONED

**4400 MW**

Impacts Total Transfer Capability 3415 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: CHGE

## MOTTHAVN-RAINEY\_345\_Q12

FWD

Thu 09/01/2022 to Mon 09/05/2022

(Import)

0001 Continuous 0200

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

## FRASER\_-GILBOA\_345\_GF5-35

FWD

Mon 09/12/2022 to Sun 09/18/2022

(Import)

0700 Continuous 1530

CENTRAL EAST - VC

**2450 MW**

Impacts Total Transfer Capability 135 MW

TTC with All Lines In Service 2585 MW

Work scheduled by: NYPA

## MARCY\_-EDIC\_345\_UE1-7

FWD

Mon 09/19/2022 to Sat 10/08/2022

(Import)

0700 Continuous 1530

OSWEGO EXPORT

**5250 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NYPA

**ARR: 19&16**

## LEEDS\_-HURLYAVE\_345\_301

FWD

Mon 09/19/2022 to Fri 10/21/2022

(Import)

0800 Continuous 1600

**10/04/2021**

UPNY CONED

**4100 MW**

Impacts Total Transfer Capability 3715 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: CHGE

## EGRDNCTY\_345\_138\_AT1

FWD

Sat 10/01/2022 to Wed 05/31/2023

(Import)

0001 Continuous 2359

**UPDATED****by CONED 03/10/2022**

CONED - LIPA

**1250 MW**

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 1500 MW

Work scheduled by: LI

## EGRDNCTY\_345\_138\_AT2

FWD

Sat 10/01/2022 to Wed 05/31/2023

(Import)

0001 Continuous 2359

**UPDATED****by CONED 03/10/2022**

CONED - LIPA

**1250 MW**

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 1500 MW

Work scheduled by: LI



# NYISO TRANSFER LIMITATIONS

Wednesday, April 27, 2022 to Friday ,October 27, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SPRNBK\_-EGRDNCTR\_345\_Y49

FWD

Sat 10/01/2022 to Wed 05/31/2023 UPDATED by CONED 03/10/2022

(Import)

0001 Continuous 2359

CONED - LIPA

**775 MW**

Impacts Total Transfer Capability 725 MW

TTC with All Lines In Service 1500 MW

Work scheduled by: LI

### CLRKSCRN-OAKDALE\_345\_36

FWD

Mon 10/03/2022 to Fri 10/07/2022 UPDATED by NYSEG 04/20/2022

(Import)

0830 Continuous 1530

CENTRAL EAST - VC

**2450 MW**

Impacts Total Transfer Capability 135 MW

TTC with All Lines In Service 2585 MW

Work scheduled by: NYSEG

### SHOR\_NPX-SHOREHAM\_138\_CSC

FWD

REV

Mon 10/03/2022 to Fri 10/21/2022 UPDATED by LI 01/07/2022

(Import) (Export)

1000 Continuous 1500

SCH - NPX\_CSC

**0 MW**

**0 MW**

Impacts Total Transfer Capability 330 MW 330 MW

TTC with All Lines In Service 330 MW 330 MW

Work scheduled by: LI

### NIAGARA\_-DYSINGER\_345\_ND1

FWD

Mon 10/17/2022 to Fri 10/21/2022 UPDATED by NYPA 02/10/2022

(Import)

0500 Continuous 1700

DYSINGER EAST

**2700 MW**

Impacts Total Transfer Capability 450 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

### PANNELL\_-CLAY\_345\_1

FWD

Mon 10/24/2022 to Fri 10/28/2022

(Import)

0700 Continuous 1530

WEST CENTRAL

**1300 MW**

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW

Work scheduled by: NYPA

### HURLYAVE-ROSETON\_345\_303

FWD

Mon 10/24/2022 to Fri 11/04/2022 UPDATED by CH 04/13/2022

(Import)

0800 Continuous 1600

UPNY CONED

**4100 MW**

Impacts Total Transfer Capability 3715 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: CHGE

### MAINESBG-WATRCURE\_345\_30

FWD

Tue 10/25/2022 to Tue 10/25/2022

(Import)

0800 Daily 1500

SCH - PJ - NY

**2200 MW**

Impacts Total Transfer Capability 50 MW

TTC with All Lines In Service 2250 MW

Work scheduled by: NYSEG

# NYISO TRANSFER LIMITATIONS

Wednesday, April 27, 2022 to Friday ,October 27, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## WATRCURE-OAKDALE\_\_345\_31

Thu 10/27/2022 to Thu 10/27/2022  
0800 Daily 1500

Work scheduled by: NYSEG

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

## PANNELL -CLAY\_\_345\_2

Mon 10/31/2022 to Fri 11/04/2022  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

## CLAY\_\_-EDIC\_\_345\_1-16

Tue 11/01/2022 to Thu 11/03/2022  
0600 Continuous 1900

Work scheduled by: NGrid

FWD  
(Import)  
OSWEGO EXPORT **4850 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

## GILBOA\_\_-N.SCTLND\_345\_GNS-1

Tue 11/01/2022 to Tue 12/06/2022  
0700 Continuous 1900

Work scheduled by: NGrid

UPDATED by NGRID 12/29/2021

FWD  
(Import)  
CENTRAL EAST - VC **2300 MW**  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 2585 MW

## LEEDS\_\_345KV\_R94301

Tue 11/01/2022 to Tue 12/06/2022  
0700 Continuous 1900

Work scheduled by: NGrid

UPDATED by NGRID 12/29/2021

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

## MARCY\_\_-N.SCTLND\_345\_18

Tue 11/01/2022 to Tue 12/06/2022  
0700 Continuous 1900

Work scheduled by: NGrid

UPDATED by NGRID 12/29/2021

ARR: 19

FWD  
(Import)  
CENTRAL EAST - VC **1400 MW**  
Impacts Total Transfer Capability 1185 MW  
TTC with All Lines In Service 2585 MW

## LINDN\_CG-LNDVFT\_\_345\_V-3022

Tue 11/01/2022 to Fri 11/04/2022  
0800 Continuous 1500

Work scheduled by: PJM

FWD REV  
(Import) (Export)  
SCH - PJM\_VFT **0 MW** **0 MW**  
Impacts Total Transfer Capability 315 MW 315 MW  
TTC with All Lines In Service 315 MW 315 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, April 27, 2022 to Friday ,October 27, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## LEEDS\_\_\_-HURLYAVE\_345\_301

FWD

Mon 11/07/2022 to Fri 12/09/2022

(Import)

0800 Continuous 1600

UPNY CONED

**4100 MW**

Impacts Total Transfer Capability 3715 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: CHGE

## MOSES\_\_\_-ADIRNDCK\_230\_MAI

FWD

Wed 11/30/2022 to Wed 03/01/2023

(Import)

0700 Continuous 1100

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

## CLAY\_\_\_-EDIC\_\_\_345\_1-16

FWD

Fri 12/30/2022 to Sat 12/31/2022

(Import)

0600 Continuous 1900

OSWEGO EXPORT

**4850 MW**

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NGrid

## FRASER\_\_\_345\_FRASER SVC

FWD

Tue 01/03/2023 to Tue 02/28/2023

(Import)

0700 Continuous 1730

UPDATED by NYPA 12/30/2021

CENTRAL EAST - VC

**2550 MW**

Impacts Total Transfer Capability 35 MW

TTC with All Lines In Service 2585 MW

Work scheduled by: NYPA

## PLSNTVLY\_345KV\_RNS4

FWD

Sat 04/01/2023 to Sat 04/01/2023

(Import)

0700 Continuous 0730

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: NGrid

## ATHENS\_\_\_-PLSNTVLY\_345\_91

FWD

Sat 04/01/2023 to Sat 04/15/2023

(Import)

0700 Continuous 1900

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: NGrid

## PLSNTVLY\_345KV\_RNS4

FWD

Sat 04/15/2023 to Sat 04/15/2023

(Import)

1830 Continuous 1900

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: NGrid

# NYISO TRANSFER LIMITATIONS

Wednesday, April 27, 2022 to Friday ,October 27, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## PLSNTVLY\_345KV\_RNS5

Sun 04/16/2023 to Sun 04/16/2023  
0700 Continuous 0730

Work scheduled by: NGrid

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

## LEEDS\_-PLSNTVLY\_345\_92

Sun 04/16/2023 to Sun 04/30/2023  
0700 Continuous 1900

Work scheduled by: NGrid

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

## PLSNTVLY\_345KV\_RNS5

Sun 04/30/2023 to Sun 04/30/2023  
1830 Continuous 1900

Work scheduled by: NGrid

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

## SHOR\_NPX-SHOREHAM\_138\_CSC

Mon 05/01/2023 to Fri 05/05/2023  
0600 Continuous 1800

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_CSC	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	330 MW	330 MW
TTC with All Lines In Service	330 MW	330 MW

## SHOR\_NPX-SHOREHAM\_138\_CSC

Mon 10/02/2023 to Fri 10/06/2023  
0600 Continuous 1800

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_CSC	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	330 MW	330 MW
TTC with All Lines In Service	330 MW	330 MW

## NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE

Mon 10/09/2023 to Fri 10/13/2023  
0600 Continuous 1600

Work scheduled by: LI

FWD  
(Import)  
SCH - PJM\_NEPTUNE **0 MW**  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

## NEWBRDGE-DUFFYAVE\_345\_501

Mon 10/09/2023 to Fri 10/13/2023  
0600 Continuous 1600

Work scheduled by: LI

FWD  
(Import)  
SCH - PJM\_NEPTUNE **0 MW**  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

**NYISO TRANSFER LIMITATIONS**

Wednesday, April 27, 2022 to Friday ,October 27, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**NEWBRDGE\_345\_138\_BK\_1**

FWD

Mon 10/09/2023 to Fri 10/13/2023

(Import)

0600 Continuous 1600

SCH - PJM\_NEPTUNE

**375 MW**

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 660 MW

Work scheduled by: LI

**NEWBRDGE\_345\_138\_BK\_2**

FWD

Mon 10/09/2023 to Fri 10/13/2023

(Import)

0600 Continuous 1600

SCH - PJM\_NEPTUNE

**375 MW**

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 660 MW

Work scheduled by: LI