

# NYISO TRANSFER LIMITATIONS

Thursday ,April 28, 2022 to Saturday ,October 28, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## HUDSONP\_-FARRAGUT\_345\_B3402

Mon 01/15/2018 to Sun 07/31/2022 EXT FORCE by CONED 01/04/2022

0001 Continuous 2359

Work scheduled by: ConEd

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

## HUDSONP\_-FARRAGUT\_345\_B3402 & MARION\_-FARRAGUT\_345\_C3403

Mon 01/15/2018 to Sun 07/31/2022

0001 2359

Work scheduled by:

FWD REV  
(Import) (Export)

SCH - PJ - NY

**2550 MW 1900 MW**

Impacts Total Transfer Capability 300 MW 300 MW

TTC with All Lines In Service 2850 MW 2200 MW

## MARION\_-FARRAGUT\_345\_C3403

Mon 01/15/2018 to Sun 07/31/2022 EXT FORCE by CONED 01/04/2022

0001 Continuous 2359

Work scheduled by: ConEd

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

## STLAWRNC-MOSES\_230\_L33P

Mon 04/30/2018 to Mon 07/25/2022 EXT FORCE by IESO 11/04/2021

0456 Continuous 0800

Work scheduled by: IESO

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

## NEWBRDGE\_345\_138\_BK\_1

Wed 09/02/2020 to Mon 08/01/2022 EXT FORCE by LI 12/10/2021

1807 Continuous 2359

Work scheduled by: LI

FWD  
(Import)

SCH - PJM\_NEPTUNE

**375 MW**

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 660 MW

## SCH-IMO-NYISO\_LIMIT\_1750

Mon 11/01/2021 to Sat 04/30/2022 UPDATED by IESO 05/03/2019

0001 Continuous 2359

Work scheduled by: IESO

FWD  
(Import)

SCH - OH - NY

**2050 MW**

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 2300 MW

## SCH-NYISO-IMO\_LIMIT\_1600

Mon 11/01/2021 to Sat 04/30/2022 UPDATED by IESO 05/03/2019

0001 Continuous 2359

Work scheduled by: IESO

REV  
(Export)

SCH - OH - NY

**1900 MW**

Impacts Total Transfer Capability 100 MW

TTC with All Lines In Service 2000 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,April 28, 2022 to Saturday ,October 28, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>BECK____-NIAGARA__345_PA301</b>						FWD	REV
Wed 02/09/2022	to	Fri 06/17/2022	<u>UPDATED</u>	<u>by NYISO</u>	<u>03/22/2022</u>	(Import)	(Export)
0700	Continuous	1700				<b>1100 MW</b>	<b>950 MW</b>
Work scheduled by: IESO					SCH - OH - NY	1200 MW	1050 MW
					Impacts Total Transfer Capability	2300 MW	2000 MW
					TTC with All Lines In Service		
<b>MOSES____-ADIRNDCK_230_MAI</b>						FWD	
Mon 02/28/2022	to	Sat 05/14/2022	<u>UPDATED</u>	<u>by NYPA</u>	<u>04/28/2022</u>	(Import)	
0700	Continuous	1300				<b>2300 MW</b>	
Work scheduled by: NYPA					MOSES SOUTH	850 MW	
					Impacts Total Transfer Capability	3150 MW	
					TTC with All Lines In Service		
<b>N.SCTLND-ALPS____345_2</b>						FWD	
Tue 03/08/2022	to	Fri 06/24/2022	<u>UPDATED</u>	<u>by NGRID</u>	<u>03/09/2022</u>	(Import)	
0700	Continuous	1900				<b>900 MW</b>	
Work scheduled by: NGrid					SCH - NE - NY	500 MW	
					Impacts Total Transfer Capability	1400 MW	
					TTC with All Lines In Service		
<b>N.SCTLND-ALPS____345_2</b>						FWD	REV
Tue 03/08/2022	to	Fri 06/24/2022	<u>UPDATED</u>	<u>by NGRID</u>	<u>03/09/2022</u>	(Import)	(Export)
0700	Continuous	1900				<b>100 MW</b>	<b>100 MW</b>
Work scheduled by: NGrid					SCH - NPX_1385	100 MW	100 MW
					Impacts Total Transfer Capability	200 MW	200 MW
					TTC with All Lines In Service		
<b>EGRDNCTY_345_138_AT1</b>						FWD	
Sat 03/12/2022	to	Sun 05/15/2022	<u>FORCED</u>	<u>by CE</u>	<u>03/13/2022</u>	(Import)	
2148	Continuous	2359				<b>1250 MW</b>	
Work scheduled by: ConEd					CONED - LIPA	250 MW	
					Impacts Total Transfer Capability	1500 MW	
					TTC with All Lines In Service		
<b>EGRDNCTY_345_138_AT2</b>						FWD	
Sat 03/12/2022	to	Sun 05/15/2022	<u>FORCED</u>	<u>by CE</u>	<u>03/13/2022</u>	(Import)	
2148	Continuous	2359				<b>1250 MW</b>	
Work scheduled by: ConEd					CONED - LIPA	250 MW	
					Impacts Total Transfer Capability	1500 MW	
					TTC with All Lines In Service		
<b>SPRNBK_-EGRDNCTR_345_Y49</b>						FWD	
Sat 03/12/2022	to	Sun 05/15/2022	<u>FORCED</u>	<u>by CE</u>	<u>03/13/2022</u>	(Import)	
2148	Continuous	2359				<b>775 MW</b>	
Work scheduled by: ConEd					CONED - LIPA	725 MW	
					Impacts Total Transfer Capability	1500 MW	
					TTC with All Lines In Service		

**NYISO TRANSFER LIMITATIONS**

Thursday ,April 28, 2022 to Saturday ,October 28, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**W49TH\_ST\_345KV\_6**

FWD

Mon 03/21/2022 to Mon 05/23/2022 **EXT FORCE** **by CE** **04/04/2022**

(Import)

0809 Continuous 2359

SCH - PJM\_HTP

**310 MW**

Impacts Total Transfer Capability 350 MW

Work scheduled by: ConEd

TTC with All Lines In Service 660 MW

**W49TH\_ST\_345KV\_8**

FWD

Mon 03/21/2022 to Mon 05/23/2022 **EXT FORCE** **by CE** **04/04/2022**

(Import)

0811 Continuous 2359

SCH - PJM\_HTP

**310 MW**

Impacts Total Transfer Capability 350 MW

Work scheduled by: ConEd

TTC with All Lines In Service 660 MW

**SCH-IMO-NYISO\_LIMIT\_700**

FWD

Fri 03/25/2022 to Sat 04/30/2022 **UPDATED** **by NYISO** **03/22/2022**

(Import)

0001 Continuous 2359

SCH - OH - NY

**1000 MW**

Impacts Total Transfer Capability 1300 MW

Work scheduled by: IESO

TTC with All Lines In Service 2300 MW

**SCH-IMO-NYISO\_LIMIT\_400**

FWD

Fri 03/25/2022 to Sat 04/30/2022 **UPDATED** **by NYISO** **03/22/2022**

(Import)

2300 Daily 0500

SCH - OH - NY

**700 MW**

Impacts Total Transfer Capability 1600 MW

Work scheduled by: NYISO

TTC with All Lines In Service 2300 MW

**FIVEMILE-STOLLERD\_345\_29**Fri 04/01/2022 to Tue 12/31/2030 **EXTENDED** **by NYSEG** **04/06/2022**

0500 Continuous 2359

SCH - PJ - NY

Impacts Total Transfer Capability

Work scheduled by: NYSEG

TTC with All Lines In Service

**ATHENS\_\_-PLSNTVLY\_345\_91**

FWD

Mon 04/18/2022 to Tue 05/24/2022 **EXTENDED** **by CE** **04/28/2022**

(Import)

0001 Continuous 2200

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 4015 MW

Work scheduled by: ConEd

TTC with All Lines In Service 7815 MW

**PLSNTVLY\_345KV\_RNS4**

FWD

Mon 04/18/2022 to Tue 05/24/2022 **EXTENDED** **by CE** **04/28/2022**

(Import)

0001 Continuous 2200

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 4015 MW

Work scheduled by: ConEd

TTC with All Lines In Service 7815 MW

**NYISO TRANSFER LIMITATIONS**

Thursday ,April 28, 2022 to Saturday ,October 28, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**SAND\_BAR-PLATSBURG\_115\_PV20**Tue 04/19/2022 to Tue 04/26/2022 **UPDATED by NYPA 04/13/2022**

0700 Continuous 1730

Work scheduled by: NYPA

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

**GOETHALS\_345KV\_5**

Wed 04/20/2022 to Fri 05/20/2022

0301 Continuous 0300

Work scheduled by: ConEd

STATEN ISLAND

Impacts Total Transfer Capability

TTC with All Lines In Service

**LINDEN\_-GOETHALS\_230\_A2253**

Wed 04/20/2022 to Fri 05/20/2022

0301 Continuous 0300

Work scheduled by: ConEd

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

**LINDEN\_-GOETHALS\_230\_A2253 & HUDSONP\_-FARRAGUT\_345\_B3402**

Wed 04/20/2022 to Fri 05/20/2022

0301 0300

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	<b>2550 MW</b>	<b>1900 MW</b>
Impacts Total Transfer Capability	300 MW	300 MW
TTC with All Lines In Service	2850 MW	2200 MW

**LINDEN\_-GOETHALS\_230\_A2253 & HUDSONP\_-FARRAGUT\_345\_B3402 & MARION\_-FARRAGUT\_345\_C3403**

Wed 04/20/2022 to Fri 05/20/2022

0301 0300

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	<b>2550 MW</b>	<b>1900 MW</b>
Impacts Total Transfer Capability	300 MW	300 MW
TTC with All Lines In Service	2850 MW	2200 MW

**LINDEN\_-GOETHALS\_230\_A2253 & MARION\_-FARRAGUT\_345\_C3403**

Wed 04/20/2022 to Fri 05/20/2022

0301 0300

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	<b>2550 MW</b>	<b>1900 MW</b>
Impacts Total Transfer Capability	300 MW	300 MW
TTC with All Lines In Service	2850 MW	2200 MW

**EDIC\_-FRASER\_345\_EF24-40**Fri 04/22/2022 to Tue 06/14/2022 **UPDATED by NJYPA 04/19/2022**

0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
CENTRAL EAST - VC	<b>2275 MW</b>
Impacts Total Transfer Capability	310 MW
TTC with All Lines In Service	2585 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,April 28, 2022 to Saturday ,October 28, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## SCH-NE-NYISO\_LIMIT\_300

Fri 04/22/2022 to Sun 04/24/2022 UPDATED by ISONE 04/23/2022

1601 Continuous 1800

Work scheduled by: ISONE

FWD

(Import)

SCH - NE - NY

500 MW

Impacts Total Transfer Capability 900 MW

TTC with All Lines In Service 1400 MW

## SCH-NYISO-NE\_LIMIT\_1300

Fri 04/22/2022 to Sun 04/24/2022 UPDATED by ISONE 04/23/2022

1601 Continuous 1800

Work scheduled by: ISONE

REV

(Export)

SCH - NE - NY

1500 MW

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 1800 MW

## CHAT\_DC\_GC1

Sat 04/23/2022 to Sat 04/23/2022

0001 Continuous 0300

Work scheduled by: HQ

FWD

(Import)

MOSES SOUTH

2850 MW

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 3150 MW

## CHAT\_DC\_GC1

Sat 04/23/2022 to Sat 04/23/2022

0001 Continuous 0300

Work scheduled by: HQ

REV

(Export)

SCH - HQ - NY

500 MW

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 1000 MW

## CHAT\_DC\_GC1 &amp; CHAT\_DC\_GC2

Sat 04/23/2022 to Sat 04/23/2022

0001 0300

Work scheduled by:

FWD

(Import)

MOSES SOUTH

2550 MW

Impacts Total Transfer Capability 600 MW

TTC with All Lines In Service 3150 MW

## CHAT\_DC\_GC1 &amp; CHAT\_DC\_GC2

Sat 04/23/2022 to Sat 04/23/2022

0001 0300

Work scheduled by:

FWD

(Import)

REV

(Export)

SCH - HQ - NY

1370 MW 0 MW

Impacts Total Transfer Capability 130 MW 1000 MW

TTC with All Lines In Service 1500 MW 1000 MW

## CHAT\_DC\_GC2

Sat 04/23/2022 to Sat 04/23/2022

0001 Continuous 0300

Work scheduled by: HQ

FWD

(Import)

MOSES SOUTH

2850 MW

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,April 28, 2022 to Saturday ,October 28, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## CHAT\_DC\_GC2

REV

Sat 04/23/2022 to Sat 04/23/2022  
0001 Continuous 0300

(Export)

Work scheduled by: HQ

SCH - HQ - NY

500 MW

Impacts Total Transfer Capability

500 MW

TTC with All Lines In Service

1000 MW

## SCH-HQ-NYISO\_LIMIT\_1150

FWD

Sat 04/23/2022 to Sat 04/23/2022  
0001 Continuous 0300

(Import)

Work scheduled by: HQ

SCH - HQ - NY

1150 MW

Impacts Total Transfer Capability

350 MW

TTC with All Lines In Service

1500 MW

## MARCY\_\_\_345KV\_CSC

FWD

Sat 04/23/2022 to Sat 04/23/2022  
0500 Continuous 1730

(Import)

Work scheduled by: NYPA

CENTRAL EAST - VC

2535 MW

Impacts Total Transfer Capability

50 MW

TTC with All Lines In Service

2585 MW

## SCH-NYISO-NE\_LIMIT\_100

REV

Sun 04/24/2022 to Mon 04/25/2022  
1800 Daily 0800

(Export)

Work scheduled by: NGrid

SCH - NE - NY

300 MW

Impacts Total Transfer Capability

1500 MW

TTC with All Lines In Service

1800 MW

## BUCHAN\_N-EASTVIEW\_345\_W93

FWD

Mon 04/25/2022 to Mon 04/25/2022  
0001 Continuous 0030

(Import)

Work scheduled by: ConEd

UPNY CONED

4350 MW

Impacts Total Transfer Capability

3465 MW

TTC with All Lines In Service

7815 MW

## RAMAPO\_\_-BUCHAN\_N\_345\_Y94

FWD

Mon 04/25/2022 to Mon 04/25/2022  
0001 Continuous 0030

(Import)

Work scheduled by: ConEd

UPNY CONED

7580 MW

Impacts Total Transfer Capability

235 MW

TTC with All Lines In Service

7815 MW

## ROCHESTR-PANNELL\_\_345\_RP1

FWD

Mon 04/25/2022 to Fri 04/29/2022  
0500 Continuous 1700

(Import)

Work scheduled by: NYPA

DYSINGER EAST

2300 MW

Impacts Total Transfer Capability

850 MW

TTC with All Lines In Service

3150 MW

**NYISO TRANSFER LIMITATIONS**

Thursday ,April 28, 2022 to Saturday ,October 28, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**DYSINGER-STA\_255\_\_345\_DH1**

FWD

Mon 04/25/2022 to Thu 04/28/2022

UPDATEDby NYSEG 04/28/2022

(Import)

0600 Continuous 1537

DYSINGER EAST

**2850 MW**

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NT

**SCH-NE-NYISO\_LIMIT\_700**

FWD

Tue 04/26/2022 to Sat 04/30/2022

(Import)

0801 Continuous 0800

SCH - NE - NY

**900 MW**

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 1400 MW

Work scheduled by: ISONE

**SCH-NYISO-NE\_LIMIT\_1100**

REV

Tue 04/26/2022 to Sat 04/30/2022

(Export)

0801 Continuous 0800

SCH - NE - NY

**1300 MW**

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 1800 MW

Work scheduled by: ISONE

**SCH-NYISO-HQ\_LIMIT\_800**

REV

Wed 04/27/2022 to Thu 04/28/2022

(Export)

0500 Continuous 1900

SCH - HQ - NY

**800 MW**

Impacts Total Transfer Capability 200 MW

TTC with All Lines In Service 1000 MW

Work scheduled by: HQ

**GORDONRD-N.SCTLND\_345\_55**

FWD

Wed 04/27/2022 to Wed 05/25/2022

(Import)

1122 Continuous 2359

CENTRAL EAST - VC

**2045 MW**

Impacts Total Transfer Capability 540 MW

TTC with All Lines In Service 2585 MW

Work scheduled by: NYISO

**GORDONRD-ROTTTRDAM\_230\_30**

FWD

Wed 04/27/2022 to Wed 05/25/2022

(Import)

1122 Continuous 2359

CENTRAL EAST - VC

**2535 MW**

Impacts Total Transfer Capability 50 MW

TTC with All Lines In Service 2585 MW

Work scheduled by: NYISO

**EDIC\_\_\_\_-GORDONRD\_345\_14**

FWD

Wed 04/27/2022 to Tue 05/10/2022

(Import)

1130 Continuous 1530

CENTRAL EAST - VC

**1695 MW**

Impacts Total Transfer Capability 890 MW

TTC with All Lines In Service 2585 MW

Work scheduled by: NYISO

# NYISO TRANSFER LIMITATIONS

Thursday ,April 28, 2022 to Saturday ,October 28, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EDIC\_\_\_\_-GORDONRD\_345\_14 & GORDONRD-ROTTRDAM\_230\_30

FWD

Wed 04/27/2022 to Tue 05/10/2022

(Import)

1130 1530

CENTRAL EAST - VC

1645 MW

Impacts Total Transfer Capability 940 MW

TTC with All Lines In Service 2585 MW

Work scheduled by:

EDIC\_\_\_\_-GORDONRD\_345\_14 & GORDONRD-ROTTRDAM\_230\_31

FWD

Wed 04/27/2022 to Tue 05/10/2022

(Import)

1130 1530

CENTRAL EAST - VC

1645 MW

Impacts Total Transfer Capability 940 MW

TTC with All Lines In Service 2585 MW

Work scheduled by:

GORDONRD-ROTTRDAM\_230\_30 & GORDONRD-ROTTRDAM\_230\_31

FWD

Wed 04/27/2022 to Tue 05/10/2022

(Import)

1130 1530

CENTRAL EAST - VC

2485 MW

Impacts Total Transfer Capability 100 MW

TTC with All Lines In Service 2585 MW

Work scheduled by:

GORDONRD-ROTTRDAM\_230\_31

FWD

Wed 04/27/2022 to Tue 05/10/2022

(Import)

1130 Continuous 1530

CENTRAL EAST - VC

2535 MW

Impacts Total Transfer Capability 50 MW

TTC with All Lines In Service 2585 MW

Work scheduled by: NYISO

SAND\_BAR-PLATSBURG\_115\_PV20

Thu 04/28/2022 to Sat 05/07/2022

CANCELLED by ISONE 04/28/2022

0700 Continuous 1730

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: NYPA

SCH-NYISO-NE\_LIMIT\_900

REV

Thu 04/28/2022 to Sat 05/07/2022

CANCELLED by ISONE 04/28/2022

(Export)

0700 Continuous 1730

SCH - NE - NY

1100 MW

Impacts Total Transfer Capability 700 MW

TTC with All Lines In Service 1800 MW

Work scheduled by: NYPA

SCH-NYISO-NE\_LIMIT\_1200

REV

Thu 04/28/2022 to Sat 04/30/2022

UPDATED by NGRID 04/01/2022

(Export)

0900 Continuous 2359

SCH - NE - NY

1400 MW

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 1800 MW

Work scheduled by: NGrid



**NYISO TRANSFER LIMITATIONS**

Thursday ,April 28, 2022 to Saturday ,October 28, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**ROTTDAM-EASTOVER\_230\_38**Thu 04/28/2022 to Wed 05/04/2022 UPDATED by NGRID 04/01/2022

0900 Continuous 1600

Work scheduled by: NGrid

**ARR: 77**

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

**NIAGARA\_345\_230\_AT4**

Fri 04/29/2022 to Fri 04/29/2022

0500 Continuous 1700

Work scheduled by: NYPA

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

REV

(Export)

**1750 MW**

250 MW

2000 MW

**SCH-IMO-NYISO\_LIMIT\_400**Sat 04/30/2022 to Sat 04/30/2022 UPDATED by NYISO 03/22/2022

2300 Daily 2359

Work scheduled by: NYISO

SCH - OH - NY

Impacts Total Transfer Capability 1600 MW

TTC with All Lines In Service 2300 MW

FWD

(Import)

**700 MW****CHAT\_DC\_GC2**

Sun 05/01/2022 to Sat 06/04/2022

0500 Continuous 2200

Work scheduled by: HQ

MOSES SOUTH

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 3150 MW

FWD

(Import)

**2850 MW****CHAT\_DC\_GC2**

Sun 05/01/2022 to Sat 06/04/2022

0500 Continuous 2200

Work scheduled by: HQ

SCH - HQ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

REV

(Export)

**500 MW**

500 MW

1000 MW

**SCH-NYISO-HQ\_LIMIT\_500**

Sun 05/01/2022 to Sat 06/04/2022

0500 Continuous 2200

Work scheduled by: HQ

SCH - HQ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

REV

(Export)

**500 MW**

500 MW

1000 MW

**BUCHAN\_N-EASTVIEW\_345\_W93**

Mon 05/02/2022 to Mon 05/02/2022

0130 Continuous 0200

Work scheduled by: ConEd

UPNY CONED

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

FWD

(Import)

**4350 MW**

**NYISO TRANSFER LIMITATIONS**

Thursday ,April 28, 2022 to Saturday ,October 28, 2023

<b>CENTRAL EAST</b>	<b>3100MW</b>
<b>CENTRAL EAST - VC</b>	<b>2585MW</b>
<b>TOTAL EAST</b>	<b>6500MW</b>
<b>UPNY CONED</b>	<b>7815MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3150MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**RAMAPO\_\_-BUCHAN\_N\_345\_Y94**

FWD

Mon 05/02/2022 to Mon 05/02/2022

(Import)

0130 Continuous 0200

Work scheduled by: ConEd

UPNY CONED

**7580 MW**

Impacts Total Transfer Capability 235 MW

TTC with All Lines In Service 7815 MW

**SCH-HQ\_CEDARS-NYISO\_LIMIT\_220**

FWD

Mon 05/02/2022 to Fri 05/20/2022

(Import)

0200 Continuous 0200

Work scheduled by: HQ

SCH - HQ\_CEDARS

**220 MW**

Impacts Total Transfer Capability 50 MW

TTC with All Lines In Service 270 MW

**ROCHESTR-PANNELL\_\_345\_RP2**

FWD

Mon 05/02/2022 to Fri 05/06/2022

(Import)

0500 Continuous 1700

Work scheduled by: NYPA

DYSINGER EAST

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

**SCH-NYISO-NE\_LIMIT\_1000**

REV

Mon 05/02/2022 to Fri 05/06/2022

(Export)

0800 Continuous 1800

Work scheduled by: ISONE

SCH - NE - NY

**1200 MW**

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 1600 MW

**SCH-NYISO-NE\_LIMIT\_800**

REV

Mon 05/02/2022 to Fri 05/06/2022

(Export)

2300 Daily(No Weekends) 0659

Work scheduled by: ISONE

SCH - NE - NY

**1000 MW**

Impacts Total Transfer Capability 600 MW

TTC with All Lines In Service 1600 MW

**BUCHAN\_N-EASTVIEW\_345\_W93**

FWD

Tue 05/03/2022 to Tue 05/03/2022

(Import)

0001 Continuous 0030

Work scheduled by: ConEd

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

**EASTVIEW-SPRNBK\_\_345\_W79**

FWD

Tue 05/03/2022 to Fri 05/06/2022

(Import)

0001 Continuous 0200

Work scheduled by: ConEd

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,April 28, 2022 to Saturday ,October 28, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### CHAT\_DC\_GC1

Tue 05/03/2022 to Fri 05/06/2022 UPDATED by HQ 04/28/2022  
 0700 Continuous 1500  
 Work scheduled by: HQ

FWD  
 (Import)  
 MOSES SOUTH **2850 MW**  
 Impacts Total Transfer Capability 300 MW  
 TTC with All Lines In Service 3150 MW

### CHAT\_DC\_GC1

Tue 05/03/2022 to Fri 05/06/2022 UPDATED by HQ 04/28/2022  
 0700 Continuous 1500  
 Work scheduled by: HQ

REV  
 (Export)  
 SCH - HQ - NY **500 MW**  
 Impacts Total Transfer Capability 500 MW  
 TTC with All Lines In Service 1000 MW

### CHAT\_DC\_GC1 & CHAT\_DC\_GC2

Tue 05/03/2022 to Fri 05/06/2022  
 0700 1500  
 Work scheduled by:

FWD  
 (Import)  
 MOSES SOUTH **2550 MW**  
 Impacts Total Transfer Capability 600 MW  
 TTC with All Lines In Service 3150 MW

### CHAT\_DC\_GC1 & CHAT\_DC\_GC2

Tue 05/03/2022 to Fri 05/06/2022  
 0700 1500  
 Work scheduled by:

FWD REV  
 (Import) (Export)  
 SCH - HQ - NY **1370 MW 0 MW**  
 Impacts Total Transfer Capability 130 MW 1000 MW  
 TTC with All Lines In Service 1500 MW 1000 MW

### CHATGUAY-MASSENA\_\_765\_7040

Tue 05/03/2022 to Fri 05/06/2022  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD  
 (Import)  
 MOSES SOUTH **1550 MW**  
 Impacts Total Transfer Capability 1600 MW  
 TTC with All Lines In Service 3150 MW

### CHATGUAY-MASSENA\_\_765\_7040

Tue 05/03/2022 to Fri 05/06/2022  
 0700 Continuous 1530  
 Work scheduled by: NYPA

FWD REV  
 (Import) (Export)  
 SCH - HQ - NY **0 MW 0 MW**  
 Impacts Total Transfer Capability 1500 MW 1000 MW  
 TTC with All Lines In Service 1500 MW 1000 MW

### LEEDS\_\_345KV\_R395

Tue 05/03/2022 to Tue 05/03/2022 UPDATED by NGRID 04/14/2022  
 0830 Daily(No Weekends) 1100  
 Work scheduled by: NGrid

FWD  
 (Import)  
 UPNY CONED **3800 MW**  
 Impacts Total Transfer Capability 4015 MW  
 TTC with All Lines In Service 7815 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,April 28, 2022 to Saturday ,October 28, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### BUCHAN\_N-EASTVIEW\_345\_W93

Fri 05/06/2022 to Fri 05/06/2022  
0130 Continuous 0200  
Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

### SCH-NYISO-NE\_LIMIT\_800

Fri 05/06/2022 to Fri 05/06/2022  
2300 Daily(No Weekends) 2359  
Work scheduled by: ISONE

REV  
(Export)  
SCH - NE - NY **1000 MW**  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 1600 MW

### SPRNBK\_-TREMONT\_345\_X28

Sun 05/08/2022 to Wed 05/11/2022 UPDATED by CONED 04/13/2022  
0201 Continuous 0300  
Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **4200 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 4600 MW

### E13THSTA-FARRAGUT\_345\_46

Mon 05/09/2022 to Tue 05/24/2022 UPDATED by CONED 04/26/2022  
0301 Continuous 0200  
Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

### SCH-NYISO-NE\_LIMIT\_1000

Mon 05/09/2022 to Fri 05/13/2022  
0600 Continuous 1600  
Work scheduled by: ISONE

REV  
(Export)  
SCH - NE - NY **1200 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 1600 MW

### FRASER\_345\_FRASER SVC

Mon 05/09/2022 to Fri 05/13/2022  
0800 Continuous 1700  
Work scheduled by: NYSEG

FWD  
(Import)  
CENTRAL EAST - VC **2550 MW**  
Impacts Total Transfer Capability 35 MW  
TTC with All Lines In Service 2585 MW

### SCH-NYISO-NE\_LIMIT\_800

Mon 05/09/2022 to Fri 05/13/2022  
2300 Daily(No Weekends) 0659  
Work scheduled by: ISONE

REV  
(Export)  
SCH - NE - NY **1000 MW**  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 1600 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,April 28, 2022 to Saturday ,October 28, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>RAMAPO__-LADENTWN_345_W72</b>					FWD		
Tue 05/10/2022	to	Wed 05/11/2022	<u>UPDATED</u>	<u>by CE</u>	<u>02/23/2022</u>	(Import)	
0700	Continuous	1900				UPNY CONED	<b>4400 MW</b>
Work scheduled by: ORU						Impacts Total Transfer Capability	3415 MW
						TTC with All Lines In Service	7815 MW
<b>PLSNTVLE-DUNWODIE_345_W89</b>						FWD	
Fri 05/13/2022	to	Fri 05/13/2022				(Import)	
0200	Continuous	0230				UPNY CONED	<b>4000 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	3815 MW
						TTC with All Lines In Service	7815 MW
<b>EFISHKIL-WOOD_ST_345_F38</b>						FWD	
Fri 05/13/2022	to	Fri 05/13/2022				(Import)	
0200	Continuous	0430				UPNY CONED	<b>4000 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	3815 MW
						TTC with All Lines In Service	7815 MW
<b>WOOD_ST_-PLSNTVLE_345_Y86</b>						FWD	
Fri 05/13/2022	to	Fri 05/13/2022				(Import)	
0200	Continuous	0430				UPNY CONED	<b>7210 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	605 MW
						TTC with All Lines In Service	7815 MW
<b>PLSNTVLE-DUNWODIE_345_W89</b>						FWD	
Fri 05/13/2022	to	Fri 05/13/2022				(Import)	
0400	Continuous	0430				UPNY CONED	<b>4000 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	3815 MW
						TTC with All Lines In Service	7815 MW
<b>SHOR_NPX-SHOREHAM_138_CSC</b>						FWD	REV
Mon 05/16/2022	to	Sat 05/21/2022	<u>UPDATED</u>	<u>by LI</u>	<u>02/10/2022</u>	(Import)	(Export)
0600	Continuous	2000				SCH - NPX_CSC	<b>0 MW 0 MW</b>
Work scheduled by: LI						Impacts Total Transfer Capability	330 MW 330 MW
						TTC with All Lines In Service	330 MW 330 MW
<b>HOMR_NYW-PIERC_NY_345_48</b>							
Mon 05/16/2022	to	Fri 05/20/2022				SCH - PJ - NY	
0800	Continuous	1500				Impacts Total Transfer Capability	
Work scheduled by: PJM						TTC with All Lines In Service	

# NYISO TRANSFER LIMITATIONS

Thursday ,April 28, 2022 to Saturday ,October 28, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### W49TH\_ST-E13THSTA\_345\_M55

FWD

Tue 05/17/2022 to Mon 05/23/2022

UPDATED

by CONED

04/26/2022

(Import)

0001 Continuous 0300

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

### PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4

FWD

Wed 05/18/2022 to Sat 05/21/2022

(Import)

0001 2200

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by:

### HOPATCON-RAMAPO\_\_\_500\_5018

FWD

REV

Wed 05/18/2022 to Sun 05/22/2022

CANCELLED

by ConEd

04/28/2022

(Import) (Export)

0200 Continuous 2300

SCH - PJ - NY

**1100 MW 1000 MW**

Impacts Total Transfer Capability 1150 MW 250 MW

TTC with All Lines In Service 2250 MW 1250 MW

Work scheduled by: PJM

### HOPATCON-RAMAPO\_\_\_500\_5018

FWD

Wed 05/18/2022 to Sun 05/22/2022

CANCELLED

by ConEd

04/28/2022

(Import)

0200 Continuous 2300

TOTAL EAST

**5200 MW**

Impacts Total Transfer Capability 1300 MW

TTC with All Lines In Service 6500 MW

Work scheduled by: PJM

### HOPATCON-RAMAPO\_\_\_500\_5018

FWD

Wed 05/18/2022 to Sun 05/22/2022

CANCELLED

by ConEd

04/28/2022

(Import)

0200 Continuous 2300

UPNY CONED

**7480 MW**

Impacts Total Transfer Capability 335 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: PJM

### RAMAPO\_\_\_345\_345\_PAR3500

FWD

Wed 05/18/2022 to Sun 05/22/2022

CANCELLED

by ConEd

04/28/2022

(Import)

0200 Continuous 2300

SCH - PJ - NY

**1750 MW**

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 2250 MW

Work scheduled by: PJM

### RAMAPO\_\_\_345\_345\_PAR4500

FWD

Wed 05/18/2022 to Sun 05/22/2022

CANCELLED

by ConEd

04/28/2022

(Import)

0200 Continuous 2300

SCH - PJ - NY

**1750 MW**

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 2250 MW

Work scheduled by: PJM

# NYISO TRANSFER LIMITATIONS

Thursday ,April 28, 2022 to Saturday ,October 28, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

					FWD	REV
					(Import)	(Export)
<b>RAMAPO___500_345_BK 1500</b>						
Wed 05/18/2022	to	Sun 05/22/2022	<b><u>CANCELLED</u></b>	<b><u>by ConEd</u></b>	<b><u>04/28/2022</u></b>	
0200	Continuous	2300			SCH - PJ - NY	<b>1100 MW</b>
Work scheduled by: PJM					Impacts Total Transfer Capability	250 MW
					TTC with All Lines In Service	1250 MW
<b>RAMAPO___500_345_BK 1500</b>					FWD	
Wed 05/18/2022	to	Sun 05/22/2022	<b><u>CANCELLED</u></b>	<b><u>by ConEd</u></b>	<b><u>04/28/2022</u></b>	(Import)
0200	Continuous	2300			UPNY CONED	<b>7480 MW</b>
Work scheduled by: PJM					Impacts Total Transfer Capability	335 MW
					TTC with All Lines In Service	7815 MW
<b>DUNWODIE-MOTTHAVN_345_71</b>					FWD	
Thu 05/19/2022	to	Fri 05/20/2022			(Import)	
0001	Continuous	0200			SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<b>DUNWODIE_345KV_3</b>					FWD	
Thu 05/19/2022	to	Fri 05/20/2022			(Import)	
0001	Continuous	0200			SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<b>DUNWODIE_345KV_5</b>					FWD	
Thu 05/19/2022	to	Fri 05/20/2022			(Import)	
0001	Continuous	0200			SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<b>MOTTHAVN-RAINEY___345_Q11</b>					FWD	
Sat 05/21/2022	to	Tue 05/24/2022			(Import)	
0001	Continuous	0200			SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<b>MARCY___-EDIC___345_UE1-7</b>					FWD	
Sat 05/21/2022	to	Sun 05/22/2022	<b><u>UPDATED</u></b>	<b><u>by NYPA</u></b>	<b><u>04/07/2022</u></b>	(Import)
0500	Continuous	1730			OSWEGO EXPORT	<b>5250 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	0 MW
					TTC with All Lines In Service	5250 MW

ARR: 19&16

# NYISO TRANSFER LIMITATIONS

Thursday ,April 28, 2022 to Saturday ,October 28, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### VOLNEY\_\_-MARCY\_\_\_\_345\_19

Sat 05/21/2022 to Sun 05/22/2022  
0500 Continuous 1730

UPDATED by NYPA 04/07/2022

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
CENTRAL EAST - VC **2475 MW**  
Impacts Total Transfer Capability 110 MW  
TTC with All Lines In Service 2585 MW

### VOLNEY\_\_-MARCY\_\_\_\_345\_19

Sat 05/21/2022 to Sun 05/22/2022  
0500 Continuous 1730

UPDATED by NYPA 04/07/2022

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
OSWEGO EXPORT **4900 MW**  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 5250 MW

### VOLNEY\_\_-MARCY\_\_\_\_345\_19 & GORDONRD-ROTTDAM\_230\_30

Sat 05/21/2022 to Sun 05/22/2022  
0500 1730

UPDATED by NYPA 04/07/2022

Work scheduled by:

ARR: 19

FWD  
(Import)  
CENTRAL EAST - VC **2425 MW**  
Impacts Total Transfer Capability 160 MW  
TTC with All Lines In Service 2585 MW

### PLSNTVLY-WOOD\_ST\_\_345\_F31

Sun 05/22/2022 to Tue 05/24/2022  
0001 Continuous 2200

UPDATED by CONED 04/28/2022

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 3815 MW  
TTC with All Lines In Service 7815 MW

### DUNWODIE-SHORE\_RD\_345\_Y50

Mon 05/23/2022 to Sun 05/29/2022  
0001 Continuous 0200

UPDATED by CONED 04/28/2022

Work scheduled by: ConEd

FWD  
(Import)  
CONED - LIPA **800 MW**  
Impacts Total Transfer Capability 700 MW  
TTC with All Lines In Service 1500 MW

### DUNWODIE\_345KV\_4

Mon 05/23/2022 to Sun 05/29/2022  
0001 Continuous 0200

UPDATED by CONED 04/28/2022

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

### DUNWODIE\_345KV\_6

Mon 05/23/2022 to Sun 05/29/2022  
0001 Continuous 0200

UPDATED by CONED 04/28/2022

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW



# NYISO TRANSFER LIMITATIONS

Thursday ,April 28, 2022 to Saturday ,October 28, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SHORE_RD_345_138_BK 1</b>					FWD	
Mon 05/23/2022	to	Sun 05/29/2022			(Import)	
0001	Continuous	0200			CONED - LIPA	<b>1350 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	150 MW
					TTC with All Lines In Service	1500 MW
<b>SHORE_RD_345_138_BK 2</b>					FWD	
Mon 05/23/2022	to	Sun 05/29/2022			(Import)	
0001	Continuous	0200			CONED - LIPA	<b>1350 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	150 MW
					TTC with All Lines In Service	1500 MW
<b>MOTHAVN-RAINEY___345_Q12</b>					FWD	
Tue 05/24/2022	to	Sat 05/28/2022			(Import)	
0201	Continuous	0200			SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	4600 MW
<b>CRICKVLY-PLSNTVLY_345_F84</b>					FWD	
Wed 05/25/2022	to	Fri 05/27/2022	<b>UPDATED</b>	<b>by CE</b>	<b>04/28/2022</b>	(Import)
0001	Continuous	2200			SCH - NE - NY	<b>350 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	1050 MW
					TTC with All Lines In Service	1400 MW
<b>CRICKVLY-PLSNTVLY_345_F84</b>					FWD	REV
Wed 05/25/2022	to	Fri 05/27/2022	<b>UPDATED</b>	<b>by CE</b>	<b>04/28/2022</b>	(Import) (Export)
0001	Continuous	2200			SCH - NPX_1385	<b>100 MW 100 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	100 MW 100 MW
					TTC with All Lines In Service	200 MW 200 MW
<b>BUCHAN_S-MILLWOOD_345_W97</b>					FWD	
Fri 05/27/2022	to	Sat 05/28/2022			(Import)	
0001	Continuous	0200			UPNY CONED	<b>7680 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	135 MW
					TTC with All Lines In Service	7815 MW
<b>MARCY___-EDIC___345_UE1-7</b>					FWD	
Sat 05/28/2022	to	Sun 05/29/2022			(Import)	
0600	Continuous	1830			OSWEGO EXPORT	<b>5250 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	0 MW
					TTC with All Lines In Service	5250 MW

ARR: 19&amp;16

# NYISO TRANSFER LIMITATIONS

Thursday ,April 28, 2022 to Saturday ,October 28, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### DUNWODIE\_345KV\_3

Sun 05/29/2022 to Sun 05/29/2022  
0201 Continuous 1800  
Work scheduled by: ConEd

UPDATED

by CE

04/12/2022

SPR/DUN-SOUTH  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

FWD

(Import)

**3800 MW**

### DUNWODIE\_345KV\_4

Sun 05/29/2022 to Sun 05/29/2022  
0201 Continuous 1800  
Work scheduled by: ConEd

UPDATED

by CE

04/12/2022

SPR/DUN-SOUTH  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

FWD

(Import)

**3800 MW**

### PLSNTVLE-DUNWODIE\_345\_W89

Sun 05/29/2022 to Sun 05/29/2022  
0201 Continuous 1800  
Work scheduled by: ConEd

UPDATED

by CE

04/12/2022

UPNY CONED  
Impacts Total Transfer Capability 3815 MW  
TTC with All Lines In Service 7815 MW

FWD

(Import)

**4000 MW**

### PIERCBRK-FIVEMILE\_345\_37

Tue 05/31/2022 to Wed 06/01/2022  
0730 Continuous 1600  
Work scheduled by: NGrid

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

### SCH-NE-NYISO\_LIMIT\_300

Wed 06/01/2022 to Wed 06/08/2022  
0700 Continuous 1600  
Work scheduled by: ISONE

UPDATED

by ISONE

03/04/2022

SCH - NE - NY  
Impacts Total Transfer Capability 900 MW  
TTC with All Lines In Service 1400 MW

FWD

(Import)

**500 MW**

### SCH-NYISO-NE\_LIMIT\_900

Wed 06/01/2022 to Wed 06/08/2022  
0700 Continuous 1600  
Work scheduled by: ISONE

UPDATED

by ISONE

03/04/2022

SCH - NE - NY  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1600 MW

REV

(Export)

**1100 MW**

### MOSES\_\_-ADIRNDCK\_230\_MA2

Wed 06/01/2022 to Tue 11/29/2022  
0700 Continuous 1800  
Work scheduled by: NYPA

MOSES SOUTH  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

FWD

(Import)

**2100 MW**

# NYISO TRANSFER LIMITATIONS

Thursday ,April 28, 2022 to Saturday ,October 28, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>FROST_BR-LONG_MTN_345_352</b>					FWD	
Thu 06/09/2022	to	Sat 06/18/2022	<u>UPDATED</u>	<u>by ISONE</u> <u>03/04/2022</u>	(Import)	
0700	Continuous	1600			<b>1150 MW</b>	
Work scheduled by: ISONE					Impacts Total Transfer Capability	250 MW
					TTC with All Lines In Service	1400 MW
<b>SCH-NE-NYISO_LIMIT_200</b>					FWD	
Thu 06/09/2022	to	Sat 06/18/2022	<u>UPDATED</u>	<u>by ISONE</u> <u>03/04/2022</u>	(Import)	
0700	Continuous	1600			<b>400 MW</b>	
Work scheduled by: ISONE					Impacts Total Transfer Capability	1000 MW
					TTC with All Lines In Service	1400 MW
<b>NIAGARA_-DYSINGER_345_ND1</b>					FWD	
Mon 06/13/2022	to	Fri 06/17/2022			(Import)	
0500	Continuous	2100			<b>2700 MW</b>	
Work scheduled by: NYPA					Impacts Total Transfer Capability	450 MW
					TTC with All Lines In Service	3150 MW
<b>OAKDALE_-FRASER___345_32</b>					FWD	
Wed 06/15/2022	to	Fri 06/17/2022			(Import)	
0800	Continuous	1600			<b>2450 MW</b>	
Work scheduled by: NYSEG					Impacts Total Transfer Capability	135 MW
					TTC with All Lines In Service	2585 MW
<b>MARCY_-EDIC___345_UE1-7</b>					FWD	
Sat 06/18/2022	to	Sun 06/19/2022			(Import)	
0600	Continuous	1830			<b>5250 MW</b>	
Work scheduled by: NYPA					Impacts Total Transfer Capability	0 MW
					TTC with All Lines In Service	5250 MW
<b>NIAGARA_-PACKARD___230_62</b>					FWD	REV
Mon 06/20/2022	to	Sun 06/26/2022	<u>UPDATED</u>	<u>by NYPA</u> <u>04/19/2022</u>	(Import)	(Export)
0500	Continuous	1700			<b>700 MW</b>	<b>1550 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	1250 MW
					TTC with All Lines In Service	1950 MW
<b>FRASER_-GILBOA___345_GF5-35</b>					FWD	
Tue 06/21/2022	to	Sun 06/26/2022			(Import)	
0700	Continuous	1530			<b>2450 MW</b>	
Work scheduled by: NYPA					Impacts Total Transfer Capability	135 MW
					TTC with All Lines In Service	2585 MW

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## BEAR SWP-EASTOVER\_230\_E205W

Mon 06/27/2022 to Tue 06/28/2022  
0700 Continuous 0759

Work scheduled by: ISONE

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

## NIAGARA\_345\_230\_AT4

Tue 06/28/2022 to Wed 06/29/2022  
0500 Continuous 1700

Work scheduled by: NYPA

FWD REV  
(Import) (Export)

SCH - OH - NY

**1900 MW 1400 MW**

Impacts Total Transfer Capability 50 MW 300 MW

TTC with All Lines In Service 1950 MW 1700 MW

## BEAR SWP-EASTOVER\_230\_E205W

Tue 06/28/2022 to Tue 06/28/2022  
0800 Daily(No Weekends) 1500

Work scheduled by: NGrid

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

## BEAR SWP-EASTOVER\_230\_E205W

Tue 06/28/2022 to Thu 06/30/2022  
1501 Continuous 1700

Work scheduled by: ISONE

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

## BECK\_\_\_\_-NIAGARA\_230\_PA27

Tue 07/05/2022 to Sat 07/09/2022  
0500 Continuous 2100

Work scheduled by: NYPA

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

## NIAGARA\_-DYSINGER\_345\_ND1

Mon 07/11/2022 to Fri 07/15/2022  
0500 Continuous 1700

Work scheduled by: NYPA

FWD  
(Import)

DYSINGER EAST

**2700 MW**

Impacts Total Transfer Capability 450 MW

TTC with All Lines In Service 3150 MW

## HURLYAVE-ROSETON\_345\_303

Mon 07/11/2022 to Fri 07/22/2022  
0800 Continuous 1600

Work scheduled by: CHGE

02/14/2022

FWD  
(Import)

UPNY CONED

**4100 MW**

Impacts Total Transfer Capability 3715 MW

TTC with All Lines In Service 7815 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,April 28, 2022 to Saturday ,October 28, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## ROCHESTR-PANNELL\_\_345\_RP1

Mon 07/25/2022 to Fri 07/29/2022

0500 Continuous 2100

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST **2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

## FRASANNX-COOPERS\_\_345\_UCC2-41

Mon 07/25/2022 to Fri 08/05/2022

0700 Continuous 1700

Work scheduled by: NYPA

**ARR: 19**

FWD

(Import)

CENTRAL EAST - VC **2275 MW**

Impacts Total Transfer Capability 310 MW

TTC with All Lines In Service 2585 MW

## MARCY\_\_-FRASANNX\_345\_UCC2-41

Mon 07/25/2022 to Fri 08/05/2022

0700 Continuous 1700

Work scheduled by: NYPA

**ARR: 19**

FWD

(Import)

CENTRAL EAST - VC **2275 MW**

Impacts Total Transfer Capability 310 MW

TTC with All Lines In Service 2585 MW

## NIAGARA\_-DYSINGER\_345\_ND2

Mon 08/01/2022 to Fri 08/05/2022

0500 Continuous 1700

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST **2700 MW**

Impacts Total Transfer Capability 450 MW

TTC with All Lines In Service 3150 MW

## MARCY\_\_-EDIC\_\_\_\_345\_UE1-7

Sat 08/06/2022 to Sun 08/07/2022

0500 Continuous 1830

Work scheduled by: NYPA

**UPDATED**

**by NYPA 04/07/2022**

**ARR: 19&16**

FWD

(Import)

OSWEGO EXPORT **5250 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

## VOLNEY\_\_-MARCY\_\_\_\_345\_19

Sat 08/06/2022 to Sun 08/07/2022

0500 Continuous 1830

Work scheduled by: NYPA

**UPDATED**

**by NYPA 04/07/2022**

**ARR: 19**

FWD

(Import)

CENTRAL EAST - VC **2475 MW**

Impacts Total Transfer Capability 110 MW

TTC with All Lines In Service 2585 MW

## VOLNEY\_\_-MARCY\_\_\_\_345\_19

Sat 08/06/2022 to Sun 08/07/2022

0500 Continuous 1830

Work scheduled by: NYPA

**UPDATED**

**by NYPA 04/07/2022**

**ARR: 19**

FWD

(Import)

OSWEGO EXPORT **4900 MW**

Impacts Total Transfer Capability 350 MW

TTC with All Lines In Service 5250 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,April 28, 2022 to Saturday ,October 28, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## FRASANNX-COOPERS\_\_345\_UCC2-41

FWD

Mon 08/08/2022 to Fri 09/09/2022

(Import)

0700 Continuous 1700

CENTRAL EAST - VC

**2275 MW**

Impacts Total Transfer Capability 310 MW

TTC with All Lines In Service 2585 MW

Work scheduled by: NYPA

**ARR: 19**

## MARCY\_\_-FRASANNX\_345\_UCC2-41

FWD

Mon 08/08/2022 to Fri 09/09/2022

(Import)

0700 Continuous 1700

CENTRAL EAST - VC

**2275 MW**

Impacts Total Transfer Capability 310 MW

TTC with All Lines In Service 2585 MW

Work scheduled by: NYPA

**ARR: 19**

## SAND\_BAR-PLATSBURG\_115\_PV20

Mon 08/22/2022 to Fri 08/26/2022

0700 Continuous 1530

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: NYPA

## ROSETON\_-ROCKTVRN\_345\_311

FWD

Mon 08/29/2022 to Fri 09/09/2022

(Import)

0800 Continuous 1600

UPNY CONED

**4400 MW**

Impacts Total Transfer Capability 3415 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: CHGE

## MOTTHAVN-RAINEY\_\_345\_Q12

FWD

Thu 09/01/2022 to Mon 09/05/2022

(Import)

0001 Continuous 0200

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

## FRASER\_\_-GILBOA\_\_345\_GF5-35

FWD

Mon 09/12/2022 to Sun 09/18/2022

(Import)

0700 Continuous 1530

CENTRAL EAST - VC

**2450 MW**

Impacts Total Transfer Capability 135 MW

TTC with All Lines In Service 2585 MW

Work scheduled by: NYPA

## MARCY\_\_-EDIC\_\_345\_UE1-7

FWD

Mon 09/19/2022 to Sat 10/08/2022

(Import)

0700 Continuous 1530

OSWEGO EXPORT

**5250 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NYPA

**ARR: 19&16**

# NYISO TRANSFER LIMITATIONS

Thursday ,April 28, 2022 to Saturday ,October 28, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>LEEDS___-HURLYAVE_345_301</b>						FWD	
Mon 09/19/2022	to	Fri 10/21/2022		<u>10/04/2021</u>	(Import)		
0800	Continuous	1600			UPNY CONED	<b>4100 MW</b>	
Work scheduled by: CHGE					Impacts Total Transfer Capability	3715 MW	
					TTC with All Lines In Service	7815 MW	
<b>EGRDNCTY_345_138_AT1</b>						FWD	
Sat 10/01/2022	to	Wed 05/31/2023	<u>UPDATED</u>	<u>by CONED</u>	<u>03/10/2022</u>	(Import)	
0001	Continuous	2359			CONED - LIPA	<b>1250 MW</b>	
Work scheduled by: LI					Impacts Total Transfer Capability	250 MW	
					TTC with All Lines In Service	1500 MW	
<b>EGRDNCTY_345_138_AT2</b>						FWD	
Sat 10/01/2022	to	Wed 05/31/2023	<u>UPDATED</u>	<u>by CONED</u>	<u>03/10/2022</u>	(Import)	
0001	Continuous	2359			CONED - LIPA	<b>1250 MW</b>	
Work scheduled by: LI					Impacts Total Transfer Capability	250 MW	
					TTC with All Lines In Service	1500 MW	
<b>SPRNBK_-EGRDNCTR_345_Y49</b>						FWD	
Sat 10/01/2022	to	Wed 05/31/2023	<u>UPDATED</u>	<u>by CONED</u>	<u>03/10/2022</u>	(Import)	
0001	Continuous	2359			CONED - LIPA	<b>775 MW</b>	
Work scheduled by: LI					Impacts Total Transfer Capability	725 MW	
					TTC with All Lines In Service	1500 MW	
<b>CLRKSCRN-OAKDALE__345_36</b>						FWD	
Mon 10/03/2022	to	Fri 10/07/2022	<u>UPDATED</u>	<u>by NYSEG</u>	<u>04/20/2022</u>	(Import)	
0830	Continuous	1530			CENTRAL EAST - VC	<b>2450 MW</b>	
Work scheduled by: NYSEG					Impacts Total Transfer Capability	135 MW	
					TTC with All Lines In Service	2585 MW	
<b>SHOR_NPX-SHOREHAM_138_CSC</b>						FWD	
Mon 10/03/2022	to	Fri 10/21/2022	<u>UPDATED</u>	<u>by LI</u>	<u>01/07/2022</u>	REV	
1000	Continuous	1500			SCH - NPX_CSC	(Import) (Export)	
Work scheduled by: LI					Impacts Total Transfer Capability	<b>0 MW</b> <b>0 MW</b>	
					TTC with All Lines In Service	330 MW 330 MW	
<b>EDIC___-GORDONRD_345_14</b>						FWD	
Mon 10/10/2022	to	Mon 10/31/2022				(Import)	
0700	Continuous	1530			CENTRAL EAST - VC	<b>1695 MW</b>	
Work scheduled by: NYPA					Impacts Total Transfer Capability	890 MW	
					TTC with All Lines In Service	2585 MW	

**NYISO TRANSFER LIMITATIONS**

Thursday ,April 28, 2022 to Saturday ,October 28, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**NIAGARA\_-DYSINGER\_345\_ND1**

FWD

Mon 10/17/2022 to Fri 10/21/2022 UPDATED by NYPA 02/10/2022  
0500 Continuous 1700

(Import)

Work scheduled by: NYPA

DYSINGER EAST **2700 MW**  
Impacts Total Transfer Capability 450 MW  
TTC with All Lines In Service 3150 MW

**PANNELL\_-CLAY\_345\_1**

FWD

Mon 10/24/2022 to Fri 10/28/2022  
0700 Continuous 1530

(Import)

Work scheduled by: NYPA

WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

**HURLYAVE-ROSETON\_345\_303**

FWD

Mon 10/24/2022 to Fri 11/04/2022 UPDATED by CH 04/13/2022  
0800 Continuous 1600

(Import)

Work scheduled by: CHGE

UPNY CONED **4100 MW**  
Impacts Total Transfer Capability 3715 MW  
TTC with All Lines In Service 7815 MW

**MAINESBG-WATRCURE\_345\_30**

FWD

Tue 10/25/2022 to Tue 10/25/2022  
0800 Daily 1500

(Import)

Work scheduled by: NYSEG

SCH - PJ - NY **2200 MW**  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 2250 MW

**WATRCURE-OAKDALE\_345\_31**

Thu 10/27/2022 to Thu 10/27/2022  
0800 Daily 1500

Work scheduled by: NYSEG

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

**PANNELL\_-CLAY\_345\_2**

FWD

Mon 10/31/2022 to Fri 11/04/2022  
0700 Continuous 1530

(Import)

Work scheduled by: NYPA

WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

**CLAY\_-EDIC\_345\_1-16**

FWD

Tue 11/01/2022 to Thu 11/03/2022  
0600 Continuous 1900

(Import)

Work scheduled by: NGrid

OSWEGO EXPORT **4850 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW



# NYISO TRANSFER LIMITATIONS

Thursday ,April 28, 2022 to Saturday ,October 28, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### GILBOA\_\_-N.SCTLND\_345\_GNS-1

Tue 11/01/2022 to Tue 12/06/2022  
0700 Continuous 1900  
Work scheduled by: NGrid

UPDATED by NGRID 12/29/2021

FWD  
(Import)  
CENTRAL EAST - VC **2300 MW**  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 2585 MW

### LEEDS\_\_\_\_345KV\_R94301

Tue 11/01/2022 to Tue 12/06/2022  
0700 Continuous 1900  
Work scheduled by: NGrid

UPDATED by NGRID 12/29/2021

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

### MARCY\_\_-N.SCTLND\_345\_18

Tue 11/01/2022 to Tue 12/06/2022  
0700 Continuous 1900  
Work scheduled by: NGrid

UPDATED by NGRID 12/29/2021

ARR: 19

FWD  
(Import)  
CENTRAL EAST - VC **1400 MW**  
Impacts Total Transfer Capability 1185 MW  
TTC with All Lines In Service 2585 MW

### LINDN.CG-LNDVFT\_\_\_\_345\_V-3022

Tue 11/01/2022 to Fri 11/04/2022  
0800 Continuous 1500  
Work scheduled by: PJM

UPDATED by NGRID 12/29/2021

FWD REV  
(Import) (Export)  
SCH - PJM\_VFT **0 MW 0 MW**  
Impacts Total Transfer Capability 315 MW 315 MW  
TTC with All Lines In Service 315 MW 315 MW

### LEEDS\_\_-HURLYAVE\_345\_301

Mon 11/07/2022 to Fri 12/09/2022  
0800 Continuous 1600  
Work scheduled by: CHGE

UPDATED by NGRID 12/29/2021

FWD  
(Import)  
UPNY CONED **4100 MW**  
Impacts Total Transfer Capability 3715 MW  
TTC with All Lines In Service 7815 MW

### MOSES\_\_-ADIRNDCK\_230\_MAI

Wed 11/30/2022 to Wed 03/01/2023  
0700 Continuous 1100  
Work scheduled by: NYPA

UPDATED by NGRID 12/29/2021

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

### CLAY\_\_\_\_-EDIC\_\_\_\_345\_1-16

Fri 12/30/2022 to Sat 12/31/2022  
0600 Continuous 1900  
Work scheduled by: NGrid

UPDATED by NGRID 12/29/2021

FWD  
(Import)  
OSWEGO EXPORT **4850 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

# NYISO TRANSFER LIMITATIONS

Thursday ,April 28, 2022 to Saturday ,October 28, 2023

## Seasonal Limits

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### FRASER\_\_\_345\_FRASER SVC

FWD

Tue 01/03/2023 to Tue 02/28/2023  
0700 Continuous 1730

UPDATED by NYPA 12/30/2021

Work scheduled by: NYPA

CENTRAL EAST - VC **2550 MW**  
Impacts Total Transfer Capability 35 MW  
TTC with All Lines In Service 2585 MW

### PLSNTVLY\_345KV\_RNS4

FWD

Sat 04/01/2023 to Sat 04/01/2023  
0700 Continuous 0730

Work scheduled by: NGrid

(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

### ATHENS\_\_-PLSNTVLY\_345\_91

FWD

Sat 04/01/2023 to Sat 04/15/2023  
0700 Continuous 1900

Work scheduled by: NGrid

(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

### PLSNTVLY\_345KV\_RNS4

FWD

Sat 04/15/2023 to Sat 04/15/2023  
1830 Continuous 1900

Work scheduled by: NGrid

(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

### PLSNTVLY\_345KV\_RNS5

FWD

Sun 04/16/2023 to Sun 04/16/2023  
0700 Continuous 0730

Work scheduled by: NGrid

(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

### LEEDS\_\_-PLSNTVLY\_345\_92

FWD

Sun 04/16/2023 to Sun 04/30/2023  
0700 Continuous 1900

Work scheduled by: NGrid

(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

### PLSNTVLY\_345KV\_RNS5

FWD

Sun 04/30/2023 to Sun 04/30/2023  
1830 Continuous 1900

Work scheduled by: NGrid

(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

**NYISO TRANSFER LIMITATIONS**

Thursday ,April 28, 2022 to Saturday ,October 28, 2023

CENTRAL EAST	3100MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6500MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3150MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SHOR_NPX-SHOREHAM_138_CSC</b>			FWD	REV
Mon 05/01/2023	to	Fri 05/05/2023	(Import)	(Export)
0600	Continuous	1800	SCH - NPX_CSC	<b>0 MW</b>
Work scheduled by: LI			Impacts Total Transfer Capability	330 MW
			TTC with All Lines In Service	330 MW
<b>SHOR_NPX-SHOREHAM_138_CSC</b>			FWD	REV
Mon 10/02/2023	to	Fri 10/06/2023	(Import)	(Export)
0600	Continuous	1800	SCH - NPX_CSC	<b>0 MW</b>
Work scheduled by: LI			Impacts Total Transfer Capability	330 MW
			TTC with All Lines In Service	330 MW
<b>NEPTUNE_-DUFFYAVE_345_NEPTUNE</b>			FWD	
Mon 10/09/2023	to	Fri 10/13/2023	(Import)	
0600	Continuous	1600	SCH - PJM_NEPTUNE	<b>0 MW</b>
Work scheduled by: LI			Impacts Total Transfer Capability	660 MW
			TTC with All Lines In Service	660 MW
<b>NEWBRDGE-DUFFYAVE_345_501</b>			FWD	
Mon 10/09/2023	to	Fri 10/13/2023	(Import)	
0600	Continuous	1600	SCH - PJM_NEPTUNE	<b>0 MW</b>
Work scheduled by: LI			Impacts Total Transfer Capability	660 MW
			TTC with All Lines In Service	660 MW
<b>NEWBRDGE_345_138_BK_1</b>			FWD	
Mon 10/09/2023	to	Fri 10/13/2023	(Import)	
0600	Continuous	1600	SCH - PJM_NEPTUNE	<b>375 MW</b>
Work scheduled by: LI			Impacts Total Transfer Capability	285 MW
			TTC with All Lines In Service	660 MW
<b>NEWBRDGE_345_138_BK_2</b>			FWD	
Mon 10/09/2023	to	Fri 10/13/2023	(Import)	
0600	Continuous	1600	SCH - PJM_NEPTUNE	<b>375 MW</b>
Work scheduled by: LI			Impacts Total Transfer Capability	285 MW
			TTC with All Lines In Service	660 MW