

# NYISO TRANSFER LIMITATIONS

Wednesday, June 01, 2022 to Friday , December 01, 2023

## Seasonal Limits

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### HUDSONP\_-FARRAGUT\_345\_B3402

Mon 01/15/2018 to Sat 12/31/2022 EXT FORCE by CONED 05/14/2022

0001 Continuous 2359

Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJ - NY **2050 MW**  
Impacts Total Transfer Capability 200 MW  
TTC with All Lines In Service 2250 MW

### HUDSONP\_-FARRAGUT\_345\_B3402 & MARION\_-FARRAGUT\_345\_C3403

Mon 01/15/2018 to Sat 12/31/2022

0001 2359

Work scheduled by:

FWD REV  
(Import) (Export)  
SCH - PJ - NY **2000 MW 1150 MW**  
Impacts Total Transfer Capability 250 MW 100 MW  
TTC with All Lines In Service 2250 MW 1250 MW

### MARION\_-FARRAGUT\_345\_C3403

Mon 01/15/2018 to Sat 12/31/2022 EXT FORCE by CONED 05/14/2022

0001 Continuous 2359

Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJ - NY **2050 MW**  
Impacts Total Transfer Capability 200 MW  
TTC with All Lines In Service 2250 MW

### STLAWRNC-MOSES\_230\_L33P

Mon 04/30/2018 to Wed 07/27/2022 EXT FORCE by IESO 05/18/2022

0456 Continuous 1600

Work scheduled by: IESO

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

### NEWBRDGE\_345\_138\_BK\_1

Wed 09/02/2020 to Mon 08/01/2022 EXT FORCE by LI 12/10/2021

1807 Continuous 2359

Work scheduled by: LI

FWD  
(Import)  
SCH - PJM\_NEPTUNE **375 MW**  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 660 MW

### BECK\_-NIAGARA\_345\_PA301

Wed 02/09/2022 to Fri 06/17/2022 UPDATED by NYISO 04/29/2022

0700 Continuous 1700

Work scheduled by: IESO

FWD REV  
(Import) (Export)  
SCH - OH - NY **900 MW 800 MW**  
Impacts Total Transfer Capability 1050 MW 900 MW  
TTC with All Lines In Service 1950 MW 1700 MW

### EDIC\_-N.SCTLND\_345\_14

Tue 03/08/2022 to Fri 05/27/2022 UPDATED by NGRID 05/17/2022

0700 Continuous 0900

Work scheduled by: NGrid

FWD  
(Import)  
CENTRAL EAST - VC **1695 MW**  
Impacts Total Transfer Capability 890 MW  
TTC with All Lines In Service 2585 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, June 01, 2022 to Friday , December 01, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

N.SCTLND-ALPS_____345_2					FWD	
Tue 03/08/2022	to	Fri 06/03/2022	<u>UPDATED</u>	<u>by NGRID</u>	<u>05/17/2022</u>	(Import)
0700	Continuous	1900				
Work scheduled by: NGrid					SCH - NE - NY	<b>750 MW</b>
					Impacts Total Transfer Capability	650 MW
					TTC with All Lines In Service	1400 MW
N.SCTLND-ALPS_____345_2					FWD	REV
Tue 03/08/2022	to	Fri 06/03/2022	<u>UPDATED</u>	<u>by NGRID</u>	<u>05/17/2022</u>	(Import) (Export)
0700	Continuous	1900				
Work scheduled by: NGrid					SCH - NPX_1385	<b>100 MW</b> <b>100 MW</b>
					Impacts Total Transfer Capability	100 MW 100 MW
					TTC with All Lines In Service	200 MW 200 MW
EGRDNCTY_345_138_AT1					FWD	
Sat 03/12/2022	to	Fri 06/10/2022	<u>EXT FORCE</u>	<u>by CE</u>	<u>05/04/2022</u>	(Import)
2148	Continuous	2359				
Work scheduled by: ConEd					CONED - LIPA	<b>1250 MW</b>
					Impacts Total Transfer Capability	250 MW
					TTC with All Lines In Service	1500 MW
EGRDNCTY_345_138_AT2					FWD	
Sat 03/12/2022	to	Fri 06/10/2022	<u>EXT FORCE</u>	<u>by CE</u>	<u>05/04/2022</u>	(Import)
2148	Continuous	2359				
Work scheduled by: ConEd					CONED - LIPA	<b>1250 MW</b>
					Impacts Total Transfer Capability	250 MW
					TTC with All Lines In Service	1500 MW
SPRNBK_ -EGRDNCTR_345_Y49					FWD	
Sat 03/12/2022	to	Fri 06/10/2022	<u>EXT FORCE</u>	<u>by CE</u>	<u>05/04/2022</u>	(Import)
2148	Continuous	2359				
Work scheduled by: ConEd					CONED - LIPA	<b>775 MW</b>
					Impacts Total Transfer Capability	725 MW
					TTC with All Lines In Service	1500 MW
W49TH_ST_345KV_6					FWD	
Mon 03/21/2022	to	Thu 06/16/2022	<u>EXT FORCE</u>	<u>by CE</u>	<u>05/02/2022</u>	(Import)
0809	Continuous	2359				
Work scheduled by: ConEd					SCH - PJM_HTP	<b>300 MW</b>
					Impacts Total Transfer Capability	360 MW
					TTC with All Lines In Service	660 MW
W49TH_ST_345KV_8					FWD	
Mon 03/21/2022	to	Thu 06/16/2022	<u>EXT FORCE</u>	<u>by CE</u>	<u>05/02/2022</u>	(Import)
0811	Continuous	2359				
Work scheduled by: ConEd					SCH - PJM_HTP	<b>450 MW</b>
					Impacts Total Transfer Capability	210 MW
					TTC with All Lines In Service	660 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, June 01, 2022 to Friday , December 01, 2023

## Seasonal Limits

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### FIVEMILE-STOLLERD\_345\_29

Fri 04/01/2022 to Tue 12/31/2030 EXTENDED by NYSEG 05/31/2022

0500 Continuous 2359

Work scheduled by: NYSEG

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

### GOETHALS\_345KV\_5

Wed 04/20/2022 to Sun 05/29/2022 EXTENDED by CONED 05/26/2022

0301 Continuous 0201

Work scheduled by: ConEd

STATEN ISLAND

Impacts Total Transfer Capability

TTC with All Lines In Service

### LINDEN\_\_GOETHALS\_230\_A2253

Wed 04/20/2022 to Sun 05/29/2022 EXTENDED by CONED 05/26/2022

0301 Continuous 0201

Work scheduled by: ConEd

FWD

(Import)

SCH - PJ - NY

**2050 MW**

Impacts Total Transfer Capability 200 MW

TTC with All Lines In Service 2250 MW

### LINDEN\_\_GOETHALS\_230\_A2253 & HUDSONP\_-FARRAGUT\_345\_B3402

Wed 04/20/2022 to Sun 05/29/2022

0301 0201

Work scheduled by:

FWD

REV

(Import) (Export)

SCH - PJ - NY

**2000 MW 1150 MW**

Impacts Total Transfer Capability 250 MW 100 MW

TTC with All Lines In Service 2250 MW 1250 MW

### LINDEN\_\_GOETHALS\_230\_A2253 & HUDSONP\_-FARRAGUT\_345\_B3402 & MARION\_\_-FARRAGUT\_345\_C3403

Wed 04/20/2022 to Sun 05/29/2022

0301 0201

Work scheduled by:

FWD

REV

(Import) (Export)

SCH - PJ - NY

**2000 MW 1150 MW**

Impacts Total Transfer Capability 250 MW 100 MW

TTC with All Lines In Service 2250 MW 1250 MW

### LINDEN\_\_GOETHALS\_230\_A2253 & MARION\_\_-FARRAGUT\_345\_C3403

Wed 04/20/2022 to Sun 05/29/2022

0301 0201

Work scheduled by:

FWD

REV

(Import) (Export)

SCH - PJ - NY

**2000 MW 1150 MW**

Impacts Total Transfer Capability 250 MW 100 MW

TTC with All Lines In Service 2250 MW 1250 MW

### EDIC\_\_\_\_-N.SCTLND\_345\_14 & GORDONRD-ROTTRDAM\_230\_31

Wed 04/27/2022 to Fri 05/27/2022

1130 0900

Work scheduled by:

FWD

(Import)

CENTRAL EAST - VC

**1645 MW**

Impacts Total Transfer Capability 940 MW

TTC with All Lines In Service 2585 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, June 01, 2022 to Friday , December 01, 2023

## Seasonal Limits

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

GORDONRD-ROTTRDAM_230_31						FWD
Wed 04/27/2022	to	Mon 10/31/2022	<u>EXT FORCE</u>	<u>by NYISO</u>	<u>05/17/2022</u>	(Import)
1130	Continuous	2359				CENTRAL EAST - VC <b>2535 MW</b>
Work scheduled by: NYISO						Impacts Total Transfer Capability 50 MW
						TTC with All Lines In Service 2585 MW
SCH-IMO-NYISO_LIMIT_500						FWD
Sun 05/01/2022	to	Fri 06/17/2022	<u>UPDATED</u>	<u>by NYISO</u>	<u>04/29/2022</u>	(Import)
0001	Continuous	1700				SCH - OH - NY <b>800 MW</b>
Work scheduled by: IESO						Impacts Total Transfer Capability 1150 MW
						TTC with All Lines In Service 1950 MW
SCH-IMO-NYISO_LIMIT_1400						FWD
Sun 05/01/2022	to	Wed 07/27/2022	<u>UPDATED</u>	<u>by IESO</u>	<u>05/18/2022</u>	(Import)
0001	Continuous	1600				SCH - OH - NY <b>1700 MW</b>
Work scheduled by: IESO						Impacts Total Transfer Capability 250 MW
						TTC with All Lines In Service 1950 MW
SCH-IMO-NYISO_LIMIT_1600						FWD
Sun 05/01/2022	to	Wed 07/27/2022	<u>UPDATED</u>	<u>by IESO</u>	<u>05/18/2022</u>	(Import)
0001	Continuous	1600				SCH - OH - NY <b>1900 MW</b>
Work scheduled by: IESO						Impacts Total Transfer Capability 50 MW
						TTC with All Lines In Service 1950 MW
SCH-NYISO-IMO_LIMIT_1200						REV
Sun 05/01/2022	to	Wed 07/27/2022	<u>UPDATED</u>	<u>by IESO</u>	<u>05/18/2022</u>	(Export)
0001	Continuous	1600				SCH - OH - NY <b>1500 MW</b>
Work scheduled by: IESO						Impacts Total Transfer Capability 200 MW
						TTC with All Lines In Service 1700 MW
SCH-NYISO-IMO_LIMIT_1400						REV
Sun 05/01/2022	to	Wed 07/27/2022	<u>UPDATED</u>	<u>by IESO</u>	<u>05/18/2022</u>	(Export)
0001	Continuous	1600				SCH - OH - NY <b>1700 MW</b>
Work scheduled by: IESO						Impacts Total Transfer Capability 0 MW
						TTC with All Lines In Service 1700 MW
CHAT_DC_GC2						FWD
Sun 05/01/2022	to	Thu 06/02/2022	<u>UPDATED</u>	<u>by HQ</u>	<u>05/26/2022</u>	(Import)
0500	Continuous	1300				MOSES SOUTH <b>2850 MW</b>
Work scheduled by: HQ						Impacts Total Transfer Capability 300 MW
						TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, June 01, 2022 to Friday , December 01, 2023

## Seasonal Limits

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>CHAT_DC_GC2</b>						REV	
Sun 05/01/2022	to	Thu 06/02/2022	<u>UPDATED</u>	<u>by HQ</u>	<u>05/26/2022</u>	(Export)	
0500	Continuous	1300					
Work scheduled by: HQ						SCH - HQ - NY	<b>500 MW</b>
						Impacts Total Transfer Capability	500 MW
						TTC with All Lines In Service	1000 MW
<b>SCH-NYISO-HQ_LIMIT_500</b>						REV	
Sun 05/01/2022	to	Thu 06/02/2022	<u>UPDATED</u>	<u>by HQ</u>	<u>05/26/2022</u>	(Export)	
0500	Continuous	1300					
Work scheduled by: HQ						SCH - HQ - NY	<b>500 MW</b>
						Impacts Total Transfer Capability	500 MW
						TTC with All Lines In Service	1000 MW
<b>E13THSTA-FARRAGUT_345_46</b>						FWD	
Mon 05/09/2022	to	Tue 05/31/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>05/31/2022</u>	(Import)	
0301	Continuous	0644					
Work scheduled by: ConEd						SPR/DUN-SOUTH	<b>3800 MW</b>
						Impacts Total Transfer Capability	800 MW
						TTC with All Lines In Service	4600 MW
<b>SCH-NYISO-IMO_LIMIT_400</b>						REV	
Wed 05/18/2022	to	Fri 06/17/2022	<u>FORCED</u>	<u>by IESO</u>	<u>05/05/2022</u>	(Export)	
0001	Continuous	1700					
Work scheduled by: IESO						SCH - OH - NY	<b>700 MW</b>
						Impacts Total Transfer Capability	1000 MW
						TTC with All Lines In Service	1700 MW
<b>PIERCBRK-FIVEMILE_345_37</b>							
Mon 05/23/2022	to	Fri 05/27/2022	<u>FORCED</u>	<u>by NGRID</u>	<u>05/23/2022</u>		
1036	Continuous	1900					
Work scheduled by: NGrid						SCH - PJ - NY	
						Impacts Total Transfer Capability	
						TTC with All Lines In Service	
<b>CRICKVLY-PLSNTVLY_345_F84</b>						FWD	
Wed 05/25/2022	to	Fri 05/27/2022	<u>UPDATED</u>	<u>by CE</u>	<u>05/25/2022</u>	(Import)	
0001	Continuous	2200					
Work scheduled by: ConEd						SCH - NE - NY	<b>350 MW</b>
						Impacts Total Transfer Capability	1050 MW
						TTC with All Lines In Service	1400 MW
<b>CRICKVLY-PLSNTVLY_345_F84</b>						FWD	REV
Wed 05/25/2022	to	Fri 05/27/2022	<u>UPDATED</u>	<u>by CE</u>	<u>05/25/2022</u>	(Import)	(Export)
0001	Continuous	2200					
Work scheduled by: ConEd						SCH - NPX_1385	<b>100 MW</b>
						Impacts Total Transfer Capability	100 MW
						TTC with All Lines In Service	200 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, June 01, 2022 to Friday , December 01, 2023

## Seasonal Limits

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### W49TH\_ST-E13THSTA\_345\_M55

FWD

Wed 05/25/2022 to Mon 05/30/2022

UPDATED

by CE

05/30/2022

(Import)

0001 Continuous 0256

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

### MARCY -EDIC 345 UE1-7

FWD

Sat 05/28/2022 to Sat 05/28/2022

UPDATED

by NYPA

05/25/2022

(Import)

0500 Continuous 1930

OSWEGO EXPORT

**5250 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NYPA

**ARR: 19&16**

### SCH-HQ-NYISO\_LIMIT\_1150

FWD

Sat 05/28/2022 to Sat 05/28/2022

UPDATED

by HQ

05/26/2022

(Import)

0500 Continuous 1930

SCH - HQ - NY

**1150 MW**

Impacts Total Transfer Capability 350 MW

TTC with All Lines In Service 1500 MW

Work scheduled by: HQ

### VOLNEY -MARCY 345\_19

FWD

Sat 05/28/2022 to Sat 05/28/2022

UPDATED

by NYPA

05/25/2022

(Import)

0500 Continuous 1930

CENTRAL EAST - VC

**2475 MW**

Impacts Total Transfer Capability 110 MW

TTC with All Lines In Service 2585 MW

Work scheduled by: NYPA

**ARR: 19**

### VOLNEY -MARCY 345\_19

FWD

Sat 05/28/2022 to Sat 05/28/2022

UPDATED

by NYPA

05/25/2022

(Import)

0500 Continuous 1930

OSWEGO EXPORT

**4900 MW**

Impacts Total Transfer Capability 350 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NYPA

**ARR: 19**

### VOLNEY -MARCY 345\_19 & GORDONRD-ROTTDAM\_230\_31

FWD

Sat 05/28/2022 to Sat 05/28/2022

CENTRAL EAST - VC

**2425 MW**

0500 1930

Impacts Total Transfer Capability 160 MW

TTC with All Lines In Service 2585 MW

Work scheduled by:

**ARR: 19**

### CHAT\_DC\_GC1

FWD

Sun 05/29/2022 to Sun 05/29/2022

MOSES SOUTH

**2850 MW**

0001 Continuous 0200

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: HQ

# NYISO TRANSFER LIMITATIONS

Wednesday, June 01, 2022 to Friday , December 01, 2023

## Seasonal Limits

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>CHAT_DC_GC1</b>						REV
Sun 05/29/2022	to	Sun 05/29/2022				(Export)
0001	Continuous	0200			SCH - HQ - NY	<b>500 MW</b>
Work scheduled by: HQ					Impacts Total Transfer Capability	500 MW
					TTC with All Lines In Service	1000 MW
<b>CHAT_DC_GC1 &amp; CHAT_DC_GC2</b>						FWD
Sun 05/29/2022	to	Sun 05/29/2022				(Import)
0001		0200			MOSES SOUTH	<b>2550 MW</b>
Work scheduled by:					Impacts Total Transfer Capability	600 MW
					TTC with All Lines In Service	3150 MW
<b>CHAT_DC_GC1 &amp; CHAT_DC_GC2</b>						FWD REV
Sun 05/29/2022	to	Sun 05/29/2022				(Import) (Export)
0001		0200			SCH - HQ - NY	<b>1370 MW 0 MW</b>
Work scheduled by:					Impacts Total Transfer Capability	130 MW 1000 MW
					TTC with All Lines In Service	1500 MW 1000 MW
<b>SCH-HQ-NYISO_LIMIT_1150</b>						FWD
Sun 05/29/2022	to	Sun 05/29/2022				(Import)
0001	Continuous	0200			SCH - HQ - NY	<b>1150 MW</b>
Work scheduled by: HQ					Impacts Total Transfer Capability	350 MW
					TTC with All Lines In Service	1500 MW
<b>EFISHKIL-WOOD_ST_345_F38</b>						FWD
Sun 05/29/2022	to	Tue 05/31/2022	<b>UPDATED</b>	<b>by CE</b>	<b>05/26/2022</b>	(Import)
0201	Continuous	0300				UPNY CONED
Work scheduled by: ConEd						<b>4000 MW</b>
					Impacts Total Transfer Capability	3815 MW
					TTC with All Lines In Service	7815 MW
<b>PLSNTVLE-DUNWODIE_345_W89</b>						FWD
Sun 05/29/2022	to	Tue 05/31/2022	<b>UPDATED</b>	<b>by CE</b>	<b>05/26/2022</b>	(Import)
0201	Continuous	0300				UPNY CONED
Work scheduled by: ConEd						<b>4000 MW</b>
					Impacts Total Transfer Capability	3815 MW
					TTC with All Lines In Service	7815 MW
<b>WOOD_ST_-PLSNTVLE_345_Y86</b>						FWD
Sun 05/29/2022	to	Tue 05/31/2022	<b>UPDATED</b>	<b>by CE</b>	<b>05/26/2022</b>	(Import)
0201	Continuous	0300				UPNY CONED
Work scheduled by: ConEd						<b>7210 MW</b>
					Impacts Total Transfer Capability	605 MW
					TTC with All Lines In Service	7815 MW

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MOSES\_\_\_-ADIRNDCK\_230\_MA2**

FWD

Tue 05/31/2022 to Thu 09/15/2022  
0500 Continuous 1930

UPDATEDby NYPA05/04/2022

(Import)

Work scheduled by: NYPA

MOSES SOUTH

**2100 MW**

Impacts Total Transfer Capability 1050 MW

TTC with All Lines In Service 3150 MW

**PANNELL\_-CLAY\_\_\_345\_2**

FWD

Tue 05/31/2022 to Thu 06/02/2022  
0700 Continuous 1500

(Import)

Work scheduled by: RGE

WEST CENTRAL

**1300 MW**

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW

**SCH-NYISO-NE\_LIMIT\_800**

REV

Tue 05/31/2022 to Fri 06/03/2022  
1500 Continuous 1900

UPDATEDby ISONE05/26/2022

(Export)

Work scheduled by: ISONE

SCH - NE - NY

**1000 MW**

Impacts Total Transfer Capability 600 MW

TTC with All Lines In Service 1600 MW

**SPRNBRK\_-TREMONT\_\_\_345\_X28**

FWD

Wed 06/01/2022 to Wed 06/01/2022  
0001 Continuous 0030

(Import)

Work scheduled by: ConEd

SPR/DUN-SOUTH

**4200 MW**

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 4600 MW

**PIERCBRK-FIVEMILE\_345\_37**

Wed 06/01/2022 to Thu 06/02/2022  
0730 Continuous 1600

Work scheduled by: NGrid

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

**SPRNBRK\_-TREMONT\_\_\_345\_X28**

FWD

Wed 06/01/2022 to Wed 06/01/2022  
1730 Continuous 1800

(Import)

Work scheduled by: ConEd

SPR/DUN-SOUTH

**4200 MW**

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 4600 MW

**SPRNBRK\_345KV\_RS3 & SPRNBRK\_345KV\_RS4**

FWD

Fri 06/03/2022 to Fri 06/03/2022  
0001 0030

(Import)

Work scheduled by:

SPR/DUN-SOUTH

**3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW



# NYISO TRANSFER LIMITATIONS

Wednesday, June 01, 2022 to Friday , December 01, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## SCH-NYISO-NE\_LIMIT\_0

Fri 06/03/2022 to Fri 06/03/2022 UPDATED by NGRID 05/17/2022

0001 Continuous 1900

Work scheduled by: NGrid

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

REV

(Export)

**200 MW**

1400 MW

1600 MW

## MARCY -EDIC 345 UE1-7

Fri 06/03/2022 to Sun 06/05/2022 UPDATED by NYPA 05/18/2022

0500 Continuous 1930

Work scheduled by: NYPA

ARR: 19&amp;16

OSWEGO EXPORT

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service

FWD

(Import)

**5250 MW**

0 MW

5250 MW

## SPRNBK 345KV\_RS3 &amp; SPRNBK 345KV\_RS4

Fri 06/03/2022 to Fri 06/03/2022

1730 1800

Work scheduled by:

SPR/DUN-SOUTH

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service

FWD

(Import)

**3200 MW**

1400 MW

4600 MW

## SCH-NE-NYISO\_LIMIT\_1000

Fri 06/03/2022 to Wed 06/08/2022 UPDATED by ISONE 05/26/2022

1900 Continuous 1600

Work scheduled by: ISONE

SCH - NE - NY

Impacts Total Transfer Capability 200 MW

TTC with All Lines In Service

FWD

(Import)

**1200 MW**

200 MW

1400 MW

## PLSNTVLY-WOOD\_ST 345\_F31

Sat 06/04/2022 to Sat 06/04/2022

0001 Continuous 2200

Work scheduled by: ConEd

UPNY CONED

Impacts Total Transfer Capability 3815 MW

TTC with All Lines In Service

FWD

(Import)

**4000 MW**

3815 MW

7815 MW

## EASTVIEW-SPRNBK 345\_W64

Sat 06/04/2022 to Mon 06/06/2022 CANCELLED by ConEd 05/27/2022

0201 Continuous 0200

Work scheduled by: ConEd

UPNY CONED

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service

FWD

(Import)

**4350 MW**

3465 MW

7815 MW

## MILLWOOD-EASTVIEW 345\_W99

Sat 06/04/2022 to Mon 06/06/2022 CANCELLED by ConEd 05/27/2022

0201 Continuous 0200

Work scheduled by: ConEd

UPNY CONED

Impacts Total Transfer Capability 265 MW

TTC with All Lines In Service

FWD

(Import)

**7550 MW**

265 MW

7815 MW

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## SPRNBRK\_\_345KV\_RNS5

FWD

Sat 06/04/2022 to Mon 06/06/2022 **CANCELLED by ConEd 05/27/2022**

(Import)

0201 Continuous 0200

SPR/DUN-SOUTH

**3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

## CHAT\_DC\_GC1

FWD

Sun 06/05/2022 to Sun 06/05/2022

(Import)

0001 Continuous 0200

MOSES SOUTH

**2850 MW**

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: HQ

## CHAT\_DC\_GC1

REV

Sun 06/05/2022 to Sun 06/05/2022

(Export)

0001 Continuous 0200

SCH - HQ - NY

**500 MW**

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 1000 MW

Work scheduled by: HQ

## CHAT\_DC\_GC1 & CHAT\_DC\_GC2

FWD

Sun 06/05/2022 to Sun 06/05/2022

(Import)

0001 0200

MOSES SOUTH

**2550 MW**

Impacts Total Transfer Capability 600 MW

TTC with All Lines In Service 3150 MW

Work scheduled by:

## CHAT\_DC\_GC1 & CHAT\_DC\_GC2

FWD

REV

Sun 06/05/2022 to Sun 06/05/2022

(Import) (Export)

0001 0200

SCH - HQ - NY

**1370 MW 0 MW**

Impacts Total Transfer Capability 130 MW 1000 MW

TTC with All Lines In Service 1500 MW 1000 MW

Work scheduled by:

## CHAT\_DC\_GC2

FWD

Sun 06/05/2022 to Sun 06/05/2022

(Import)

0001 Continuous 0200

MOSES SOUTH

**2850 MW**

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: HQ

## CHAT\_DC\_GC2

REV

Sun 06/05/2022 to Sun 06/05/2022

(Export)

0001 Continuous 0200

SCH - HQ - NY

**500 MW**

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 1000 MW

Work scheduled by: HQ

# NYISO TRANSFER LIMITATIONS

Wednesday, June 01, 2022 to Friday , December 01, 2023

## Seasonal Limits

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-HQ-NYISO\_LIMIT\_1150

Sun 06/05/2022 to Sun 06/05/2022  
0001 Continuous 0200  
Work scheduled by: HQ

FWD  
(Import)  
SCH - HQ - NY **1150 MW**  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 1500 MW

### MILLWOOD-EASTVIEW\_345\_W85

Sun 06/05/2022 to Sun 06/05/2022  
0001 Continuous 2200  
Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **7550 MW**  
Impacts Total Transfer Capability 265 MW  
TTC with All Lines In Service 7815 MW

### W49TH\_ST-E13THSTA\_345\_M55

Mon 06/06/2022 to Tue 06/07/2022  
0201 Continuous 0200  
Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

### HUDSONTP-W49TH\_ST\_345\_Y56

Thu 06/09/2022 to Sat 06/11/2022  
0001 Continuous 0200  
Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJM\_HTP **0 MW**  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

### W49TH\_ST\_345KV\_7

Thu 06/09/2022 to Sat 06/11/2022  
0001 Continuous 0200  
Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJM\_HTP **300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

### FROST\_BR-LONG\_MTN\_345\_352

Thu 06/09/2022 to Sat 06/18/2022 UPDATED by ISONE 03/04/2022  
0700 Continuous 1600  
Work scheduled by: ISONE

FWD  
(Import)  
SCH - NE - NY **1150 MW**  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 1400 MW

### SCH-NE-NYISO\_LIMIT\_200

Thu 06/09/2022 to Sat 06/18/2022 UPDATED by ISONE 03/04/2022  
0700 Continuous 1600  
Work scheduled by: ISONE

FWD  
(Import)  
SCH - NE - NY **400 MW**  
Impacts Total Transfer Capability 1000 MW  
TTC with All Lines In Service 1400 MW

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## MOTTHAVN-RAINEY\_\_\_345\_Q11

Sun 06/12/2022 to Wed 06/15/2022  
0001 Continuous 0200  
Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

## NIAGARA\_-DYSINGER\_345\_ND1

Mon 06/13/2022 to Fri 06/17/2022  
0500 Continuous 2100  
Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **2700 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 3200 MW

## OAKDALE\_-FRASER\_\_\_345\_32

Wed 06/15/2022 to Fri 06/17/2022  
0800 Continuous 1600  
Work scheduled by: NYSEG

FWD  
(Import)  
CENTRAL EAST - VC **2450 MW**  
Impacts Total Transfer Capability 135 MW  
TTC with All Lines In Service 2585 MW

## MARCY\_-EDIC\_\_\_345\_UE1-7

Sat 06/18/2022 to Sun 06/19/2022  
0600 Continuous 1830  
Work scheduled by: NYPA

FWD  
(Import)  
OSWEGO EXPORT **5250 MW**  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

ARR: 19&16

## NIAGARA\_-PACKARD\_\_\_230\_62

Mon 06/20/2022 to Sun 06/26/2022  
0500 Continuous 1700  
Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - OH - NY **700 MW 1550 MW**  
Impacts Total Transfer Capability 1250 MW 150 MW  
TTC with All Lines In Service 1950 MW 1700 MW

## FRASER\_-GILBOA\_\_\_345\_GF5-35

Tue 06/21/2022 to Sun 06/26/2022  
0700 Continuous 1530  
Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2450 MW**  
Impacts Total Transfer Capability 135 MW  
TTC with All Lines In Service 2585 MW

## BEAR SWP-EASTOVER\_230\_E205W

Mon 06/27/2022 to Tue 06/28/2022  
0700 Continuous 0759  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

# NYISO TRANSFER LIMITATIONS

Wednesday, June 01, 2022 to Friday , December 01, 2023

## Seasonal Limits

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### NIAGARA\_\_345\_230\_AT4

Tue 06/28/2022 to Wed 06/29/2022  
0500 Continuous 1700  
Work scheduled by: NYPA

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	1900 MW	1400 MW
Impacts Total Transfer Capability	50 MW	300 MW
TTC with All Lines In Service	1950 MW	1700 MW

### BEAR SWP-EASTOVER\_230\_E205W

Tue 06/28/2022 to Tue 06/28/2022  
0800 Daily(No Weekends) 1500  
Work scheduled by: NGrid

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

### BEAR SWP-EASTOVER\_230\_E205W

Tue 06/28/2022 to Thu 06/30/2022  
1501 Continuous 1700  
Work scheduled by: ISONE

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

### BECK\_\_\_\_-NIAGARA\_230\_PA27

Tue 07/05/2022 to Sat 07/09/2022  
0500 Continuous 2100  
Work scheduled by: NYPA

SCH - OH - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

### DYSINGER-STA\_255\_\_345\_DH1

Tue 07/05/2022 to Sat 07/09/2022  
0700 Continuous 1900  
Work scheduled by: NT

	FWD
	(Import)
DYSINGER EAST	2850 MW
Impacts Total Transfer Capability	350 MW
TTC with All Lines In Service	3200 MW

### SAND\_BAR-PLATSBRG\_115\_PV20

Wed 07/06/2022 to Fri 07/08/2022 **UPDATED by NYPA 05/31/2022**  
0530 Continuous 2000  
Work scheduled by: NYPA

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

### NIAGARA\_-DYSINGER\_345\_ND1

Mon 07/11/2022 to Fri 07/15/2022  
0500 Continuous 1700  
Work scheduled by: NYPA

	FWD
	(Import)
DYSINGER EAST	2700 MW
Impacts Total Transfer Capability	500 MW
TTC with All Lines In Service	3200 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, June 01, 2022 to Friday , December 01, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**HURLYAVE-ROSETON\_\_345\_303**

Mon 07/11/2022 to Fri 07/22/2022

0800 Continuous 1600

Work scheduled by: CHGE

02/14/2022

UPNY CONED

Impacts Total Transfer Capability 3715 MW

TTC with All Lines In Service 7815 MW

FWD

(Import)

**4100 MW**
**BECK\_\_-PACKARD\_\_230\_BP76**

Tue 07/12/2022 to Tue 07/12/2022

0700 Daily(No Weekends) 1300

Work scheduled by: NGrid

SCH - OH - NY

Impacts Total Transfer Capability 450 MW 550 MW

TTC with All Lines In Service 1950 MW 1700 MW

FWD

(Import) (Export)

**1500 MW 1150 MW**
**PLSNTVLY-WOOD\_ST\_\_345\_F31**

Sun 07/17/2022 to Tue 07/19/2022

0001 Continuous 2200

Work scheduled by: ConEd

UPNY CONED

Impacts Total Transfer Capability 3815 MW

TTC with All Lines In Service 7815 MW

FWD

(Import)

**4000 MW**
**MILLWOOD-EASTVIEW\_345\_W85**

Wed 07/20/2022 to Fri 07/22/2022

0001 Continuous 2200

Work scheduled by: ConEd

**CANCELLED by ConEd 06/01/2022**

UPNY CONED

Impacts Total Transfer Capability 265 MW

TTC with All Lines In Service 7815 MW

FWD

(Import)

**7550 MW**
**ROCHESTR-PANNELL\_\_345\_RP1**

Mon 07/25/2022 to Fri 07/29/2022

0500 Continuous 2100

Work scheduled by: NYPA

DYSINGER EAST

Impacts Total Transfer Capability 900 MW

TTC with All Lines In Service 3200 MW

FWD

(Import)

**2300 MW**
**FRASANNX-COOPERS\_\_345\_UCC2-41**

Mon 07/25/2022 to Fri 08/05/2022

0700 Continuous 1700

Work scheduled by: NYPA

**ARR: 19**

CENTRAL EAST - VC

Impacts Total Transfer Capability 310 MW

TTC with All Lines In Service 2585 MW

FWD

(Import)

**2275 MW**
**MARCY\_\_-FRASANNX\_345\_UCC2-41**

Mon 07/25/2022 to Fri 08/05/2022

0700 Continuous 1700

Work scheduled by: NYPA

**ARR: 19**

CENTRAL EAST - VC

Impacts Total Transfer Capability 310 MW

TTC with All Lines In Service 2585 MW

FWD

(Import)

**2275 MW**

# NYISO TRANSFER LIMITATIONS

Wednesday, June 01, 2022 to Friday , December 01, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## NIAGARA\_-DYSINGER\_345\_ND2

FWD

Mon 08/01/2022 to Fri 08/05/2022

(Import)

0500 Continuous 1700

DYSINGER EAST

**2700 MW**

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 3200 MW

Work scheduled by: NYPA

## NIAGARA\_-DYSINGER\_345\_ND2 & DYSINGER-STA 255\_345\_DH2

FWD

Mon 08/01/2022 to Fri 08/05/2022

(Import)

0700 1700

DYSINGER EAST

**2500 MW**

Impacts Total Transfer Capability 700 MW

TTC with All Lines In Service 3200 MW

Work scheduled by:

## DYSINGER-STA 255\_345\_DH2

FWD

Mon 08/01/2022 to Fri 08/05/2022

(Import)

0700 Continuous 1900

UPDATEDby NT05/23/2022

DYSINGER EAST

**2850 MW**

Impacts Total Transfer Capability 350 MW

TTC with All Lines In Service 3200 MW

Work scheduled by: NT

## MARCY\_-EDIC\_345\_UE1-7

FWD

Sat 08/06/2022 to Sun 08/07/2022

(Import)

0500 Continuous 1830

UPDATEDby NYPA05/25/2022

OSWEGO EXPORT

**5250 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NYPA

ARR: 19&amp;16

## VOLNEY\_-MARCY\_345\_19

FWD

Sat 08/06/2022 to Sun 08/07/2022

(Import)

0500 Continuous 1830

UPDATEDby NYPA05/25/2022

CENTRAL EAST - VC

**2475 MW**

Impacts Total Transfer Capability 110 MW

TTC with All Lines In Service 2585 MW

Work scheduled by: NYPA

ARR: 19

## VOLNEY\_-MARCY\_345\_19

FWD

Sat 08/06/2022 to Sun 08/07/2022

(Import)

0500 Continuous 1830

UPDATEDby NYPA05/25/2022

OSWEGO EXPORT

**4900 MW**

Impacts Total Transfer Capability 350 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NYPA

ARR: 19

## VOLNEY\_-MARCY\_345\_19 & GORDONRD-ROTTRDAM 230\_31

FWD

Sat 08/06/2022 to Sun 08/07/2022

(Import)

0500 1830

CENTRAL EAST - VC

**2425 MW**

Impacts Total Transfer Capability 160 MW

TTC with All Lines In Service 2585 MW

Work scheduled by:

ARR: 19

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## FRASANNX-COOPERS\_\_345\_UCC2-41

FWD

Mon 08/08/2022 to Fri 09/09/2022

(Import)

0700 Continuous 1700

CENTRAL EAST - VC

**2275 MW**

Impacts Total Transfer Capability 310 MW

TTC with All Lines In Service 2585 MW

Work scheduled by: NYPA

**ARR: 19**

## MARCY\_\_-FRASANNX\_345\_UCC2-41

FWD

Mon 08/08/2022 to Fri 09/09/2022

(Import)

0700 Continuous 1700

CENTRAL EAST - VC

**2275 MW**

Impacts Total Transfer Capability 310 MW

TTC with All Lines In Service 2585 MW

Work scheduled by: NYPA

**ARR: 19**

## STLAWRNC-MOSES\_\_230\_L34P

Mon 08/15/2022 to Tue 04/18/2023

**EXTENDED by IESO 05/18/2022**

0400 Continuous 2359

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: IESO

## SAND\_BAR-PLATSBRG\_115\_PV20

Mon 08/22/2022 to Fri 08/26/2022

0700 Continuous 1530

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: NYPA

## ROSETON\_-ROCKTVRN\_345\_311

FWD

Mon 08/29/2022 to Fri 09/09/2022

(Import)

0800 Continuous 1600

UPNY CONED

**4400 MW**

Impacts Total Transfer Capability 3415 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: CHGE

## MOTTHAVN-RAINEY\_\_345\_Q12

FWD

Thu 09/01/2022 to Mon 09/05/2022

(Import)

0001 Continuous 0200

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

## FRASER\_\_-GILBOA\_\_345\_GF5-35

FWD

Mon 09/12/2022 to Sun 09/18/2022

(Import)

0700 Continuous 1530

CENTRAL EAST - VC

**2450 MW**

Impacts Total Transfer Capability 135 MW

TTC with All Lines In Service 2585 MW

Work scheduled by: NYPA



# NYISO TRANSFER LIMITATIONS

Wednesday, June 01, 2022 to Friday , December 01, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## MOSES\_\_\_-ADIRNDCK\_230\_MA2

FWD

Thu 09/15/2022 to Tue 11/29/2022  
1931 Continuous 1800

UPDATEDby NYPA05/04/2022

(Import)

Work scheduled by: NYPA

MOSES SOUTH

2100 MW

Impacts Total Transfer Capability 1050 MW

TTC with All Lines In Service 3150 MW

## MARCY\_\_\_-EDIC\_\_\_345\_UE1-7

FWD

Mon 09/19/2022 to Sat 10/08/2022  
0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19&amp;16

OSWEGO EXPORT

5250 MW

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

## LEEDS\_\_\_-HURLYAVE\_345\_301

FWD

Mon 09/19/2022 to Fri 10/21/2022  
0800 Continuous 1600

Work scheduled by: CHGE

10/04/2021

(Import)

UPNY CONED

4100 MW

Impacts Total Transfer Capability 3715 MW

TTC with All Lines In Service 7815 MW

## EGRDNCTY\_345\_138\_AT1

FWD

Sat 10/01/2022 to Wed 05/31/2023  
0001 Continuous 2359

UPDATEDby CONED03/10/2022

(Import)

Work scheduled by: LI

CONED - LIPA

1250 MW

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 1500 MW

## EGRDNCTY\_345\_138\_AT2

FWD

Sat 10/01/2022 to Wed 05/31/2023  
0001 Continuous 2359

UPDATEDby CONED03/10/2022

(Import)

Work scheduled by: LI

CONED - LIPA

1250 MW

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 1500 MW

## SPRNBRK\_-EGRDNCTR\_345\_Y49

FWD

Sat 10/01/2022 to Wed 05/31/2023  
0001 Continuous 2359

UPDATEDby CONED03/10/2022

(Import)

Work scheduled by: LI

CONED - LIPA

775 MW

Impacts Total Transfer Capability 725 MW

TTC with All Lines In Service 1500 MW

## CLRKSCRN-OAKDALE\_\_\_345\_36

FWD

Mon 10/03/2022 to Fri 10/07/2022  
0830 Continuous 1530

UPDATEDby NYSEG04/20/2022

(Import)

Work scheduled by: NYSEG

CENTRAL EAST - VC

2450 MW

Impacts Total Transfer Capability 135 MW

TTC with All Lines In Service 2585 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, June 01, 2022 to Friday , December 01, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SHOR_NPX-SHOREHAM_138_CSC					FWD	REV
					(Import)	(Export)
Mon 10/03/2022	to	Fri 10/21/2022	<u>UPDATED</u>	<u>by LI</u>	<u>01/07/2022</u>	
1000	Continuous	1500			SCH - NPX_CSC	<b>0 MW</b>
Work scheduled by: LI					Impacts Total Transfer Capability	330 MW
					TTC with All Lines In Service	330 MW
EDIC____-N.SCTLND_345_14 & GORDONRD-ROTTDAM_230_31					FWD	
					(Import)	
Mon 10/10/2022	to	Mon 10/31/2022			CENTRAL EAST - VC	<b>1645 MW</b>
0700		2359			Impacts Total Transfer Capability	940 MW
Work scheduled by:					TTC with All Lines In Service	2585 MW
EDIC____-N.SCTLND_345_14					FWD	
					(Import)	
Mon 10/10/2022	to	Tue 12/31/2030			CENTRAL EAST - VC	<b>1695 MW</b>
0700	Continuous	2359			Impacts Total Transfer Capability	890 MW
Work scheduled by: NGrid					TTC with All Lines In Service	2585 MW
NIAGARA_-DYSINGER_345_ND1					FWD	
					(Import)	
Mon 10/17/2022	to	Fri 10/21/2022	<u>UPDATED</u>	<u>by NYPA</u>	<u>02/10/2022</u>	
0500	Continuous	1700			DYSINGER EAST	<b>2700 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	500 MW
					TTC with All Lines In Service	3200 MW
PANNELL_-CLAY____345_1					FWD	
					(Import)	
Mon 10/24/2022	to	Fri 10/28/2022			WEST CENTRAL	<b>1300 MW</b>
0700	Continuous	1530			Impacts Total Transfer Capability	950 MW
Work scheduled by: NYPA					TTC with All Lines In Service	2250 MW
HURLYAVE-ROSETON_345_303					FWD	
					(Import)	
Mon 10/24/2022	to	Fri 11/04/2022	<u>UPDATED</u>	<u>by CH</u>	<u>04/13/2022</u>	
0800	Continuous	1600			UPNY CONED	<b>4100 MW</b>
Work scheduled by: CHGE					Impacts Total Transfer Capability	3715 MW
					TTC with All Lines In Service	7815 MW
MAINESBG-WATRCURE_345_30					FWD	
					(Import)	
Tue 10/25/2022	to	Tue 10/25/2022			SCH - PJ - NY	<b>2200 MW</b>
0800	Daily	1500			Impacts Total Transfer Capability	50 MW
Work scheduled by: NYSEG					TTC with All Lines In Service	2250 MW

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**WATRCURE-OAKDALE\_\_345\_31**

Thu 10/27/2022 to Thu 10/27/2022  
0800 Daily 1500

Work scheduled by: NYSEG

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

**PANNELL -CLAY\_\_345\_2**

Mon 10/31/2022 to Fri 11/04/2022  
0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

WEST CENTRAL

**1300 MW**

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW

**CLAY\_\_-EDIC\_\_345\_1-16**

Tue 11/01/2022 to Thu 11/03/2022  
0600 Continuous 1900

Work scheduled by: NGrid

UPDATED

by NGRID 05/09/2022

FWD

(Import)

OSWEGO EXPORT

**4850 MW**

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 5250 MW

**NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE**

Tue 11/01/2022 to Sat 11/19/2022  
0600 Continuous 1600

Work scheduled by: LI

FWD

(Import)

SCH - PJM\_NEPTUNE

**0 MW**

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

**NEWBRDGE-DUFFYAVE\_345\_501**

Tue 11/01/2022 to Sat 11/19/2022  
0600 Continuous 1600

Work scheduled by: LI

FWD

(Import)

SCH - PJM\_NEPTUNE

**0 MW**

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

**NEWBRDGE\_345\_138\_BK\_1**

Tue 11/01/2022 to Sat 11/19/2022  
0600 Continuous 1600

Work scheduled by: LI

FWD

(Import)

SCH - PJM\_NEPTUNE

**375 MW**

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 660 MW

**NEWBRDGE\_345\_138\_BK\_2**

Tue 11/01/2022 to Sat 11/19/2022  
0600 Continuous 1600

Work scheduled by: LI

FWD

(Import)

SCH - PJM\_NEPTUNE

**375 MW**

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 660 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, June 01, 2022 to Friday , December 01, 2023

## Seasonal Limits

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### GILBOA\_\_-N.SCTLND\_345\_GNS-1

Tue 11/01/2022 to Tue 12/06/2022 UPDATED by NGRID 12/29/2021  
0700 Continuous 1900

Work scheduled by: NGrid

FWD  
(Import)  
CENTRAL EAST - VC **2300 MW**  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 2585 MW

### LEEDS\_\_\_\_345KV\_R94301

Tue 11/01/2022 to Tue 12/06/2022 UPDATED by NGRID 12/29/2021  
0700 Continuous 1900

Work scheduled by: NGrid

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

### MARCY\_\_-N.SCTLND\_345\_18

Tue 11/01/2022 to Tue 12/06/2022 UPDATED by NGRID 12/29/2021  
0700 Continuous 1900

Work scheduled by: NGrid

ARR: 19

FWD  
(Import)  
CENTRAL EAST - VC **1400 MW**  
Impacts Total Transfer Capability 1185 MW  
TTC with All Lines In Service 2585 MW

### LINDN.CG-LNDVFT\_\_\_\_345\_V-3022

Tue 11/01/2022 to Fri 11/04/2022  
0800 Continuous 1500

Work scheduled by: PJM

FWD REV  
(Import) (Export)  
SCH - PJM\_VFT **0 MW 0 MW**  
Impacts Total Transfer Capability 315 MW 315 MW  
TTC with All Lines In Service 315 MW 315 MW

### LEEDS\_\_-HURLYAVE\_345\_301

Mon 11/07/2022 to Fri 12/09/2022  
0800 Continuous 1600

Work scheduled by: CHGE

FWD  
(Import)  
UPNY CONED **4100 MW**  
Impacts Total Transfer Capability 3715 MW  
TTC with All Lines In Service 7815 MW

### MOSES\_\_-ADIRNDCK\_230\_MAI

Wed 11/30/2022 to Wed 03/01/2023  
0700 Continuous 1100

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

### CLAY\_\_\_\_-EDIC\_\_\_\_345\_1-16

Fri 12/30/2022 to Sat 12/31/2022 UPDATED by NGRID 05/09/2022  
0600 Continuous 1900

Work scheduled by: NGrid

FWD  
(Import)  
OSWEGO EXPORT **4850 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

# NYISO TRANSFER LIMITATIONS

Wednesday, June 01, 2022 to Friday , December 01, 2023

## Seasonal Limits

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### FRASER\_\_\_345\_FRASER SVC

FWD

Tue 01/03/2023 to Tue 02/28/2023  
0700 Continuous 1730

UPDATED by NYPA 12/30/2021

(Import)

Work scheduled by: NYPA

CENTRAL EAST - VC **2550 MW**  
Impacts Total Transfer Capability 35 MW  
TTC with All Lines In Service 2585 MW

### PLSNTVLY\_345KV\_RNS4

FWD

Sat 04/01/2023 to Sat 04/01/2023  
0700 Continuous 0730

(Import)

Work scheduled by: NGrid

UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

### ATHENS\_\_-PLSNTVLY\_345\_91

FWD

Sat 04/01/2023 to Sat 04/15/2023  
0700 Continuous 1900

(Import)

Work scheduled by: NGrid

UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

### PLSNTVLY\_345KV\_RNS4

FWD

Sat 04/15/2023 to Sat 04/15/2023  
1830 Continuous 1900

(Import)

Work scheduled by: NGrid

UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

### PLSNTVLY\_345KV\_RNS5

FWD

Sun 04/16/2023 to Sun 04/16/2023  
0700 Continuous 0730

(Import)

Work scheduled by: NGrid

UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

### LEEDS\_\_\_-PLSNTVLY\_345\_92

FWD

Sun 04/16/2023 to Sun 04/30/2023  
0700 Continuous 1900

(Import)

Work scheduled by: NGrid

UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

### PLSNTVLY\_345KV\_RNS5

FWD

Sun 04/30/2023 to Sun 04/30/2023  
1830 Continuous 1900

(Import)

Work scheduled by: NGrid

UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**SHOR\_NPX-SHOREHAM\_138\_CSC**

Mon 05/01/2023 to Fri 05/05/2023  
0600 Continuous 1800

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_CSC	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	330 MW	330 MW
TTC with All Lines In Service	330 MW	330 MW

**SHOR\_NPX-SHOREHAM\_138\_CSC**

Mon 10/02/2023 to Fri 10/06/2023  
0600 Continuous 1800

Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_CSC	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	330 MW	330 MW
TTC with All Lines In Service	330 MW	330 MW

**NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE**

Mon 10/09/2023 to Fri 10/13/2023  
0600 Continuous 1600

Work scheduled by: LI

	FWD
	(Import)
SCH - PJM_NEPTUNE	<b>0 MW</b>
Impacts Total Transfer Capability	660 MW
TTC with All Lines In Service	660 MW

**NEWBRDGE-DUFFYAVE\_345\_501**

Mon 10/09/2023 to Fri 10/13/2023  
0600 Continuous 1600

Work scheduled by: LI

	FWD
	(Import)
SCH - PJM_NEPTUNE	<b>0 MW</b>
Impacts Total Transfer Capability	660 MW
TTC with All Lines In Service	660 MW

**NEWBRDGE\_345\_138\_BK\_1**

Mon 10/09/2023 to Fri 10/13/2023  
0600 Continuous 1600

Work scheduled by: LI

	FWD
	(Import)
SCH - PJM_NEPTUNE	<b>375 MW</b>
Impacts Total Transfer Capability	285 MW
TTC with All Lines In Service	660 MW

**NEWBRDGE\_345\_138\_BK\_2**

Mon 10/09/2023 to Fri 10/13/2023  
0600 Continuous 1600

Work scheduled by: LI

	FWD
	(Import)
SCH - PJM_NEPTUNE	<b>375 MW</b>
Impacts Total Transfer Capability	285 MW
TTC with All Lines In Service	660 MW