

# NYISO TRANSFER LIMITATIONS

Tuesday ,June 21, 2022 to Thursday ,December 21, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## HUDSONP\_-FARRAGUT\_345\_B3402

FWD

Mon 01/15/2018 to Sat 12/31/2022 EXT FORCE by CONED 05/14/2022

(Import)

0001 Continuous 2359

Work scheduled by: ConEd

SCH - PJ - NY

2050 MW

Impacts Total Transfer Capability 200 MW

TTC with All Lines In Service 2250 MW

## HUDSONP\_-FARRAGUT\_345\_B3402 & MARION\_-FARRAGUT\_345\_C3403

FWD

REV

Mon 01/15/2018 to Sat 12/31/2022

(Import) (Export)

0001 2359

Work scheduled by:

SCH - PJ - NY

2000 MW 1150 MW

Impacts Total Transfer Capability 250 MW 100 MW

TTC with All Lines In Service 2250 MW 1250 MW

## MARION\_-FARRAGUT\_345\_C3403

FWD

Mon 01/15/2018 to Sat 12/31/2022 EXT FORCE by CONED 05/14/2022

(Import)

0001 Continuous 2359

Work scheduled by: ConEd

SCH - PJ - NY

2050 MW

Impacts Total Transfer Capability 200 MW

TTC with All Lines In Service 2250 MW

## STLAWRNC-MOSES\_230\_L33P

Mon 04/30/2018 to Wed 07/27/2022 EXT FORCE by IESO 05/18/2022

0456 Continuous 1600

Work scheduled by: IESO

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

## NEWBRDGE\_345\_138\_BK\_1

FWD

Wed 09/02/2020 to Mon 08/01/2022 EXT FORCE by LI 12/10/2021

(Import)

1807 Continuous 2359

Work scheduled by: LI

SCH - PJM\_NEPTUNE

375 MW

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 660 MW

## BECK\_-NIAGARA\_345\_PA301

FWD

REV

Wed 02/09/2022 to Fri 06/17/2022 UPDATED by NYISO 06/16/2022

(Import) (Export)

0700 Continuous 1700

Work scheduled by: IESO

SCH - OH - NY

900 MW 800 MW

Impacts Total Transfer Capability 1050 MW 900 MW

TTC with All Lines In Service 1950 MW 1700 MW

## W49TH\_ST\_345KV\_6

FWD

Mon 03/21/2022 to Sun 06/19/2022 EXT FORCE by CONED 06/15/2022

(Import)

0809 Continuous 2359

Work scheduled by: ConEd

SCH - PJM\_HTP

300 MW

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,June 21, 2022 to Thursday ,December 21, 2023

## Seasonal Limits

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### W49TH\_ST\_345KV\_8

FWD

Mon 03/21/2022 to Sun 06/19/2022 EXT FORCE by CONED 06/15/2022

(Import)

0811 Continuous 2359

SCH - PJM\_HTP

**450 MW**

Impacts Total Transfer Capability 210 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

### GORDONRD-ROTTDRAM\_230\_31

FWD

Wed 04/27/2022 to Mon 10/31/2022 EXT FORCE by NYISO 05/17/2022

(Import)

1130 Continuous 2359

CENTRAL EAST - VC

**2805 MW**

Impacts Total Transfer Capability 170 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYISO

### SCH-IMO-NYISO\_LIMIT\_500

FWD

Sun 05/01/2022 to Fri 06/17/2022 UPDATED by NYISO 06/16/2022

(Import)

0001 Continuous 1700

SCH - OH - NY

**800 MW**

Impacts Total Transfer Capability 1150 MW

TTC with All Lines In Service 1950 MW

Work scheduled by: IESO

### SCH-IMO-NYISO\_LIMIT\_1400

FWD

Sun 05/01/2022 to Wed 07/27/2022 UPDATED by IESO 05/18/2022

(Import)

0001 Continuous 1600

SCH - OH - NY

**1700 MW**

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 1950 MW

Work scheduled by: IESO

### SCH-IMO-NYISO\_LIMIT\_1600

FWD

Sun 05/01/2022 to Wed 07/27/2022 UPDATED by IESO 05/18/2022

(Import)

0001 Continuous 1600

SCH - OH - NY

**1900 MW**

Impacts Total Transfer Capability 50 MW

TTC with All Lines In Service 1950 MW

Work scheduled by: IESO

### SCH-NYISO-IMO\_LIMIT\_1200

REV

Sun 05/01/2022 to Wed 07/27/2022 UPDATED by IESO 05/18/2022

(Export)

0001 Continuous 1600

SCH - OH - NY

**1500 MW**

Impacts Total Transfer Capability 200 MW

TTC with All Lines In Service 1700 MW

Work scheduled by: IESO

### SCH-NYISO-IMO\_LIMIT\_1400

REV

Sun 05/01/2022 to Wed 07/27/2022 UPDATED by IESO 05/18/2022

(Export)

0001 Continuous 1600

SCH - OH - NY

**1700 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 1700 MW

Work scheduled by: IESO

**NYISO TRANSFER LIMITATIONS**

Tuesday ,June 21, 2022 to Thursday ,December 21, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**SCH-NYISO-IMO\_LIMIT\_400**

REV

Wed 05/18/2022 to Fri 06/17/2022 UPDATED by IESO 06/10/2022

(Export)

0001 Continuous 1700

Work scheduled by: IESO

SCH - OH - NY

**700 MW**

Impacts Total Transfer Capability

1000 MW

TTC with All Lines In Service

1700 MW

**MOSES -ADIRNDCK\_230\_MA2**

FWD

Tue 05/31/2022 to Thu 09/15/2022 UPDATED by NYPA 05/04/2022

(Import)

0500 Continuous 1930

Work scheduled by: NYPA

MOSES SOUTH

**2100 MW**

Impacts Total Transfer Capability

1050 MW

TTC with All Lines In Service

3150 MW

**SCH-NE-NYISO\_LIMIT\_600**

FWD

Thu 06/09/2022 to Thu 06/16/2022 UPDATED by ISONE 06/04/2022

(Import)

0700 Continuous 2259

Work scheduled by: ISONE

SCH - NE - NY

**800 MW**

Impacts Total Transfer Capability

600 MW

TTC with All Lines In Service

1400 MW

**FROST\_BR-LONG\_MTN\_345\_352**

FWD

Thu 06/09/2022 to Fri 06/17/2022 UPDATED by ISONE 06/04/2022

(Import)

0700 Continuous 1600

Work scheduled by: ISONE

SCH - NE - NY

**1150 MW**

Impacts Total Transfer Capability

250 MW

TTC with All Lines In Service

1400 MW

**SCH-NE-NYISO\_LIMIT\_300**

FWD

Thu 06/09/2022 to Fri 06/17/2022 UPDATED by ISONE 06/04/2022

(Import)

2300 Continuous 0659

Work scheduled by: ISONE

SCH - NE - NY

**500 MW**

Impacts Total Transfer Capability

900 MW

TTC with All Lines In Service

1400 MW

**NIAGARA -DYSINGER\_345\_ND1**

FWD

Mon 06/13/2022 to Fri 06/17/2022 UPDATED by NYPA 06/13/2022

(Import)

0500 Continuous 2100

Work scheduled by: NYPA

DYSINGER EAST

**2700 MW**

Impacts Total Transfer Capability

500 MW

TTC with All Lines In Service

3200 MW

**SCH-NE-NYISO\_LIMIT\_600**

FWD

Fri 06/17/2022 to Fri 06/17/2022 UPDATED by ISONE 06/04/2022

(Import)

0700 Continuous 1600

Work scheduled by: ISONE

SCH - NE - NY

**800 MW**

Impacts Total Transfer Capability

600 MW

TTC with All Lines In Service

1400 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,June 21, 2022 to Thursday ,December 21, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## SCH-IMO-NYISO\_LIMIT\_1300

FWD

Fri 06/17/2022 to Tue 06/28/2022 UPDATED by IESO 06/10/2022

(Import)

1700 Continuous 0600

Work scheduled by: IESO

SCH - OH - NY **1600 MW**  
 Impacts Total Transfer Capability 350 MW  
 TTC with All Lines In Service 1950 MW

## SCH-NYISO-IMO\_LIMIT\_1000

REV

Fri 06/17/2022 to Tue 06/28/2022 UPDATED by IESO 06/10/2022

(Export)

1700 Continuous 0600

Work scheduled by: IESO

SCH - OH - NY **1300 MW**  
 Impacts Total Transfer Capability 400 MW  
 TTC with All Lines In Service 1700 MW

## NEWBRDGE-DUFFYAVE\_345\_501

FWD

Sat 06/18/2022 to Sat 06/18/2022 CANCELLED by LI 06/16/2022

(Import)

0001 Continuous 1200

Work scheduled by: LI

SCH - PJM\_NEPTUNE **0 MW**  
 Impacts Total Transfer Capability 660 MW  
 TTC with All Lines In Service 660 MW

## NEWBRDGE\_345\_138\_BK\_2

FWD

Sat 06/18/2022 to Sat 06/18/2022 CANCELLED by LI 06/16/2022

(Import)

0001 Continuous 1200

Work scheduled by: LI

SCH - PJM\_NEPTUNE **375 MW**  
 Impacts Total Transfer Capability 285 MW  
 TTC with All Lines In Service 660 MW

## CRICKVLY-PLSNTVLY\_345\_F83

FWD

Sat 06/18/2022 to Sat 06/18/2022

(Import)

0001 Continuous 2159

Work scheduled by: ConEd

SCH - NE - NY **350 MW**  
 Impacts Total Transfer Capability 1050 MW  
 TTC with All Lines In Service 1400 MW

## CRICKVLY-PLSNTVLY\_345\_F83

FWD

REV

Sat 06/18/2022 to Sat 06/18/2022

(Import) (Export)

0001 Continuous 2159

Work scheduled by: ConEd

SCH - NPX\_1385 **100 MW** **100 MW**  
 Impacts Total Transfer Capability 100 MW 100 MW  
 TTC with All Lines In Service 200 MW 200 MW

## CRICKVLY-PLSNTVLY\_345\_F84

FWD

Sat 06/18/2022 to Sat 06/18/2022

(Import)

0001 Continuous 2159

Work scheduled by: ConEd

SCH - NE - NY **350 MW**  
 Impacts Total Transfer Capability 1050 MW  
 TTC with All Lines In Service 1400 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,June 21, 2022 to Thursday ,December 21, 2023

## Seasonal Limits

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### CRICKVLY-PLSNTVLY\_345\_F84

Sat 06/18/2022 to Sat 06/18/2022  
0001 Continuous 2159  
Work scheduled by: ConEd

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	100 MW	100 MW
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

### PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4

Sat 06/18/2022 to Sat 06/18/2022  
0001 2159  
Work scheduled by:

	FWD
	(Import)
UPNY CONED	3800 MW
Impacts Total Transfer Capability	4015 MW
TTC with All Lines In Service	7815 MW

### SCH-NYISO-NE\_LIMIT\_600

Sat 06/18/2022 to Sat 06/18/2022  
0001 Continuous 2159  
Work scheduled by: ConEd

	REV
	(Export)
SCH - NE - NY	800 MW
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	1600 MW

### MARCY -EDIC 345\_UE1-7

Sat 06/18/2022 to Sun 06/19/2022  
0500 Continuous 1830  
Work scheduled by: NYPA

**UPDATED by NYPA 06/15/2022**  
**ARR: 19&16**

	FWD
	(Import)
OSWEGO EXPORT	5250 MW
Impacts Total Transfer Capability	0 MW
TTC with All Lines In Service	5250 MW

### PLSNTVLY\_345KV\_RN5 & PLSNTVLY\_345KV\_RN4

Sat 06/18/2022 to Tue 06/21/2022  
2200 0200  
Work scheduled by:

	FWD
	(Import)
UPNY CONED	3800 MW
Impacts Total Transfer Capability	4015 MW
TTC with All Lines In Service	7815 MW

### FRASER -GILBOA 345\_GF5-35

Tue 06/21/2022 to Sun 06/26/2022  
0700 Continuous 1530  
Work scheduled by: NYPA

	FWD
	(Import)
CENTRAL EAST - VC	2650 MW
Impacts Total Transfer Capability	325 MW
TTC with All Lines In Service	2975 MW

### SCH-IMO-NYISO\_LIMIT\_1100

Thu 06/23/2022 to Mon 06/27/2022  
0600 Continuous 1159  
Work scheduled by: IESO

	FWD
	(Import)
SCH - OH - NY	1400 MW
Impacts Total Transfer Capability	550 MW
TTC with All Lines In Service	1950 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,June 21, 2022 to Thursday ,December 21, 2023

## Seasonal Limits

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NYISO-IMO\_LIMIT\_600

Thu 06/23/2022	to	Mon 06/27/2022	<u>UPDATED</u>	<u>by IESO</u>	<u>06/20/2022</u>	SCH - OH - NY	REV
0600	Continuous	1159				Impacts Total Transfer Capability	(Export)
Work scheduled by: IESO						TTC with All Lines In Service	900 MW
							800 MW
							1700 MW

### BEAR SWP-EASTOVER\_230\_E205W

Mon 06/27/2022	to	Tue 06/28/2022	<u>UPDATED</u>	<u>by NGRID</u>	<u>06/13/2022</u>	SCH - NE - NY
0700	Continuous	0759				Impacts Total Transfer Capability
Work scheduled by: ISONE						TTC with All Lines In Service

### NIAGARA\_\_345\_230\_AT4

Tue 06/28/2022	to	Wed 06/29/2022	<u>UPDATED</u>	<u>by NYPA</u>	<u>06/21/2022</u>	SCH - OH - NY	FWD	REV
0500	Continuous	1700				Impacts Total Transfer Capability	(Import)	(Export)
Work scheduled by: NYPA						TTC with All Lines In Service	1900 MW	1400 MW
							50 MW	300 MW
							1950 MW	1700 MW

### BEAR SWP-EASTOVER\_230\_E205W

Tue 06/28/2022	to	Thu 06/30/2022	<u>UPDATED</u>	<u>by NGRID</u>	<u>06/13/2022</u>	SCH - NE - NY
1501	Continuous	1700				Impacts Total Transfer Capability
Work scheduled by: ISONE						TTC with All Lines In Service

### BECK\_\_\_\_-NIAGARA\_\_345\_PA302

Wed 06/29/2022	to	Fri 07/01/2022				SCH - OH - NY	FWD	REV
0700	Continuous	1600				Impacts Total Transfer Capability	(Import)	(Export)
Work scheduled by: IESO						TTC with All Lines In Service	900 MW	800 MW
							1050 MW	900 MW
							1950 MW	1700 MW

### BECK\_\_\_\_-NIAGARA\_\_230\_PA27

Tue 07/05/2022	to	Sat 07/09/2022				SCH - OH - NY
0500	Continuous	2100				Impacts Total Transfer Capability
Work scheduled by: NYPA						TTC with All Lines In Service

### DYSINGER-STA\_255\_\_345\_DH1

Tue 07/05/2022	to	Sat 07/09/2022				DYSINGER EAST	FWD
0700	Continuous	1900				Impacts Total Transfer Capability	(Import)
Work scheduled by: NT						TTC with All Lines In Service	2850 MW
							350 MW
							3200 MW

**NYISO TRANSFER LIMITATIONS**

Tuesday ,June 21, 2022 to Thursday ,December 21, 2023

**CENTRAL EAST 2650MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6000MW**  
**UPNY CONED 7815MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3200MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**SAND\_BAR-PLATSBURG\_115\_PV20**

Wed 07/06/2022 to Fri 07/08/2022 **UPDATED by NYPA 05/31/2022**  
0530 Continuous 2000

Work scheduled by: NYPA

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

**NIAGARA\_-DYSINGER\_345\_ND1**

Mon 07/11/2022 to Fri 07/15/2022  
0500 Continuous 1700

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **2700 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 3200 MW

**HURLYAVE-ROSETON\_345\_303**

Mon 07/11/2022 to Fri 07/22/2022  
0800 Continuous 1600

Work scheduled by: CHGE

**02/14/2022**

FWD  
(Import)  
UPNY CONED **4100 MW**  
Impacts Total Transfer Capability 3715 MW  
TTC with All Lines In Service 7815 MW

**BECK\_-PACKARD\_230\_BP76**

Tue 07/12/2022 to Tue 07/12/2022  
0700 Daily(No Weekends) 1300

Work scheduled by: NGrid

FWD REV  
(Import) (Export)  
SCH - OH - NY **1500 MW 1150 MW**  
Impacts Total Transfer Capability 450 MW 550 MW  
TTC with All Lines In Service 1950 MW 1700 MW

**BECK\_-PACKARD\_230\_BP76**

Fri 07/15/2022 to Thu 09/01/2022  
1200 Continuous 0900

Work scheduled by: IESO

FWD REV  
(Import) (Export)  
SCH - OH - NY **1500 MW 1150 MW**  
Impacts Total Transfer Capability 450 MW 550 MW  
TTC with All Lines In Service 1950 MW 1700 MW

**COOPERS\_-DOLSONAV\_345\_CCDA42**

Mon 07/18/2022 to Fri 07/22/2022  
0700 Continuous 1630

Work scheduled by: NYSEG

FWD  
(Import)  
CENTRAL EAST - VC **2720 MW**  
Impacts Total Transfer Capability 255 MW  
TTC with All Lines In Service 2975 MW

**PLSNTVLY-WOOD\_ST\_345\_F31**

Sun 07/24/2022 to Tue 07/26/2022 **UPDATED by CONED 06/07/2022**  
0001 Continuous 2200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 3815 MW  
TTC with All Lines In Service 7815 MW

**NYISO TRANSFER LIMITATIONS**

Tuesday ,June 21, 2022 to Thursday ,December 21, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**ROCHESTR-PANNELL\_\_345\_RP1**

FWD

Mon 07/25/2022 to Fri 07/29/2022

(Import)

0500 Continuous 2100

DYSINGER EAST **2300 MW**

Impacts Total Transfer Capability 900 MW

TTC with All Lines In Service 3200 MW

Work scheduled by: NYPA

**FRASANNX-COOPERS\_\_345\_UCC2-41**

FWD

Mon 07/25/2022 to Fri 08/05/2022

(Import)

0700 Continuous 1700

CENTRAL EAST - VC **2500 MW**

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

**ARR: 19****MARCY\_\_-FRASANNX\_345\_UCC2-41**

FWD

Mon 07/25/2022 to Fri 08/05/2022

(Import)

0700 Continuous 1700

CENTRAL EAST - VC **2500 MW**

Impacts Total Transfer Capability 475 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYPA

**ARR: 19****MILLWOOD-EASTVIEW\_345\_W85**

FWD

Wed 07/27/2022 to Fri 07/29/2022

(Import)

0001 Continuous 2200

UPNY CONED **7550 MW**

Impacts Total Transfer Capability 265 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

**NIAGARA\_-DYSINGER\_345\_ND2**

FWD

Mon 08/01/2022 to Fri 08/05/2022

(Import)

0500 Continuous 1700

DYSINGER EAST **2700 MW**

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 3200 MW

Work scheduled by: NYPA

**NIAGARA\_-DYSINGER\_345\_ND2 & DYSINGER-STA\_255\_\_345\_DH2**

FWD

Mon 08/01/2022 to Fri 08/05/2022

(Import)

0700 1700

DYSINGER EAST **2500 MW**

Impacts Total Transfer Capability 700 MW

TTC with All Lines In Service 3200 MW

Work scheduled by:

**DYSINGER-STA\_255\_\_345\_DH2**

FWD

Mon 08/01/2022 to Fri 08/05/2022

(Import)

0700 Continuous 1900

DYSINGER EAST **2850 MW**

Impacts Total Transfer Capability 350 MW

TTC with All Lines In Service 3200 MW

Work scheduled by: NT

**UPDATED****by NT****05/23/2022**



# NYISO TRANSFER LIMITATIONS

Tuesday ,June 21, 2022 to Thursday ,December 21, 2023

## Seasonal Limits

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MARCY\_\_-EDIC\_\_\_\_345\_UE1-7

Sat 08/06/2022 to Sun 08/07/2022  
0500 Continuous 1830

UPDATED by NYPA 05/25/2022

Work scheduled by: NYPA

ARR: 19&16

FWD  
(Import)  
OSWEGO EXPORT **5250 MW**  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

### VOLNEY\_\_-MARC\_\_\_\_345\_19

Sat 08/06/2022 to Sun 08/07/2022  
0500 Continuous 1830

UPDATED by NYPA 05/25/2022

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
CENTRAL EAST - VC **2825 MW**  
Impacts Total Transfer Capability 150 MW  
TTC with All Lines In Service 2975 MW

### VOLNEY\_\_-MARC\_\_\_\_345\_19

Sat 08/06/2022 to Sun 08/07/2022  
0500 Continuous 1830

UPDATED by NYPA 05/25/2022

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
OSWEGO EXPORT **4900 MW**  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 5250 MW

### FRASANNX-COOPERS\_\_345\_UCC2-41

Mon 08/08/2022 to Fri 09/09/2022  
0700 Continuous 1700

UPDATED by NYPA 05/25/2022

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

### MARCY\_\_-FRASANNX\_345\_UCC2-41

Mon 08/08/2022 to Fri 09/09/2022  
0700 Continuous 1700

UPDATED by NYPA 05/25/2022

Work scheduled by: NYPA

ARR: 19

FWD  
(Import)  
CENTRAL EAST - VC **2500 MW**  
Impacts Total Transfer Capability 475 MW  
TTC with All Lines In Service 2975 MW

### STLAWRNC-MOSES\_\_\_\_230\_L34P

Mon 08/15/2022 to Tue 04/18/2023  
0400 Continuous 2359

EXTENDED by IESO 05/18/2022

Work scheduled by: IESO

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

### SAND\_BAR-PLATSBRG\_115\_PV20

Mon 08/22/2022 to Fri 08/26/2022  
0700 Continuous 1530

Work scheduled by: NYPA

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

# NYISO TRANSFER LIMITATIONS

Tuesday ,June 21, 2022 to Thursday ,December 21, 2023

## Seasonal Limits

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### ROSETON\_-ROCKTVRN\_345\_311

FWD

Mon 08/29/2022 to Fri 09/09/2022

(Import)

0800 Continuous 1600

UPNY CONED

**4400 MW**

Impacts Total Transfer Capability 3415 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: CHGE

### EFISHKIL-WOOD\_ST\_\_345\_F38

FWD

Thu 09/01/2022 to Sat 09/03/2022

(Import)

0001 Continuous 2200

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 3815 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

### PLSNTVLE-DUNWODIE\_345\_W89

FWD

Thu 09/01/2022 to Sat 09/03/2022

(Import)

0001 Continuous 2200

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 3815 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

### WOOD\_ST\_-PLSNTVLE\_345\_Y86

FWD

Thu 09/01/2022 to Sat 09/03/2022

(Import)

0001 Continuous 2200

UPNY CONED

**7210 MW**

Impacts Total Transfer Capability 605 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

### MOTTHAVN-RAINEY\_\_345\_Q12

FWD

Thu 09/01/2022 to Mon 09/05/2022

(Import)

0001 Continuous 0200

UPDATED

by CE

06/14/2022

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

### DUNWODIE\_345KV\_6

FWD

Wed 09/07/2022 to Wed 09/07/2022

(Import)

0001 Continuous 0030

UPDATED

by CONED

06/09/2022

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

### DUNWODIE\_345KV\_8

FWD

Wed 09/07/2022 to Wed 09/07/2022

(Import)

0001 Continuous 0030

UPDATED

by CONED

06/09/2022

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**NYISO TRANSFER LIMITATIONS**

Tuesday ,June 21, 2022 to Thursday ,December 21, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**WOOD\_ST\_-PLSNTVLE\_345\_Y87**

FWD

Wed 09/07/2022 to Wed 09/07/2022  
0001 Continuous 0300

**UPDATED****by CONED****06/09/2022**

(Import)

Work scheduled by: ConEd

UPNY CONED

**7260 MW**

Impacts Total Transfer Capability 555 MW

TTC with All Lines In Service 7815 MW

**PLSNTVLE-DUNWODIE\_345\_W90**

FWD

Wed 09/07/2022 to Sat 09/10/2022  
0001 Continuous 0200

**UPDATED****by CONED****06/09/2022**

(Import)

Work scheduled by: ConEd

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 3815 MW

TTC with All Lines In Service 7815 MW

**W49TH\_ST\_345KV\_6**

FWD

Fri 09/09/2022 to Fri 09/09/2022  
0001 Continuous 0030

(Import)

Work scheduled by: ConEd

SCH - PJM\_HTP

**300 MW**

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

**W49TH\_ST-E13THSTA\_345\_M55**

FWD

Fri 09/09/2022 to Sun 09/11/2022  
0001 Continuous 0200

(Import)

Work scheduled by: ConEd

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_6**

FWD

Sat 09/10/2022 to Sat 09/10/2022  
0130 Continuous 0200

**UPDATED****by CONED****06/09/2022**

(Import)

Work scheduled by: ConEd

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_8**

FWD

Sat 09/10/2022 to Sat 09/10/2022  
0130 Continuous 0200

**UPDATED****by CONED****06/09/2022**

(Import)

Work scheduled by: ConEd

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

**WOOD\_ST\_-PLSNTVLE\_345\_Y87**

FWD

Sat 09/10/2022 to Sat 09/10/2022  
0130 Continuous 0200

**UPDATED****by CONED****06/09/2022**

(Import)

Work scheduled by: ConEd

UPNY CONED

**7260 MW**

Impacts Total Transfer Capability 555 MW

TTC with All Lines In Service 7815 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,June 21, 2022 to Thursday ,December 21, 2023

## Seasonal Limits

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### W49TH\_ST\_345KV\_6

Sun 09/11/2022 to Sun 09/11/2022  
0130 Continuous 0200  
Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJM\_HTP **300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

### FRASER\_\_-GILBOA\_\_345\_GF5-35

Mon 09/12/2022 to Sun 09/18/2022  
0700 Continuous 1530  
Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2650 MW**  
Impacts Total Transfer Capability 325 MW  
TTC with All Lines In Service 2975 MW

### W49TH\_ST-E13THSTA\_345\_M54

Thu 09/15/2022 to Thu 09/15/2022  
0001 Continuous 0031  
Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

### SPRNBK\_\_345KV\_RS3 & SPRNBK\_\_345KV\_RS4

Thu 09/15/2022 to Fri 09/16/2022  
0001 0300  
Work scheduled by:

FWD  
(Import)  
SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

### MOSES\_\_-ADIRNDCK\_230\_MA2

Thu 09/15/2022 to Tue 11/29/2022 **UPDATED by NYPA 05/04/2022**  
1931 Continuous 1800  
Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

### EASTVIEW-SPRNBK\_\_345\_W78

Fri 09/16/2022 to Wed 09/21/2022 **UPDATED by CONED 06/07/2022**  
2100 Continuous 0200  
Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

### MILLWOOD-EASTVIEW\_345\_W85

Fri 09/16/2022 to Wed 09/21/2022 **UPDATED by CONED 06/07/2022**  
2100 Continuous 0200  
Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **7550 MW**  
Impacts Total Transfer Capability 265 MW  
TTC with All Lines In Service 7815 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,June 21, 2022 to Thursday ,December 21, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## SPRNBRK\_\_345KV\_RNS3

FWD

Fri 09/16/2022 to Wed 09/21/2022 UPDATED by CONED 06/07/2022

(Import)

2100 Continuous 0200

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

## FRASER\_\_345\_FRASER SVC

FWD

Mon 09/19/2022 to Tue 09/27/2022

(Import)

0600 Continuous 1700

CENTRAL EAST - VC

**2935 MW**

Impacts Total Transfer Capability 40 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYSEG

## MARCY\_\_-EDIC\_\_345\_UE1-7

FWD

Mon 09/19/2022 to Sat 10/08/2022 UPDATED by NGRID 06/06/2022

(Import)

0700 Continuous 1530

OSWEGO EXPORT

**5250 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NYPA

**ARR: 19&16**

## LEEDS\_\_-HURLYAVE\_345\_301

FWD

Mon 09/19/2022 to Fri 10/21/2022

(Import)

0800 Continuous 1600

10/04/2021

UPNY CONED

**4100 MW**

Impacts Total Transfer Capability 3715 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: CHGE

## SPRNBRK\_\_345KV\_RNS4

FWD

Mon 09/26/2022 to Mon 09/26/2022

(Import)

0001 Continuous 0031

SPR/DUN-SOUTH

**3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

## EASTVIEW-SPRNBRK\_\_345\_W65

FWD

Mon 09/26/2022 to Wed 09/28/2022

(Import)

0001 Continuous 1800

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

## MILLWOOD-EASTVIEW\_345\_W82

FWD

Mon 09/26/2022 to Wed 09/28/2022

(Import)

0001 Continuous 1800

UPNY CONED

**7550 MW**

Impacts Total Transfer Capability 265 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

# NYISO TRANSFER LIMITATIONS

Tuesday ,June 21, 2022 to Thursday ,December 21, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## SPRNBK\_\_345KV\_RNS4

FWD

Wed 09/28/2022 to Wed 09/28/2022

(Import)

1730 Continuous 1800

SPR/DUN-SOUTH

3200 MW

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

## EASTVIEW-SPRNBK\_\_345\_W64

FWD

Thu 09/29/2022 to Sat 10/01/2022

(Import)

0001 Continuous 0200

UPDATEDby CONED 06/08/2022

UPNY CONED

4350 MW

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

## MILLWOOD-EASTVIEW\_345\_W99

FWD

Thu 09/29/2022 to Sat 10/01/2022

(Import)

0001 Continuous 0200

UPDATEDby CONED 06/08/2022

UPNY CONED

7550 MW

Impacts Total Transfer Capability 265 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

## SPRNBK\_\_345KV\_RNS5

FWD

Thu 09/29/2022 to Sat 10/01/2022

(Import)

0001 Continuous 0200

UPDATEDby CONED 06/08/2022

SPR/DUN-SOUTH

3200 MW

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

## EGRDNCTY\_345\_138\_AT1

FWD

Sat 10/01/2022 to Wed 05/31/2023

(Import)

0001 Continuous 2359

UPDATEDby CONED 03/10/2022

CONED - LIPA

1250 MW

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 1500 MW

Work scheduled by: LI

## EGRDNCTY\_345\_138\_AT2

FWD

Sat 10/01/2022 to Wed 05/31/2023

(Import)

0001 Continuous 2359

UPDATEDby CONED 03/10/2022

CONED - LIPA

1250 MW

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 1500 MW

Work scheduled by: LI

## SPRNBK\_-EGRDNCTR\_345\_Y49

FWD

Sat 10/01/2022 to Wed 05/31/2023

(Import)

0001 Continuous 2359

UPDATEDby CONED 03/10/2022

CONED - LIPA

775 MW

Impacts Total Transfer Capability 725 MW

TTC with All Lines In Service 1500 MW

Work scheduled by: LI

# NYISO TRANSFER LIMITATIONS

Tuesday ,June 21, 2022 to Thursday ,December 21, 2023

## Seasonal Limits

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### CLRKSCRN-OAKDALE\_\_345\_36

FWD

Mon 10/03/2022 to Fri 10/07/2022 UPDATED by NYSEG 04/20/2022

(Import)

0830 Continuous 1530

CENTRAL EAST - VC

**2650 MW**

Impacts Total Transfer Capability 325 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NYSEG

### SHOR\_NPX-SHOREHAM\_138\_CSC

FWD

REV

Mon 10/03/2022 to Fri 10/21/2022 UPDATED by LI 01/07/2022

(Import) (Export)

1000 Continuous 1500

SCH - NPX\_CSC

**0 MW**

**0 MW**

Impacts Total Transfer Capability 330 MW 330 MW

TTC with All Lines In Service 330 MW 330 MW

Work scheduled by: LI

### EDIC\_\_\_\_-N.SCTLND\_345\_14 & GORDONRD-ROTTDAM\_230\_31

FWD

Mon 10/10/2022 to Mon 10/31/2022

(Import)

0700 2359

CENTRAL EAST - VC

**1500 MW**

Impacts Total Transfer Capability 1475 MW

TTC with All Lines In Service 2975 MW

Work scheduled by:

### EDIC\_\_\_\_-N.SCTLND\_345\_14

FWD

Mon 10/10/2022 to Tue 12/31/2030

(Import)

0700 Continuous 2359

CENTRAL EAST - VC

**1670 MW**

Impacts Total Transfer Capability 1305 MW

TTC with All Lines In Service 2975 MW

Work scheduled by: NGrid

### EASTVIEW-SPRNBK\_\_345\_W79

FWD

Mon 10/17/2022 to Mon 10/17/2022 UPDATED by CONED 06/18/2022

(Import)

0001 Continuous 0031

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

### BUCHAN\_N-EASTVIEW\_345\_W93

FWD

Mon 10/17/2022 to Sat 11/26/2022 UPDATED by CONED 06/18/2022

(Import)

0001 Continuous 0200

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

### NIAGARA\_-DYSINGER\_345\_ND1

FWD

Mon 10/17/2022 to Fri 10/21/2022 UPDATED by NYPA 02/10/2022

(Import)

0500 Continuous 1700

DYSINGER EAST

**2700 MW**

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 3200 MW

Work scheduled by: NYPA

**NYISO TRANSFER LIMITATIONS**

Tuesday ,June 21, 2022 to Thursday ,December 21, 2023

**CENTRAL EAST 2650MW**  
**CENTRAL EAST - VC 2975MW**  
**TOTAL EAST 6000MW**  
**UPNY CONED 7815MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3200MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**RAMAPO\_\_-BUCHAN\_N\_345\_Y94**

FWD

Tue 10/18/2022 to Fri 10/28/2022

UPDATEDby CONED 06/18/2022

(Import)

0001 Continuous 0200

Work scheduled by: ConEd

UPNY CONED

**7580 MW**

Impacts Total Transfer Capability 235 MW

TTC with All Lines In Service 7815 MW

**PANNELL\_-CLAY\_\_\_\_345\_1**

FWD

Mon 10/24/2022 to Fri 10/28/2022

(Import)

0700 Continuous 1530

Work scheduled by: NYPA

WEST CENTRAL

**1300 MW**

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW

**HURLYAVE-ROSETON\_\_345\_303**

FWD

Mon 10/24/2022 to Fri 11/04/2022

UPDATEDby CH04/13/2022

(Import)

0800 Continuous 1600

Work scheduled by: CHGE

UPNY CONED

**4100 MW**

Impacts Total Transfer Capability 3715 MW

TTC with All Lines In Service 7815 MW

**MAINESBG-WATRCURE\_345\_30**

FWD

Tue 10/25/2022 to Tue 10/25/2022

(Import)

0800 Daily 1500

Work scheduled by: NYSEG

SCH - PJ - NY

**2200 MW**

Impacts Total Transfer Capability 50 MW

TTC with All Lines In Service 2250 MW

**WATRCURE-OAKDALE\_\_345\_31**

Thu 10/27/2022 to Thu 10/27/2022

0800 Daily 1500

Work scheduled by: NYSEG

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

**PANNELL\_-CLAY\_\_\_\_345\_2**

FWD

Mon 10/31/2022 to Fri 11/04/2022

(Import)

0700 Continuous 1530

Work scheduled by: NYPA

WEST CENTRAL

**1300 MW**

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW

**CLAY\_\_\_\_-EDIC\_\_\_\_345\_1-16**

FWD

Tue 11/01/2022 to Thu 11/03/2022

UPDATEDby NGRID 05/09/2022

(Import)

0600 Continuous 1900

Work scheduled by: NGrid

OSWEGO EXPORT

**4850 MW**

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 5250 MW



# NYISO TRANSFER LIMITATIONS

Tuesday ,June 21, 2022 to Thursday ,December 21, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE

Tue 11/01/2022 to Sat 11/19/2022  
0600 Continuous 1600

Work scheduled by: LI

FWD  
(Import)  
SCH - PJM\_NEPTUNE **0 MW**  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

## NEWBRDGE-DUFFYAVE\_345\_501

Tue 11/01/2022 to Sat 11/19/2022  
0600 Continuous 1600

Work scheduled by: LI

FWD  
(Import)  
SCH - PJM\_NEPTUNE **0 MW**  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

## NEWBRDGE\_345\_138\_BK\_1

Tue 11/01/2022 to Sat 11/19/2022  
0600 Continuous 1600

Work scheduled by: LI

FWD  
(Import)  
SCH - PJM\_NEPTUNE **375 MW**  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 660 MW

## NEWBRDGE\_345\_138\_BK\_2

Tue 11/01/2022 to Sat 11/19/2022  
0600 Continuous 1600

Work scheduled by: LI

FWD  
(Import)  
SCH - PJM\_NEPTUNE **375 MW**  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 660 MW

## GILBOA\_-N.SCTLND\_345\_GNS-1

Tue 11/01/2022 to Tue 12/06/2022 **UPDATED by NGRID 12/29/2021**  
0700 Continuous 1900

Work scheduled by: NGrid

FWD  
(Import)  
CENTRAL EAST - VC **2520 MW**  
Impacts Total Transfer Capability 455 MW  
TTC with All Lines In Service 2975 MW

## LEEDS\_345KV\_R94301

Tue 11/01/2022 to Tue 12/06/2022 **UPDATED by NGRID 12/29/2021**  
0700 Continuous 1900

Work scheduled by: NGrid

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

## MARCY\_-N.SCTLND\_345\_18

Tue 11/01/2022 to Tue 12/06/2022 **UPDATED by NGRID 12/29/2021**  
0700 Continuous 1900

Work scheduled by: NGrid

ARR: 19

FWD  
(Import)  
CENTRAL EAST - VC **1470 MW**  
Impacts Total Transfer Capability 1505 MW  
TTC with All Lines In Service 2975 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,June 21, 2022 to Thursday ,December 21, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## LINDN\_CG-LNDVFT\_\_\_345\_V-3022

Tue 11/01/2022 to Fri 11/04/2022  
0800 Continuous 1500

Work scheduled by: PJM

	FWD	REV
	(Import)	(Export)
SCH - PJM_VFT	0 MW	0 MW
Impacts Total Transfer Capability	315 MW	315 MW
TTC with All Lines In Service	315 MW	315 MW

## LEEDS\_\_\_-HURLYAVE\_345\_301

Mon 11/07/2022 to Fri 12/09/2022  
0800 Continuous 1600

Work scheduled by: CHGE

	FWD
	(Import)
UPNY CONED	4100 MW
Impacts Total Transfer Capability	3715 MW
TTC with All Lines In Service	7815 MW

## RAMAPO\_\_\_-BUCHAN\_N\_345\_Y94

Mon 11/21/2022 to Sat 11/26/2022  
0001 Continuous 0200

Work scheduled by: ConEd

UPDATED by CONED 06/18/2022

	FWD
	(Import)
UPNY CONED	7580 MW
Impacts Total Transfer Capability	235 MW
TTC with All Lines In Service	7815 MW

## EASTVIEW-SPRNBK\_\_\_345\_W79

Sat 11/26/2022 to Sat 11/26/2022  
0130 Continuous 0200

Work scheduled by: ConEd

UPDATED by CONED 06/18/2022

	FWD
	(Import)
UPNY CONED	4350 MW
Impacts Total Transfer Capability	3465 MW
TTC with All Lines In Service	7815 MW

## BUCHAN\_S-MILLWOOD\_345\_W98

Tue 11/29/2022 to Thu 12/01/2022  
0001 Continuous 0200

Work scheduled by: ConEd

	FWD
	(Import)
UPNY CONED	7680 MW
Impacts Total Transfer Capability	135 MW
TTC with All Lines In Service	7815 MW

## MILLWOOD\_345KV\_18

Tue 11/29/2022 to Thu 12/01/2022  
0001 Continuous 0200

Work scheduled by: ConEd

	FWD
	(Import)
UPNY CONED	4350 MW
Impacts Total Transfer Capability	3465 MW
TTC with All Lines In Service	7815 MW

## MOSES\_\_\_-ADIRNDCK\_230\_MAI

Wed 11/30/2022 to Wed 03/01/2023  
0700 Continuous 1100

Work scheduled by: NYPA

	FWD
	(Import)
MOSES SOUTH	2300 MW
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,June 21, 2022 to Thursday ,December 21, 2023

## Seasonal Limits

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MARCY\_\_\_\_345KV\_CSC

Wed 12/07/2022 to Tue 12/20/2022  
0700 Continuous 1530  
Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2925 MW**  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 2975 MW

### W49TH\_ST-E13THSTA\_345\_M54

Wed 12/14/2022 to Wed 12/14/2022  
0130 Continuous 0200  
Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

### CLAY\_\_\_\_-EDIC\_\_\_\_345\_1-16

Fri 12/30/2022 to Sat 12/31/2022 **UPDATED by NGRID 05/09/2022**  
0600 Continuous 1900  
Work scheduled by: NGrid

FWD  
(Import)  
OSWEGO EXPORT **4850 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

### FRASER\_\_\_\_345\_FRASER SVC

Tue 01/03/2023 to Tue 02/28/2023 **UPDATED by NYPA 12/30/2021**  
0700 Continuous 1730  
Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2935 MW**  
Impacts Total Transfer Capability 40 MW  
TTC with All Lines In Service 2975 MW

### N.SCTLND-ALPS\_\_\_\_345\_2

Mon 03/27/2023 to Fri 05/19/2023 **UPDATED by NGRID 06/16/2022**  
0700 Continuous 1900  
Work scheduled by: NGrid

FWD  
(Import)  
SCH - NE - NY **900 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1400 MW

### N.SCTLND-ALPS\_\_\_\_345\_2

Mon 03/27/2023 to Fri 05/19/2023 **UPDATED by NGRID 06/16/2022**  
0700 Continuous 1900  
Work scheduled by: NGrid

FWD	REV
(Import)	(Export)
SCH - NPX_1385 <b>100 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability 100 MW	100 MW
TTC with All Lines In Service 200 MW	200 MW

### PLSNTVLY\_345KV\_RNS4

Sat 04/01/2023 to Sat 04/01/2023  
0700 Continuous 0730  
Work scheduled by: NGrid

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,June 21, 2022 to Thursday ,December 21, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## ATHENS\_\_-PLSNTVLY\_345\_91

Sat 04/01/2023 to Sat 04/15/2023

0700 Continuous 1900

Work scheduled by: NGrid

FWD

(Import)

UPNY CONED

3800 MW

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

## MOTTHAVN-RAINEY\_\_345\_Q12

Thu 04/13/2023 to Sat 04/22/2023

0001 Continuous 0200

Work scheduled by: ConEd

UPDATEDby CE06/14/2022

FWD

(Import)

SPR/DUN-SOUTH

3800 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

## PLSNTVLY\_345KV\_RNS4

Sat 04/15/2023 to Sat 04/15/2023

1830 Continuous 1900

Work scheduled by: NGrid

FWD

(Import)

UPNY CONED

3800 MW

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

## PLSNTVLY\_345KV\_RNS5

Sun 04/16/2023 to Sun 04/16/2023

0700 Continuous 0730

Work scheduled by: NGrid

FWD

(Import)

UPNY CONED

3800 MW

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

## LEEDS\_\_-PLSNTVLY\_345\_92

Sun 04/16/2023 to Sun 04/30/2023

0700 Continuous 1900

Work scheduled by: NGrid

FWD

(Import)

UPNY CONED

3800 MW

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

## PLSNTVLY\_345KV\_RNS5

Sun 04/30/2023 to Sun 04/30/2023

1830 Continuous 1900

Work scheduled by: NGrid

FWD

(Import)

UPNY CONED

3800 MW

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

## SHOR\_NPX-SHOREHAM\_138\_CSC

Mon 05/01/2023 to Fri 05/05/2023

0600 Continuous 1800

Work scheduled by: LI

FWD

REV

(Import) (Export)

SCH - NPX\_CSC

0 MW

0 MW

Impacts Total Transfer Capability 330 MW 330 MW

TTC with All Lines In Service 330 MW 330 MW

**NYISO TRANSFER LIMITATIONS**

Tuesday ,June 21, 2022 to Thursday ,December 21, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2975MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SHOR_NPX-SHOREHAM_138_CSC</b>				FWD	REV
Mon 10/02/2023	to	Fri 10/06/2023		(Import)	(Export)
0600	Continuous	1800		SCH - NPX_CSC	<b>0 MW</b>
Work scheduled by: LI				Impacts Total Transfer Capability	330 MW
				TTC with All Lines In Service	330 MW
<b>NEPTUNE_-DUFFYAVE_345_NEPTUNE</b>				FWD	
Mon 10/09/2023	to	Fri 10/13/2023		(Import)	
0600	Continuous	1600		SCH - PJM_NEPTUNE	<b>0 MW</b>
Work scheduled by: LI				Impacts Total Transfer Capability	660 MW
				TTC with All Lines In Service	660 MW
<b>NEWBRDGE-DUFFYAVE_345_501</b>				FWD	
Mon 10/09/2023	to	Fri 10/13/2023		(Import)	
0600	Continuous	1600		SCH - PJM_NEPTUNE	<b>0 MW</b>
Work scheduled by: LI				Impacts Total Transfer Capability	660 MW
				TTC with All Lines In Service	660 MW
<b>NEWBRDGE_345_138_BK_1</b>				FWD	
Mon 10/09/2023	to	Fri 10/13/2023		(Import)	
0600	Continuous	1600		SCH - PJM_NEPTUNE	<b>375 MW</b>
Work scheduled by: LI				Impacts Total Transfer Capability	285 MW
				TTC with All Lines In Service	660 MW
<b>NEWBRDGE_345_138_BK_2</b>				FWD	
Mon 10/09/2023	to	Fri 10/13/2023		(Import)	
0600	Continuous	1600		SCH - PJM_NEPTUNE	<b>375 MW</b>
Work scheduled by: LI				Impacts Total Transfer Capability	285 MW
				TTC with All Lines In Service	660 MW
<b>HOMRC_NY-MAINS_NY_345_47</b>					
Fri 12/08/2023	to	Fri 12/15/2023	<b><u>UPDATED</u></b>	<b><u>by PJM</u></b>	<b><u>01/11/2022</u></b>
0800	Continuous	1600			
Work scheduled by: PJM				SCH - PJ - NY	
				Impacts Total Transfer Capability	
				TTC with All Lines In Service	
<b>HOMR_NYW-PIERC_NY_345_48</b>					
Fri 12/08/2023	to	Fri 12/15/2023	<b><u>UPDATED</u></b>	<b><u>by PJM</u></b>	<b><u>01/11/2022</u></b>
0800	Continuous	1600			
Work scheduled by: PJM				SCH - PJ - NY	
				Impacts Total Transfer Capability	
				TTC with All Lines In Service	