

# NYISO TRANSFER LIMITATIONS

Tuesday ,June 07, 2022 to Thursday ,December 07, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## HUDSONP\_-FARRAGUT\_345\_B3402

Mon 01/15/2018 to Sat 12/31/2022 EXT FORCE by CONED 05/14/2022

0001 Continuous 2359

Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJ - NY **2050 MW**  
Impacts Total Transfer Capability 200 MW  
TTC with All Lines In Service 2250 MW

## HUDSONP\_-FARRAGUT\_345\_B3402 & MARION\_-FARRAGUT\_345\_C3403

Mon 01/15/2018 to Sat 12/31/2022

0001 2359

Work scheduled by:

FWD REV  
(Import) (Export)  
SCH - PJ - NY **2000 MW 1150 MW**  
Impacts Total Transfer Capability 250 MW 100 MW  
TTC with All Lines In Service 2250 MW 1250 MW

## MARION\_-FARRAGUT\_345\_C3403

Mon 01/15/2018 to Sat 12/31/2022 EXT FORCE by CONED 05/14/2022

0001 Continuous 2359

Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJ - NY **2050 MW**  
Impacts Total Transfer Capability 200 MW  
TTC with All Lines In Service 2250 MW

## STLAWRNC-MOSES\_\_\_\_230\_L33P

Mon 04/30/2018 to Wed 07/27/2022 EXT FORCE by IESO 05/18/2022

0456 Continuous 1600

Work scheduled by: IESO

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

## NEWBRDGE\_345\_138\_BK\_1

Wed 09/02/2020 to Mon 08/01/2022 EXT FORCE by LI 12/10/2021

1807 Continuous 2359

Work scheduled by: LI

FWD  
(Import)  
SCH - PJM\_NEPTUNE **375 MW**  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 660 MW

## BECK\_\_\_\_-NIAGARA\_345\_PA301

Wed 02/09/2022 to Fri 06/17/2022 UPDATED by NYISO 04/29/2022

0700 Continuous 1700

Work scheduled by: IESO

FWD REV  
(Import) (Export)  
SCH - OH - NY **900 MW 800 MW**  
Impacts Total Transfer Capability 1050 MW 900 MW  
TTC with All Lines In Service 1950 MW 1700 MW

## N.SCTLND-ALPS\_\_\_\_345\_2

Tue 03/08/2022 to Fri 06/03/2022 UPDATED by NGRID 06/02/2022

0700 Continuous 1900

Work scheduled by: NGrid

FWD  
(Import)  
SCH - NE - NY **750 MW**  
Impacts Total Transfer Capability 650 MW  
TTC with All Lines In Service 1400 MW

**NYISO TRANSFER LIMITATIONS**

Tuesday ,June 07, 2022 to Thursday ,December 07, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

						FWD	REV
						(Import)	(Export)
<b>N.SCTLND-ALPS_____345_2</b>							
Tue 03/08/2022	to	Fri 06/03/2022	<u>UPDATED</u>	<u>by NGRID</u>	<u>06/02/2022</u>	SCH - NPX_1385	<b>100 MW</b>
0700	Continuous	1900				Impacts Total Transfer Capability	100 MW
Work scheduled by: NGrid						TTC with All Lines In Service	200 MW
<b>EGRDNCTY_345_138_AT1</b>						FWD	
Sat 03/12/2022	to	Fri 06/10/2022	<u>EXT FORCE</u>	<u>by CE</u>	<u>05/04/2022</u>	(Import)	
2148	Continuous	2359				CONED - LIPA	<b>1250 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	250 MW
						TTC with All Lines In Service	1500 MW
<b>EGRDNCTY_345_138_AT2</b>						FWD	
Sat 03/12/2022	to	Fri 06/10/2022	<u>EXT FORCE</u>	<u>by CE</u>	<u>05/04/2022</u>	(Import)	
2148	Continuous	2359				CONED - LIPA	<b>1250 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	250 MW
						TTC with All Lines In Service	1500 MW
<b>SPRNBK_-EGRDNCTR_345_Y49</b>						FWD	
Sat 03/12/2022	to	Fri 06/10/2022	<u>EXT FORCE</u>	<u>by CE</u>	<u>05/04/2022</u>	(Import)	
2148	Continuous	2359				CONED - LIPA	<b>775 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	725 MW
						TTC with All Lines In Service	1500 MW
<b>W49TH_ST_345KV_6</b>						FWD	
Mon 03/21/2022	to	Thu 06/16/2022	<u>EXT FORCE</u>	<u>by CONED</u>	<u>06/02/2022</u>	(Import)	
0809	Continuous	2359				SCH - PJM_HTP	<b>300 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	360 MW
						TTC with All Lines In Service	660 MW
<b>W49TH_ST_345KV_8</b>						FWD	
Mon 03/21/2022	to	Thu 06/16/2022	<u>EXT FORCE</u>	<u>by CONED</u>	<u>06/02/2022</u>	(Import)	
0811	Continuous	2359				SCH - PJM_HTP	<b>450 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability	210 MW
						TTC with All Lines In Service	660 MW
<b>FIVEMILE-STOLLERD_345_29</b>							
Fri 04/01/2022	to	Tue 12/31/2030	<u>EXTENDED</u>	<u>by NYSEG</u>	<u>05/31/2022</u>	SCH - PJ - NY	
0500	Continuous	2359				Impacts Total Transfer Capability	
Work scheduled by: NYSEG						TTC with All Lines In Service	

# NYISO TRANSFER LIMITATIONS

Tuesday ,June 07, 2022 to Thursday ,December 07, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## GORDONRD-ROTTRDAM\_230\_31

FWD

Wed 04/27/2022 to Mon 10/31/2022 EXT FORCE by NYISO 05/17/2022

(Import)

1130 Continuous 2359

CENTRAL EAST - VC

**2535 MW**

Impacts Total Transfer Capability 50 MW

TTC with All Lines In Service 2585 MW

Work scheduled by: NYISO

## SCH-IMO-NYISO\_LIMIT\_500

FWD

Sun 05/01/2022 to Fri 06/17/2022 UPDATED by NYISO 04/29/2022

(Import)

0001 Continuous 1700

SCH - OH - NY

**800 MW**

Impacts Total Transfer Capability 1150 MW

TTC with All Lines In Service 1950 MW

Work scheduled by: IESO

## SCH-IMO-NYISO\_LIMIT\_1400

FWD

Sun 05/01/2022 to Wed 07/27/2022 UPDATED by IESO 05/18/2022

(Import)

0001 Continuous 1600

SCH - OH - NY

**1700 MW**

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 1950 MW

Work scheduled by: IESO

## SCH-IMO-NYISO\_LIMIT\_1600

FWD

Sun 05/01/2022 to Wed 07/27/2022 UPDATED by IESO 05/18/2022

(Import)

0001 Continuous 1600

SCH - OH - NY

**1900 MW**

Impacts Total Transfer Capability 50 MW

TTC with All Lines In Service 1950 MW

Work scheduled by: IESO

## SCH-NYISO-IMO\_LIMIT\_1200

REV

Sun 05/01/2022 to Wed 07/27/2022 UPDATED by IESO 05/18/2022

(Export)

0001 Continuous 1600

SCH - OH - NY

**1500 MW**

Impacts Total Transfer Capability 200 MW

TTC with All Lines In Service 1700 MW

Work scheduled by: IESO

## SCH-NYISO-IMO\_LIMIT\_1400

REV

Sun 05/01/2022 to Wed 07/27/2022 UPDATED by IESO 05/18/2022

(Export)

0001 Continuous 1600

SCH - OH - NY

**1700 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 1700 MW

Work scheduled by: IESO

## CHAT\_DC\_GC2

FWD

Sun 05/01/2022 to Thu 06/02/2022 UPDATED by HQ 05/26/2022

(Import)

0500 Continuous 1300

MOSES SOUTH

**2850 MW**

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: HQ

**NYISO TRANSFER LIMITATIONS**

Tuesday ,June 07, 2022 to Thursday ,December 07, 2023

**CENTRAL EAST 2650MW**  
**CENTRAL EAST - VC 2585MW**  
**TOTAL EAST 6000MW**  
**UPNY CONED 7815MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3200MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**CHAT\_DC\_GC2**

REV

Sun 05/01/2022 to Thu 06/02/2022 **UPDATED** **by HQ** **05/26/2022**  
0500 Continuous 1300

(Export)

Work scheduled by: HQ

SCH - HQ - NY

**500 MW**

Impacts Total Transfer Capability

500 MW

TTC with All Lines In Service

1000 MW

**SCH-NYISO-HQ\_LIMIT\_500**

REV

Sun 05/01/2022 to Thu 06/02/2022 **UPDATED** **by HQ** **05/26/2022**  
0500 Continuous 1300

(Export)

Work scheduled by: HQ

SCH - HQ - NY

**500 MW**

Impacts Total Transfer Capability

500 MW

TTC with All Lines In Service

1000 MW

**SCH-NYISO-IMO\_LIMIT\_400**

REV

Wed 05/18/2022 to Fri 06/17/2022 **FORCED** **by IESO** **05/05/2022**  
0001 Continuous 1700

(Export)

Work scheduled by: IESO

SCH - OH - NY

**700 MW**

Impacts Total Transfer Capability

1000 MW

TTC with All Lines In Service

1700 MW

**MOSES\_\_-ADIRNDCK\_230\_MA2**

FWD

Tue 05/31/2022 to Thu 09/15/2022 **UPDATED** **by NYPA** **05/04/2022**  
0500 Continuous 1930

(Import)

Work scheduled by: NYPA

MOSES SOUTH

**2100 MW**

Impacts Total Transfer Capability

1050 MW

TTC with All Lines In Service

3150 MW

**PANNELL\_-CLAY\_\_\_\_345\_2**

FWD

Tue 05/31/2022 to Thu 06/02/2022  
0700 Continuous 1500

(Import)

Work scheduled by: RGE

WEST CENTRAL

**1300 MW**

Impacts Total Transfer Capability

950 MW

TTC with All Lines In Service

2250 MW

**SCH-NYISO-NE\_LIMIT\_800**

REV

Tue 05/31/2022 to Fri 06/03/2022 **UPDATED** **by ISONE** **05/26/2022**  
1500 Continuous 1900

(Export)

Work scheduled by: ISONE

SCH - NE - NY

**1000 MW**

Impacts Total Transfer Capability

600 MW

TTC with All Lines In Service

1600 MW

**PIERCBRK-FIVEMILE\_345\_37**

Wed 06/01/2022 to Thu 06/02/2022  
0730 Continuous 1600

Work scheduled by: NGrid

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

# NYISO TRANSFER LIMITATIONS

Tuesday ,June 07, 2022 to Thursday ,December 07, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## SPRNBK\_\_345KV\_RS3 & SPRNBK\_\_345KV\_RS4

FWD

Fri 06/03/2022 to Fri 06/03/2022  
0001 0030

(Import)

SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

Work scheduled by:

## SCH-NYISO-NE\_LIMIT\_0

REV

Fri 06/03/2022 to Fri 06/03/2022 UPDATED by NGRID 06/02/2022  
0001 Continuous 1900

(Export)

SCH - NE - NY **200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 1600 MW

Work scheduled by: NGrid

## MARCY\_\_-EDIC\_\_345\_UE1-7

FWD

Fri 06/03/2022 to Fri 06/03/2022 UPDATED by NYPA 06/04/2022  
0500 Continuous 2300

(Import)

OSWEGO EXPORT **5250 MW**  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

Work scheduled by: NYPA

ARR: 19&amp;16

## SPRNBK\_\_345KV\_RS3 & SPRNBK\_\_345KV\_RS4

FWD

Fri 06/03/2022 to Fri 06/03/2022  
1730 1800

(Import)

SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

Work scheduled by:

## SCH-NE-NYISO\_LIMIT\_1000

FWD

Fri 06/03/2022 to Wed 06/08/2022 UPDATED by ISONE 05/26/2022  
1900 Continuous 1600

(Import)

SCH - NE - NY **1200 MW**  
Impacts Total Transfer Capability 200 MW  
TTC with All Lines In Service 1400 MW

Work scheduled by: ISONE

## PLSNTVLY-WOOD\_ST\_\_345\_F31

FWD

Sat 06/04/2022 to Sat 06/04/2022  
0001 Continuous 2200

(Import)

UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 3815 MW  
TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

## CHAT\_DC\_GC1

FWD

Sun 06/05/2022 to Sun 06/05/2022 CANCELLED by HQ 06/05/2022  
0001 Continuous 0200

(Import)

MOSES SOUTH **2850 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

Work scheduled by: HQ

# NYISO TRANSFER LIMITATIONS

Tuesday ,June 07, 2022 to Thursday ,December 07, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## CHAT\_DC\_GC1

Sun 06/05/2022 to Sun 06/05/2022  
0001 Continuous 0200

CANCELLED by HQ06/05/2022

Work scheduled by: HQ

SCH - HQ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

REV

(Export)

**500 MW**

500 MW

1000 MW

## CHAT\_DC\_GC2

Sun 06/05/2022 to Sun 06/05/2022  
0001 Continuous 0200

CANCELLED by HQ06/05/2022

Work scheduled by: HQ

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD

(Import)

**2850 MW**

300 MW

3150 MW

## CHAT\_DC\_GC2

Sun 06/05/2022 to Sun 06/05/2022  
0001 Continuous 0200

CANCELLED by HQ06/05/2022

Work scheduled by: HQ

SCH - HQ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

REV

(Export)

**500 MW**

500 MW

1000 MW

## SCH-HQ-NYISO\_LIMIT\_1150

Sun 06/05/2022 to Sun 06/05/2022  
0001 Continuous 0200

CANCELLED by HQ06/05/2022

Work scheduled by: HQ

SCH - HQ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD

(Import)

**1150 MW**

350 MW

1500 MW

## MILLWOOD-EASTVIEW\_345\_W85

Sun 06/05/2022 to Wed 06/08/2022  
0001 Continuous 2200

CANCELLED by CE06/03/2022

Work scheduled by: ConEd

UPNY CONED

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD

(Import)

**7550 MW**

265 MW

7815 MW

## CHAT\_DC\_GC1

Mon 06/06/2022 to Tue 06/07/2022  
1107 Continuous 2359

Work scheduled by: HQ

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD

(Import)

**2850 MW**

300 MW

3150 MW

## CHAT\_DC\_GC1

Mon 06/06/2022 to Tue 06/07/2022  
1107 Continuous 2359

Work scheduled by: HQ

SCH - HQ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

REV

(Export)

**500 MW**

500 MW

1000 MW

**NYISO TRANSFER LIMITATIONS**

Tuesday ,June 07, 2022 to Thursday ,December 07, 2023

**CENTRAL EAST 2650MW**  
**CENTRAL EAST - VC 2585MW**  
**TOTAL EAST 6000MW**  
**UPNY CONED 7815MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3200MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**HUDSONTP-W49TH\_ST\_345\_Y56**

FWD

Thu 06/09/2022 to Sat 06/11/2022

(Import)

0001 Continuous 0200

SCH - PJM\_HTP

**0 MW**

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

**W49TH\_ST\_345KV\_7**

FWD

Thu 06/09/2022 to Sat 06/11/2022

(Import)

0001 Continuous 0200

SCH - PJM\_HTP

**300 MW**

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

**SCH-NE-NYISO\_LIMIT\_600**

FWD

Thu 06/09/2022 to Thu 06/16/2022

(Import)

0700 Continuous 2259

**UPDATED****by ISONE 06/04/2022**

SCH - NE - NY

**800 MW**

Impacts Total Transfer Capability 600 MW

TTC with All Lines In Service 1400 MW

Work scheduled by: ISONE

**FROST\_BR-LONG\_MTN\_345\_352**

FWD

Thu 06/09/2022 to Fri 06/17/2022

(Import)

0700 Continuous 1600

**UPDATED****by ISONE 06/04/2022**

SCH - NE - NY

**1150 MW**

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 1400 MW

Work scheduled by: ISONE

**SCH-NE-NYISO\_LIMIT\_300**

FWD

Thu 06/09/2022 to Fri 06/17/2022

(Import)

2300 Continuous 0659

**UPDATED****by ISONE 06/04/2022**

SCH - NE - NY

**500 MW**

Impacts Total Transfer Capability 900 MW

TTC with All Lines In Service 1400 MW

Work scheduled by: ISONE

**W49TH\_ST-E13THSTA\_345\_M55**

FWD

Fri 06/10/2022 to Sat 06/11/2022

(Import)

0201 Continuous 0200

**UPDATED****by CE 06/05/2022**

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**MOTTHAVN-RAINEY\_\_\_345\_Q11**

FWD

Sun 06/12/2022 to Wed 06/15/2022

(Import)

0001 Continuous 0200

**CANCELLED****by ConEd 06/02/2022**

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

# NYISO TRANSFER LIMITATIONS

Tuesday ,June 07, 2022 to Thursday ,December 07, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## NIAGARA\_-DYSINGER\_345\_ND1

FWD

Mon 06/13/2022 to Fri 06/17/2022

(Import)

0500 Continuous 2100

DYSINGER EAST **2700 MW**

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 3200 MW

Work scheduled by: NYPA

## OAKDALE\_-FRASER\_345\_32

FWD

Wed 06/15/2022 to Fri 06/17/2022

(Import)

0800 Continuous 1600

CENTRAL EAST - VC **2450 MW**

Impacts Total Transfer Capability 135 MW

TTC with All Lines In Service 2585 MW

Work scheduled by: NYSEG

## SCH-NE-NYISO\_LIMIT\_600

FWD

Fri 06/17/2022 to Fri 06/17/2022

(Import)

0700 Continuous 1600

**UPDATED by ISONE 06/04/2022**SCH - NE - NY **800 MW**

Impacts Total Transfer Capability 600 MW

TTC with All Lines In Service 1400 MW

Work scheduled by: ISONE

## MARCY\_-EDIC\_345\_UE1-7

FWD

Sat 06/18/2022 to Sun 06/19/2022

(Import)

0600 Continuous 1830

OSWEGO EXPORT **5250 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NYPA

**ARR: 19&16**

## FRASER\_-GILBOA\_345\_GF5-35

FWD

Tue 06/21/2022 to Sun 06/26/2022

(Import)

0700 Continuous 1530

CENTRAL EAST - VC **2450 MW**

Impacts Total Transfer Capability 135 MW

TTC with All Lines In Service 2585 MW

Work scheduled by: NYPA

## BEAR SWP-EASTOVER\_230\_E205W

Mon 06/27/2022 to Tue 06/28/2022

0700 Continuous 0759

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: ISONE

## NIAGARA\_345\_230\_AT4

FWD

REV

Tue 06/28/2022 to Wed 06/29/2022

(Import) (Export)

0500 Continuous 1700

SCH - OH - NY **1900 MW 1400 MW**

Impacts Total Transfer Capability 50 MW 300 MW

TTC with All Lines In Service 1950 MW 1700 MW

Work scheduled by: NYPA



**NYISO TRANSFER LIMITATIONS**

Tuesday ,June 07, 2022 to Thursday ,December 07, 2023

CENTRAL EAST 2650MW  
CENTRAL EAST - VC 2585MW  
TOTAL EAST 6000MW  
UPNY CONED 7815MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3200MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**BEAR SWP-EASTOVER\_230\_E205W**

Tue 06/28/2022 to Tue 06/28/2022

0800 Daily(No Weekends) 1500

Work scheduled by: NGrid

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

**BEAR SWP-EASTOVER\_230\_E205W**

Tue 06/28/2022 to Thu 06/30/2022

1501 Continuous 1700

Work scheduled by: ISONE

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

**BECK\_\_\_\_-NIAGARA\_230\_PA27**

Tue 07/05/2022 to Sat 07/09/2022

0500 Continuous 2100

Work scheduled by: NYPA

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

**DYSINGER-STA\_255\_\_345\_DH1**

Tue 07/05/2022 to Sat 07/09/2022

0700 Continuous 1900

Work scheduled by: NT

FWD

(Import)

DYSINGER EAST

**2850 MW**

Impacts Total Transfer Capability 350 MW

TTC with All Lines In Service 3200 MW

**SAND\_BAR-PLATSBURG\_115\_PV20**

Wed 07/06/2022 to Fri 07/08/2022

0530 Continuous 2000

Work scheduled by: NYPA

**UPDATED****by NYPA****05/31/2022**

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

**NIAGARA\_-DYSINGER\_345\_ND1**

Mon 07/11/2022 to Fri 07/15/2022

0500 Continuous 1700

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST

**2700 MW**

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 3200 MW

**HURLYAVE-ROSETON\_\_345\_303**

Mon 07/11/2022 to Fri 07/22/2022

0800 Continuous 1600

Work scheduled by: CHGE

**02/14/2022**

FWD

(Import)

UPNY CONED

**4100 MW**

Impacts Total Transfer Capability 3715 MW

TTC with All Lines In Service 7815 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,June 07, 2022 to Thursday ,December 07, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## BECK\_\_\_\_-PACKARD\_\_230\_BP76

Tue 07/12/2022 to Tue 07/12/2022

0700 Daily(No Weekends) 1300

Work scheduled by: NGrid

FWD REV  
(Import) (Export)

SCH - OH - NY **1500 MW 1150 MW**  
 Impacts Total Transfer Capability 450 MW 550 MW  
 TTC with All Lines In Service 1950 MW 1700 MW

## PLSNTVLY-WOOD\_ST\_\_345\_F31

Sun 07/24/2022 to Tue 07/26/2022

0001 Continuous 2200

Work scheduled by: ConEd

FWD  
(Import)

UPNY CONED **4000 MW**  
 Impacts Total Transfer Capability 3815 MW  
 TTC with All Lines In Service 7815 MW

## ROCHESTR-PANNELL\_\_345\_RP1

Mon 07/25/2022 to Fri 07/29/2022

0500 Continuous 2100

Work scheduled by: NYPA

FWD  
(Import)

DYSINGER EAST **2300 MW**  
 Impacts Total Transfer Capability 900 MW  
 TTC with All Lines In Service 3200 MW

## FRASANNX-COOPERS\_\_345\_UCC2-41

Mon 07/25/2022 to Fri 08/05/2022

0700 Continuous 1700

Work scheduled by: NYPA

FWD  
(Import)

CENTRAL EAST - VC **2275 MW**  
 Impacts Total Transfer Capability 310 MW  
 TTC with All Lines In Service 2585 MW

ARR: 19

## MARCY\_\_\_\_-FRASANNX\_345\_UCC2-41

Mon 07/25/2022 to Fri 08/05/2022

0700 Continuous 1700

Work scheduled by: NYPA

FWD  
(Import)

CENTRAL EAST - VC **2275 MW**  
 Impacts Total Transfer Capability 310 MW  
 TTC with All Lines In Service 2585 MW

ARR: 19

## NIAGARA\_-DYSINGER\_345\_ND2

Mon 08/01/2022 to Fri 08/05/2022

0500 Continuous 1700

Work scheduled by: NYPA

FWD  
(Import)

DYSINGER EAST **2700 MW**  
 Impacts Total Transfer Capability 500 MW  
 TTC with All Lines In Service 3200 MW

## NIAGARA\_-DYSINGER\_345\_ND2 & DYSINGER-STA\_255\_\_345\_DH2

Mon 08/01/2022 to Fri 08/05/2022

0700 1700

Work scheduled by:

FWD  
(Import)

DYSINGER EAST **2500 MW**  
 Impacts Total Transfer Capability 700 MW  
 TTC with All Lines In Service 3200 MW

**NYISO TRANSFER LIMITATIONS**

Tuesday ,June 07, 2022 to Thursday ,December 07, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**DYSINGER-STA\_255\_\_345\_DH2**

FWD

Mon 08/01/2022 to Fri 08/05/2022

UPDATEDby NT05/23/2022

(Import)

0700 Continuous 1900

DYSINGER EAST

**2850 MW**

Impacts Total Transfer Capability 350 MW

TTC with All Lines In Service 3200 MW

Work scheduled by: NT

**MARCY\_\_-EDIC\_\_345\_UE1-7**

FWD

Sat 08/06/2022 to Sun 08/07/2022

UPDATEDby NYPA05/25/2022

(Import)

0500 Continuous 1830

OSWEGO EXPORT

**5250 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NYPA

**ARR: 19&16****VOLNEY\_\_-MARCY\_\_345\_19**

FWD

Sat 08/06/2022 to Sun 08/07/2022

UPDATEDby NYPA05/25/2022

(Import)

0500 Continuous 1830

CENTRAL EAST - VC

**2475 MW**

Impacts Total Transfer Capability 110 MW

TTC with All Lines In Service 2585 MW

Work scheduled by: NYPA

**ARR: 19****VOLNEY\_\_-MARCY\_\_345\_19**

FWD

Sat 08/06/2022 to Sun 08/07/2022

UPDATEDby NYPA05/25/2022

(Import)

0500 Continuous 1830

OSWEGO EXPORT

**4900 MW**

Impacts Total Transfer Capability 350 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NYPA

**ARR: 19****VOLNEY\_\_-MARCY\_\_345\_19 & GORDONRD-ROTTDAM\_230\_31**

FWD

Sat 08/06/2022 to Sun 08/07/2022

CENTRAL EAST - VC

**2425 MW**

0500 1830

Impacts Total Transfer Capability 160 MW

TTC with All Lines In Service 2585 MW

Work scheduled by:

**ARR: 19****FRASANNX-COOPERS\_\_345\_UCC2-41**

FWD

Mon 08/08/2022 to Fri 09/09/2022

CENTRAL EAST - VC

**2275 MW**

0700 Continuous 1700

Impacts Total Transfer Capability 310 MW

TTC with All Lines In Service 2585 MW

Work scheduled by: NYPA

**ARR: 19****MARCY\_\_-FRASANNX\_345\_UCC2-41**

FWD

Mon 08/08/2022 to Fri 09/09/2022

CENTRAL EAST - VC

**2275 MW**

0700 Continuous 1700

Impacts Total Transfer Capability 310 MW

TTC with All Lines In Service 2585 MW

Work scheduled by: NYPA

**ARR: 19**

**NYISO TRANSFER LIMITATIONS**

Tuesday ,June 07, 2022 to Thursday ,December 07, 2023

CENTRAL EAST 2650MW  
CENTRAL EAST - VC 2585MW  
TOTAL EAST 6000MW  
UPNY CONED 7815MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3200MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**STLAWRNC-MOSES\_\_\_230\_L34P**

Mon 08/15/2022 to Tue 04/18/2023

0400 Continuous 2359

Work scheduled by: IESO

**EXTENDED by IESO 05/18/2022**

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

**SAND\_BAR-PLATSBRG\_115\_PV20**

Mon 08/22/2022 to Fri 08/26/2022

0700 Continuous 1530

Work scheduled by: NYPA

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

**ROSETON\_-ROCKTVRN\_345\_311**

Mon 08/29/2022 to Fri 09/09/2022

0800 Continuous 1600

Work scheduled by: CHGE

FWD

(Import)

UPNY CONED

**4400 MW**

Impacts Total Transfer Capability 3415 MW

TTC with All Lines In Service 7815 MW

**EFISHKIL-WOOD\_ST\_\_345\_F38**

Thu 09/01/2022 to Sat 09/03/2022

0001 Continuous 2200

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 3815 MW

TTC with All Lines In Service 7815 MW

**PLSNTVLE-DUNWODIE\_345\_W89**

Thu 09/01/2022 to Sat 09/03/2022

0001 Continuous 2200

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 3815 MW

TTC with All Lines In Service 7815 MW

**WOOD\_ST\_-PLSNTVLE\_345\_Y86**

Thu 09/01/2022 to Sat 09/03/2022

0001 Continuous 2200

Work scheduled by: ConEd

FWD

(Import)

UPNY CONED

**7210 MW**

Impacts Total Transfer Capability 605 MW

TTC with All Lines In Service 7815 MW

**MOTTHAVN-RAINEY\_\_\_345\_Q12**

Thu 09/01/2022 to Mon 09/05/2022

0001 Continuous 0200

Work scheduled by: ConEd

FWD

(Import)

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,June 07, 2022 to Thursday ,December 07, 2023

## Seasonal Limits

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### DUNWODIE\_345KV\_6

Wed 09/07/2022 to Wed 09/07/2022  
0001 Continuous 0030  
Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

### DUNWODIE\_345KV\_8

Wed 09/07/2022 to Wed 09/07/2022  
0001 Continuous 0030  
Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

### WOOD\_ST\_-PLSNTVLE\_345\_Y87

Wed 09/07/2022 to Wed 09/07/2022  
0001 Continuous 0030  
Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **7260 MW**  
Impacts Total Transfer Capability 555 MW  
TTC with All Lines In Service 7815 MW

### PLSNTVLE-DUNWODIE\_345\_W90

Wed 09/07/2022 to Sat 09/10/2022  
0001 Continuous 0200  
Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 3815 MW  
TTC with All Lines In Service 7815 MW

### DUNWODIE\_345KV\_6

Sat 09/10/2022 to Sat 09/10/2022  
0130 Continuous 0200  
Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

### DUNWODIE\_345KV\_8

Sat 09/10/2022 to Sat 09/10/2022  
0130 Continuous 0200  
Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

### WOOD\_ST\_-PLSNTVLE\_345\_Y87

Sat 09/10/2022 to Sat 09/10/2022  
0130 Continuous 0200  
Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **7260 MW**  
Impacts Total Transfer Capability 555 MW  
TTC with All Lines In Service 7815 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,June 07, 2022 to Thursday ,December 07, 2023

## Seasonal Limits

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### FRASER\_\_-GILBOA\_\_345\_GF5-35

Mon 09/12/2022 to Sun 09/18/2022  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2450 MW**  
Impacts Total Transfer Capability 135 MW  
TTC with All Lines In Service 2585 MW

### EASTVIEW-SPRNBK\_\_345\_W64

Tue 09/13/2022 to Thu 09/15/2022  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

### MILLWOOD-EASTVIEW\_345\_W99

Tue 09/13/2022 to Thu 09/15/2022  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **7550 MW**  
Impacts Total Transfer Capability 265 MW  
TTC with All Lines In Service 7815 MW

### SPRNBK\_\_345KV\_RNS5

Tue 09/13/2022 to Thu 09/15/2022  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

### MOSES\_\_-ADIRNDCK\_230\_MA2

Thu 09/15/2022 to Tue 11/29/2022 **UPDATED by NYPA 05/04/2022**  
1931 Continuous 1800

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

### EASTVIEW-SPRNBK\_\_345\_W78

Fri 09/16/2022 to Wed 09/21/2022 **UPDATED by CONED 06/07/2022**  
2100 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

### MILLWOOD-EASTVIEW\_345\_W85

Fri 09/16/2022 to Wed 09/21/2022 **UPDATED by CONED 06/07/2022**  
2100 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **7550 MW**  
Impacts Total Transfer Capability 265 MW  
TTC with All Lines In Service 7815 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,June 07, 2022 to Thursday ,December 07, 2023

## Seasonal Limits

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SPRNBRK\_\_345KV\_RNS3

FWD

Fri 09/16/2022 to Wed 09/21/2022 UPDATED by CONED 06/07/2022

(Import)

2100 Continuous 0200

SPR/DUN-SOUTH **3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

### FRASER\_\_345\_FRASER SVC

FWD

Mon 09/19/2022 to Tue 09/27/2022

(Import)

0600 Continuous 1700

CENTRAL EAST - VC **2550 MW**

Impacts Total Transfer Capability 35 MW

TTC with All Lines In Service 2585 MW

Work scheduled by: NYSEG

### MARCY\_\_-EDIC\_\_345\_UE1-7

FWD

Mon 09/19/2022 to Sat 10/08/2022 UPDATED by NGRID 06/06/2022

(Import)

0700 Continuous 1530

OSWEGO EXPORT **5250 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NYPA

ARR: 19&16

### LEEDS\_\_-HURLYAVE\_345\_301

FWD

Mon 09/19/2022 to Fri 10/21/2022 10/04/2021

(Import)

0800 Continuous 1600

UPNY CONED **4100 MW**

Impacts Total Transfer Capability 3715 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: CHGE

### EGRDNCTY\_345\_138\_AT1

FWD

Sat 10/01/2022 to Wed 05/31/2023 UPDATED by CONED 03/10/2022

(Import)

0001 Continuous 2359

CONED - LIPA **1250 MW**

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 1500 MW

Work scheduled by: LI

### EGRDNCTY\_345\_138\_AT2

FWD

Sat 10/01/2022 to Wed 05/31/2023 UPDATED by CONED 03/10/2022

(Import)

0001 Continuous 2359

CONED - LIPA **1250 MW**

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 1500 MW

Work scheduled by: LI

### SPRNBRK\_-EGRDNCTR\_345\_Y49

FWD

Sat 10/01/2022 to Wed 05/31/2023 UPDATED by CONED 03/10/2022

(Import)

0001 Continuous 2359

CONED - LIPA **775 MW**

Impacts Total Transfer Capability 725 MW

TTC with All Lines In Service 1500 MW

Work scheduled by: LI

# NYISO TRANSFER LIMITATIONS

Tuesday ,June 07, 2022 to Thursday ,December 07, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CLRKSCRN-OAKDALE__345_36					FWD	
Mon 10/03/2022	to	Fri 10/07/2022	<u>UPDATED</u>	<u>by NYSEG</u>	<u>04/20/2022</u>	(Import)
0830	Continuous	1530				
Work scheduled by: NYSEG					CENTRAL EAST - VC	<b>2450 MW</b>
					Impacts Total Transfer Capability	135 MW
					TTC with All Lines In Service	2585 MW
SHOR_NPX-SHOREHAM_138_CSC					FWD	REV
Mon 10/03/2022	to	Fri 10/21/2022	<u>UPDATED</u>	<u>by LI</u>	<u>01/07/2022</u>	(Import) (Export)
1000	Continuous	1500				
Work scheduled by: LI					SCH - NPX_CSC	<b>0 MW</b> <b>0 MW</b>
					Impacts Total Transfer Capability	330 MW 330 MW
					TTC with All Lines In Service	330 MW 330 MW
EDIC____-N.SCTLND_345_14 & GORDONRD-ROTTDAM_230_31					FWD	
Mon 10/10/2022	to	Mon 10/31/2022				(Import)
0700		2359				
Work scheduled by:					CENTRAL EAST - VC	<b>1645 MW</b>
					Impacts Total Transfer Capability	940 MW
					TTC with All Lines In Service	2585 MW
EDIC____-N.SCTLND_345_14					FWD	
Mon 10/10/2022	to	Tue 12/31/2030				(Import)
0700	Continuous	2359				
Work scheduled by: NGrid					CENTRAL EAST - VC	<b>1695 MW</b>
					Impacts Total Transfer Capability	890 MW
					TTC with All Lines In Service	2585 MW
NIAGARA_-DYSINGER_345_ND1					FWD	
Mon 10/17/2022	to	Fri 10/21/2022	<u>UPDATED</u>	<u>by NYPA</u>	<u>02/10/2022</u>	(Import)
0500	Continuous	1700				
Work scheduled by: NYPA					DYSINGER EAST	<b>2700 MW</b>
					Impacts Total Transfer Capability	500 MW
					TTC with All Lines In Service	3200 MW
PANNELL_-CLAY____345_1					FWD	
Mon 10/24/2022	to	Fri 10/28/2022				(Import)
0700	Continuous	1530				
Work scheduled by: NYPA					WEST CENTRAL	<b>1300 MW</b>
					Impacts Total Transfer Capability	950 MW
					TTC with All Lines In Service	2250 MW
HURLYAVE-ROSETON__345_303					FWD	
Mon 10/24/2022	to	Fri 11/04/2022	<u>UPDATED</u>	<u>by CH</u>	<u>04/13/2022</u>	(Import)
0800	Continuous	1600				
Work scheduled by: CHGE					UPNY CONED	<b>4100 MW</b>
					Impacts Total Transfer Capability	3715 MW
					TTC with All Lines In Service	7815 MW



# NYISO TRANSFER LIMITATIONS

Tuesday, June 07, 2022 to Thursday, December 07, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## MAINESBG-WATRCURE\_345\_30

Tue 10/25/2022 to Tue 10/25/2022  
0800 Daily 1500

Work scheduled by: NYSEG

FWD  
(Import)  
SCH - PJ - NY **2200 MW**  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 2250 MW

## WATRCURE-OAKDALE\_345\_31

Thu 10/27/2022 to Thu 10/27/2022  
0800 Daily 1500

Work scheduled by: NYSEG

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

## PANNELL -CLAY\_345\_2

Mon 10/31/2022 to Fri 11/04/2022  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

## CLAY -EDIC\_345\_1-16

Tue 11/01/2022 to Thu 11/03/2022  
0600 Continuous 1900

Work scheduled by: NGrid

**UPDATED by NGRID 05/09/2022**

FWD  
(Import)  
OSWEGO EXPORT **4850 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

## NEPTUNE -DUFFYAVE\_345\_NEPTUNE

Tue 11/01/2022 to Sat 11/19/2022  
0600 Continuous 1600

Work scheduled by: LI

FWD  
(Import)  
SCH - PJM\_NEPTUNE **0 MW**  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

## NEWBRDGE-DUFFYAVE\_345\_501

Tue 11/01/2022 to Sat 11/19/2022  
0600 Continuous 1600

Work scheduled by: LI

FWD  
(Import)  
SCH - PJM\_NEPTUNE **0 MW**  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

## NEWBRDGE\_345\_138\_BK\_1

Tue 11/01/2022 to Sat 11/19/2022  
0600 Continuous 1600

Work scheduled by: LI

FWD  
(Import)  
SCH - PJM\_NEPTUNE **375 MW**  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 660 MW

# NYISO TRANSFER LIMITATIONS

Tuesday ,June 07, 2022 to Thursday ,December 07, 2023

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEWBRDGE_345_138_BK_2					FWD	
Tue 11/01/2022	to	Sat 11/19/2022			(Import)	
0600	Continuous	1600			SCH - PJM_NEPTUNE	375 MW
Work scheduled by: LI					Impacts Total Transfer Capability	285 MW
					TTC with All Lines In Service	660 MW
GILBOA__-N.SCTLND_345_GNS-1					FWD	
Tue 11/01/2022	to	Tue 12/06/2022	<u>UPDATED</u>	<u>by NGRID</u> <u>12/29/2021</u>	(Import)	
0700	Continuous	1900			CENTRAL EAST - VC	2300 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	285 MW
					TTC with All Lines In Service	2585 MW
LEEDS___345KV_R94301					FWD	
Tue 11/01/2022	to	Tue 12/06/2022	<u>UPDATED</u>	<u>by NGRID</u> <u>12/29/2021</u>	(Import)	
0700	Continuous	1900			UPNY CONED	3800 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	4015 MW
					TTC with All Lines In Service	7815 MW
MARCY___-N.SCTLND_345_18					FWD	
Tue 11/01/2022	to	Tue 12/06/2022	<u>UPDATED</u>	<u>by NGRID</u> <u>12/29/2021</u>	(Import)	
0700	Continuous	1900			CENTRAL EAST - VC	1400 MW
Work scheduled by: NGrid					Impacts Total Transfer Capability	1185 MW
					TTC with All Lines In Service	2585 MW
LINDN_CG-LNDVFT___345_V-3022					FWD	REV
Tue 11/01/2022	to	Fri 11/04/2022			(Import)	(Export)
0800	Continuous	1500			SCH - PJM_VFT	0 MW 0 MW
Work scheduled by: PJM					Impacts Total Transfer Capability	315 MW 315 MW
					TTC with All Lines In Service	315 MW 315 MW
LEEDS___-HURLYAVE_345_301					FWD	
Mon 11/07/2022	to	Fri 12/09/2022			(Import)	
0800	Continuous	1600			UPNY CONED	4100 MW
Work scheduled by: CHGE					Impacts Total Transfer Capability	3715 MW
					TTC with All Lines In Service	7815 MW
MOSES___-ADIRNDCK_230_MAI					FWD	
Wed 11/30/2022	to	Wed 03/01/2023			(Import)	
0700	Continuous	1100			MOSES SOUTH	2300 MW
Work scheduled by: NYPA					Impacts Total Transfer Capability	850 MW
					TTC with All Lines In Service	3150 MW

**NYISO TRANSFER LIMITATIONS**

Tuesday ,June 07, 2022 to Thursday ,December 07, 2023

**CENTRAL EAST 2650MW**  
**CENTRAL EAST - VC 2585MW**  
**TOTAL EAST 6000MW**  
**UPNY CONED 7815MW**  
**SPR/DUN-SOUTH 4600MW**  
**DYSINGER EAST 3200MW**  
**MOSES SOUTH 3150MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**CLAY -EDIC 345\_1-16**

FWD

Fri 12/30/2022 to Sat 12/31/2022

UPDATEDby NGRID 05/09/2022

(Import)

0600 Continuous 1900

OSWEGO EXPORT

**4850 MW**

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NGrid

**FRASER 345\_FRASER SVC**

FWD

Tue 01/03/2023 to Tue 02/28/2023

UPDATEDby NYPA 12/30/2021

(Import)

0700 Continuous 1730

CENTRAL EAST - VC

**2550 MW**

Impacts Total Transfer Capability 35 MW

TTC with All Lines In Service 2585 MW

Work scheduled by: NYPA

**PLSNTVLY\_345KV\_RNS4**

FWD

Sat 04/01/2023 to Sat 04/01/2023

(Import)

0700 Continuous 0730

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: NGrid

**ATHENS -PLSNTVLY\_345\_91**

FWD

Sat 04/01/2023 to Sat 04/15/2023

(Import)

0700 Continuous 1900

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: NGrid

**PLSNTVLY\_345KV\_RNS4**

FWD

Sat 04/15/2023 to Sat 04/15/2023

(Import)

1830 Continuous 1900

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: NGrid

**PLSNTVLY\_345KV\_RNS5**

FWD

Sun 04/16/2023 to Sun 04/16/2023

(Import)

0700 Continuous 0730

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: NGrid

**LEEDS -PLSNTVLY\_345\_92**

FWD

Sun 04/16/2023 to Sun 04/30/2023

(Import)

0700 Continuous 1900

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: NGrid

# NYISO TRANSFER LIMITATIONS

Tuesday ,June 07, 2022 to Thursday ,December 07, 2023

## Seasonal Limits

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### PLSNTVLY\_345KV\_RNS5

Sun 04/30/2023 to Sun 04/30/2023  
1830 Continuous 1900  
Work scheduled by: NGrid

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

### SHOR\_NPX-SHOREHAM\_138\_CSC

Mon 05/01/2023 to Fri 05/05/2023  
0600 Continuous 1800  
Work scheduled by: LI

FWD	REV
(Import)	(Export)
SCH - NPX_CSC	<b>0 MW</b> <b>0 MW</b>
Impacts Total Transfer Capability	330 MW 330 MW
TTC with All Lines In Service	330 MW 330 MW

### SHOR\_NPX-SHOREHAM\_138\_CSC

Mon 10/02/2023 to Fri 10/06/2023  
0600 Continuous 1800  
Work scheduled by: LI

FWD	REV
(Import)	(Export)
SCH - NPX_CSC	<b>0 MW</b> <b>0 MW</b>
Impacts Total Transfer Capability	330 MW 330 MW
TTC with All Lines In Service	330 MW 330 MW

### NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE

Mon 10/09/2023 to Fri 10/13/2023  
0600 Continuous 1600  
Work scheduled by: LI

FWD  
(Import)  
SCH - PJM\_NEPTUNE **0 MW**  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

### NEWBRDGE-DUFFYAVE\_345\_501

Mon 10/09/2023 to Fri 10/13/2023  
0600 Continuous 1600  
Work scheduled by: LI

FWD  
(Import)  
SCH - PJM\_NEPTUNE **0 MW**  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

### NEWBRDGE\_345\_138\_BK\_1

Mon 10/09/2023 to Fri 10/13/2023  
0600 Continuous 1600  
Work scheduled by: LI

FWD  
(Import)  
SCH - PJM\_NEPTUNE **375 MW**  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 660 MW

### NEWBRDGE\_345\_138\_BK\_2

Mon 10/09/2023 to Fri 10/13/2023  
0600 Continuous 1600  
Work scheduled by: LI

FWD  
(Import)  
SCH - PJM\_NEPTUNE **375 MW**  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 660 MW