

NYISO TRANSFER LIMITATIONS

Monday ,October 03, 2022 to Wednesday, April 03, 2024

| | |
|-------------------|--------|
| CENTRAL EAST | 2650MW |
| CENTRAL EAST - VC | 2585MW |
| TOTAL EAST | 6000MW |
| UPNY CONED | 7815MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3200MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONP_-FARRAGUT_345_B3402

FWD

Mon 01/15/2018 to Tue 01/31/2023 EXT FORCE by CONED 08/06/2022

(Import)

0001 Continuous 2359

Work scheduled by: ConEd

SCH - PJ - NY **2050 MW**
 Impacts Total Transfer Capability 200 MW
 TTC with All Lines In Service 2250 MW

HUDSONP_-FARRAGUT_345_B3402 & MARION_-FARRAGUT_345_C3403

FWD

REV

Mon 01/15/2018 to Tue 01/31/2023

(Import) (Export)

0001 2359

Work scheduled by:

SCH - PJ - NY **2000 MW 1150 MW**
 Impacts Total Transfer Capability 250 MW 50 MW
 TTC with All Lines In Service 2250 MW 1200 MW

MARION_-FARRAGUT_345_C3403

FWD

Mon 01/15/2018 to Tue 01/31/2023 EXT FORCE by CONED 08/06/2022

(Import)

0001 Continuous 2359

Work scheduled by: ConEd

SCH - PJ - NY **2050 MW**
 Impacts Total Transfer Capability 200 MW
 TTC with All Lines In Service 2250 MW

GORDONRD-ROTTDAM_230_30

FWD

Wed 04/27/2022 to Thu 10/06/2022 UPDATED by LS 09/29/2022

(Import)

1122 Continuous 1000

Work scheduled by: NYISO

CENTRAL EAST - VC **2535 MW**
 Impacts Total Transfer Capability 50 MW
 TTC with All Lines In Service 2585 MW

STLAWRNC-MOSES_230_L34P

Sat 07/30/2022 to Mon 10/03/2022 EXTENDED by IESO 08/15/2022

1600 Continuous 1759

Work scheduled by: IESO

SCH - OH - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

SCH-IMO-NYISO_LIMIT_1400

FWD

Wed 08/10/2022 to Mon 10/10/2022 EXTENDED by IESO 08/19/2022

(Import)

0800 Continuous 1600

Work scheduled by: IESO

SCH - OH - NY **1700 MW**
 Impacts Total Transfer Capability 200 MW
 TTC with All Lines In Service 1900 MW

BECK_-NIAGARA_230_PA27

Wed 08/24/2022 to Fri 10/28/2022 EXTENDED by IESO 09/26/2022

0800 Continuous 1700

Work scheduled by: IESO

SCH - OH - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

NYISO TRANSFER LIMITATIONS

Monday ,October 03, 2022 to Wednesday, April 03, 2024

| | |
|-------------------|--------|
| CENTRAL EAST | 2650MW |
| CENTRAL EAST - VC | 2585MW |
| TOTAL EAST | 6000MW |
| UPNY CONED | 7815MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3200MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-HQ_CEDARS-NYISO_LIMIT_240

FWD

Tue 09/06/2022 to Thu 10/06/2022 EXTENDED by HQ 09/27/2022
0500 Continuous 2200

(Import)

SCH - HQ_CEDARS

240 MW

Impacts Total Transfer Capability 30 MW

TTC with All Lines In Service 270 MW

Work scheduled by: HQ

SCH-NYISO-HQ_CEDARS_LIMIT_0

REV

Tue 09/06/2022 to Thu 10/06/2022 EXTENDED by HQ 09/27/2022
0500 Continuous 2200

(Export)

SCH - HQ_CEDARS

0 MW

Impacts Total Transfer Capability 100 MW

TTC with All Lines In Service 100 MW

Work scheduled by: HQ

MOSES__-ADIRNDCK_230_MA2

FWD

Tue 09/06/2022 to Thu 12/01/2022 UPDATED by NYPA 09/06/2022
1200 Continuous 0659

(Import)

MOSES SOUTH

2100 MW

Impacts Total Transfer Capability 1050 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4

FWD

Fri 09/16/2022 to Sat 10/15/2022
0001 0300

(Import)

UPNY CONED

3800 MW

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by:

SCH-NE-NYISO_LIMIT_100

FWD

Fri 09/16/2022 to Sat 10/15/2022 UPDATED by CE 09/16/2022
0001 Continuous 0300

(Import)

SCH - NE - NY

300 MW

Impacts Total Transfer Capability 1100 MW

TTC with All Lines In Service 1400 MW

Work scheduled by: ConEd

HURLYAVE-ROSETON__345_303

FWD

Mon 09/19/2022 to Fri 12/02/2022 09/21/2022
0800 Continuous 1600

(Import)

UPNY CONED

4100 MW

Impacts Total Transfer Capability 3715 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: CHGE

LEEDS__-HURLYAVE_345_301

FWD

Mon 09/19/2022 to Fri 12/02/2022 10/04/2021
0800 Continuous 1600

(Import)

UPNY CONED

4100 MW

Impacts Total Transfer Capability 3715 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: CHGE

NYISO TRANSFER LIMITATIONS

Monday ,October 03, 2022 to Wednesday, April 03, 2024

CENTRAL EAST 2650MW
CENTRAL EAST - VC 2585MW
TOTAL EAST 6000MW
UPNY CONED 7815MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3200MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY -EDIC 345 UE1-7

FWD

Tue 09/20/2022 to Sat 10/08/2022

UPDATEDby NYPA 08/10/2022

(Import)

0500 Continuous 1930

OSWEGO EXPORT

5250 MW

Work scheduled by: NYPA

ARR: 19&16

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

W49TH_ST-E13THSTA 345 M54

FWD

Wed 09/21/2022 to Sun 12/25/2022

UPDATEDby CE 09/25/2022

(Import)

0101 Continuous 0200

SPR/DUN-SOUTH

3800 MW

Work scheduled by: ConEd

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

SCH-NPX_1385-NYISO_LIMIT_125

FWD

Sun 09/25/2022 to Sat 10/15/2022

UPDATEDby CE 09/16/2022

(Import)

0001 Continuous 0300

SCH - NPX_1385

125 MW

Work scheduled by: ConEd

Impacts Total Transfer Capability 75 MW

TTC with All Lines In Service 200 MW

FITZPTRK-EDIC 345 FE-1 & GORDONRD-ROTTRDAM_230_30

FWD

Mon 09/26/2022 to Thu 10/06/2022

(Import)

0600 1000

CENTRAL EAST - VC

2430 MW

Work scheduled by:

Impacts Total Transfer Capability 155 MW

TTC with All Lines In Service 2585 MW

FITZPTRK-EDIC 345 FE-1

FWD

Mon 09/26/2022 to Sun 10/09/2022

by NYPA 09/26/2022

(Import)

0600 Continuous 0659

CENTRAL EAST - VC

2480 MW

Work scheduled by: NGrid

Impacts Total Transfer Capability 105 MW

TTC with All Lines In Service 2585 MW

FITZPTRK-EDIC 345 FE-1

FWD

Mon 09/26/2022 to Sun 10/09/2022

by NYPA 09/26/2022

(Import)

0600 Continuous 0659

OSWEGO EXPORT

4800 MW

Work scheduled by: NGrid

Impacts Total Transfer Capability 450 MW

TTC with All Lines In Service 5250 MW

COOPERS -DOLSONAV 345 CCDA42

FWD

Mon 09/26/2022 to Wed 09/28/2022

UPDATEDby NYSEG 09/22/2022

(Import)

0800 Continuous 1630

CENTRAL EAST - VC

2485 MW

Work scheduled by: NYSEG

Impacts Total Transfer Capability 100 MW

TTC with All Lines In Service 2585 MW

NYISO TRANSFER LIMITATIONS

Monday ,October 03, 2022 to Wednesday, April 03, 2024

| | |
|-------------------|--------|
| CENTRAL EAST | 2650MW |
| CENTRAL EAST - VC | 2585MW |
| TOTAL EAST | 6000MW |
| UPNY CONED | 7815MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3200MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

| | | | | | | | |
|---|------------|----------------|-----------------|-----------------|-------------------|-----------------------------------|----------------------|
| MILLWOOD_345KV_18 | | | | | FWD | | |
| Wed 09/28/2022 | to | Wed 09/28/2022 | <u>EXTENDED</u> | <u>by CONED</u> | <u>09/26/2022</u> | (Import) | |
| 0930 | Continuous | 1000 | | | | UPNY CONED | 4350 MW |
| Work scheduled by: ConEd | | | | | | Impacts Total Transfer Capability | 3465 MW |
| | | | | | | TTC with All Lines In Service | 7815 MW |
| MARCY_345KV_CSC | | | | | | FWD | |
| Thu 09/29/2022 | to | Tue 10/04/2022 | <u>EXTENDED</u> | <u>by NYPA</u> | <u>10/03/2022</u> | (Import) | |
| 0500 | Continuous | 2359 | | | | CENTRAL EAST - VC | 2535 MW |
| Work scheduled by: NYPA | | | | | | Impacts Total Transfer Capability | 50 MW |
| | | | | | | TTC with All Lines In Service | 2585 MW |
| NRTH1385-NOR HBR_138_601 | | | | | | FWD | REV |
| Thu 09/29/2022 | to | Thu 09/29/2022 | | | | (Import) | (Export) |
| 0800 | Continuous | 1700 | | | | SCH - NPX_1385 | 100 MW 100 MW |
| Work scheduled by: ISONE | | | | | | Impacts Total Transfer Capability | 100 MW 100 MW |
| | | | | | | TTC with All Lines In Service | 200 MW 200 MW |
| NRTH1385-NOR HBR_138_601 & NRTH1385-NOR HBR_138_602 | | | | | | FWD | REV |
| Thu 09/29/2022 | to | Thu 09/29/2022 | | | | (Import) | (Export) |
| 0800 | | 1700 | | | | SCH - NPX_1385 | 0 MW 0 MW |
| Work scheduled by: | | | | | | Impacts Total Transfer Capability | 200 MW 200 MW |
| | | | | | | TTC with All Lines In Service | 200 MW 200 MW |
| NRTH1385-NOR HBR_138_601 & NRTH1385-NOR HBR_138_603 | | | | | | FWD | REV |
| Thu 09/29/2022 | to | Thu 09/29/2022 | | | | (Import) | (Export) |
| 0800 | | 1700 | | | | SCH - NPX_1385 | 0 MW 0 MW |
| Work scheduled by: | | | | | | Impacts Total Transfer Capability | 200 MW 200 MW |
| | | | | | | TTC with All Lines In Service | 200 MW 200 MW |
| NRTH1385-NOR HBR_138_602 | | | | | | FWD | REV |
| Thu 09/29/2022 | to | Thu 09/29/2022 | | | | (Import) | (Export) |
| 0800 | Continuous | 1700 | | | | SCH - NPX_1385 | 100 MW 100 MW |
| Work scheduled by: ISONE | | | | | | Impacts Total Transfer Capability | 100 MW 100 MW |
| | | | | | | TTC with All Lines In Service | 200 MW 200 MW |
| NRTH1385-NOR HBR_138_602 & NRTH1385-NOR HBR_138_603 | | | | | | FWD | REV |
| Thu 09/29/2022 | to | Thu 09/29/2022 | | | | (Import) | (Export) |
| 0800 | | 1700 | | | | SCH - NPX_1385 | 0 MW 0 MW |
| Work scheduled by: | | | | | | Impacts Total Transfer Capability | 200 MW 200 MW |
| | | | | | | TTC with All Lines In Service | 200 MW 200 MW |

NYISO TRANSFER LIMITATIONS

Monday ,October 03, 2022 to Wednesday, April 03, 2024

| | |
|-------------------|--------|
| CENTRAL EAST | 2650MW |
| CENTRAL EAST - VC | 2585MW |
| TOTAL EAST | 6000MW |
| UPNY CONED | 7815MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3200MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

| | | | | | | |
|------------------------------|------------|----------------|------------------|-----------------------------------|-----------------------------------|---------------|
| NRTH1385-NOR HBR__138_603 | | | | | FWD | REV |
| Thu 09/29/2022 | to | Thu 09/29/2022 | | | (Import) | (Export) |
| 0800 | Continuous | 1700 | | | SCH - NPX_1385 | 100 MW 100 MW |
| Work scheduled by: ISONE | | | | | Impacts Total Transfer Capability | 100 MW 100 MW |
| | | | | | TTC with All Lines In Service | 200 MW 200 MW |
| NRTH1385-NRTHPORT_138_NNC | | | | | FWD | REV |
| Thu 09/29/2022 | to | Thu 09/29/2022 | | | (Import) | (Export) |
| 0800 | Continuous | 1700 | | | SCH - NPX_1385 | 0 MW 0 MW |
| Work scheduled by: ISONE | | | | | Impacts Total Transfer Capability | 200 MW 200 MW |
| | | | | | TTC with All Lines In Service | 200 MW 200 MW |
| COOPERS_-MIDDLETP_345_CCRT34 | | | | | FWD | |
| Fri 09/30/2022 | to | Sun 10/09/2022 | <u>UPDATED</u> | <u>by NYSEG</u> <u>09/29/2022</u> | (Import) | |
| 0700 | Continuous | 1600 | | | CENTRAL EAST - VC | 2485 MW |
| Work scheduled by: NYSEG | | | | | Impacts Total Transfer Capability | 100 MW |
| | | | | | TTC with All Lines In Service | 2585 MW |
| EGRDNCTY_345_138_AT1 | | | | | FWD | |
| Sat 10/01/2022 | to | Wed 05/31/2023 | <u>UPDATED</u> | <u>by CONED</u> <u>03/10/2022</u> | (Import) | |
| 0001 | Continuous | 2359 | | | CONED - LIPA | 1250 MW |
| Work scheduled by: LI | | | | | Impacts Total Transfer Capability | 250 MW |
| | | | | | TTC with All Lines In Service | 1500 MW |
| EGRDNCTY_345_138_AT2 | | | | | FWD | |
| Sat 10/01/2022 | to | Wed 05/31/2023 | <u>UPDATED</u> | <u>by CONED</u> <u>03/10/2022</u> | (Import) | |
| 0001 | Continuous | 2359 | | | CONED - LIPA | 1250 MW |
| Work scheduled by: LI | | | | | Impacts Total Transfer Capability | 250 MW |
| | | | | | TTC with All Lines In Service | 1500 MW |
| SPRNBRK_-EGRDNCTR_345_Y49 | | | | | FWD | |
| Sat 10/01/2022 | to | Wed 05/31/2023 | <u>UPDATED</u> | <u>by CONED</u> <u>03/10/2022</u> | (Import) | |
| 0001 | Continuous | 2359 | | | CONED - LIPA | 775 MW |
| Work scheduled by: LI | | | | | Impacts Total Transfer Capability | 725 MW |
| | | | | | TTC with All Lines In Service | 1500 MW |
| CHAT_DC_GC1 | | | | | FWD | |
| Sun 10/02/2022 | to | Sun 10/02/2022 | <u>CANCELLED</u> | <u>by HQ</u> <u>09/28/2022</u> | (Import) | |
| 0001 | Continuous | 0200 | | | MOSES SOUTH | 2850 MW |
| Work scheduled by: HQ | | | | | Impacts Total Transfer Capability | 300 MW |
| | | | | | TTC with All Lines In Service | 3150 MW |

NYISO TRANSFER LIMITATIONS

Monday ,October 03, 2022 to Wednesday, April 03, 2024

| | |
|-------------------|--------|
| CENTRAL EAST | 2650MW |
| CENTRAL EAST - VC | 2585MW |
| TOTAL EAST | 6000MW |
| UPNY CONED | 7815MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3200MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHAT_DC_GC1

| | | | | | | | |
|-----------------------|------------|----------------|-------------------------|---------------------|--------------------------|-----------------------------------|---------------|
| Sun 10/02/2022 | to | Sun 10/02/2022 | <u>CANCELLED</u> | <u>by HQ</u> | <u>09/28/2022</u> | SCH - HQ - NY | REV |
| 0001 | Continuous | 0200 | | | | Impacts Total Transfer Capability | (Export) |
| Work scheduled by: HQ | | | | | | TTC with All Lines In Service | 500 MW |
| | | | | | | | 500 MW |
| | | | | | | | 1000 MW |

CHAT_DC_GC2

| | | | | | | | |
|-----------------------|------------|----------------|-------------------------|---------------------|--------------------------|-----------------------------------|----------------|
| Sun 10/02/2022 | to | Sun 10/02/2022 | <u>CANCELLED</u> | <u>by HQ</u> | <u>09/28/2022</u> | MOSES SOUTH | FWD |
| 0001 | Continuous | 0200 | | | | Impacts Total Transfer Capability | (Import) |
| Work scheduled by: HQ | | | | | | TTC with All Lines In Service | 2850 MW |
| | | | | | | | 300 MW |
| | | | | | | | 3150 MW |

CHAT_DC_GC2

| | | | | | | | |
|-----------------------|------------|----------------|-------------------------|---------------------|--------------------------|-----------------------------------|---------------|
| Sun 10/02/2022 | to | Sun 10/02/2022 | <u>CANCELLED</u> | <u>by HQ</u> | <u>09/28/2022</u> | SCH - HQ - NY | REV |
| 0001 | Continuous | 0200 | | | | Impacts Total Transfer Capability | (Export) |
| Work scheduled by: HQ | | | | | | TTC with All Lines In Service | 500 MW |
| | | | | | | | 500 MW |
| | | | | | | | 1000 MW |

SCH-HQ-NYISO_LIMIT_1150

| | | | | | | | |
|-----------------------|------------|----------------|-------------------------|---------------------|--------------------------|-----------------------------------|----------------|
| Sun 10/02/2022 | to | Sun 10/02/2022 | <u>CANCELLED</u> | <u>by HQ</u> | <u>09/28/2022</u> | SCH - HQ - NY | FWD |
| 0001 | Continuous | 0200 | | | | Impacts Total Transfer Capability | (Import) |
| Work scheduled by: HQ | | | | | | TTC with All Lines In Service | 1150 MW |
| | | | | | | | 350 MW |
| | | | | | | | 1500 MW |

SPRNBK_-TREMONT_345_X28

| | | | | | | | |
|--------------------------|------------|----------------|----------------------|------------------------|--------------------------|-----------------------------------|----------------|
| Sun 10/02/2022 | to | Wed 10/05/2022 | <u>FORCED</u> | <u>by CONED</u> | <u>10/03/2022</u> | SPR/DUN-SOUTH | FWD |
| 1554 | Continuous | 2359 | | | | Impacts Total Transfer Capability | (Import) |
| Work scheduled by: ConEd | | | | | | TTC with All Lines In Service | 4200 MW |
| | | | | | | | 400 MW |
| | | | | | | | 4600 MW |

SHOR_NPX-SHOREHAM_138_CSC

| | | | | | | | | |
|-----------------------|------------|----------------|--|--|--------------------------|-----------------------------------|-------------|-------------|
| Mon 10/03/2022 | to | Fri 10/21/2022 | | | <u>09/28/2022</u> | SCH - NPX_CSC | FWD | REV |
| 0700 | Continuous | 1500 | | | | Impacts Total Transfer Capability | (Import) | (Export) |
| Work scheduled by: LI | | | | | | TTC with All Lines In Service | 0 MW | 0 MW |
| | | | | | | | 330 MW | 330 MW |
| | | | | | | | 330 MW | 330 MW |

SCH-IMO-NYISO_LIMIT_850

| | | | | | | | |
|-------------------------|------------|----------------|-----------------------|-----------------------|--------------------------|-----------------------------------|----------------|
| Mon 10/03/2022 | to | Fri 10/07/2022 | <u>UPDATED</u> | <u>by IESO</u> | <u>09/29/2022</u> | SCH - OH - NY | FWD |
| 0800 | Continuous | 1800 | | | | Impacts Total Transfer Capability | (Import) |
| Work scheduled by: IESO | | | | | | TTC with All Lines In Service | 1150 MW |
| | | | | | | | 750 MW |
| | | | | | | | 1900 MW |

NYISO TRANSFER LIMITATIONS

Monday ,October 03, 2022 to Wednesday, April 03, 2024

| | |
|-------------------|--------|
| CENTRAL EAST | 2650MW |
| CENTRAL EAST - VC | 2585MW |
| TOTAL EAST | 6000MW |
| UPNY CONED | 7815MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3200MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-IMO_LIMIT_900

REV

Mon 10/03/2022 to Fri 10/07/2022 **UPDATED** **by IESO** **09/29/2022**

(Export)

0800 Continuous 1800

Work scheduled by: IESO

SCH - OH - NY **1200 MW**
 Impacts Total Transfer Capability 350 MW
 TTC with All Lines In Service 1550 MW

CLRKSCRN-OAKDALE_345_36

FWD

Mon 10/03/2022 to Fri 10/07/2022 **UPDATED** **by NYSEG** **04/20/2022**

(Import)

0830 Continuous 1530

Work scheduled by: NYSEG

CENTRAL EAST - VC **2450 MW**
 Impacts Total Transfer Capability 135 MW
 TTC with All Lines In Service 2585 MW

STLAWRNC-MOSES_230_L34PMon 10/03/2022 to Mon 09/25/2023 **UPDATED** **by IESO** **08/15/2022**

1800 Continuous 0800

Work scheduled by: IESO

SCH - OH - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

SCH-NYISO-NE_LIMIT_900

REV

Mon 10/03/2022 to Wed 10/05/2022 **UPDATED** **by ISONE** **09/29/2022**

(Export)

2300 Continuous 0659

Work scheduled by: NGrid

SCH - NE - NY **1100 MW**
 Impacts Total Transfer Capability 500 MW
 TTC with All Lines In Service 1600 MW

MAINESBG-WATRCURE_345_30

Tue 10/04/2022 to Wed 10/05/2022

0830 Continuous 1530

Work scheduled by: NYSEG

SCH - PJ - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

W49TH_ST_345KV_7

FWD

Wed 10/05/2022 to Wed 10/05/2022

(Import)

0201 Continuous 0230

Work scheduled by: ConEd

SCH - PJM_HTP **300 MW**
 Impacts Total Transfer Capability 360 MW
 TTC with All Lines In Service 660 MW

W49TH_ST_345KV_8

FWD

Wed 10/05/2022 to Wed 10/05/2022

(Import)

0201 Continuous 0230

Work scheduled by: ConEd

SCH - PJM_HTP **450 MW**
 Impacts Total Transfer Capability 210 MW
 TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Monday ,October 03, 2022 to Wednesday, April 03, 2024

| | |
|-------------------|--------|
| CENTRAL EAST | 2650MW |
| CENTRAL EAST - VC | 2585MW |
| TOTAL EAST | 6000MW |
| UPNY CONED | 7815MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3200MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONTP-W49TH_ST_345_Y56

Wed 10/05/2022 to Sun 10/09/2022

0201 Continuous 1800

Work scheduled by: ConEd

FWD

(Import)

SCH - PJM_HTP

0 MW

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

LADENTWN-BUCHAN_S_345_Y88

Wed 10/05/2022 to Fri 10/07/2022

0600 Continuous 2100

Work scheduled by: ORU

CANCELLED by ORU 09/28/2022

FWD

(Import)

UPNY CONED

7560 MW

Impacts Total Transfer Capability 255 MW

TTC with All Lines In Service 7815 MW

LEEDS____345_LEEDS SVC

Wed 10/05/2022 to Fri 10/07/2022

0700 Continuous 1200

Work scheduled by: NGrid

UPDATED by NGRID 10/03/2022

FWD

(Import)

CENTRAL EAST - VC

2570 MW

Impacts Total Transfer Capability 15 MW

TTC with All Lines In Service 2585 MW

DUNWODIE_345KV_3

Thu 10/06/2022 to Sun 10/16/2022

0001 Continuous 0200

Work scheduled by: ConEd

UPDATED by CE 06/30/2022

FWD

(Import)

SPR/DUN-SOUTH

3800 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_5

Thu 10/06/2022 to Sun 10/16/2022

0001 Continuous 0200

Work scheduled by: ConEd

UPDATED by CE 06/30/2022

FWD

(Import)

SPR/DUN-SOUTH

3800 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

DUNWODIE-MOTTHAVN_345_71

Thu 10/06/2022 to Thu 11/10/2022

0001 Continuous 0300

Work scheduled by: ConEd

UPDATED by CE 06/30/2022

FWD

(Import)

SPR/DUN-SOUTH

3800 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

GILBOA__-N.SCTLND_345_GNS-1

Thu 10/06/2022 to Thu 10/20/2022

0830 Continuous 1400

Work scheduled by: NGrid

CANCELLED by NGrid 09/28/2022

FWD

(Import)

CENTRAL EAST - VC

2300 MW

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 2585 MW

NYISO TRANSFER LIMITATIONS

Monday ,October 03, 2022 to Wednesday, April 03, 2024

| | |
|-------------------|--------|
| CENTRAL EAST | 2650MW |
| CENTRAL EAST - VC | 2585MW |
| TOTAL EAST | 6000MW |
| UPNY CONED | 7815MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3200MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK__345KV_RNS4

FWD

Sun 10/09/2022 to Sun 10/09/2022

(Import)

0001 Continuous 0030

SPR/DUN-SOUTH

3200 MW

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

EASTVIEW-SPRNBK__345_W65

FWD

Sun 10/09/2022 to Wed 10/12/2022

(Import)

0001 Continuous 0200

UPNY CONED

4350 MW

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

MILLWOOD-EASTVIEW_345_W82

FWD

Sun 10/09/2022 to Wed 10/12/2022

(Import)

0001 Continuous 0200

UPNY CONED

7550 MW

Impacts Total Transfer Capability 265 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

CHAT_DC_GC1

FWD

Sun 10/09/2022 to Sun 11/06/2022

(Import)

0400 Continuous 2200

MOSES SOUTH

2850 MW

Impacts Total Transfer Capability 300 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: HQ

CHAT_DC_GC1

REV

Sun 10/09/2022 to Sun 11/06/2022

(Export)

0400 Continuous 2200

SCH - HQ - NY

500 MW

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 1000 MW

Work scheduled by: HQ

SCH-NYISO-HQ_LIMIT_500

REV

Sun 10/09/2022 to Sun 11/06/2022

(Export)

0400 Continuous 2200

SCH - HQ - NY

500 MW

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 1000 MW

Work scheduled by: HQ

MARCY__-FRASANNX_345_UCC2-41

FWD

Sun 10/09/2022 to Mon 10/31/2022

(Import)

0700 Continuous 1730

CENTRAL EAST - VC

2275 MW

Impacts Total Transfer Capability 310 MW

TTC with All Lines In Service 2585 MW

Work scheduled by: NYPA

ARR: 19

CANCELLED by NYPA 09/30/2022

NYISO TRANSFER LIMITATIONS

Monday ,October 03, 2022 to Wednesday, April 03, 2024

| | |
|-------------------|--------|
| CENTRAL EAST | 2650MW |
| CENTRAL EAST - VC | 2585MW |
| TOTAL EAST | 6000MW |
| UPNY CONED | 7815MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3200MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_7

Sun 10/09/2022 to Sun 10/09/2022
1730 Continuous 1800
Work scheduled by: ConEd

FWD
(Import)
SCH - PJM_HTP **300 MW**
Impacts Total Transfer Capability 360 MW
TTC with All Lines In Service 660 MW

W49TH_ST_345KV_8

Sun 10/09/2022 to Sun 10/09/2022
1730 Continuous 1800
Work scheduled by: ConEd

FWD
(Import)
SCH - PJM_HTP **450 MW**
Impacts Total Transfer Capability 210 MW
TTC with All Lines In Service 660 MW

EDIC___-GORDONRD_345_14

Mon 10/10/2022 to Mon 10/31/2022 UPDATED by NYPA 05/17/2022
0700 Continuous 1530
Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **1670 MW**
Impacts Total Transfer Capability 915 MW
TTC with All Lines In Service 2585 MW

SCRIBA___-VOLNEY___345_21

Mon 10/10/2022 to Fri 10/14/2022
0730 Continuous 1700
Work scheduled by: NGrid

FWD
(Import)
OSWEGO EXPORT **5250 MW**
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 5250 MW

SPRNBK__345KV_RNS4

Wed 10/12/2022 to Wed 10/12/2022
0130 Continuous 0200
Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

EASTVIEW-SPRNBK__345_W64

Wed 10/12/2022 to Wed 10/12/2022
0201 Continuous 0230
Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4350 MW**
Impacts Total Transfer Capability 3465 MW
TTC with All Lines In Service 7815 MW

MILLWOOD-EASTVIEW_345_W99

Wed 10/12/2022 to Wed 10/12/2022
0201 Continuous 0230
Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **7550 MW**
Impacts Total Transfer Capability 265 MW
TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Monday ,October 03, 2022 to Wednesday, April 03, 2024

| | |
|-------------------|--------|
| CENTRAL EAST | 2650MW |
| CENTRAL EAST - VC | 2585MW |
| TOTAL EAST | 6000MW |
| UPNY CONED | 7815MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3200MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK__345KV_RNS5

FWD

Wed 10/12/2022 to Wed 10/12/2022

(Import)

0201 Continuous 0230

SPR/DUN-SOUTH

3200 MW

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

EASTVIEW-SPRNBK__345_W64

FWD

Wed 10/12/2022 to Sat 10/15/2022

(Import)

0201 Continuous 0200

UPNY CONED

4350 MW

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

MILLWOOD-EASTVIEW_345_W99

FWD

Sat 10/15/2022 to Sat 10/15/2022

(Import)

0130 Continuous 0200

UPNY CONED

7550 MW

Impacts Total Transfer Capability 265 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

EASTVIEW-SPRNBK__345_W79

FWD

Mon 10/17/2022 to Mon 10/17/2022

(Import)

0001 Continuous 0031

UPDATEDby CONED 09/07/2022

UPNY CONED

4350 MW

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

BUCHAN_N-EASTVIEW_345_W93

FWD

Mon 10/17/2022 to Fri 10/28/2022

(Import)

0001 Continuous 0200

UPDATEDby CONED 09/07/2022

UPNY CONED

4350 MW

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

CHATGUAY-MASSENA__765_7040

FWD

Mon 10/17/2022 to Mon 10/24/2022

(Import)

0100 Continuous 1800

MOSES SOUTH

1550 MW

Impacts Total Transfer Capability 1600 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: HQ

CHATGUAY-MASSENA__765_7040

FWD

REV

Mon 10/17/2022 to Mon 10/24/2022

(Import) (Export)

0100 Continuous 1800

SCH - HQ - NY

0 MW

0 MW

Impacts Total Transfer Capability 1500 MW 1000 MW

TTC with All Lines In Service 1500 MW 1000 MW

Work scheduled by: HQ

NYISO TRANSFER LIMITATIONS

Monday ,October 03, 2022 to Wednesday, April 03, 2024

| | |
|-------------------|--------|
| CENTRAL EAST | 2650MW |
| CENTRAL EAST - VC | 2585MW |
| TOTAL EAST | 6000MW |
| UPNY CONED | 7815MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3200MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHAT_DC_GC1 & CHAT_DC_GC2

Mon 10/17/2022 to Mon 10/24/2022
0100 1800

Work scheduled by:

FWD
(Import)
MOSES SOUTH **2550 MW**
Impacts Total Transfer Capability 600 MW
TTC with All Lines In Service 3150 MW

CHAT_DC_GC1 & CHAT_DC_GC2

Mon 10/17/2022 to Mon 10/24/2022
0100 1800

Work scheduled by:

FWD REV
(Import) (Export)
SCH - HQ - NY **1370 MW 0 MW**
Impacts Total Transfer Capability 130 MW 1000 MW
TTC with All Lines In Service 1500 MW 1000 MW

CHAT_DC_GC2

Mon 10/17/2022 to Mon 10/24/2022
0100 Continuous 1800

Work scheduled by: HQ

FWD
(Import)
MOSES SOUTH **2850 MW**
Impacts Total Transfer Capability 300 MW
TTC with All Lines In Service 3150 MW

CHAT_DC_GC2

Mon 10/17/2022 to Mon 10/24/2022
0100 Continuous 1800

Work scheduled by: HQ

REV
(Export)
SCH - HQ - NY **500 MW**
Impacts Total Transfer Capability 500 MW
TTC with All Lines In Service 1000 MW

NIAGARA_-DYSINGER_345_ND1

Mon 10/17/2022 to Fri 10/21/2022
0500 Continuous 1700

Work scheduled by: NYPA

UPDATED by NYPA 02/10/2022

FWD
(Import)
DYSINGER EAST **2700 MW**
Impacts Total Transfer Capability 500 MW
TTC with All Lines In Service 3200 MW

RAMAPO_-BUCHAN_N_345_Y94

Tue 10/18/2022 to Sun 10/30/2022
0001 Continuous 0200

Work scheduled by: ConEd

UPDATED by CONED 09/07/2022

FWD
(Import)
UPNY CONED **7580 MW**
Impacts Total Transfer Capability 235 MW
TTC with All Lines In Service 7815 MW

FIVEMILE-ESTOLERD_345_29

Tue 10/18/2022 to Tue 10/18/2022
0730 Daily(No Weekends) 1230

Work scheduled by: NGrid

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

NYISO TRANSFER LIMITATIONS

Monday ,October 03, 2022 to Wednesday, April 03, 2024

| | |
|-------------------|--------|
| CENTRAL EAST | 2650MW |
| CENTRAL EAST - VC | 2585MW |
| TOTAL EAST | 6000MW |
| UPNY CONED | 7815MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3200MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PANNELL_-CLAY_____345_1

FWD

Mon 10/24/2022 to Fri 10/28/2022

UPDATEDby NYPA09/01/2022

(Import)

0700 Continuous 1530

WEST CENTRAL

1300 MW

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW

Work scheduled by: NYPA

ELBRIDGE-LAFAYTTE_345_17-LE

FWD

Tue 10/25/2022 to Tue 10/25/2022

(Import)

0630 Continuous 1700

OSWEGO EXPORT

5250 MW

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NGrid

ARR: 75

OSWEGO_-ELBRIDGE_345_17

FWD

Tue 10/25/2022 to Tue 10/25/2022

(Import)

0630 Continuous 1700

OSWEGO EXPORT

5250 MW

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NGrid

ARR: 75

MAINESBG-WATRCURE_345_30

Tue 10/25/2022 to Tue 10/25/2022

0800 Daily 1500

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: NYSEG

WATRCURE-OAKDALE_345_31

Thu 10/27/2022 to Thu 10/27/2022

0800 Daily 1500

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: NYSEG

EASTVIEW-SPRNBK_345_W79

FWD

Fri 10/28/2022 to Fri 10/28/2022

(Import)

0130 Continuous 0200

UPDATEDby CONED09/07/2022

UPNY CONED

4350 MW

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

PANNELL_-CLAY_____345_2

FWD

Mon 10/31/2022 to Fri 11/04/2022

(Import)

0700 Continuous 1530

UPDATEDby NYPA09/01/2022

WEST CENTRAL

1300 MW

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW

Work scheduled by: NYPA

NYISO TRANSFER LIMITATIONS

Monday ,October 03, 2022 to Wednesday, April 03, 2024

| | |
|-------------------|--------|
| CENTRAL EAST | 2650MW |
| CENTRAL EAST - VC | 2585MW |
| TOTAL EAST | 6000MW |
| UPNY CONED | 7815MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3200MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BUCHAN_S-MILLWOOD_345_W97

Tue 11/01/2022 to Wed 11/02/2022
0001 Continuous 0200
Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **7680 MW**
Impacts Total Transfer Capability 135 MW
TTC with All Lines In Service 7815 MW

CLAY_-EDIC_345_1-16

Tue 11/01/2022 to Thu 11/03/2022
0600 Continuous 1900
Work scheduled by: NGrid

UPDATED by NGRID 05/09/2022

FWD
(Import)
OSWEGO EXPORT **4850 MW**
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 5250 MW

NEPTUNE_-DUFFYAVE_345_NEPTUNE

Tue 11/01/2022 to Sat 11/19/2022
0600 Continuous 1600
Work scheduled by: LI

FWD
(Import)
SCH - PJM_NEPTUNE **0 MW**
Impacts Total Transfer Capability 660 MW
TTC with All Lines In Service 660 MW

NEWBRDGE-DUFFYAVE_345_501

Tue 11/01/2022 to Sat 11/19/2022
0600 Continuous 1600
Work scheduled by: LI

FWD
(Import)
SCH - PJM_NEPTUNE **0 MW**
Impacts Total Transfer Capability 660 MW
TTC with All Lines In Service 660 MW

NEWBRDGE_345_138_BK_1

Tue 11/01/2022 to Sat 11/19/2022
0600 Continuous 1600
Work scheduled by: LI

FWD
(Import)
SCH - PJM_NEPTUNE **375 MW**
Impacts Total Transfer Capability 285 MW
TTC with All Lines In Service 660 MW

NEWBRDGE_345_138_BK_2

Tue 11/01/2022 to Sat 11/19/2022
0600 Continuous 1600
Work scheduled by: LI

FWD
(Import)
SCH - PJM_NEPTUNE **375 MW**
Impacts Total Transfer Capability 285 MW
TTC with All Lines In Service 660 MW

GILBOA_-N.SCTLND_345_GNS-1

Tue 11/01/2022 to Tue 12/06/2022
0700 Continuous 1900
Work scheduled by: NGrid

UPDATED by NGRID 12/29/2021

FWD
(Import)
CENTRAL EAST - VC **2300 MW**
Impacts Total Transfer Capability 285 MW
TTC with All Lines In Service 2585 MW

NYISO TRANSFER LIMITATIONS

Monday ,October 03, 2022 to Wednesday, April 03, 2024

| | |
|-------------------|--------|
| CENTRAL EAST | 2650MW |
| CENTRAL EAST - VC | 2585MW |
| TOTAL EAST | 6000MW |
| UPNY CONED | 7815MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3200MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___-N.SCTLND_345_18

FWD

Tue 11/01/2022 to Tue 12/06/2022 UPDATED by NGRID 12/29/2021

(Import)

0700 Continuous 1900

CENTRAL EAST - VC

1345 MW

Impacts Total Transfer Capability 1240 MW

TTC with All Lines In Service 2585 MW

Work scheduled by: NGrid

ARR: 19

LINDN_CG-LNDVFT___345_V-3022

FWD

REV

Tue 11/01/2022 to Fri 11/04/2022

(Import) (Export)

0800 Continuous 1500

SCH - PJM_VFT

0 MW**0 MW**

Impacts Total Transfer Capability 315 MW 315 MW

TTC with All Lines In Service 315 MW 315 MW

Work scheduled by: PJM

DUNWODIE_345KV_3

FWD

Thu 11/10/2022 to Thu 11/10/2022 UPDATED by CE 06/30/2022

(Import)

0230 Continuous 0300

SPR/DUN-SOUTH

3800 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

DUNWODIE_345KV_5

FWD

Thu 11/10/2022 to Thu 11/10/2022 UPDATED by CE 06/30/2022

(Import)

0230 Continuous 0300

SPR/DUN-SOUTH

3800 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

MAINESBG-WATRCURE_345_30

FWD

Thu 11/10/2022 to Thu 11/10/2022

(Import)

0800 Continuous 1600

SCH - PJ - NY

2300 MW

Impacts Total Transfer Capability 550 MW

TTC with All Lines In Service 2850 MW

Work scheduled by: PJM

LADENTWN-BUCHAN_S_345_Y88

FWD

Wed 11/16/2022 to Fri 11/18/2022 CANCELLED by ORU 09/28/2022

(Import)

0600 Continuous 2100

UPNY CONED

7560 MW

Impacts Total Transfer Capability 255 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ORU

EASTVIEW-SPRNBK___345_W79

FWD

Sat 11/19/2022 to Sat 11/19/2022 UPDATED by CONED 09/07/2022

(Import)

0001 Continuous 0030

UPNY CONED

4350 MW

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

NYISO TRANSFER LIMITATIONS

Monday ,October 03, 2022 to Wednesday, April 03, 2024

| | |
|-------------------|--------|
| CENTRAL EAST | 2650MW |
| CENTRAL EAST - VC | 2585MW |
| TOTAL EAST | 6000MW |
| UPNY CONED | 7815MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3200MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BUCHAN_N-EASTVIEW_345_W93

FWD

Sat 11/19/2022 to Sat 11/26/2022 UPDATED by CONED 09/07/2022

(Import)

0001 Continuous 0200

UPNY CONED

4350 MW

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

RAMAPO_-BUCHAN_N_345_Y94

FWD

Sat 11/19/2022 to Sat 11/26/2022 UPDATED by CONED 09/07/2022

(Import)

0001 Continuous 0200

UPNY CONED

7580 MW

Impacts Total Transfer Capability 235 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

E13THSTA-FARRAGUT_345_45

FWD

Wed 11/23/2022 to Sat 12/10/2022 UPDATED by CONED 09/07/2022

(Import)

0001 Continuous 0300

SPR/DUN-SOUTH

3800 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

HOMRC_NY-MAINS_NY_345_47

Wed 11/23/2022 to Wed 11/23/2022 UPDATED by PJM 08/09/2022

0800 Continuous 1600

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: PJM

EASTVIEW-SPRNBK_345_W79

FWD

Sat 11/26/2022 to Sat 11/26/2022 UPDATED by CONED 09/07/2022

(Import)

0130 Continuous 0200

UPNY CONED

4350 MW

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

BUCHAN_S-MILLWOOD_345_W98

FWD

Tue 11/29/2022 to Thu 12/01/2022

(Import)

0001 Continuous 0200

UPNY CONED

7680 MW

Impacts Total Transfer Capability 135 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

MILLWOOD_345KV_18

FWD

Tue 11/29/2022 to Thu 12/01/2022

(Import)

0001 Continuous 0200

UPNY CONED

4350 MW

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

NYISO TRANSFER LIMITATIONS

Monday ,October 03, 2022 to Wednesday, April 03, 2024

| | |
|-------------------|--------|
| CENTRAL EAST | 2650MW |
| CENTRAL EAST - VC | 2585MW |
| TOTAL EAST | 6000MW |
| UPNY CONED | 7815MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3200MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CRICKVLY-PLSNTVLY_345_F84

Thu 12/01/2022 to Fri 12/16/2022

0001 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
SCH - NE - NY **600 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 1400 MW

CRICKVLY-PLSNTVLY_345_F84

Thu 12/01/2022 to Fri 12/16/2022

0001 Continuous 0200

Work scheduled by: ConEd

FWD REV
(Import) (Export)
SCH - NPX_1385 **100 MW 100 MW**
Impacts Total Transfer Capability 100 MW 100 MW
TTC with All Lines In Service 200 MW 200 MW

MOSES___-ADIRNDCK_230_MA1

Thu 12/01/2022 to Wed 03/01/2023

0701 Continuous 1100

Work scheduled by: NYPA

UPDATED by NYPA 09/02/2022

FWD
(Import)
MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

MILLWOOD_345KV_18

Fri 12/02/2022 to Mon 12/12/2022

0001 Continuous 1800

Work scheduled by: ConEd

FWD
(Import)
UPNY CONED **4350 MW**
Impacts Total Transfer Capability 3465 MW
TTC with All Lines In Service 7815 MW

MARCY___345KV_CSC

Wed 12/07/2022 to Tue 12/20/2022

0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2535 MW**
Impacts Total Transfer Capability 50 MW
TTC with All Lines In Service 2585 MW

HOPATCON-RAMAPO___500_5018

Mon 12/12/2022 to Fri 12/16/2022

0001 Continuous 2000

Work scheduled by: ConEd

FWD REV
(Import) (Export)
SCH - PJ - NY **1650 MW 1200 MW**
Impacts Total Transfer Capability 1200 MW 1000 MW
TTC with All Lines In Service 2850 MW 2200 MW

HOPATCON-RAMAPO___500_5018

Mon 12/12/2022 to Fri 12/16/2022

0001 Continuous 2000

Work scheduled by: ConEd

FWD
(Import)
TOTAL EAST **5200 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 6000 MW

NYISO TRANSFER LIMITATIONS

Monday ,October 03, 2022 to Wednesday, April 03, 2024

CENTRAL EAST 2650MW
CENTRAL EAST - VC 2585MW
TOTAL EAST 6000MW
UPNY CONED 7815MW
SPR/DUN-SOUTH 4600MW
DYSINGER EAST 3200MW
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HOPATCON-RAMAPO___500_5018

FWD

Mon 12/12/2022 to Fri 12/16/2022

(Import)

0001 Continuous 2000

UPNY CONED

7480 MW

Impacts Total Transfer Capability 335 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

HOPATCON-RAMAPO___500_5018 & MARCY___345KV_CSC

FWD

Mon 12/12/2022 to Fri 12/16/2022

(Import)

0001 2000

TOTAL EAST

5100 MW

Impacts Total Transfer Capability 900 MW

TTC with All Lines In Service 6000 MW

Work scheduled by:

RAMAPO___345_345_PAR3500

FWD

REV

Mon 12/12/2022 to Fri 12/16/2022

(Import) (Export)

0001 Continuous 2000

SCH - PJ - NY

2500 MW 1250 MW

Impacts Total Transfer Capability 350 MW 950 MW

TTC with All Lines In Service 2850 MW 2200 MW

Work scheduled by: ConEd

RAMAPO___345_345_PAR4500

FWD

REV

Mon 12/12/2022 to Fri 12/16/2022

(Import) (Export)

0001 Continuous 2000

SCH - PJ - NY

2500 MW 1250 MW

Impacts Total Transfer Capability 350 MW 950 MW

TTC with All Lines In Service 2850 MW 2200 MW

Work scheduled by: ConEd

RAMAPO___500_345_BK 1500

FWD

REV

Mon 12/12/2022 to Fri 12/16/2022

(Import) (Export)

0001 Continuous 2000

SCH - PJ - NY

1650 MW 1200 MW

Impacts Total Transfer Capability 1200 MW 1000 MW

TTC with All Lines In Service 2850 MW 2200 MW

Work scheduled by: ConEd

RAMAPO___500_345_BK 1500

FWD

Mon 12/12/2022 to Fri 12/16/2022

(Import)

0001 Continuous 2000

UPNY CONED

7480 MW

Impacts Total Transfer Capability 335 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

CRICKVLY-PLSNTVLY_345_F83

FWD

Fri 12/16/2022 to Sun 01/01/2023

(Import)

0201 Continuous 0200

EXTENDEDby CE09/22/2022

SCH - NE - NY

600 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 1400 MW

Work scheduled by: ConEd

NYISO TRANSFER LIMITATIONS

Monday ,October 03, 2022 to Wednesday, April 03, 2024

| | |
|-------------------|--------|
| CENTRAL EAST | 2650MW |
| CENTRAL EAST - VC | 2585MW |
| TOTAL EAST | 6000MW |
| UPNY CONED | 7815MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3200MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CRICKVLY-PLSNTVLY_345_F83

Fri 12/16/2022 to Sun 01/01/2023
0201 Continuous 0200

EXTENDED by CE 09/22/2022

Work scheduled by: ConEd

| | FWD | REV |
|-----------------------------------|----------|----------|
| | (Import) | (Export) |
| SCH - NPX_1385 | 100 MW | 100 MW |
| Impacts Total Transfer Capability | 100 MW | 100 MW |
| TTC with All Lines In Service | 200 MW | 200 MW |

FRASER__-COOPERS__345_33

Mon 12/19/2022 to Fri 12/23/2022
0600 Continuous 1659

Work scheduled by: NYSEG

| | FWD |
|-----------------------------------|----------|
| | (Import) |
| CENTRAL EAST - VC | 2335 MW |
| Impacts Total Transfer Capability | 250 MW |
| TTC with All Lines In Service | 2585 MW |

HOMRC_NY-MAINS_NY_345_47

Thu 12/22/2022 to Thu 12/22/2022
0800 Continuous 1600

Work scheduled by: PJM

| |
|-----------------------------------|
| SCH - PJ - NY |
| Impacts Total Transfer Capability |
| TTC with All Lines In Service |

W49TH_ST-E13THSTA_345_M54

Tue 12/27/2022 to Tue 12/27/2022
0130 Continuous 0200

UPDATED by CE 09/25/2022

Work scheduled by: ConEd

| | FWD |
|-----------------------------------|----------|
| | (Import) |
| SPR/DUN-SOUTH | 3800 MW |
| Impacts Total Transfer Capability | 800 MW |
| TTC with All Lines In Service | 4600 MW |

CLAY__-EDIC__345_1-16

Fri 12/30/2022 to Sat 12/31/2022
0600 Continuous 1900

UPDATED by NGRID 05/09/2022

Work scheduled by: NGrid

| | FWD |
|-----------------------------------|----------|
| | (Import) |
| OSWEGO EXPORT | 4850 MW |
| Impacts Total Transfer Capability | 400 MW |
| TTC with All Lines In Service | 5250 MW |

E13THSTA-FARRAGUT_345_46

Mon 01/02/2023 to Wed 01/04/2023
0001 Continuous 0300

Work scheduled by: ConEd

| | FWD |
|-----------------------------------|----------|
| | (Import) |
| SPR/DUN-SOUTH | 3800 MW |
| Impacts Total Transfer Capability | 800 MW |
| TTC with All Lines In Service | 4600 MW |

FRASER__345_FRASER SVC

Tue 01/03/2023 to Tue 02/28/2023
0700 Continuous 1730

UPDATED by NYPA 12/30/2021

Work scheduled by: NYPA

| | FWD |
|-----------------------------------|----------|
| | (Import) |
| CENTRAL EAST - VC | 2550 MW |
| Impacts Total Transfer Capability | 35 MW |
| TTC with All Lines In Service | 2585 MW |

| | |
|-------------------|--------|
| CENTRAL EAST | 2650MW |
| CENTRAL EAST - VC | 2585MW |
| TOTAL EAST | 6000MW |
| UPNY CONED | 7815MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3200MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

| | | | | |
|-----------------------------------|------------|----------------|-----------------------------------|----------------|
| NIAGARA__-PACKARD__230_62 | | | FWD | REV |
| Mon 01/09/2023 | to | Fri 01/20/2023 | (Import) | (Export) |
| 0500 | Continuous | 1900 | SCH - OH - NY | 900 MW |
| Work scheduled by: NYPA | | | Impacts Total Transfer Capability | 1400 MW |
| | | | TTC with All Lines In Service | 2300 MW |
| E13THSTA-FARRAGUT_345_46 | | | FWD | |
| Fri 01/27/2023 | to | Wed 02/01/2023 | (Import) | |
| 0001 | Continuous | 0300 | SPR/DUN-SOUTH | 3800 MW |
| Work scheduled by: ConEd | | | Impacts Total Transfer Capability | 800 MW |
| | | | TTC with All Lines In Service | 4600 MW |
| E13THSTA-FARRAGUT_345_45 | | | FWD | |
| Wed 02/08/2023 | to | Wed 02/08/2023 | (Import) | |
| 0001 | Continuous | 0030 | SPR/DUN-SOUTH | 3800 MW |
| Work scheduled by: ConEd | | | Impacts Total Transfer Capability | 800 MW |
| | | | TTC with All Lines In Service | 4600 MW |
| E13THSTA-FARRAGUT_345_45 | | | FWD | |
| Wed 02/22/2023 | to | Wed 02/22/2023 | (Import) | |
| 0230 | Continuous | 0300 | SPR/DUN-SOUTH | 3800 MW |
| Work scheduled by: ConEd | | | Impacts Total Transfer Capability | 800 MW |
| | | | TTC with All Lines In Service | 4600 MW |
| EDIC__-FRASER__345_EF24-40 | | | FWD | |
| Wed 03/01/2023 | to | Sat 04/15/2023 | (Import) | |
| 0600 | Continuous | 1800 | CENTRAL EAST - VC | 2275 MW |
| Work scheduled by: NGrid | | | Impacts Total Transfer Capability | 310 MW |
| | | | TTC with All Lines In Service | 2585 MW |
| GORDONRD-N.SCTLND_345_55 | | | FWD | |
| Wed 03/01/2023 | to | Fri 03/31/2023 | (Import) | |
| 0700 | Continuous | 1600 | CENTRAL EAST - VC | 2045 MW |
| Work scheduled by: LS | | | Impacts Total Transfer Capability | 540 MW |
| | | | TTC with All Lines In Service | 2585 MW |
| MOSES__-ADIRNDCK_230_MAI | | | FWD | |
| Wed 03/01/2023 | to | Fri 05/26/2023 | (Import) | |
| 1101 | Continuous | 1930 | MOSES SOUTH | 2300 MW |
| Work scheduled by: NYPA | | | Impacts Total Transfer Capability | 850 MW |
| | | | TTC with All Lines In Service | 3150 MW |

NYISO TRANSFER LIMITATIONS

Monday ,October 03, 2022 to Wednesday, April 03, 2024

| | |
|-------------------|--------|
| CENTRAL EAST | 2650MW |
| CENTRAL EAST - VC | 2585MW |
| TOTAL EAST | 6000MW |
| UPNY CONED | 7815MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3200MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_-ROBNSNRD_230_64

Mon 03/06/2023 to Fri 03/17/2023

0500 Continuous 1900

Work scheduled by: NYPA

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

REV

(Export)

1900 MW

100 MW

2000 MW

N.SCTLND-ALPS____345_2

Mon 03/27/2023 to Fri 05/19/2023

0700 Continuous 1900

Work scheduled by: NGrid

UPDATEDby NGRID 06/16/2022

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD

(Import)

900 MW

500 MW

1400 MW

N.SCTLND-ALPS____345_2

Mon 03/27/2023 to Fri 05/19/2023

0700 Continuous 1900

Work scheduled by: NGrid

UPDATEDby NGRID 06/16/2022

SCH - NPX_1385

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD

(Import) (Export)

100 MW

100 MW

100 MW

200 MW

PLSNTVLY_345KV_RNS4

Sat 04/01/2023 to Sat 04/01/2023

0700 Continuous 0730

Work scheduled by: NGrid

UPNY CONED

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD

(Import)

3800 MW

4015 MW

7815 MW

ATHENS_-PLSNTVLY_345_91

Sat 04/01/2023 to Sat 04/15/2023

0700 Continuous 1900

Work scheduled by: NGrid

UPNY CONED

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD

(Import)

3800 MW

4015 MW

7815 MW

LINDN_CG-LNDVFT____345_V-3022

Sun 04/09/2023 to Sat 04/15/2023

1400 Continuous 1400

Work scheduled by: PJM

SCH - PJM_VFT

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD

(Import) (Export)

0 MW

315 MW

315 MW

0 MW

315 MW

315 MW

DYSINGER-STA_255__345_DH1

Mon 04/10/2023 to Fri 04/14/2023

0500 Continuous 2000

Work scheduled by: NYPA

DYSINGER EAST

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD

(Import)

2850 MW

350 MW

3200 MW

NYISO TRANSFER LIMITATIONS

Monday ,October 03, 2022 to Wednesday, April 03, 2024

| | |
|-------------------|--------|
| CENTRAL EAST | 2650MW |
| CENTRAL EAST - VC | 2585MW |
| TOTAL EAST | 6000MW |
| UPNY CONED | 7815MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3200MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

GORDONRD-N.SCTLND_345_55

FWD

Mon 04/10/2023 to Fri 04/14/2023

(Import)

0600 Continuous 1700

CENTRAL EAST - VC

2045 MW

Impacts Total Transfer Capability 540 MW

TTC with All Lines In Service 2585 MW

Work scheduled by: NGrid

DUNWODIE_345KV_3

FWD

Wed 04/12/2023 to Wed 04/12/2023

(Import)

0201 Continuous 0230

SPR/DUN-SOUTH

3800 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

DUNWODIE_345KV_4

FWD

Wed 04/12/2023 to Wed 04/12/2023

(Import)

0201 Continuous 0230

SPR/DUN-SOUTH

3800 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

PLSNTVLE-DUNWODIE_345_W89

FWD

Wed 04/12/2023 to Wed 04/12/2023

(Import)

0201 Continuous 0230

UPNY CONED

4000 MW

Impacts Total Transfer Capability 3815 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

MOTHAVN-RAINEY___345_Q12

FWD

Thu 04/13/2023 to Sat 04/22/2023

(Import)

0001 Continuous 0200

UPDATED**by CE****06/14/2022**

SPR/DUN-SOUTH

3800 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

PLSNTVLY_345KV_RNS4

FWD

Sat 04/15/2023 to Sat 04/15/2023

(Import)

1830 Continuous 1900

UPNY CONED

3800 MW

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: NGrid

PLSNTVLY_345KV_RNS5

FWD

Sun 04/16/2023 to Sun 04/16/2023

(Import)

0700 Continuous 0730

UPNY CONED

3800 MW

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: NGrid

NYISO TRANSFER LIMITATIONS

Monday ,October 03, 2022 to Wednesday, April 03, 2024

| | |
|--------------------------|---------------|
| CENTRAL EAST | 2650MW |
| CENTRAL EAST - VC | 2585MW |
| TOTAL EAST | 6000MW |
| UPNY CONED | 7815MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3200MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LEEDS___-PLSNTVLY_345_92

FWD

Sun 04/16/2023 to Sun 04/30/2023

(Import)

0700 Continuous 1900

Work scheduled by: NGrid

UPNY CONED

3800 MW

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

DYSINGER-STA_255__345_DH2

FWD

Mon 04/17/2023 to Fri 04/21/2023

(Import)

0500 Continuous 2000

Work scheduled by: NYPA

DYSINGER EAST

2850 MW

Impacts Total Transfer Capability 350 MW

TTC with All Lines In Service 3200 MW

CLAY___-EDIC___345_2-15

FWD

Mon 04/17/2023 to Fri 04/28/2023

(Import)

0600 Continuous 1800

Work scheduled by: NGrid

OSWEGO EXPORT

4850 MW

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 5250 MW

DUNWODIE_345KV_3

FWD

Thu 04/20/2023 to Thu 04/20/2023

(Import)

0130 Continuous 0200

Work scheduled by: ConEd

SPR/DUN-SOUTH

3800 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_4

FWD

Thu 04/20/2023 to Thu 04/20/2023

(Import)

0130 Continuous 0200

Work scheduled by: ConEd

SPR/DUN-SOUTH

3800 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

PLSNTVLE-DUNWODIE_345_W89

FWD

Thu 04/20/2023 to Thu 04/20/2023

(Import)

0130 Continuous 0200

Work scheduled by: ConEd

UPNY CONED

4000 MW

Impacts Total Transfer Capability 3815 MW

TTC with All Lines In Service 7815 MW

PANNELL_-CLAY___345_1

FWD

Mon 04/24/2023 to Fri 04/28/2023

(Import)

0700 Continuous 1530

Work scheduled by: NYPA

WEST CENTRAL

1300 MW

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW

NYISO TRANSFER LIMITATIONS

Monday ,October 03, 2022 to Wednesday, April 03, 2024

| | |
|-------------------|--------|
| CENTRAL EAST | 2650MW |
| CENTRAL EAST - VC | 2585MW |
| TOTAL EAST | 6000MW |
| UPNY CONED | 7815MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3200MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOTTHAVN-RAINEY___345_Q12

FWD

Tue 04/25/2023 to Tue 04/25/2023
0130 Continuous 0200

UPDATEDby CE06/14/2022

(Import)

Work scheduled by: ConEd

SPR/DUN-SOUTH

3800 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

PLSNTVLY_345KV_RNS5

FWD

Sun 04/30/2023 to Sun 04/30/2023
1830 Continuous 1900

(Import)

Work scheduled by: NGrid

UPNY CONED

3800 MW

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

SHOR_NPX-SHOREHAM_138_CSC

FWD

REV

Mon 05/01/2023 to Fri 05/05/2023
0600 Continuous 1800

(Import) (Export)

Work scheduled by: LI

SCH - NPX_CSC

0 MW**0 MW**

Impacts Total Transfer Capability 330 MW 330 MW

TTC with All Lines In Service 330 MW 330 MW

PANNELL_-CLAY___345_2

FWD

Mon 05/01/2023 to Fri 05/05/2023
0700 Continuous 1530

(Import)

Work scheduled by: NYPA

WEST CENTRAL

1300 MW

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW

PLSNTVLY-WOOD_ST__345_F30

FWD

Wed 05/03/2023 to Mon 05/15/2023
0001 Continuous 2200

(Import)

Work scheduled by: ConEd

UPNY CONED

4000 MW

Impacts Total Transfer Capability 3815 MW

TTC with All Lines In Service 7815 MW

PLSNTVLY_345KV_RNS5

FWD

Wed 05/03/2023 to Mon 05/15/2023
0001 Continuous 2200

(Import)

Work scheduled by: ConEd

UPNY CONED

3800 MW

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

NIAGARA_-ROBNSNRD_230_64

REV

Fri 05/05/2023 to Fri 05/05/2023
0500 Continuous 1700

(Export)

Work scheduled by: NYPA

SCH - OH - NY

1400 MW

Impacts Total Transfer Capability 150 MW

TTC with All Lines In Service 1550 MW

| | |
|-------------------|--------|
| CENTRAL EAST | 2650MW |
| CENTRAL EAST - VC | 2585MW |
| TOTAL EAST | 6000MW |
| UPNY CONED | 7815MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3200MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_6

Sat 05/06/2023 to Sat 05/06/2023
0001 Continuous 0030

Work scheduled by: ConEd

FWD
(Import)
SCH - PJM_HTP **300 MW**
Impacts Total Transfer Capability 360 MW
TTC with All Lines In Service 660 MW

W49TH_ST_345KV_8

Sat 05/06/2023 to Sat 05/06/2023
0001 Continuous 0030

Work scheduled by: ConEd

FWD
(Import)
SCH - PJM_HTP **450 MW**
Impacts Total Transfer Capability 210 MW
TTC with All Lines In Service 660 MW

DOLSONAV-ROCKTVRN_345_DART44

Mon 05/08/2023 to Sat 05/13/2023
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2485 MW**
Impacts Total Transfer Capability 100 MW
TTC with All Lines In Service 2585 MW

COOPERS_-DOLSONAV_345_CCDA42

Mon 05/08/2023 to Sun 05/21/2023
0700 Continuous 1530

Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **2485 MW**
Impacts Total Transfer Capability 100 MW
TTC with All Lines In Service 2585 MW

W49TH_ST_345KV_6

Sat 05/13/2023 to Sat 05/13/2023
0130 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
SCH - PJM_HTP **300 MW**
Impacts Total Transfer Capability 360 MW
TTC with All Lines In Service 660 MW

W49TH_ST_345KV_8

Sat 05/13/2023 to Sat 05/13/2023
0130 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
SCH - PJM_HTP **450 MW**
Impacts Total Transfer Capability 210 MW
TTC with All Lines In Service 660 MW

MOTTHAVN-RAINEY___345_Q11

Wed 05/17/2023 to Sat 05/20/2023
0001 Continuous 0200

Work scheduled by: ConEd

FWD
(Import)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Monday ,October 03, 2022 to Wednesday, April 03, 2024

| | |
|-------------------|--------|
| CENTRAL EAST | 2650MW |
| CENTRAL EAST - VC | 2585MW |
| TOTAL EAST | 6000MW |
| UPNY CONED | 7815MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3200MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BECK____-NIAGARA__230_PA27

Tue 05/30/2023 to Fri 06/02/2023
0500 Continuous 2100

Work scheduled by: NYPA

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

NIAGARA__345_230_AT4

Wed 06/28/2023 to Thu 06/29/2023
0500 Continuous 1900

Work scheduled by: NYPA

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

REV

(Export)

1150 MW

400 MW

1550 MW

NIAGARA__345_230_AT4

Mon 08/21/2023 to Fri 08/25/2023
0500 Continuous 2100

Work scheduled by: NYPA

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

REV

(Export)

1150 MW

400 MW

1550 MW

ADIRNDCK-PORTER__230_12

Tue 08/22/2023 to Tue 08/22/2023
0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH

2100 MW

Impacts Total Transfer Capability 1050 MW

TTC with All Lines In Service 3150 MW

ADIRNDCK-CHASLAKE_230_13

Wed 08/23/2023 to Wed 08/23/2023
0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

MOSES SOUTH

2100 MW

Impacts Total Transfer Capability 1050 MW

TTC with All Lines In Service 3150 MW

CLAY____-EDIC____345_1-16

Mon 09/11/2023 to Fri 09/15/2023
0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

OSWEGO EXPORT

4850 MW

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 5250 MW

FRASER__-GILBOA__345_GF5-35

Mon 09/11/2023 to Sun 09/17/2023
0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

CENTRAL EAST - VC

2450 MW

Impacts Total Transfer Capability 135 MW

TTC with All Lines In Service 2585 MW

NYISO TRANSFER LIMITATIONS

Monday ,October 03, 2022 to Wednesday, April 03, 2024

| | |
|-------------------|--------|
| CENTRAL EAST | 2650MW |
| CENTRAL EAST - VC | 2585MW |
| TOTAL EAST | 6000MW |
| UPNY CONED | 7815MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3200MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

| | | | | | | |
|-------------------------------|------------|----------------|----------------|--------------|-----------------------------------|-------------------|
| SPRNBRK_-W49TH_ST_345_M51 | | | | | FWD | |
| Fri 09/15/2023 | to | Mon 10/23/2023 | <u>UPDATED</u> | <u>by CE</u> | <u>08/10/2022</u> | (Import) |
| 0001 | Continuous | 0200 | | | | |
| Work scheduled by: ConEd | | | | | SPR/DUN-SOUTH | 3200 MW |
| | | | | | Impacts Total Transfer Capability | 1400 MW |
| | | | | | TTC with All Lines In Service | 4600 MW |
| SPRNBRK_345KV_RNS5 | | | | | FWD | |
| Fri 09/15/2023 | to | Mon 10/23/2023 | <u>UPDATED</u> | <u>by CE</u> | <u>08/10/2022</u> | (Import) |
| 0001 | Continuous | 0200 | | | | |
| Work scheduled by: ConEd | | | | | SPR/DUN-SOUTH | 3200 MW |
| | | | | | Impacts Total Transfer Capability | 1400 MW |
| | | | | | TTC with All Lines In Service | 4600 MW |
| CLAY_-EDIC_345_2-15 | | | | | FWD | |
| Mon 09/18/2023 | to | Fri 09/22/2023 | | | | (Import) |
| 0700 | Continuous | 1530 | | | | |
| Work scheduled by: NYPA | | | | | OSWEGO EXPORT | 4850 MW |
| | | | | | Impacts Total Transfer Capability | 400 MW |
| | | | | | TTC with All Lines In Service | 5250 MW |
| NIAGARA_-DYSINGER_345_ND2 | | | | | FWD | |
| Mon 09/25/2023 | to | Fri 09/29/2023 | | | | (Import) |
| 0500 | Continuous | 2000 | | | | |
| Work scheduled by: NYPA | | | | | DYSINGER EAST | 2700 MW |
| | | | | | Impacts Total Transfer Capability | 500 MW |
| | | | | | TTC with All Lines In Service | 3200 MW |
| MARCY_345KV_CSC | | | | | FWD | |
| Mon 09/25/2023 | to | Sat 10/07/2023 | | | | (Import) |
| 0700 | Continuous | 1530 | | | | |
| Work scheduled by: NYPA | | | | | CENTRAL EAST - VC | 2535 MW |
| | | | | | Impacts Total Transfer Capability | 50 MW |
| | | | | | TTC with All Lines In Service | 2585 MW |
| SHOR_NPX-SHOREHAM_138_CSC | | | | | FWD | REV |
| Mon 10/02/2023 | to | Fri 10/06/2023 | | | | (Import) (Export) |
| 0600 | Continuous | 1800 | | | | |
| Work scheduled by: LI | | | | | SCH - NPX_CSC | 0 MW 0 MW |
| | | | | | Impacts Total Transfer Capability | 330 MW 330 MW |
| | | | | | TTC with All Lines In Service | 330 MW 330 MW |
| NEPTUNE_-DUFFYAVE_345_NEPTUNE | | | | | FWD | |
| Mon 10/09/2023 | to | Fri 10/13/2023 | | | | (Import) |
| 0600 | Continuous | 1600 | | | | |
| Work scheduled by: LI | | | | | SCH - PJM_NEPTUNE | 0 MW |
| | | | | | Impacts Total Transfer Capability | 660 MW |
| | | | | | TTC with All Lines In Service | 660 MW |

NYISO TRANSFER LIMITATIONS

Monday ,October 03, 2022 to Wednesday, April 03, 2024

| | |
|--------------------------|---------------|
| CENTRAL EAST | 2650MW |
| CENTRAL EAST - VC | 2585MW |
| TOTAL EAST | 6000MW |
| UPNY CONED | 7815MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3200MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEWBRDGE-DUFFYAVE_345_501

FWD

Mon 10/09/2023 to Fri 10/13/2023

(Import)

0600 Continuous 1600

SCH - PJM_NEPTUNE

0 MW

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

Work scheduled by: LI

NEWBRDGE_345_138_BK_1

FWD

Mon 10/09/2023 to Fri 10/13/2023

(Import)

0600 Continuous 1600

SCH - PJM_NEPTUNE

375 MW

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 660 MW

Work scheduled by: LI

NEWBRDGE_345_138_BK_2

FWD

Mon 10/09/2023 to Fri 10/13/2023

(Import)

0600 Continuous 1600

SCH - PJM_NEPTUNE

375 MW

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 660 MW

Work scheduled by: LI

GILBOA_-N.SCTLND_345_GNS-1

FWD

Mon 10/09/2023 to Fri 10/13/2023

(Import)

0700 Continuous 1530

CENTRAL EAST - VC

2300 MW

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 2585 MW

Work scheduled by: NYPA

NIAGARA_-PACKARD_230_61

REV

Fri 10/13/2023 to Fri 10/13/2023

(Export)

0500 Continuous 1900

SCH - OH - NY

1350 MW

Impacts Total Transfer Capability 200 MW

TTC with All Lines In Service 1550 MW

Work scheduled by: NYPA

MOSES_-MASSENA_230_MMS1 & MOSES_-MASSENA_230_MMS2

FWD

REV

Wed 11/15/2023 to Mon 11/20/2023

(Import) (Export)

0700 1530

SCH - HQ - NY

850 MW 0 MW

Impacts Total Transfer Capability 650 MW 1000 MW

TTC with All Lines In Service 1500 MW 1000 MW

Work scheduled by:

MOSES_-MASSENA_230_MMS1 & MOSES_-MASSENA_230_MMS2

FWD

Wed 11/15/2023 to Mon 11/20/2023

(Import)

0700 1530

SCH - HQ_CEDARS

90 MW

Impacts Total Transfer Capability 189 MW

TTC with All Lines In Service 279 MW

Work scheduled by:

NYISO TRANSFER LIMITATIONS

Monday ,October 03, 2022 to Wednesday, April 03, 2024

| | |
|-------------------|--------|
| CENTRAL EAST | 2650MW |
| CENTRAL EAST - VC | 2585MW |
| TOTAL EAST | 6000MW |
| UPNY CONED | 7815MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3200MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHATGUAY-MASSENA__765_7040

Wed 11/15/2023 to Mon 11/27/2023
0700 Continuous 1730
Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **1550 MW**
Impacts Total Transfer Capability 1600 MW
TTC with All Lines In Service 3150 MW

CHATGUAY-MASSENA__765_7040

Wed 11/15/2023 to Mon 11/27/2023
0700 Continuous 1730
Work scheduled by: NYPA

FWD REV
(Import) (Export)
SCH - HQ - NY **0 MW 0 MW**
Impacts Total Transfer Capability 1500 MW 1000 MW
TTC with All Lines In Service 1500 MW 1000 MW

MASSENA_-MARCY____765_MSU1

Wed 11/15/2023 to Mon 11/27/2023
0700 Continuous 1730
Work scheduled by: NYPA

FWD
(Import)
CENTRAL EAST - VC **1720 MW**
Impacts Total Transfer Capability 865 MW
TTC with All Lines In Service 2585 MW

MASSENA_-MARCY____765_MSU1

Wed 11/15/2023 to Mon 11/27/2023
0700 Continuous 1730
Work scheduled by: NYPA

FWD
(Import)
MOSES SOUTH **500 MW**
Impacts Total Transfer Capability 2650 MW
TTC with All Lines In Service 3150 MW

MASSENA_-MARCY____765_MSU1

Wed 11/15/2023 to Mon 11/27/2023
0700 Continuous 1730
Work scheduled by: NYPA

FWD REV
(Import) (Export)
SCH - HQ - NY **475 MW 1000 MW**
Impacts Total Transfer Capability 1025 MW 0 MW
TTC with All Lines In Service 1500 MW 1000 MW

MASSENA_-MARCY____765_MSU1

Wed 11/15/2023 to Mon 11/27/2023
0700 Continuous 1730
Work scheduled by: NYPA

FWD
(Import)
SCH - HQ_CEDARS **90 MW**
Impacts Total Transfer Capability 189 MW
TTC with All Lines In Service 279 MW

MASSENA_-MARCY____765_MSU1 & CHATGUAY-MASSENA__765_7040

Wed 11/15/2023 to Mon 11/27/2023
0700 Continuous 1730
Work scheduled by:

FWD
(Import)
MOSES SOUTH **500 MW**
Impacts Total Transfer Capability 2650 MW
TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Monday ,October 03, 2022 to Wednesday, April 03, 2024

| | |
|-------------------|--------|
| CENTRAL EAST | 2650MW |
| CENTRAL EAST - VC | 2585MW |
| TOTAL EAST | 6000MW |
| UPNY CONED | 7815MW |
| SPR/DUN-SOUTH | 4600MW |
| DYSINGER EAST | 3200MW |
| MOSES SOUTH | 3150MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA__345_230_AT4

REV

Mon 11/27/2023 to Fri 12/01/2023

(Export)

0500 Continuous 1900

SCH - OH - NY

1750 MW

Impacts Total Transfer Capability

250 MW

TTC with All Lines In Service

2000 MW

Work scheduled by: NYPA

HOMRC_NY-MAINS_NY_345_47

Fri 12/08/2023 to Fri 12/15/2023

UPDATEDby PJM01/11/2022

0800 Continuous 1600

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: PJM

HOMR_NYW-PIERC_NY_345_48

Fri 12/08/2023 to Fri 12/15/2023

UPDATEDby PJM01/11/2022

0800 Continuous 1600

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: PJM

W49TH_ST-E13THSTA_345_M55

FWD

Mon 01/08/2024 to Fri 02/09/2024

(Import)

0001 Continuous 0200

SPR/DUN-SOUTH

3800 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

W49TH_ST_345KV_6

FWD

Mon 01/08/2024 to Fri 02/09/2024

(Import)

0001 Continuous 0200

SCH - PJM_HTP

310 MW

Impacts Total Transfer Capability 350 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

W49TH_ST_345KV_8

FWD

Sat 02/03/2024 to Fri 02/09/2024

(Import)

0001 Continuous 0200

SCH - PJM_HTP

310 MW

Impacts Total Transfer Capability 350 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd