

NYISO TRANSFER LIMITATIONS

Page 1 of 47
Number Of Records: 174
Report Run Date: 10/25/2022 17:19 (EPT)

Seasonal Limits

Tuesday, October 25, 2022 to Wednesday, April 24, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
HUDSONP_-FARRAGUT_345_B3402				2050 MW	
Mon 01/15/2018	to	Tue 01/31/2023			
0001	Continuous	2359	<u>EXT FORCED by ConEd 08/06/2022 16:26</u>		
Work scheduled by: ConEd				Impacts Total Transfer Capability	200 MW
				TTC with All Lines In Service	2250 MW
MARION__-FARRAGUT_345_C3403				2050 MW	
Mon 01/15/2018	to	Tue 01/31/2023			
0001	Continuous	2359	<u>EXT FORCED by ConEd 08/06/2022 16:26</u>		
Work scheduled by: ConEd				Impacts Total Transfer Capability	200 MW
				TTC with All Lines In Service	2250 MW
MARION__-FARRAGUT_345_C3403 , HUDSONP_-FARRAGUT_345_B3402				2000 MW	1150 MW
Mon 01/15/2018	to	Tue 01/31/2023			
0001		2359			
Work scheduled by:				Impacts Total Transfer Capability	250 MW
				TTC with All Lines In Service	1200 MW

NYISO TRANSFER LIMITATIONS

Page 2 of 47
Number Of Records: 174
Report Run Date: 10/25/2022 17:19 (EPT)

Seasonal Limits

Tuesday, October 25, 2022 to Wednesday, April 24, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
SCH-IMO-NYISO_LIMIT_1400				1700 MW	
Wed 08/10/2022	to	Mon 11/21/2022	<u>EXTENDED by IESO 08/19/2022 14:10</u>		
0800	Continuous	1600			
Work scheduled by: IESO					
				Impacts Total Transfer Capability	200 MW
				TTC with All Lines In Service	1900 MW
BECK____-NIAGARA_230_PA27				1700 MW	
Wed 08/24/2022	to	Fri 10/28/2022	<u>EXTENDED by IESO 09/26/2022 15:45</u>		
0800	Continuous	1700			
Work scheduled by: IESO					
				Impacts Total Transfer Capability	200 MW
				TTC with All Lines In Service	1900 MW
SCH-HQ_CEDARS-NYISO_LIMIT_240				240 MW	
Tue 09/06/2022	to	Fri 10/28/2022	<u>EXTENDED by HQ 09/27/2022 13:12</u>		
0500	Continuous	1900			
Work scheduled by: HQ					
				Impacts Total Transfer Capability	30 MW
				TTC with All Lines In Service	270 MW
SCH-NYISO-HQ_CEDARS_LIMIT_0				0 MW	
Tue 09/06/2022	to	Fri 10/28/2022	<u>EXTENDED by HQ 09/27/2022 13:12</u>		
0500	Continuous	1900			
Work scheduled by: HQ					
				Impacts Total Transfer Capability	100 MW
				TTC with All Lines In Service	100 MW

NYISO TRANSFER LIMITATIONS

Page 3 of 47
Number Of Records: 174
Report Run Date: 10/25/2022 17:19 (EPT)

Seasonal Limits

Tuesday, October 25, 2022 to Wednesday, April 24, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
MOSES___-ADIRNDCK_230_MA2				2100 MW	
Tue 09/06/2022	to	Thu 12/01/2022	UPDATED by NYPA 09/06/2022 15:41	MOSES SOUTH	
1200	Continuous	0659		Impacts Total Transfer Capability	1050 MW
Work scheduled by: NYPA				TTC with All Lines In Service	3150 MW
HURLYAVE-ROSETON_345_303				4100 MW	
Mon 09/19/2022	to	Fri 12/02/2022	UPDATED by CHGE 10/04/2022 09:16	UPNY CONED	
0800	Continuous	1600		Impacts Total Transfer Capability	3715 MW
Work scheduled by: CHGE				TTC with All Lines In Service	7815 MW
LEEDS___-HURLYAVE_345_301				4100 MW	
Mon 09/19/2022	to	Fri 12/02/2022	10/04/2021 10:51	UPNY CONED	
0800	Continuous	1600		Impacts Total Transfer Capability	3715 MW
Work scheduled by: CHGE				TTC with All Lines In Service	7815 MW
EGRDNCTY_345_138_AT1				1250 MW	
Sat 10/01/2022	to	Wed 05/31/2023	UPDATED by ConEd 10/01/2022 09:02	CONED - LIPA	
0001	Continuous	2359		Impacts Total Transfer Capability	250 MW
Work scheduled by: LI				TTC with All Lines In Service	1500 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, October 25, 2022 to Wednesday, April 24, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

					FWD	REV
					(Import)	(Export)
EGRDNCTY_345_138_AT2						
Sat 10/01/2022	to	Wed 05/31/2023	<u>UPDATED by ConEd 10/01/2022 09:02</u>	CONED - LIPA	1250 MW	
0001	Continuous	2359		Impacts Total Transfer Capability	250 MW	
Work scheduled by: LI				TTC with All Lines In Service	1500 MW	
					FWD	REV
					(Import)	(Export)
SPRNBK_-EGRDNCTR_345_Y49						
Sat 10/01/2022	to	Wed 05/31/2023	<u>UPDATED by ConEd 10/01/2022 09:02</u>	CONED - LIPA	775 MW	
0001	Continuous	2359		Impacts Total Transfer Capability	725 MW	
Work scheduled by: LI				TTC with All Lines In Service	1500 MW	
					FWD	REV
					(Import)	(Export)
STLAWRNC-MOSES____230_L34P						
Mon 10/03/2022	to	Mon 09/25/2023	<u>UPDATED by IESO 10/04/2022 16:51</u>	SCH - OH - NY		
1800	Continuous	0800		Impacts Total Transfer Capability		
Work scheduled by: IESO				TTC with All Lines In Service		

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, October 25, 2022 to Wednesday, April 24, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
DUNWODIE-MOTTHAVN_345_71					
Thu 10/06/2022	to	Thu 11/10/2022			
0001	Continuous	0300	UPDATED by ConEd 08/16/2022 09:29		
Work scheduled by: ConEd					
				SPR/DUN-SOUTH	3800 MW
				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
CHAT_DC_GC1				FWD	REV
				(Import)	(Export)
Sun 10/09/2022	to	Sun 11/06/2022			
0400	Continuous	2200			
Work scheduled by: HQ					
				MOSES SOUTH	2850 MW
				Impacts Total Transfer Capability	300 MW
				TTC with All Lines In Service	3150 MW
CHAT_DC_GC1				FWD	REV
				(Import)	(Export)
Sun 10/09/2022	to	Sun 11/06/2022			
0400	Continuous	2200			
Work scheduled by: HQ					
				SCH - HQ - NY	500 MW
				Impacts Total Transfer Capability	500 MW
				TTC with All Lines In Service	1000 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, October 25, 2022 to Wednesday, April 24, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
SCH-NYISO-HQ_LIMIT_500					
Sun 10/09/2022	to	Sun 11/06/2022		SCH - HQ - NY	500 MW
0400	Continuous	2200		Impacts Total Transfer Capability	500 MW
Work scheduled by: HQ				TTC with All Lines In Service	1000 MW
EDIC____-GORDONRD_345_14				FWD	REV
				(Import)	(Export)
Mon 10/10/2022	to	Mon 10/31/2022		CENTRAL EAST - VC	1670 MW
0700	Continuous	1530	<u>UPDATED by NYPA 06/30/2022 15:45</u>	Impacts Total Transfer Capability	915 MW
Work scheduled by: NYPA				TTC with All Lines In Service	2585 MW
W49TH_ST-E13THSTA_345_M55				FWD	REV
				(Import)	(Export)
Tue 10/18/2022	to	Fri 11/04/2022		SPR/DUN-SOUTH	3800 MW
0003	Continuous	2359	<u>EXT FORCED by ConEd 10/19/2022 17:42</u>	Impacts Total Transfer Capability	800 MW
Work scheduled by: ConEd				TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, October 25, 2022 to Wednesday, April 24, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
BUCHAN_N-EASTVIEW_345_W93					
Wed 10/19/2022	to	Tue 11/01/2022			
0001	Continuous	0200	UPDATED by ConEd 09/07/2022 11:39	UPNY CONED	4350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	3465 MW
				TTC with All Lines In Service	7815 MW
RAMAPO__-BUCHAN_N_345_Y94					
Thu 10/20/2022	to	Tue 11/01/2022			
0001	Continuous	0200	UPDATED by ConEd 09/07/2022 11:39	UPNY CONED	7580 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	235 MW
				TTC with All Lines In Service	7815 MW
PANNELL_-CLAY____345_1					
Mon 10/24/2022	to	Fri 10/28/2022			
0700	Continuous	1530	UPDATED by NYPA 09/01/2022 11:59	WEST CENTRAL	1300 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	950 MW
				TTC with All Lines In Service	2250 MW
ELBRIDGE-LAFAYTTE_345_17-LE					
Tue 10/25/2022	to	Tue 10/25/2022			
0630	Continuous	0830	ARR: 75	OSWEGO EXPORT	5250 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	0 MW
				TTC with All Lines In Service	5250 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, October 25, 2022 to Wednesday, April 24, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
OSWEGO__-ELBRIDGE_345_17					
Tue 10/25/2022	to	Tue 10/25/2022			
0630	Continuous	1700			
Work scheduled by: NGrid					
ARR: 75					
OSWEGO EXPORT				5250 MW	
Impacts Total Transfer Capability				0 MW	
TTC with All Lines In Service				5250 MW	
ALCOA_PA_115KV_R8105					
Tue 10/25/2022	to	Thu 10/27/2022			
0700	Daily(No Weekends)	1600			
Work scheduled by: NGrid					
MOSES SOUTH				3100 MW	
Impacts Total Transfer Capability				50 MW	
TTC with All Lines In Service				3150 MW	
MAINESBG-WATRCURE_345_30					
Tue 10/25/2022	to	Tue 10/25/2022			
0800	Daily	1500			
Work scheduled by: NYSEG					
SCH - PJ - NY					
Impacts Total Transfer Capability					
TTC with All Lines In Service					
ELBRIDGE-LAFAYTTE_345_17-LE					
Tue 10/25/2022	to	Tue 10/25/2022			
1500	Continuous	1700			
Work scheduled by: NGrid					
ARR: 75					
OSWEGO EXPORT				5250 MW	
Impacts Total Transfer Capability				0 MW	
TTC with All Lines In Service				5250 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, October 25, 2022 to Wednesday, April 24, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LEEDS___345KV_R395

Wed 10/26/2022 to Wed 10/26/2022

0900 Daily(No
Weekends)

1030

Work scheduled by: NGrid

UPNY CONED

Impacts Total Transfer
Capability

TTC with All Lines In Service

FWD REV
(Import) (Export)

3800 MW

4015 MW

7815 MW

WATRCURE-OAKDALE_345_31

Thu 10/27/2022 to Thu 10/27/2022

0800 Daily

1500

Work scheduled by: NYSEG

SCH - PJ - NY

Impacts Total Transfer
Capability

TTC with All Lines In Service

FWD REV
(Import) (Export)

SCH-NYISO-NE_LIMIT_900

Sat 10/29/2022 to Sat 10/29/2022

0900 Continuous

1100

Work scheduled by: ISONE

SCH - NE - NY

Impacts Total Transfer
Capability

TTC with All Lines In Service

FWD REV
(Import) (Export)

1100 MW

500 MW

1600 MW

NYISO TRANSFER LIMITATIONS

Page 10 of 47
Number Of Records: 174
Report Run Date: 10/25/2022 17:19 (EPT)

Seasonal Limits

Tuesday, October 25, 2022 to Wednesday, April 24, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
EASTVIEW-SPRNBK__345_W79					
Sun 10/30/2022	to	Sun 10/30/2022			
0130	Continuous	0200	UPDATED by ConEd 09/07/2022 11:39	UPNY CONED	4350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	3465 MW
				TTC with All Lines In Service	7815 MW
PANNELL_-CLAY____345_2					
Mon 10/31/2022	to	Fri 11/04/2022			
0700	Continuous	1530	UPDATED by NYPA 09/01/2022 11:47	WEST CENTRAL	1300 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	950 MW
				TTC with All Lines In Service	2250 MW
BUCHAN_S-MILLWOOD_345_W97					
Tue 11/01/2022	to	Wed 11/02/2022			
0001	Continuous	0200		UPNY CONED	7680 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	135 MW
				TTC with All Lines In Service	7815 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, October 25, 2022 to Wednesday, April 24, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
CLAY___-EDIC___345_1-16					
Tue 11/01/2022	to	Thu 11/03/2022			
0600	Continuous	1900	UPDATED by NGrid 07/05/2022 10:37	OSWEGO EXPORT	4850 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	400 MW
				TTC with All Lines In Service	5250 MW
GILBOA___N.SCTLND_345_GNS-1					
Tue 11/01/2022	to	Tue 12/06/2022			
0700	Continuous	1900	UPDATED by NGrid 08/19/2022 14:50	CENTRAL EAST - VC	2300 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	285 MW
				TTC with All Lines In Service	2585 MW
MARCY___-N.SCTLND_345_18					
Tue 11/01/2022	to	Tue 12/06/2022			
0700	Continuous	1900	UPDATED by NGrid 08/19/2022 14:50	CENTRAL EAST - VC	1345 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	1240 MW
				TTC with All Lines In Service	2585 MW

ARR: 19

NYISO TRANSFER LIMITATIONS

Page 12 of 47
Number Of Records: 174
Report Run Date: 10/25/2022 17:19 (EPT)

Seasonal Limits

Tuesday, October 25, 2022 to Wednesday, April 24, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
LINDN_CG-LNDVFT__345_V-3022					
Tue 11/01/2022	to	Fri 11/04/2022		SCH - PJM_VFT	0 MW
0800	Continuous	1500		Impacts Total Transfer Capability	315 MW
Work scheduled by: PJM				TTC with All Lines In Service	315 MW
NEPTUNE_-DUFFYAVE_345_NEPTUNE					
Wed 11/02/2022	to	Tue 11/08/2022		SCH - PJM_NEPTUNE	0 MW
0600	Continuous	1600		Impacts Total Transfer Capability	660 MW
Work scheduled by: LI				TTC with All Lines In Service	660 MW
NEWBRDGE_345_138_BK_1					
Wed 11/02/2022	to	Tue 11/08/2022		SCH - PJM_NEPTUNE	375 MW
0600	Continuous	1600		Impacts Total Transfer Capability	285 MW
Work scheduled by: LI				TTC with All Lines In Service	660 MW

NYISO TRANSFER LIMITATIONS

Page 13 of 47
Number Of Records: 174
Report Run Date: 10/25/2022 17:19 (EPT)

Seasonal Limits

Tuesday, October 25, 2022 to Wednesday, April 24, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
NEWBRDGE_345_138_BK_2					
Wed 11/02/2022	to	Tue 11/08/2022		SCH - PJM_NEPTUNE	375 MW
0600	Continuous	1600		Impacts Total Transfer Capability	285 MW
Work scheduled by: LI				TTC with All Lines In Service	660 MW
				FWD	REV
				(Import)	(Export)
NEWBRDGE-DUFFYAVE_345_501					
Wed 11/02/2022	to	Tue 11/08/2022		SCH - PJM_NEPTUNE	0 MW
0600	Continuous	1600		Impacts Total Transfer Capability	660 MW
Work scheduled by: LI				TTC with All Lines In Service	660 MW
				FWD	REV
				(Import)	(Export)
HOMR_NYW-PIERC_NY_345_48					
Wed 11/02/2022	to	Wed 11/02/2022		SCH - PJ - NY	
0800	Continuous	1500		Impacts Total Transfer Capability	
Work scheduled by: NYSEG				TTC with All Lines In Service	

UPDATED by PJM 10/25/2022 13:37

NYISO TRANSFER LIMITATIONS

Page 14 of 47
Number Of Records: 174
Report Run Date: 10/25/2022 17:19 (EPT)

Seasonal Limits

Tuesday, October 25, 2022 to Wednesday, April 24, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BECK___-PACKARD_230_BP76

Thu 11/03/2022 to Thu 11/03/2022
0730 Daily(No Weekends) 1200
Work scheduled by: NGrid

	FWD	REV
	(Import)	(Export)
SCH - OH - NY	1750 MW	1400 MW
Impacts Total Transfer Capability	550 MW	600 MW
TTC with All Lines In Service	2300 MW	2000 MW

CEDARS_-ROSEMNTB_115_2/22

Mon 11/07/2022 to Fri 11/11/2022
0700 Continuous 1700
Work scheduled by: NGrid

	FWD	REV
	(Import)	(Export)
SCH - HQ_CEDARS	95 MW	100 MW
Impacts Total Transfer Capability	184 MW	0 MW
TTC with All Lines In Service	279 MW	100 MW

DENNISON-ROSEMNTB_115_2/22

Mon 11/07/2022 to Fri 11/11/2022
0700 Continuous 1700
Work scheduled by: NGrid

	FWD	REV
	(Import)	(Export)
SCH - HQ_CEDARS	95 MW	100 MW
Impacts Total Transfer Capability	184 MW	0 MW
TTC with All Lines In Service	279 MW	100 MW

DUNWODIE_345KV_3

Thu 11/10/2022 to Thu 11/10/2022
0230 Continuous 0300
Work scheduled by: ConEd

UPDATED by ConEd 08/16/2022 09:29

	FWD	REV
	(Import)	(Export)
SPR/DUN-SOUTH	3800 MW	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

NYISO TRANSFER LIMITATIONS

Page 15 of 47
Number Of Records: 174
Report Run Date: 10/25/2022 17:19 (EPT)

Seasonal Limits

Tuesday, October 25, 2022 to Wednesday, April 24, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
DUNWODIE_345KV_5					
Thu 11/10/2022	to	Thu 11/10/2022			
0230	Continuous	0300	UPDATED by ConEd 08/16/2022 09:29		
Work scheduled by: ConEd					
				SPR/DUN-SOUTH	3800 MW
				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
MAINESBG-WATRCURE_345_30				FWD	REV
				(Import)	(Export)
Thu 11/10/2022	to	Thu 11/10/2022			
0800	Continuous	1600			
Work scheduled by: PJM					
				SCH - PJ - NY	2300 MW
				Impacts Total Transfer Capability	550 MW
				TTC with All Lines In Service	2850 MW
DUNWODIE_345KV_7				FWD	REV
				(Import)	(Export)
Wed 11/16/2022	to	Wed 11/16/2022			
0100	Continuous	0200			
Work scheduled by: ConEd					
				SPR/DUN-SOUTH	3800 MW
				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_3				FWD	REV
				(Import)	(Export)
Thu 11/17/2022	to	Thu 11/17/2022			
0001	Continuous	0030			
Work scheduled by: ConEd					
				SPR/DUN-SOUTH	3800 MW
				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Page 16 of 47

Number Of Records: 174

Report Run Date: 10/25/2022 17:19 (EPT)

Seasonal Limits

Tuesday, October 25, 2022 to Wednesday, April 24, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
DUNWODIE_345KV_4					
Thu 11/17/2022	to	Thu 11/17/2022			
0001	Continuous	0030	SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	4600 MW	
PLSNTVLE-DUNWODIE_345_W89					
Thu 11/17/2022	to	Thu 11/17/2022			
0001	Continuous	0030	UPNY CONED	4000 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	3815 MW	
			TTC with All Lines In Service	7815 MW	
DUNWODIE_345KV_3					
Thu 11/17/2022	to	Thu 11/17/2022			
1730	Continuous	1800	SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	4600 MW	
DUNWODIE_345KV_4					
Thu 11/17/2022	to	Thu 11/17/2022			
1730	Continuous	1800	SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	4600 MW	

NYISO TRANSFER LIMITATIONS

Page 17 of 47
Number Of Records: 174
Report Run Date: 10/25/2022 17:19 (EPT)

Seasonal Limits

Tuesday, October 25, 2022 to Wednesday, April 24, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
PLSNTVLE-DUNWODIE_345_W89					
Thu 11/17/2022	to	Thu 11/17/2022			
1730	Continuous	1800	UPNY CONED	4000 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	3815 MW	
			TTC with All Lines In Service	7815 MW	
BUCHAN_N-EASTVIEW_345_W93				FWD	REV
				(Import)	(Export)
Mon 11/21/2022	to	Mon 11/28/2022			
0001	Continuous	0200	UPDATED by ConEd 09/07/2022 11:39	UPNY CONED	4350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	3465 MW
				TTC with All Lines In Service	7815 MW
EASTVIEW-SPRNBK__345_W79				FWD	REV
				(Import)	(Export)
Mon 11/21/2022	to	Mon 11/21/2022			
0001	Continuous	0030	UPDATED by ConEd 09/07/2022 11:39	UPNY CONED	4350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	3465 MW
				TTC with All Lines In Service	7815 MW

NYISO TRANSFER LIMITATIONS

Page 18 of 47
Number Of Records: 174
Report Run Date: 10/25/2022 17:19 (EPT)

Seasonal Limits

Tuesday, October 25, 2022 to Wednesday, April 24, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
RAMAPO__-BUCHAN_N_345_Y94					
Mon 11/21/2022	to	Mon 11/28/2022	<u>UPDATED by ConEd 09/07/2022 11:39</u>	UPNY CONED	7580 MW
0001	Continuous	0200		Impacts Total Transfer Capability	235 MW
Work scheduled by: ConEd				TTC with All Lines In Service	7815 MW
				FWD	REV
				(Import)	(Export)
E13THSTA-FARRAGUT_345_45					
Wed 11/23/2022	to	Sat 12/10/2022	<u>UPDATED by ConEd 10/05/2022 10:15</u>	SPR/DUN-SOUTH	3800 MW
0001	Continuous	0300		Impacts Total Transfer Capability	800 MW
Work scheduled by: ConEd				TTC with All Lines In Service	4600 MW
				FWD	REV
				(Import)	(Export)
HOMRC_NY-MAINS_NY_345_47					
Wed 11/23/2022	to	Wed 11/23/2022	<u>UPDATED by PJM 08/09/2022 11:26</u>	SCH - PJ - NY	
0800	Continuous	1600		Impacts Total Transfer Capability	
Work scheduled by: PJM				TTC with All Lines In Service	
				FWD	REV
				(Import)	(Export)
EASTVIEW-SPRNBK__345_W79					
Mon 11/28/2022	to	Mon 11/28/2022	<u>UPDATED by ConEd 09/07/2022 11:39</u>	UPNY CONED	4350 MW
0130	Continuous	0200		Impacts Total Transfer Capability	3465 MW
Work scheduled by: ConEd				TTC with All Lines In Service	7815 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, October 25, 2022 to Wednesday, April 24, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
BUCHAN_S-MILLWOOD_345_W98					
Tue 11/29/2022	to	Thu 12/01/2022			
0001	Continuous	0200	UPNY CONED	7680 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	135 MW	
			TTC with All Lines In Service	7815 MW	
MILLWOOD_345KV_18					
Tue 11/29/2022	to	Thu 12/01/2022			
0001	Continuous	0200	UPNY CONED	4350 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	3465 MW	
			TTC with All Lines In Service	7815 MW	
CRICKVLY-PLSNTVLY_345_F84					
Thu 12/01/2022	to	Fri 12/16/2022			
0001	Continuous	0200	SCH - NE - NY	600 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	1400 MW	
CRICKVLY-PLSNTVLY_345_F84					
Thu 12/01/2022	to	Fri 12/16/2022			
0001	Continuous	0200	SCH - NPX_1385	100 MW	100 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	100 MW	100 MW
			TTC with All Lines In Service	200 MW	200 MW

NYISO TRANSFER LIMITATIONS

Page 20 of 47
Number Of Records: 174
Report Run Date: 10/25/2022 17:19 (EPT)

Seasonal Limits

Tuesday, October 25, 2022 to Wednesday, April 24, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
MOSES___-ADIRNDCK_230_MA1					
Thu 12/01/2022	to	Wed 03/01/2023			
0701	Continuous	1100	UPDATED by NYPA 09/02/2022 14:08	MOSES SOUTH	2300 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	850 MW
				TTC with All Lines In Service	3150 MW
				FWD	REV
				(Import)	(Export)
MILLWOOD_345KV_18					
Fri 12/02/2022	to	Mon 12/12/2022			
0001	Continuous	1800		UPNY CONED	4350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	3465 MW
				TTC with All Lines In Service	7815 MW
				FWD	REV
				(Import)	(Export)
W49TH_ST-E13THSTA_345_M54					
Fri 12/02/2022	to	Fri 12/02/2022			
0001	Continuous	0030		SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
				FWD	REV
				(Import)	(Export)
W49TH_ST-E13THSTA_345_M54					
Sat 12/03/2022	to	Sat 12/03/2022			
0130	Continuous	0200		SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Page 21 of 47
Number Of Records: 174
Report Run Date: 10/25/2022 17:19 (EPT)

Seasonal Limits

Tuesday, October 25, 2022 to Wednesday, April 24, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
FRASER__-COOPERS__345_33					
Wed 12/07/2022	to	Wed 12/07/2022	CENTRAL EAST - VC	2335 MW	
0700	Continuous	1700	Impacts Total Transfer Capability	250 MW	
Work scheduled by: NYSEG				TTC with All Lines In Service	2585 MW
MARCY__345KV_CSC					
Wed 12/07/2022	to	Tue 12/20/2022	CENTRAL EAST - VC	2535 MW	
0700	Continuous	1530	Impacts Total Transfer Capability	50 MW	
Work scheduled by: NYPA				TTC with All Lines In Service	2585 MW
LAFAYTTE-CLRKSCRN_345_4-46					
Thu 12/08/2022	to	Sun 12/11/2022	CENTRAL EAST - VC	2450 MW	
0800	Continuous	1600	Impacts Total Transfer Capability	135 MW	
Work scheduled by: NGrid				TTC with All Lines In Service	2585 MW
PIERCBRK-FIVEMILE_345_37					
Thu 12/08/2022	to	Thu 12/08/2022	SCH - PJ - NY	2700 MW	
0800	Continuous	1600	Impacts Total Transfer Capability	150 MW	
Work scheduled by: PJM				TTC with All Lines In Service	2850 MW

NYISO TRANSFER LIMITATIONS

Page 22 of 47

Number Of Records: 174

Report Run Date: 10/25/2022 17:19 (EPT)

Seasonal Limits

Tuesday, October 25, 2022 to Wednesday, April 24, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
SPRNBK_-TREMONT__345_X28					
Fri 12/09/2022	to	Fri 12/09/2022			
0001	Continuous	0030	SPR/DUN-SOUTH	4200 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	400 MW	
			TTC with All Lines In Service	4600 MW	
SPRNBK_-TREMONT__345_X28					
Fri 12/09/2022	to	Fri 12/09/2022			
1730	Continuous	1800	SPR/DUN-SOUTH	4200 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	400 MW	
			TTC with All Lines In Service	4600 MW	
HOPATCON-RAMAPO__500_5018					
Mon 12/12/2022	to	Fri 12/16/2022			
0001	Continuous	2000	TOTAL EAST	5200 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	6000 MW	
HOPATCON-RAMAPO__500_5018					
Mon 12/12/2022	to	Fri 12/16/2022			
0001	Continuous	2000	SCH - PJ - NY	1650 MW	1200 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	1200 MW	1000 MW
			TTC with All Lines In Service	2850 MW	2200 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, October 25, 2022 to Wednesday, April 24, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
HOPATCON-RAMAPO__500_5018					
Mon 12/12/2022	to	Fri 12/16/2022	UPNY CONED	7480 MW	
0001	Continuous	2000	Impacts Total Transfer Capability	335 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	7815 MW
MARCY__345KV_CSC , HOPATCON-RAMAPO__500_5018					
Mon 12/12/2022	to	Fri 12/16/2022	TOTAL EAST	5100 MW	
0001		2000	Impacts Total Transfer Capability	900 MW	
Work scheduled by:				TTC with All Lines In Service	6000 MW
RAMAPO__345_345_PAR3500					
Mon 12/12/2022	to	Fri 12/16/2022	SCH - PJ - NY	2500 MW	1250 MW
0001	Continuous	2000	Impacts Total Transfer Capability	350 MW	950 MW
Work scheduled by: ConEd				TTC with All Lines In Service	2850 MW
					2200 MW
RAMAPO__345_345_PAR4500					
Mon 12/12/2022	to	Fri 12/16/2022	SCH - PJ - NY	2500 MW	1250 MW
0001	Continuous	2000	Impacts Total Transfer Capability	350 MW	950 MW
Work scheduled by: ConEd				TTC with All Lines In Service	2850 MW
					2200 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, October 25, 2022 to Wednesday, April 24, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
RAMAPO__500_345_BK 1500					
Mon 12/12/2022	to	Fri 12/16/2022		SCH - PJ - NY	1650 MW
0001	Continuous	2000		Impacts Total Transfer Capability	1200 MW
Work scheduled by: ConEd				TTC with All Lines In Service	2850 MW
					2200 MW
RAMAPO__500_345_BK 1500				FWD	REV
				(Import)	(Export)
Mon 12/12/2022	to	Fri 12/16/2022		UPNY CONED	7480 MW
0001	Continuous	2000		Impacts Total Transfer Capability	335 MW
Work scheduled by: ConEd				TTC with All Lines In Service	7815 MW
CRICKVLY-PLSNTVLY_345_F83				FWD	REV
				(Import)	(Export)
Fri 12/16/2022	to	Sun 01/01/2023	<u>EXTENDED by ConEd 09/22/2022 10:12</u>	SCH - NPX_1385	100 MW
0201	Continuous	0200		Impacts Total Transfer Capability	100 MW
Work scheduled by: ConEd				TTC with All Lines In Service	200 MW
					200 MW
CRICKVLY-PLSNTVLY_345_F83				FWD	REV
				(Import)	(Export)
Fri 12/16/2022	to	Sun 01/01/2023	<u>EXTENDED by ConEd 09/22/2022 10:12</u>	SCH - NE - NY	600 MW
0201	Continuous	0200		Impacts Total Transfer Capability	800 MW
Work scheduled by: ConEd				TTC with All Lines In Service	1400 MW

NYISO TRANSFER LIMITATIONS

Page 25 of 47
Number Of Records: 174
Report Run Date: 10/25/2022 17:19 (EPT)

Seasonal Limits

Tuesday, October 25, 2022 to Wednesday, April 24, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
FRASER__-COOPERS__345_33					
Mon 12/19/2022	to	Fri 12/23/2022		CENTRAL EAST - VC	2335 MW
0600	Continuous	1659		Impacts Total Transfer Capability	250 MW
Work scheduled by: NYSEG				TTC with All Lines In Service	2585 MW
HOMRC_NY-MAINS_NY_345_47				FWD	REV
				(Import)	(Export)
Thu 12/22/2022	to	Thu 12/22/2022		SCH - PJ - NY	
0800	Continuous	1600		Impacts Total Transfer Capability	
Work scheduled by: PJM				TTC with All Lines In Service	
W49TH_ST-E13THSTA_345_M54				FWD	REV
				(Import)	(Export)
Tue 12/27/2022	to	Tue 12/27/2022	<u>UPDATED by ConEd 10/05/2022 15:32</u>	SPR/DUN-SOUTH	3800 MW
0130	Continuous	0200		Impacts Total Transfer Capability	800 MW
Work scheduled by: ConEd				TTC with All Lines In Service	4600 MW
CLAY__-EDIC__345_1-16				FWD	REV
				(Import)	(Export)
Fri 12/30/2022	to	Sat 12/31/2022	<u>UPDATED by NGrid 07/05/2022 10:37</u>	OSWEGO EXPORT	4850 MW
0600	Continuous	1900		Impacts Total Transfer Capability	400 MW
Work scheduled by: NGrid				TTC with All Lines In Service	5250 MW

NYISO TRANSFER LIMITATIONS

Page 26 of 47
Number Of Records: 174
Report Run Date: 10/25/2022 17:19 (EPT)

Seasonal Limits

Tuesday, October 25, 2022 to Wednesday, April 24, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV	
				(Import)	(Export)	
FRASER__345_FRASER SVC				2550 MW		
Tue 01/03/2023	to	Tue 02/28/2023	UPDATED by NYPA 12/30/2021 15:43	Impacts Total Transfer Capability	35 MW	
0700	Continuous	1730		TTC with All Lines In Service	2585 MW	
Work scheduled by: NYPA						
NIAGARA_-PACKARD__230_62				900 MW	1850 MW	
Mon 01/09/2023	to	Fri 01/20/2023		Impacts Total Transfer Capability	150 MW	
0500	Continuous	1900		TTC with All Lines In Service	2000 MW	
Work scheduled by: NYPA						
E13THSTA-FARRAGUT_345_46				3800 MW		
Fri 01/27/2023	to	Wed 02/01/2023	UPDATED by ConEd 10/06/2022 11:35	Impacts Total Transfer Capability	800 MW	
0001	Continuous	0300		TTC with All Lines In Service	4600 MW	
Work scheduled by: ConEd						
E13THSTA-FARRAGUT_345_45				3800 MW		
Wed 02/08/2023	to	Wed 02/08/2023		Impacts Total Transfer Capability	800 MW	
0001	Continuous	0030		TTC with All Lines In Service	4600 MW	
Work scheduled by: ConEd						

NYISO TRANSFER LIMITATIONS

Page 27 of 47
Number Of Records: 174
Report Run Date: 10/25/2022 17:19 (EPT)

Seasonal Limits

Tuesday, October 25, 2022 to Wednesday, April 24, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
DUNWODIE_345KV_7					
Sun 02/19/2023	to	Mon 02/27/2023			
0001	Continuous	0200	SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	4600 MW	
DUNWODIE_345KV_8					
Sun 02/19/2023	to	Mon 02/27/2023			
0001	Continuous	0200	SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	4600 MW	
DUNWODIE-MOTTHAVN_345_72					
Sun 02/19/2023	to	Mon 02/27/2023			
0001	Continuous	0200	SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	4600 MW	
E13THSTA-FARRAGUT_345_45					
Wed 02/22/2023	to	Wed 02/22/2023			
0230	Continuous	0300	SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	4600 MW	

NYISO TRANSFER LIMITATIONS

Page 28 of 47
Number Of Records: 174
Report Run Date: 10/25/2022 17:19 (EPT)

Seasonal Limits

Tuesday, October 25, 2022 to Wednesday, April 24, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
EDIC___-FRASER___345_EF24-40					
Wed 03/01/2023	to	Sat 04/15/2023		CENTRAL EAST - VC	2275 MW
0600	Continuous	1800		Impacts Total Transfer Capability	310 MW
Work scheduled by: NGrid				TTC with All Lines In Service	2585 MW
GORDONRD-N.SCTLND_345_55					
Wed 03/01/2023	to	Fri 03/31/2023		CENTRAL EAST - VC	2045 MW
0700	Continuous	1600		Impacts Total Transfer Capability	540 MW
Work scheduled by: LS				TTC with All Lines In Service	2585 MW
MOSES___-ADIRNDCK_230_MA1					
Wed 03/01/2023	to	Fri 05/26/2023		MOSES SOUTH	2300 MW
1101	Continuous	1930		Impacts Total Transfer Capability	850 MW
Work scheduled by: NYPA				TTC with All Lines In Service	3150 MW
NIAGARA_-ROBNSNRD_230_64					
Mon 03/06/2023	to	Fri 03/17/2023		SCH - OH - NY	1900 MW
0500	Continuous	1900		Impacts Total Transfer Capability	100 MW
Work scheduled by: NYPA				TTC with All Lines In Service	2000 MW

NYISO TRANSFER LIMITATIONS

Page 29 of 47
Number Of Records: 174
Report Run Date: 10/25/2022 17:19 (EPT)

Seasonal Limits

Tuesday, October 25, 2022 to Wednesday, April 24, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
N.SCTLND-ALPS____345_2					
Mon 03/27/2023	to	Fri 05/19/2023			
0700	Continuous	1900	UPDATED by NGrid 07/05/2022 10:45	SCH - NE - NY	900 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	500 MW
				TTC with All Lines In Service	1400 MW
N.SCTLND-ALPS____345_2					
Mon 03/27/2023	to	Fri 05/19/2023			
0700	Continuous	1900	UPDATED by NGrid 07/05/2022 10:45	SCH - NPX_1385	100 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	100 MW
				TTC with All Lines In Service	200 MW
MOTTHAVN-RAINEY____345_Q12					
Wed 03/29/2023	to	Sun 04/30/2023			
0001	Continuous	0200	UPDATED by ConEd 09/05/2022 07:25	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
ATHENS__-PLSNTVLY_345_91					
Sat 04/01/2023	to	Sat 04/15/2023			
0700	Continuous	1900		UPNY CONED	3800 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	4015 MW
				TTC with All Lines In Service	7815 MW

NYISO TRANSFER LIMITATIONS

Page 30 of 47
Number Of Records: 174
Report Run Date: 10/25/2022 17:19 (EPT)

Seasonal Limits

Tuesday, October 25, 2022 to Wednesday, April 24, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
PLSNTVLY_345KV_RNS4					
Sat 04/01/2023	to	Sat 04/01/2023			
0700	Continuous	0730	UPNY CONED	3800 MW	
Work scheduled by: NGrid			Impacts Total Transfer Capability	4015 MW	
			TTC with All Lines In Service	7815 MW	
LINDN_CG-LNDVFT__345_V-3022				FWD	REV
				(Import)	(Export)
Sun 04/09/2023	to	Sat 04/15/2023			
1400	Continuous	1400	SCH - PJM_VFT	0 MW	0 MW
Work scheduled by: PJM			Impacts Total Transfer Capability	315 MW	315 MW
			TTC with All Lines In Service	315 MW	315 MW
DYSINGER-STA_255_345_DH1				FWD	REV
				(Import)	(Export)
Mon 04/10/2023	to	Fri 04/14/2023			
0500	Continuous	2000	DYSINGER EAST	2850 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	350 MW	
			TTC with All Lines In Service	3200 MW	
GORDONRD-N.SCTLND_345_55				FWD	REV
				(Import)	(Export)
Mon 04/10/2023	to	Fri 04/14/2023			
0600	Continuous	1700	CENTRAL EAST - VC	2045 MW	
Work scheduled by: NGrid			Impacts Total Transfer Capability	540 MW	
			TTC with All Lines In Service	2585 MW	

NYISO TRANSFER LIMITATIONS

Page 31 of 47

Number Of Records: 174

Report Run Date: 10/25/2022 17:19 (EPT)

Seasonal Limits

Tuesday, October 25, 2022 to Wednesday, April 24, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
DUNWODIE_345KV_3					
Wed 04/12/2023	to	Wed 04/12/2023			
0201	Continuous	0230	SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	4600 MW	
DUNWODIE_345KV_4					
Wed 04/12/2023	to	Wed 04/12/2023			
0201	Continuous	0230	SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	4600 MW	
PLSNTVLE-DUNWODIE_345_W89					
Wed 04/12/2023	to	Wed 04/12/2023			
0201	Continuous	0230	UPNY CONED	4000 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	3815 MW	
			TTC with All Lines In Service	7815 MW	
PLSNTVLY_345KV_RNS4					
Sat 04/15/2023	to	Sat 04/15/2023			
1830	Continuous	1900	UPNY CONED	3800 MW	
Work scheduled by: NGrid			Impacts Total Transfer Capability	4015 MW	
			TTC with All Lines In Service	7815 MW	

NYISO TRANSFER LIMITATIONS

Page 32 of 47

Number Of Records: 174

Report Run Date: 10/25/2022 17:19 (EPT)

Seasonal Limits

Tuesday, October 25, 2022 to Wednesday, April 24, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
LEEDS___-PLSNTVLY_345_92					
Sun 04/16/2023	to	Sun 04/30/2023			
0700	Continuous	1900	UPNY CONED	3800 MW	
Work scheduled by: NGrid			Impacts Total Transfer Capability	4015 MW	
			TTC with All Lines In Service	7815 MW	
				FWD	REV
				(Import)	(Export)
PLSNTVLY_345KV_RNS5					
Sun 04/16/2023	to	Sun 04/16/2023			
0700	Continuous	0730	UPNY CONED	3800 MW	
Work scheduled by: NGrid			Impacts Total Transfer Capability	4015 MW	
			TTC with All Lines In Service	7815 MW	
				FWD	REV
				(Import)	(Export)
E13THSTA-FARRAGUT_345_46					
Mon 04/17/2023	to	Wed 04/19/2023			
0001	Continuous	0200	SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	4600 MW	
				FWD	REV
				(Import)	(Export)
DYSINGER-STA_255__345_DH2					
Mon 04/17/2023	to	Fri 04/21/2023			
0500	Continuous	2000	DYSINGER EAST	2850 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	350 MW	
			TTC with All Lines In Service	3200 MW	

NYISO TRANSFER LIMITATIONS

Page 33 of 47
Number Of Records: 174
Report Run Date: 10/25/2022 17:19 (EPT)

Seasonal Limits

Tuesday, October 25, 2022 to Wednesday, April 24, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
CLAY___-EDIC___345_2-15					
Mon 04/17/2023	to	Fri 04/28/2023			
0600	Continuous	1800	OSWEGO EXPORT	4850 MW	
Work scheduled by: NGrid			Impacts Total Transfer Capability	400 MW	
			TTC with All Lines In Service	5250 MW	
				FWD	REV
				(Import)	(Export)
DUNWODIE_345KV_3					
Thu 04/20/2023	to	Thu 04/20/2023			
0130	Continuous	0200	SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	4600 MW	
				FWD	REV
				(Import)	(Export)
DUNWODIE_345KV_4					
Thu 04/20/2023	to	Thu 04/20/2023			
0130	Continuous	0200	SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	4600 MW	
				FWD	REV
				(Import)	(Export)
PLSNTVLE-DUNWODIE_345_W89					
Thu 04/20/2023	to	Thu 04/20/2023			
0130	Continuous	0200	UPNY CONED	4000 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	3815 MW	
			TTC with All Lines In Service	7815 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, October 25, 2022 to Wednesday, April 24, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
PANNELL_-CLAY____345_1					
Mon 04/24/2023	to	Fri 04/28/2023			
0700	Continuous	1530	WEST CENTRAL	1300 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	950 MW	
			TTC with All Lines In Service	2250 MW	
				FWD	REV
				(Import)	(Export)
PLSNTVLY_345KV_RNS5					
Sun 04/30/2023	to	Sun 04/30/2023			
1830	Continuous	1900	UPNY CONED	3800 MW	
Work scheduled by: NGrid			Impacts Total Transfer Capability	4015 MW	
			TTC with All Lines In Service	7815 MW	
				FWD	REV
				(Import)	(Export)
SHOR_NPX-SHOREHAM_138_CSC					
Mon 05/01/2023	to	Fri 05/05/2023			
0600	Continuous	1800	SCH - NPX_CSC	0 MW	0 MW
Work scheduled by: LI			Impacts Total Transfer Capability	330 MW	330 MW
			TTC with All Lines In Service	330 MW	330 MW
				FWD	REV
				(Import)	(Export)
PANNELL_-CLAY____345_2					
Mon 05/01/2023	to	Fri 05/05/2023			
0700	Continuous	1530	WEST CENTRAL	1300 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	950 MW	
			TTC with All Lines In Service	2250 MW	

NYISO TRANSFER LIMITATIONS

Page 35 of 47
Number Of Records: 174
Report Run Date: 10/25/2022 17:19 (EPT)

Seasonal Limits

Tuesday, October 25, 2022 to Wednesday, April 24, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
PLSNTVLY_345KV_RNS5					
Wed 05/03/2023	to	Mon 05/15/2023			
0001	Continuous	2200	UPNY CONED	3800 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	4015 MW	
			TTC with All Lines In Service	7815 MW	
PLSNTVLY-WOOD_ST_345_F30					
Wed 05/03/2023	to	Mon 05/15/2023			
0001	Continuous	2200	UPNY CONED	4000 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	3815 MW	
			TTC with All Lines In Service	7815 MW	
NIAGARA_-ROBNSNRD_230_64					
Fri 05/05/2023	to	Fri 05/05/2023			
0500	Continuous	1700	SCH - OH - NY		1400 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability		150 MW
			TTC with All Lines In Service		1550 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, October 25, 2022 to Wednesday, April 24, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
W49TH_ST_345KV_6					
Sat 05/06/2023	to	Sat 05/06/2023	SCH - PJM_HTP	300 MW	
0001	Continuous	0030	Impacts Total Transfer Capability	360 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	660 MW
W49TH_ST_345KV_8					
Sat 05/06/2023	to	Sat 05/06/2023	SCH - PJM_HTP	450 MW	
0001	Continuous	0030	Impacts Total Transfer Capability	210 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	660 MW
COOPERS_-DOLSONAV_345_CCDA42					
Mon 05/08/2023	to	Sun 05/21/2023	CENTRAL EAST - VC	2485 MW	
0700	Continuous	1530	Impacts Total Transfer Capability	100 MW	
Work scheduled by: NYPA				TTC with All Lines In Service	2585 MW

NYISO TRANSFER LIMITATIONS

Page 37 of 47

Number Of Records: 174

Report Run Date: 10/25/2022 17:19 (EPT)

Seasonal Limits

Tuesday, October 25, 2022 to Wednesday, April 24, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
DOLSONAV-ROCKTVRN_345_DART44					
Mon 05/08/2023	to	Sat 05/13/2023	CENTRAL EAST - VC	2485 MW	
0700	Continuous	1530	Impacts Total Transfer Capability	100 MW	
Work scheduled by: NYPA			TTC with All Lines In Service	2585 MW	
				FWD	REV
				(Import)	(Export)
W49TH_ST_345KV_6					
Sat 05/13/2023	to	Sat 05/13/2023	SCH - PJM_HTP	300 MW	
0130	Continuous	0200	Impacts Total Transfer Capability	360 MW	
Work scheduled by: ConEd			TTC with All Lines In Service	660 MW	
				FWD	REV
				(Import)	(Export)
W49TH_ST_345KV_8					
Sat 05/13/2023	to	Sat 05/13/2023	SCH - PJM_HTP	450 MW	
0130	Continuous	0200	Impacts Total Transfer Capability	210 MW	
Work scheduled by: ConEd			TTC with All Lines In Service	660 MW	
				FWD	REV
				(Import)	(Export)
W49TH_ST_345KV_6					
Mon 05/15/2023	to	Mon 05/15/2023	SCH - PJM_HTP	300 MW	
0001	Continuous	0030	Impacts Total Transfer Capability	360 MW	
Work scheduled by: ConEd			TTC with All Lines In Service	660 MW	

NYISO TRANSFER LIMITATIONS

Page 38 of 47
Number Of Records: 174
Report Run Date: 10/25/2022 17:19 (EPT)

Seasonal Limits

Tuesday, October 25, 2022 to Wednesday, April 24, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
W49TH_ST-E13THSTA_345_M55					
Mon 05/15/2023	to	Wed 05/17/2023			
0001	Continuous	0200	SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	4600 MW	
MOTTHAVN-RAINEY___345_Q11					
Wed 05/17/2023	to	Sat 05/20/2023			
0001	Continuous	0200	SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	4600 MW	
W49TH_ST_345KV_6					
Wed 05/17/2023	to	Wed 05/17/2023			
0130	Continuous	0200	SCH - PJM_HTP	300 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	360 MW	
			TTC with All Lines In Service	660 MW	

NYISO TRANSFER LIMITATIONS

Page 39 of 47
Number Of Records: 174
Report Run Date: 10/25/2022 17:19 (EPT)

Seasonal Limits

Tuesday, October 25, 2022 to Wednesday, April 24, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD (Import)	REV (Export)
BECK___-NIAGARA__230_PA27					
Tue 05/30/2023	to	Fri 06/02/2023			
0500	Continuous	2100	SCH - OH - NY		
Work scheduled by: NYPA			Impacts Total Transfer Capability		
			TTC with All Lines In Service		
NIAGARA__345_230_AT4					
Wed 06/28/2023	to	Thu 06/29/2023			
0500	Continuous	1900	SCH - OH - NY		1150 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability		400 MW
			TTC with All Lines In Service		1550 MW
NIAGARA__345_230_AT4					
Mon 08/21/2023	to	Fri 08/25/2023			
0500	Continuous	2100	SCH - OH - NY		1150 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability		400 MW
			TTC with All Lines In Service		1550 MW
ADIRNDCK-PORTER__230_12					
Tue 08/22/2023	to	Tue 08/22/2023			
0700	Continuous	1530	MOSES SOUTH	2100 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	1050 MW	
			TTC with All Lines In Service	3150 MW	

NYISO TRANSFER LIMITATIONS

Page 40 of 47
Number Of Records: 174
Report Run Date: 10/25/2022 17:19 (EPT)

Seasonal Limits

Tuesday, October 25, 2022 to Wednesday, April 24, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
ADIRNDCK-CHASLAKE_230_13					
Wed 08/23/2023	to	Wed 08/23/2023			
0700	Continuous	1530	MOSES SOUTH	2100 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	1050 MW	
			TTC with All Lines In Service	3150 MW	
CLAY___-EDIC___345_1-16				FWD	REV
				(Import)	(Export)
Mon 09/11/2023	to	Fri 09/15/2023			
0700	Continuous	1530	OSWEGO EXPORT	4850 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	400 MW	
			TTC with All Lines In Service	5250 MW	
FRASER___-GILBOA___345_GF5-35				FWD	REV
				(Import)	(Export)
Mon 09/11/2023	to	Sun 09/17/2023			
0700	Continuous	1530	CENTRAL EAST - VC	2450 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	135 MW	
			TTC with All Lines In Service	2585 MW	

NYISO TRANSFER LIMITATIONS

Page 41 of 47
Number Of Records: 174
Report Run Date: 10/25/2022 17:19 (EPT)

Seasonal Limits

Tuesday, October 25, 2022 to Wednesday, April 24, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
SPRNBK__345KV_RNS5					
Fri 09/15/2023	to	Mon 10/23/2023	<u>UPDATED by ConEd 08/10/2022 13:51</u>	SPR/DUN-SOUTH	3200 MW
0001	Continuous	0200		Impacts Total Transfer Capability	1400 MW
Work scheduled by: ConEd				TTC with All Lines In Service	4600 MW
SPRNBK_-W49TH_ST_345_M51					
Fri 09/15/2023	to	Mon 10/23/2023	<u>UPDATED by ConEd 08/10/2022 13:51</u>	SPR/DUN-SOUTH	3200 MW
0001	Continuous	0200		Impacts Total Transfer Capability	1400 MW
Work scheduled by: ConEd				TTC with All Lines In Service	4600 MW
CLAY___-EDIC___345_2-15					
Mon 09/18/2023	to	Fri 09/22/2023		OSWEGO EXPORT	4850 MW
0700	Continuous	1530		Impacts Total Transfer Capability	400 MW
Work scheduled by: NYPA				TTC with All Lines In Service	5250 MW

NYISO TRANSFER LIMITATIONS

Page 42 of 47
Number Of Records: 174
Report Run Date: 10/25/2022 17:19 (EPT)

Seasonal Limits

Tuesday, October 25, 2022 to Wednesday, April 24, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
NIAGARA_-DYSINGER_345_ND2					
Mon 09/25/2023	to	Fri 09/29/2023	DYSINGER EAST	2700 MW	
0500	Continuous	2000	Impacts Total Transfer Capability	500 MW	
Work scheduled by: NYPA				TTC with All Lines In Service	3200 MW
				FWD	REV
				(Import)	(Export)
MARCY____345KV_CSC					
Mon 09/25/2023	to	Sat 10/07/2023	CENTRAL EAST - VC	2535 MW	
0700	Continuous	1530	Impacts Total Transfer Capability	50 MW	
Work scheduled by: NYPA				TTC with All Lines In Service	2585 MW
				FWD	REV
				(Import)	(Export)
SHOR_NPX-SHOREHAM_138_CSC					
Mon 10/02/2023	to	Fri 10/06/2023	SCH - NPX_CSC	0 MW	0 MW
0600	Continuous	1800	Impacts Total Transfer Capability	330 MW	330 MW
Work scheduled by: LI				TTC with All Lines In Service	330 MW
				FWD	REV
				(Import)	(Export)
NEPTUNE_-DUFFYAVE_345_NEPTUNE					
Mon 10/09/2023	to	Fri 10/13/2023	SCH - PJM_NEPTUNE	0 MW	
0600	Continuous	1600	Impacts Total Transfer Capability	660 MW	
Work scheduled by: LI				TTC with All Lines In Service	660 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits			Tuesday, October 25, 2022 to Wednesday, April 24, 2024		FWD	REV
NEWBRIDGE_345_138_BK_1					(Import)	(Export)
Mon 10/09/2023	to	Fri 10/13/2023		SCH - PJM_NEPTUNE	375 MW	
0600	Continuous	1600		Impacts Total Transfer Capability	285 MW	
CENTRAL EAST				TTC with All Lines In Service	660 MW	
2650 MW						
CENTRAL EAST - VC						REV
2585 MW						(Export)
TOTAL EAST						
6000 MW						
UPNY CONED						
NEWBRIDGE_345_138_BK_2						
SPR/DUN-SOUTH						
4600 MW						
Mon 10/09/2023	to	Fri 10/13/2023		SCH - PJM_NEPTUNE	375 MW	
DYSINGER EAST				Impacts Total Transfer Capability	285 MW	
0600	Continuous	1600		TTC with All Lines In Service	660 MW	
MOSES SOUTH						
3150 MW						
Work scheduled by: LI						
NEWBRIDGE-DUFFYAVE_345_501					(Import)	(Export)
Mon 10/09/2023	to	Fri 10/13/2023		SCH - PJM_NEPTUNE	0 MW	
0600	Continuous	1600		Impacts Total Transfer Capability	660 MW	
Work scheduled by: LI				TTC with All Lines In Service	660 MW	
GILBOA__N.SCTLND_345_GNS-1					FWD	REV
Mon 10/09/2023	to	Fri 10/13/2023			(Import)	(Export)
0700	Continuous	1530		CENTRAL EAST - VC	2300 MW	
Work scheduled by: NYPA				Impacts Total Transfer Capability	285 MW	
				TTC with All Lines In Service	2585 MW	
NIAGARA_-PACKARD_230_61					FWD	REV
Fri 10/13/2023	to	Fri 10/13/2023			(Import)	(Export)
0500	Continuous	1900		SCH - OH - NY	1350 MW	
Work scheduled by: NYPA				Impacts Total Transfer Capability	200 MW	
				TTC with All Lines In Service	1550 MW	
HURLYAVE-ROSETON_345_303					FWD	REV
Mon 11/13/2023	to	Fri 12/22/2023			(Import)	(Export)
0800	Continuous	1600		UPNY CONED	4100 MW	
Work scheduled by: CHGE				Impacts Total Transfer Capability	3715 MW	
				TTC with All Lines In Service	7815 MW	

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, October 25, 2022 to Wednesday, April 24, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
CHATGUAY-MASSENA__765_7040					
Wed 11/15/2023	to	Mon 11/27/2023		SCH - HQ - NY	
0700	Continuous	1730		0 MW	0 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	1500 MW
				TTC with All Lines In Service	1000 MW
CHATGUAY-MASSENA__765_7040				FWD	REV
				(Import)	(Export)
Wed 11/15/2023	to	Mon 11/27/2023		MOSES SOUTH	
0700	Continuous	1730		1550 MW	
Work scheduled by: NYPA				Impacts Total Transfer Capability	1600 MW
				TTC with All Lines In Service	3150 MW
CHATGUAY-MASSENA__765_7040 , MASSENA_-MARCY__765_MSU1				FWD	REV
				(Import)	(Export)
Wed 11/15/2023	to	Mon 11/27/2023		MOSES SOUTH	
0700		1730		500 MW	
Work scheduled by:				Impacts Total Transfer Capability	2650 MW
				TTC with All Lines In Service	3150 MW
MASSENA_-MARCY__765_MSU1				FWD	REV
				(Import)	(Export)
Wed 11/15/2023	to	Mon 11/27/2023		CENTRAL EAST - VC	
0700	Continuous	1730		1720 MW	
Work scheduled by: NYPA				Impacts Total Transfer Capability	865 MW
				TTC with All Lines In Service	2585 MW

NYISO TRANSFER LIMITATIONS

Page 45 of 47

Number Of Records: 174

Report Run Date: 10/25/2022 17:19 (EPT)

Seasonal Limits

Tuesday, October 25, 2022 to Wednesday, April 24, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
MASSENA_-MARCY___765_MSU1					
Wed 11/15/2023	to	Mon 11/27/2023	SCH - HQ_CEDARS	90 MW	
0700	Continuous	1730	Impacts Total Transfer Capability	189 MW	
Work scheduled by: NYPA				TTC with All Lines In Service	279 MW
MASSENA_-MARCY___765_MSU1					
Wed 11/15/2023	to	Mon 11/27/2023	SCH - HQ - NY	475 MW	1000 MW
0700	Continuous	1730	Impacts Total Transfer Capability	1025 MW	0 MW
Work scheduled by: NYPA				TTC with All Lines In Service	1500 MW
MASSENA_-MARCY___765_MSU1					
Wed 11/15/2023	to	Mon 11/27/2023	MOSES SOUTH	500 MW	
0700	Continuous	1730	Impacts Total Transfer Capability	2650 MW	
Work scheduled by: NYPA				TTC with All Lines In Service	3150 MW
MOSES___-MASSENA__230_MMS1 , MOSES___-MASSENA__230_MMS2					
Wed 11/15/2023	to	Mon 11/20/2023	SCH - HQ_CEDARS	90 MW	
0700		1530	Impacts Total Transfer Capability	189 MW	
Work scheduled by:				TTC with All Lines In Service	279 MW

NYISO TRANSFER LIMITATIONS

Page 46 of 47
Number Of Records: 174
Report Run Date: 10/25/2022 17:19 (EPT)

Seasonal Limits

Tuesday, October 25, 2022 to Wednesday, April 24, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES__-MASSENA_230_MMS1 , MOSES__-
MASSENA_230_MMS2

Wed 11/15/2023 to Mon 11/20/2023
0700 1530

Work scheduled by:

SCH - HQ - NY

Impacts Total Transfer
Capability

TTC with All Lines In Service

FWD REV
(Import) (Export)

850 MW 0 MW

650 MW 1000 MW

1500 MW 1000 MW

NIAGARA_345_230_AT4

Mon 11/27/2023 to Fri 12/01/2023
0500 Continuous 1900

Work scheduled by: NYPA

SCH - OH - NY

Impacts Total Transfer
Capability

TTC with All Lines In Service

FWD REV
(Import) (Export)

1750 MW

250 MW

2000 MW

HOMR_NYW-PIERC_NY_345_48

Fri 12/08/2023 to Fri 12/15/2023
0800 Continuous 1600

Work scheduled by: PJM

UPDATED by PJM 07/28/2022 14:08

SCH - PJ - NY

Impacts Total Transfer
Capability

TTC with All Lines In Service

FWD REV
(Import) (Export)

HOMRC_NY-MAINS_NY_345_47

Fri 12/08/2023 to Fri 12/15/2023
0800 Continuous 1600

Work scheduled by: PJM

UPDATED by PJM 07/28/2022 14:08

SCH - PJ - NY

Impacts Total Transfer
Capability

TTC with All Lines In Service

FWD REV
(Import) (Export)

Report Run Date: 10/25/2022 17:19 (EPT)

Seasonal Limits			Tuesday, October 25, 2022 to Wednesday, April 24, 2024		FWD	REV
W40TH_ST_245KV_6					(Import)	(Export)
Mon 01/08/2024	to	Mon 02/19/2024	SCH - PJM_HTP		310 MW	
0001	Continuous	0201	Impacts Total Transfer Capability		350 MW	
CENTRAL EAST	Scheduled by: ConEd		TTC with All Lines In Service		660 MW	
CENTRAL EAST - VC	2585 MW					
-----TOTAL EAST-----						
UPNY CONED	7815 MW					REV
W49TH_ST-13THSTA	345 M55					(Import)
SPR/DUN-SOUTH	4600 MW		SR/DAMS OVER		880 MW	
Mon 01/08/2024	to	Mon 02/19/2024	Imports/Exports		800 MW	
DYSINGER EAST	3200 MW		Capacity			
0001	Continuous	0201	TTC with All Lines In Service		4600 MW	
Work scheduled by: ConEd						

W49TH_ST_345KV_8					(Import)	(Export)
Sat 02/03/2024	to	Mon 02/19/2024	SCH - PJM_HTP		310 MW	
0001	Continuous	0201	Impacts Total Transfer Capability		350 MW	
Work scheduled by: ConEd			TTC with All Lines In Service		660 MW	