

NYISO TRANSFER LIMITATIONS

Page 1 of 50
Number Of Records: 179
Report Run Date: 10/18/2022 19:51 (EPT)

Seasonal Limits

Tuesday, October 18, 2022 to Wednesday, April 17, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV	
HUDSONP_-FARRAGUT_345_B3402				(Import)	(Export)	
Mon 01/15/2018	to	Tue 01/31/2023	<u>EXT FORCED by ConEd 08/06/2022 16:26</u>	2050 MW		
0001	Continuous	2359		Impacts Total Transfer Capability	200 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	2250 MW	
MARION__-FARRAGUT_345_C3403				FWD	REV	
				(Import)	(Export)	
Mon 01/15/2018	to	Tue 01/31/2023	<u>EXT FORCED by ConEd 08/06/2022 16:26</u>	2050 MW		
0001	Continuous	2359		Impacts Total Transfer Capability	200 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	2250 MW	
MARION__-FARRAGUT_345_C3403 , HUDSONP_-FARRAGUT_345_B3402				FWD	REV	
				(Import)	(Export)	
Mon 01/15/2018	to	Tue 01/31/2023		2000 MW	1150 MW	
0001		2359		Impacts Total Transfer Capability	250 MW	50 MW
Work scheduled by:				TTC with All Lines In Service	2250 MW	1200 MW

NYISO TRANSFER LIMITATIONS

Page 2 of 50
Number Of Records: 179
Report Run Date: 10/18/2022 19:51 (EPT)

Seasonal Limits

Tuesday, October 18, 2022 to Wednesday, April 17, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
SCH-IMO-NYISO_LIMIT_1400					
Wed 08/10/2022	to	Mon 11/21/2022	<u>EXTENDED by IESO 08/19/2022 14:10</u>		
0800	Continuous	1600			
Work scheduled by: IESO					
				FWD	REV
				(Import)	(Export)
BECK____-NIAGARA_230_PA27					
Wed 08/24/2022	to	Fri 10/28/2022	<u>EXTENDED by IESO 09/26/2022 15:45</u>		
0800	Continuous	1700			
Work scheduled by: IESO					
				FWD	REV
				(Import)	(Export)
SCH-HQ_CEDARS-NYISO_LIMIT_240					
Tue 09/06/2022	to	Fri 10/28/2022	<u>EXTENDED by HQ 09/27/2022 13:12</u>		
0500	Continuous	1900			
Work scheduled by: HQ					
				FWD	REV
				(Import)	(Export)
SCH-NYISO-HQ_CEDARS_LIMIT_0					
Tue 09/06/2022	to	Fri 10/28/2022	<u>EXTENDED by HQ 09/27/2022 13:12</u>		
0500	Continuous	1900			
Work scheduled by: HQ					
				FWD	REV
				(Import)	(Export)
SCH-IMO-NYISO_LIMIT_1400					
Wed 08/10/2022	to	Mon 11/21/2022	<u>EXTENDED by IESO 08/19/2022 14:10</u>		
0800	Continuous	1600			
Work scheduled by: IESO					
				FWD	REV
				(Import)	(Export)
BECK____-NIAGARA_230_PA27					
Wed 08/24/2022	to	Fri 10/28/2022	<u>EXTENDED by IESO 09/26/2022 15:45</u>		
0800	Continuous	1700			
Work scheduled by: IESO					
				FWD	REV
				(Import)	(Export)
SCH-HQ_CEDARS-NYISO_LIMIT_240					
Tue 09/06/2022	to	Fri 10/28/2022	<u>EXTENDED by HQ 09/27/2022 13:12</u>		
0500	Continuous	1900			
Work scheduled by: HQ					
				FWD	REV
				(Import)	(Export)
SCH-NYISO-HQ_CEDARS_LIMIT_0					
Tue 09/06/2022	to	Fri 10/28/2022	<u>EXTENDED by HQ 09/27/2022 13:12</u>		
0500	Continuous	1900			
Work scheduled by: HQ					
				FWD	REV
				(Import)	(Export)
SCH-IMO-NYISO_LIMIT_1400					
Wed 08/10/2022	to	Mon 11/21/2022	<u>EXTENDED by IESO 08/19/2022 14:10</u>		
0800	Continuous	1600			
Work scheduled by: IESO					
				FWD	REV
				(Import)	(Export)
BECK____-NIAGARA_230_PA27					
Wed 08/24/2022	to	Fri 10/28/2022	<u>EXTENDED by IESO 09/26/2022 15:45</u>		
0800	Continuous	1700			
Work scheduled by: IESO					
				FWD	REV
				(Import)	(Export)
SCH-HQ_CEDARS-NYISO_LIMIT_240					
Tue 09/06/2022	to	Fri 10/28/2022	<u>EXTENDED by HQ 09/27/2022 13:12</u>		
0500	Continuous	1900			
Work scheduled by: HQ					
				FWD	REV
				(Import)	(Export)
SCH-NYISO-HQ_CEDARS_LIMIT_0					
Tue 09/06/2022	to	Fri 10/28/2022	<u>EXTENDED by HQ 09/27/2022 13:12</u>		
0500	Continuous	1900			
Work scheduled by: HQ					
				FWD	REV
				(Import)	(Export)
SCH-IMO-NYISO_LIMIT_1400					
Wed 08/10/2022	to	Mon 11/21/2022	<u>EXTENDED by IESO 08/19/2022 14:10</u>		
0800	Continuous	1600			
Work scheduled by: IESO					
				FWD	REV
				(Import)	(Export)
BECK____-NIAGARA_230_PA27					
Wed 08/24/2022	to	Fri 10/28/2022	<u>EXTENDED by IESO 09/26/2022 15:45</u>		
0800	Continuous	1700			
Work scheduled by: IESO					
				FWD	REV
				(Import)	(Export)
SCH-HQ_CEDARS-NYISO_LIMIT_240					
Tue 09/06/2022	to	Fri 10/28/2022	<u>EXTENDED by HQ 09/27/2022 13:12</u>		
0500	Continuous	1900			
Work scheduled by: HQ					
				FWD	REV
				(Import)	(Export)
SCH-NYISO-HQ_CEDARS_LIMIT_0					
Tue 09/06/2022	to	Fri 10/28/2022	<u>EXTENDED by HQ 09/27/2022 13:12</u>		
0500	Continuous	1900			
Work scheduled by: HQ					
				FWD	REV
				(Import)	(Export)
SCH-IMO-NYISO_LIMIT_1400					
Wed 08/10/2022	to	Mon 11/21/2022	<u>EXTENDED by IESO 08/19/2022 14:10</u>		
0800	Continuous	1600			
Work scheduled by: IESO					
				FWD	REV
				(Import)	(Export)
BECK____-NIAGARA_230_PA27					
Wed 08/24/2022	to	Fri 10/28/2022	<u>EXTENDED by IESO 09/26/2022 15:45</u>		
0800	Continuous	1700			
Work scheduled by: IESO					
				FWD	REV
				(Import)	(Export)
SCH-HQ_CEDARS-NYISO_LIMIT_240					
Tue 09/06/2022	to	Fri 10/28/2022	<u>EXTENDED by HQ 09/27/2022 13:12</u>		
0500	Continuous	1900			
Work scheduled by: HQ					
				FWD	REV
				(Import)	(Export)
SCH-NYISO-HQ_CEDARS_LIMIT_0					
Tue 09/06/2022	to	Fri 10/28/2022	<u>EXTENDED by HQ 09/27/2022 13:12</u>		
0500	Continuous	1900			
Work scheduled by: HQ					
				FWD	REV
				(Import)	(Export)
SCH-IMO-NYISO_LIMIT_1400					
Wed 08/10/2022	to	Mon 11/21/2022	<u>EXTENDED by IESO 08/19/2022 14:10</u>		
0800	Continuous	1600			
Work scheduled by: IESO					
				FWD	REV
				(Import)	(Export)
BECK____-NIAGARA_230_PA27					
Wed 08/24/2022	to	Fri 10/28/2022	<u>EXTENDED by IESO 09/26/2022 15:45</u>		
0800	Continuous	1700			
Work scheduled by: IESO					
				FWD	REV
				(Import)	(Export)
SCH-HQ_CEDARS-NYISO_LIMIT_240					
Tue 09/06/2022	to	Fri 10/28/2022	<u>EXTENDED by HQ 09/27/2022 13:12</u>		
0500	Continuous	1900			
Work scheduled by: HQ					
				FWD	REV
				(Import)	(Export)
SCH-NYISO-HQ_CEDARS_LIMIT_0					
Tue 09/06/2022	to	Fri 10/28/2022	<u>EXTENDED by HQ 09/27/2022 13:12</u>		
0500	Continuous	1900			
Work scheduled by: HQ					
				FWD	REV
				(Import)	(Export)
SCH-IMO-NYISO_LIMIT_1400					
Wed 08/10/2022	to	Mon 11/21/2022	<u>EXTENDED by IESO 08/19/2022 14:10</u>		
0800	Continuous	1600			
Work scheduled by: IESO					
				FWD	REV
				(Import)	(Export)
BECK____-NIAGARA_230_PA27					
Wed 08/24/2022	to	Fri 10/28/2022	<u>EXTENDED by IESO 09/26/2022 15:45</u>		
0800	Continuous	1700			
Work scheduled by: IESO					
				FWD	REV
				(Import)	(Export)
SCH-HQ_CEDARS-NYISO_LIMIT_240					
Tue 09/06/2022	to	Fri 10/28/2022	<u>EXTENDED by HQ 09/27/2022 13:12</u>		
0500	Continuous	1900			
Work scheduled by: HQ					
				FWD	REV
				(Import)	(Export)
SCH-NYISO-HQ_CEDARS_LIMIT_0					
Tue 09/06/2022	to	Fri 10/28/2022	<u>EXTENDED by HQ 09/27/2022 13:12</u>		
0500	Continuous	1900			
Work scheduled by: HQ					
				FWD	REV
				(Import)	(Export)
SCH-IMO-NYISO_LIMIT_1400					
Wed 08/10/2022	to	Mon 11/21/2022	<u>EXTENDED by IESO 08/19/2022 14:10</u>		
0800	Continuous	1600			
Work scheduled by: IESO					
				FWD	REV
				(Import)	(Export)
BECK____-NIAGARA_230_PA27					
Wed 08/24/2022	to	Fri 10/28/2022	<u>EXTENDED by IESO 09/26/2022 15:45</u>		
0800	Continuous	1700			
Work scheduled by: IESO					
				FWD	REV
				(Import)	(Export)
SCH-HQ_CEDARS-NYISO_LIMIT_240					
Tue 09/06/2022	to	Fri 10/28/2022	<u>EXTENDED by HQ 09/27/2022 13:12</u>		
0500	Continuous	1900			
Work scheduled by: HQ					
				FWD	REV
				(Import)	(Export)
SCH-NYISO-HQ_CEDARS_LIMIT_0					
Tue 09/06/2022	to	Fri 10/28/2022	<u>EXTENDED by HQ 09/27/2022 13:12</u>		
0500	Continuous	1900			
Work scheduled by: HQ					
				FWD	REV
				(Import)	(Export)
SCH-IMO-NYISO_LIMIT_1400					
Wed 08/10/2022	to	Mon 11/21/2022	<u>EXTENDED by IESO 08/19/2022 14:10</u>		
0800	Continuous	1600			
Work scheduled by: IESO					
				FWD	REV
				(Import)	(Export)
BECK____-NIAGARA_230_PA27					
Wed 08/24/2022	to	Fri 10/28/2022	<u>EXTENDED by IESO 09/26/2022 15:45</u>		
0800	Continuous	1700			
Work scheduled by: IESO					
				FWD	REV
				(Import)	(Export)
SCH-HQ_CEDARS-NYISO_LIMIT_240					
Tue 09/06/2022	to	Fri 10/28/2022	<u>EXTENDED by HQ 09/27/2022 13:12</u>		
0500	Continuous	1900			
Work scheduled by: HQ					
				FWD	REV
				(Import)	(Export)
SCH-NYISO-HQ_CEDARS_LIMIT_0					
Tue 09/06/2022	to	Fri 10/28/2022	<u>EXTENDED by HQ 09/27/2022 13:12</u>		
0500	Continuous	1900			
Work scheduled by: HQ					
				FWD	REV
				(Import)	(Export)
SCH-IMO-NYISO_LIMIT_1400					
Wed 08/10/2022	to	Mon 11/21/2022	<u>EXTENDED by IESO 08/19/2022 14:10</u>		
0800	Continuous	1600			
Work scheduled by: IESO					
				FWD	REV
				(Import)	(Export)
BECK____-NIAGARA_230_PA27					
Wed 08/24/2022	to	Fri 10/28/2022	<u>EXTENDED by IESO 09/26/2022 15:45</u>		
0800	Continuous	1700			
Work scheduled by: IESO					
				FWD	REV
				(Import)	(Export)
SCH-HQ_CEDARS-NYISO_LIMIT_240					
Tue 09/06/2022	to	Fri 10/28/2022	<u>EXTENDED by HQ 09/27/2022 13:12</u>		
0500	Continuous	1900			
Work scheduled by: HQ					
				FWD	REV
				(Import)	(Export)
SCH-NYISO-HQ_CEDARS_LIMIT_0					
Tue 09/06/2022	to	Fri 10/28/2022	<u>EXTENDED by HQ 09/27/2022 13:12</u>		
0500	Continuous	1900			
Work scheduled by: HQ					
				FWD	REV
				(Import)	(Export)
SCH-IMO-NYISO_LIMIT_1400					
Wed 08/10/2022	to	Mon 11/21/2022	<u>EXTENDED by IESO 08/19/2022 14:10</u>		
0800	Continuous	1600			
Work scheduled by: IESO					
				FWD	REV
				(Import)	(Export)
BECK____-NIAGARA_230_PA27					
Wed 08/24/2022	to	Fri 10/28/2022	<u>EXTENDED by IESO 09/26/2022 15:45</u>		
0800	Continuous	1700			
Work scheduled by: IESO					
				FWD	REV
				(Import)	(Export)
SCH-HQ_CEDARS-NYISO_LIMIT_240					
Tue 09/06/2022	to	Fri 10/28/2022	<u>EXTENDED by HQ 09/27/2022 13:12</u>		

NYISO TRANSFER LIMITATIONS

Page 3 of 50
Number Of Records: 179
Report Run Date: 10/18/2022 19:51 (EPT)

Seasonal Limits

Tuesday, October 18, 2022 to Wednesday, April 17, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
MOSES___-ADIRNDCK_230_MA2					
Tue 09/06/2022	to	Thu 12/01/2022			
1200	Continuous	0659	UPDATED by NYPA 09/06/2022 15:41	MOSES SOUTH	2100 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	1050 MW
				TTC with All Lines In Service	3150 MW
HURLYAVE-ROSETON_345_303					
Mon 09/19/2022	to	Fri 12/02/2022			
0800	Continuous	1600	UPDATED by CHGE 10/04/2022 09:16	UPNY CONED	4100 MW
Work scheduled by: CHGE				Impacts Total Transfer Capability	3715 MW
				TTC with All Lines In Service	7815 MW
LEEDS___-HURLYAVE_345_301					
Mon 09/19/2022	to	Fri 12/02/2022			
0800	Continuous	1600	10/04/2021 10:51	UPNY CONED	4100 MW
Work scheduled by: CHGE				Impacts Total Transfer Capability	3715 MW
				TTC with All Lines In Service	7815 MW
EGRDNCTY_345_138_AT1					
Sat 10/01/2022	to	Wed 05/31/2023			
0001	Continuous	2359	UPDATED by ConEd 10/01/2022 09:02	CONED - LIPA	1250 MW
Work scheduled by: LI				Impacts Total Transfer Capability	250 MW
				TTC with All Lines In Service	1500 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, October 18, 2022 to Wednesday, April 17, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

					FWD	REV
					(Import)	(Export)
EGRDNCTY_345_138_AT2						
Sat 10/01/2022	to	Wed 05/31/2023	<u>UPDATED by ConEd 10/01/2022 09:02</u>	CONED - LIPA	1250 MW	
0001	Continuous	2359		Impacts Total Transfer Capability	250 MW	
Work scheduled by: LI				TTC with All Lines In Service	1500 MW	
					FWD	REV
					(Import)	(Export)
SPRNBK_-EGRDNCTR_345_Y49						
Sat 10/01/2022	to	Wed 05/31/2023	<u>UPDATED by ConEd 10/01/2022 09:02</u>	CONED - LIPA	775 MW	
0001	Continuous	2359		Impacts Total Transfer Capability	725 MW	
Work scheduled by: LI				TTC with All Lines In Service	1500 MW	
					FWD	REV
					(Import)	(Export)
SHOR_NPX-SHOREHAM_138_CSC						
Mon 10/03/2022	to	Fri 10/21/2022	<u>09/28/2022 15:42</u>	SCH - NPX_CSC	0 MW	0 MW
0700	Continuous	1500		Impacts Total Transfer Capability	330 MW	330 MW
Work scheduled by: LI				TTC with All Lines In Service	330 MW	330 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, October 18, 2022 to Wednesday, April 17, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD (Import)	REV (Export)	
<hr/>						
STLAWRNC-MOSES___230_L34P						
Mon 10/03/2022	to	Mon 09/25/2023	<u>UPDATED by IESO 10/04/2022 16:51</u>			
1800	Continuous	0800				
Work scheduled by: IESO						
				SCH - OH - NY		
				Impacts Total Transfer Capability		
				TTC with All Lines In Service		
<hr/>						
DUNWODIE-MOTTHAVN_345_71				FWD (Import)	REV (Export)	
Thu 10/06/2022	to	Thu 11/10/2022	<u>UPDATED by ConEd 08/16/2022 09:29</u>			
0001	Continuous	0300				
Work scheduled by: ConEd						
				SPR/DUN-SOUTH	3800 MW	
				Impacts Total Transfer Capability	800 MW	
				TTC with All Lines In Service	4600 MW	
<hr/>						
CHAT_DC_GC1				FWD (Import)	REV (Export)	
Sun 10/09/2022	to	Sun 11/06/2022				
0400	Continuous	2200				
Work scheduled by: HQ						
				MOSES SOUTH	2850 MW	
				Impacts Total Transfer Capability	300 MW	
				TTC with All Lines In Service	3150 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, October 18, 2022 to Wednesday, April 17, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
CHAT_DC_GC1					
Sun 10/09/2022	to	Sun 11/06/2022		SCH - HQ - NY	500 MW
0400	Continuous	2200		Impacts Total Transfer Capability	500 MW
Work scheduled by: HQ				TTC with All Lines In Service	1000 MW
SCH-NYISO-HQ_LIMIT_500					
Sun 10/09/2022	to	Sun 11/06/2022		SCH - HQ - NY	500 MW
0400	Continuous	2200		Impacts Total Transfer Capability	500 MW
Work scheduled by: HQ				TTC with All Lines In Service	1000 MW
EDIC____-GORDONRD_345_14					
Mon 10/10/2022	to	Mon 10/31/2022		CENTRAL EAST - VC	1670 MW
0700	Continuous	1530		Impacts Total Transfer Capability	915 MW
Work scheduled by: NYPA				TTC with All Lines In Service	2585 MW

UPDATED by NYPA 06/30/2022 15:45

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, October 18, 2022 to Wednesday, April 17, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
CHAT_DC_GC2					
Mon 10/17/2022	to	Mon 10/24/2022	MOSES SOUTH	2850 MW	
0100	Continuous	1800	Impacts Total Transfer Capability	300 MW	
Work scheduled by: HQ				TTC with All Lines In Service	3150 MW
				FWD	REV
				(Import)	(Export)
CHAT_DC_GC2					
Mon 10/17/2022	to	Mon 10/24/2022	SCH - HQ - NY		500 MW
0100	Continuous	1800	Impacts Total Transfer Capability		500 MW
Work scheduled by: HQ				TTC with All Lines In Service	1000 MW
				FWD	REV
				(Import)	(Export)
CHAT_DC_GC2 , CHAT_DC_GC1					
Mon 10/17/2022	to	Mon 10/24/2022	MOSES SOUTH	2550 MW	
0100		1800	Impacts Total Transfer Capability	600 MW	
Work scheduled by:				TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, October 18, 2022 to Wednesday, April 17, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
CHAT_DC_GC2 , CHAT_DC_GC1					
Mon 10/17/2022	to	Mon 10/24/2022		SCH - HQ - NY	
0100		1800		1370 MW	0 MW
Work scheduled by:				Impacts Total Transfer Capability	1000 MW
				TTC with All Lines In Service	1000 MW
CHATGUAY-MASSENA__765_7040				FWD	REV
				(Import)	(Export)
Mon 10/17/2022	to	Mon 10/24/2022		SCH - HQ - NY	
0100	Continuous	1800		0 MW	0 MW
Work scheduled by: HQ				Impacts Total Transfer Capability	1000 MW
				TTC with All Lines In Service	1000 MW
CHATGUAY-MASSENA__765_7040				FWD	REV
				(Import)	(Export)
Mon 10/17/2022	to	Mon 10/24/2022		MOSES SOUTH	
0100	Continuous	1800		1550 MW	
Work scheduled by: HQ				Impacts Total Transfer Capability	1600 MW
				TTC with All Lines In Service	3150 MW
NIAGARA_-DYSINGER_345_ND1				FWD	REV
				(Import)	(Export)
Mon 10/17/2022	to	Fri 10/21/2022		DYSINGER EAST	
0500	Continuous	1700		2700 MW	
Work scheduled by: NYPA				Impacts Total Transfer Capability	500 MW
				TTC with All Lines In Service	3200 MW

UPDATED by NYPA 09/30/2022 09:24

NYISO TRANSFER LIMITATIONS

Page 9 of 50
Number Of Records: 179
Report Run Date: 10/18/2022 19:51 (EPT)

Seasonal Limits

Tuesday, October 18, 2022 to Wednesday, April 17, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
W49TH_ST-E13THSTA_345_M55				3800 MW	
Tue 10/18/2022	to	Wed 10/19/2022			
0003	Continuous	2359	<u>FORCED by ConEd 10/18/2022 16:12</u>		
Work scheduled by: ConEd					
				SPR/DUN-SOUTH	
				Impacts Total Transfer	800 MW
				Capability	
				TTC with All Lines In Service	4600 MW
FROST_BR-LONG_MTN_345_352				1150 MW	
Tue 10/18/2022	to	Wed 10/19/2022			
0600	Continuous	1800	<u>CANCELLED by TO 10/17/2022 14:04</u>		
Work scheduled by: ISONE					
				SCH - NE - NY	
				Impacts Total Transfer	250 MW
				Capability	
				TTC with All Lines In Service	1400 MW
SCH-NE-NYISO_LIMIT_500				700 MW	
Tue 10/18/2022	to	Wed 10/19/2022			
0600	Continuous	1800	<u>CANCELLED by TO 10/17/2022 14:04</u>		
Work scheduled by: ISONE					
				SCH - NE - NY	
				Impacts Total Transfer	700 MW
				Capability	
				TTC with All Lines In Service	1400 MW
FIVEMILE-ESTOLERD_345_29					
Tue 10/18/2022	to	Tue 10/18/2022			
0730	Daily(No Weekends)	1230			
Work scheduled by: NGrid					
				SCH - PJ - NY	
				Impacts Total Transfer	
				Capability	
				TTC with All Lines In Service	

NYISO TRANSFER LIMITATIONS

Page 10 of 50

Number Of Records: 179

Report Run Date: 10/18/2022 19:51 (EPT)

Seasonal Limits

Tuesday, October 18, 2022 to Wednesday, April 17, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
FRASANNX-COOPERS__345_UCC2-41					
Tue 10/18/2022	to	Wed 10/19/2022		CENTRAL EAST - VC	2275 MW
0730	Continuous	1800	ARR: 19	Impacts Total Transfer Capability	310 MW
Work scheduled by: NYSEG				TTC with All Lines In Service	2585 MW
MARCY__-FRASANNX_345_UCC2-41					
Tue 10/18/2022	to	Wed 10/19/2022		CENTRAL EAST - VC	2275 MW
0730	Continuous	1800	ARR: 19	Impacts Total Transfer Capability	310 MW
Work scheduled by: NYSEG				TTC with All Lines In Service	2585 MW
BUCHAN_N-EASTVIEW_345_W93					
Wed 10/19/2022	to	Tue 11/01/2022	UPDATED by ConEd 09/07/2022 11:39	UPNY CONED	4350 MW
0001	Continuous	0200		Impacts Total Transfer Capability	3465 MW
Work scheduled by: ConEd				TTC with All Lines In Service	7815 MW

NYISO TRANSFER LIMITATIONS

Page 11 of 50
Number Of Records: 179
Report Run Date: 10/18/2022 19:51 (EPT)

Seasonal Limits

Tuesday, October 18, 2022 to Wednesday, April 17, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
EASTVIEW-SPRNBK__345_W79					
Wed 10/19/2022	to	Wed 10/19/2022			
0001	Continuous	0031	UPDATED by ConEd 09/07/2022 11:39	UPNY CONED	4350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	3465 MW
				TTC with All Lines In Service	7815 MW
RAMAPO__-BUCHAN_N_345_Y94					
Thu 10/20/2022	to	Tue 11/01/2022			
0001	Continuous	0200	UPDATED by ConEd 09/07/2022 11:39	UPNY CONED	7580 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	235 MW
				TTC with All Lines In Service	7815 MW
ALCOA_PA_115KV_R8105					
Mon 10/24/2022	to	Wed 10/26/2022			
0700	Daily(No Weekends)	1700		MOSES SOUTH	3100 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	50 MW
				TTC with All Lines In Service	3150 MW
PANNELL_-CLAY____345_1					
Mon 10/24/2022	to	Fri 10/28/2022			
0700	Continuous	1530	UPDATED by NYPA 09/01/2022 11:59	WEST CENTRAL	1300 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	950 MW
				TTC with All Lines In Service	2250 MW

NYISO TRANSFER LIMITATIONS

Page 12 of 50
Number Of Records: 179
Report Run Date: 10/18/2022 19:51 (EPT)

Seasonal Limits

Tuesday, October 18, 2022 to Wednesday, April 17, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
ELBRIDGE-LAFAYTTE_345_17-LE					
Tue 10/25/2022	to	Tue 10/25/2022		OSWEGO EXPORT	5250 MW
0630	Continuous	1700	ARR: 75	Impacts Total Transfer Capability	0 MW
Work scheduled by: NGrid				TTC with All Lines In Service	5250 MW
OSWEGO__-ELBRIDGE_345_17					
Tue 10/25/2022	to	Tue 10/25/2022		OSWEGO EXPORT	5250 MW
0630	Continuous	1700	ARR: 75	Impacts Total Transfer Capability	0 MW
Work scheduled by: NGrid				TTC with All Lines In Service	5250 MW
MAINESBG-WATRCURE_345_30					
Tue 10/25/2022	to	Tue 10/25/2022		SCH - PJ - NY	
0800	Daily	1500		Impacts Total Transfer Capability	
Work scheduled by: NYSEG				TTC with All Lines In Service	

NYISO TRANSFER LIMITATIONS

Page 13 of 50
Number Of Records: 179
Report Run Date: 10/18/2022 19:51 (EPT)

Seasonal Limits

Tuesday, October 18, 2022 to Wednesday, April 17, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LEEDS__345KV_R395

Wed 10/26/2022 to Wed 10/26/2022
0900 Daily(No Weekends) 1030

Work scheduled by: NGrid

	FWD (Import)	REV (Export)
UPNY CONED	3800 MW	
Impacts Total Transfer Capability	4015 MW	
TTC with All Lines In Service	7815 MW	

WATRCURE-OAKDALE__345_31

Thu 10/27/2022 to Thu 10/27/2022
0800 Daily 1500

Work scheduled by: NYSEG

	FWD (Import)	REV (Export)
SCH - PJ - NY		
Impacts Total Transfer Capability		
TTC with All Lines In Service		

EASTVIEW-SPRNBK__345_W79

Sun 10/30/2022 to Sun 10/30/2022
0130 Continuous 0200

Work scheduled by: ConEd

UPDATED by ConEd 09/07/2022 11:39

	FWD (Import)	REV (Export)
UPNY CONED	4350 MW	
Impacts Total Transfer Capability	3465 MW	
TTC with All Lines In Service	7815 MW	

NYISO TRANSFER LIMITATIONS

Page 14 of 50
Number Of Records: 179
Report Run Date: 10/18/2022 19:51 (EPT)

Seasonal Limits

Tuesday, October 18, 2022 to Wednesday, April 17, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
PANNELL_-CLAY____345_2					
Mon 10/31/2022	to	Fri 11/04/2022	<u>UPDATED by NYPA 09/01/2022 11:47</u>	WEST CENTRAL	1300 MW
0700	Continuous	1530		Impacts Total Transfer Capability	950 MW
Work scheduled by: NYPA				TTC with All Lines In Service	2250 MW
BUCHAN_S-MILLWOOD_345_W97				FWD	REV
				(Import)	(Export)
Tue 11/01/2022	to	Wed 11/02/2022		UPNY CONED	7680 MW
0001	Continuous	0200		Impacts Total Transfer Capability	135 MW
Work scheduled by: ConEd				TTC with All Lines In Service	7815 MW
CLAY____-EDIC____345_1-16				FWD	REV
				(Import)	(Export)
Tue 11/01/2022	to	Thu 11/03/2022	<u>UPDATED by NGrid 07/05/2022 10:37</u>	OSWEGO EXPORT	4850 MW
0600	Continuous	1900		Impacts Total Transfer Capability	400 MW
Work scheduled by: NGrid				TTC with All Lines In Service	5250 MW
GILBOA__-N.SCTLND_345_GNS-1				FWD	REV
				(Import)	(Export)
Tue 11/01/2022	to	Tue 12/06/2022	<u>UPDATED by NGrid 08/19/2022 14:50</u>	CENTRAL EAST - VC	2300 MW
0700	Continuous	1900		Impacts Total Transfer Capability	285 MW
Work scheduled by: NGrid				TTC with All Lines In Service	2585 MW

NYISO TRANSFER LIMITATIONS

Page 15 of 50
Number Of Records: 179
Report Run Date: 10/18/2022 19:51 (EPT)

Seasonal Limits

Tuesday, October 18, 2022 to Wednesday, April 17, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
MARCY___-N.SCTLND_345_18				1345 MW	
Tue 11/01/2022	to	Tue 12/06/2022	UPDATED by NGrid 08/19/2022 14:50		
0700	Continuous	1900	ARR: 19		
Work scheduled by: NGrid				Impacts Total Transfer Capability	1240 MW
				TTC with All Lines In Service	2585 MW
LINDN_CG-LNDVFT___345_V-3022				0 MW	0 MW
Tue 11/01/2022	to	Fri 11/04/2022			
0800	Continuous	1500			
Work scheduled by: PJM				Impacts Total Transfer Capability	315 MW
				TTC with All Lines In Service	315 MW
NEPTUNE_-DUFFYAVE_345_NEPTUNE				0 MW	
Wed 11/02/2022	to	Tue 11/08/2022			
0600	Continuous	1600			
Work scheduled by: LI				Impacts Total Transfer Capability	660 MW
				TTC with All Lines In Service	660 MW
NEWBRDGE_345_138_BK_1				375 MW	
Wed 11/02/2022	to	Tue 11/08/2022			
0600	Continuous	1600			
Work scheduled by: LI				Impacts Total Transfer Capability	285 MW
				TTC with All Lines In Service	660 MW

NYISO TRANSFER LIMITATIONS

Page 16 of 50
Number Of Records: 179
Report Run Date: 10/18/2022 19:51 (EPT)

Seasonal Limits

Tuesday, October 18, 2022 to Wednesday, April 17, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
NEWBRDGE_345_138_BK_2					
Wed 11/02/2022	to	Tue 11/08/2022		SCH - PJM_NEPTUNE	375 MW
0600	Continuous	1600		Impacts Total Transfer Capability	285 MW
Work scheduled by: LI				TTC with All Lines In Service	660 MW
NEWBRDGE-DUFFYAVE_345_501					
Wed 11/02/2022	to	Tue 11/08/2022		SCH - PJM_NEPTUNE	0 MW
0600	Continuous	1600		Impacts Total Transfer Capability	660 MW
Work scheduled by: LI				TTC with All Lines In Service	660 MW
CEDARS_-ROSEMNTB_115_2/22					
Mon 11/07/2022	to	Fri 11/11/2022		SCH - HQ_CEDARS	95 MW
0630	Continuous	1600		Impacts Total Transfer Capability	184 MW
Work scheduled by: NGrid				TTC with All Lines In Service	279 MW
DENNISON-ROSEMNTB_115_2/22					
Mon 11/07/2022	to	Fri 11/11/2022		SCH - HQ_CEDARS	95 MW
0630	Continuous	1600		Impacts Total Transfer Capability	184 MW
Work scheduled by: NGrid				TTC with All Lines In Service	279 MW

NYISO TRANSFER LIMITATIONS

Page 17 of 50
Number Of Records: 179
Report Run Date: 10/18/2022 19:51 (EPT)

Seasonal Limits

Tuesday, October 18, 2022 to Wednesday, April 17, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
DUNWODIE_345KV_3					
Thu 11/10/2022	to	Thu 11/10/2022			
0230	Continuous	0300	<u>UPDATED by ConEd 08/16/2022 09:29</u>		
Work scheduled by: ConEd					
				SPR/DUN-SOUTH	3800 MW
				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_5					
Thu 11/10/2022	to	Thu 11/10/2022			
0230	Continuous	0300	<u>UPDATED by ConEd 08/16/2022 09:29</u>		
Work scheduled by: ConEd					
				SPR/DUN-SOUTH	3800 MW
				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Page 18 of 50
Number Of Records: 179
Report Run Date: 10/18/2022 19:51 (EPT)

Seasonal Limits

Tuesday, October 18, 2022 to Wednesday, April 17, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
MAINESBG-WATRCURE_345_30					
Thu 11/10/2022	to	Thu 11/10/2022	SCH - PJ - NY	2300 MW	
0800	Continuous	1600	Impacts Total Transfer Capability	550 MW	
Work scheduled by: PJM				TTC with All Lines In Service	2850 MW
DUNWODIE_345KV_7				FWD	REV
				(Import)	(Export)
Wed 11/16/2022	to	Wed 11/16/2022	SPR/DUN-SOUTH	3800 MW	
0100	Continuous	0200	Impacts Total Transfer Capability	800 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_3				FWD	REV
				(Import)	(Export)
Thu 11/17/2022	to	Thu 11/17/2022	SPR/DUN-SOUTH	3800 MW	
0001	Continuous	0030	Impacts Total Transfer Capability	800 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, October 18, 2022 to Wednesday, April 17, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
DUNWODIE_345KV_4					
Thu 11/17/2022	to	Thu 11/17/2022		SPR/DUN-SOUTH	3800 MW
0001	Continuous	0030		Impacts Total Transfer Capability	800 MW
Work scheduled by: ConEd				TTC with All Lines In Service	4600 MW
PLSNTVLE-DUNWODIE_345_W89					
Thu 11/17/2022	to	Thu 11/17/2022		UPNY CONED	4000 MW
0001	Continuous	0030		Impacts Total Transfer Capability	3815 MW
Work scheduled by: ConEd				TTC with All Lines In Service	7815 MW
DUNWODIE_345KV_3					
Thu 11/17/2022	to	Thu 11/17/2022		SPR/DUN-SOUTH	3800 MW
1730	Continuous	1800		Impacts Total Transfer Capability	800 MW
Work scheduled by: ConEd				TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Page 20 of 50

Number Of Records: 179

Report Run Date: 10/18/2022 19:51 (EPT)

Seasonal Limits

Tuesday, October 18, 2022 to Wednesday, April 17, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
DUNWODIE_345KV_4					
Thu 11/17/2022	to	Thu 11/17/2022			
1730	Continuous	1800	SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	4600 MW	
PLSNTVLE-DUNWODIE_345_W89					
Thu 11/17/2022	to	Thu 11/17/2022			
1730	Continuous	1800	UPNY CONED	4000 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	3815 MW	
			TTC with All Lines In Service	7815 MW	
BUCHAN_N-EASTVIEW_345_W93					
Mon 11/21/2022	to	Mon 11/28/2022			
0001	Continuous	0200	UPDATED by ConEd 09/07/2022 11:39		
Work scheduled by: ConEd			UPNY CONED	4350 MW	
			Impacts Total Transfer Capability	3465 MW	
			TTC with All Lines In Service	7815 MW	
EASTVIEW-SPRNBRK_345_W79					
Mon 11/21/2022	to	Mon 11/21/2022			
0001	Continuous	0030	UPDATED by ConEd 09/07/2022 11:39		
Work scheduled by: ConEd			UPNY CONED	4350 MW	
			Impacts Total Transfer Capability	3465 MW	
			TTC with All Lines In Service	7815 MW	

NYISO TRANSFER LIMITATIONS

Page 21 of 50
Number Of Records: 179
Report Run Date: 10/18/2022 19:51 (EPT)

Seasonal Limits

Tuesday, October 18, 2022 to Wednesday, April 17, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
RAMAPO__-BUCHAN_N_345_Y94					
Mon 11/21/2022	to	Mon 11/28/2022	<u>UPDATED by ConEd 09/07/2022 11:39</u>	UPNY CONED	7580 MW
0001	Continuous	0200		Impacts Total Transfer Capability	235 MW
Work scheduled by: ConEd				TTC with All Lines In Service	7815 MW
				FWD	REV
				(Import)	(Export)
E13THSTA-FARRAGUT_345_45					
Wed 11/23/2022	to	Sat 12/10/2022	<u>UPDATED by ConEd 10/05/2022 10:15</u>	SPR/DUN-SOUTH	3800 MW
0001	Continuous	0300		Impacts Total Transfer Capability	800 MW
Work scheduled by: ConEd				TTC with All Lines In Service	4600 MW
				FWD	REV
				(Import)	(Export)
HOMRC_NY-MAINS_NY_345_47					
Wed 11/23/2022	to	Wed 11/23/2022	<u>UPDATED by PJM 08/09/2022 11:26</u>	SCH - PJ - NY	
0800	Continuous	1600		Impacts Total Transfer Capability	
Work scheduled by: PJM				TTC with All Lines In Service	
				FWD	REV
				(Import)	(Export)
EASTVIEW-SPRNBK__345_W79					
Mon 11/28/2022	to	Mon 11/28/2022	<u>UPDATED by ConEd 09/07/2022 11:39</u>	UPNY CONED	4350 MW
0130	Continuous	0200		Impacts Total Transfer Capability	3465 MW
Work scheduled by: ConEd				TTC with All Lines In Service	7815 MW

NYISO TRANSFER LIMITATIONS

Page 22 of 50
Number Of Records: 179
Report Run Date: 10/18/2022 19:51 (EPT)

Seasonal Limits

Tuesday, October 18, 2022 to Wednesday, April 17, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
BUCHAN_S-MILLWOOD_345_W98					
Tue 11/29/2022	to	Thu 12/01/2022			
0001	Continuous	0200	UPNY CONED	7680 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	135 MW	
			TTC with All Lines In Service	7815 MW	
MILLWOOD_345KV_18					
Tue 11/29/2022	to	Thu 12/01/2022			
0001	Continuous	0200	UPNY CONED	4350 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	3465 MW	
			TTC with All Lines In Service	7815 MW	
CRICKVLY-PLSNTVLY_345_F84					
Thu 12/01/2022	to	Fri 12/16/2022			
0001	Continuous	0200	SCH - NE - NY	600 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	1400 MW	
CRICKVLY-PLSNTVLY_345_F84					
Thu 12/01/2022	to	Fri 12/16/2022			
0001	Continuous	0200	SCH - NPX_1385	100 MW	100 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	100 MW	100 MW
			TTC with All Lines In Service	200 MW	200 MW

NYISO TRANSFER LIMITATIONS

Page 23 of 50
Number Of Records: 179
Report Run Date: 10/18/2022 19:51 (EPT)

Seasonal Limits

Tuesday, October 18, 2022 to Wednesday, April 17, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
MOSES___-ADIRNDCK_230_MA1					
Thu 12/01/2022	to	Wed 03/01/2023			
0701	Continuous	1100	UPDATED by NYPA 09/02/2022 14:08	MOSES SOUTH	2300 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	850 MW
				TTC with All Lines In Service	3150 MW
MILLWOOD_345KV_18					
Fri 12/02/2022	to	Mon 12/12/2022			
0001	Continuous	1800		UPNY CONED	4350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	3465 MW
				TTC with All Lines In Service	7815 MW
FRASER___-COOPERS_345_33					
Wed 12/07/2022	to	Wed 12/07/2022			
0700	Continuous	1700		CENTRAL EAST - VC	2335 MW
Work scheduled by: NYSEG				Impacts Total Transfer Capability	250 MW
				TTC with All Lines In Service	2585 MW
MARCY___345KV_CSC					
Wed 12/07/2022	to	Tue 12/20/2022			
0700	Continuous	1530		CENTRAL EAST - VC	2535 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	50 MW
				TTC with All Lines In Service	2585 MW

NYISO TRANSFER LIMITATIONS

Page 24 of 50

Number Of Records: 179

Report Run Date: 10/18/2022 19:51 (EPT)

Seasonal Limits

Tuesday, October 18, 2022 to Wednesday, April 17, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
LAFAYTTE-CLRKSCRN_345_4-46					
Thu 12/08/2022	to	Sun 12/11/2022	CENTRAL EAST - VC	2450 MW	
0800	Continuous	1600	Impacts Total Transfer Capability	135 MW	
Work scheduled by: NGrid			TTC with All Lines In Service	2585 MW	
PIERCBRK-FIVEMILE_345_37				FWD	REV
				(Import)	(Export)
Thu 12/08/2022	to	Thu 12/08/2022	SCH - PJ - NY	2700 MW	
0800	Continuous	1600	Impacts Total Transfer Capability	150 MW	
Work scheduled by: PJM			TTC with All Lines In Service	2850 MW	
SPRNBK_-TREMONT_345_X28				FWD	REV
				(Import)	(Export)
Fri 12/09/2022	to	Fri 12/09/2022	SPR/DUN-SOUTH	4200 MW	
0001	Continuous	0030	Impacts Total Transfer Capability	400 MW	
Work scheduled by: ConEd			TTC with All Lines In Service	4600 MW	
SPRNBK_-TREMONT_345_X28				FWD	REV
				(Import)	(Export)
Fri 12/09/2022	to	Fri 12/09/2022	SPR/DUN-SOUTH	4200 MW	
1730	Continuous	1800	Impacts Total Transfer Capability	400 MW	
Work scheduled by: ConEd			TTC with All Lines In Service	4600 MW	

NYISO TRANSFER LIMITATIONS

Page 25 of 50
Number Of Records: 179
Report Run Date: 10/18/2022 19:51 (EPT)

Seasonal Limits

Tuesday, October 18, 2022 to Wednesday, April 17, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
HOPATCON-RAMAPO__500_5018					
Mon 12/12/2022	to	Fri 12/16/2022	TOTAL EAST	5200 MW	
0001	Continuous	2000	Impacts Total Transfer Capability	800 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	6000 MW
HOPATCON-RAMAPO__500_5018				FWD	REV
				(Import)	(Export)
Mon 12/12/2022	to	Fri 12/16/2022	SCH - PJ - NY	1650 MW	1200 MW
0001	Continuous	2000	Impacts Total Transfer Capability	1200 MW	1000 MW
Work scheduled by: ConEd				TTC with All Lines In Service	2850 MW
					2200 MW
HOPATCON-RAMAPO__500_5018				FWD	REV
				(Import)	(Export)
Mon 12/12/2022	to	Fri 12/16/2022	UPNY CONED	7480 MW	
0001	Continuous	2000	Impacts Total Transfer Capability	335 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	7815 MW
MARCY__345KV_CSC , HOPATCON-RAMAPO__500_5018				FWD	REV
				(Import)	(Export)
Mon 12/12/2022	to	Fri 12/16/2022	TOTAL EAST	5100 MW	
0001		2000	Impacts Total Transfer Capability	900 MW	
Work scheduled by:				TTC with All Lines In Service	6000 MW

NYISO TRANSFER LIMITATIONS

Page 26 of 50
Number Of Records: 179
Report Run Date: 10/18/2022 19:51 (EPT)

Seasonal Limits

Tuesday, October 18, 2022 to Wednesday, April 17, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
RAMAPO__345_345_PAR3500					
Mon 12/12/2022	to	Fri 12/16/2022	SCH - PJ - NY	2500 MW	1250 MW
0001	Continuous	2000	Impacts Total Transfer Capability	350 MW	950 MW
Work scheduled by: ConEd				TTC with All Lines In Service	2850 MW
				2850 MW	2200 MW
				FWD	REV
				(Import)	(Export)
RAMAPO__345_345_PAR4500					
Mon 12/12/2022	to	Fri 12/16/2022	SCH - PJ - NY	2500 MW	1250 MW
0001	Continuous	2000	Impacts Total Transfer Capability	350 MW	950 MW
Work scheduled by: ConEd				TTC with All Lines In Service	2850 MW
				2850 MW	2200 MW
				FWD	REV
				(Import)	(Export)
RAMAPO__500_345_BK 1500					
Mon 12/12/2022	to	Fri 12/16/2022	SCH - PJ - NY	1650 MW	1200 MW
0001	Continuous	2000	Impacts Total Transfer Capability	1200 MW	1000 MW
Work scheduled by: ConEd				TTC with All Lines In Service	2850 MW
				2850 MW	2200 MW

NYISO TRANSFER LIMITATIONS

Page 27 of 50
Number Of Records: 179
Report Run Date: 10/18/2022 19:51 (EPT)

Seasonal Limits

Tuesday, October 18, 2022 to Wednesday, April 17, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
RAMAPO__500_345_BK 1500					
Mon 12/12/2022	to	Fri 12/16/2022			
0001	Continuous	2000	UPNY CONED	7480 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	335 MW	
			TTC with All Lines In Service	7815 MW	
				FWD	REV
				(Import)	(Export)
CRICKVLY-PLSNTVLY_345_F83					
Fri 12/16/2022	to	Sun 01/01/2023			
0201	Continuous	0200	<u>EXTENDED by ConEd 09/22/2022 10:12</u>	100 MW	100 MW
Work scheduled by: ConEd			SCH - NPX_1385		
			Impacts Total Transfer Capability	100 MW	100 MW
			TTC with All Lines In Service	200 MW	200 MW
				FWD	REV
				(Import)	(Export)
CRICKVLY-PLSNTVLY_345_F83					
Fri 12/16/2022	to	Sun 01/01/2023			
0201	Continuous	0200	<u>EXTENDED by ConEd 09/22/2022 10:12</u>	600 MW	
Work scheduled by: ConEd			SCH - NE - NY		
			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	1400 MW	

NYISO TRANSFER LIMITATIONS

Page 28 of 50

Number Of Records: 179

Report Run Date: 10/18/2022 19:51 (EPT)

Seasonal Limits

Tuesday, October 18, 2022 to Wednesday, April 17, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
FRASER__-COOPERS__345_33				2335 MW	
Mon 12/19/2022	to	Fri 12/23/2022	CENTRAL EAST - VC		
0600	Continuous	1659	Impacts Total Transfer Capability	250 MW	
Work scheduled by: NYSEG				TTC with All Lines In Service	2585 MW
				FWD	REV
				(Import)	(Export)
HOMRC_NY-MAINS_NY_345_47					
Thu 12/22/2022	to	Thu 12/22/2022	SCH - PJ - NY		
0800	Continuous	1600	Impacts Total Transfer Capability		
Work scheduled by: PJM				TTC with All Lines In Service	
				FWD	REV
				(Import)	(Export)
W49TH_ST-E13THSTA_345_M54				3800 MW	
Tue 12/27/2022	to	Tue 12/27/2022	SPR/DUN-SOUTH		
0130	Continuous	0200	Impacts Total Transfer Capability	800 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	4600 MW

UPDATED by ConEd 10/05/2022 15:32

NYISO TRANSFER LIMITATIONS

Page 29 of 50
Number Of Records: 179
Report Run Date: 10/18/2022 19:51 (EPT)

Seasonal Limits

Tuesday, October 18, 2022 to Wednesday, April 17, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
CLAY___-EDIC___345_1-16					
Fri 12/30/2022	to	Sat 12/31/2022			
0600	Continuous	1900	UPDATED by NGrid 07/05/2022 10:37	OSWEGO EXPORT	4850 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	400 MW
				TTC with All Lines In Service	5250 MW
				FWD	REV
				(Import)	(Export)
FRASER___345_FRASER SVC					
Tue 01/03/2023	to	Tue 02/28/2023			
0700	Continuous	1730	UPDATED by NYPA 12/30/2021 15:43	CENTRAL EAST - VC	2550 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	35 MW
				TTC with All Lines In Service	2585 MW
				FWD	REV
				(Import)	(Export)
NIAGARA_-PACKARD_230_62					
Mon 01/09/2023	to	Fri 01/20/2023			
0500	Continuous	1900		SCH - OH - NY	900 MW 1850 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	1400 MW 150 MW
				TTC with All Lines In Service	2300 MW 2000 MW
				FWD	REV
				(Import)	(Export)
E13THSTA-FARRAGUT_345_46					
Fri 01/27/2023	to	Wed 02/01/2023			
0001	Continuous	0300	UPDATED by ConEd 10/06/2022 11:35	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits			Tuesday, October 18, 2022 to Wednesday, April 17, 2024		FWD	REV
F12THSTA-FARRAGUT_345_45					(Import)	(Export)
Wed 02/08/2023	to	Wed 02/08/2023	SPR/DUN-SOUTH		3800 MW	
0001	Continuous	0030	Impacts Total Transfer Capability		800 MW	
CENTRAL EAST scheduled by: ConEd			TTC with All Lines In Service		4600 MW	
CENTRAL EAST - VC 2585 MW						REV
TOTAL EAST-----6000-MW-----						(Import)
UPNY CONED 7815 MW						
E13THSTA-FARRAGUT_345_45						(Export)
Wed 02/22/2023	to	Wed 02/22/2023	SPR/DUN-SOUTH		3800 MW	
0230	Continuous	0300	Impacts Total Transfer Capability		800 MW	
DYSINGER EAST 3200 MW			TTC with All Lines In Service		4600 MW	
MOSES SOUTH 3150 MW						
Work scheduled by: ConEd						
EDIC____-FRASER____345_EF24-40					(Import)	(Export)
Wed 03/01/2023	to	Sat 04/15/2023	CENTRAL EAST - VC		2275 MW	
0600	Continuous	1800	Impacts Total Transfer Capability		310 MW	
Work scheduled by: NGrid			TTC with All Lines In Service		2585 MW	
GORDONRD-N.SCTLND_345_55					FWD	REV
Wed 03/01/2023	to	Fri 03/31/2023	CENTRAL EAST - VC		(Import)	(Export)
0700	Continuous	1600			2045 MW	
Work scheduled by: LS			Impacts Total Transfer Capability		540 MW	
			TTC with All Lines In Service		2585 MW	
MOSES____-ADIRNDCK_230_MA1					FWD	REV
Wed 03/01/2023	to	Fri 05/26/2023	MOSES SOUTH		(Import)	(Export)
1101	Continuous	1930			2300 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability		850 MW	
			TTC with All Lines In Service		3150 MW	
NIAGARA_-ROBNSNRD_230_64					FWD	REV
Mon 03/06/2023	to	Fri 03/17/2023	SCH - OH - NY		(Import)	(Export)
0500	Continuous	1900				1900 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability			100 MW
			TTC with All Lines In Service			2000 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and NAMP values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NYISO TRANSFER LIMITATIONS

Page 31 of 50
Number Of Records: 179
Report Run Date: 10/18/2022 19:51 (EPT)

Seasonal Limits

Tuesday, October 18, 2022 to Wednesday, April 17, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
N.SCTLND-ALPS___345_2					
Mon 03/27/2023	to	Fri 05/19/2023			
0700	Continuous	1900	UPDATED by NGrid 07/05/2022 10:45	SCH - NE - NY	900 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	500 MW
				TTC with All Lines In Service	1400 MW
N.SCTLND-ALPS___345_2					
Mon 03/27/2023	to	Fri 05/19/2023			
0700	Continuous	1900	UPDATED by NGrid 07/05/2022 10:45	SCH - NPX_1385	100 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	100 MW
				TTC with All Lines In Service	200 MW
MOTTHAVN-RAINEY___345_Q12					
Wed 03/29/2023	to	Sun 04/30/2023			
0001	Continuous	0200	UPDATED by ConEd 09/05/2022 07:25	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
ATHENS___-PLSNTVLY_345_91					
Sat 04/01/2023	to	Sat 04/15/2023			
0700	Continuous	1900		UPNY CONED	3800 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	4015 MW
				TTC with All Lines In Service	7815 MW

NYISO TRANSFER LIMITATIONS

Page 32 of 50

Number Of Records: 179

Report Run Date: 10/18/2022 19:51 (EPT)

Seasonal Limits

Tuesday, October 18, 2022 to Wednesday, April 17, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
PLSNTVLY_345KV_RNS4					
Sat 04/01/2023	to	Sat 04/01/2023			
0700	Continuous	0730	UPNY CONED	3800 MW	
Work scheduled by: NGrid			Impacts Total Transfer Capability	4015 MW	
			TTC with All Lines In Service	7815 MW	
LINDN_CG-LNDVFT___345_V-3022					
Sun 04/09/2023	to	Sat 04/15/2023			
1400	Continuous	1400	SCH - PJM_VFT	0 MW	0 MW
Work scheduled by: PJM			Impacts Total Transfer Capability	315 MW	315 MW
			TTC with All Lines In Service	315 MW	315 MW
DYSINGER-STA_255__345_DH1					
Mon 04/10/2023	to	Fri 04/14/2023			
0500	Continuous	2000	DYSINGER EAST	2850 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	350 MW	
			TTC with All Lines In Service	3200 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, October 18, 2022 to Wednesday, April 17, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
GORDONRD-N.SCTLND_345_55					
Mon 04/10/2023	to	Fri 04/14/2023			
0600	Continuous	1700	CENTRAL EAST - VC	2045 MW	
Work scheduled by: NGrid			Impacts Total Transfer Capability	540 MW	
			TTC with All Lines In Service	2585 MW	
				FWD	REV
DUNWODIE_345KV_3				(Import)	(Export)
Wed 04/12/2023	to	Wed 04/12/2023			
0201	Continuous	0230	SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	4600 MW	
				FWD	REV
DUNWODIE_345KV_4				(Import)	(Export)
Wed 04/12/2023	to	Wed 04/12/2023			
0201	Continuous	0230	SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	4600 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, October 18, 2022 to Wednesday, April 17, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
PLSNTVLE-DUNWODIE_345_W89					
Wed 04/12/2023	to	Wed 04/12/2023	UPNY CONED	4000 MW	
0201	Continuous	0230	Impacts Total Transfer Capability	3815 MW	
Work scheduled by: ConEd			TTC with All Lines In Service	7815 MW	
				FWD	REV
				(Import)	(Export)
PLSNTVLY_345KV_RNS4					
Sat 04/15/2023	to	Sat 04/15/2023	UPNY CONED	3800 MW	
1830	Continuous	1900	Impacts Total Transfer Capability	4015 MW	
Work scheduled by: NGrid			TTC with All Lines In Service	7815 MW	
				FWD	REV
				(Import)	(Export)
LEEDS__-PLSNTVLY_345_92					
Sun 04/16/2023	to	Sun 04/30/2023	UPNY CONED	3800 MW	
0700	Continuous	1900	Impacts Total Transfer Capability	4015 MW	
Work scheduled by: NGrid			TTC with All Lines In Service	7815 MW	
				FWD	REV
				(Import)	(Export)
PLSNTVLY_345KV_RNS5					
Sun 04/16/2023	to	Sun 04/16/2023	UPNY CONED	3800 MW	
0700	Continuous	0730	Impacts Total Transfer Capability	4015 MW	
Work scheduled by: NGrid			TTC with All Lines In Service	7815 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits			Tuesday, October 18, 2022 to Wednesday, April 17, 2024		FWD	REV
F12THSTA -FABRACUT_345_46					(Import)	(Export)
Mon 04/17/2023	to	Wed 04/19/2023	SPR/DUN-SOUTH		3800 MW	
0001	Continuous	0200			800 MW	
CENTRAL EAST scheduled: 2650 MW			Impacts Total Transfer Capability		4600 MW	
CENTRAL EAST - VC 2585 MW			TTC with All Lines In Service		4600 MW	
TOTAL EAST ----- 6000 MW						REV
UPNY CONED 7815 MW						(Import)
SPR/DUN-SOUTH 255_345_46 MW						
Mon 04/17/2023	to	Fri 04/21/2023	DYSINGER EAST		3200 MW	
0500	Continuous	2000			2850 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability		350 MW	
			TTC with All Lines In Service		3200 MW	
CLAY____-EDIC____345_2-15					FWD	REV
					(Import)	(Export)
Mon 04/17/2023	to	Fri 04/28/2023	OSWEGO EXPORT		4850 MW	
0600	Continuous	1800			400 MW	
Work scheduled by: NGrid			TTC with All Lines In Service		5250 MW	
DUNWODIE_345KV_3					FWD	REV
					(Import)	(Export)
Thu 04/20/2023	to	Thu 04/20/2023	SPR/DUN-SOUTH		3800 MW	
0130	Continuous	0200			800 MW	
Work scheduled by: ConEd			TTC with All Lines In Service		4600 MW	
DUNWODIE_345KV_4					FWD	REV
					(Import)	(Export)
Thu 04/20/2023	to	Thu 04/20/2023	SPR/DUN-SOUTH		3800 MW	
0130	Continuous	0200			800 MW	
Work scheduled by: ConEd			TTC with All Lines In Service		4600 MW	
PLSNTVLE-DUNWODIE_345_W89					FWD	REV
					(Import)	(Export)
Thu 04/20/2023	to	Thu 04/20/2023	UPNY CONED		4000 MW	
0130	Continuous	0200			3815 MW	
Work scheduled by: ConEd			TTC with All Lines In Service		7815 MW	

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and NEM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NYISO TRANSFER LIMITATIONS

Page 36 of 50

Number Of Records: 179

Report Run Date: 10/18/2022 19:51 (EPT)

Seasonal Limits

Tuesday, October 18, 2022 to Wednesday, April 17, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
PANNELL_-CLAY____345_1					
Mon 04/24/2023	to	Fri 04/28/2023			
0700	Continuous	1530	WEST CENTRAL	1300 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	950 MW	
			TTC with All Lines In Service	2250 MW	
PLSNTVLY_345KV_RNS5				FWD	REV
				(Import)	(Export)
Sun 04/30/2023	to	Sun 04/30/2023			
1830	Continuous	1900	UPNY CONED	3800 MW	
Work scheduled by: NGrid			Impacts Total Transfer Capability	4015 MW	
			TTC with All Lines In Service	7815 MW	
SHOR_NPX-SHOREHAM_138_CSC				FWD	REV
				(Import)	(Export)
Mon 05/01/2023	to	Fri 05/05/2023			
0600	Continuous	1800	SCH - NPX_CSC	0 MW	0 MW
Work scheduled by: LI			Impacts Total Transfer Capability	330 MW	330 MW
			TTC with All Lines In Service	330 MW	330 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, October 18, 2022 to Wednesday, April 17, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
PANNELL_-CLAY____345_2				1300 MW	
Mon 05/01/2023	to	Fri 05/05/2023			
0700	Continuous	1530	WEST CENTRAL		
Work scheduled by: NYPA			Impacts Total Transfer Capability	950 MW	
			TTC with All Lines In Service	2250 MW	
PLSNTVLY_345KV_RNS5				3800 MW	
Wed 05/03/2023	to	Mon 05/15/2023			
0001	Continuous	2200	UPNY CONED		
Work scheduled by: ConEd			Impacts Total Transfer Capability	4015 MW	
			TTC with All Lines In Service	7815 MW	
PLSNTVLY-WOOD_ST_345_F30				4000 MW	
Wed 05/03/2023	to	Mon 05/15/2023			
0001	Continuous	2200	UPNY CONED		
Work scheduled by: ConEd			Impacts Total Transfer Capability	3815 MW	
			TTC with All Lines In Service	7815 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, October 18, 2022 to Wednesday, April 17, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
NIAGARA_-ROBNSNRD_230_64					
Fri 05/05/2023	to	Fri 05/05/2023	SCH - OH - NY		1400 MW
0500	Continuous	1700	Impacts Total Transfer Capability		150 MW
Work scheduled by: NYPA				TTC with All Lines In Service	1550 MW
				FWD	REV
				(Import)	(Export)
W49TH_ST_345KV_6					
Sat 05/06/2023	to	Sat 05/06/2023	SCH - PJM_HTP	300 MW	
0001	Continuous	0030	Impacts Total Transfer Capability	360 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	660 MW
				FWD	REV
				(Import)	(Export)
W49TH_ST_345KV_8					
Sat 05/06/2023	to	Sat 05/06/2023	SCH - PJM_HTP	450 MW	
0001	Continuous	0030	Impacts Total Transfer Capability	210 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	660 MW

NYISO TRANSFER LIMITATIONS

Page 39 of 50
Number Of Records: 179
Report Run Date: 10/18/2022 19:51 (EPT)

Seasonal Limits

Tuesday, October 18, 2022 to Wednesday, April 17, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
COOPERS_-DOLSONAV_345_CCDA42					
Mon 05/08/2023	to	Sun 05/21/2023	CENTRAL EAST - VC	2485 MW	
0700	Continuous	1530	Impacts Total Transfer Capability	100 MW	
Work scheduled by: NYPA			TTC with All Lines In Service	2585 MW	
DOLSONAV-ROCKTVRN_345_DART44				FWD	REV
				(Import)	(Export)
Mon 05/08/2023	to	Sat 05/13/2023	CENTRAL EAST - VC	2485 MW	
0700	Continuous	1530	Impacts Total Transfer Capability	100 MW	
Work scheduled by: NYPA			TTC with All Lines In Service	2585 MW	
W49TH_ST_345KV_6				FWD	REV
				(Import)	(Export)
Sat 05/13/2023	to	Sat 05/13/2023	SCH - PJM_HTP	300 MW	
0130	Continuous	0200	Impacts Total Transfer Capability	360 MW	
Work scheduled by: ConEd			TTC with All Lines In Service	660 MW	
W49TH_ST_345KV_8				FWD	REV
				(Import)	(Export)
Sat 05/13/2023	to	Sat 05/13/2023	SCH - PJM_HTP	450 MW	
0130	Continuous	0200	Impacts Total Transfer Capability	210 MW	
Work scheduled by: ConEd			TTC with All Lines In Service	660 MW	

NYISO TRANSFER LIMITATIONS

Page 40 of 50
Number Of Records: 179
Report Run Date: 10/18/2022 19:51 (EPT)

Seasonal Limits

Tuesday, October 18, 2022 to Wednesday, April 17, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
W49TH_ST_345KV_6					
Mon 05/15/2023	to	Mon 05/15/2023	SCH - PJM_HTP	300 MW	
0001	Continuous	0030	Impacts Total Transfer Capability	360 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	660 MW
W49TH_ST-E13THSTA_345_M55				FWD	REV
				(Import)	(Export)
Mon 05/15/2023	to	Wed 05/17/2023	SPR/DUN-SOUTH	3800 MW	
0001	Continuous	0200	Impacts Total Transfer Capability	800 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	4600 MW
MOTTHAVN-RAINEY__345_Q11				FWD	REV
				(Import)	(Export)
Wed 05/17/2023	to	Sat 05/20/2023	SPR/DUN-SOUTH	3800 MW	
0001	Continuous	0200	Impacts Total Transfer Capability	800 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Page 41 of 50
Number Of Records: 179
Report Run Date: 10/18/2022 19:51 (EPT)

Seasonal Limits

Tuesday, October 18, 2022 to Wednesday, April 17, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
W49TH_ST_345KV_6					
Wed 05/17/2023	to	Wed 05/17/2023		SCH - PJM_HTP	300 MW
0130	Continuous	0200		Impacts Total Transfer Capability	360 MW
Work scheduled by: ConEd				TTC with All Lines In Service	660 MW
				FWD	REV
				(Import)	(Export)
BECK____-NIAGARA_230_PA27					
Tue 05/30/2023	to	Fri 06/02/2023		SCH - OH - NY	
0500	Continuous	2100		Impacts Total Transfer Capability	
Work scheduled by: NYPA				TTC with All Lines In Service	
				FWD	REV
				(Import)	(Export)
NIAGARA_345_230_AT4					
Wed 06/28/2023	to	Thu 06/29/2023		SCH - OH - NY	1150 MW
0500	Continuous	1900		Impacts Total Transfer Capability	400 MW
Work scheduled by: NYPA				TTC with All Lines In Service	1550 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, October 18, 2022 to Wednesday, April 17, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
NIAGARA_345_230_AT4					
Mon 08/21/2023	to	Fri 08/25/2023		SCH - OH - NY	
0500	Continuous	2100			1150 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	400 MW
				TTC with All Lines In Service	1550 MW
ADIRNDCK-PORTER_230_12				FWD	REV
				(Import)	(Export)
Tue 08/22/2023	to	Tue 08/22/2023		MOSES SOUTH	
0700	Continuous	1530			2100 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	1050 MW
				TTC with All Lines In Service	3150 MW
ADIRNDCK-CHASLAKE_230_13				FWD	REV
				(Import)	(Export)
Wed 08/23/2023	to	Wed 08/23/2023		MOSES SOUTH	
0700	Continuous	1530			2100 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	1050 MW
				TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, October 18, 2022 to Wednesday, April 17, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
CLAY___-EDIC___345_1-16					
Mon 09/11/2023	to	Fri 09/15/2023			
0700	Continuous	1530	OSWEGO EXPORT	4850 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	400 MW	
			TTC with All Lines In Service	5250 MW	
FRASER___-GILBOA___345_GF5-35				FWD	REV
				(Import)	(Export)
Mon 09/11/2023	to	Sun 09/17/2023			
0700	Continuous	1530	CENTRAL EAST - VC	2450 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	135 MW	
			TTC with All Lines In Service	2585 MW	
SPRNBK___345KV_RNS5				FWD	REV
				(Import)	(Export)
Fri 09/15/2023	to	Mon 10/23/2023			
0001	Continuous	0200	UPDATED by ConEd 08/10/2022 13:51	SPR/DUN-SOUTH	3200 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	1400 MW	
			TTC with All Lines In Service	4600 MW	
SPRNBK___-W49TH_ST_345_M51				FWD	REV
				(Import)	(Export)
Fri 09/15/2023	to	Mon 10/23/2023			
0001	Continuous	0200	UPDATED by ConEd 08/10/2022 13:51	SPR/DUN-SOUTH	3200 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	1400 MW	
			TTC with All Lines In Service	4600 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, October 18, 2022 to Wednesday, April 17, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
CLAY____-EDIC____345_2-15					
Mon 09/18/2023	to	Fri 09/22/2023			
0700	Continuous	1530	OSWEGO EXPORT	4850 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	400 MW	
			TTC with All Lines In Service	5250 MW	
NIAGARA_-DYSINGER_345_ND2				FWD	REV
				(Import)	(Export)
Mon 09/25/2023	to	Fri 09/29/2023			
0500	Continuous	2000	DYSINGER EAST	2700 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	500 MW	
			TTC with All Lines In Service	3200 MW	
MARCY____345KV_CSC				FWD	REV
				(Import)	(Export)
Mon 09/25/2023	to	Sat 10/07/2023			
0700	Continuous	1530	CENTRAL EAST - VC	2535 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	50 MW	
			TTC with All Lines In Service	2585 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, October 18, 2022 to Wednesday, April 17, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
SHOR_NPX-SHOREHAM_138_CSC					
Mon 10/02/2023	to	Fri 10/06/2023	SCH - NPX_CSC	0 MW	0 MW
0600	Continuous	1800	Impacts Total Transfer Capability	330 MW	330 MW
Work scheduled by: LI			TTC with All Lines In Service	330 MW	330 MW
NEPTUNE_-DUFFYAVE_345_NEPTUNE				FWD	REV
				(Import)	(Export)
Mon 10/09/2023	to	Fri 10/13/2023	SCH - PJM_NEPTUNE	0 MW	
0600	Continuous	1600	Impacts Total Transfer Capability	660 MW	
Work scheduled by: LI			TTC with All Lines In Service	660 MW	
NEWBRDGE_345_138_BK_1				FWD	REV
				(Import)	(Export)
Mon 10/09/2023	to	Fri 10/13/2023	SCH - PJM_NEPTUNE	375 MW	
0600	Continuous	1600	Impacts Total Transfer Capability	285 MW	
Work scheduled by: LI			TTC with All Lines In Service	660 MW	
NEWBRDGE_345_138_BK_2				FWD	REV
				(Import)	(Export)
Mon 10/09/2023	to	Fri 10/13/2023	SCH - PJM_NEPTUNE	375 MW	
0600	Continuous	1600	Impacts Total Transfer Capability	285 MW	
Work scheduled by: LI			TTC with All Lines In Service	660 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits			Tuesday, October 18, 2022 to Wednesday, April 17, 2024		FWD	REV
NEWBROOK - BUFFYAVE_245_501					(Import)	(Export)
Mon 10/09/2023	to	Fri 10/13/2023	SCH - PJM_NEPTUNE		0 MW	
0600	Continuous	1600	Impacts Total Transfer Capability		660 MW	
CENTRAL EAST scheduled by: NYPA			TTC with All Lines In Service		660 MW	
CENTRAL EAST - VC 2585 MW						REV
TOTAL EAST 6000 MW						(Import)
UPNY CONED 7815 MW						
GILBOA - N.SCTLND_345_GNS-1						
Mon 10/09/2023	to	Fri 10/13/2023	MONTHLY EAST		230 MW	
0700	Continuous	1530	Impacts Total Transfer Capability		285 MW	
DYSINGER EAST 3200 MW			TTC with All Lines In Service		2585 MW	
MOSES SOUTH 3150 MW						
Work scheduled by: NYPA						
NIAGARA - PACKARD_230_61					(Import)	(Export)
Fri 10/13/2023	to	Fri 10/13/2023	SCH - OH - NY			1350 MW
0500	Continuous	1900	Impacts Total Transfer Capability			200 MW
Work scheduled by: NYPA			TTC with All Lines In Service			1550 MW
HURLYAVE-ROSETON_345_303					FWD	REV
					(Import)	(Export)
Mon 11/13/2023	to	Fri 12/22/2023	UPNY CONED		4100 MW	
0800	Continuous	1600	Impacts Total Transfer Capability		3715 MW	
Work scheduled by: CHGE			TTC with All Lines In Service		7815 MW	
CHATGUAY-MASSENA_765_7040					FWD	REV
					(Import)	(Export)
Wed 11/15/2023	to	Mon 11/27/2023	SCH - HQ - NY		0 MW	0 MW
0700	Continuous	1730	Impacts Total Transfer Capability		1500 MW	1000 MW
Work scheduled by: NYPA			TTC with All Lines In Service		1500 MW	1000 MW
CHATGUAY-MASSENA_765_7040					FWD	REV
					(Import)	(Export)
Wed 11/15/2023	to	Mon 11/27/2023	MOSES SOUTH		1550 MW	
0700	Continuous	1730	Impacts Total Transfer Capability		1600 MW	
Work scheduled by: NYPA			TTC with All Lines In Service		3150 MW	

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and NEM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, October 18, 2022 to Wednesday, April 17, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
CHATGUAY-MASSENA__765_7040 , MASSENA_-MARCY__765_MSU1				MOSES SOUTH	500 MW
Wed 11/15/2023	to	Mon 11/27/2023		Impacts Total Transfer Capability	2650 MW
0700		1730		TTC with All Lines In Service	3150 MW
Work scheduled by:					
				FWD	REV
				(Import)	(Export)
MASSENA_-MARCY__765_MSU1				CENTRAL EAST - VC	1720 MW
Wed 11/15/2023	to	Mon 11/27/2023		Impacts Total Transfer Capability	865 MW
0700	Continuous	1730		TTC with All Lines In Service	2585 MW
Work scheduled by: NYPA					
				FWD	REV
				(Import)	(Export)
MASSENA_-MARCY__765_MSU1				SCH - HQ_CEDARS	90 MW
Wed 11/15/2023	to	Mon 11/27/2023		Impacts Total Transfer Capability	189 MW
0700	Continuous	1730		TTC with All Lines In Service	279 MW
Work scheduled by: NYPA					
				FWD	REV
				(Import)	(Export)
MASSENA_-MARCY__765_MSU1				SCH - HQ - NY	475 MW 1000 MW
Wed 11/15/2023	to	Mon 11/27/2023		Impacts Total Transfer Capability	1025 MW 0 MW
0700	Continuous	1730		TTC with All Lines In Service	1500 MW 1000 MW
Work scheduled by: NYPA					

NYISO TRANSFER LIMITATIONS

Page 48 of 50

Number Of Records: 179

Report Run Date: 10/18/2022 19:51 (EPT)

Seasonal Limits

Tuesday, October 18, 2022 to Wednesday, April 17, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
MASSENA_-MARCY___765_MSU1					
Wed 11/15/2023	to	Mon 11/27/2023			
0700	Continuous	1730	MOSES SOUTH	500 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	2650 MW	
			TTC with All Lines In Service	3150 MW	
MOSES_-MASSENA_230_MMS1 , MOSES_-MASSENA_230_MMS2				FWD	REV
				(Import)	(Export)
Wed 11/15/2023	to	Mon 11/20/2023	SCH - HQ_CEDARS	90 MW	
0700		1530	Impacts Total Transfer Capability	189 MW	
Work scheduled by:			TTC with All Lines In Service	279 MW	
MOSES_-MASSENA_230_MMS1 , MOSES_-MASSENA_230_MMS2				FWD	REV
				(Import)	(Export)
Wed 11/15/2023	to	Mon 11/20/2023	SCH - HQ - NY	850 MW	0 MW
0700		1530	Impacts Total Transfer Capability	650 MW	1000 MW
Work scheduled by:			TTC with All Lines In Service	1500 MW	1000 MW

NYISO TRANSFER LIMITATIONS

Page 49 of 50
Number Of Records: 179
Report Run Date: 10/18/2022 19:51 (EPT)

Seasonal Limits

Tuesday, October 18, 2022 to Wednesday, April 17, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
NIAGARA_345_230_AT4					
Mon 11/27/2023	to	Fri 12/01/2023		SCH - OH - NY	1750 MW
0500	Continuous	1900		Impacts Total Transfer Capability	250 MW
Work scheduled by: NYPA				TTC with All Lines In Service	2000 MW
HOMR_NYW-PIERC_NY_345_48				FWD	REV
				(Import)	(Export)
Fri 12/08/2023	to	Fri 12/15/2023	<u>UPDATED by PJM 07/28/2022 14:08</u>	SCH - PJ - NY	
0800	Continuous	1600		Impacts Total Transfer Capability	
Work scheduled by: PJM				TTC with All Lines In Service	
HOMRC_NY-MAINS_NY_345_47				FWD	REV
				(Import)	(Export)
Fri 12/08/2023	to	Fri 12/15/2023	<u>UPDATED by PJM 07/28/2022 14:08</u>	SCH - PJ - NY	
0800	Continuous	1600		Impacts Total Transfer Capability	
Work scheduled by: PJM				TTC with All Lines In Service	
W49TH_ST_345KV_6				FWD	REV
				(Import)	(Export)
Mon 01/08/2024	to	Mon 02/19/2024		SCH - PJM_HTP	310 MW
0001	Continuous	0201		Impacts Total Transfer Capability	350 MW
Work scheduled by: ConEd				TTC with All Lines In Service	660 MW

NYISO TRANSFER LIMITATIONS

Page 50 of 50
Number Of Records: 179
Report Run Date: 10/18/2022 19:51 (EPT)

Seasonal Limits

Tuesday, October 18, 2022 to Wednesday, April 17, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
W49TH_ST-E13THSTA_345_M55					
Mon 01/08/2024	to	Mon 02/19/2024			
0001	Continuous	0201	SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	4600 MW	
				FWD	REV
				(Import)	(Export)
W49TH_ST_345KV_8					
Sat 02/03/2024	to	Mon 02/19/2024			
0001	Continuous	0201	SCH - PJM_HTP	310 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	350 MW	
			TTC with All Lines In Service	660 MW	