

NYISO TRANSFER LIMITATIONS

Page 1 of 48
Number Of Records: 177
Report Run Date: 10/27/2022 12:10 (EPT)

Seasonal Limits

Thursday, October 27, 2022 to Friday, April 26, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
HUDSONP_-FARRAGUT_345_B3402				2050 MW	
Mon 01/15/2018	to	Tue 01/31/2023			
0001	Continuous	2359	<u>EXT FORCED by ConEd 08/06/2022 16:26</u>		
Work scheduled by: ConEd				Impacts Total Transfer Capability	200 MW
				TTC with All Lines In Service	2250 MW
MARION__-FARRAGUT_345_C3403				2050 MW	
Mon 01/15/2018	to	Tue 01/31/2023			
0001	Continuous	2359	<u>EXT FORCED by ConEd 08/06/2022 16:26</u>		
Work scheduled by: ConEd				Impacts Total Transfer Capability	200 MW
				TTC with All Lines In Service	2250 MW
MARION__-FARRAGUT_345_C3403 , HUDSONP_-FARRAGUT_345_B3402				2000 MW	1150 MW
Mon 01/15/2018	to	Tue 01/31/2023			
0001		2359			
Work scheduled by:				Impacts Total Transfer Capability	250 MW
				TTC with All Lines In Service	1200 MW

NYISO TRANSFER LIMITATIONS

Page 2 of 48
Number Of Records: 177
Report Run Date: 10/27/2022 12:10 (EPT)

Seasonal Limits

Thursday, October 27, 2022 to Friday, April 26, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
SCH-IMO-NYISO_LIMIT_1400				1700 MW	
Wed 08/10/2022	to	Mon 11/21/2022	<u>EXTENDED by IESO 08/19/2022 14:10</u>	SCH - OH - NY	
0800	Continuous	1600		Impacts Total Transfer Capability	200 MW
Work scheduled by: IESO				TTC with All Lines In Service	1900 MW
				FWD	REV
				(Import)	(Export)
BECK___-NIAGARA_230_PA27					
Wed 08/24/2022	to	Fri 10/28/2022	<u>EXTENDED by IESO 09/26/2022 15:45</u>	SCH - OH - NY	
0800	Continuous	1700		Impacts Total Transfer Capability	
Work scheduled by: IESO				TTC with All Lines In Service	
				FWD	REV
				(Import)	(Export)
MOSES___-ADIRNDCK_230_MA2				2100 MW	
Tue 09/06/2022	to	Thu 12/01/2022	<u>UPDATED by NYPA 09/06/2022 15:41</u>	MOSES SOUTH	
1200	Continuous	0659		Impacts Total Transfer Capability	1050 MW
Work scheduled by: NYPA				TTC with All Lines In Service	3150 MW
				FWD	REV
				(Import)	(Export)
HURLYAVE-ROSETON_345_303				4100 MW	
Mon 09/19/2022	to	Fri 12/02/2022	<u>UPDATED by CHGE 10/04/2022 09:16</u>	UPNY CONED	
0800	Continuous	1600		Impacts Total Transfer Capability	3715 MW
Work scheduled by: CHGE				TTC with All Lines In Service	7815 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, October 27, 2022 to Friday, April 26, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
LEEDS___-HURLYAVE_345_301				4100 MW	
Mon 09/19/2022	to	Fri 12/02/2022	10/04/2021 10:51	UPNY CONED	
0800	Continuous	1600		Impacts Total Transfer Capability	3715 MW
Work scheduled by: CHGE				TTC with All Lines In Service	7815 MW
EGRDNCTY_345_138_AT1				1250 MW	
Sat 10/01/2022	to	Wed 05/31/2023	UPDATED by ConEd 10/01/2022 09:02	CONED - LIPA	
0001	Continuous	2359		Impacts Total Transfer Capability	250 MW
Work scheduled by: LI				TTC with All Lines In Service	1500 MW
EGRDNCTY_345_138_AT2				1250 MW	
Sat 10/01/2022	to	Wed 05/31/2023	UPDATED by ConEd 10/01/2022 09:02	CONED - LIPA	
0001	Continuous	2359		Impacts Total Transfer Capability	250 MW
Work scheduled by: LI				TTC with All Lines In Service	1500 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, October 27, 2022 to Friday, April 26, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
SPRNBK_-EGRDNCTR_345_Y49					
Sat 10/01/2022	to	Wed 05/31/2023			
0001	Continuous	2359	UPDATED by ConEd 10/01/2022 09:02	CONED - LIPA	775 MW
Work scheduled by: LI				Impacts Total Transfer Capability	725 MW
				TTC with All Lines In Service	1500 MW
STLAWRNC-MOSES___230_L34P					
Mon 10/03/2022	to	Mon 09/25/2023			
1800	Continuous	0800	UPDATED by IESO 10/04/2022 16:51	SCH - OH - NY	
Work scheduled by: IESO				Impacts Total Transfer Capability	
				TTC with All Lines In Service	
DUNWODIE-MOTTHAVN_345_71					
Thu 10/06/2022	to	Thu 11/10/2022			
0001	Continuous	0300	UPDATED by ConEd 08/16/2022 09:29	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, October 27, 2022 to Friday, April 26, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
CHAT_DC_GC1					
Sun 10/09/2022	to	Tue 11/01/2022			
0400	Continuous	1200	<u>UPDATED by HQ 10/25/2022 17:45</u>		
Work scheduled by: HQ					
				MOSES SOUTH	2850 MW
				Impacts Total Transfer Capability	300 MW
				TTC with All Lines In Service	3150 MW
CHAT_DC_GC1					
Sun 10/09/2022	to	Tue 11/01/2022			
0400	Continuous	1200	<u>UPDATED by HQ 10/25/2022 17:45</u>		
Work scheduled by: HQ					
				SCH - HQ - NY	500 MW
				Impacts Total Transfer Capability	500 MW
				TTC with All Lines In Service	1000 MW
SCH-NYISO-HQ_LIMIT_500					
Sun 10/09/2022	to	Tue 11/01/2022			
0400	Continuous	1200	<u>UPDATED by HQ 10/25/2022 17:45</u>		
Work scheduled by: HQ					
				SCH - HQ - NY	500 MW
				Impacts Total Transfer Capability	500 MW
				TTC with All Lines In Service	1000 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, October 27, 2022 to Friday, April 26, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
EDIC____-GORDONRD_345_14					
Mon 10/10/2022	to	Mon 10/31/2022			
0700	Continuous	1530	<u>UPDATED by NYPA 06/30/2022 15:45</u>	CENTRAL EAST - VC	1670 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	915 MW
				TTC with All Lines In Service	2585 MW
W49TH_ST-E13THSTA_345_M55					
Tue 10/18/2022	to	Fri 11/04/2022			
0003	Continuous	2359	<u>EXT FORCED by ConEd 10/19/2022 17:42</u>	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
BUCHAN_N-EASTVIEW_345_W93					
Wed 10/19/2022	to	Tue 11/01/2022			
0001	Continuous	0200	<u>UPDATED by ConEd 09/07/2022 11:39</u>	UPNY CONED	4350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	3465 MW
				TTC with All Lines In Service	7815 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, October 27, 2022 to Friday, April 26, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
RAMAPO__-BUCHAN_N_345_Y94					
Thu 10/20/2022	to	Tue 11/01/2022			
0001	Continuous	0200	UPDATED by ConEd 09/07/2022 11:39	UPNY CONED	7580 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	235 MW
				TTC with All Lines In Service	7815 MW
PANNELL_-CLAY____345_1					
Mon 10/24/2022	to	Fri 10/28/2022			
0700	Continuous	1530	UPDATED by NYPA 09/01/2022 11:59	WEST CENTRAL	1300 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	950 MW
				TTC with All Lines In Service	2250 MW
ALCOA_PA_115KV_R8105					
Tue 10/25/2022	to	Thu 10/27/2022			
0700	Daily(No Weekends)	1700	UPDATED by HQ 10/25/2022 18:04	MOSES SOUTH	3100 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	50 MW
				TTC with All Lines In Service	3150 MW
SCH-HQ_CEDARS-NYISO_LIMIT_80					
Tue 10/25/2022	to	Thu 10/27/2022			
0700	Daily(No Weekends)	1700	UPDATED by HQ 10/25/2022 18:04	SCH - HQ_CEDARS	80 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	190 MW
				TTC with All Lines In Service	270 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, October 27, 2022 to Friday, April 26, 2024

FWD

REV

~~WATCURE_OAKDALE_345_31~~

Thu 10/27/2022 to Thu 10/27/2022
0800 Daily 1500
CENTRAL EAST scheduled 2650 MW SEG
CENTRAL EAST - VC 2585 MW
~~TOTAL EAST 6000 MW~~
UPNY CONED 7815 MW
SCH-NYISO-NE LIMIT 1100
SPR/DUN SOUTH 4600 MW to Sat 10/29/2022
DYSINGER EAST 3200 MW Continuous 1100
MOSES SOUTH 3150 MW
Work scheduled by: ISONE

CANCELLED by TO 10/27/2022 10:43

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH - PJ - NY

Impacts Total Transfer Capability
TTC with All Lines In Service

REV

UPNY CONED 4350 MW
Impacts Total Transfer Capability 3465 MW
TTC with All Lines In Service 1600 MW

EASTVIEW-SPRNBK_345_W79

Sun 10/30/2022 to Sun 10/30/2022
0130 Continuous 0200
Work scheduled by: ConEd

UPDATED by ConEd 09/07/2022 11:39

UPNY CONED

Impacts Total Transfer Capability

TTC with All Lines In Service

(Import)

(Export)

4350 MW

3465 MW

7815 MW

NRTH1385-NOR HBR_138_601

Mon 10/31/2022 to Mon 10/31/2022
0500 Continuous 2359
Work scheduled by: LI

SCH - NPX_1385

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD

REV

(Import)

(Export)

100 MW

100 MW

200 MW

100 MW

100 MW

200 MW

NRTH1385-NOR HBR_138_602

Mon 10/31/2022 to Mon 10/31/2022
0500 Continuous 2359
Work scheduled by: LI

SCH - NPX_1385

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD

REV

(Import)

(Export)

100 MW

100 MW

200 MW

100 MW

100 MW

200 MW

NRTH1385-NOR HBR_138_603

Mon 10/31/2022 to Mon 10/31/2022
0500 Continuous 2359
Work scheduled by: LI

SCH - NPX_1385

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD

REV

(Import)

(Export)

100 MW

100 MW

200 MW

100 MW

100 MW

200 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, October 27, 2022 to Friday, April 26, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

			FWD	REV
			(Import)	(Export)
NRTH1385-NORHBR__138_601 , NRTH1385-NORHBR__138_602				
Mon 10/31/2022	to	Mon 10/31/2022	SCH - NPX_1385	0 MW
0500		2359	Impacts Total Transfer Capability	200 MW
Work scheduled by:			TTC with All Lines In Service	200 MW
NRTH1385-NORHBR__138_601 , NRTH1385-NORHBR__138_603				
Mon 10/31/2022	to	Mon 10/31/2022	SCH - NPX_1385	0 MW
0500		2359	Impacts Total Transfer Capability	200 MW
Work scheduled by:			TTC with All Lines In Service	200 MW
NRTH1385-NORHBR__138_602 , NRTH1385-NORHBR__138_603				
Mon 10/31/2022	to	Mon 10/31/2022	SCH - NPX_1385	0 MW
0500		2359	Impacts Total Transfer Capability	200 MW
Work scheduled by:			TTC with All Lines In Service	200 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, October 27, 2022 to Friday, April 26, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
NRTH1385-NRTHPORT_138_NNC					
Mon 10/31/2022	to	Mon 10/31/2022		SCH - NPX_1385	
0500	Continuous	2359		Impacts Total Transfer Capability	200 MW
Work scheduled by: LI				TTC with All Lines In Service	200 MW
PANNELL_-CLAY____345_2				FWD	REV
				(Import)	(Export)
Mon 10/31/2022	to	Sat 11/05/2022	UPDATED by NYPA 09/01/2022 11:47	WEST CENTRAL	1300 MW
0700	Continuous	1530		Impacts Total Transfer Capability	950 MW
Work scheduled by: NYPA				TTC with All Lines In Service	2250 MW
BUCHAN_S-MILLWOOD_345_W97				FWD	REV
				(Import)	(Export)
Tue 11/01/2022	to	Wed 11/02/2022		UPNY CONED	7680 MW
0001	Continuous	0200		Impacts Total Transfer Capability	135 MW
Work scheduled by: ConEd				TTC with All Lines In Service	7815 MW
CLAY____-EDIC____345_1-16				FWD	REV
				(Import)	(Export)
Tue 11/01/2022	to	Thu 11/03/2022	UPDATED by NGrid 07/05/2022 10:37	OSWEGO EXPORT	4850 MW
0600	Continuous	1900		Impacts Total Transfer Capability	400 MW
Work scheduled by: NGrid				TTC with All Lines In Service	5250 MW

NYISO TRANSFER LIMITATIONS

Page 11 of 48

Number Of Records: 177

Report Run Date: 10/27/2022 12:10 (EPT)

Seasonal Limits

Thursday, October 27, 2022 to Friday, April 26, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
GILBOA__-N.SCTLND_345_GNS-1					
Tue 11/01/2022	to	Tue 12/06/2022			
0700	Continuous	1900	UPDATED by NGrid 08/19/2022 14:50	CENTRAL EAST - VC	2300 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	285 MW
				TTC with All Lines In Service	2585 MW
MARCY__-N.SCTLND_345_18					
Tue 11/01/2022	to	Tue 12/06/2022			
0700	Continuous	1900	UPDATED by NGrid 08/19/2022 14:50	CENTRAL EAST - VC	1345 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	1240 MW
				TTC with All Lines In Service	2585 MW
LINDN_CG-LNDVFT__345_V-3022					
Tue 11/01/2022	to	Fri 11/04/2022			
0800	Continuous	1500	ARR: 19	SCH - PJM_VFT	0 MW
Work scheduled by: PJM				Impacts Total Transfer Capability	315 MW
				TTC with All Lines In Service	315 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, October 27, 2022 to Friday, April 26, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
NEPTUNE_-DUFFYAVE_345_NEPTUNE					
Wed 11/02/2022	to	Tue 11/08/2022		SCH - PJM_NEPTUNE	0 MW
0600	Continuous	1600		Impacts Total Transfer Capability	660 MW
Work scheduled by: LI				TTC with All Lines In Service	660 MW
NEWBRDGE_345_138_BK_1					
Wed 11/02/2022	to	Tue 11/08/2022		SCH - PJM_NEPTUNE	375 MW
0600	Continuous	1600		Impacts Total Transfer Capability	285 MW
Work scheduled by: LI				TTC with All Lines In Service	660 MW
NEWBRDGE_345_138_BK_2					
Wed 11/02/2022	to	Tue 11/08/2022		SCH - PJM_NEPTUNE	375 MW
0600	Continuous	1600		Impacts Total Transfer Capability	285 MW
Work scheduled by: LI				TTC with All Lines In Service	660 MW
NEWBRDGE-DUFFYAVE_345_501					
Wed 11/02/2022	to	Tue 11/08/2022		SCH - PJM_NEPTUNE	0 MW
0600	Continuous	1600		Impacts Total Transfer Capability	660 MW
Work scheduled by: LI				TTC with All Lines In Service	660 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, October 27, 2022 to Friday, April 26, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
<hr/>					
HOMR_NYW-PIERC_NY_345_48					
Wed 11/02/2022	to	Wed 11/02/2022	UPDATED by PJM 10/25/2022 13:37	SCH - PJ - NY	
0800	Continuous	1500		Impacts Total Transfer Capability	
Work scheduled by: NYSEG				TTC with All Lines In Service	
<hr/>					
BECK___-PACKARD_230_BP76				FWD	REV
				(Import)	(Export)
Thu 11/03/2022	to	Thu 11/03/2022		SCH - OH - NY	
0730	Daily(No Weekends)	1200		Impacts Total Transfer Capability	
Work scheduled by: NGrid				TTC with All Lines In Service	
<hr/>					
CEDARS_-ROSEMNTB_115_2/22				FWD	REV
				(Import)	(Export)
Mon 11/07/2022	to	Fri 11/11/2022		SCH - HQ_CEDARS	
0700	Continuous	1700		Impacts Total Transfer Capability	
Work scheduled by: NGrid				TTC with All Lines In Service	
<hr/>					

NYISO TRANSFER LIMITATIONS

Page 14 of 48

Number Of Records: 177

Report Run Date: 10/27/2022 12:10 (EPT)

Seasonal Limits

Thursday, October 27, 2022 to Friday, April 26, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
DENNISON-ROSEMNTB_115_2/22					
Mon 11/07/2022	to	Fri 11/11/2022			
0700	Continuous	1700	SCH - HQ_CEDARS	95 MW	100 MW
Work scheduled by: NGrid			Impacts Total Transfer Capability	184 MW	0 MW
			TTC with All Lines In Service	279 MW	100 MW
				FWD	REV
				(Import)	(Export)
DUNWODIE_345KV_3					
Thu 11/10/2022	to	Thu 11/10/2022			
0230	Continuous	0300	UPDATED by ConEd 08/16/2022 09:29	3800 MW	
Work scheduled by: ConEd			SPR/DUN-SOUTH		
			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	4600 MW	
				FWD	REV
				(Import)	(Export)
DUNWODIE_345KV_5					
Thu 11/10/2022	to	Thu 11/10/2022			
0230	Continuous	0300	UPDATED by ConEd 08/16/2022 09:29	3800 MW	
Work scheduled by: ConEd			SPR/DUN-SOUTH		
			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	4600 MW	
				FWD	REV
				(Import)	(Export)
MAINESBG-WATRCURE_345_30					
Thu 11/10/2022	to	Thu 11/10/2022			
0800	Continuous	1600	SCH - PJ - NY	2300 MW	
Work scheduled by: PJM			Impacts Total Transfer Capability	550 MW	
			TTC with All Lines In Service	2850 MW	

NYISO TRANSFER LIMITATIONS

Page 15 of 48

Number Of Records: 177

Report Run Date: 10/27/2022 12:10 (EPT)

Seasonal Limits

Thursday, October 27, 2022 to Friday, April 26, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
ALCOA_PA_115KV_R8105					
Mon 11/14/2022	to	Mon 11/14/2022	MOSES SOUTH	3100 MW	
1230	Daily	1530	Impacts Total Transfer Capability	50 MW	
Work scheduled by: NGrid				TTC with All Lines In Service	3150 MW
DUNWODIE_345KV_7				FWD	REV
				(Import)	(Export)
Wed 11/16/2022	to	Wed 11/16/2022	SPR/DUN-SOUTH	3800 MW	
0100	Continuous	0200	Impacts Total Transfer Capability	800 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_3				FWD	REV
				(Import)	(Export)
Thu 11/17/2022	to	Thu 11/17/2022	SPR/DUN-SOUTH	3800 MW	
0001	Continuous	0030	Impacts Total Transfer Capability	800 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Page 16 of 48

Number Of Records: 177

Report Run Date: 10/27/2022 12:10 (EPT)

Seasonal Limits

Thursday, October 27, 2022 to Friday, April 26, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
DUNWODIE_345KV_4					
Thu 11/17/2022	to	Thu 11/17/2022	SPR/DUN-SOUTH	3800 MW	
0001	Continuous	0030	Impacts Total Transfer Capability	800 MW	
Work scheduled by: ConEd			TTC with All Lines In Service	4600 MW	
PLSNTVLE-DUNWODIE_345_W89					
Thu 11/17/2022	to	Thu 11/17/2022	UPNY CONED	4000 MW	
0001	Continuous	0030	Impacts Total Transfer Capability	3815 MW	
Work scheduled by: ConEd			TTC with All Lines In Service	7815 MW	
DUNWODIE_345KV_3					
Thu 11/17/2022	to	Thu 11/17/2022	SPR/DUN-SOUTH	3800 MW	
1730	Continuous	1800	Impacts Total Transfer Capability	800 MW	
Work scheduled by: ConEd			TTC with All Lines In Service	4600 MW	

NYISO TRANSFER LIMITATIONS

Page 17 of 48

Number Of Records: 177

Report Run Date: 10/27/2022 12:10 (EPT)

Seasonal Limits

Thursday, October 27, 2022 to Friday, April 26, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
DUNWODIE_345KV_4					
Thu 11/17/2022	to	Thu 11/17/2022			
1730	Continuous	1800	SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	4600 MW	
				FWD	REV
				(Import)	(Export)
PLSNTVLE-DUNWODIE_345_W89					
Thu 11/17/2022	to	Thu 11/17/2022			
1730	Continuous	1800	UPNY CONED	4000 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	3815 MW	
			TTC with All Lines In Service	7815 MW	
				FWD	REV
				(Import)	(Export)
BUCHAN_N-EASTVIEW_345_W93					
Mon 11/21/2022	to	Mon 11/28/2022			
0001	Continuous	0200	UPDATED by ConEd 09/07/2022 11:39	UPNY CONED	4350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	3465 MW
				TTC with All Lines In Service	7815 MW
				FWD	REV
				(Import)	(Export)
EASTVIEW-SPRNBK__345_W79					
Mon 11/21/2022	to	Mon 11/21/2022			
0001	Continuous	0030	UPDATED by ConEd 09/07/2022 11:39	UPNY CONED	4350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	3465 MW
				TTC with All Lines In Service	7815 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits			Thursday, October 27, 2022 to Friday, April 26, 2024		FWD	REV
RAMAPO - BUCHAN_N_345_W04					(Import)	(Export)
Mon 11/21/2022	to	Mon 11/28/2022			UPNY CONED	7580 MW
0001	Continuous	0200			Impacts Total Transfer Capability	230 MW
CENTRAL EAST scheduled by: ConEd					TTC with All Lines In Service	7815 MW
CENTRAL EAST - VC 2585 MW						
TOTAL EAST ----- 6000 MW						REV
UPNY CONED PARRAGUT_345_W5					UPNY CONED	7580 MW
Wed 11/23/2022	to	Sat 12/10/2022			Impacts Total Transfer Capability	230 MW
0001	Continuous	0300			TTC with All Lines In Service	7815 MW
SPR/DWN SOUTH 4600 MW						
DYSINGER EAST 3200 MW						
MOSES SOUTH 3150 MW						
Work scheduled by: ConEd						
					TTC with All Lines In Service	4600 MW
HOMRC_NY-MAINS_NY_345_47					FWD	REV
Wed 11/23/2022	to	Wed 11/23/2022			(Import)	(Export)
0800	Continuous	1600				
Work scheduled by: PJM					SCH - PJ - NY	
					Impacts Total Transfer Capability	
					TTC with All Lines In Service	
EASTVIEW-SPRNBK__345_W79					FWD	REV
Mon 11/28/2022	to	Mon 11/28/2022			(Import)	(Export)
0130	Continuous	0200				
Work scheduled by: ConEd					UPNY CONED	4350 MW
					Impacts Total Transfer Capability	3465 MW
					TTC with All Lines In Service	7815 MW
BUCHAN_S-MILLWOOD_345_W98					FWD	REV
Tue 11/29/2022	to	Thu 12/01/2022			(Import)	(Export)
0001	Continuous	0200				
Work scheduled by: ConEd					UPNY CONED	7680 MW
					Impacts Total Transfer Capability	135 MW
					TTC with All Lines In Service	7815 MW
MILLWOOD_345KV_18					FWD	REV
Tue 11/29/2022	to	Thu 12/01/2022			(Import)	(Export)
0001	Continuous	0200				
Work scheduled by: ConEd					UPNY CONED	4350 MW
					Impacts Total Transfer Capability	3465 MW
					TTC with All Lines In Service	7815 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and NAMI values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NYISO TRANSFER LIMITATIONS

Page 19 of 48

Number Of Records: 177

Report Run Date: 10/27/2022 12:10 (EPT)

Seasonal Limits

Thursday, October 27, 2022 to Friday, April 26, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
CRICKVLY-PLSNTVLY_345_F84					
Thu 12/01/2022	to	Fri 12/16/2022		SCH - NE - NY	600 MW
0001	Continuous	0200		Impacts Total Transfer Capability	800 MW
Work scheduled by: ConEd				TTC with All Lines In Service	1400 MW
CRICKVLY-PLSNTVLY_345_F84					
Thu 12/01/2022	to	Fri 12/16/2022		SCH - NPX_1385	100 MW
0001	Continuous	0200		Impacts Total Transfer Capability	100 MW
Work scheduled by: ConEd				TTC with All Lines In Service	200 MW
CHASLAKE-PORTER__230_11					
Thu 12/01/2022	to	Wed 05/31/2023		MOSES SOUTH	2300 MW
0630	Continuous	1700		Impacts Total Transfer Capability	850 MW
Work scheduled by: NGrid				TTC with All Lines In Service	3150 MW
MOSES__-ADIRNDCK_230_MA1					
Thu 12/01/2022	to	Wed 03/01/2023		MOSES SOUTH	2300 MW
0701	Continuous	1100		Impacts Total Transfer Capability	850 MW
Work scheduled by: NYPA				TTC with All Lines In Service	3150 MW

UPDATED by NYPA 09/02/2022 14:08

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, October 27, 2022 to Friday, April 26, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
MILLWOOD_345KV_18					
Fri 12/02/2022	to	Mon 12/12/2022			
0001	Continuous	1800	UPNY CONED	4350 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	3465 MW	
			TTC with All Lines In Service	7815 MW	
W49TH_ST-E13THSTA_345_M54					
Fri 12/02/2022	to	Fri 12/02/2022			
0001	Continuous	0030	SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	4600 MW	
W49TH_ST-E13THSTA_345_M54					
Sat 12/03/2022	to	Sat 12/03/2022			
0130	Continuous	0200	SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	4600 MW	
FRASER_-COOPERS_345_33					
Wed 12/07/2022	to	Wed 12/07/2022			
0700	Continuous	1700	CENTRAL EAST - VC	2335 MW	
Work scheduled by: NYSEG			Impacts Total Transfer Capability	250 MW	
			TTC with All Lines In Service	2585 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, October 27, 2022 to Friday, April 26, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
MARCY___345KV_CSC					
Wed 12/07/2022	to	Tue 12/20/2022			
0700	Continuous	1530	CENTRAL EAST - VC	2535 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	50 MW	
			TTC with All Lines In Service	2585 MW	
LAFAYTTE-CLRKSCRN_345_4-46				FWD	REV
				(Import)	(Export)
Thu 12/08/2022	to	Sun 12/11/2022			
0800	Continuous	1600	CENTRAL EAST - VC	2450 MW	
Work scheduled by: NGrid			Impacts Total Transfer Capability	135 MW	
			TTC with All Lines In Service	2585 MW	
PIERCBRK-FIVEMILE_345_37				FWD	REV
				(Import)	(Export)
Thu 12/08/2022	to	Thu 12/08/2022			
0800	Continuous	1600	SCH - PJ - NY	2700 MW	
Work scheduled by: PJM			Impacts Total Transfer Capability	150 MW	
			TTC with All Lines In Service	2850 MW	
SPRNBK_-TREMONT_345_X28				FWD	REV
				(Import)	(Export)
Fri 12/09/2022	to	Fri 12/09/2022			
0001	Continuous	0030	SPR/DUN-SOUTH	4200 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	400 MW	
			TTC with All Lines In Service	4600 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, October 27, 2022 to Friday, April 26, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
SPRNBK_-TREMONT__345_X28					
Fri 12/09/2022	to	Fri 12/09/2022			
1730	Continuous	1800	SPR/DUN-SOUTH	4200 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	400 MW	
			TTC with All Lines In Service	4600 MW	
HOPATCON-RAMAPO__500_5018					
Mon 12/12/2022	to	Fri 12/16/2022			
0001	Continuous	2000	TOTAL EAST	5200 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	6000 MW	
HOPATCON-RAMAPO__500_5018					
Mon 12/12/2022	to	Fri 12/16/2022			
0001	Continuous	2000	SCH - PJ - NY	1650 MW	1200 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	1200 MW	1000 MW
			TTC with All Lines In Service	2850 MW	2200 MW
HOPATCON-RAMAPO__500_5018					
Mon 12/12/2022	to	Fri 12/16/2022			
0001	Continuous	2000	UPNY CONED	7480 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	335 MW	
			TTC with All Lines In Service	7815 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, October 27, 2022 to Friday, April 26, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
MARCY___345KV_CSC , HOPATCON-RAMAPO___500_5018					
Mon 12/12/2022	to	Fri 12/16/2022			
0001		2000	TOTAL EAST	5100 MW	
Work scheduled by:			Impacts Total Transfer Capability	900 MW	
			TTC with All Lines In Service	6000 MW	
RAMAPO___345_345_PAR3500				FWD	REV
				(Import)	(Export)
Mon 12/12/2022	to	Fri 12/16/2022	SCH - PJ - NY	2500 MW	1250 MW
0001	Continuous	2000	Impacts Total Transfer Capability	350 MW	950 MW
Work scheduled by: ConEd			TTC with All Lines In Service	2850 MW	2200 MW
RAMAPO___345_345_PAR4500				FWD	REV
				(Import)	(Export)
Mon 12/12/2022	to	Fri 12/16/2022	SCH - PJ - NY	2500 MW	1250 MW
0001	Continuous	2000	Impacts Total Transfer Capability	350 MW	950 MW
Work scheduled by: ConEd			TTC with All Lines In Service	2850 MW	2200 MW
RAMAPO___500_345_BK 1500				FWD	REV
				(Import)	(Export)
Mon 12/12/2022	to	Fri 12/16/2022	SCH - PJ - NY	1650 MW	1200 MW
0001	Continuous	2000	Impacts Total Transfer Capability	1200 MW	1000 MW
Work scheduled by: ConEd			TTC with All Lines In Service	2850 MW	2200 MW

NYISO TRANSFER LIMITATIONS

Page 24 of 48

Number Of Records: 177

Report Run Date: 10/27/2022 12:10 (EPT)

Seasonal Limits

Thursday, October 27, 2022 to Friday, April 26, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
RAMAPO__500_345_BK 1500					
Mon 12/12/2022	to	Fri 12/16/2022			
0001	Continuous	2000	UPNY CONED	7480 MW	
Work scheduled by: ConEd				Impacts Total Transfer Capability	335 MW
				TTC with All Lines In Service	7815 MW
CRICKVLY-PLSNTVLY_345_F83				FWD	REV
				(Import)	(Export)
Fri 12/16/2022	to	Sun 01/01/2023			
0201	Continuous	0200	EXTENDED by ConEd 09/22/2022 10:12	SCH - NPX_1385	100 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	100 MW
				TTC with All Lines In Service	200 MW
CRICKVLY-PLSNTVLY_345_F83				FWD	REV
				(Import)	(Export)
Fri 12/16/2022	to	Sun 01/01/2023			
0201	Continuous	0200	EXTENDED by ConEd 09/22/2022 10:12	SCH - NE - NY	600 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	1400 MW
FRASER__-COOPERS__345_33				FWD	REV
				(Import)	(Export)
Mon 12/19/2022	to	Fri 12/23/2022			
0600	Continuous	1659		CENTRAL EAST - VC	2335 MW
Work scheduled by: NYSEG				Impacts Total Transfer Capability	250 MW
				TTC with All Lines In Service	2585 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, October 27, 2022 to Friday, April 26, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD (Import)	REV (Export)
HOMRC_NY-MAINS_NY_345_47					
Thu 12/22/2022	to	Thu 12/22/2022			
0800	Continuous	1600			
Work scheduled by: PJM			SCH - PJ - NY		
			Impacts Total Transfer Capability		
			TTC with All Lines In Service		
W49TH_ST-E13THSTA_345_M54					
Tue 12/27/2022	to	Tue 12/27/2022		FWD (Import)	REV (Export)
0130	Continuous	0200	UPDATED by ConEd 10/05/2022 15:32		
Work scheduled by: ConEd			SPR/DUN-SOUTH	3800 MW	
			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	4600 MW	
CLAY___-EDIC___345_1-16					
Fri 12/30/2022	to	Sat 12/31/2022		FWD (Import)	REV (Export)
0600	Continuous	1900	UPDATED by NGrid 07/05/2022 10:37		
Work scheduled by: NGrid			OSWEGO EXPORT	4850 MW	
			Impacts Total Transfer Capability	400 MW	
			TTC with All Lines In Service	5250 MW	
FRASER___345_FRASER SVC					
Tue 01/03/2023	to	Tue 02/28/2023		FWD (Import)	REV (Export)
0700	Continuous	1730	UPDATED by NYPA 12/30/2021 15:43		
Work scheduled by: NYPA			CENTRAL EAST - VC	2550 MW	
			Impacts Total Transfer Capability	35 MW	
			TTC with All Lines In Service	2585 MW	

NYISO TRANSFER LIMITATIONS

Page 26 of 48

Number Of Records: 177

Report Run Date: 10/27/2022 12:10 (EPT)

Seasonal Limits

Thursday, October 27, 2022 to Friday, April 26, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
NIAGARA_-PACKARD__230_62					
Mon 01/09/2023	to	Fri 01/20/2023		SCH - OH - NY	
0500	Continuous	1900		Impacts Total Transfer Capability	1400 MW 150 MW
Work scheduled by: NYPA				TTC with All Lines In Service	2300 MW 2000 MW
E13THSTA-FARRAGUT_345_46				FWD	REV
				(Import)	(Export)
Fri 01/27/2023	to	Wed 02/01/2023	CANCELLED by TO 10/27/2022 08:28	SPR/DUN-SOUTH	3800 MW
0001	Continuous	0300		Impacts Total Transfer Capability	800 MW
Work scheduled by: ConEd				TTC with All Lines In Service	4600 MW
E13THSTA-FARRAGUT_345_45				FWD	REV
				(Import)	(Export)
Wed 02/08/2023	to	Wed 02/08/2023		SPR/DUN-SOUTH	3800 MW
0001	Continuous	0030		Impacts Total Transfer Capability	800 MW
Work scheduled by: ConEd				TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_7				FWD	REV
				(Import)	(Export)
Sun 02/19/2023	to	Mon 02/27/2023		SPR/DUN-SOUTH	3800 MW
0001	Continuous	0200		Impacts Total Transfer Capability	800 MW
Work scheduled by: ConEd				TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, October 27, 2022 to Friday, April 26, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
DUNWODIE_345KV_8					
Sun 02/19/2023	to	Mon 02/27/2023			
0001	Continuous	0200	SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	4600 MW	
DUNWODIE-MOTTHAVN_345_72					
Sun 02/19/2023	to	Mon 02/27/2023			
0001	Continuous	0200	SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	4600 MW	
E13THSTA-FARRAGUT_345_45					
Wed 02/22/2023	to	Wed 02/22/2023			
0230	Continuous	0300	SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	4600 MW	
EDIC____-FRASER____345_EF24-40					
Wed 03/01/2023	to	Sat 04/15/2023			
0600	Continuous	1800	CENTRAL EAST - VC	2275 MW	
Work scheduled by: NGrid			Impacts Total Transfer Capability	310 MW	
			TTC with All Lines In Service	2585 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, October 27, 2022 to Friday, April 26, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
GORDONRD-N.SCTLND_345_55					
Wed 03/01/2023	to	Fri 03/31/2023			
0700	Continuous	1600	CENTRAL EAST - VC	2045 MW	
Work scheduled by: LS			Impacts Total Transfer Capability	540 MW	
			TTC with All Lines In Service	2585 MW	
MOSES__-ADIRNDCK_230_MA1					
Wed 03/01/2023	to	Fri 05/26/2023			
1101	Continuous	1930	MOSES SOUTH	2300 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	850 MW	
			TTC with All Lines In Service	3150 MW	
NIAGARA_-ROBNSNRD_230_64					
Mon 03/06/2023	to	Fri 03/17/2023			
0500	Continuous	1900	SCH - OH - NY		1900 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability		100 MW
			TTC with All Lines In Service		2000 MW
N.SCTLND-ALPS____345_2					
Mon 03/27/2023	to	Fri 05/19/2023			
0700	Continuous	1900	SCH - NE - NY	900 MW	
Work scheduled by: NGrid			Impacts Total Transfer Capability	500 MW	
			TTC with All Lines In Service	1400 MW	

UPDATED by NGrid 07/05/2022 10:45

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, October 27, 2022 to Friday, April 26, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
N.SCTLND-ALPS___345_2					
Mon 03/27/2023	to	Fri 05/19/2023			
0700	Continuous	1900	UPDATED by NGrid 07/05/2022 10:45	100 MW	100 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	100 MW
				TTC with All Lines In Service	200 MW
MOTTHAVN-RAINEY___345_Q12				FWD	REV
				(Import)	(Export)
Wed 03/29/2023	to	Sun 04/30/2023			
0001	Continuous	0200	UPDATED by ConEd 09/05/2022 07:25	3800 MW	
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
ATHENS__-PLSNTVLY_345_91				FWD	REV
				(Import)	(Export)
Sat 04/01/2023	to	Sat 04/15/2023			
0700	Continuous	1900		3800 MW	
Work scheduled by: NGrid				Impacts Total Transfer Capability	4015 MW
				TTC with All Lines In Service	7815 MW
PLSNTVLY_345KV_RNS4				FWD	REV
				(Import)	(Export)
Sat 04/01/2023	to	Sat 04/01/2023			
0700	Continuous	0730		3800 MW	
Work scheduled by: NGrid				Impacts Total Transfer Capability	4015 MW
				TTC with All Lines In Service	7815 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, October 27, 2022 to Friday, April 26, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
LINDN_CG-LNDVFT__345_V-3022					
Sun 04/09/2023	to	Sat 04/15/2023	SCH - PJM_VFT	0 MW	0 MW
1400	Continuous	1400	Impacts Total Transfer Capability	315 MW	315 MW
Work scheduled by: PJM			TTC with All Lines In Service	315 MW	315 MW
				FWD	REV
				(Import)	(Export)
DYSINGER-STA_255__345_DH1					
Mon 04/10/2023	to	Fri 04/14/2023	DYSINGER EAST	2850 MW	
0500	Continuous	2000	Impacts Total Transfer Capability	350 MW	
Work scheduled by: NYPA			TTC with All Lines In Service	3200 MW	
				FWD	REV
				(Import)	(Export)
GORDONRD-N.SCTLND_345_55					
Mon 04/10/2023	to	Fri 04/14/2023	CENTRAL EAST - VC	2045 MW	
0600	Continuous	1700	Impacts Total Transfer Capability	540 MW	
Work scheduled by: NGrid			TTC with All Lines In Service	2585 MW	
				FWD	REV
				(Import)	(Export)
DUNWODIE_345KV_3					
Wed 04/12/2023	to	Wed 04/12/2023	SPR/DUN-SOUTH	3800 MW	
0201	Continuous	0230	Impacts Total Transfer Capability	800 MW	
Work scheduled by: ConEd			TTC with All Lines In Service	4600 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, October 27, 2022 to Friday, April 26, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
DUNWODIE_345KV_4					
Wed 04/12/2023	to	Wed 04/12/2023			
0201	Continuous	0230	SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	4600 MW	
PLSNTVLE-DUNWODIE_345_W89					
Wed 04/12/2023	to	Wed 04/12/2023			
0201	Continuous	0230	UPNY CONED	4000 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	3815 MW	
			TTC with All Lines In Service	7815 MW	
PLSNTVLY_345KV_RNS4					
Sat 04/15/2023	to	Sat 04/15/2023			
1830	Continuous	1900	UPNY CONED	3800 MW	
Work scheduled by: NGrid			Impacts Total Transfer Capability	4015 MW	
			TTC with All Lines In Service	7815 MW	
LEEDS__-PLSNTVLY_345_92					
Sun 04/16/2023	to	Sun 04/30/2023			
0700	Continuous	1900	UPNY CONED	3800 MW	
Work scheduled by: NGrid			Impacts Total Transfer Capability	4015 MW	
			TTC with All Lines In Service	7815 MW	

NYISO TRANSFER LIMITATIONS

Page 32 of 48

Number Of Records: 177

Report Run Date: 10/27/2022 12:10 (EPT)

Seasonal Limits

Thursday, October 27, 2022 to Friday, April 26, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
PLSNTVLY_345KV_RNS5					
Sun 04/16/2023	to	Sun 04/16/2023			
0700	Continuous	0730	UPNY CONED	3800 MW	
Work scheduled by: NGrid				Impacts Total Transfer Capability	4015 MW
				TTC with All Lines In Service	7815 MW
E13THSTA-FARRAGUT_345_46					
Mon 04/17/2023	to	Wed 04/19/2023			
0001	Continuous	0200	SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
DYSINGER-STA_255_345_DH2					
Mon 04/17/2023	to	Fri 04/21/2023			
0500	Continuous	2000	DYSINGER EAST	2850 MW	
Work scheduled by: NYPA				Impacts Total Transfer Capability	350 MW
				TTC with All Lines In Service	3200 MW
CLAY____-EDIC____345_2-15					
Mon 04/17/2023	to	Fri 04/28/2023			
0600	Continuous	1800	OSWEGO EXPORT	4850 MW	
Work scheduled by: NGrid				Impacts Total Transfer Capability	400 MW
				TTC with All Lines In Service	5250 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, October 27, 2022 to Friday, April 26, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
DUNWODIE_345KV_3					
Thu 04/20/2023	to	Thu 04/20/2023			
0130	Continuous	0200	SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_4					
Thu 04/20/2023	to	Thu 04/20/2023			
0130	Continuous	0200	SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
PLSNTVLE-DUNWODIE_345_W89					
Thu 04/20/2023	to	Thu 04/20/2023			
0130	Continuous	0200	UPNY CONED	4000 MW	
Work scheduled by: ConEd				Impacts Total Transfer Capability	3815 MW
				TTC with All Lines In Service	7815 MW
PANNELL_-CLAY_345_1					
Mon 04/24/2023	to	Fri 04/28/2023			
0700	Continuous	1530	WEST CENTRAL	1300 MW	
Work scheduled by: NYPA				Impacts Total Transfer Capability	950 MW
				TTC with All Lines In Service	2250 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, October 27, 2022 to Friday, April 26, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
PLSNTVLY_345KV_RNS5					
Sun 04/30/2023	to	Sun 04/30/2023			
1830	Continuous	1900	UPNY CONED	3800 MW	
Work scheduled by: NGrid			Impacts Total Transfer Capability	4015 MW	
			TTC with All Lines In Service	7815 MW	
SHOR_NPX-SHOREHAM_138_CSC					
Mon 05/01/2023	to	Fri 05/05/2023			
0600	Continuous	1800	SCH - NPX_CSC	0 MW	0 MW
Work scheduled by: LI			Impacts Total Transfer Capability	330 MW	330 MW
			TTC with All Lines In Service	330 MW	330 MW
PANNELL_-CLAY____345_2					
Mon 05/01/2023	to	Fri 05/05/2023			
0700	Continuous	1530	WEST CENTRAL	1300 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	950 MW	
			TTC with All Lines In Service	2250 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, October 27, 2022 to Friday, April 26, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
PLSNTVLY_345KV_RNS5					
Wed 05/03/2023	to	Mon 05/15/2023		UPNY CONED	3800 MW
0001	Continuous	2200		Impacts Total Transfer Capability	4015 MW
Work scheduled by: ConEd				TTC with All Lines In Service	7815 MW
PLSNTVLY-WOOD_ST__345_F30					
Wed 05/03/2023	to	Mon 05/15/2023		UPNY CONED	4000 MW
0001	Continuous	2200		Impacts Total Transfer Capability	3815 MW
Work scheduled by: ConEd				TTC with All Lines In Service	7815 MW
NIAGARA_-ROBNSNRD_230_64					
Fri 05/05/2023	to	Fri 05/05/2023		SCH - OH - NY	1400 MW
0500	Continuous	1700		Impacts Total Transfer Capability	150 MW
Work scheduled by: NYPA				TTC with All Lines In Service	1550 MW

NYISO TRANSFER LIMITATIONS

Page 36 of 48

Number Of Records: 177

Report Run Date: 10/27/2022 12:10 (EPT)

Seasonal Limits

Thursday, October 27, 2022 to Friday, April 26, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
W49TH_ST_345KV_6					
Sat 05/06/2023	to	Sat 05/06/2023			
0001	Continuous	0030	SCH - PJM_HTP	300 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	360 MW	
			TTC with All Lines In Service	660 MW	
W49TH_ST_345KV_8					
Sat 05/06/2023	to	Sat 05/06/2023			
0001	Continuous	0030	SCH - PJM_HTP	450 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	210 MW	
			TTC with All Lines In Service	660 MW	
COOPERS_-DOLSONAV_345_CCDA42					
Mon 05/08/2023	to	Sun 05/21/2023			
0700	Continuous	1530	CENTRAL EAST - VC	2485 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	100 MW	
			TTC with All Lines In Service	2585 MW	
DOLSONAV-ROCKTVRN_345_DART44					
Mon 05/08/2023	to	Sat 05/13/2023			
0700	Continuous	1530	CENTRAL EAST - VC	2485 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	100 MW	
			TTC with All Lines In Service	2585 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits			Thursday, October 27, 2022 to Friday, April 26, 2024		FWD	REV
W49TH_ST_345KV_6					(Import)	(Export)
Sat 05/13/2023	to	Sat 05/13/2023	SCH - PJM_HTP		300 MW	
0130	Continuous	0200	Impacts Total Transfer Capability		360 MW	
CENTRAL EAST scheduled by: ConEd			TTC with All Lines In Service		660 MW	
CENTRAL EAST - VC 2585 MW						REV
TOTAL EAST 6000 MW						(Import)
W49TH_ST_345KV_8			SCH - PJM_HTP		450 MW	
W49TH_ST_345KV_8			Impacts Total Transfer Capability		210 MW	
SPR/DUN-SOUTH			TTC with All Lines In Service		660 MW	
Sat 05/13/2023	to	Sat 05/13/2023				REV
DYSINGER EAST			SCH - PJM_HTP		450 MW	
0130	Continuous	0200	Impacts Total Transfer Capability		210 MW	
MOSES SOUTH 3150 MW			TTC with All Lines In Service		660 MW	
Work scheduled by: ConEd						REV
W49TH_ST_345KV_6					(Import)	(Export)
Mon 05/15/2023	to	Mon 05/15/2023	SCH - PJM_HTP		300 MW	
0001	Continuous	0030	Impacts Total Transfer Capability		360 MW	
Work scheduled by: ConEd			TTC with All Lines In Service		660 MW	
W49TH_ST-E13THSTA_345_M55					FWD	REV
					(Import)	(Export)
Mon 05/15/2023	to	Wed 05/17/2023	SPR/DUN-SOUTH		3800 MW	
0001	Continuous	0200	Impacts Total Transfer Capability		800 MW	
Work scheduled by: ConEd			TTC with All Lines In Service		4600 MW	
MOTTHAVN-RAINEY__345_Q11					FWD	REV
					(Import)	(Export)
Wed 05/17/2023	to	Sat 05/20/2023	SPR/DUN-SOUTH		3800 MW	
0001	Continuous	0200	Impacts Total Transfer Capability		800 MW	
Work scheduled by: ConEd			TTC with All Lines In Service		4600 MW	
W49TH_ST_345KV_6					FWD	REV
					(Import)	(Export)
Wed 05/17/2023	to	Wed 05/17/2023	SCH - PJM_HTP		300 MW	
0130	Continuous	0200	Impacts Total Transfer Capability		360 MW	
Work scheduled by: ConEd			TTC with All Lines In Service		660 MW	

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAP values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, October 27, 2022 to Friday, April 26, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
BECK___-NIAGARA_230_PA27					
Tue 05/30/2023	to	Fri 06/02/2023		SCH - OH - NY	
0500	Continuous	2100		Impacts Total Transfer Capability	
Work scheduled by: NYPA				TTC with All Lines In Service	
				FWD	REV
NIAGARA_345_230_AT4				(Import)	(Export)
Wed 06/28/2023	to	Thu 06/29/2023		SCH - OH - NY	1150 MW
0500	Continuous	1900		Impacts Total Transfer Capability	400 MW
Work scheduled by: NYPA				TTC with All Lines In Service	1550 MW
				FWD	REV
NIAGARA_345_230_AT4				(Import)	(Export)
Mon 08/21/2023	to	Fri 08/25/2023		SCH - OH - NY	1150 MW
0500	Continuous	2100		Impacts Total Transfer Capability	400 MW
Work scheduled by: NYPA				TTC with All Lines In Service	1550 MW

NYISO TRANSFER LIMITATIONS

Page 39 of 48

Number Of Records: 177

Report Run Date: 10/27/2022 12:10 (EPT)

Seasonal Limits

Thursday, October 27, 2022 to Friday, April 26, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
ADIRNDCK-PORTER__230_12					
Tue 08/22/2023	to	Tue 08/22/2023			
0700	Continuous	1530	MOSES SOUTH	2100 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	1050 MW	
			TTC with All Lines In Service	3150 MW	
				FWD	REV
				(Import)	(Export)
ADIRNDCK-CHASLAKE_230_13					
Wed 08/23/2023	to	Wed 08/23/2023			
0700	Continuous	1530	MOSES SOUTH	2100 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	1050 MW	
			TTC with All Lines In Service	3150 MW	
				FWD	REV
				(Import)	(Export)
CLAY__-EDIC__345_1-16					
Mon 09/11/2023	to	Fri 09/15/2023			
0700	Continuous	1530	OSWEGO EXPORT	4850 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	400 MW	
			TTC with All Lines In Service	5250 MW	

NYISO TRANSFER LIMITATIONS

Page 40 of 48

Number Of Records: 177

Report Run Date: 10/27/2022 12:10 (EPT)

Seasonal Limits

Thursday, October 27, 2022 to Friday, April 26, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
FRASER__-GILBOA__345_GF5-35					
Mon 09/11/2023	to	Sun 09/17/2023			
0700	Continuous	1530	CENTRAL EAST - VC	2450 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	135 MW	
			TTC with All Lines In Service	2585 MW	
				FWD	REV
				(Import)	(Export)
SPRNBK__345KV_RNS5					
Fri 09/15/2023	to	Mon 10/23/2023			
0001	Continuous	0200	UPDATED by ConEd 08/10/2022 13:51	SPR/DUN-SOUTH	3200 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	1400 MW	
			TTC with All Lines In Service	4600 MW	
				FWD	REV
				(Import)	(Export)
SPRNBK_-W49TH_ST_345_M51					
Fri 09/15/2023	to	Mon 10/23/2023			
0001	Continuous	0200	UPDATED by ConEd 08/10/2022 13:51	SPR/DUN-SOUTH	3200 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	1400 MW	
			TTC with All Lines In Service	4600 MW	
				FWD	REV
				(Import)	(Export)
CLAY__-EDIC__345_2-15					
Mon 09/18/2023	to	Fri 09/22/2023			
0700	Continuous	1530	OSWEGO EXPORT	4850 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	400 MW	
			TTC with All Lines In Service	5250 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, October 27, 2022 to Friday, April 26, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
NIAGARA_-DYSINGER_345_ND2					
Mon 09/25/2023	to	Fri 09/29/2023	DYSINGER EAST	2700 MW	
0500	Continuous	2000	Impacts Total Transfer Capability	500 MW	
Work scheduled by: NYPA				TTC with All Lines In Service	3200 MW
				FWD	REV
				(Import)	(Export)
MARCY___345KV_CSC					
Mon 09/25/2023	to	Sat 10/07/2023	CENTRAL EAST - VC	2535 MW	
0700	Continuous	1530	Impacts Total Transfer Capability	50 MW	
Work scheduled by: NYPA				TTC with All Lines In Service	2585 MW
				FWD	REV
				(Import)	(Export)
SHOR_NPX-SHOREHAM_138_CSC					
Mon 10/02/2023	to	Fri 10/06/2023	SCH - NPX_CSC	0 MW	0 MW
0600	Continuous	1800	Impacts Total Transfer Capability	330 MW	330 MW
Work scheduled by: LI				TTC with All Lines In Service	330 MW

NYISO TRANSFER LIMITATIONS

Page 42 of 48

Number Of Records: 177

Report Run Date: 10/27/2022 12:10 (EPT)

Seasonal Limits

Thursday, October 27, 2022 to Friday, April 26, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
NEPTUNE_-DUFFYAVE_345_NEPTUNE					
Mon 10/09/2023	to	Fri 10/13/2023	SCH - PJM_NEPTUNE	0 MW	
0600	Continuous	1600	Impacts Total Transfer Capability	660 MW	
Work scheduled by: LI			TTC with All Lines In Service	660 MW	
				FWD	REV
				(Import)	(Export)
NEWBRDGE_345_138_BK_1					
Mon 10/09/2023	to	Fri 10/13/2023	SCH - PJM_NEPTUNE	375 MW	
0600	Continuous	1600	Impacts Total Transfer Capability	285 MW	
Work scheduled by: LI			TTC with All Lines In Service	660 MW	
				FWD	REV
				(Import)	(Export)
NEWBRDGE_345_138_BK_2					
Mon 10/09/2023	to	Fri 10/13/2023	SCH - PJM_NEPTUNE	375 MW	
0600	Continuous	1600	Impacts Total Transfer Capability	285 MW	
Work scheduled by: LI			TTC with All Lines In Service	660 MW	
				FWD	REV
				(Import)	(Export)
NEWBRDGE-DUFFYAVE_345_501					
Mon 10/09/2023	to	Fri 10/13/2023	SCH - PJM_NEPTUNE	0 MW	
0600	Continuous	1600	Impacts Total Transfer Capability	660 MW	
Work scheduled by: LI			TTC with All Lines In Service	660 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, October 27, 2022 to Friday, April 26, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
GILBOA__N.SCTLND_345_GNS-1					
Mon 10/09/2023	to	Fri 10/13/2023	CENTRAL EAST - VC	2300 MW	
0700	Continuous	1530	Impacts Total Transfer Capability	285 MW	
Work scheduled by: NYPA				TTC with All Lines In Service	2585 MW
				FWD	REV
				(Import)	(Export)
NIAGARA__PACKARD__230_61					
Fri 10/13/2023	to	Fri 10/13/2023	SCH - OH - NY		1350 MW
0500	Continuous	1900	Impacts Total Transfer Capability		200 MW
Work scheduled by: NYPA				TTC with All Lines In Service	1550 MW
				FWD	REV
				(Import)	(Export)
HURLYAVE-ROSETON__345_303					
Mon 11/13/2023	to	Fri 12/22/2023	UPNY CONED	4100 MW	
0800	Continuous	1600	Impacts Total Transfer Capability	3715 MW	
Work scheduled by: CHGE				TTC with All Lines In Service	7815 MW
				FWD	REV
				(Import)	(Export)
CHATGUAY-MASSENA__765_7040					
Wed 11/15/2023	to	Mon 11/27/2023	SCH - HQ - NY	0 MW	0 MW
0700	Continuous	1730	Impacts Total Transfer Capability	1500 MW	1000 MW
Work scheduled by: NYPA				TTC with All Lines In Service	1500 MW
					1000 MW

NYISO TRANSFER LIMITATIONS

Page 44 of 48

Number Of Records: 177

Report Run Date: 10/27/2022 12:10 (EPT)

Seasonal Limits

Thursday, October 27, 2022 to Friday, April 26, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
CHATGUAY-MASSENA__765_7040					
Wed 11/15/2023	to	Mon 11/27/2023			
0700	Continuous	1730	MOSES SOUTH	1550 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	1600 MW	
			TTC with All Lines In Service	3150 MW	
CHATGUAY-MASSENA__765_7040 , MASSENA_-MARCY__765_MSU1				FWD	REV
				(Import)	(Export)
Wed 11/15/2023	to	Mon 11/27/2023	MOSES SOUTH	500 MW	
0700		1730	Impacts Total Transfer Capability	2650 MW	
Work scheduled by:			TTC with All Lines In Service	3150 MW	
MASSENA_-MARCY__765_MSU1				FWD	REV
				(Import)	(Export)
Wed 11/15/2023	to	Mon 11/27/2023	CENTRAL EAST - VC	1720 MW	
0700	Continuous	1730	Impacts Total Transfer Capability	865 MW	
Work scheduled by: NYPA			TTC with All Lines In Service	2585 MW	
MASSENA_-MARCY__765_MSU1				FWD	REV
				(Import)	(Export)
Wed 11/15/2023	to	Mon 11/27/2023	SCH - HQ_CEDARS	90 MW	
0700	Continuous	1730	Impacts Total Transfer Capability	189 MW	
Work scheduled by: NYPA			TTC with All Lines In Service	279 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, October 27, 2022 to Friday, April 26, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
MASSENA_-MARCY___765_MSU1					
Wed 11/15/2023	to	Mon 11/27/2023		SCH - HQ - NY	475 MW
0700	Continuous	1730		Impacts Total Transfer Capability	1025 MW
Work scheduled by: NYPA				TTC with All Lines In Service	1500 MW
					1000 MW
MASSENA_-MARCY___765_MSU1					
Wed 11/15/2023	to	Mon 11/27/2023		MOSES SOUTH	500 MW
0700	Continuous	1730		Impacts Total Transfer Capability	2650 MW
Work scheduled by: NYPA				TTC with All Lines In Service	3150 MW
MOSES___-MASSENA_230_MMS1 , MOSES___-MASSENA_230_MMS2					
Wed 11/15/2023	to	Mon 11/20/2023		SCH - HQ_CEDARS	90 MW
0700		1530		Impacts Total Transfer Capability	189 MW
Work scheduled by:				TTC with All Lines In Service	279 MW

NYISO TRANSFER LIMITATIONS

Page 46 of 48

Number Of Records: 177

Report Run Date: 10/27/2022 12:10 (EPT)

Seasonal Limits

Thursday, October 27, 2022 to Friday, April 26, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
MOSES___-MASSENA_230_MMS1 , MOSES___-MASSENA_230_MMS2					
Wed 11/15/2023	to	Mon 11/20/2023	SCH - HQ - NY	850 MW	0 MW
0700		1530	Impacts Total Transfer Capability	650 MW	1000 MW
Work scheduled by:				TTC with All Lines In Service	1000 MW
NIAGARA_345_230_AT4				FWD	REV
				(Import)	(Export)
Mon 11/27/2023	to	Fri 12/01/2023	SCH - OH - NY		1750 MW
0500	Continuous	1900	Impacts Total Transfer Capability		250 MW
Work scheduled by: NYPA				TTC with All Lines In Service	2000 MW
HOMR_NYW-PIERC_NY_345_48				FWD	REV
				(Import)	(Export)
Fri 12/08/2023	to	Fri 12/15/2023	SCH - PJ - NY		
0800	Continuous	1600	Impacts Total Transfer Capability		
Work scheduled by: PJM				TTC with All Lines In Service	

UPDATED by PJM 07/28/2022 14:08

NYISO TRANSFER LIMITATIONS

Page 47 of 48

Number Of Records: 177

Report Run Date: 10/27/2022 12:10 (EPT)

Seasonal Limits

Thursday, October 27, 2022 to Friday, April 26, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD (Import)	REV (Export)
HOMRC_NY-MAINS_NY_345_47					
Fri 12/08/2023	to	Fri 12/15/2023			
0800	Continuous	1600	UPDATED by PJM 07/28/2022 14:08		
Work scheduled by: PJM			SCH - PJ - NY		
			Impacts Total Transfer Capability		
			TTC with All Lines In Service		
W49TH_ST_345KV_6					
Mon 01/08/2024	to	Mon 02/19/2024		FWD (Import)	REV (Export)
0001	Continuous	0201	SCH - PJM_HTP	310 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	350 MW	
			TTC with All Lines In Service	660 MW	
W49TH_ST-E13THSTA_345_M55					
Mon 01/08/2024	to	Mon 02/19/2024		FWD (Import)	REV (Export)
0001	Continuous	0201	SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	4600 MW	
W49TH_ST_345KV_8					
Sat 02/03/2024	to	Mon 02/19/2024		FWD (Import)	REV (Export)
0001	Continuous	0201	SCH - PJM_HTP	310 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	350 MW	
			TTC with All Lines In Service	660 MW	

NYISO TRANSFER LIMITATIONS

Page 48 of 48

Number Of Records: 177

Report Run Date: 10/27/2022 12:10 (EPT)
