

# NYISO TRANSFER LIMITATIONS

Sunday ,October 09, 2022 to Tuesday ,April 09, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## HUDSONP\_-FARRAGUT\_345\_B3402

Mon 01/15/2018 to Tue 01/31/2023 EXT FORCE by CONED 08/06/2022  
 0001 Continuous 2359  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SCH - PJ - NY **2050 MW**  
 Impacts Total Transfer Capability 200 MW  
 TTC with All Lines In Service 2250 MW

## HUDSONP\_-FARRAGUT\_345\_B3402 & MARION\_-FARRAGUT\_345\_C3403

Mon 01/15/2018 to Tue 01/31/2023  
 0001 2359  
 Work scheduled by:

FWD REV  
 (Import) (Export)  
 SCH - PJ - NY **2000 MW 1150 MW**  
 Impacts Total Transfer Capability 250 MW 50 MW  
 TTC with All Lines In Service 2250 MW 1200 MW

## MARION\_-FARRAGUT\_345\_C3403

Mon 01/15/2018 to Tue 01/31/2023 EXT FORCE by CONED 08/06/2022  
 0001 Continuous 2359  
 Work scheduled by: ConEd

FWD  
 (Import)  
 SCH - PJ - NY **2050 MW**  
 Impacts Total Transfer Capability 200 MW  
 TTC with All Lines In Service 2250 MW

## GORDONRD-ROTTDAM\_230\_30

Wed 04/27/2022 to Thu 10/06/2022 UPDATED by LS 09/29/2022  
 1122 Continuous 1000  
 Work scheduled by: NYISO

FWD  
 (Import)  
 CENTRAL EAST - VC **2535 MW**  
 Impacts Total Transfer Capability 50 MW  
 TTC with All Lines In Service 2585 MW

## SCH-IMO-NYISO\_LIMIT\_1400

Wed 08/10/2022 to Mon 10/10/2022 EXTENDED by IESO 08/19/2022  
 0800 Continuous 1600  
 Work scheduled by: IESO

FWD  
 (Import)  
 SCH - OH - NY **1700 MW**  
 Impacts Total Transfer Capability 200 MW  
 TTC with All Lines In Service 1900 MW

## BECK\_-NIAGARA\_230\_PA27

Wed 08/24/2022 to Fri 10/28/2022 EXTENDED by IESO 09/26/2022  
 0800 Continuous 1700  
 Work scheduled by: IESO

SCH - OH - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

## SCH-HQ\_CEDARS-NYISO\_LIMIT\_240

Tue 09/06/2022 to Fri 10/28/2022 EXTENDED by HQ 09/27/2022  
 0500 Continuous 1900  
 Work scheduled by: HQ

FWD  
 (Import)  
 SCH - HQ\_CEDARS **240 MW**  
 Impacts Total Transfer Capability 30 MW  
 TTC with All Lines In Service 270 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 09, 2022 to Tuesday ,April 09, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## SCH-NYISO-HQ\_CEDARS\_LIMIT\_0

Tue 09/06/2022 to Fri 10/28/2022  
0500 Continuous 1900

EXTENDED by HQ 09/27/2022

Work scheduled by: HQ

SCH - HQ\_CEDARS

Impacts Total Transfer Capability

TTC with All Lines In Service

REV

(Export)

0 MW

100 MW

100 MW

## MOSES-ADIRNDCK\_230\_MA2

Tue 09/06/2022 to Thu 12/01/2022  
1200 Continuous 0659

UPDATED by NYPA 09/06/2022

Work scheduled by: NYPA

MOSES SOUTH

Impacts Total Transfer Capability 1050 MW

TTC with All Lines In Service 3150 MW

FWD

(Import)

2100 MW

1050 MW

3150 MW

## PLSNTVLY\_345KV\_RN5 &amp; PLSNTVLY\_345KV\_RN4

Fri 09/16/2022 to Sat 10/15/2022  
0001 0300

Work scheduled by:

UPNY CONED

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

FWD

(Import)

3800 MW

4015 MW

7815 MW

## SCH-NE-NYISO\_LIMIT\_100

Fri 09/16/2022 to Sat 10/15/2022  
0001 Continuous 0300

UPDATED by CE 09/16/2022

Work scheduled by: ConEd

SCH - NE - NY

Impacts Total Transfer Capability 1100 MW

TTC with All Lines In Service 1400 MW

FWD

(Import)

300 MW

1100 MW

1400 MW

## HURLYAVE-ROSETON\_345\_303

Mon 09/19/2022 to Fri 12/02/2022  
0800 Continuous 1600

UPDATED by CHGE 10/04/2022

Work scheduled by: CHGE

UPNY CONED

Impacts Total Transfer Capability 3715 MW

TTC with All Lines In Service 7815 MW

FWD

(Import)

4100 MW

3715 MW

7815 MW

## LEEDS-HURLYAVE\_345\_301

Mon 09/19/2022 to Fri 12/02/2022  
0800 Continuous 1600

10/04/2021

Work scheduled by: CHGE

UPNY CONED

Impacts Total Transfer Capability 3715 MW

TTC with All Lines In Service 7815 MW

FWD

(Import)

4100 MW

3715 MW

7815 MW

## MARCY-EDIC\_345\_UE1-7

Tue 09/20/2022 to Sat 10/08/2022  
0500 Continuous 1930

UPDATED by NYPA 08/10/2022

Work scheduled by: NYPA

ARR: 19&16

OSWEGO EXPORT

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

FWD

(Import)

5250 MW

0 MW

5250 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 09, 2022 to Tuesday ,April 09, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## W49TH\_ST-E13THSTA\_345\_M54

FWD

Wed 09/21/2022 to Sun 12/25/2022 UPDATED by CE 09/25/2022

(Import)

0101 Continuous 0200

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

## SCH-NPX\_1385-NYISO\_LIMIT\_125

FWD

Sun 09/25/2022 to Sat 10/15/2022 UPDATED by CE 09/16/2022

(Import)

0001 Continuous 0300

SCH - NPX\_1385

**125 MW**

Impacts Total Transfer Capability 75 MW

TTC with All Lines In Service 200 MW

Work scheduled by: ConEd

## FITZPTRK-EDIC\_\_\_\_345\_FE-1 & GORDONRD-ROTTRDAM\_230\_30

FWD

Mon 09/26/2022 to Thu 10/06/2022

(Import)

0600 1000

CENTRAL EAST - VC

**2430 MW**

Impacts Total Transfer Capability 155 MW

TTC with All Lines In Service 2585 MW

Work scheduled by:

## FITZPTRK-EDIC\_\_\_\_345\_FE-1

FWD

Mon 09/26/2022 to Mon 10/10/2022 EXTENDED by NGRID 10/09/2022

(Import)

0600 Continuous 1800

CENTRAL EAST - VC

**2480 MW**

Impacts Total Transfer Capability 105 MW

TTC with All Lines In Service 2585 MW

Work scheduled by: NGrid

## FITZPTRK-EDIC\_\_\_\_345\_FE-1

FWD

Mon 09/26/2022 to Mon 10/10/2022 EXTENDED by NGRID 10/09/2022

(Import)

0600 Continuous 1800

OSWEGO EXPORT

**4800 MW**

Impacts Total Transfer Capability 450 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NGrid

## MARCY\_\_\_\_345KV\_CSC

FWD

Thu 09/29/2022 to Fri 10/07/2022 UPDATED by NYPA 10/07/2022

(Import)

0500 Continuous 1530

CENTRAL EAST - VC

**2535 MW**

Impacts Total Transfer Capability 50 MW

TTC with All Lines In Service 2585 MW

Work scheduled by: NYPA

## COOPERS\_-MIDDLETP\_345\_CCRT34

FWD

Fri 09/30/2022 to Wed 10/12/2022 EXTENDED by CHGE 10/08/2022

(Import)

0700 Continuous 1600

CENTRAL EAST - VC

**2485 MW**

Impacts Total Transfer Capability 100 MW

TTC with All Lines In Service 2585 MW

Work scheduled by: NYSEG

# NYISO TRANSFER LIMITATIONS

Sunday ,October 09, 2022 to Tuesday ,April 09, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## EGRDNCTY\_345\_138\_AT1

Sat 10/01/2022 to Wed 05/31/2023 UPDATED by CONED 10/09/2022  
0001 Continuous 2359

Work scheduled by: LI

FWD  
(Import)  
CONED - LIPA **1250 MW**  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 1500 MW

## EGRDNCTY\_345\_138\_AT2

Sat 10/01/2022 to Wed 05/31/2023 UPDATED by CONED 10/09/2022  
0001 Continuous 2359

Work scheduled by: LI

FWD  
(Import)  
CONED - LIPA **1250 MW**  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 1500 MW

## SPRNBK\_-EGRDNCTR\_345\_Y49

Sat 10/01/2022 to Wed 05/31/2023 UPDATED by CONED 10/09/2022  
0001 Continuous 2359

Work scheduled by: LI

FWD  
(Import)  
CONED - LIPA **775 MW**  
Impacts Total Transfer Capability 725 MW  
TTC with All Lines In Service 1500 MW

## SPRNBK\_-TREMONT\_\_345\_X28

Sun 10/02/2022 to Wed 10/05/2022 FORCED by CONED 10/03/2022  
1554 Continuous 2359

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **4200 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 4600 MW

## SHOR\_NPX-SHOREHAM\_138\_CSC

Mon 10/03/2022 to Fri 10/21/2022 09/28/2022  
0700 Continuous 1500

Work scheduled by: LI

FWD REV  
(Import) (Export)  
SCH - NPX\_CSC **0 MW** **0 MW**  
Impacts Total Transfer Capability 330 MW 330 MW  
TTC with All Lines In Service 330 MW 330 MW

## SCH-IMO-NYISO\_LIMIT\_850

Mon 10/03/2022 to Fri 10/07/2022 UPDATED by IESO 09/29/2022  
0800 Continuous 1800

Work scheduled by: IESO

FWD  
(Import)  
SCH - OH - NY **1150 MW**  
Impacts Total Transfer Capability 750 MW  
TTC with All Lines In Service 1900 MW

## SCH-NYISO-IMO\_LIMIT\_900

Mon 10/03/2022 to Fri 10/07/2022 UPDATED by IESO 09/29/2022  
0800 Continuous 1800

Work scheduled by: IESO

REV  
(Export)  
SCH - OH - NY **1200 MW**  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 1550 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 09, 2022 to Tuesday ,April 09, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## CLRKSCRN-OAKDALE\_\_345\_36

FWD

Mon 10/03/2022 to Thu 10/06/2022 UPDATED by NYSEG 04/20/2022

(Import)

0830 Continuous 1330

CENTRAL EAST - VC **2450 MW**

Impacts Total Transfer Capability 135 MW

TTC with All Lines In Service 2585 MW

Work scheduled by: NYSEG

## STLAWRNC-MOSES\_\_\_\_230\_L34P

Mon 10/03/2022 to Mon 09/25/2023 UPDATED by IESO 08/15/2022

1800 Continuous 0800

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: IESO

## SCH-NYISO-NE\_LIMIT\_900

REV

Mon 10/03/2022 to Wed 10/05/2022 UPDATED by ISONE 09/29/2022

(Export)

2300 Continuous 0659

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

**1100 MW**

500 MW

1600 MW

Work scheduled by: NGrid

## MAINESBG-WATRCURE\_345\_30

Tue 10/04/2022 to Wed 10/05/2022 CANCELLED by NYSEG 10/04/2022

0830 Continuous 1530

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: NYSEG

## W49TH\_ST\_345KV\_7

FWD

Wed 10/05/2022 to Wed 10/05/2022

(Import)

0201 Continuous 0230

SCH - PJM\_HTP

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

## W49TH\_ST\_345KV\_8

FWD

Wed 10/05/2022 to Wed 10/05/2022

(Import)

0201 Continuous 0230

SCH - PJM\_HTP

Impacts Total Transfer Capability 210 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

## HUDSONTP-W49TH\_ST\_345\_Y56

FWD

Wed 10/05/2022 to Sat 10/08/2022

(Import)

0201 Continuous 1800

SCH - PJM\_HTP

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

# NYISO TRANSFER LIMITATIONS

Sunday ,October 09, 2022 to Tuesday ,April 09, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## MAINESBG-WATRCURE\_345\_30

Wed 10/05/2022 to Thu 10/06/2022 **UPDATED** **by NYSEG** **10/04/2022**  
0800 Continuous 1600

Work scheduled by: NYSEG

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

## DUNWODIE\_345KV\_3

Thu 10/06/2022 to Sun 10/16/2022 **UPDATED** **by CE** **06/30/2022**  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

## DUNWODIE\_345KV\_5

Thu 10/06/2022 to Sun 10/16/2022 **UPDATED** **by CE** **06/30/2022**  
0001 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

## DUNWODIE-MOTTHAVN\_345\_71

Thu 10/06/2022 to Thu 11/10/2022 **UPDATED** **by CE** **06/30/2022**  
0001 Continuous 0300

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

## LEEDS\_\_\_\_345\_LEEDS SVC

Thu 10/06/2022 to Fri 10/07/2022 **CANCELLED** **by NGrid** **10/06/2022**  
0700 Continuous 1200

Work scheduled by: NGrid

FWD  
(Import)  
CENTRAL EAST - VC **2570 MW**  
Impacts Total Transfer Capability 15 MW  
TTC with All Lines In Service 2585 MW

## HOPATCON-RAMAPO\_\_\_\_500\_5018 & MARCY\_\_\_\_345KV\_CSC

Fri 10/07/2022 to Fri 10/07/2022  
1145 1530

Work scheduled by:

TOTAL EAST  
Impacts Total Transfer Capability  
TTC with All Lines In Service

## HOPATCON-RAMAPO\_\_\_\_500\_5018

Fri 10/07/2022 to Sun 10/09/2022 **FORCED** **by PJM** **10/07/2022**  
1145 Continuous 2359

Work scheduled by: PJM

FWD REV  
(Import) (Export)  
SCH - PJ - NY **1100 MW 1000 MW**  
Impacts Total Transfer Capability 1150 MW 200 MW  
TTC with All Lines In Service 2250 MW 1200 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 09, 2022 to Tuesday ,April 09, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## HOPATCON-RAMAPO\_\_\_500\_5018

Fri 10/07/2022 to Sun 10/09/2022 **FORCED** by PJM 10/07/2022  
1145 Continuous 2359

Work scheduled by: PJM

TOTAL EAST  
Impacts Total Transfer Capability  
TTC with All Lines In Service

## HOPATCON-RAMAPO\_\_\_500\_5018

Fri 10/07/2022 to Sun 10/09/2022 **FORCED** by PJM 10/07/2022  
1145 Continuous 2359

Work scheduled by: PJM

FWD  
(Import)  
UPNY CONED **7480 MW**  
Impacts Total Transfer Capability 335 MW  
TTC with All Lines In Service 7815 MW

## RAMAPO\_\_\_345\_345\_PAR3500

Fri 10/07/2022 to Sun 10/09/2022 **FORCED** by PJM 10/07/2022  
1145 Continuous 2359

Work scheduled by: PJM

FWD  
(Import)  
SCH - PJ - NY **1750 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 2250 MW

## RAMAPO\_\_\_345\_345\_PAR4500

Fri 10/07/2022 to Sun 10/09/2022 **FORCED** by PJM 10/07/2022  
1145 Continuous 2359

Work scheduled by: PJM

FWD  
(Import)  
SCH - PJ - NY **1750 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 2250 MW

## RAMAPO\_\_\_500\_345\_BK 1500

Fri 10/07/2022 to Sun 10/09/2022 **FORCED** by PJM 10/07/2022  
1145 Continuous 2359

Work scheduled by: PJM

FWD REV  
(Import) (Export)  
SCH - PJ - NY **1100 MW 1000 MW**  
Impacts Total Transfer Capability 1150 MW 200 MW  
TTC with All Lines In Service 2250 MW 1200 MW

## RAMAPO\_\_\_500\_345\_BK 1500

Fri 10/07/2022 to Sun 10/09/2022 **FORCED** by PJM 10/07/2022  
1145 Continuous 2359

Work scheduled by: PJM

FWD  
(Import)  
UPNY CONED **7480 MW**  
Impacts Total Transfer Capability 335 MW  
TTC with All Lines In Service 7815 MW

## CHAT\_DC\_GC1

Sun 10/09/2022 to Sun 11/06/2022  
0400 Continuous 2200

Work scheduled by: HQ

FWD  
(Import)  
MOSES SOUTH **2850 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 09, 2022 to Tuesday ,April 09, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>CHAT_DC_GC1</b>						REV
Sun 10/09/2022	to	Sun 11/06/2022				(Export)
0400	Continuous	2200			SCH - HQ - NY	<b>500 MW</b>
Work scheduled by: HQ					Impacts Total Transfer Capability	500 MW
					TTC with All Lines In Service	1000 MW
<b>SCH-NYISO-HQ_LIMIT_500</b>						REV
Sun 10/09/2022	to	Sun 11/06/2022				(Export)
0400	Continuous	2200			SCH - HQ - NY	<b>500 MW</b>
Work scheduled by: HQ					Impacts Total Transfer Capability	500 MW
					TTC with All Lines In Service	1000 MW
<b>SPRNBK__345KV_RNS4</b>						FWD
Mon 10/10/2022	to	Mon 10/10/2022	<u>UPDATED</u>	<u>by CE</u>	<u>10/09/2022</u>	(Import)
0001	Continuous	0030			SPR/DUN-SOUTH	<b>3200 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	4600 MW
<b>EASTVIEW-SPRNBK__345_W65</b>						FWD
Mon 10/10/2022	to	Thu 10/13/2022	<u>UPDATED</u>	<u>by CE</u>	<u>10/09/2022</u>	(Import)
0001	Continuous	0200			UPNY CONED	<b>4350 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	3465 MW
					TTC with All Lines In Service	7815 MW
<b>MILLWOOD-EASTVIEW_345_W82</b>						FWD
Mon 10/10/2022	to	Thu 10/13/2022	<u>UPDATED</u>	<u>by CE</u>	<u>10/09/2022</u>	(Import)
0001	Continuous	0200			UPNY CONED	<b>7550 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	265 MW
					TTC with All Lines In Service	7815 MW
<b>EDIC____-GORDONRD_345_14</b>						FWD
Mon 10/10/2022	to	Mon 10/31/2022	<u>UPDATED</u>	<u>by NYPA</u>	<u>05/17/2022</u>	(Import)
0700	Continuous	1530			CENTRAL EAST - VC	<b>1670 MW</b>
Work scheduled by: NYPA					Impacts Total Transfer Capability	915 MW
					TTC with All Lines In Service	2585 MW
<b>SCRIBA__-VOLNEY__345_21</b>						FWD
Mon 10/10/2022	to	Fri 10/14/2022				(Import)
0730	Continuous	1700			OSWEGO EXPORT	<b>5250 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability	0 MW
					TTC with All Lines In Service	5250 MW



# NYISO TRANSFER LIMITATIONS

Sunday ,October 09, 2022 to Tuesday ,April 09, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SPRNBK__345KV_RNS4</b>						FWD
Thu 10/13/2022	to	Thu 10/13/2022	<u>UPDATED</u>	<u>by CE</u>	<u>10/09/2022</u>	(Import)
0130	Continuous	0200				SPR/DUN-SOUTH <b>3200 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability 1400 MW
						TTC with All Lines In Service 4600 MW
<b>MILLWOOD-EASTVIEW_345_W99</b>						FWD
Thu 10/13/2022	to	Thu 10/13/2022	<u>UPDATED</u>	<u>by CE</u>	<u>10/09/2022</u>	(Import)
0201	Continuous	0230				UPNY CONED <b>7550 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability 265 MW
						TTC with All Lines In Service 7815 MW
<b>SPRNBK__345KV_RNS5</b>						FWD
Thu 10/13/2022	to	Thu 10/13/2022	<u>UPDATED</u>	<u>by CE</u>	<u>10/09/2022</u>	(Import)
0201	Continuous	0230				SPR/DUN-SOUTH <b>3200 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability 1400 MW
						TTC with All Lines In Service 4600 MW
<b>EASTVIEW-SPRNBK__345_W64</b>						FWD
Thu 10/13/2022	to	Sun 10/16/2022	<u>UPDATED</u>	<u>by CE</u>	<u>10/09/2022</u>	(Import)
0201	Continuous	0200				UPNY CONED <b>4350 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability 3465 MW
						TTC with All Lines In Service 7815 MW
<b>MILLWOOD-EASTVIEW_345_W99</b>						FWD
Sun 10/16/2022	to	Sun 10/16/2022	<u>UPDATED</u>	<u>by CE</u>	<u>10/09/2022</u>	(Import)
0130	Continuous	0200				UPNY CONED <b>7550 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability 265 MW
						TTC with All Lines In Service 7815 MW
<b>EASTVIEW-SPRNBK__345_W79</b>						FWD
Mon 10/17/2022	to	Mon 10/17/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>09/07/2022</u>	(Import)
0001	Continuous	0031				UPNY CONED <b>4350 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability 3465 MW
						TTC with All Lines In Service 7815 MW
<b>BUCHAN_N-EASTVIEW_345_W93</b>						FWD
Mon 10/17/2022	to	Fri 10/28/2022	<u>UPDATED</u>	<u>by CONED</u>	<u>09/07/2022</u>	(Import)
0001	Continuous	0200				UPNY CONED <b>4350 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability 3465 MW
						TTC with All Lines In Service 7815 MW

CENTRAL EAST 2650MW  
CENTRAL EAST - VC 2585MW  
TOTAL EAST 6000MW  
UPNY CONED 7815MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3200MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## CHATGUAY-MASSENA\_\_765\_7040

Mon 10/17/2022 to Mon 10/24/2022  
0100 Continuous 1800

Work scheduled by: HQ

FWD  
(Import)  
MOSES SOUTH 1550 MW  
Impacts Total Transfer Capability 1600 MW  
TTC with All Lines In Service 3150 MW

## CHATGUAY-MASSENA\_\_765\_7040

Mon 10/17/2022 to Mon 10/24/2022  
0100 Continuous 1800

Work scheduled by: HQ

FWD REV  
(Import) (Export)  
SCH - HQ - NY 0 MW 0 MW  
Impacts Total Transfer Capability 1500 MW 1000 MW  
TTC with All Lines In Service 1500 MW 1000 MW

## CHAT\_DC\_GC1 & CHAT\_DC\_GC2

Mon 10/17/2022 to Mon 10/24/2022  
0100 1800

Work scheduled by:

FWD  
(Import)  
MOSES SOUTH 2550 MW  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 3150 MW

## CHAT\_DC\_GC1 & CHAT\_DC\_GC2

Mon 10/17/2022 to Mon 10/24/2022  
0100 1800

Work scheduled by:

FWD REV  
(Import) (Export)  
SCH - HQ - NY 1370 MW 0 MW  
Impacts Total Transfer Capability 130 MW 1000 MW  
TTC with All Lines In Service 1500 MW 1000 MW

## CHAT\_DC\_GC2

Mon 10/17/2022 to Mon 10/24/2022  
0100 Continuous 1800

Work scheduled by: HQ

FWD  
(Import)  
MOSES SOUTH 2850 MW  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

## CHAT\_DC\_GC2

Mon 10/17/2022 to Mon 10/24/2022  
0100 Continuous 1800

Work scheduled by: HQ

REV  
(Export)  
SCH - HQ - NY 500 MW  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1000 MW

## NIAGARA\_-DYSINGER\_345\_ND1

Mon 10/17/2022 to Fri 10/21/2022  
0500 Continuous 1700

Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST 2700 MW  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 3200 MW

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**ALCOA\_PA\_115KV\_R8105**

Mon 10/17/2022 to Wed 10/19/2022  
0800 Daily(No Weekends) 1630  
Work scheduled by: NGrid

FWD  
(Import)  
MOSES SOUTH **3100 MW**  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 3150 MW

**RAMAPO\_\_-BUCHAN\_N\_345\_Y94**

Tue 10/18/2022 to Sun 10/30/2022  
0001 Continuous 0200  
Work scheduled by: ConEd

UPDATED by CONED 09/07/2022

FWD  
(Import)  
UPNY CONED **7580 MW**  
Impacts Total Transfer Capability 235 MW  
TTC with All Lines In Service 7815 MW

**FIVEMILE-ESTOLERD\_345\_29**

Tue 10/18/2022 to Tue 10/18/2022  
0730 Daily(No Weekends) 1230  
Work scheduled by: NGrid

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

**FRASANNX-COOPERS\_\_345\_UCC2-41**

Tue 10/18/2022 to Wed 10/19/2022  
0730 Continuous 1800  
Work scheduled by: NYSEG

ARR: 19

FWD  
(Import)  
CENTRAL EAST - VC **2275 MW**  
Impacts Total Transfer Capability 310 MW  
TTC with All Lines In Service 2585 MW

**MARCY\_\_-FRASANNX\_345\_UCC2-41**

Tue 10/18/2022 to Wed 10/19/2022  
0730 Continuous 1800  
Work scheduled by: NYSEG

ARR: 19

FWD  
(Import)  
CENTRAL EAST - VC **2275 MW**  
Impacts Total Transfer Capability 310 MW  
TTC with All Lines In Service 2585 MW

**PANNELL\_-CLAY\_\_\_\_345\_1**

Mon 10/24/2022 to Fri 10/28/2022  
0700 Continuous 1530  
Work scheduled by: NYPA

UPDATED by NYPA 09/01/2022

FWD  
(Import)  
WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

**ELBRIDGE-LAFAYTTE\_345\_17-LE**

Tue 10/25/2022 to Tue 10/25/2022  
0630 Continuous 1700  
Work scheduled by: NGrid

ARR: 75

FWD  
(Import)  
OSWEGO EXPORT **5250 MW**  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

CENTRAL EAST 2650MW  
CENTRAL EAST - VC 2585MW  
TOTAL EAST 6000MW  
UPNY CONED 7815MW  
SPR/DUN-SOUTH 4600MW  
DYSINGER EAST 3200MW  
MOSES SOUTH 3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## OSWEGO\_\_ -ELBRIDGE\_345\_17

FWD

Tue 10/25/2022 to Tue 10/25/2022

(Import)

0630 Continuous 1700

OSWEGO EXPORT

5250 MW

Work scheduled by: NGrid

ARR: 75

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

## MAINESBG-WATRCURE\_345\_30

Tue 10/25/2022 to Tue 10/25/2022

0800 Daily 1500

Work scheduled by: NYSEG

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

## LEEDS\_\_\_345KV\_R395

FWD

Wed 10/26/2022 to Wed 10/26/2022

(Import)

0900 Daily(No Weekends) 1030

Work scheduled by: NGrid

UPNY CONED

3800 MW

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

## WATRCURE-OAKDALE\_\_345\_31

Thu 10/27/2022 to Thu 10/27/2022

0800 Daily 1500

Work scheduled by: NYSEG

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

## EASTVIEW-SPRNBK\_\_345\_W79

FWD

Fri 10/28/2022 to Fri 10/28/2022

(Import)

0130 Continuous 0200

Work scheduled by: ConEd

UPDATEDby CONED09/07/2022

UPNY CONED

4350 MW

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

## PANNELL\_-CLAY\_\_\_\_345\_2

FWD

Mon 10/31/2022 to Fri 11/04/2022

(Import)

0700 Continuous 1530

Work scheduled by: NYPA

UPDATEDby NYPA09/01/2022

WEST CENTRAL

1300 MW

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW

## BUCHAN\_S-MILLWOOD\_345\_W97

FWD

Tue 11/01/2022 to Wed 11/02/2022

(Import)

0001 Continuous 0200

Work scheduled by: ConEd

UPNY CONED

7680 MW

Impacts Total Transfer Capability 135 MW

TTC with All Lines In Service 7815 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 09, 2022 to Tuesday ,April 09, 2024

## Seasonal Limits

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>CLAY -EDIC 345_1-16</b>					FWD	
Tue 11/01/2022	to	Thu 11/03/2022	<u>UPDATED</u>	<u>by NGRID</u> <u>05/09/2022</u>	(Import)	
0600	Continuous	1900			OSWEGO EXPORT	<b>4850 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability	400 MW
					TTC with All Lines In Service	5250 MW
<b>GILBOA -N.SCTLND 345_GNS-1</b>					FWD	
Tue 11/01/2022	to	Tue 12/06/2022	<u>UPDATED</u>	<u>by NGRID</u> <u>12/29/2021</u>	(Import)	
0700	Continuous	1900			CENTRAL EAST - VC	<b>2300 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability	285 MW
					TTC with All Lines In Service	2585 MW
<b>MARCY -N.SCTLND 345_18</b>					FWD	
Tue 11/01/2022	to	Tue 12/06/2022	<u>UPDATED</u>	<u>by NGRID</u> <u>12/29/2021</u>	(Import)	
0700	Continuous	1900			CENTRAL EAST - VC	<b>1345 MW</b>
Work scheduled by: NGrid					Impacts Total Transfer Capability	1240 MW
					TTC with All Lines In Service	2585 MW
<b>LINDN_CG-LNDVFT 345_V-3022</b>					FWD	REV
Tue 11/01/2022	to	Fri 11/04/2022			(Import)	(Export)
0800	Continuous	1500			SCH - PJM_VFT	<b>0 MW 0 MW</b>
Work scheduled by: PJM					Impacts Total Transfer Capability	315 MW 315 MW
					TTC with All Lines In Service	315 MW 315 MW
<b>NEPTUNE -DUFFYAVE 345_NEPTUNE</b>					FWD	
Wed 11/02/2022	to	Tue 11/08/2022			(Import)	
0600	Continuous	1600			SCH - PJM_NEPTUNE	<b>0 MW</b>
Work scheduled by: LI					Impacts Total Transfer Capability	660 MW
					TTC with All Lines In Service	660 MW
<b>NEWBRDGE-DUFFYAVE 345_501</b>					FWD	
Wed 11/02/2022	to	Tue 11/08/2022			(Import)	
0600	Continuous	1600			SCH - PJM_NEPTUNE	<b>0 MW</b>
Work scheduled by: LI					Impacts Total Transfer Capability	660 MW
					TTC with All Lines In Service	660 MW
<b>NEWBRDGE 345_138_BK_1</b>					FWD	
Wed 11/02/2022	to	Tue 11/08/2022			(Import)	
0600	Continuous	1600			SCH - PJM_NEPTUNE	<b>375 MW</b>
Work scheduled by: LI					Impacts Total Transfer Capability	285 MW
					TTC with All Lines In Service	660 MW

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**NEWBRIDGE\_345\_138\_BK\_2**

Wed 11/02/2022 to Tue 11/08/2022  
0600 Continuous 1600

Work scheduled by: LI

FWD  
(Import)  
SCH - PJM\_NEPTUNE **375 MW**  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 660 MW

**DUNWODIE\_345KV\_3**

Thu 11/10/2022 to Thu 11/10/2022  
0230 Continuous 0300

Work scheduled by: ConEd

UPDATED by CE 06/30/2022

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_5**

Thu 11/10/2022 to Thu 11/10/2022  
0230 Continuous 0300

Work scheduled by: ConEd

UPDATED by CE 06/30/2022

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**MAINESBG-WATRCURE\_345\_30**

Thu 11/10/2022 to Thu 11/10/2022  
0800 Continuous 1600

Work scheduled by: PJM

FWD  
(Import)  
SCH - PJ - NY **2300 MW**  
Impacts Total Transfer Capability 550 MW  
TTC with All Lines In Service 2850 MW

**DUNWODIE\_345KV\_7**

Wed 11/16/2022 to Wed 11/16/2022  
0100 Continuous 0200

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

**EASTVIEW-SPRNBK\_345\_W79**

Sat 11/19/2022 to Sat 11/19/2022  
0001 Continuous 0030

Work scheduled by: ConEd

UPDATED by CONED 09/07/2022

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

**BUCHAN\_N-EASTVIEW\_345\_W93**

Sat 11/19/2022 to Sat 11/26/2022  
0001 Continuous 0200

Work scheduled by: ConEd

UPDATED by CONED 09/07/2022

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 09, 2022 to Tuesday ,April 09, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**RAMAPO\_\_-BUCHAN\_N\_345\_Y94**

FWD

Sat 11/19/2022 to Sat 11/26/2022 UPDATED by CONED 09/07/2022

(Import)

0001 Continuous 0200

Work scheduled by: ConEd

UPNY CONED **7580 MW**  
 Impacts Total Transfer Capability 235 MW  
 TTC with All Lines In Service 7815 MW

**E13THSTA-FARRAGUT\_345\_45**

FWD

Wed 11/23/2022 to Sat 12/10/2022 UPDATED by CONED 09/07/2022

(Import)

0001 Continuous 0300

Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

**HOMRC\_NY-MAINS\_NY\_345\_47**Wed 11/23/2022 to Wed 11/23/2022 UPDATED by PJM 08/09/2022

0800 Continuous 1600

Work scheduled by: PJM

SCH - PJ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

**EASTVIEW-SPRNBK\_\_345\_W79**

FWD

Sat 11/26/2022 to Sat 11/26/2022 UPDATED by CONED 09/07/2022

(Import)

0130 Continuous 0200

Work scheduled by: ConEd

UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 3465 MW  
 TTC with All Lines In Service 7815 MW

**BUCHAN\_S-MILLWOOD\_345\_W98**

FWD

Tue 11/29/2022 to Thu 12/01/2022

(Import)

0001 Continuous 0200

Work scheduled by: ConEd

UPNY CONED **7680 MW**  
 Impacts Total Transfer Capability 135 MW  
 TTC with All Lines In Service 7815 MW

**MILLWOOD\_345KV\_18**

FWD

Tue 11/29/2022 to Thu 12/01/2022

(Import)

0001 Continuous 0200

Work scheduled by: ConEd

UPNY CONED **4350 MW**  
 Impacts Total Transfer Capability 3465 MW  
 TTC with All Lines In Service 7815 MW

**CRICKVLY-PLSNTVLY\_345\_F84**

FWD

Thu 12/01/2022 to Fri 12/16/2022

(Import)

0001 Continuous 0200

Work scheduled by: ConEd

SCH - NE - NY **600 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 1400 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 09, 2022 to Tuesday ,April 09, 2024

## Seasonal Limits

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### CRICKVLY-PLSNTVLY\_345\_F84

Thu 12/01/2022 to Fri 12/16/2022  
0001 Continuous 0200

Work scheduled by: ConEd

	FWD	REV
	(Import)	(Export)
SCH - NPX_1385	100 MW	100 MW
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

### MOSES-ADIRNDCK\_230\_MAI

Thu 12/01/2022 to Wed 03/01/2023  
0701 Continuous 1100

Work scheduled by: NYPA

UPDATED by NYPA 09/02/2022

	FWD
	(Import)
MOSES SOUTH	2300 MW
Impacts Total Transfer Capability	850 MW
TTC with All Lines In Service	3150 MW

### MILLWOOD\_345KV\_18

Fri 12/02/2022 to Mon 12/12/2022  
0001 Continuous 1800

Work scheduled by: ConEd

	FWD
	(Import)
UPNY CONED	4350 MW
Impacts Total Transfer Capability	3465 MW
TTC with All Lines In Service	7815 MW

### MARCY-345KV\_CSC

Wed 12/07/2022 to Tue 12/20/2022  
0700 Continuous 1530

Work scheduled by: NYPA

	FWD
	(Import)
CENTRAL EAST - VC	2535 MW
Impacts Total Transfer Capability	50 MW
TTC with All Lines In Service	2585 MW

### HOPATCON-RAMAPO-500\_5018

Mon 12/12/2022 to Fri 12/16/2022  
0001 Continuous 2000

Work scheduled by: ConEd

	FWD	REV
	(Import)	(Export)
SCH - PJ - NY	1650 MW	1200 MW
Impacts Total Transfer Capability	1200 MW	1000 MW
TTC with All Lines In Service	2850 MW	2200 MW

### HOPATCON-RAMAPO-500\_5018

Mon 12/12/2022 to Fri 12/16/2022  
0001 Continuous 2000

Work scheduled by: ConEd

	FWD
	(Import)
TOTAL EAST	5200 MW
Impacts Total Transfer Capability	800 MW
TTC with All Lines In Service	6000 MW

### HOPATCON-RAMAPO-500\_5018

Mon 12/12/2022 to Fri 12/16/2022  
0001 Continuous 2000

Work scheduled by: ConEd

	FWD
	(Import)
UPNY CONED	7480 MW
Impacts Total Transfer Capability	335 MW
TTC with All Lines In Service	7815 MW



CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HOPATCON-RAMAPO\_\_\_500\_5018 & MARCY\_\_\_345KV\_CSC

FWD

Mon 12/12/2022 to Fri 12/16/2022

(Import)

0001

2000

TOTAL EAST

5100 MW

Impacts Total Transfer Capability 900 MW

TTC with All Lines In Service 6000 MW

Work scheduled by:

RAMAPO\_\_\_345\_345\_PAR3500

FWD

REV

Mon 12/12/2022 to Fri 12/16/2022

(Import) (Export)

0001

Continuous

2000

SCH - PJ - NY

2500 MW 1250 MW

Impacts Total Transfer Capability 350 MW 950 MW

TTC with All Lines In Service 2850 MW 2200 MW

Work scheduled by: ConEd

RAMAPO\_\_\_345\_345\_PAR4500

FWD

REV

Mon 12/12/2022 to Fri 12/16/2022

(Import) (Export)

0001

Continuous

2000

SCH - PJ - NY

2500 MW 1250 MW

Impacts Total Transfer Capability 350 MW 950 MW

TTC with All Lines In Service 2850 MW 2200 MW

Work scheduled by: ConEd

RAMAPO\_\_\_500\_345\_BK 1500

FWD

REV

Mon 12/12/2022 to Fri 12/16/2022

(Import) (Export)

0001

Continuous

2000

SCH - PJ - NY

1650 MW 1200 MW

Impacts Total Transfer Capability 1200 MW 1000 MW

TTC with All Lines In Service 2850 MW 2200 MW

Work scheduled by: ConEd

RAMAPO\_\_\_500\_345\_BK 1500

FWD

Mon 12/12/2022 to Fri 12/16/2022

(Import)

0001

Continuous

2000

UPNY CONED

7480 MW

Impacts Total Transfer Capability 335 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

CRICKVLY-PLSNTVLY\_345\_F83

FWD

Fri 12/16/2022 to Sun 01/01/2023

(Import)

0201

Continuous

0200

EXTENDEDby CE09/22/2022

SCH - NE - NY

600 MW

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 1400 MW

Work scheduled by: ConEd

CRICKVLY-PLSNTVLY\_345\_F83

FWD

REV

Fri 12/16/2022 to Sun 01/01/2023

(Import) (Export)

0201

Continuous

0200

EXTENDEDby CE09/22/2022

SCH - NPX\_1385

100 MW 100 MW

Impacts Total Transfer Capability 100 MW 100 MW

TTC with All Lines In Service 200 MW 200 MW

Work scheduled by: ConEd

# NYISO TRANSFER LIMITATIONS

Sunday ,October 09, 2022 to Tuesday ,April 09, 2024

## Seasonal Limits

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### FRASER\_\_-COOPERS\_\_345\_33

FWD

Mon 12/19/2022 to Fri 12/23/2022

(Import)

0600 Continuous 1659

CENTRAL EAST - VC

**2335 MW**

Impacts Total Transfer Capability 250 MW

TTC with All Lines In Service 2585 MW

Work scheduled by: NYSEG

### HOMRC\_NY-MAINS\_NY\_345\_47

Thu 12/22/2022 to Thu 12/22/2022

0800 Continuous 1600

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: PJM

### W49TH\_ST-E13THSTA\_345\_M54

FWD

Tue 12/27/2022 to Tue 12/27/2022

(Import)

0130 Continuous 0200

UPDATED

by CE

09/25/2022

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

### CLAY\_\_-EDIC\_\_345\_1-16

FWD

Fri 12/30/2022 to Sat 12/31/2022

(Import)

0600 Continuous 1900

UPDATED

by NGRID

05/09/2022

OSWEGO EXPORT

**4850 MW**

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NGrid

### E13THSTA-FARRAGUT\_345\_46

FWD

Mon 01/02/2023 to Wed 01/04/2023

(Import)

0001 Continuous 0300

UPDATED

by CE

10/06/2022

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

### FRASER\_\_345\_FRASER SVC

FWD

Tue 01/03/2023 to Tue 02/28/2023

(Import)

0700 Continuous 1730

UPDATED

by NYPA

12/30/2021

CENTRAL EAST - VC

**2550 MW**

Impacts Total Transfer Capability 35 MW

TTC with All Lines In Service 2585 MW

Work scheduled by: NYPA

### NIAGARA\_-PACKARD\_\_230\_62

FWD

REV

Mon 01/09/2023 to Fri 01/20/2023

(Import) (Export)

0500 Continuous 1900

SCH - OH - NY

**900 MW**

**1850 MW**

Impacts Total Transfer Capability 1400 MW 150 MW

TTC with All Lines In Service 2300 MW 2000 MW

Work scheduled by: NYPA

# NYISO TRANSFER LIMITATIONS

Sunday ,October 09, 2022 to Tuesday ,April 09, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>E13THSTA-FARRAGUT_345_46</b>						FWD
Fri 01/27/2023	to	Wed 02/01/2023	<u>UPDATED</u>	<u>by CE</u>	<u>10/06/2022</u>	(Import)
0001	Continuous	0300				SPR/DUN-SOUTH <b>3800 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 4600 MW
<b>E13THSTA-FARRAGUT_345_45</b>						FWD
Wed 02/08/2023	to	Wed 02/08/2023				(Import)
0001	Continuous	0030				SPR/DUN-SOUTH <b>3800 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 4600 MW
<b>E13THSTA-FARRAGUT_345_45</b>						FWD
Wed 02/22/2023	to	Wed 02/22/2023				(Import)
0230	Continuous	0300				SPR/DUN-SOUTH <b>3800 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability 800 MW
						TTC with All Lines In Service 4600 MW
<b>EDIC____-FRASER____345_EF24-40</b>						FWD
Wed 03/01/2023	to	Sat 04/15/2023				(Import)
0600	Continuous	1800				CENTRAL EAST - VC <b>2275 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability 310 MW
						TTC with All Lines In Service 2585 MW
<b>GORDONRD-N.SCTLND_345_55</b>						FWD
Wed 03/01/2023	to	Fri 03/31/2023				(Import)
0700	Continuous	1600				CENTRAL EAST - VC <b>2045 MW</b>
Work scheduled by: LS						Impacts Total Transfer Capability 540 MW
						TTC with All Lines In Service 2585 MW
<b>MOSES____-ADIRNDCK_230_MAI</b>						FWD
Wed 03/01/2023	to	Fri 05/26/2023				(Import)
1101	Continuous	1930				MOSES SOUTH <b>2300 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability 850 MW
						TTC with All Lines In Service 3150 MW
<b>NIAGARA_-ROBNSNRD_230_64</b>						REV
Mon 03/06/2023	to	Fri 03/17/2023				(Export)
0500	Continuous	1900				SCH - OH - NY <b>1900 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability 100 MW
						TTC with All Lines In Service 2000 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 09, 2022 to Tuesday ,April 09, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## N.SCTLND-ALPS\_\_\_\_345\_2

Mon 03/27/2023 to Fri 05/19/2023  
0700 Continuous 1900

UPDATED by NGRID 06/16/2022

Work scheduled by: NGrid

FWD  
(Import)  
**900 MW**  
SCH - NE - NY  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1400 MW

## N.SCTLND-ALPS\_\_\_\_345\_2

Mon 03/27/2023 to Fri 05/19/2023  
0700 Continuous 1900

UPDATED by NGRID 06/16/2022

Work scheduled by: NGrid

FWD REV  
(Import) (Export)  
**100 MW 100 MW**  
SCH - NPX\_1385  
Impacts Total Transfer Capability 100 MW 100 MW  
TTC with All Lines In Service 200 MW 200 MW

## MOTTHAVN-RAINEY\_\_\_\_345\_Q12

Wed 03/29/2023 to Sun 04/30/2023  
0001 Continuous 0200

UPDATED by CE 06/14/2022

Work scheduled by: ConEd

FWD  
(Import)  
**3800 MW**  
SPR/DUN-SOUTH  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

## PLSNTVLY\_345KV\_RNS4

Sat 04/01/2023 to Sat 04/01/2023  
0700 Continuous 0730

Work scheduled by: NGrid

FWD  
(Import)  
**3800 MW**  
UPNY CONED  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

## ATHENS\_\_-PLSNTVLY\_345\_91

Sat 04/01/2023 to Sat 04/15/2023  
0700 Continuous 1900

Work scheduled by: NGrid

FWD  
(Import)  
**3800 MW**  
UPNY CONED  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

## LINDN\_CG-LNDVFT\_\_\_\_345\_V-3022

Sun 04/09/2023 to Sat 04/15/2023  
1400 Continuous 1400

Work scheduled by: PJM

FWD REV  
(Import) (Export)  
**0 MW 0 MW**  
SCH - PJM\_VFT  
Impacts Total Transfer Capability 315 MW 315 MW  
TTC with All Lines In Service 315 MW 315 MW

## DYSINGER-STA\_255\_\_\_\_345\_DH1

Mon 04/10/2023 to Fri 04/14/2023  
0500 Continuous 2000

Work scheduled by: NYPA

FWD  
(Import)  
**2850 MW**  
DYSINGER EAST  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 3200 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 09, 2022 to Tuesday ,April 09, 2024

## Seasonal Limits

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### GORDONRD-N.SCTLND\_345\_55

FWD

Mon 04/10/2023 to Fri 04/14/2023

(Import)

0600 Continuous 1700

CENTRAL EAST - VC

**2045 MW**

Impacts Total Transfer Capability 540 MW

TTC with All Lines In Service 2585 MW

Work scheduled by: NGrid

### DUNWODIE\_345KV\_3

FWD

Wed 04/12/2023 to Wed 04/12/2023

(Import)

0201 Continuous 0230

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

### DUNWODIE\_345KV\_4

FWD

Wed 04/12/2023 to Wed 04/12/2023

(Import)

0201 Continuous 0230

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

### PLSNTVLE-DUNWODIE\_345\_W89

FWD

Wed 04/12/2023 to Wed 04/12/2023

(Import)

0201 Continuous 0230

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 3815 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

### PLSNTVLY\_345KV\_RNS4

FWD

Sat 04/15/2023 to Sat 04/15/2023

(Import)

1830 Continuous 1900

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: NGrid

### PLSNTVLY\_345KV\_RNS5

FWD

Sun 04/16/2023 to Sun 04/16/2023

(Import)

0700 Continuous 0730

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: NGrid

### LEEDS\_\_\_-PLSNTVLY\_345\_92

FWD

Sun 04/16/2023 to Sun 04/30/2023

(Import)

0700 Continuous 1900

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: NGrid

# NYISO TRANSFER LIMITATIONS

Sunday ,October 09, 2022 to Tuesday ,April 09, 2024

## Seasonal Limits

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### DYSINGER-STA\_255\_\_345\_DH2

FWD

Mon 04/17/2023 to Fri 04/21/2023

(Import)

0500 Continuous 2000

DYSINGER EAST **2850 MW**

Impacts Total Transfer Capability 350 MW

TTC with All Lines In Service 3200 MW

Work scheduled by: NYPA

### CLAY\_\_-EDIC\_\_345\_2-15

FWD

Mon 04/17/2023 to Fri 04/28/2023

(Import)

0600 Continuous 1800

OSWEGO EXPORT **4850 MW**

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NGrid

### DUNWODIE\_345KV\_3

FWD

Thu 04/20/2023 to Thu 04/20/2023

(Import)

0130 Continuous 0200

SPR/DUN-SOUTH **3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

### DUNWODIE\_345KV\_4

FWD

Thu 04/20/2023 to Thu 04/20/2023

(Import)

0130 Continuous 0200

SPR/DUN-SOUTH **3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

### PLSNTVLE-DUNWODIE\_345\_W89

FWD

Thu 04/20/2023 to Thu 04/20/2023

(Import)

0130 Continuous 0200

UPNY CONED **4000 MW**

Impacts Total Transfer Capability 3815 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

### PANNELL\_-CLAY\_\_345\_1

FWD

Mon 04/24/2023 to Fri 04/28/2023

(Import)

0700 Continuous 1530

WEST CENTRAL **1300 MW**

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW

Work scheduled by: NYPA

### PLSNTVLY\_345KV\_RNS5

FWD

Sun 04/30/2023 to Sun 04/30/2023

(Import)

1830 Continuous 1900

UPNY CONED **3800 MW**

Impacts Total Transfer Capability 4015 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: NGrid

# NYISO TRANSFER LIMITATIONS

Sunday ,October 09, 2022 to Tuesday ,April 09, 2024

## Seasonal Limits

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SHOR_NPX-SHOREHAM_138_CSC</b>			FWD	REV
Mon 05/01/2023	to	Fri 05/05/2023	(Import)	(Export)
0600	Continuous	1800	SCH - NPX_CSC	<b>0 MW</b>
Work scheduled by: LI			Impacts Total Transfer Capability	330 MW
			TTC with All Lines In Service	330 MW
<b>PANNELL -CLAY_345_2</b>			FWD	
Mon 05/01/2023	to	Fri 05/05/2023	(Import)	
0700	Continuous	1530	WEST CENTRAL	<b>1300 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	950 MW
			TTC with All Lines In Service	2250 MW
<b>PLSNTVLY-WOOD_ST_345_F30</b>			FWD	
Wed 05/03/2023	to	Mon 05/15/2023	(Import)	
0001	Continuous	2200	UPNY CONED	<b>4000 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	3815 MW
			TTC with All Lines In Service	7815 MW
<b>PLSNTVLY_345KV_RNS5</b>			FWD	
Wed 05/03/2023	to	Mon 05/15/2023	(Import)	
0001	Continuous	2200	UPNY CONED	<b>3800 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	4015 MW
			TTC with All Lines In Service	7815 MW
<b>NIAGARA -ROBNSNRD_230_64</b>				REV
Fri 05/05/2023	to	Fri 05/05/2023		(Export)
0500	Continuous	1700	SCH - OH - NY	<b>1400 MW</b>
Work scheduled by: NYPA			Impacts Total Transfer Capability	150 MW
			TTC with All Lines In Service	1550 MW
<b>W49TH_ST_345KV_6</b>			FWD	
Sat 05/06/2023	to	Sat 05/06/2023	(Import)	
0001	Continuous	0030	SCH - PJM_HTP	<b>300 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	360 MW
			TTC with All Lines In Service	660 MW
<b>W49TH_ST_345KV_8</b>			FWD	
Sat 05/06/2023	to	Sat 05/06/2023	(Import)	
0001	Continuous	0030	SCH - PJM_HTP	<b>450 MW</b>
Work scheduled by: ConEd			Impacts Total Transfer Capability	210 MW
			TTC with All Lines In Service	660 MW

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**DOLSONAV-ROCKTVRN\_345\_DART44**

FWD

Mon 05/08/2023 to Sat 05/13/2023

(Import)

0700 Continuous 1530

CENTRAL EAST - VC

**2485 MW**

Impacts Total Transfer Capability 100 MW

TTC with All Lines In Service 2585 MW

Work scheduled by: NYPA

**COOPERS\_-DOLSONAV\_345\_CCDA42**

FWD

Mon 05/08/2023 to Sun 05/21/2023

(Import)

0700 Continuous 1530

CENTRAL EAST - VC

**2485 MW**

Impacts Total Transfer Capability 100 MW

TTC with All Lines In Service 2585 MW

Work scheduled by: NYPA

**W49TH\_ST\_345KV\_6**

FWD

Sat 05/13/2023 to Sat 05/13/2023

(Import)

0130 Continuous 0200

SCH - PJM\_HTP

**300 MW**

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

**W49TH\_ST\_345KV\_8**

FWD

Sat 05/13/2023 to Sat 05/13/2023

(Import)

0130 Continuous 0200

SCH - PJM\_HTP

**450 MW**

Impacts Total Transfer Capability 210 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

**MOTTHAVN-RAINEY\_\_345\_Q11**

FWD

Wed 05/17/2023 to Sat 05/20/2023

(Import)

0001 Continuous 0200

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**BECK\_-NIAGARA\_230\_PA27**

Tue 05/30/2023 to Fri 06/02/2023

0500 Continuous 2100

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: NYPA

**NIAGARA\_345\_230\_AT4**

REV

Wed 06/28/2023 to Thu 06/29/2023

(Export)

0500 Continuous 1900

SCH - OH - NY

**1150 MW**

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 1550 MW

Work scheduled by: NYPA



CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## NIAGARA\_\_345\_230\_AT4

REV

Mon 08/21/2023 to Fri 08/25/2023

(Export)

0500 Continuous 2100

SCH - OH - NY

**1150 MW**

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

1550 MW

Work scheduled by: NYPA

## ADIRNDCK-PORTER\_\_230\_12

FWD

Tue 08/22/2023 to Tue 08/22/2023

(Import)

0700 Continuous 1530

MOSES SOUTH

**2100 MW**

Impacts Total Transfer Capability 1050 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

## ADIRNDCK-CHASLAKE\_230\_13

FWD

Wed 08/23/2023 to Wed 08/23/2023

(Import)

0700 Continuous 1530

MOSES SOUTH

**2100 MW**

Impacts Total Transfer Capability 1050 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

## CLAY\_\_-EDIC\_\_345\_1-16

FWD

Mon 09/11/2023 to Fri 09/15/2023

(Import)

0700 Continuous 1530

OSWEGO EXPORT

**4850 MW**

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NYPA

## FRASER\_\_-GILBOA\_\_345\_GF5-35

FWD

Mon 09/11/2023 to Sun 09/17/2023

(Import)

0700 Continuous 1530

CENTRAL EAST - VC

**2450 MW**

Impacts Total Transfer Capability 135 MW

TTC with All Lines In Service 2585 MW

Work scheduled by: NYPA

## SPRNBRK\_-W49TH\_ST\_345\_M51

FWD

Fri 09/15/2023 to Mon 10/23/2023

(Import)

0001 Continuous 0200

UPDATEDby CE08/10/2022

SPR/DUN-SOUTH

**3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

## SPRNBRK\_\_345KV\_RNS5

FWD

Fri 09/15/2023 to Mon 10/23/2023

(Import)

0001 Continuous 0200

UPDATEDby CE08/10/2022

SPR/DUN-SOUTH

**3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

# NYISO TRANSFER LIMITATIONS

Sunday ,October 09, 2022 to Tuesday ,April 09, 2024

## Seasonal Limits

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### CLAY\_\_\_\_-EDIC\_\_\_\_345\_2-15

Mon 09/18/2023 to Fri 09/22/2023

0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

OSWEGO EXPORT

**4850 MW**

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 5250 MW

### NIAGARA\_-DYSINGER\_345\_ND2

Mon 09/25/2023 to Fri 09/29/2023

0500 Continuous 2000

Work scheduled by: NYPA

FWD

(Import)

DYSINGER EAST

**2700 MW**

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 3200 MW

### MARCY\_\_\_\_345KV\_CSC

Mon 09/25/2023 to Sat 10/07/2023

0700 Continuous 1530

Work scheduled by: NYPA

FWD

(Import)

CENTRAL EAST - VC

**2535 MW**

Impacts Total Transfer Capability 50 MW

TTC with All Lines In Service 2585 MW

### SHOR\_NPX-SHOREHAM\_138\_CSC

Mon 10/02/2023 to Fri 10/06/2023

0600 Continuous 1800

Work scheduled by: LI

FWD

REV

(Import) (Export)

SCH - NPX\_CSC

**0 MW**

**0 MW**

Impacts Total Transfer Capability 330 MW 330 MW

TTC with All Lines In Service 330 MW 330 MW

### NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE

Mon 10/09/2023 to Fri 10/13/2023

0600 Continuous 1600

Work scheduled by: LI

FWD

(Import)

SCH - PJM\_NEPTUNE

**0 MW**

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

### NEWBRDGE-DUFFYAVE\_345\_501

Mon 10/09/2023 to Fri 10/13/2023

0600 Continuous 1600

Work scheduled by: LI

FWD

(Import)

SCH - PJM\_NEPTUNE

**0 MW**

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

### NEWBRDGE\_345\_138\_BK\_1

Mon 10/09/2023 to Fri 10/13/2023

0600 Continuous 1600

Work scheduled by: LI

FWD

(Import)

SCH - PJM\_NEPTUNE

**375 MW**

Impacts Total Transfer Capability 285 MW

TTC with All Lines In Service 660 MW

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**NEWBRIDGE\_345\_138\_BK\_2**

Mon 10/09/2023 to Fri 10/13/2023  
0600 Continuous 1600  
Work scheduled by: LI

FWD  
(Import)  
SCH - PJM\_NEPTUNE **375 MW**  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 660 MW

**GILBOA\_\_-N.SCTLND\_345\_GNS-1**

Mon 10/09/2023 to Fri 10/13/2023  
0700 Continuous 1530  
Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2300 MW**  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 2585 MW

**NIAGARA\_\_-PACKARD\_\_230\_61**

Fri 10/13/2023 to Fri 10/13/2023  
0500 Continuous 1900  
Work scheduled by: NYPA

REV  
(Export)  
SCH - OH - NY **1350 MW**  
Impacts Total Transfer Capability 200 MW  
TTC with All Lines In Service 1550 MW

**MOSES\_\_-MASSENA\_\_230\_MMS1 & MOSES\_\_-MASSENA\_\_230\_MMS2**

Wed 11/15/2023 to Mon 11/20/2023  
0700 1530  
Work scheduled by:

FWD REV  
(Import) (Export)  
SCH - HQ - NY **850 MW 0 MW**  
Impacts Total Transfer Capability 650 MW 1000 MW  
TTC with All Lines In Service 1500 MW 1000 MW

**MOSES\_\_-MASSENA\_\_230\_MMS1 & MOSES\_\_-MASSENA\_\_230\_MMS2**

Wed 11/15/2023 to Mon 11/20/2023  
0700 1530  
Work scheduled by:

FWD  
(Import)  
SCH - HQ\_CEDARS **90 MW**  
Impacts Total Transfer Capability 189 MW  
TTC with All Lines In Service 279 MW

**CHATGUAY-MASSENA\_\_765\_7040**

Wed 11/15/2023 to Mon 11/27/2023  
0700 Continuous 1730  
Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **1550 MW**  
Impacts Total Transfer Capability 1600 MW  
TTC with All Lines In Service 3150 MW

**CHATGUAY-MASSENA\_\_765\_7040**

Wed 11/15/2023 to Mon 11/27/2023  
0700 Continuous 1730  
Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - HQ - NY **0 MW 0 MW**  
Impacts Total Transfer Capability 1500 MW 1000 MW  
TTC with All Lines In Service 1500 MW 1000 MW

# NYISO TRANSFER LIMITATIONS

Sunday ,October 09, 2022 to Tuesday ,April 09, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## MASSENA\_-MARCY\_\_\_\_765\_MSU1

Wed 11/15/2023 to Mon 11/27/2023  
0700 Continuous 1730  
Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **1720 MW**  
Impacts Total Transfer Capability 865 MW  
TTC with All Lines In Service 2585 MW

## MASSENA\_-MARCY\_\_\_\_765\_MSU1

Wed 11/15/2023 to Mon 11/27/2023  
0700 Continuous 1730  
Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **500 MW**  
Impacts Total Transfer Capability 2650 MW  
TTC with All Lines In Service 3150 MW

## MASSENA\_-MARCY\_\_\_\_765\_MSU1

Wed 11/15/2023 to Mon 11/27/2023  
0700 Continuous 1730  
Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - HQ - NY **475 MW 1000 MW**  
Impacts Total Transfer Capability 1025 MW 0 MW  
TTC with All Lines In Service 1500 MW 1000 MW

## MASSENA\_-MARCY\_\_\_\_765\_MSU1

Wed 11/15/2023 to Mon 11/27/2023  
0700 Continuous 1730  
Work scheduled by: NYPA

FWD  
(Import)  
SCH - HQ\_CEDARS **90 MW**  
Impacts Total Transfer Capability 189 MW  
TTC with All Lines In Service 279 MW

## MASSENA\_-MARCY\_\_\_\_765\_MSU1 & CHATGUAY-MASSENA\_\_765\_7040

Wed 11/15/2023 to Mon 11/27/2023  
0700 1730  
Work scheduled by:

FWD  
(Import)  
MOSES SOUTH **500 MW**  
Impacts Total Transfer Capability 2650 MW  
TTC with All Lines In Service 3150 MW

## NIAGARA\_\_345\_230\_AT4

Mon 11/27/2023 to Fri 12/01/2023  
0500 Continuous 1900  
Work scheduled by: NYPA

REV  
(Export)  
SCH - OH - NY **1750 MW**  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 2000 MW

## HOMRC\_NY-MAINS\_NY\_345\_47

Fri 12/08/2023 to Fri 12/15/2023 **UPDATED by PJM 01/11/2022**  
0800 Continuous 1600  
Work scheduled by: PJM

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

**NYISO TRANSFER LIMITATIONS**

Sunday ,October 09, 2022 to Tuesday ,April 09, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**HOMR\_NYW-PIERC\_NY\_345\_48**Fri 12/08/2023 to Fri 12/15/2023 UPDATED by PJM 01/11/2022

0800 Continuous 1600

Work scheduled by: PJM

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

**W49TH\_ST-E13THSTA\_345\_M55**

Mon 01/08/2024 to Mon 02/19/2024

0001 Continuous 0201

Work scheduled by: ConEd

FWD

(Import)

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

**W49TH\_ST\_345KV\_6**

Mon 01/08/2024 to Mon 02/19/2024

0001 Continuous 0201

Work scheduled by: ConEd

FWD

(Import)

SCH - PJM\_HTP

**310 MW**

Impacts Total Transfer Capability 350 MW

TTC with All Lines In Service 660 MW

**W49TH\_ST\_345KV\_8**

Sat 02/03/2024 to Mon 02/19/2024

0001 Continuous 0201

Work scheduled by: ConEd

FWD

(Import)

SCH - PJM\_HTP

**310 MW**

Impacts Total Transfer Capability 350 MW

TTC with All Lines In Service 660 MW