

# NYISO TRANSFER LIMITATIONS

Monday ,October 10, 2022 to Wednesday, April 10, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## HUDSONP\_-FARRAGUT\_345\_B3402

Mon 01/15/2018 to Tue 01/31/2023 EXT FORCE by CONED 08/06/2022

0001 Continuous 2359

Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJ - NY **2050 MW**  
Impacts Total Transfer Capability 200 MW  
TTC with All Lines In Service 2250 MW

## HUDSONP\_-FARRAGUT\_345\_B3402 & MARION\_-FARRAGUT\_345\_C3403

Mon 01/15/2018 to Tue 01/31/2023

0001 2359

Work scheduled by:

FWD REV  
(Import) (Export)  
SCH - PJ - NY **2000 MW 1150 MW**  
Impacts Total Transfer Capability 250 MW 50 MW  
TTC with All Lines In Service 2250 MW 1200 MW

## MARION\_-FARRAGUT\_345\_C3403

Mon 01/15/2018 to Tue 01/31/2023 EXT FORCE by CONED 08/06/2022

0001 Continuous 2359

Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJ - NY **2050 MW**  
Impacts Total Transfer Capability 200 MW  
TTC with All Lines In Service 2250 MW

## GORDONRD-ROTTDAM\_230\_30

Wed 04/27/2022 to Thu 10/06/2022 UPDATED by LS 09/29/2022

1122 Continuous 1000

Work scheduled by: NYISO

FWD  
(Import)  
CENTRAL EAST - VC **2535 MW**  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 2585 MW

## SCH-IMO-NYISO\_LIMIT\_1400

Wed 08/10/2022 to Mon 10/10/2022 EXTENDED by IESO 08/19/2022

0800 Continuous 1600

Work scheduled by: IESO

FWD  
(Import)  
SCH - OH - NY **1700 MW**  
Impacts Total Transfer Capability 200 MW  
TTC with All Lines In Service 1900 MW

## BECK\_-NIAGARA\_230\_PA27

Wed 08/24/2022 to Fri 10/28/2022 EXTENDED by IESO 09/26/2022

0800 Continuous 1700

Work scheduled by: IESO

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

## SCH-HQ\_CEDARS-NYISO\_LIMIT\_240

Tue 09/06/2022 to Fri 10/28/2022 EXTENDED by HQ 09/27/2022

0500 Continuous 1900

Work scheduled by: HQ

FWD  
(Import)  
SCH - HQ\_CEDARS **240 MW**  
Impacts Total Transfer Capability 30 MW  
TTC with All Lines In Service 270 MW

# NYISO TRANSFER LIMITATIONS

Monday ,October 10, 2022 to Wednesday, April 10, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-HQ_CEDARS_LIMIT_0						REV
Tue 09/06/2022	to	Fri 10/28/2022	<u>EXTENDED</u>	<u>by HQ</u>	<u>09/27/2022</u>	(Export)
0500	Continuous	1900				0 MW
Work scheduled by: HQ					SCH - HQ_CEDARS	100 MW
					Impacts Total Transfer Capability	100 MW
					TTC with All Lines In Service	100 MW
MOSES -ADIRNDCK_230_MA2						FWD
Tue 09/06/2022	to	Thu 12/01/2022	<u>UPDATED</u>	<u>by NYPA</u>	<u>09/06/2022</u>	(Import)
1200	Continuous	0659				2100 MW
Work scheduled by: NYPA					MOSES SOUTH	1050 MW
					Impacts Total Transfer Capability	3150 MW
					TTC with All Lines In Service	
PLSNTVLY_345KV_RN5 & PLSNTVLY_345KV_RN4						FWD
Fri 09/16/2022	to	Sat 10/15/2022				(Import)
0001		0300				3800 MW
Work scheduled by:					UPNY CONED	4015 MW
					Impacts Total Transfer Capability	7815 MW
					TTC with All Lines In Service	
SCH-NE-NYISO_LIMIT_100						FWD
Fri 09/16/2022	to	Sat 10/15/2022	<u>UPDATED</u>	<u>by CE</u>	<u>09/16/2022</u>	(Import)
0001	Continuous	0300				300 MW
Work scheduled by: ConEd					SCH - NE - NY	1100 MW
					Impacts Total Transfer Capability	1400 MW
					TTC with All Lines In Service	
HURLYAVE-ROSETON_345_303						FWD
Mon 09/19/2022	to	Fri 12/02/2022	<u>UPDATED</u>	<u>by CHGE</u>	<u>10/04/2022</u>	(Import)
0800	Continuous	1600				4100 MW
Work scheduled by: CHGE					UPNY CONED	3715 MW
					Impacts Total Transfer Capability	7815 MW
					TTC with All Lines In Service	
LEEDS -HURLYAVE_345_301						FWD
Mon 09/19/2022	to	Fri 12/02/2022			<u>10/04/2021</u>	(Import)
0800	Continuous	1600				4100 MW
Work scheduled by: CHGE					UPNY CONED	3715 MW
					Impacts Total Transfer Capability	7815 MW
					TTC with All Lines In Service	
MARCY -EDIC_345_UE1-7						FWD
Tue 09/20/2022	to	Sat 10/08/2022	<u>UPDATED</u>	<u>by NYPA</u>	<u>08/10/2022</u>	(Import)
0500	Continuous	1930				5250 MW
Work scheduled by: NYPA					OSWEGO EXPORT	0 MW
					Impacts Total Transfer Capability	5250 MW
					TTC with All Lines In Service	

ARR: 19&amp;16

# NYISO TRANSFER LIMITATIONS

Monday ,October 10, 2022 to Wednesday, April 10, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## W49TH\_ST-E13THSTA\_345\_M54

FWD

Wed 09/21/2022 to Sun 12/25/2022 UPDATED by CE 09/25/2022

(Import)

0101 Continuous 0200

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

## SCH-NPX\_1385-NYISO\_LIMIT\_125

FWD

Sun 09/25/2022 to Sat 10/15/2022 UPDATED by CE 09/16/2022

(Import)

0001 Continuous 0300

SCH - NPX\_1385

**125 MW**

Impacts Total Transfer Capability 75 MW

TTC with All Lines In Service 200 MW

Work scheduled by: ConEd

## FITZPTRK-EDIC\_\_\_\_345\_FE-1 & GORDONRD-ROTTRDAM\_230\_30

FWD

Mon 09/26/2022 to Thu 10/06/2022

(Import)

0600 1000

CENTRAL EAST - VC

**2430 MW**

Impacts Total Transfer Capability 155 MW

TTC with All Lines In Service 2585 MW

Work scheduled by:

## FITZPTRK-EDIC\_\_\_\_345\_FE-1

FWD

Mon 09/26/2022 to Mon 10/10/2022 EXTENDED by NGRID 10/09/2022

(Import)

0600 Continuous 1800

CENTRAL EAST - VC

**2480 MW**

Impacts Total Transfer Capability 105 MW

TTC with All Lines In Service 2585 MW

Work scheduled by: NGrid

## FITZPTRK-EDIC\_\_\_\_345\_FE-1

FWD

Mon 09/26/2022 to Mon 10/10/2022 EXTENDED by NGRID 10/09/2022

(Import)

0600 Continuous 1800

OSWEGO EXPORT

**4800 MW**

Impacts Total Transfer Capability 450 MW

TTC with All Lines In Service 5250 MW

Work scheduled by: NGrid

## MARCY\_\_\_\_345KV\_CSC

FWD

Thu 09/29/2022 to Fri 10/07/2022 UPDATED by NYPA 10/07/2022

(Import)

0500 Continuous 1530

CENTRAL EAST - VC

**2535 MW**

Impacts Total Transfer Capability 50 MW

TTC with All Lines In Service 2585 MW

Work scheduled by: NYPA

## COOPERS\_-MIDDLETP\_345\_CCRT34

FWD

Fri 09/30/2022 to Wed 10/12/2022 EXTENDED by CHGE 10/08/2022

(Import)

0700 Continuous 1600

CENTRAL EAST - VC

**2485 MW**

Impacts Total Transfer Capability 100 MW

TTC with All Lines In Service 2585 MW

Work scheduled by: NYSEG

# NYISO TRANSFER LIMITATIONS

Monday ,October 10, 2022 to Wednesday, April 10, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## EGRDNCTY\_345\_138\_AT1

Sat 10/01/2022 to Wed 05/31/2023  
0001 Continuous 2359

UPDATED by CONED 10/09/2022

Work scheduled by: LI

FWD  
(Import)  
**1250 MW**  
CONED - LIPA  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 1500 MW

## EGRDNCTY\_345\_138\_AT2

Sat 10/01/2022 to Wed 05/31/2023  
0001 Continuous 2359

UPDATED by CONED 10/09/2022

Work scheduled by: LI

FWD  
(Import)  
**1250 MW**  
CONED - LIPA  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 1500 MW

## SPRNBK -EGRDNCTR\_345\_Y49

Sat 10/01/2022 to Wed 05/31/2023  
0001 Continuous 2359

UPDATED by CONED 10/09/2022

Work scheduled by: LI

FWD  
(Import)  
**775 MW**  
CONED - LIPA  
Impacts Total Transfer Capability 725 MW  
TTC with All Lines In Service 1500 MW

## SPRNBK -TREMONT\_345\_X28

Sun 10/02/2022 to Wed 10/05/2022  
1554 Continuous 2359

FORCED by CONED 10/03/2022

Work scheduled by: ConEd

FWD  
(Import)  
**4200 MW**  
SPR/DUN-SOUTH  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 4600 MW

## SHOR\_NPX-SHOREHAM\_138\_CSC

Mon 10/03/2022 to Fri 10/21/2022  
0700 Continuous 1500

09/28/2022

Work scheduled by: LI

FWD REV  
(Import) (Export)  
**0 MW 0 MW**  
SCH - NPX\_CSC  
Impacts Total Transfer Capability 330 MW 330 MW  
TTC with All Lines In Service 330 MW 330 MW

## SCH-IMO-NYISO\_LIMIT\_850

Mon 10/03/2022 to Fri 10/07/2022  
0800 Continuous 1800

UPDATED by IESO 09/29/2022

Work scheduled by: IESO

FWD  
(Import)  
**1150 MW**  
SCH - OH - NY  
Impacts Total Transfer Capability 750 MW  
TTC with All Lines In Service 1900 MW

## SCH-NYISO-IMO\_LIMIT\_900

Mon 10/03/2022 to Fri 10/07/2022  
0800 Continuous 1800

UPDATED by IESO 09/29/2022

Work scheduled by: IESO

REV  
(Export)  
**1200 MW**  
SCH - OH - NY  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 1550 MW

**NYISO TRANSFER LIMITATIONS**

Monday ,October 10, 2022 to Wednesday, April 10, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**CLRKSCRN-OAKDALE\_\_345\_36**

FWD

Mon 10/03/2022 to Thu 10/06/2022 **UPDATED** **by NYSEG** **04/20/2022**

(Import)

0830 Continuous 1330

CENTRAL EAST - VC **2450 MW**

Impacts Total Transfer Capability 135 MW

TTC with All Lines In Service 2585 MW

Work scheduled by: NYSEG

**STLAWRNC-MOSES\_\_\_\_230\_L34P**Mon 10/03/2022 to Mon 09/25/2023 **UPDATED** **by IESO** **08/15/2022**

1800 Continuous 0800

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: IESO

**SCH-NYISO-NE\_LIMIT\_900**

REV

Mon 10/03/2022 to Wed 10/05/2022 **UPDATED** **by ISONE** **09/29/2022**

(Export)

2300 Continuous 0659

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: NGrid

**1100 MW**

500 MW

1600 MW

**W49TH\_ST\_345KV\_7**

FWD

Wed 10/05/2022 to Wed 10/05/2022

(Import)

0201 Continuous 0230

SCH - PJM\_HTP

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

**W49TH\_ST\_345KV\_8**

FWD

Wed 10/05/2022 to Wed 10/05/2022

(Import)

0201 Continuous 0230

SCH - PJM\_HTP

Impacts Total Transfer Capability 210 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

**HUDSONTP-W49TH\_ST\_345\_Y56**

FWD

Wed 10/05/2022 to Sat 10/08/2022

(Import)

0201 Continuous 1800

SCH - PJM\_HTP

Impacts Total Transfer Capability 660 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

**MAINESBG-WATRCURE\_345\_30**Wed 10/05/2022 to Thu 10/06/2022 **UPDATED** **by NYSEG** **10/04/2022**

0800 Continuous 1600

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: NYSEG

# NYISO TRANSFER LIMITATIONS

Monday ,October 10, 2022 to Wednesday, April 10, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## DUNWODIE\_345KV\_3

FWD

Thu 10/06/2022 to Sun 10/16/2022 UPDATED by CE 06/30/2022

(Import)

0001 Continuous 0200

SPR/DUN-SOUTH **3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

## DUNWODIE\_345KV\_5

FWD

Thu 10/06/2022 to Sun 10/16/2022 UPDATED by CE 06/30/2022

(Import)

0001 Continuous 0200

SPR/DUN-SOUTH **3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

## DUNWODIE-MOTTHAVN\_345\_71

FWD

Thu 10/06/2022 to Thu 11/10/2022 UPDATED by CE 06/30/2022

(Import)

0001 Continuous 0300

SPR/DUN-SOUTH **3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

## LEEDS\_\_\_\_345\_LEEDS SVC

FWD

Thu 10/06/2022 to Fri 10/07/2022 CANCELLED by NGrid 10/06/2022

(Import)

0700 Continuous 1200

CENTRAL EAST - VC **2570 MW**

Impacts Total Transfer Capability 15 MW

TTC with All Lines In Service 2585 MW

Work scheduled by: NGrid

## HOPATCON-RAMAPO\_\_\_\_500\_5018 &amp; MARCY\_\_\_\_345KV\_CSC

Fri 10/07/2022 to Fri 10/07/2022

1145 1530

TOTAL EAST

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by:

## HOPATCON-RAMAPO\_\_\_\_500\_5018

FWD

REV

Fri 10/07/2022 to Sun 10/09/2022 FORCED by PJM 10/07/2022

(Import) (Export)

1145 Continuous 2359

SCH - PJ - NY **1100 MW 1000 MW**

Impacts Total Transfer Capability 1150 MW 200 MW

TTC with All Lines In Service 2250 MW 1200 MW

Work scheduled by: PJM

## HOPATCON-RAMAPO\_\_\_\_500\_5018

Fri 10/07/2022 to Sun 10/09/2022 FORCED by PJM 10/07/2022

1145 Continuous 2359

TOTAL EAST

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: PJM

# NYISO TRANSFER LIMITATIONS

Monday ,October 10, 2022 to Wednesday, April 10, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HOPATCON-RAMAPO___500_5018						FWD			
Fri 10/07/2022	to	Sun 10/09/2022	<u>FORCED</u>	<u>by PJM</u>	<u>10/07/2022</u>	(Import)			
1145	Continuous	2359				UPNY CONED	7480 MW		
Impacts Total Transfer Capability						335 MW			
TTC with All Lines In Service						7815 MW			
Work scheduled by: PJM									
RAMAPO___345_345_PAR3500						FWD			
Fri 10/07/2022	to	Sun 10/09/2022	<u>FORCED</u>	<u>by PJM</u>	<u>10/07/2022</u>	(Import)			
1145	Continuous	2359				SCH - PJ - NY	1750 MW		
Impacts Total Transfer Capability						500 MW			
TTC with All Lines In Service						2250 MW			
Work scheduled by: PJM									
RAMAPO___345_345_PAR4500						FWD			
Fri 10/07/2022	to	Sun 10/09/2022	<u>FORCED</u>	<u>by PJM</u>	<u>10/07/2022</u>	(Import)			
1145	Continuous	2359				SCH - PJ - NY	1750 MW		
Impacts Total Transfer Capability						500 MW			
TTC with All Lines In Service						2250 MW			
Work scheduled by: PJM									
RAMAPO___500_345_BK 1500						FWD	REV		
Fri 10/07/2022	to	Sun 10/09/2022	<u>FORCED</u>	<u>by PJM</u>	<u>10/07/2022</u>	(Import)	(Export)		
1145	Continuous	2359				SCH - PJ - NY	1100 MW 1000 MW		
Impacts Total Transfer Capability						1150 MW 200 MW			
TTC with All Lines In Service						2250 MW 1200 MW			
Work scheduled by: PJM									
RAMAPO___500_345_BK 1500						FWD			
Fri 10/07/2022	to	Sun 10/09/2022	<u>FORCED</u>	<u>by PJM</u>	<u>10/07/2022</u>	(Import)			
1145	Continuous	2359				UPNY CONED	7480 MW		
Impacts Total Transfer Capability						335 MW			
TTC with All Lines In Service						7815 MW			
Work scheduled by: PJM									
CHAT_DC_GC1						FWD			
Sun 10/09/2022	to	Sun 11/06/2022				(Import)			
0400	Continuous	2200				MOSES SOUTH	2850 MW		
Impacts Total Transfer Capability						300 MW			
TTC with All Lines In Service						3150 MW			
Work scheduled by: HQ									
CHAT_DC_GC1							REV		
Sun 10/09/2022	to	Sun 11/06/2022				(Export)			
0400	Continuous	2200				SCH - HQ - NY	500 MW		
Impacts Total Transfer Capability						500 MW			
TTC with All Lines In Service						1000 MW			
Work scheduled by: HQ									

**NYISO TRANSFER LIMITATIONS**

Monday ,October 10, 2022 to Wednesday, April 10, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SCH-NYISO-HQ_LIMIT_500</b>						REV
Sun 10/09/2022	to	Sun 11/06/2022				(Export)
0400	Continuous	2200			SCH - HQ - NY	<b>500 MW</b>
Work scheduled by: HQ						Impacts Total Transfer Capability 500 MW
						TTC with All Lines In Service 1000 MW
<b>SPRNBK__345KV_RNS4</b>						FWD
Mon 10/10/2022	to	Mon 10/10/2022	<u>UPDATED</u>	<u>by CE</u>	<u>10/09/2022</u>	(Import)
0001	Continuous	0030				SPR/DUN-SOUTH <b>3200 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability 1400 MW
						TTC with All Lines In Service 4600 MW
<b>EASTVIEW-SPRNBK__345_W65</b>						FWD
Mon 10/10/2022	to	Thu 10/13/2022	<u>UPDATED</u>	<u>by CE</u>	<u>10/09/2022</u>	(Import)
0001	Continuous	0200				UPNY CONED <b>4350 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability 3465 MW
						TTC with All Lines In Service 7815 MW
<b>MILLWOOD-EASTVIEW_345_W82</b>						FWD
Mon 10/10/2022	to	Thu 10/13/2022	<u>UPDATED</u>	<u>by CE</u>	<u>10/09/2022</u>	(Import)
0001	Continuous	0200				UPNY CONED <b>7550 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability 265 MW
						TTC with All Lines In Service 7815 MW
<b>EDIC____-GORDONRD_345_14</b>						FWD
Mon 10/10/2022	to	Mon 10/31/2022	<u>UPDATED</u>	<u>by NYPA</u>	<u>05/17/2022</u>	(Import)
0700	Continuous	1530				CENTRAL EAST - VC <b>1670 MW</b>
Work scheduled by: NYPA						Impacts Total Transfer Capability 915 MW
						TTC with All Lines In Service 2585 MW
<b>SCRIBA__-VOLNEY__345_21</b>						FWD
Mon 10/10/2022	to	Fri 10/14/2022				(Import)
0730	Continuous	1700				OSWEGO EXPORT <b>5250 MW</b>
Work scheduled by: NGrid						Impacts Total Transfer Capability 0 MW
						TTC with All Lines In Service 5250 MW
<b>SPRNBK__345KV_RNS4</b>						FWD
Thu 10/13/2022	to	Thu 10/13/2022	<u>UPDATED</u>	<u>by CE</u>	<u>10/09/2022</u>	(Import)
0130	Continuous	0200				SPR/DUN-SOUTH <b>3200 MW</b>
Work scheduled by: ConEd						Impacts Total Transfer Capability 1400 MW
						TTC with All Lines In Service 4600 MW



# NYISO TRANSFER LIMITATIONS

Monday ,October 10, 2022 to Wednesday, April 10, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## MILLWOOD-EASTVIEW\_345\_W99

FWD

Thu 10/13/2022 to Thu 10/13/2022 UPDATED by CE 10/09/2022

(Import)

0201 Continuous 0230

UPNY CONED

**7550 MW**

Impacts Total Transfer Capability 265 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

## SPRNBK\_345KV\_RNS5

FWD

Thu 10/13/2022 to Thu 10/13/2022 UPDATED by CE 10/09/2022

(Import)

0201 Continuous 0230

SPR/DUN-SOUTH

**3200 MW**

Impacts Total Transfer Capability 1400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

## EASTVIEW-SPRNBK\_345\_W64

FWD

Thu 10/13/2022 to Sun 10/16/2022 UPDATED by CE 10/09/2022

(Import)

0201 Continuous 0200

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

## MILLWOOD-EASTVIEW\_345\_W99

FWD

Sun 10/16/2022 to Sun 10/16/2022 UPDATED by CE 10/09/2022

(Import)

0130 Continuous 0200

UPNY CONED

**7550 MW**

Impacts Total Transfer Capability 265 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

## EASTVIEW-SPRNBK\_345\_W79

FWD

Mon 10/17/2022 to Mon 10/17/2022 UPDATED by CONED 09/07/2022

(Import)

0001 Continuous 0031

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

## BUCHAN\_N-EASTVIEW\_345\_W93

FWD

Mon 10/17/2022 to Fri 10/28/2022 UPDATED by CONED 09/07/2022

(Import)

0001 Continuous 0200

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

## CHATGUAY-MASSENA\_765\_7040

FWD

Mon 10/17/2022 to Mon 10/24/2022

(Import)

0100 Continuous 1800

MOSES SOUTH

**1550 MW**

Impacts Total Transfer Capability 1600 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: HQ

**NYISO TRANSFER LIMITATIONS**

Monday ,October 10, 2022 to Wednesday, April 10, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**CHATGUAY-MASSENA\_\_765\_7040**

Mon 10/17/2022 to Mon 10/24/2022  
0100 Continuous 1800

Work scheduled by: HQ

	FWD	REV
	(Import)	(Export)
SCH - HQ - NY	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	1500 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

**CHAT\_DC\_GC1 & CHAT\_DC\_GC2**

Mon 10/17/2022 to Mon 10/24/2022  
0100 1800

Work scheduled by:

	FWD
	(Import)
MOSES SOUTH	<b>2550 MW</b>
Impacts Total Transfer Capability	600 MW
TTC with All Lines In Service	3150 MW

**CHAT\_DC\_GC1 & CHAT\_DC\_GC2**

Mon 10/17/2022 to Mon 10/24/2022  
0100 1800

Work scheduled by:

	FWD	REV
	(Import)	(Export)
SCH - HQ - NY	<b>1370 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	130 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

**CHAT\_DC\_GC2**

Mon 10/17/2022 to Mon 10/24/2022  
0100 Continuous 1800

Work scheduled by: HQ

	FWD
	(Import)
MOSES SOUTH	<b>2850 MW</b>
Impacts Total Transfer Capability	300 MW
TTC with All Lines In Service	3150 MW

**CHAT\_DC\_GC2**

Mon 10/17/2022 to Mon 10/24/2022  
0100 Continuous 1800

Work scheduled by: HQ

		REV
		(Export)
SCH - HQ - NY		<b>500 MW</b>
Impacts Total Transfer Capability		500 MW
TTC with All Lines In Service		1000 MW

**NIAGARA\_-DYSINGER\_345\_ND1**

Mon 10/17/2022 to Fri 10/21/2022 **UPDATED** **by NYPA** **02/10/2022**  
0500 Continuous 1700

Work scheduled by: NYPA

	FWD
	(Import)
DYSINGER EAST	<b>2700 MW</b>
Impacts Total Transfer Capability	500 MW
TTC with All Lines In Service	3200 MW

**ALCOA\_PA\_115KV\_R8105**

Mon 10/17/2022 to Wed 10/19/2022  
0800 Daily(No Weekends) 1630

Work scheduled by: NGrid

	FWD
	(Import)
MOSES SOUTH	<b>3100 MW</b>
Impacts Total Transfer Capability	50 MW
TTC with All Lines In Service	3150 MW

# NYISO TRANSFER LIMITATIONS

Monday ,October 10, 2022 to Wednesday, April 10, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## RAMAPO\_\_-BUCHAN\_N\_345\_Y94

FWD

Tue 10/18/2022 to Sun 10/30/2022

UPDATEDby CONED 09/07/2022

(Import)

0001 Continuous 0200

Work scheduled by: ConEd

UPNY CONED

**7580 MW**

Impacts Total Transfer Capability 235 MW

TTC with All Lines In Service 7815 MW

## FIVEMILE-ESTOLERD\_345\_29

Tue 10/18/2022 to Tue 10/18/2022

0730 Daily(No Weekends) 1230

Work scheduled by: NGrid

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

## FRASANNX-COOPERS\_\_345\_UCC2-41

FWD

Tue 10/18/2022 to Wed 10/19/2022

0730 Continuous 1800

Work scheduled by: NYSEG

**ARR: 19**

CENTRAL EAST - VC

**2275 MW**

Impacts Total Transfer Capability 310 MW

TTC with All Lines In Service 2585 MW

## MARCY\_\_-FRASANNX\_345\_UCC2-41

FWD

Tue 10/18/2022 to Wed 10/19/2022

0730 Continuous 1800

Work scheduled by: NYSEG

**ARR: 19**

CENTRAL EAST - VC

**2275 MW**

Impacts Total Transfer Capability 310 MW

TTC with All Lines In Service 2585 MW

## PANNELL\_-CLAY\_\_\_\_345\_1

FWD

Mon 10/24/2022 to Fri 10/28/2022

0700 Continuous 1530

Work scheduled by: NYPA

UPDATEDby NYPA 09/01/2022

(Import)

WEST CENTRAL

**1300 MW**

Impacts Total Transfer Capability 950 MW

TTC with All Lines In Service 2250 MW

## ELBRIDGE-LAFAYTTE\_345\_17-LE

FWD

Tue 10/25/2022 to Tue 10/25/2022

0630 Continuous 1700

Work scheduled by: NGrid

**ARR: 75**

OSWEGO EXPORT

**5250 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

## OSWEGO\_\_-ELBRIDGE\_345\_17

FWD

Tue 10/25/2022 to Tue 10/25/2022

0630 Continuous 1700

Work scheduled by: NGrid

**ARR: 75**

OSWEGO EXPORT

**5250 MW**

Impacts Total Transfer Capability 0 MW

TTC with All Lines In Service 5250 MW

# NYISO TRANSFER LIMITATIONS

Monday ,October 10, 2022 to Wednesday, April 10, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## MAINESBG-WATRCURE\_345\_30

Tue 10/25/2022 to Tue 10/25/2022  
0800 Daily 1500  
Work scheduled by: NYSEG

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

## LEEDS\_345KV\_R395

Wed 10/26/2022 to Wed 10/26/2022  
0900 Daily(No Weekends) 1030  
Work scheduled by: NGrid

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

## WATRCURE-OAKDALE\_345\_31

Thu 10/27/2022 to Thu 10/27/2022  
0800 Daily 1500  
Work scheduled by: NYSEG

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

## EASTVIEW-SPRNBK\_345\_W79

Fri 10/28/2022 to Fri 10/28/2022 UPDATED by CONED 09/07/2022  
0130 Continuous 0200  
Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

## PANNELL\_-CLAY\_345\_2

Mon 10/31/2022 to Fri 11/04/2022 UPDATED by NYPA 09/01/2022  
0700 Continuous 1530  
Work scheduled by: NYPA

FWD  
(Import)  
WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

## BUCHAN\_S-MILLWOOD\_345\_W97

Tue 11/01/2022 to Wed 11/02/2022  
0001 Continuous 0200  
Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **7680 MW**  
Impacts Total Transfer Capability 135 MW  
TTC with All Lines In Service 7815 MW

## CLAY\_-EDIC\_345\_1-16

Tue 11/01/2022 to Thu 11/03/2022 UPDATED by NGRID 05/09/2022  
0600 Continuous 1900  
Work scheduled by: NGrid

FWD  
(Import)  
OSWEGO EXPORT **4850 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

# NYISO TRANSFER LIMITATIONS

Monday ,October 10, 2022 to Wednesday, April 10, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## GILBOA\_\_-N.SCTLND\_345\_GNS-1

Tue 11/01/2022 to Tue 12/06/2022 **UPDATED** **by NGRID** **12/29/2021**  
 0700 Continuous 1900  
 Work scheduled by: NGrid

FWD  
 (Import)  
 CENTRAL EAST - VC **2300 MW**  
 Impacts Total Transfer Capability 285 MW  
 TTC with All Lines In Service 2585 MW

## MARCY\_\_-N.SCTLND\_345\_18

Tue 11/01/2022 to Tue 12/06/2022 **UPDATED** **by NGRID** **12/29/2021**  
 0700 Continuous 1900  
 Work scheduled by: NGrid **ARR: 19**

FWD  
 (Import)  
 CENTRAL EAST - VC **1345 MW**  
 Impacts Total Transfer Capability 1240 MW  
 TTC with All Lines In Service 2585 MW

## LINDN\_CG-LNDVFT\_\_345\_V-3022

Tue 11/01/2022 to Fri 11/04/2022  
 0800 Continuous 1500  
 Work scheduled by: PJM

FWD	REV
(Import)	(Export)
SCH - PJM_VFT	<b>0 MW</b> <b>0 MW</b>
Impacts Total Transfer Capability	315 MW 315 MW
TTC with All Lines In Service	315 MW 315 MW

## NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE

Wed 11/02/2022 to Tue 11/08/2022  
 0600 Continuous 1600  
 Work scheduled by: LI

FWD  
 (Import)  
 SCH - PJM\_NEPTUNE **0 MW**  
 Impacts Total Transfer Capability 660 MW  
 TTC with All Lines In Service 660 MW

## NEWBRDGE-DUFFYAVE\_345\_501

Wed 11/02/2022 to Tue 11/08/2022  
 0600 Continuous 1600  
 Work scheduled by: LI

FWD  
 (Import)  
 SCH - PJM\_NEPTUNE **0 MW**  
 Impacts Total Transfer Capability 660 MW  
 TTC with All Lines In Service 660 MW

## NEWBRDGE\_345\_138\_BK\_1

Wed 11/02/2022 to Tue 11/08/2022  
 0600 Continuous 1600  
 Work scheduled by: LI

FWD  
 (Import)  
 SCH - PJM\_NEPTUNE **375 MW**  
 Impacts Total Transfer Capability 285 MW  
 TTC with All Lines In Service 660 MW

## NEWBRDGE\_345\_138\_BK\_2

Wed 11/02/2022 to Tue 11/08/2022  
 0600 Continuous 1600  
 Work scheduled by: LI

FWD  
 (Import)  
 SCH - PJM\_NEPTUNE **375 MW**  
 Impacts Total Transfer Capability 285 MW  
 TTC with All Lines In Service 660 MW

# NYISO TRANSFER LIMITATIONS

Monday ,October 10, 2022 to Wednesday, April 10, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## DUNWODIE\_345KV\_3

FWD

Thu 11/10/2022 to Thu 11/10/2022 UPDATED by CE 06/30/2022  
0230 Continuous 0300

Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

## DUNWODIE\_345KV\_5

FWD

Thu 11/10/2022 to Thu 11/10/2022 UPDATED by CE 06/30/2022  
0230 Continuous 0300

Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

## MAINESBG-WATRCURE\_345\_30

FWD

Thu 11/10/2022 to Thu 11/10/2022  
0800 Continuous 1600

Work scheduled by: PJM

SCH - PJ - NY **2300 MW**  
Impacts Total Transfer Capability 550 MW  
TTC with All Lines In Service 2850 MW

## DUNWODIE\_345KV\_7

FWD

Wed 11/16/2022 to Wed 11/16/2022  
0100 Continuous 0200

Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

## EASTVIEW-SPRNBK\_345\_W79

FWD

Sat 11/19/2022 to Sat 11/19/2022 UPDATED by CONED 09/07/2022  
0001 Continuous 0030

Work scheduled by: ConEd

UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

## BUCHAN\_N-EASTVIEW\_345\_W93

FWD

Sat 11/19/2022 to Sat 11/26/2022 UPDATED by CONED 09/07/2022  
0001 Continuous 0200

Work scheduled by: ConEd

UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

## RAMAPO\_-BUCHAN\_N\_345\_Y94

FWD

Sat 11/19/2022 to Sat 11/26/2022 UPDATED by CONED 09/07/2022  
0001 Continuous 0200

Work scheduled by: ConEd

UPNY CONED **7580 MW**  
Impacts Total Transfer Capability 235 MW  
TTC with All Lines In Service 7815 MW

# NYISO TRANSFER LIMITATIONS

Monday ,October 10, 2022 to Wednesday, April 10, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## E13THSTA-FARRAGUT\_345\_45

FWD

Wed 11/23/2022 to Sat 12/10/2022 UPDATED by CONED 09/07/2022

(Import)

0001 Continuous 0300

SPR/DUN-SOUTH **3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

## HOMRC\_NY-MAINS\_NY\_345\_47

Wed 11/23/2022 to Wed 11/23/2022 UPDATED by PJM 08/09/2022

0800 Continuous 1600

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: PJM

## EASTVIEW-SPRNBK\_345\_W79

FWD

Sat 11/26/2022 to Sat 11/26/2022 UPDATED by CONED 09/07/2022

(Import)

0130 Continuous 0200

UPNY CONED **4350 MW**

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

## BUCHAN\_S-MILLWOOD\_345\_W98

FWD

Tue 11/29/2022 to Thu 12/01/2022

(Import)

0001 Continuous 0200

UPNY CONED

**7680 MW**

Impacts Total Transfer Capability 135 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

## MILLWOOD\_345KV\_18

FWD

Tue 11/29/2022 to Thu 12/01/2022

(Import)

0001 Continuous 0200

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

## CRICKVLY-PLSNTVLY\_345\_F84

FWD

Thu 12/01/2022 to Fri 12/16/2022

(Import)

0001 Continuous 0200

SCH - NE - NY

**600 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 1400 MW

Work scheduled by: ConEd

## CRICKVLY-PLSNTVLY\_345\_F84

FWD

REV

Thu 12/01/2022 to Fri 12/16/2022

(Import) (Export)

0001 Continuous 0200

SCH - NPX\_1385

**100 MW 100 MW**

Impacts Total Transfer Capability 100 MW 100 MW

TTC with All Lines In Service 200 MW 200 MW

Work scheduled by: ConEd

**NYISO TRANSFER LIMITATIONS**

Monday ,October 10, 2022 to Wednesday, April 10, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**MOSES\_\_\_-ADIRNDCK\_230\_MAl**

FWD

Thu 12/01/2022 to Wed 03/01/2023

UPDATEDby NYPA09/02/2022

(Import)

0701 Continuous 1100

MOSES SOUTH

**2300 MW**

Impacts Total Transfer Capability 850 MW

TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

**MILLWOOD\_345KV\_18**

FWD

Fri 12/02/2022 to Mon 12/12/2022

(Import)

0001 Continuous 1800

UPNY CONED

**4350 MW**

Impacts Total Transfer Capability 3465 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

**MARCY\_\_\_345KV\_CSC**

FWD

Wed 12/07/2022 to Tue 12/20/2022

(Import)

0700 Continuous 1530

CENTRAL EAST - VC

**2535 MW**

Impacts Total Transfer Capability 50 MW

TTC with All Lines In Service 2585 MW

Work scheduled by: NYPA

**HOPATCON-RAMAPO\_\_\_500\_5018**

FWD

REV

Mon 12/12/2022 to Fri 12/16/2022

(Import) (Export)

0001 Continuous 2000

SCH - PJ - NY

**1650 MW 1200 MW**

Impacts Total Transfer Capability 1200 MW 1000 MW

TTC with All Lines In Service 2850 MW 2200 MW

Work scheduled by: ConEd

**HOPATCON-RAMAPO\_\_\_500\_5018**

FWD

Mon 12/12/2022 to Fri 12/16/2022

(Import)

0001 Continuous 2000

TOTAL EAST

**5200 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 6000 MW

Work scheduled by: ConEd

**HOPATCON-RAMAPO\_\_\_500\_5018**

FWD

Mon 12/12/2022 to Fri 12/16/2022

(Import)

0001 Continuous 2000

UPNY CONED

**7480 MW**

Impacts Total Transfer Capability 335 MW

TTC with All Lines In Service 7815 MW

Work scheduled by: ConEd

**HOPATCON-RAMAPO\_\_\_500\_5018 & MARCY\_\_\_345KV\_CSC**

FWD

Mon 12/12/2022 to Fri 12/16/2022

(Import)

0001 2000

TOTAL EAST

**5100 MW**

Impacts Total Transfer Capability 900 MW

TTC with All Lines In Service 6000 MW

Work scheduled by:



# NYISO TRANSFER LIMITATIONS

Monday ,October 10, 2022 to Wednesday, April 10, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

RAMAPO___345_345_PAR3500					FWD	REV
Mon 12/12/2022	to	Fri 12/16/2022			(Import)	(Export)
0001	Continuous	2000			SCH - PJ - NY	<b>2500 MW</b> <b>1250 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	350 MW 950 MW
					TTC with All Lines In Service	2850 MW 2200 MW
RAMAPO___345_345_PAR4500					FWD	REV
Mon 12/12/2022	to	Fri 12/16/2022			(Import)	(Export)
0001	Continuous	2000			SCH - PJ - NY	<b>2500 MW</b> <b>1250 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	350 MW 950 MW
					TTC with All Lines In Service	2850 MW 2200 MW
RAMAPO___500_345_BK 1500					FWD	REV
Mon 12/12/2022	to	Fri 12/16/2022			(Import)	(Export)
0001	Continuous	2000			SCH - PJ - NY	<b>1650 MW</b> <b>1200 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	1200 MW 1000 MW
					TTC with All Lines In Service	2850 MW 2200 MW
RAMAPO___500_345_BK 1500					FWD	
Mon 12/12/2022	to	Fri 12/16/2022			(Import)	
0001	Continuous	2000			UPNY CONED	<b>7480 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	335 MW
					TTC with All Lines In Service	7815 MW
CRICKVLY-PLSNTVLY_345_F83					FWD	
Fri 12/16/2022	to	Sun 01/01/2023	<b>EXTENDED</b>	<b>by CE</b> <b>09/22/2022</b>	(Import)	
0201	Continuous	0200			SCH - NE - NY	<b>600 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	800 MW
					TTC with All Lines In Service	1400 MW
CRICKVLY-PLSNTVLY_345_F83					FWD	REV
Fri 12/16/2022	to	Sun 01/01/2023	<b>EXTENDED</b>	<b>by CE</b> <b>09/22/2022</b>	(Import)	(Export)
0201	Continuous	0200			SCH - NPX_1385	<b>100 MW</b> <b>100 MW</b>
Work scheduled by: ConEd					Impacts Total Transfer Capability	100 MW 100 MW
					TTC with All Lines In Service	200 MW 200 MW
FRASER___-COOPERS___345_33					FWD	
Mon 12/19/2022	to	Fri 12/23/2022			(Import)	
0600	Continuous	1659			CENTRAL EAST - VC	<b>2335 MW</b>
Work scheduled by: NYSEG					Impacts Total Transfer Capability	250 MW
					TTC with All Lines In Service	2585 MW

# NYISO TRANSFER LIMITATIONS

Monday ,October 10, 2022 to Wednesday, April 10, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## HOMRC\_NY-MAINS\_NY\_345\_47

Thu 12/22/2022 to Thu 12/22/2022

0800 Continuous 1600

Work scheduled by: PJM

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

## W49TH\_ST-E13THSTA\_345\_M54

Tue 12/27/2022 to Tue 12/27/2022

0130 Continuous 0200

Work scheduled by: ConEd

UPDATEDby CE09/25/2022

SPR/DUN-SOUTH

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

FWD

(Import)

**3800 MW**

## CLAY -EDIC 345\_1-16

Fri 12/30/2022 to Sat 12/31/2022

0600 Continuous 1900

Work scheduled by: NGrid

UPDATEDby NGRID05/09/2022

OSWEGO EXPORT

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 5250 MW

FWD

(Import)

**4850 MW**

## E13THSTA-FARRAGUT\_345\_46

Mon 01/02/2023 to Wed 01/04/2023

0001 Continuous 0300

Work scheduled by: ConEd

UPDATEDby CE10/06/2022

SPR/DUN-SOUTH

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

FWD

(Import)

**3800 MW**

## FRASER 345\_FRASER SVC

Tue 01/03/2023 to Tue 02/28/2023

0700 Continuous 1730

Work scheduled by: NYPA

UPDATEDby NYPA12/30/2021

CENTRAL EAST - VC

Impacts Total Transfer Capability 35 MW

TTC with All Lines In Service 2585 MW

FWD

(Import)

**2550 MW**

## NIAGARA -PACKARD\_230\_62

Mon 01/09/2023 to Fri 01/20/2023

0500 Continuous 1900

Work scheduled by: NYPA

SCH - OH - NY

Impacts Total Transfer Capability 1400 MW 150 MW

TTC with All Lines In Service 2300 MW 2000 MW

FWD

(Import) (Export)

**900 MW 1850 MW**

## E13THSTA-FARRAGUT\_345\_46

Fri 01/27/2023 to Wed 02/01/2023

0001 Continuous 0300

Work scheduled by: ConEd

UPDATEDby CE10/06/2022

SPR/DUN-SOUTH

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

FWD

(Import)

**3800 MW**

# NYISO TRANSFER LIMITATIONS

Monday ,October 10, 2022 to Wednesday, April 10, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## E13THSTA-FARRAGUT\_345\_45

Wed 02/08/2023 to Wed 02/08/2023  
0001 Continuous 0030

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

## E13THSTA-FARRAGUT\_345\_45

Wed 02/22/2023 to Wed 02/22/2023  
0230 Continuous 0300

Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

## EDIC\_\_-FRASER\_\_345\_EF24-40

Wed 03/01/2023 to Sat 04/15/2023  
0600 Continuous 1800

Work scheduled by: NGrid

FWD  
(Import)  
CENTRAL EAST - VC **2275 MW**  
Impacts Total Transfer Capability 310 MW  
TTC with All Lines In Service 2585 MW

## GORDONRD-N.SCTLND\_345\_55

Wed 03/01/2023 to Fri 03/31/2023  
0700 Continuous 1600

Work scheduled by: LS

FWD  
(Import)  
CENTRAL EAST - VC **2045 MW**  
Impacts Total Transfer Capability 540 MW  
TTC with All Lines In Service 2585 MW

## MOSES\_\_-ADIRNDCK\_230\_MAI

Wed 03/01/2023 to Fri 05/26/2023  
1101 Continuous 1930

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

## NIAGARA\_-ROBNSNRD\_230\_64

Mon 03/06/2023 to Fri 03/17/2023  
0500 Continuous 1900

Work scheduled by: NYPA

REV  
(Export)  
SCH - OH - NY **1900 MW**  
Impacts Total Transfer Capability 100 MW  
TTC with All Lines In Service 2000 MW

## N.SCTLND-ALPS\_\_\_\_345\_2

Mon 03/27/2023 to Fri 05/19/2023  
0700 Continuous 1900

Work scheduled by: NGrid

UPDATED by NGRID 06/16/2022

FWD  
(Import)  
SCH - NE - NY **900 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1400 MW

# NYISO TRANSFER LIMITATIONS

Monday ,October 10, 2022 to Wednesday, April 10, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

N.SCTLND-ALPS_____345_2					FWD	REV
					(Import)	(Export)
Mon 03/27/2023	to	Fri 05/19/2023	<u>UPDATED</u>	<u>by NGRID</u> <u>06/16/2022</u>	SCH - NPX_1385	<b>100 MW</b>
0700	Continuous	1900			Impacts Total Transfer Capability	100 MW
Work scheduled by: NGrid					TTC with All Lines In Service	200 MW
MOTTHAVN-RAINEY_____345_Q12					FWD	
					(Import)	
Wed 03/29/2023	to	Sun 04/30/2023	<u>UPDATED</u>	<u>by CE</u> <u>06/14/2022</u>	SPR/DUN-SOUTH	<b>3800 MW</b>
0001	Continuous	0200			Impacts Total Transfer Capability	800 MW
Work scheduled by: ConEd					TTC with All Lines In Service	4600 MW
PLSNTVLY_345KV_RNS4					FWD	
					(Import)	
Sat 04/01/2023	to	Sat 04/01/2023			UPNY CONED	<b>3800 MW</b>
0700	Continuous	0730			Impacts Total Transfer Capability	4015 MW
Work scheduled by: NGrid					TTC with All Lines In Service	7815 MW
ATHENS__-PLSNTVLY_345_91					FWD	
					(Import)	
Sat 04/01/2023	to	Sat 04/15/2023			UPNY CONED	<b>3800 MW</b>
0700	Continuous	1900			Impacts Total Transfer Capability	4015 MW
Work scheduled by: NGrid					TTC with All Lines In Service	7815 MW
LINDN_CG-LNDVFT_____345_V-3022					FWD	REV
					(Import)	(Export)
Sun 04/09/2023	to	Sat 04/15/2023			SCH - PJM_VFT	<b>0 MW</b>
1400	Continuous	1400			Impacts Total Transfer Capability	315 MW
Work scheduled by: PJM					TTC with All Lines In Service	315 MW
DYSINGER-STA_255_____345_DH1					FWD	
					(Import)	
Mon 04/10/2023	to	Fri 04/14/2023			DYSINGER EAST	<b>2850 MW</b>
0500	Continuous	2000			Impacts Total Transfer Capability	350 MW
Work scheduled by: NYPA					TTC with All Lines In Service	3200 MW
GORDONRD-N.SCTLND_345_55					FWD	
					(Import)	
Mon 04/10/2023	to	Fri 04/14/2023			CENTRAL EAST - VC	<b>2045 MW</b>
0600	Continuous	1700			Impacts Total Transfer Capability	540 MW
Work scheduled by: NGrid					TTC with All Lines In Service	2585 MW

<b>CENTRAL EAST</b>	<b>2650MW</b>
<b>CENTRAL EAST - VC</b>	<b>2585MW</b>
<b>TOTAL EAST</b>	<b>6000MW</b>
<b>UPNY CONED</b>	<b>7815MW</b>
<b>SPR/DUN-SOUTH</b>	<b>4600MW</b>
<b>DYSINGER EAST</b>	<b>3200MW</b>
<b>MOSES SOUTH</b>	<b>3150MW</b>

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**DUNWODIE\_345KV\_3**

FWD

Wed 04/12/2023 to Wed 04/12/2023

(Import)

0201 Continuous 0230

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

Work scheduled by: ConEd

TTC with All Lines In Service 4600 MW

**DUNWODIE\_345KV\_4**

FWD

Wed 04/12/2023 to Wed 04/12/2023

(Import)

0201 Continuous 0230

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

Work scheduled by: ConEd

TTC with All Lines In Service 4600 MW

**PLSNTVLE-DUNWODIE\_345\_W89**

FWD

Wed 04/12/2023 to Wed 04/12/2023

(Import)

0201 Continuous 0230

UPNY CONED

**4000 MW**

Impacts Total Transfer Capability 3815 MW

Work scheduled by: ConEd

TTC with All Lines In Service 7815 MW

**PLSNTVLY\_345KV\_RNS4**

FWD

Sat 04/15/2023 to Sat 04/15/2023

(Import)

1830 Continuous 1900

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 4015 MW

Work scheduled by: NGrid

TTC with All Lines In Service 7815 MW

**PLSNTVLY\_345KV\_RNS5**

FWD

Sun 04/16/2023 to Sun 04/16/2023

(Import)

0700 Continuous 0730

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 4015 MW

Work scheduled by: NGrid

TTC with All Lines In Service 7815 MW

**LEEDS\_\_-PLSNTVLY\_345\_92**

FWD

Sun 04/16/2023 to Sun 04/30/2023

(Import)

0700 Continuous 1900

UPNY CONED

**3800 MW**

Impacts Total Transfer Capability 4015 MW

Work scheduled by: NGrid

TTC with All Lines In Service 7815 MW

**DYSINGER-STA\_255\_\_345\_DH2**

FWD

Mon 04/17/2023 to Fri 04/21/2023

(Import)

0500 Continuous 2000

DYSINGER EAST

**2850 MW**

Impacts Total Transfer Capability 350 MW

Work scheduled by: NYPA

TTC with All Lines In Service 3200 MW

# NYISO TRANSFER LIMITATIONS

Monday ,October 10, 2022 to Wednesday, April 10, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>CLAY____-EDIC____345_2-15</b>				FWD	
Mon 04/17/2023	to	Fri 04/28/2023		(Import)	
0600	Continuous	1800		OSWEGO EXPORT	<b>4850 MW</b>
Work scheduled by: NGrid				Impacts Total Transfer Capability	400 MW
				TTC with All Lines In Service	5250 MW
<b>DUNWODIE_345KV_3</b>				FWD	
Thu 04/20/2023	to	Thu 04/20/2023		(Import)	
0130	Continuous	0200		SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
<b>DUNWODIE_345KV_4</b>				FWD	
Thu 04/20/2023	to	Thu 04/20/2023		(Import)	
0130	Continuous	0200		SPR/DUN-SOUTH	<b>3800 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
<b>PLSNTVLE-DUNWODIE_345_W89</b>				FWD	
Thu 04/20/2023	to	Thu 04/20/2023		(Import)	
0130	Continuous	0200		UPNY CONED	<b>4000 MW</b>
Work scheduled by: ConEd				Impacts Total Transfer Capability	3815 MW
				TTC with All Lines In Service	7815 MW
<b>PANNELL_-CLAY____345_1</b>				FWD	
Mon 04/24/2023	to	Fri 04/28/2023		(Import)	
0700	Continuous	1530		WEST CENTRAL	<b>1300 MW</b>
Work scheduled by: NYPA				Impacts Total Transfer Capability	950 MW
				TTC with All Lines In Service	2250 MW
<b>PLSNTVLY_345KV_RNS5</b>				FWD	
Sun 04/30/2023	to	Sun 04/30/2023		(Import)	
1830	Continuous	1900		UPNY CONED	<b>3800 MW</b>
Work scheduled by: NGrid				Impacts Total Transfer Capability	4015 MW
				TTC with All Lines In Service	7815 MW
<b>SHOR_NPX-SHOREHAM_138_CSC</b>				FWD	REV
Mon 05/01/2023	to	Fri 05/05/2023		(Import)	(Export)
0600	Continuous	1800		SCH - NPX_CSC	<b>0 MW 0 MW</b>
Work scheduled by: LI				Impacts Total Transfer Capability	330 MW 330 MW
				TTC with All Lines In Service	330 MW 330 MW

# NYISO TRANSFER LIMITATIONS

Monday ,October 10, 2022 to Wednesday, April 10, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## PANNELL\_-CLAY\_\_\_\_345\_2

Mon 05/01/2023 to Fri 05/05/2023  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

## PLSNTVLY-WOOD\_ST\_\_345\_F30

Wed 05/03/2023 to Mon 05/15/2023  
0001 Continuous 2200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 3815 MW  
TTC with All Lines In Service 7815 MW

## PLSNTVLY\_345KV\_RNS5

Wed 05/03/2023 to Mon 05/15/2023  
0001 Continuous 2200

Work scheduled by: ConEd

FWD  
(Import)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

## NIAGARA\_-ROBNSNRD\_230\_64

Fri 05/05/2023 to Fri 05/05/2023  
0500 Continuous 1700

Work scheduled by: NYPA

REV  
(Export)  
SCH - OH - NY **1400 MW**  
Impacts Total Transfer Capability 150 MW  
TTC with All Lines In Service 1550 MW

## W49TH\_ST\_345KV\_6

Sat 05/06/2023 to Sat 05/06/2023  
0001 Continuous 0030

Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJM\_HTP **300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

## W49TH\_ST\_345KV\_8

Sat 05/06/2023 to Sat 05/06/2023  
0001 Continuous 0030

Work scheduled by: ConEd

FWD  
(Import)  
SCH - PJM\_HTP **450 MW**  
Impacts Total Transfer Capability 210 MW  
TTC with All Lines In Service 660 MW

## DOLSONAV-ROCKTVRN\_345\_DART44

Mon 05/08/2023 to Sat 05/13/2023  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2485 MW**  
Impacts Total Transfer Capability 100 MW  
TTC with All Lines In Service 2585 MW

# NYISO TRANSFER LIMITATIONS

Monday ,October 10, 2022 to Wednesday, April 10, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## COOPERS\_-DOLSONAV\_345\_CCDA42

FWD

Mon 05/08/2023 to Sun 05/21/2023

(Import)

0700 Continuous 1530

CENTRAL EAST - VC

**2485 MW**

Impacts Total Transfer Capability 100 MW

TTC with All Lines In Service 2585 MW

Work scheduled by: NYPA

## W49TH\_ST\_345KV\_6

FWD

Sat 05/13/2023 to Sat 05/13/2023

(Import)

0130 Continuous 0200

SCH - PJM\_HTP

**300 MW**

Impacts Total Transfer Capability 360 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

## W49TH\_ST\_345KV\_8

FWD

Sat 05/13/2023 to Sat 05/13/2023

(Import)

0130 Continuous 0200

SCH - PJM\_HTP

**450 MW**

Impacts Total Transfer Capability 210 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

## MOTTHAVN-RAINEY\_345\_Q11

FWD

Wed 05/17/2023 to Sat 05/20/2023

(Import)

0001 Continuous 0200

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

## BECK\_-NIAGARA\_230\_PA27

Tue 05/30/2023 to Fri 06/02/2023

0500 Continuous 2100

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: NYPA

## NIAGARA\_345\_230\_AT4

REV

Wed 06/28/2023 to Thu 06/29/2023

(Export)

0500 Continuous 1900

SCH - OH - NY

**1150 MW**

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 1550 MW

Work scheduled by: NYPA

## NIAGARA\_345\_230\_AT4

REV

Mon 08/21/2023 to Fri 08/25/2023

(Export)

0500 Continuous 2100

SCH - OH - NY

**1150 MW**

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 1550 MW

Work scheduled by: NYPA



# NYISO TRANSFER LIMITATIONS

Monday ,October 10, 2022 to Wednesday, April 10, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## ADIRNDCK-PORTER\_\_\_230\_12

Tue 08/22/2023 to Tue 08/22/2023  
0700 Continuous 1530  
Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

## ADIRNDCK-CHASLAKE\_230\_13

Wed 08/23/2023 to Wed 08/23/2023  
0700 Continuous 1530  
Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

## CLAY\_\_\_-EDIC\_\_\_345\_1-16

Mon 09/11/2023 to Fri 09/15/2023  
0700 Continuous 1530  
Work scheduled by: NYPA

FWD  
(Import)  
OSWEGO EXPORT **4850 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

## FRASER\_\_\_-GILBOA\_\_\_345\_GF5-35

Mon 09/11/2023 to Sun 09/17/2023  
0700 Continuous 1530  
Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2450 MW**  
Impacts Total Transfer Capability 135 MW  
TTC with All Lines In Service 2585 MW

## SPRNBRK\_-W49TH\_ST\_345\_M51

Fri 09/15/2023 to Mon 10/23/2023 **UPDATED by CE 08/10/2022**  
0001 Continuous 0200  
Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

## SPRNBRK\_\_\_345KV\_RNS5

Fri 09/15/2023 to Mon 10/23/2023 **UPDATED by CE 08/10/2022**  
0001 Continuous 0200  
Work scheduled by: ConEd

FWD  
(Import)  
SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

## CLAY\_\_\_-EDIC\_\_\_345\_2-15

Mon 09/18/2023 to Fri 09/22/2023  
0700 Continuous 1530  
Work scheduled by: NYPA

FWD  
(Import)  
OSWEGO EXPORT **4850 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

# NYISO TRANSFER LIMITATIONS

Monday ,October 10, 2022 to Wednesday, April 10, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## NIAGARA\_-DYSINGER\_345\_ND2

Mon 09/25/2023 to Fri 09/29/2023  
0500 Continuous 2000  
Work scheduled by: NYPA

FWD  
(Import)  
DYSINGER EAST **2700 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 3200 MW

## MARCY\_345KV\_CSC

Mon 09/25/2023 to Sat 10/07/2023  
0700 Continuous 1530  
Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2535 MW**  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 2585 MW

## SHOR\_NPX-SHOREHAM\_138\_CSC

Mon 10/02/2023 to Fri 10/06/2023  
0600 Continuous 1800  
Work scheduled by: LI

	FWD	REV
	(Import)	(Export)
SCH - NPX_CSC	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	330 MW	330 MW
TTC with All Lines In Service	330 MW	330 MW

## NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE

Mon 10/09/2023 to Fri 10/13/2023  
0600 Continuous 1600  
Work scheduled by: LI

FWD  
(Import)  
SCH - PJM\_NEPTUNE **0 MW**  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

## NEWBRDGE-DUFFYAVE\_345\_501

Mon 10/09/2023 to Fri 10/13/2023  
0600 Continuous 1600  
Work scheduled by: LI

FWD  
(Import)  
SCH - PJM\_NEPTUNE **0 MW**  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

## NEWBRDGE\_345\_138\_BK\_1

Mon 10/09/2023 to Fri 10/13/2023  
0600 Continuous 1600  
Work scheduled by: LI

FWD  
(Import)  
SCH - PJM\_NEPTUNE **375 MW**  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 660 MW

## NEWBRDGE\_345\_138\_BK\_2

Mon 10/09/2023 to Fri 10/13/2023  
0600 Continuous 1600  
Work scheduled by: LI

FWD  
(Import)  
SCH - PJM\_NEPTUNE **375 MW**  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 660 MW

# NYISO TRANSFER LIMITATIONS

Monday ,October 10, 2022 to Wednesday, April 10, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## GILBOA\_\_-N.SCTLND\_345\_GNS-1

Mon 10/09/2023 to Fri 10/13/2023  
0700 Continuous 1530

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **2300 MW**  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 2585 MW

## NIAGARA\_\_-PACKARD\_\_230\_61

Fri 10/13/2023 to Fri 10/13/2023  
0500 Continuous 1900

Work scheduled by: NYPA

REV  
(Export)  
SCH - OH - NY **1350 MW**  
Impacts Total Transfer Capability 200 MW  
TTC with All Lines In Service 1550 MW

## MOSES\_\_-MASSENA\_\_230\_MMS1 & MOSES\_\_-MASSENA\_\_230\_MMS2

Wed 11/15/2023 to Mon 11/20/2023  
0700 1530

Work scheduled by:

FWD REV  
(Import) (Export)  
SCH - HQ - NY **850 MW 0 MW**  
Impacts Total Transfer Capability 650 MW 1000 MW  
TTC with All Lines In Service 1500 MW 1000 MW

## MOSES\_\_-MASSENA\_\_230\_MMS1 & MOSES\_\_-MASSENA\_\_230\_MMS2

Wed 11/15/2023 to Mon 11/20/2023  
0700 1530

Work scheduled by:

FWD  
(Import)  
SCH - HQ\_CEDARS **90 MW**  
Impacts Total Transfer Capability 189 MW  
TTC with All Lines In Service 279 MW

## CHATGUAY-MASSENA\_\_765\_7040

Wed 11/15/2023 to Mon 11/27/2023  
0700 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **1550 MW**  
Impacts Total Transfer Capability 1600 MW  
TTC with All Lines In Service 3150 MW

## CHATGUAY-MASSENA\_\_765\_7040

Wed 11/15/2023 to Mon 11/27/2023  
0700 Continuous 1730

Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - HQ - NY **0 MW 0 MW**  
Impacts Total Transfer Capability 1500 MW 1000 MW  
TTC with All Lines In Service 1500 MW 1000 MW

## MASSENA\_\_-MARCY\_\_765\_MSU1

Wed 11/15/2023 to Mon 11/27/2023  
0700 Continuous 1730

Work scheduled by: NYPA

FWD  
(Import)  
CENTRAL EAST - VC **1720 MW**  
Impacts Total Transfer Capability 865 MW  
TTC with All Lines In Service 2585 MW

# NYISO TRANSFER LIMITATIONS

Monday ,October 10, 2022 to Wednesday, April 10, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

## MASSENA\_-MARC\_765\_MSU1

Wed 11/15/2023 to Mon 11/27/2023  
0700 Continuous 1730  
Work scheduled by: NYPA

FWD  
(Import)  
MOSES SOUTH **500 MW**  
Impacts Total Transfer Capability 2650 MW  
TTC with All Lines In Service 3150 MW

## MASSENA\_-MARC\_765\_MSU1

Wed 11/15/2023 to Mon 11/27/2023  
0700 Continuous 1730  
Work scheduled by: NYPA

FWD REV  
(Import) (Export)  
SCH - HQ - NY **475 MW 1000 MW**  
Impacts Total Transfer Capability 1025 MW 0 MW  
TTC with All Lines In Service 1500 MW 1000 MW

## MASSENA\_-MARC\_765\_MSU1

Wed 11/15/2023 to Mon 11/27/2023  
0700 Continuous 1730  
Work scheduled by: NYPA

FWD  
(Import)  
SCH - HQ\_CEDARS **90 MW**  
Impacts Total Transfer Capability 189 MW  
TTC with All Lines In Service 279 MW

## MASSENA\_-MARC\_765\_MSU1 & CHATGUAY-MASSENA\_765\_7040

Wed 11/15/2023 to Mon 11/27/2023  
0700 1730  
Work scheduled by:

FWD  
(Import)  
MOSES SOUTH **500 MW**  
Impacts Total Transfer Capability 2650 MW  
TTC with All Lines In Service 3150 MW

## NIAGARA\_345\_230\_AT4

Mon 11/27/2023 to Fri 12/01/2023  
0500 Continuous 1900  
Work scheduled by: NYPA

REV  
(Export)  
SCH - OH - NY **1750 MW**  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 2000 MW

## HOMRC\_NY-MAINS\_NY\_345\_47

Fri 12/08/2023 to Fri 12/15/2023 UPDATED by PJM 01/11/2022  
0800 Continuous 1600  
Work scheduled by: PJM

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

## HOMR\_NYW-PIERC\_NY\_345\_48

Fri 12/08/2023 to Fri 12/15/2023 UPDATED by PJM 01/11/2022  
0800 Continuous 1600  
Work scheduled by: PJM

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

**NYISO TRANSFER LIMITATIONS**

Monday ,October 10, 2022 to Wednesday, April 10, 2024

CENTRAL EAST	2650MW
CENTRAL EAST - VC	2585MW
TOTAL EAST	6000MW
UPNY CONED	7815MW
SPR/DUN-SOUTH	4600MW
DYSINGER EAST	3200MW
MOSES SOUTH	3150MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

**W49TH\_ST-E13THSTA\_345\_M55**

FWD

Mon 01/08/2024 to Mon 02/19/2024

(Import)

0001 Continuous 0201

SPR/DUN-SOUTH

**3800 MW**

Impacts Total Transfer Capability 800 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

**W49TH\_ST\_345KV\_6**

FWD

Mon 01/08/2024 to Mon 02/19/2024

(Import)

0001 Continuous 0201

SCH - PJM\_HTP

**310 MW**

Impacts Total Transfer Capability 350 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd

**W49TH\_ST\_345KV\_8**

FWD

Sat 02/03/2024 to Mon 02/19/2024

(Import)

0001 Continuous 0201

SCH - PJM\_HTP

**310 MW**

Impacts Total Transfer Capability 350 MW

TTC with All Lines In Service 660 MW

Work scheduled by: ConEd