

NYISO TRANSFER LIMITATIONS

Page 1 of 49
Number Of Records: 175
Report Run Date: 10/20/2022 18:04 (EPT)

Seasonal Limits

Thursday, October 20, 2022 to Friday, April 19, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
HUDSONP_-FARRAGUT_345_B3402				2050 MW	
Mon 01/15/2018	to	Tue 01/31/2023			
0001	Continuous	2359	<u>EXT FORCED by ConEd 08/06/2022 16:26</u>		
Work scheduled by: ConEd				Impacts Total Transfer Capability	200 MW
				TTC with All Lines In Service	2250 MW
MARION__-FARRAGUT_345_C3403				2050 MW	
Mon 01/15/2018	to	Tue 01/31/2023			
0001	Continuous	2359	<u>EXT FORCED by ConEd 08/06/2022 16:26</u>		
Work scheduled by: ConEd				Impacts Total Transfer Capability	200 MW
				TTC with All Lines In Service	2250 MW
MARION__-FARRAGUT_345_C3403 , HUDSONP_-FARRAGUT_345_B3402				2000 MW	1150 MW
Mon 01/15/2018	to	Tue 01/31/2023			
0001		2359			
Work scheduled by:				Impacts Total Transfer Capability	250 MW
				TTC with All Lines In Service	1200 MW

NYISO TRANSFER LIMITATIONS

Page 2 of 49
Number Of Records: 175
Report Run Date: 10/20/2022 18:04 (EPT)

Seasonal Limits

Thursday, October 20, 2022 to Friday, April 19, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
SCH-IMO-NYISO_LIMIT_1400				1700 MW	
Wed 08/10/2022	to	Mon 11/21/2022	<u>EXTENDED by IESO 08/19/2022 14:10</u>		
0800	Continuous	1600			
Work scheduled by: IESO					
				Impacts Total Transfer Capability	200 MW
				TTC with All Lines In Service	1900 MW
BECK____-NIAGARA_230_PA27				1700 MW	
Wed 08/24/2022	to	Fri 10/28/2022	<u>EXTENDED by IESO 09/26/2022 15:45</u>		
0800	Continuous	1700			
Work scheduled by: IESO					
				Impacts Total Transfer Capability	200 MW
				TTC with All Lines In Service	1900 MW
SCH-HQ_CEDARS-NYISO_LIMIT_240				240 MW	
Tue 09/06/2022	to	Fri 10/28/2022	<u>EXTENDED by HQ 09/27/2022 13:12</u>		
0500	Continuous	1900			
Work scheduled by: HQ					
				Impacts Total Transfer Capability	30 MW
				TTC with All Lines In Service	270 MW
SCH-NYISO-HQ_CEDARS_LIMIT_0				0 MW	
Tue 09/06/2022	to	Fri 10/28/2022	<u>EXTENDED by HQ 09/27/2022 13:12</u>		
0500	Continuous	1900			
Work scheduled by: HQ					
				Impacts Total Transfer Capability	100 MW
				TTC with All Lines In Service	100 MW

NYISO TRANSFER LIMITATIONS

Page 3 of 49
Number Of Records: 175
Report Run Date: 10/20/2022 18:04 (EPT)

Seasonal Limits

Thursday, October 20, 2022 to Friday, April 19, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
MOSES___-ADIRNDCK_230_MA2				2100 MW	
Tue 09/06/2022	to	Thu 12/01/2022			
1200	Continuous	0659	UPDATED by NYPA 09/06/2022 15:41		
Work scheduled by: NYPA					
				MOSES SOUTH	
				Impacts Total Transfer	1050 MW
				Capability	
				TTC with All Lines In Service	3150 MW
HURLYAVE-ROSETON_345_303				4100 MW	
Mon 09/19/2022	to	Fri 12/02/2022			
0800	Continuous	1600	UPDATED by CHGE 10/04/2022 09:16		
Work scheduled by: CHGE					
				UPNY CONED	
				Impacts Total Transfer	3715 MW
				Capability	
				TTC with All Lines In Service	7815 MW
LEEDS___-HURLYAVE_345_301				4100 MW	
Mon 09/19/2022	to	Fri 12/02/2022			
0800	Continuous	1600	10/04/2021 10:51		
Work scheduled by: CHGE					
				UPNY CONED	
				Impacts Total Transfer	3715 MW
				Capability	
				TTC with All Lines In Service	7815 MW
EGRDNCTY_345_138_AT1				1250 MW	
Sat 10/01/2022	to	Wed 05/31/2023			
0001	Continuous	2359	UPDATED by ConEd 10/01/2022 09:02		
Work scheduled by: LI					
				CONED - LIPA	
				Impacts Total Transfer	250 MW
				Capability	
				TTC with All Lines In Service	1500 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, October 20, 2022 to Friday, April 19, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

					FWD	REV
					(Import)	(Export)
EGRDNCTY_345_138_AT2						
Sat 10/01/2022	to	Wed 05/31/2023	<u>UPDATED by ConEd 10/01/2022 09:02</u>	CONED - LIPA	1250 MW	
0001	Continuous	2359		Impacts Total Transfer Capability	250 MW	
Work scheduled by: LI				TTC with All Lines In Service	1500 MW	
<hr/>						
SPRNBK_-EGRDNCTR_345_Y49					FWD	REV
					(Import)	(Export)
Sat 10/01/2022	to	Wed 05/31/2023	<u>UPDATED by ConEd 10/01/2022 09:02</u>	CONED - LIPA	775 MW	
0001	Continuous	2359		Impacts Total Transfer Capability	725 MW	
Work scheduled by: LI				TTC with All Lines In Service	1500 MW	
<hr/>						
SHOR_NPX-SHOREHAM_138_CSC					FWD	REV
					(Import)	(Export)
Mon 10/03/2022	to	Fri 10/21/2022	<u>UPDATED by LI 10/19/2022 18:59</u>	SCH - NPX_CSC	0 MW	0 MW
0700	Continuous	1600		Impacts Total Transfer Capability	330 MW	330 MW
Work scheduled by: LI				TTC with All Lines In Service	330 MW	330 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, October 20, 2022 to Friday, April 19, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD (Import)	REV (Export)
<hr/>					
STLAWRNC-MOSES___230_L34P					
Mon 10/03/2022	to	Mon 09/25/2023	<u>UPDATED by IESO 10/04/2022 16:51</u>	SCH - OH - NY	
1800	Continuous	0800		Impacts Total Transfer	
Work scheduled by: IESO				Capability	
				TTC with All Lines In Service	
<hr/>					
DUNWODIE-MOTTHAVN_345_71				FWD (Import)	REV (Export)
Thu 10/06/2022	to	Thu 11/10/2022	<u>UPDATED by ConEd 08/16/2022 09:29</u>	SPR/DUN-SOUTH	
0001	Continuous	0300		Impacts Total Transfer	3800 MW
Work scheduled by: ConEd				Capability	800 MW
				TTC with All Lines In Service	4600 MW
<hr/>					
CHAT_DC_GC1				FWD (Import)	REV (Export)
Sun 10/09/2022	to	Sun 11/06/2022		MOSES SOUTH	
0400	Continuous	2200		Impacts Total Transfer	2850 MW
Work scheduled by: HQ				Capability	300 MW
				TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, October 20, 2022 to Friday, April 19, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
CHAT_DC_GC1					
Sun 10/09/2022	to	Sun 11/06/2022		SCH - HQ - NY	500 MW
0400	Continuous	2200		Impacts Total Transfer Capability	500 MW
Work scheduled by: HQ				TTC with All Lines In Service	1000 MW
SCH-NYISO-HQ_LIMIT_500					
Sun 10/09/2022	to	Sun 11/06/2022		SCH - HQ - NY	500 MW
0400	Continuous	2200		Impacts Total Transfer Capability	500 MW
Work scheduled by: HQ				TTC with All Lines In Service	1000 MW
EDIC____-GORDONRD_345_14					
Mon 10/10/2022	to	Mon 10/31/2022		CENTRAL EAST - VC	1670 MW
0700	Continuous	1530		Impacts Total Transfer Capability	915 MW
Work scheduled by: NYPA				TTC with All Lines In Service	2585 MW

UPDATED by NYPA 06/30/2022 15:45

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, October 20, 2022 to Friday, April 19, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
CHAT_DC_GC2					
Mon 10/17/2022	to	Mon 10/24/2022			
0100	Continuous	1800	MOSES SOUTH	2850 MW	
Work scheduled by: HQ			Impacts Total Transfer Capability	300 MW	
			TTC with All Lines In Service	3150 MW	
				FWD	REV
				(Import)	(Export)
CHAT_DC_GC2					
Mon 10/17/2022	to	Mon 10/24/2022			
0100	Continuous	1800	SCH - HQ - NY		500 MW
Work scheduled by: HQ			Impacts Total Transfer Capability		500 MW
			TTC with All Lines In Service		1000 MW
				FWD	REV
				(Import)	(Export)
CHAT_DC_GC2 , CHAT_DC_GC1					
Mon 10/17/2022	to	Mon 10/24/2022			
0100		1800	MOSES SOUTH	2550 MW	
Work scheduled by:			Impacts Total Transfer Capability	600 MW	
			TTC with All Lines In Service	3150 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, October 20, 2022 to Friday, April 19, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
CHAT_DC_GC2 , CHAT_DC_GC1					
Mon 10/17/2022	to	Mon 10/24/2022		SCH - HQ - NY	
0100		1800		1370 MW	0 MW
Work scheduled by:				Impacts Total Transfer Capability	1000 MW
				TTC with All Lines In Service	1000 MW
CHATGUAY-MASSENA__765_7040				FWD	REV
				(Import)	(Export)
Mon 10/17/2022	to	Mon 10/24/2022		SCH - HQ - NY	
0100	Continuous	1800		0 MW	0 MW
Work scheduled by: HQ				Impacts Total Transfer Capability	1000 MW
				TTC with All Lines In Service	1000 MW
CHATGUAY-MASSENA__765_7040				FWD	REV
				(Import)	(Export)
Mon 10/17/2022	to	Mon 10/24/2022		MOSES SOUTH	
0100	Continuous	1800		1550 MW	
Work scheduled by: HQ				Impacts Total Transfer Capability	1600 MW
				TTC with All Lines In Service	3150 MW
NIAGARA_-DYSINGER_345_ND1				FWD	REV
				(Import)	(Export)
Mon 10/17/2022	to	Fri 10/21/2022		DYSINGER EAST	
0500	Continuous	1700		2700 MW	
Work scheduled by: NYPA				Impacts Total Transfer Capability	500 MW
				TTC with All Lines In Service	3200 MW

UPDATED by NYPA 09/30/2022 09:24

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, October 20, 2022 to Friday, April 19, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
W49TH_ST-E13THSTA_345_M55					
Tue 10/18/2022	to	Thu 10/20/2022			
0003	Continuous	2359	<u>EXT FORCED by ConEd 10/19/2022 17:42</u>	3800 MW	
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
BUCHAN_N-EASTVIEW_345_W93					
Wed 10/19/2022	to	Tue 11/01/2022			
0001	Continuous	0200	<u>UPDATED by ConEd 09/07/2022 11:39</u>	4350 MW	
Work scheduled by: ConEd				Impacts Total Transfer Capability	3465 MW
				TTC with All Lines In Service	7815 MW
RAMAPO__-BUCHAN_N_345_Y94					
Thu 10/20/2022	to	Tue 11/01/2022			
0001	Continuous	0200	<u>UPDATED by ConEd 09/07/2022 11:39</u>	7580 MW	
Work scheduled by: ConEd				Impacts Total Transfer Capability	235 MW
				TTC with All Lines In Service	7815 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, October 20, 2022 to Friday, April 19, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ALCOA_PA_115KV_R8105

Mon 10/24/2022 to Wed 10/26/2022

0700 Daily(No Weekends) 1700

Work scheduled by: NGrid

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD
(Import)

3100 MW

50 MW

3150 MW

REV
(Export)

PANNELL_-CLAY____345_1

Mon 10/24/2022 to Fri 10/28/2022

0700 Continuous 1530

Work scheduled by: NYPA

UPDATED by NYPA 09/01/2022 11:59

WEST CENTRAL

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD
(Import)

1300 MW

950 MW

2250 MW

REV
(Export)

ELBRIDGE-LAFAYTTE_345_17-LE

Tue 10/25/2022 to Tue 10/25/2022

0630 Continuous 1700

Work scheduled by: NGrid

ARR: 75

OSWEGO EXPORT

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD
(Import)

5250 MW

0 MW

5250 MW

REV
(Export)

NYISO TRANSFER LIMITATIONS

Page 11 of 49

Number Of Records: 175

Report Run Date: 10/20/2022 18:04 (EPT)

Seasonal Limits

Thursday, October 20, 2022 to Friday, April 19, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD (Import)	REV (Export)
OSWEGO__-ELBRIDGE_345_17				OSWEGO EXPORT	5250 MW
Tue 10/25/2022	to	Tue 10/25/2022		Impacts Total Transfer Capability	0 MW
0630	Continuous	1700		TTC with All Lines In Service	5250 MW
Work scheduled by: NGrid					
ARR: 75					
MAINESBG-WATRCURE_345_30				SCH - PJ - NY	
Tue 10/25/2022	to	Tue 10/25/2022		Impacts Total Transfer Capability	
0800	Daily	1500		TTC with All Lines In Service	
Work scheduled by: NYSEG					
LEEDS__345KV_R395				UPNY CONED	3800 MW
Wed 10/26/2022	to	Wed 10/26/2022		Impacts Total Transfer Capability	4015 MW
0900	Daily(No Weekends)	1030		TTC with All Lines In Service	7815 MW
Work scheduled by: NGrid					

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, October 20, 2022 to Friday, April 19, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD (Import)	REV (Export)
WATRCURE-OAKDALE__345_31					
Thu 10/27/2022	to	Thu 10/27/2022			
0800	Daily	1500			
Work scheduled by: NYSEG			SCH - PJ - NY		
			Impacts Total Transfer Capability		
			TTC with All Lines In Service		
EASTVIEW-SPRNBK__345_W79					
Sun 10/30/2022	to	Sun 10/30/2022		FWD (Import)	REV (Export)
0130	Continuous	0200			
Work scheduled by: ConEd			UPNY CONED	4350 MW	
			Impacts Total Transfer Capability	3465 MW	
			TTC with All Lines In Service	7815 MW	
PANNELL_-CLAY____345_2					
Mon 10/31/2022	to	Fri 11/04/2022		FWD (Import)	REV (Export)
0700	Continuous	1530			
Work scheduled by: NYPA			WEST CENTRAL	1300 MW	
			Impacts Total Transfer Capability	950 MW	
			TTC with All Lines In Service	2250 MW	
BUCHAN_S-MILLWOOD_345_W97					
Tue 11/01/2022	to	Wed 11/02/2022		FWD (Import)	REV (Export)
0001	Continuous	0200			
Work scheduled by: ConEd			UPNY CONED	7680 MW	
			Impacts Total Transfer Capability	135 MW	
			TTC with All Lines In Service	7815 MW	

NYISO TRANSFER LIMITATIONS

Page 13 of 49
Number Of Records: 175
Report Run Date: 10/20/2022 18:04 (EPT)

Seasonal Limits

Thursday, October 20, 2022 to Friday, April 19, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
CLAY___-EDIC___345_1-16					
Tue 11/01/2022	to	Thu 11/03/2022			
0600	Continuous	1900	UPDATED by NGrid 07/05/2022 10:37	OSWEGO EXPORT	4850 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	400 MW
				TTC with All Lines In Service	5250 MW
GILBOA___N.SCTLND_345_GNS-1					
Tue 11/01/2022	to	Tue 12/06/2022			
0700	Continuous	1900	UPDATED by NGrid 08/19/2022 14:50	CENTRAL EAST - VC	2300 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	285 MW
				TTC with All Lines In Service	2585 MW
MARCY___-N.SCTLND_345_18					
Tue 11/01/2022	to	Tue 12/06/2022			
0700	Continuous	1900	UPDATED by NGrid 08/19/2022 14:50	CENTRAL EAST - VC	1345 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	1240 MW
				TTC with All Lines In Service	2585 MW
LINDN_CG-LNDVFT___345_V-3022					
Tue 11/01/2022	to	Fri 11/04/2022			
0800	Continuous	1500	ARR: 19	SCH - PJM_VFT	0 MW
Work scheduled by: PJM				Impacts Total Transfer Capability	315 MW
				TTC with All Lines In Service	315 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, October 20, 2022 to Friday, April 19, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
NEPTUNE_-DUFFYAVE_345_NEPTUNE					
Wed 11/02/2022	to	Tue 11/08/2022		SCH - PJM_NEPTUNE	0 MW
0600	Continuous	1600		Impacts Total Transfer Capability	660 MW
Work scheduled by: LI				TTC with All Lines In Service	660 MW
NEWBRDGE_345_138_BK_1					
Wed 11/02/2022	to	Tue 11/08/2022		SCH - PJM_NEPTUNE	375 MW
0600	Continuous	1600		Impacts Total Transfer Capability	285 MW
Work scheduled by: LI				TTC with All Lines In Service	660 MW
NEWBRDGE_345_138_BK_2					
Wed 11/02/2022	to	Tue 11/08/2022		SCH - PJM_NEPTUNE	375 MW
0600	Continuous	1600		Impacts Total Transfer Capability	285 MW
Work scheduled by: LI				TTC with All Lines In Service	660 MW
NEWBRDGE-DUFFYAVE_345_501					
Wed 11/02/2022	to	Tue 11/08/2022		SCH - PJM_NEPTUNE	0 MW
0600	Continuous	1600		Impacts Total Transfer Capability	660 MW
Work scheduled by: LI				TTC with All Lines In Service	660 MW

NYISO TRANSFER LIMITATIONS

Page 15 of 49

Number Of Records: 175

Report Run Date: 10/20/2022 18:04 (EPT)

Seasonal Limits

Thursday, October 20, 2022 to Friday, April 19, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
CEDARS__-ROSEMNTB_115_2/22					
Mon 11/07/2022	to	Fri 11/11/2022		SCH - HQ_CEDARS	95 MW
0700	Continuous	1700		Impacts Total Transfer Capability	184 MW
Work scheduled by: NGrid				TTC with All Lines In Service	279 MW
					100 MW
DENNISON-ROSEMNTB_115_2/22					
Mon 11/07/2022	to	Fri 11/11/2022		SCH - HQ_CEDARS	95 MW
0700	Continuous	1700		Impacts Total Transfer Capability	184 MW
Work scheduled by: NGrid				TTC with All Lines In Service	279 MW
					100 MW
DUNWODIE_345KV_3					
Thu 11/10/2022	to	Thu 11/10/2022		SPR/DUN-SOUTH	3800 MW
0230	Continuous	0300	UPDATED by ConEd 08/16/2022 09:29	Impacts Total Transfer Capability	800 MW
Work scheduled by: ConEd				TTC with All Lines In Service	4600 MW
DUNWODIE_345KV_5					
Thu 11/10/2022	to	Thu 11/10/2022		SPR/DUN-SOUTH	3800 MW
0230	Continuous	0300	UPDATED by ConEd 08/16/2022 09:29	Impacts Total Transfer Capability	800 MW
Work scheduled by: ConEd				TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Page 16 of 49
Number Of Records: 175
Report Run Date: 10/20/2022 18:04 (EPT)

Seasonal Limits

Thursday, October 20, 2022 to Friday, April 19, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
MAINESBG-WATRCURE_345_30					
Thu 11/10/2022	to	Thu 11/10/2022	SCH - PJ - NY	2300 MW	
0800	Continuous	1600	Impacts Total Transfer Capability	550 MW	
Work scheduled by: PJM			TTC with All Lines In Service	2850 MW	
				FWD	REV
				(Import)	(Export)
DUNWODIE_345KV_7					
Wed 11/16/2022	to	Wed 11/16/2022	SPR/DUN-SOUTH	3800 MW	
0100	Continuous	0200	Impacts Total Transfer Capability	800 MW	
Work scheduled by: ConEd			TTC with All Lines In Service	4600 MW	
				FWD	REV
				(Import)	(Export)
DUNWODIE_345KV_3					
Thu 11/17/2022	to	Thu 11/17/2022	SPR/DUN-SOUTH	3800 MW	
0001	Continuous	0030	Impacts Total Transfer Capability	800 MW	
Work scheduled by: ConEd			TTC with All Lines In Service	4600 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, October 20, 2022 to Friday, April 19, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
DUNWODIE_345KV_4					
Thu 11/17/2022	to	Thu 11/17/2022			
0001	Continuous	0030	SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	4600 MW	
PLSNTVLE-DUNWODIE_345_W89					
Thu 11/17/2022	to	Thu 11/17/2022			
0001	Continuous	0030	UPNY CONED	4000 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	3815 MW	
			TTC with All Lines In Service	7815 MW	
DUNWODIE_345KV_3					
Thu 11/17/2022	to	Thu 11/17/2022			
1730	Continuous	1800	SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	4600 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, October 20, 2022 to Friday, April 19, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
DUNWODIE_345KV_4					
Thu 11/17/2022	to	Thu 11/17/2022			
1730	Continuous	1800	SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	4600 MW	
PLSNTVLE-DUNWODIE_345_W89				FWD	REV
				(Import)	(Export)
Thu 11/17/2022	to	Thu 11/17/2022			
1730	Continuous	1800	UPNY CONED	4000 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	3815 MW	
			TTC with All Lines In Service	7815 MW	
BUCHAN_N-EASTVIEW_345_W93				FWD	REV
				(Import)	(Export)
Mon 11/21/2022	to	Mon 11/28/2022			
0001	Continuous	0200	UPDATED by ConEd 09/07/2022 11:39	UPNY CONED	4350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	3465 MW
				TTC with All Lines In Service	7815 MW
EASTVIEW-SPRNBRK_345_W79				FWD	REV
				(Import)	(Export)
Mon 11/21/2022	to	Mon 11/21/2022			
0001	Continuous	0030	UPDATED by ConEd 09/07/2022 11:39	UPNY CONED	4350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	3465 MW
				TTC with All Lines In Service	7815 MW

NYISO TRANSFER LIMITATIONS

Page 19 of 49

Number Of Records: 175

Report Run Date: 10/20/2022 18:04 (EPT)

Seasonal Limits

Thursday, October 20, 2022 to Friday, April 19, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
RAMAPO__-BUCHAN_N_345_Y94					
Mon 11/21/2022	to	Mon 11/28/2022			
0001	Continuous	0200	UPDATED by ConEd 09/07/2022 11:39	UPNY CONED	7580 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	235 MW
				TTC with All Lines In Service	7815 MW
E13THSTA-FARRAGUT_345_45					
Wed 11/23/2022	to	Sat 12/10/2022			
0001	Continuous	0300	UPDATED by ConEd 10/05/2022 10:15	SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
HOMRC_NY-MAINS_NY_345_47					
Wed 11/23/2022	to	Wed 11/23/2022			
0800	Continuous	1600	UPDATED by PJM 08/09/2022 11:26	SCH - PJ - NY	
Work scheduled by: PJM				Impacts Total Transfer Capability	
				TTC with All Lines In Service	
EASTVIEW-SPRNBK__345_W79					
Mon 11/28/2022	to	Mon 11/28/2022			
0130	Continuous	0200	UPDATED by ConEd 09/07/2022 11:39	UPNY CONED	4350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	3465 MW
				TTC with All Lines In Service	7815 MW

NYISO TRANSFER LIMITATIONS

Page 20 of 49

Number Of Records: 175

Report Run Date: 10/20/2022 18:04 (EPT)

Seasonal Limits

Thursday, October 20, 2022 to Friday, April 19, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
BUCHAN_S-MILLWOOD_345_W98					
Tue 11/29/2022	to	Thu 12/01/2022			
0001	Continuous	0200	UPNY CONED	7680 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	135 MW	
			TTC with All Lines In Service	7815 MW	
MILLWOOD_345KV_18					
Tue 11/29/2022	to	Thu 12/01/2022			
0001	Continuous	0200	UPNY CONED	4350 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	3465 MW	
			TTC with All Lines In Service	7815 MW	
CRICKVLY-PLSNTVLY_345_F84					
Thu 12/01/2022	to	Fri 12/16/2022			
0001	Continuous	0200	SCH - NE - NY	600 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	1400 MW	
CRICKVLY-PLSNTVLY_345_F84					
Thu 12/01/2022	to	Fri 12/16/2022			
0001	Continuous	0200	SCH - NPX_1385	100 MW	100 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	100 MW	100 MW
			TTC with All Lines In Service	200 MW	200 MW

NYISO TRANSFER LIMITATIONS

Page 21 of 49

Number Of Records: 175

Report Run Date: 10/20/2022 18:04 (EPT)

Seasonal Limits

Thursday, October 20, 2022 to Friday, April 19, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
MOSES___-ADIRNDCK_230_MA1					
Thu 12/01/2022	to	Wed 03/01/2023			
0701	Continuous	1100	UPDATED by NYPA 09/02/2022 14:08	MOSES SOUTH	2300 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	850 MW
				TTC with All Lines In Service	3150 MW
				FWD	REV
				(Import)	(Export)
MILLWOOD_345KV_18					
Fri 12/02/2022	to	Mon 12/12/2022			
0001	Continuous	1800		UPNY CONED	4350 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	3465 MW
				TTC with All Lines In Service	7815 MW
				FWD	REV
				(Import)	(Export)
W49TH_ST-E13THSTA_345_M54					
Fri 12/02/2022	to	Fri 12/02/2022			
0001	Continuous	0030		SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
				FWD	REV
				(Import)	(Export)
W49TH_ST-E13THSTA_345_M54					
Sat 12/03/2022	to	Sat 12/03/2022			
0130	Continuous	0200		SPR/DUN-SOUTH	3800 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Page 22 of 49

Number Of Records: 175

Report Run Date: 10/20/2022 18:04 (EPT)

Seasonal Limits

Thursday, October 20, 2022 to Friday, April 19, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
FRASER__-COOPERS__345_33					
Wed 12/07/2022	to	Wed 12/07/2022		CENTRAL EAST - VC	2335 MW
0700	Continuous	1700		Impacts Total Transfer Capability	250 MW
Work scheduled by: NYSEG				TTC with All Lines In Service	2585 MW
MARCY__345KV_CSC					
Wed 12/07/2022	to	Tue 12/20/2022		CENTRAL EAST - VC	2535 MW
0700	Continuous	1530		Impacts Total Transfer Capability	50 MW
Work scheduled by: NYPA				TTC with All Lines In Service	2585 MW
LAFAYTTE-CLRKSCRN_345_4-46					
Thu 12/08/2022	to	Sun 12/11/2022		CENTRAL EAST - VC	2450 MW
0800	Continuous	1600		Impacts Total Transfer Capability	135 MW
Work scheduled by: NGrid				TTC with All Lines In Service	2585 MW
PIERCBRK-FIVEMILE_345_37					
Thu 12/08/2022	to	Thu 12/08/2022		SCH - PJ - NY	2700 MW
0800	Continuous	1600		Impacts Total Transfer Capability	150 MW
Work scheduled by: PJM				TTC with All Lines In Service	2850 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, October 20, 2022 to Friday, April 19, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
SPRNBK_-TREMONT__345_X28					
Fri 12/09/2022	to	Fri 12/09/2022			
0001	Continuous	0030	SPR/DUN-SOUTH	4200 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	400 MW	
			TTC with All Lines In Service	4600 MW	
SPRNBK_-TREMONT__345_X28					
Fri 12/09/2022	to	Fri 12/09/2022			
1730	Continuous	1800	SPR/DUN-SOUTH	4200 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	400 MW	
			TTC with All Lines In Service	4600 MW	
HOPATCON-RAMAPO__500_5018					
Mon 12/12/2022	to	Fri 12/16/2022			
0001	Continuous	2000	TOTAL EAST	5200 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	6000 MW	
HOPATCON-RAMAPO__500_5018					
Mon 12/12/2022	to	Fri 12/16/2022			
0001	Continuous	2000	SCH - PJ - NY	1650 MW	1200 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	1200 MW	1000 MW
			TTC with All Lines In Service	2850 MW	2200 MW

NYISO TRANSFER LIMITATIONS

Page 24 of 49

Number Of Records: 175

Report Run Date: 10/20/2022 18:04 (EPT)

Seasonal Limits

Thursday, October 20, 2022 to Friday, April 19, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
HOPATCON-RAMAPO__500_5018					
Mon 12/12/2022	to	Fri 12/16/2022			
0001	Continuous	2000	UPNY CONED	7480 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	335 MW	
			TTC with All Lines In Service	7815 MW	
MARCY__345KV_CSC , HOPATCON-RAMAPO__500_5018					
Mon 12/12/2022	to	Fri 12/16/2022			
0001		2000	TOTAL EAST	5100 MW	
Work scheduled by:			Impacts Total Transfer Capability	900 MW	
			TTC with All Lines In Service	6000 MW	
RAMAPO__345_345_PAR3500					
Mon 12/12/2022	to	Fri 12/16/2022			
0001	Continuous	2000	SCH - PJ - NY	2500 MW	1250 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	350 MW	950 MW
			TTC with All Lines In Service	2850 MW	2200 MW
RAMAPO__345_345_PAR4500					
Mon 12/12/2022	to	Fri 12/16/2022			
0001	Continuous	2000	SCH - PJ - NY	2500 MW	1250 MW
Work scheduled by: ConEd			Impacts Total Transfer Capability	350 MW	950 MW
			TTC with All Lines In Service	2850 MW	2200 MW

NYISO TRANSFER LIMITATIONS

Page 25 of 49
Number Of Records: 175
Report Run Date: 10/20/2022 18:04 (EPT)

Seasonal Limits

Thursday, October 20, 2022 to Friday, April 19, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
RAMAPO__500_345_BK 1500					
Mon 12/12/2022	to	Fri 12/16/2022			
0001	Continuous	2000	SCH - PJ - NY	1650 MW	1200 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	1000 MW
				TTC with All Lines In Service	2200 MW
				FWD	REV
				(Import)	(Export)
RAMAPO__500_345_BK 1500					
Mon 12/12/2022	to	Fri 12/16/2022			
0001	Continuous	2000	UPNY CONED	7480 MW	
Work scheduled by: ConEd				Impacts Total Transfer Capability	335 MW
				TTC with All Lines In Service	7815 MW
				FWD	REV
				(Import)	(Export)
CRICKVLY-PLSNTVLY_345_F83					
Fri 12/16/2022	to	Sun 01/01/2023			
0201	Continuous	0200	<u>EXTENDED by ConEd 09/22/2022 10:12</u>	100 MW	100 MW
Work scheduled by: ConEd				Impacts Total Transfer Capability	100 MW
				TTC with All Lines In Service	200 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, October 20, 2022 to Friday, April 19, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
CRICKVLY-PLSNTVLY_345_F83					
Fri 12/16/2022	to	Sun 01/01/2023			
0201	Continuous	0200	<u>EXTENDED by ConEd 09/22/2022 10:12</u>	600 MW	
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	1400 MW
				FWD	REV
				(Import)	(Export)
FRASER__-COOPERS__345_33					
Mon 12/19/2022	to	Fri 12/23/2022			
0600	Continuous	1659		2335 MW	
Work scheduled by: NYSEG				Impacts Total Transfer Capability	250 MW
				TTC with All Lines In Service	2585 MW
				FWD	REV
				(Import)	(Export)
HOMRC_NY-MAINS_NY_345_47					
Thu 12/22/2022	to	Thu 12/22/2022			
0800	Continuous	1600			
Work scheduled by: PJM				SCH - PJ - NY	
				Impacts Total Transfer Capability	
				TTC with All Lines In Service	

NYISO TRANSFER LIMITATIONS

Page 27 of 49
Number Of Records: 175
Report Run Date: 10/20/2022 18:04 (EPT)

Seasonal Limits

Thursday, October 20, 2022 to Friday, April 19, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
W49TH_ST-E13THSTA_345_M54					
Tue 12/27/2022	to	Tue 12/27/2022			
0130	Continuous	0200	UPDATED by ConEd 10/05/2022 15:32	3800 MW	
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
CLAY___-EDIC___345_1-16					
Fri 12/30/2022	to	Sat 12/31/2022			
0600	Continuous	1900	UPDATED by NGrid 07/05/2022 10:37	4850 MW	
Work scheduled by: NGrid				Impacts Total Transfer Capability	400 MW
				TTC with All Lines In Service	5250 MW
FRASER___345_FRASER SVC					
Tue 01/03/2023	to	Tue 02/28/2023			
0700	Continuous	1730	UPDATED by NYPA 12/30/2021 15:43	2550 MW	
Work scheduled by: NYPA				Impacts Total Transfer Capability	35 MW
				TTC with All Lines In Service	2585 MW
NIAGARA_-PACKARD__230_62					
Mon 01/09/2023	to	Fri 01/20/2023			
0500	Continuous	1900		900 MW	1850 MW
Work scheduled by: NYPA				Impacts Total Transfer Capability	1400 MW
				TTC with All Lines In Service	2300 MW

NYISO TRANSFER LIMITATIONS

Page 28 of 49

Number Of Records: 175

Report Run Date: 10/20/2022 18:04 (EPT)

Seasonal Limits

Thursday, October 20, 2022 to Friday, April 19, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
E13THSTA-FARRAGUT_345_46					
Fri 01/27/2023	to	Wed 02/01/2023			
0001	Continuous	0300	UPDATED by ConEd 10/06/2022 11:35		
Work scheduled by: ConEd					
				SPR/DUN-SOUTH	3800 MW
				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
E13THSTA-FARRAGUT_345_45					
Wed 02/08/2023	to	Wed 02/08/2023			
0001	Continuous	0030			
Work scheduled by: ConEd					
				SPR/DUN-SOUTH	3800 MW
				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
E13THSTA-FARRAGUT_345_45					
Wed 02/22/2023	to	Wed 02/22/2023			
0230	Continuous	0300			
Work scheduled by: ConEd					
				SPR/DUN-SOUTH	3800 MW
				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
EDIC____-FRASER____345_EF24-40					
Wed 03/01/2023	to	Sat 04/15/2023			
0600	Continuous	1800			
Work scheduled by: NGrid					
				CENTRAL EAST - VC	2275 MW
				Impacts Total Transfer Capability	310 MW
				TTC with All Lines In Service	2585 MW

NYISO TRANSFER LIMITATIONS

Page 29 of 49

Number Of Records: 175

Report Run Date: 10/20/2022 18:04 (EPT)

Seasonal Limits

Thursday, October 20, 2022 to Friday, April 19, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
GORDONRD-N.SCTLND_345_55					
Wed 03/01/2023	to	Fri 03/31/2023			
0700	Continuous	1600	CENTRAL EAST - VC	2045 MW	
Work scheduled by: LS			Impacts Total Transfer Capability	540 MW	
			TTC with All Lines In Service	2585 MW	
MOSES__-ADIRNDCK_230_MA1				FWD	REV
				(Import)	(Export)
Wed 03/01/2023	to	Fri 05/26/2023			
1101	Continuous	1930	MOSES SOUTH	2300 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	850 MW	
			TTC with All Lines In Service	3150 MW	
NIAGARA_-ROBNSNRD_230_64				FWD	REV
				(Import)	(Export)
Mon 03/06/2023	to	Fri 03/17/2023			
0500	Continuous	1900	SCH - OH - NY		1900 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability		100 MW
			TTC with All Lines In Service		2000 MW
N.SCTLND-ALPS____345_2				FWD	REV
				(Import)	(Export)
Mon 03/27/2023	to	Fri 05/19/2023			
0700	Continuous	1900	SCH - NE - NY	900 MW	
Work scheduled by: NGrid			Impacts Total Transfer Capability	500 MW	
			TTC with All Lines In Service	1400 MW	

UPDATED by NGrid 07/05/2022 10:45

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, October 20, 2022 to Friday, April 19, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
N.SCTLND-ALPS___345_2					
Mon 03/27/2023	to	Fri 05/19/2023			
0700	Continuous	1900	UPDATED by NGrid 07/05/2022 10:45	100 MW	100 MW
Work scheduled by: NGrid				Impacts Total Transfer Capability	100 MW
				TTC with All Lines In Service	200 MW
MOTTHAVN-RAINEY___345_Q12				FWD	REV
				(Import)	(Export)
Wed 03/29/2023	to	Sun 04/30/2023			
0001	Continuous	0200	UPDATED by ConEd 09/05/2022 07:25	3800 MW	
Work scheduled by: ConEd				Impacts Total Transfer Capability	800 MW
				TTC with All Lines In Service	4600 MW
ATHENS_-PLSNTVLY_345_91				FWD	REV
				(Import)	(Export)
Sat 04/01/2023	to	Sat 04/15/2023			
0700	Continuous	1900		3800 MW	
Work scheduled by: NGrid				Impacts Total Transfer Capability	4015 MW
				TTC with All Lines In Service	7815 MW
PLSNTVLY_345KV_RNS4				FWD	REV
				(Import)	(Export)
Sat 04/01/2023	to	Sat 04/01/2023			
0700	Continuous	0730		3800 MW	
Work scheduled by: NGrid				Impacts Total Transfer Capability	4015 MW
				TTC with All Lines In Service	7815 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, October 20, 2022 to Friday, April 19, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
LINDN_CG-LNDVFT__345_V-3022					
Sun 04/09/2023	to	Sat 04/15/2023			
1400	Continuous	1400	SCH - PJM_VFT	0 MW	0 MW
Work scheduled by: PJM			Impacts Total Transfer Capability	315 MW	315 MW
			TTC with All Lines In Service	315 MW	315 MW
				FWD	REV
				(Import)	(Export)
DYSINGER-STA_255__345_DH1					
Mon 04/10/2023	to	Fri 04/14/2023			
0500	Continuous	2000	DYSINGER EAST	2850 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	350 MW	
			TTC with All Lines In Service	3200 MW	
				FWD	REV
				(Import)	(Export)
GORDONRD-N.SCTLND_345_55					
Mon 04/10/2023	to	Fri 04/14/2023			
0600	Continuous	1700	CENTRAL EAST - VC	2045 MW	
Work scheduled by: NGrid			Impacts Total Transfer Capability	540 MW	
			TTC with All Lines In Service	2585 MW	
				FWD	REV
				(Import)	(Export)
DUNWODIE_345KV_3					
Wed 04/12/2023	to	Wed 04/12/2023			
0201	Continuous	0230	SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	4600 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, October 20, 2022 to Friday, April 19, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
DUNWODIE_345KV_4					
Wed 04/12/2023	to	Wed 04/12/2023	SPR/DUN-SOUTH	3800 MW	
0201	Continuous	0230	Impacts Total Transfer Capability	800 MW	
Work scheduled by: ConEd			TTC with All Lines In Service	4600 MW	
				FWD	REV
				(Import)	(Export)
PLSNTVLE-DUNWODIE_345_W89					
Wed 04/12/2023	to	Wed 04/12/2023	UPNY CONED	4000 MW	
0201	Continuous	0230	Impacts Total Transfer Capability	3815 MW	
Work scheduled by: ConEd			TTC with All Lines In Service	7815 MW	
				FWD	REV
				(Import)	(Export)
PLSNTVLY_345KV_RNS4					
Sat 04/15/2023	to	Sat 04/15/2023	UPNY CONED	3800 MW	
1830	Continuous	1900	Impacts Total Transfer Capability	4015 MW	
Work scheduled by: NGrid			TTC with All Lines In Service	7815 MW	

NYISO TRANSFER LIMITATIONS

Page 33 of 49
Number Of Records: 175
Report Run Date: 10/20/2022 18:04 (EPT)

Seasonal Limits

Thursday, October 20, 2022 to Friday, April 19, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
LEEDS___-PLSNTVLY_345_92					
Sun 04/16/2023	to	Sun 04/30/2023	UPNY CONED	3800 MW	
0700	Continuous	1900	Impacts Total Transfer Capability	4015 MW	
Work scheduled by: NGrid				TTC with All Lines In Service	7815 MW
PLSNTVLY_345KV_RNS5					
Sun 04/16/2023	to	Sun 04/16/2023	UPNY CONED	3800 MW	
0700	Continuous	0730	Impacts Total Transfer Capability	4015 MW	
Work scheduled by: NGrid				TTC with All Lines In Service	7815 MW
E13THSTA-FARRAGUT_345_46					
Mon 04/17/2023	to	Wed 04/19/2023	SPR/DUN-SOUTH	3800 MW	
0001	Continuous	0200	Impacts Total Transfer Capability	800 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	4600 MW
DYSINGER-STA_255__345_DH2					
Mon 04/17/2023	to	Fri 04/21/2023	DYSINGER EAST	2850 MW	
0500	Continuous	2000	Impacts Total Transfer Capability	350 MW	
Work scheduled by: NYPA				TTC with All Lines In Service	3200 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, October 20, 2022 to Friday, April 19, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
CLAY____-EDIC____345_2-15					
Mon 04/17/2023	to	Fri 04/28/2023			
0600	Continuous	1800	OSWEGO EXPORT	4850 MW	
Work scheduled by: NGrid			Impacts Total Transfer Capability	400 MW	
			TTC with All Lines In Service	5250 MW	
DUNWODIE_345KV_3				FWD	REV
				(Import)	(Export)
Thu 04/20/2023	to	Thu 04/20/2023			
0130	Continuous	0200	SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	4600 MW	
DUNWODIE_345KV_4				FWD	REV
				(Import)	(Export)
Thu 04/20/2023	to	Thu 04/20/2023			
0130	Continuous	0200	SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	4600 MW	
PLSNTVLE-DUNWODIE_345_W89				FWD	REV
				(Import)	(Export)
Thu 04/20/2023	to	Thu 04/20/2023			
0130	Continuous	0200	UPNY CONED	4000 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	3815 MW	
			TTC with All Lines In Service	7815 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits			Thursday, October 20, 2022 to Friday, April 19, 2024		FWD	REV
PANNELL - CLAY 345_1					(Import)	(Export)
Mon 04/24/2023	to	Fri 04/28/2023	WEST CENTRAL		1300 MW	
0700	Continuous	1530	Impacts Total Transfer Capability		950 MW	
CENTRAL EAST scheduled by: NYPA			TTC with All Lines In Service		2250 MW	
CENTRAL EAST - VC 2585 MW						REV
TOTAL EAST 6000 MW						(Import)
UPNY CONED			UPNY CONED		3800 MW	
PLSNTVLY_345KV_RNS5			Impacts Total Transfer Capability		4015 MW	
Sun 04/30/2023	to	Sun 04/30/2023	TTC with All Lines In Service		7815 MW	
SPR/DUN-SOUTH						REV
DYSINGER EAST			DYSINGER EAST		3200 MW	
1830	Continuous	1900	Impacts Total Transfer Capability		4015 MW	
MOSES SOUTH 3150 MW			TTC with All Lines In Service		7815 MW	
Work scheduled by: NGrid						
SHOR_NPX-SHOREHAM_138_CSC					(Import)	(Export)
Mon 05/01/2023	to	Fri 05/05/2023	SCH - NPX_CSC		0 MW	0 MW
0600	Continuous	1800	Impacts Total Transfer Capability		330 MW	330 MW
Work scheduled by: LI			TTC with All Lines In Service		330 MW	330 MW
PANNELL - CLAY 345_2					FWD	REV
Mon 05/01/2023	to	Fri 05/05/2023	WEST CENTRAL		1300 MW	
0700	Continuous	1530	Impacts Total Transfer Capability		950 MW	
Work scheduled by: NYPA			TTC with All Lines In Service		2250 MW	
PLSNTVLY_345KV_RNS5					FWD	REV
Wed 05/03/2023	to	Mon 05/15/2023	UPNY CONED		3800 MW	
0001	Continuous	2200	Impacts Total Transfer Capability		4015 MW	
Work scheduled by: ConEd			TTC with All Lines In Service		7815 MW	
PLSNTVLY-WOOD_ST_345_F30					FWD	REV
Wed 05/03/2023	to	Mon 05/15/2023	UPNY CONED		4000 MW	
0001	Continuous	2200	Impacts Total Transfer Capability		3815 MW	
Work scheduled by: ConEd			TTC with All Lines In Service		7815 MW	

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, October 20, 2022 to Friday, April 19, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
NIAGARA_-ROBNSNRD_230_64					
Fri 05/05/2023	to	Fri 05/05/2023	SCH - OH - NY		1400 MW
0500	Continuous	1700	Impacts Total Transfer Capability		150 MW
Work scheduled by: NYPA				TTC with All Lines In Service	1550 MW
				FWD	REV
				(Import)	(Export)
W49TH_ST_345KV_6					
Sat 05/06/2023	to	Sat 05/06/2023	SCH - PJM_HTP	300 MW	
0001	Continuous	0030	Impacts Total Transfer Capability	360 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	660 MW
				FWD	REV
				(Import)	(Export)
W49TH_ST_345KV_8					
Sat 05/06/2023	to	Sat 05/06/2023	SCH - PJM_HTP	450 MW	
0001	Continuous	0030	Impacts Total Transfer Capability	210 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	660 MW
				FWD	REV
				(Import)	(Export)
COOPERS_-DOLSONAV_345_CCDA42					
Mon 05/08/2023	to	Sun 05/21/2023	CENTRAL EAST - VC	2485 MW	
0700	Continuous	1530	Impacts Total Transfer Capability	100 MW	
Work scheduled by: NYPA				TTC with All Lines In Service	2585 MW

NYISO TRANSFER LIMITATIONS

Page 37 of 49
Number Of Records: 175
Report Run Date: 10/20/2022 18:04 (EPT)

Seasonal Limits

Thursday, October 20, 2022 to Friday, April 19, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
DOLSONAV-ROCKTVRN_345_DART44					
Mon 05/08/2023	to	Sat 05/13/2023			
0700	Continuous	1530	CENTRAL EAST - VC	2485 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	100 MW	
			TTC with All Lines In Service	2585 MW	
W49TH_ST_345KV_6				FWD	REV
				(Import)	(Export)
Sat 05/13/2023	to	Sat 05/13/2023			
0130	Continuous	0200	SCH - PJM_HTP	300 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	360 MW	
			TTC with All Lines In Service	660 MW	
W49TH_ST_345KV_8				FWD	REV
				(Import)	(Export)
Sat 05/13/2023	to	Sat 05/13/2023			
0130	Continuous	0200	SCH - PJM_HTP	450 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	210 MW	
			TTC with All Lines In Service	660 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, October 20, 2022 to Friday, April 19, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
W49TH_ST_345KV_6					
Mon 05/15/2023	to	Mon 05/15/2023	SCH - PJM_HTP	300 MW	
0001	Continuous	0030	Impacts Total Transfer Capability	360 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	660 MW
W49TH_ST-E13THSTA_345_M55				FWD	REV
				(Import)	(Export)
Mon 05/15/2023	to	Wed 05/17/2023	SPR/DUN-SOUTH	3800 MW	
0001	Continuous	0200	Impacts Total Transfer Capability	800 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	4600 MW
MOTTHAVN-RAINEY__345_Q11				FWD	REV
				(Import)	(Export)
Wed 05/17/2023	to	Sat 05/20/2023	SPR/DUN-SOUTH	3800 MW	
0001	Continuous	0200	Impacts Total Transfer Capability	800 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	4600 MW

NYISO TRANSFER LIMITATIONS

Page 39 of 49
Number Of Records: 175
Report Run Date: 10/20/2022 18:04 (EPT)

Seasonal Limits

Thursday, October 20, 2022 to Friday, April 19, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
W49TH_ST_345KV_6					
Wed 05/17/2023	to	Wed 05/17/2023	SCH - PJM_HTP	300 MW	
0130	Continuous	0200	Impacts Total Transfer Capability	360 MW	
Work scheduled by: ConEd			TTC with All Lines In Service	660 MW	
				FWD	REV
				(Import)	(Export)
BECK____-NIAGARA__230_PA27					
Tue 05/30/2023	to	Fri 06/02/2023	SCH - OH - NY		
0500	Continuous	2100	Impacts Total Transfer Capability		
Work scheduled by: NYPA			TTC with All Lines In Service		
				FWD	REV
				(Import)	(Export)
NIAGARA__345_230_AT4					
Wed 06/28/2023	to	Thu 06/29/2023	SCH - OH - NY		1150 MW
0500	Continuous	1900	Impacts Total Transfer Capability		400 MW
Work scheduled by: NYPA			TTC with All Lines In Service		1550 MW
				FWD	REV
				(Import)	(Export)
NIAGARA__345_230_AT4					
Mon 08/21/2023	to	Fri 08/25/2023	SCH - OH - NY		1150 MW
0500	Continuous	2100	Impacts Total Transfer Capability		400 MW
Work scheduled by: NYPA			TTC with All Lines In Service		1550 MW

NYISO TRANSFER LIMITATIONS

Page 40 of 49
Number Of Records: 175
Report Run Date: 10/20/2022 18:04 (EPT)

Seasonal Limits

Thursday, October 20, 2022 to Friday, April 19, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
ADIRNDCK-PORTER__230_12					
Tue 08/22/2023	to	Tue 08/22/2023			
0700	Continuous	1530	MOSES SOUTH	2100 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	1050 MW	
			TTC with All Lines In Service	3150 MW	
ADIRNDCK-CHASLAKE_230_13					
Wed 08/23/2023	to	Wed 08/23/2023			
0700	Continuous	1530	MOSES SOUTH	2100 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	1050 MW	
			TTC with All Lines In Service	3150 MW	
CLAY__-EDIC__345_1-16					
Mon 09/11/2023	to	Fri 09/15/2023			
0700	Continuous	1530	OSWEGO EXPORT	4850 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	400 MW	
			TTC with All Lines In Service	5250 MW	
FRASER__-GILBOA__345_GF5-35					
Mon 09/11/2023	to	Sun 09/17/2023			
0700	Continuous	1530	CENTRAL EAST - VC	2450 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	135 MW	
			TTC with All Lines In Service	2585 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, October 20, 2022 to Friday, April 19, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

					FWD	REV
					(Import)	(Export)
SPRNBK__345KV_RNS5						
Fri 09/15/2023	to	Mon 10/23/2023	<u>UPDATED by ConEd 08/10/2022 13:51</u>		SPR/DUN-SOUTH	3200 MW
0001	Continuous	0200			Impacts Total Transfer Capability	1400 MW
Work scheduled by: ConEd					TTC with All Lines In Service	4600 MW
<hr/>						
SPRNBK_-W49TH_ST_345_M51					FWD	REV
					(Import)	(Export)
Fri 09/15/2023	to	Mon 10/23/2023	<u>UPDATED by ConEd 08/10/2022 13:51</u>		SPR/DUN-SOUTH	3200 MW
0001	Continuous	0200			Impacts Total Transfer Capability	1400 MW
Work scheduled by: ConEd					TTC with All Lines In Service	4600 MW
<hr/>						
CLAY____-EDIC____345_2-15					FWD	REV
					(Import)	(Export)
Mon 09/18/2023	to	Fri 09/22/2023			OSWEGO EXPORT	4850 MW
0700	Continuous	1530			Impacts Total Transfer Capability	400 MW
Work scheduled by: NYPA					TTC with All Lines In Service	5250 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, October 20, 2022 to Friday, April 19, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
NIAGARA_-DYSINGER_345_ND2					
Mon 09/25/2023	to	Fri 09/29/2023	DYSINGER EAST	2700 MW	
0500	Continuous	2000	Impacts Total Transfer Capability	500 MW	
Work scheduled by: NYPA			TTC with All Lines In Service	3200 MW	
				FWD	REV
				(Import)	(Export)
MARCY____345KV_CSC					
Mon 09/25/2023	to	Sat 10/07/2023	CENTRAL EAST - VC	2535 MW	
0700	Continuous	1530	Impacts Total Transfer Capability	50 MW	
Work scheduled by: NYPA			TTC with All Lines In Service	2585 MW	
				FWD	REV
				(Import)	(Export)
SHOR_NPX-SHOREHAM_138_CSC					
Mon 10/02/2023	to	Fri 10/06/2023	SCH - NPX_CSC	0 MW	0 MW
0600	Continuous	1800	Impacts Total Transfer Capability	330 MW	330 MW
Work scheduled by: LI			TTC with All Lines In Service	330 MW	330 MW

NYISO TRANSFER LIMITATIONS

Page 43 of 49

Number Of Records: 175

Report Run Date: 10/20/2022 18:04 (EPT)

Seasonal Limits

Thursday, October 20, 2022 to Friday, April 19, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
NEPTUNE_-DUFFYAVE_345_NEPTUNE					
Mon 10/09/2023	to	Fri 10/13/2023	SCH - PJM_NEPTUNE	0 MW	
0600	Continuous	1600	Impacts Total Transfer Capability	660 MW	
Work scheduled by: LI			TTC with All Lines In Service	660 MW	
NEWBRDGE_345_138_BK_1				FWD	REV
				(Import)	(Export)
Mon 10/09/2023	to	Fri 10/13/2023	SCH - PJM_NEPTUNE	375 MW	
0600	Continuous	1600	Impacts Total Transfer Capability	285 MW	
Work scheduled by: LI			TTC with All Lines In Service	660 MW	
NEWBRDGE_345_138_BK_2				FWD	REV
				(Import)	(Export)
Mon 10/09/2023	to	Fri 10/13/2023	SCH - PJM_NEPTUNE	375 MW	
0600	Continuous	1600	Impacts Total Transfer Capability	285 MW	
Work scheduled by: LI			TTC with All Lines In Service	660 MW	
NEWBRDGE-DUFFYAVE_345_501				FWD	REV
				(Import)	(Export)
Mon 10/09/2023	to	Fri 10/13/2023	SCH - PJM_NEPTUNE	0 MW	
0600	Continuous	1600	Impacts Total Transfer Capability	660 MW	
Work scheduled by: LI			TTC with All Lines In Service	660 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, October 20, 2022 to Friday, April 19, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
GILBOA__-N.SCTLND_345_GNS-1					
Mon 10/09/2023	to	Fri 10/13/2023	CENTRAL EAST - VC	2300 MW	
0700	Continuous	1530	Impacts Total Transfer Capability	285 MW	
Work scheduled by: NYPA			TTC with All Lines In Service	2585 MW	
				FWD	REV
				(Import)	(Export)
NIAGARA_-PACKARD__230_61					
Fri 10/13/2023	to	Fri 10/13/2023	SCH - OH - NY		1350 MW
0500	Continuous	1900	Impacts Total Transfer Capability		200 MW
Work scheduled by: NYPA			TTC with All Lines In Service		1550 MW
				FWD	REV
				(Import)	(Export)
HURLYAVE-ROSETON__345_303					
Mon 11/13/2023	to	Fri 12/22/2023	UPNY CONED	4100 MW	
0800	Continuous	1600	Impacts Total Transfer Capability	3715 MW	
Work scheduled by: CHGE			TTC with All Lines In Service	7815 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, October 20, 2022 to Friday, April 19, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
CHATGUAY-MASSENA__765_7040					
Wed 11/15/2023	to	Mon 11/27/2023			
0700	Continuous	1730	SCH - HQ - NY	0 MW	0 MW
Work scheduled by: NYPA			Impacts Total Transfer Capability	1500 MW	1000 MW
			TTC with All Lines In Service	1500 MW	1000 MW
				FWD	REV
				(Import)	(Export)
CHATGUAY-MASSENA__765_7040					
Wed 11/15/2023	to	Mon 11/27/2023			
0700	Continuous	1730	MOSES SOUTH	1550 MW	
Work scheduled by: NYPA			Impacts Total Transfer Capability	1600 MW	
			TTC with All Lines In Service	3150 MW	
				FWD	REV
				(Import)	(Export)
CHATGUAY-MASSENA__765_7040 , MASSENA_-MARCY__765_MSU1					
Wed 11/15/2023	to	Mon 11/27/2023			
0700		1730	MOSES SOUTH	500 MW	
Work scheduled by:			Impacts Total Transfer Capability	2650 MW	
			TTC with All Lines In Service	3150 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, October 20, 2022 to Friday, April 19, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
MASSENA_-MARCY___765_MSU1					
Wed 11/15/2023	to	Mon 11/27/2023	CENTRAL EAST - VC	1720 MW	
0700	Continuous	1730	Impacts Total Transfer Capability	865 MW	
Work scheduled by: NYPA				TTC with All Lines In Service	2585 MW
MASSENA_-MARCY___765_MSU1					
Wed 11/15/2023	to	Mon 11/27/2023	SCH - HQ_CEDARS	90 MW	
0700	Continuous	1730	Impacts Total Transfer Capability	189 MW	
Work scheduled by: NYPA				TTC with All Lines In Service	279 MW
MASSENA_-MARCY___765_MSU1					
Wed 11/15/2023	to	Mon 11/27/2023	SCH - HQ - NY	475 MW	1000 MW
0700	Continuous	1730	Impacts Total Transfer Capability	1025 MW	0 MW
Work scheduled by: NYPA				TTC with All Lines In Service	1500 MW
MASSENA_-MARCY___765_MSU1					
Wed 11/15/2023	to	Mon 11/27/2023	MOSES SOUTH	500 MW	
0700	Continuous	1730	Impacts Total Transfer Capability	2650 MW	
Work scheduled by: NYPA				TTC with All Lines In Service	3150 MW

NYISO TRANSFER LIMITATIONS

Page 47 of 49

Number Of Records: 175

Report Run Date: 10/20/2022 18:04 (EPT)

Seasonal Limits

Thursday, October 20, 2022 to Friday, April 19, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
MOSES___-MASSENA_230_MMS1 , MOSES___- MASSENA_230_MMS2					
Wed 11/15/2023	to	Mon 11/20/2023	SCH - HQ_CEDARS	90 MW	
0700		1530	Impacts Total Transfer Capability	189 MW	
Work scheduled by:				TTC with All Lines In Service	279 MW
MOSES___-MASSENA_230_MMS1 , MOSES___- MASSENA_230_MMS2				FWD	REV
				(Import)	(Export)
Wed 11/15/2023	to	Mon 11/20/2023	SCH - HQ - NY	850 MW	0 MW
0700		1530	Impacts Total Transfer Capability	650 MW	1000 MW
Work scheduled by:				TTC with All Lines In Service	1500 MW
NIAGARA_345_230_AT4				FWD	REV
				(Import)	(Export)
Mon 11/27/2023	to	Fri 12/01/2023	SCH - OH - NY		1750 MW
0500	Continuous	1900	Impacts Total Transfer Capability		250 MW
Work scheduled by: NYPA				TTC with All Lines In Service	2000 MW

NYISO TRANSFER LIMITATIONS

Page 48 of 49

Number Of Records: 175

Report Run Date: 10/20/2022 18:04 (EPT)

Seasonal Limits

Thursday, October 20, 2022 to Friday, April 19, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HOMR_NYW-PIERC_NY_345_48

Fri 12/08/2023 to Fri 12/15/2023

0800 Continuous 1600

Work scheduled by: PJM

UPDATED by PJM 07/28/2022 14:08

SCH - PJ - NY
Impacts Total Transfer
Capability
TTC with All Lines In Service

FWD REV
(Import) (Export)

HOMRC_NY-MAINS_NY_345_47

Fri 12/08/2023 to Fri 12/15/2023

0800 Continuous 1600

Work scheduled by: PJM

UPDATED by PJM 07/28/2022 14:08

SCH - PJ - NY
Impacts Total Transfer
Capability
TTC with All Lines In Service

FWD REV
(Import) (Export)

W49TH_ST_345KV_6

Mon 01/08/2024 to Mon 02/19/2024

0001 Continuous 0201

Work scheduled by: ConEd

SCH - PJM_HTP
Impacts Total Transfer
Capability
TTC with All Lines In Service

FWD REV
(Import) (Export)

310 MW
350 MW
660 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, October 20, 2022 to Friday, April 19, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2585 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

				FWD	REV
				(Import)	(Export)
W49TH_ST-E13THSTA_345_M55					
Mon 01/08/2024	to	Mon 02/19/2024			
0001	Continuous	0201	SPR/DUN-SOUTH	3800 MW	
Work scheduled by: ConEd			Impacts Total Transfer Capability	800 MW	
			TTC with All Lines In Service	4600 MW	
				FWD	REV
				(Import)	(Export)
W49TH_ST_345KV_8					
Sat 02/03/2024	to	Mon 02/19/2024	SCH - PJM_HTP	310 MW	
0001	Continuous	0201	Impacts Total Transfer Capability	350 MW	
Work scheduled by: ConEd			TTC with All Lines In Service	660 MW	