NYISO TRANSFER LIMITATIONS

Seasonal Limits **Saturday, January 28, 2023 to Saturday, July 27, 2024**

CENTRAL EAST	**2650 MW**
CENTRAL EAST - VC	**2585 MW**
TOTAL EAST	**6000 MW**
UPNY CONED	**7815 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3150 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONP_-FARRAGUT_345_B3402

Mon 01/15/2018 to Tue 02/28/2023
0001 Continuous 2359
Work scheduled by: ConEd

EXT FORCED by ConEd 08/06/2022 16:26

	FWD (Import)	REV (Export)
SCH - PJ - NY		
Impacts Total Transfer Capability		
TTC with All Lines In Service		

MARION__-FARRAGUT_345_C3403

Mon 01/15/2018 to Tue 02/28/2023
0001 Continuous 2359
Work scheduled by: ConEd

EXT FORCED by ConEd 08/06/2022 16:26

	FWD (Import)	REV (Export)
SCH - PJ - NY		
Impacts Total Transfer Capability		
TTC with All Lines In Service		

MARION__-FARRAGUT_345_C3403 , HUDSONP_-FARRAGUT_345_B3402

Mon 01/15/2018 to Tue 02/28/2023
0001 2359
Work scheduled by:

	FWD (Import)	REV (Export)
SCH - PJ - NY	**2350 MW**	**2050 MW**
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	2450 MW	2150 MW

EGRDNCTY_345_138_AT1

Sat 10/01/2022 to Wed 05/31/2023
0001 Continuous 2359
Work scheduled by: LI

UPDATED by ConEd 10/01/2022 09:02

	FWD (Import)	REV (Export)
CONED - LIPA	**1250 MW**	
Impacts Total Transfer Capability	250 MW	
TTC with All Lines In Service	1500 MW	

EGRDNCTY_345_138_AT2

Sat 10/01/2022 to Wed 05/31/2023
0001 Continuous 2359
Work scheduled by: LI

UPDATED by ConEd 10/01/2022 09:02

	FWD (Import)	REV (Export)
CONED - LIPA	**1250 MW**	
Impacts Total Transfer Capability	250 MW	
TTC with All Lines In Service	1500 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits — **Saturday, January 28, 2023 to Saturday, July 27, 2024**

CENTRAL EAST	**2650 MW**
CENTRAL EAST - VC	**2585 MW**
TOTAL EAST	**6000 MW**
UPNY CONED	**7815 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3150 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBRK_-EGRDNCTR_345_Y49

Sat 10/01/2022 to Wed 05/31/2023
0001 Continuous 2359
Work scheduled by: LI

UPDATED by ConEd 10/01/2022 09:02

	FWD (Import)	REV (Export)
CONED - LIPA	**775 MW**	
Impacts Total Transfer Capability	725 MW	
TTC with All Lines In Service	1500 MW	

STLAWRNC-MOSES___230_L34P

Mon 10/03/2022 to Mon 09/25/2023
1800 Continuous 0800
Work scheduled by: IESO

UPDATED by IESO 10/04/2022 16:51

	FWD (Import)	REV (Export)
SCH - OH - NY		
Impacts Total Transfer Capability		
TTC with All Lines In Service		

W49TH_ST-E13THSTA_345_M54

Fri 12/30/2022 to Thu 02/02/2023
0001 Continuous 2359
Work scheduled by: ConEd

EXTENDED by ConEd 12/16/2022 13:47

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	**3800 MW**	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

MARCY_SO_SERIES_COMP_I/S

Sat 12/31/2022 to Wed 03/01/2023
1700 Continuous 0559
Work scheduled by: NYISO

	FWD (Import)	REV (Export)
CENTRAL EAST - VC	**2360 MW**	
Impacts Total Transfer Capability	225 MW	
TTC with All Lines In Service	2585 MW	

CHASLAKE-PORTER___230_11

Tue 01/03/2023 to Fri 02/17/2023
0630 Continuous 1730
Work scheduled by: NGrid

UPDATED by NGrid 01/27/2023 13:52

	FWD (Import)	REV (Export)
MOSES SOUTH	**2300 MW**	
Impacts Total Transfer Capability	850 MW	
TTC with All Lines In Service	3150 MW	

MOSES___-ADIRNDCK_230_MA1

Tue 01/03/2023 to Tue 02/28/2023
0700 Continuous 1930
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
MOSES SOUTH	**2300 MW**	
Impacts Total Transfer Capability	850 MW	
TTC with All Lines In Service	3150 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits **Saturday, January 28, 2023 to Saturday, July 27, 2024**

CENTRAL EAST	**2650 MW**
CENTRAL EAST - VC	**2585 MW**
TOTAL EAST	**6000 MW**
UPNY CONED	**7815 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3150 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-IMO-NYISO_LIMIT_1750

Fri 01/20/2023 to Sun 04/30/2023
1601 Continuous 2359
Work scheduled by: IESO

UPDATED by IESO 01/18/2023 16:31

	FWD (Import)	REV (Export)
SCH - OH - NY	**2050 MW**	
Impacts Total Transfer Capability	350 MW	
TTC with All Lines In Service	2400 MW	

SCH-NYISO-IMO_LIMIT_1600

Sat 01/21/2023 to Sun 04/30/2023
1800 Continuous 2359
Work scheduled by: IESO

UPDATED by IESO 01/18/2023 16:31

	FWD (Import)	REV (Export)
SCH - OH - NY		**1900 MW**
Impacts Total Transfer Capability		100 MW
TTC with All Lines In Service		2000 MW

DUNWODIE_345KV_8

Sun 01/22/2023 to Sun 03/05/2023
0001 Continuous 0200
Work scheduled by: ConEd

UPDATED by ConEd 01/27/2023 11:24

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	**3800 MW**	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

PLSNTVLY-WOOD_ST__345_F31

Sun 01/22/2023 to Sat 01/28/2023
0001 Continuous 0200
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
UPNY CONED	**4000 MW**	
Impacts Total Transfer Capability	3815 MW	
TTC with All Lines In Service	7815 MW	

MILLWOOD_345KV_18

Mon 01/23/2023 to Sat 01/28/2023
0001 Continuous 0200
Work scheduled by: ConEd

UPDATED by ConEd 01/18/2023 16:04

	FWD (Import)	REV (Export)
UPNY CONED	**4350 MW**	
Impacts Total Transfer Capability	3465 MW	
TTC with All Lines In Service	7815 MW	

PLSNTVLY_345KV_RNS4

Sat 01/28/2023 to Sat 01/28/2023
0130 Continuous 0200
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
UPNY CONED	**3800 MW**	
Impacts Total Transfer Capability	4015 MW	
TTC with All Lines In Service	7815 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits **Saturday, January 28, 2023 to Saturday, July 27, 2024**

CENTRAL EAST	**2650 MW**
CENTRAL EAST - VC	**2585 MW**
TOTAL EAST	**6000 MW**
UPNY CONED	**7815 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3150 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BECK___-NIAGARA__345_PA302

Mon 01/30/2023 to Mon 01/30/2023
0500 Continuous 1600
Work scheduled by: IESO

UPDATED by IESO 01/26/2023 14:20

	FWD (Import)	REV (Export)
SCH - OH - NY	**1100 MW**	**950 MW**
Impacts Total Transfer Capability	1300 MW	1050 MW
TTC with All Lines In Service	2400 MW	2000 MW

OAKDALE_-FRASER___345_32

Mon 01/30/2023 to Thu 02/02/2023
0800 Continuous 1500
Work scheduled by: NYSEG

	FWD (Import)	REV (Export)
CENTRAL EAST - VC	**2450 MW**	
Impacts Total Transfer Capability	135 MW	
TTC with All Lines In Service	2585 MW	

LONG_MTN-CRICKVLY_345_398

Tue 02/07/2023 to Wed 02/08/2023
0001 Continuous 0200
Work scheduled by: ConEd

UPDATED by ConEd 01/19/2023 17:09

	FWD (Import)	REV (Export)
SCH - NPX_1385	**100 MW**	**100 MW**
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

LONG_MTN-CRICKVLY_345_398

Tue 02/07/2023 to Wed 02/08/2023
0001 Continuous 0200
Work scheduled by: ConEd

UPDATED by ConEd 01/19/2023 17:09

	FWD (Import)	REV (Export)
SCH - NE - NY	**700 MW**	**1300 MW**
Impacts Total Transfer Capability	900 MW	500 MW
TTC with All Lines In Service	1600 MW	1800 MW

SCH-NYISO-NE_LIMIT_600

Tue 02/07/2023 to Tue 02/07/2023
0001 Continuous 0659
Work scheduled by: ConEd

UPDATED by ConEd 01/19/2023 17:09

	FWD (Import)	REV (Export)
SCH - NE - NY		**800 MW**
Impacts Total Transfer Capability		1000 MW
TTC with All Lines In Service		1800 MW

SCH-NYISO-NE_LIMIT_800

Tue 02/07/2023 to Tue 02/07/2023
0700 Continuous 2259
Work scheduled by: ConEd

UPDATED by ConEd 01/19/2023 17:09

	FWD (Import)	REV (Export)
SCH - NE - NY		**1000 MW**
Impacts Total Transfer Capability		800 MW
TTC with All Lines In Service		1800 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits **Saturday, January 28, 2023 to Saturday, July 27, 2024**

CENTRAL EAST	**2650 MW**
CENTRAL EAST - VC	**2585 MW**
TOTAL EAST	**6000 MW**
UPNY CONED	**7815 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3150 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-NE_LIMIT_600

Tue 02/07/2023 to Wed 02/08/2023
2300 Continuous 0200
Work scheduled by: ConEd

UPDATED by ConEd 01/19/2023 17:09

	FWD (Import)	REV (Export)
SCH - NE - NY		**800 MW**
Impacts Total Transfer Capability		1000 MW
TTC with All Lines In Service		1800 MW

MILLWOOD_345KV_18

Sat 02/11/2023 to Wed 02/15/2023
0001 Continuous 2200
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
UPNY CONED	**4350 MW**	
Impacts Total Transfer Capability	3465 MW	
TTC with All Lines In Service	7815 MW	

PLSNTVLY_345KV_RNS4

Sat 02/11/2023 to Thu 02/16/2023
0001 Continuous 0030
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
UPNY CONED	**3800 MW**	
Impacts Total Transfer Capability	4015 MW	
TTC with All Lines In Service	7815 MW	

PLSNTVLY-WOOD_ST__345_F31

Sat 02/11/2023 to Thu 02/16/2023
0001 Continuous 0030
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
UPNY CONED	**4000 MW**	
Impacts Total Transfer Capability	3815 MW	
TTC with All Lines In Service	7815 MW	

PLSNTVLY_345KV_RNS4

Thu 02/16/2023 to Thu 02/16/2023
2130 Continuous 2200
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
UPNY CONED	**3800 MW**	
Impacts Total Transfer Capability	4015 MW	
TTC with All Lines In Service	7815 MW	

PLSNTVLY-WOOD_ST__345_F31

Thu 02/16/2023 to Thu 02/16/2023
2130 Continuous 2200
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
UPNY CONED	**4000 MW**	
Impacts Total Transfer Capability	3815 MW	
TTC with All Lines In Service	7815 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits **Saturday, January 28, 2023 to Saturday, July 27, 2024**

CENTRAL EAST	**2650 MW**
CENTRAL EAST - VC	**2585 MW**
TOTAL EAST	**6000 MW**
UPNY CONED	**7815 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3150 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_6

				FWD (Import)	REV (Export)
Tue 02/21/2023	to	Tue 02/21/2023	SPR/DUN-SOUTH	**3800 MW**	
0201	Continuous	0230	Impacts Total Transfer Capability	800 MW	
Work scheduled by:	ConEd		TTC with All Lines In Service	4600 MW	

PLSNTVLE-DUNWODIE_345_W90

				FWD (Import)	REV (Export)
Tue 02/21/2023	to	Thu 02/23/2023	UPNY CONED	**4000 MW**	
0201	Continuous	2200	Impacts Total Transfer Capability	3815 MW	
Work scheduled by:	ConEd		TTC with All Lines In Service	7815 MW	

WOOD_ST_-PLSNTVLE_345_Y87

				FWD (Import)	REV (Export)
Tue 02/21/2023	to	Thu 02/23/2023	UPNY CONED	**7260 MW**	
0201	Continuous	2200	Impacts Total Transfer Capability	555 MW	
Work scheduled by:	ConEd		TTC with All Lines In Service	7815 MW	

CHASLAKE-PORTER___230_11

				FWD (Import)	REV (Export)
Tue 02/21/2023	to	Sat 07/15/2023	**UPDATED by NGrid 01/27/2023 13:52**	MOSES SOUTH	**2300 MW**
0630	Continuous	1730		Impacts Total Transfer Capability	850 MW
Work scheduled by:	NGrid			TTC with All Lines In Service	3150 MW

MARCY___-EDIC____345_UE1-7

				FWD (Import)	REV (Export)
Wed 02/22/2023	to	Thu 02/23/2023		OSWEGO EXPORT	**5250 MW**
0700	Continuous	1530	**ARR: 19,16**	Impacts Total Transfer Capability	0 MW
Work scheduled by:	NYPA			TTC with All Lines In Service	5250 MW

DUNWODIE_345KV_6

				FWD (Import)	REV (Export)
Thu 02/23/2023	to	Thu 02/23/2023	SPR/DUN-SOUTH	**3800 MW**	
0130	Continuous	0200	Impacts Total Transfer Capability	800 MW	
Work scheduled by:	ConEd		TTC with All Lines In Service	4600 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits **Saturday, January 28, 2023 to Saturday, July 27, 2024**

CENTRAL EAST	**2650 MW**
CENTRAL EAST - VC	**2585 MW**
TOTAL EAST	**6000 MW**
UPNY CONED	**7815 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3150 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FITZPTRK-EDIC____345_FE-1

				FWD (Import)	REV (Export)
Fri 02/24/2023	to	Tue 02/28/2023	OSWEGO EXPORT	**4800 MW**	
0700	Continuous	1700	Impacts Total Transfer Capability	450 MW	
Work scheduled by: NGrid			TTC with All Lines In Service	5250 MW	

FITZPTRK-EDIC____345_FE-1

				FWD (Import)	REV (Export)
Fri 02/24/2023	to	Tue 02/28/2023	CENTRAL EAST - VC	**2480 MW**	
0700	Continuous	1700	Impacts Total Transfer Capability	105 MW	
Work scheduled by: NGrid			TTC with All Lines In Service	2585 MW	

DUNWODIE_345KV_7

				FWD (Import)	REV (Export)
Sat 02/25/2023	to	Sun 03/05/2023	**UPDATED by ConEd 01/27/2023 11:24** SPR/DUN-SOUTH	**3800 MW**	
0001	Continuous	0200	Impacts Total Transfer Capability	800 MW	
Work scheduled by: ConEd			TTC with All Lines In Service	4600 MW	

DUNWODIE-MOTTHAVN_345_72

				FWD (Import)	REV (Export)
Sat 02/25/2023	to	Sun 03/05/2023	**UPDATED by ConEd 01/27/2023 11:24** SPR/DUN-SOUTH	**3800 MW**	
0001	Continuous	0200	Impacts Total Transfer Capability	800 MW	
Work scheduled by: ConEd			TTC with All Lines In Service	4600 MW	

EDIC___-FRASER__345_EF24-40

				FWD (Import)	REV (Export)
Wed 03/01/2023	to	Sat 04/15/2023	CENTRAL EAST - VC	**2275 MW**	
0600	Continuous	1800	Impacts Total Transfer Capability	310 MW	
Work scheduled by: NGrid			TTC with All Lines In Service	2585 MW	

MOSES__-ADIRNDCK_230_MA2

				FWD (Import)	REV (Export)
Wed 03/01/2023	to	Sun 03/05/2023	MOSES SOUTH	**2300 MW**	
0600	Continuous	1930	Impacts Total Transfer Capability	850 MW	
Work scheduled by: NYPA			TTC with All Lines In Service	3150 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits **Saturday, January 28, 2023 to Saturday, July 27, 2024**

CENTRAL EAST	**2650 MW**
CENTRAL EAST - VC	**2585 MW**
TOTAL EAST	**6000 MW**
UPNY CONED	**7815 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3150 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

N.SCTLND-ALPS____345_2

Wed 03/01/2023 to Mon 04/24/2023
0700 Continuous 1600
Work scheduled by: NGrid

UPDATED by NGrid 07/05/2022 10:45

	FWD (Import)	REV (Export)
SCH - NE - NY	**900 MW**	
Impacts Total Transfer Capability	700 MW	
TTC with All Lines In Service	1600 MW	

N.SCTLND-ALPS____345_2

Wed 03/01/2023 to Mon 04/24/2023
0700 Continuous 1600
Work scheduled by: NGrid

UPDATED by NGrid 07/05/2022 10:45

	FWD (Import)	REV (Export)
SCH - NPX_1385	**100 MW**	**100 MW**
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

NIAGARA_-PACKARD__230_61

Thu 03/02/2023 to Fri 03/10/2023
0500 Continuous 2300
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - OH - NY	**1400 MW**	**1850 MW**
Impacts Total Transfer Capability	1000 MW	150 MW
TTC with All Lines In Service	2400 MW	2000 MW

E13THSTA-FARRAGUT_345_45

Mon 03/06/2023 to Mon 03/06/2023
0100 Continuous 0130
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	**3800 MW**	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

E13THSTA-FARRAGUT_345_45

Mon 03/06/2023 to Thu 03/09/2023
0100 Continuous 0130
Work scheduled by: ConEd

CANCELLED by NYISO 01/25/2023 15:46

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	**3800 MW**	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

NRTH1385-NRTHPORT_138_NNC

Mon 03/06/2023 to Fri 03/10/2023
0500 Continuous 2359
Work scheduled by: LI

	FWD (Import)	REV (Export)
SCH - NPX_1385	**0 MW**	**0 MW**
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits **Saturday, January 28, 2023 to Saturday, July 27, 2024**

CENTRAL EAST	**2650 MW**
CENTRAL EAST - VC	**2585 MW**
TOTAL EAST	**6000 MW**
UPNY CONED	**7815 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3150 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-ADIRNDCK_230_MA1

				FWD (Import)	REV (Export)
Mon 03/06/2023	to	Fri 05/26/2023	MOSES SOUTH	**2300 MW**	
0700	Continuous	1930	Impacts Total Transfer Capability	850 MW	
Work scheduled by:	NYPA		TTC with All Lines In Service	3150 MW	

SCH-NE-NYISO_LIMIT_600

				FWD (Import)	REV (Export)
Tue 03/07/2023	to	Wed 03/08/2023	SCH - NE - NY	**800 MW**	
2300	Continuous	0659	Impacts Total Transfer Capability	800 MW	
Work scheduled by:	ISONE		TTC with All Lines In Service	1600 MW	

SCH-NE-NYISO_LIMIT_600

				FWD (Import)	REV (Export)
Wed 03/08/2023	to	Thu 03/09/2023	SCH - NE - NY	**800 MW**	
2300	Continuous	0659	Impacts Total Transfer Capability	800 MW	
Work scheduled by:	ISONE		TTC with All Lines In Service	1600 MW	

E13THSTA-FARRAGUT_345_45

				FWD (Import)	REV (Export)
Thu 03/09/2023	to	Thu 03/09/2023	SPR/DUN-SOUTH	**3800 MW**	
0130	Continuous	0200	Impacts Total Transfer Capability	800 MW	
Work scheduled by:	ConEd		TTC with All Lines In Service	4600 MW	

E13THSTA-FARRAGUT_345_45

					FWD (Import)	REV (Export)
Thu 03/09/2023	to	Thu 03/09/2023	**CANCELLED by NYISO 01/25/2023 15:46**	SPR/DUN-SOUTH	**3800 MW**	
0130	Continuous	0200		Impacts Total Transfer Capability	800 MW	
Work scheduled by:	ConEd			TTC with All Lines In Service	4600 MW	

SCH-NE-NYISO_LIMIT_600

				FWD (Import)	REV (Export)
Thu 03/09/2023	to	Fri 03/10/2023	SCH - NE - NY	**800 MW**	
2300	Continuous	0659	Impacts Total Transfer Capability	800 MW	
Work scheduled by:	ISONE		TTC with All Lines In Service	1600 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits **Saturday, January 28, 2023 to Saturday, July 27, 2024**

CENTRAL EAST	**2650 MW**
CENTRAL EAST - VC	**2585 MW**
TOTAL EAST	**6000 MW**
UPNY CONED	**7815 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3150 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBRK_-TREMONT__345_X28

					FWD (Import)	REV (Export)
Fri 03/10/2023	to	Fri 03/10/2023	**UPDATED by ConEd 01/28/2023 08:01**	SPR/DUN-SOUTH	**4200 MW**	
0001	Continuous	0030		Impacts Total Transfer Capability	400 MW	
Work scheduled by:	ConEd			TTC with All Lines In Service	4600 MW	

SCH-NE-NYISO_LIMIT_600

					FWD (Import)	REV (Export)
Fri 03/10/2023	to	Sat 03/11/2023		SCH - NE - NY	**800 MW**	
2300	Continuous	0659		Impacts Total Transfer Capability	800 MW	
Work scheduled by:	ISONE			TTC with All Lines In Service	1600 MW	

SCH-NE-NYISO_LIMIT_600

					FWD (Import)	REV (Export)
Sat 03/11/2023	to	Sun 03/12/2023		SCH - NE - NY	**800 MW**	
2300	Continuous	0659		Impacts Total Transfer Capability	800 MW	
Work scheduled by:	ISONE			TTC with All Lines In Service	1600 MW	

SPRNBRK_-TREMONT__345_X28

					FWD (Import)	REV (Export)
Sun 03/12/2023	to	Sun 03/12/2023	**UPDATED by ConEd 01/28/2023 08:01**	SPR/DUN-SOUTH	**4200 MW**	
1730	Continuous	1800		Impacts Total Transfer Capability	400 MW	
Work scheduled by:	ConEd			TTC with All Lines In Service	4600 MW	

SCH-NE-NYISO_LIMIT_600

					FWD (Import)	REV (Export)
Sun 03/12/2023	to	Mon 03/13/2023		SCH - NE - NY	**800 MW**	
2300	Continuous	0659		Impacts Total Transfer Capability	800 MW	
Work scheduled by:	ISONE			TTC with All Lines In Service	1600 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits **Saturday, January 28, 2023 to Saturday, July 27, 2024**

CENTRAL EAST	**2650 MW**
CENTRAL EAST - VC	**2585 MW**
TOTAL EAST	**6000 MW**
UPNY CONED	**7815 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3150 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NINEMILE-CLAY____345_8

				FWD (Import)	REV (Export)
Mon 03/13/2023	to	Thu 03/23/2023	OSWEGO EXPORT	**5150 MW**	
0029	Continuous	1700	Impacts Total Transfer Capability	100 MW	
Work scheduled by:	NGrid		TTC with All Lines In Service	5250 MW	

NIAGARA_-ROBNSNRD_230_64

				FWD (Import)	REV (Export)
Mon 03/13/2023	to	Fri 03/31/2023	SCH - OH - NY		**1900 MW**
0500	Continuous	1900	Impacts Total Transfer Capability		100 MW
Work scheduled by:	NYPA		TTC with All Lines In Service		2000 MW

COOPERS_-MIDDLETP_345_CCRT34

				FWD (Import)	REV (Export)
Mon 03/13/2023	to	Fri 03/17/2023	CENTRAL EAST - VC	**2485 MW**	
0700	Continuous	0759	Impacts Total Transfer Capability	100 MW	
Work scheduled by:	NYSEG		TTC with All Lines In Service	2585 MW	

SCH-NE-NYISO_LIMIT_600

				FWD (Import)	REV (Export)
Mon 03/13/2023	to	Tue 03/14/2023	SCH - NE - NY	**800 MW**	
2300	Continuous	0659	Impacts Total Transfer Capability	800 MW	
Work scheduled by:	ISONE		TTC with All Lines In Service	1600 MW	

SCH-NE-NYISO_LIMIT_600

				FWD (Import)	REV (Export)
Tue 03/14/2023	to	Wed 03/15/2023	SCH - NE - NY	**800 MW**	
2300	Continuous	0659	Impacts Total Transfer Capability	800 MW	
Work scheduled by:	ISONE		TTC with All Lines In Service	1600 MW	

EASTVIEW-SPRNBRK__345_W64

				FWD (Import)	REV (Export)
Wed 03/15/2023	to	Fri 03/24/2023	UPNY CONED	**4350 MW**	
0201	Continuous	0200	Impacts Total Transfer Capability	3465 MW	
Work scheduled by:	ConEd		TTC with All Lines In Service	7815 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits **Saturday, January 28, 2023 to Saturday, July 27, 2024**

CENTRAL EAST	**2650 MW**
CENTRAL EAST - VC	**2585 MW**
TOTAL EAST	**6000 MW**
UPNY CONED	**7815 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3150 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MILLWOOD-EASTVIEW_345_W99

				FWD (Import)	REV (Export)
Wed 03/15/2023	to	Wed 03/15/2023	UPNY CONED	**7550 MW**	
0201	Continuous	0230	Impacts Total Transfer Capability	265 MW	
Work scheduled by:	ConEd		TTC with All Lines In Service	7815 MW	

SPRNBRK__345KV_RNS5

				FWD (Import)	REV (Export)
Wed 03/15/2023	to	Wed 03/15/2023	SPR/DUN-SOUTH	**3200 MW**	
0201	Continuous	0230	Impacts Total Transfer Capability	1400 MW	
Work scheduled by:	ConEd		TTC with All Lines In Service	4600 MW	

SCH-NE-NYISO_LIMIT_600

				FWD (Import)	REV (Export)
Wed 03/15/2023	to	Thu 03/16/2023	SCH - NE - NY	**800 MW**	
2300	Continuous	0659	Impacts Total Transfer Capability	800 MW	
Work scheduled by:	ISONE		TTC with All Lines In Service	1600 MW	

SCH-NE-NYISO_LIMIT_600

				FWD (Import)	REV (Export)
Thu 03/16/2023	to	Fri 03/17/2023	SCH - NE - NY	**800 MW**	
2300	Continuous	0659	Impacts Total Transfer Capability	800 MW	
Work scheduled by:	ISONE		TTC with All Lines In Service	1600 MW	

SCH-NE-NYISO_LIMIT_600

				FWD (Import)	REV (Export)
Fri 03/17/2023	to	Sat 03/18/2023	SCH - NE - NY	**800 MW**	
2300	Continuous	0659	Impacts Total Transfer Capability	800 MW	
Work scheduled by:	ISONE		TTC with All Lines In Service	1600 MW	

SCH-NE-NYISO_LIMIT_600

				FWD (Import)	REV (Export)
Sat 03/18/2023	to	Sun 03/19/2023	SCH - NE - NY	**800 MW**	
2300	Continuous	0659	Impacts Total Transfer Capability	800 MW	
Work scheduled by:	ISONE		TTC with All Lines In Service	1600 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits **Saturday, January 28, 2023 to Saturday, July 27, 2024**

CENTRAL EAST	**2650 MW**
CENTRAL EAST - VC	**2585 MW**
TOTAL EAST	**6000 MW**
UPNY CONED	**7815 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3150 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NE-NYISO_LIMIT_600

				FWD (Import)	REV (Export)
Sun 03/19/2023	to	Mon 03/20/2023	SCH - NE - NY	**800 MW**	
2300	Continuous	0659	Impacts Total Transfer Capability	800 MW	
Work scheduled by:	ISONE		TTC with All Lines In Service	1600 MW	

GORDONRD-N.SCTLND_345_55

				FWD (Import)	REV (Export)
Mon 03/20/2023	to	Wed 04/19/2023	CENTRAL EAST - VC	**2045 MW**	
0700	Continuous	1400	Impacts Total Transfer Capability	540 MW	
Work scheduled by:	LS		TTC with All Lines In Service	2585 MW	

SCH-NE-NYISO_LIMIT_600

				FWD (Import)	REV (Export)
Mon 03/20/2023	to	Tue 03/21/2023	SCH - NE - NY	**800 MW**	
2300	Continuous	0659	Impacts Total Transfer Capability	800 MW	
Work scheduled by:	ISONE		TTC with All Lines In Service	1600 MW	

MILLWOOD_345KV_18

				FWD (Import)	REV (Export)
Tue 03/21/2023	to	Thu 03/23/2023	UPNY CONED	**4350 MW**	
0001	Continuous	2200	Impacts Total Transfer Capability	3465 MW	
Work scheduled by:	ConEd		TTC with All Lines In Service	7815 MW	

SCH-NE-NYISO_LIMIT_600

				FWD (Import)	REV (Export)
Tue 03/21/2023	to	Wed 03/22/2023	SCH - NE - NY	**800 MW**	
2300	Continuous	0659	Impacts Total Transfer Capability	800 MW	
Work scheduled by:	ISONE		TTC with All Lines In Service	1600 MW	

SCH-NE-NYISO_LIMIT_600

				FWD (Import)	REV (Export)
Wed 03/22/2023	to	Thu 03/23/2023	SCH - NE - NY	**800 MW**	
2300	Continuous	0659	Impacts Total Transfer Capability	800 MW	
Work scheduled by:	ISONE		TTC with All Lines In Service	1600 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits **Saturday, January 28, 2023 to Saturday, July 27, 2024**

CENTRAL EAST	**2650 MW**
CENTRAL EAST - VC	**2585 MW**
TOTAL EAST	**6000 MW**
UPNY CONED	**7815 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3150 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NE-NYISO_LIMIT_600

				FWD (Import)	REV (Export)
Thu 03/23/2023	to	Fri 03/24/2023	SCH - NE - NY	**800 MW**	
2300	Continuous	0659	Impacts Total Transfer Capability	800 MW	
Work scheduled by:	ISONE		TTC with All Lines In Service	1600 MW	

MILLWOOD-EASTVIEW_345_W99

				FWD (Import)	REV (Export)
Fri 03/24/2023	to	Fri 03/24/2023	UPNY CONED	**7550 MW**	
0130	Continuous	0200	Impacts Total Transfer Capability	265 MW	
Work scheduled by:	ConEd		TTC with All Lines In Service	7815 MW	

SPRNBRK__345KV_RNS5

				FWD (Import)	REV (Export)
Fri 03/24/2023	to	Fri 03/24/2023	SPR/DUN-SOUTH	**3200 MW**	
0130	Continuous	0200	Impacts Total Transfer Capability	1400 MW	
Work scheduled by:	ConEd		TTC with All Lines In Service	4600 MW	

SCH-NE-NYISO_LIMIT_600

				FWD (Import)	REV (Export)
Fri 03/24/2023	to	Sat 03/25/2023	SCH - NE - NY	**800 MW**	
2300	Continuous	0659	Impacts Total Transfer Capability	800 MW	
Work scheduled by:	ISONE		TTC with All Lines In Service	1600 MW	

VOLNEY__-MARCY___345_19

				FWD (Import)	REV (Export)
Sat 03/25/2023	to	Sun 03/26/2023	**UPDATED by NYPA 01/25/2023 11:58**	OSWEGO EXPORT	**4900 MW**
0500	Continuous	1900	**ARR: 19**	Impacts Total Transfer Capability	350 MW
Work scheduled by:	NYPA			TTC with All Lines In Service	5250 MW

VOLNEY__-MARCY___345_19

				FWD (Import)	REV (Export)
Sat 03/25/2023	to	Sun 03/26/2023	**UPDATED by NYPA 01/25/2023 11:58**	CENTRAL EAST - VC	**2475 MW**
0500	Continuous	1900	**ARR: 19**	Impacts Total Transfer Capability	110 MW
Work scheduled by:	NYPA			TTC with All Lines In Service	2585 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits **Saturday, January 28, 2023 to Saturday, July 27, 2024**

CENTRAL EAST	**2650 MW**
CENTRAL EAST - VC	**2585 MW**
TOTAL EAST	**6000 MW**
UPNY CONED	**7815 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3150 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NE-NYISO_LIMIT_600

				FWD (Import)	REV (Export)
Sat 03/25/2023	to	Sun 03/26/2023	SCH - NE - NY	**800 MW**	
2300	Continuous	0659	Impacts Total Transfer Capability	800 MW	
Work scheduled by:	ISONE		TTC with All Lines In Service	1600 MW	

EASTVIEW-SPRNBRK__345_W78

				FWD (Import)	REV (Export)
Sun 03/26/2023	to	Tue 03/28/2023	UPNY CONED	**4350 MW**	
0001	Continuous	0200	Impacts Total Transfer Capability	3465 MW	
Work scheduled by:	ConEd		TTC with All Lines In Service	7815 MW	

MILLWOOD-EASTVIEW_345_W85

				FWD (Import)	REV (Export)
Sun 03/26/2023	to	Tue 03/28/2023	UPNY CONED	**7550 MW**	
0001	Continuous	0200	Impacts Total Transfer Capability	265 MW	
Work scheduled by:	ConEd		TTC with All Lines In Service	7815 MW	

SPRNBRK__345KV_RNS3

				FWD (Import)	REV (Export)
Sun 03/26/2023	to	Tue 03/28/2023	SPR/DUN-SOUTH	**3800 MW**	
0001	Continuous	0200	Impacts Total Transfer Capability	800 MW	
Work scheduled by:	ConEd		TTC with All Lines In Service	4600 MW	

SCH-NE-NYISO_LIMIT_600

				FWD (Import)	REV (Export)
Sun 03/26/2023	to	Mon 03/27/2023	SCH - NE - NY	**800 MW**	
2300	Continuous	0659	Impacts Total Transfer Capability	800 MW	
Work scheduled by:	ISONE		TTC with All Lines In Service	1600 MW	

LADENTWN-BUCHAN_S_345_Y88

				FWD (Import)	REV (Export)
Mon 03/27/2023	to	Mon 03/27/2023	UPNY CONED	**7560 MW**	
0600	Continuous	0630	Impacts Total Transfer Capability	255 MW	
Work scheduled by:	ORU		TTC with All Lines In Service	7815 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits **Saturday, January 28, 2023 to Saturday, July 27, 2024**

CENTRAL EAST	**2650 MW**
CENTRAL EAST - VC	**2585 MW**
TOTAL EAST	**6000 MW**
UPNY CONED	**7815 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3150 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NE-NYISO_LIMIT_600

				FWD (Import)	REV (Export)
Mon 03/27/2023	to	Tue 03/28/2023	SCH - NE - NY	**800 MW**	
2300	Continuous	0659	Impacts Total Transfer Capability	800 MW	
Work scheduled by:	ISONE		TTC with All Lines In Service	1600 MW	

MOTTHAVN-RAINEY___345_Q12

				FWD (Import)	REV (Export)
Wed 03/29/2023	to	Sun 04/30/2023	**UPDATED by ConEd 01/02/2023 14:23**	SPR/DUN-SOUTH	**3800 MW**
0001	Continuous	0200		Impacts Total Transfer Capability	800 MW
Work scheduled by:	ConEd			TTC with All Lines In Service	4600 MW

LADENTWN-BUCHAN_S_345_Y88

				FWD (Import)	REV (Export)
Wed 03/29/2023	to	Wed 03/29/2023		UPNY CONED	**7560 MW**
2030	Continuous	2100		Impacts Total Transfer Capability	255 MW
Work scheduled by:	ORU			TTC with All Lines In Service	7815 MW

VOLNEY__-MARCY___345_19

				FWD (Import)	REV (Export)
Sat 04/01/2023	to	Sun 04/02/2023		OSWEGO EXPORT	**4900 MW**
0500	Continuous	1900	**ARR: 19**	Impacts Total Transfer Capability	350 MW
Work scheduled by:	NYPA			TTC with All Lines In Service	5250 MW

VOLNEY__-MARCY___345_19

				FWD (Import)	REV (Export)
Sat 04/01/2023	to	Sun 04/02/2023		CENTRAL EAST - VC	**2475 MW**
0500	Continuous	1900	**ARR: 19**	Impacts Total Transfer Capability	110 MW
Work scheduled by:	NYPA			TTC with All Lines In Service	2585 MW

ATHENS__-PLSNTVLY_345_91

				FWD (Import)	REV (Export)
Sat 04/01/2023	to	Sun 04/16/2023		UPNY CONED	**3800 MW**
0700	Continuous	0200		Impacts Total Transfer Capability	4015 MW
Work scheduled by:	NGrid			TTC with All Lines In Service	7815 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits **Saturday, January 28, 2023 to Saturday, July 27, 2024**

CENTRAL EAST	**2650 MW**
CENTRAL EAST - VC	**2585 MW**
TOTAL EAST	**6000 MW**
UPNY CONED	**7815 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3150 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY_345KV_RNS4

Sat 04/01/2023 to Sat 04/01/2023
0700 Continuous 0730
Work scheduled by: NGrid

	FWD (Import)	REV (Export)
UPNY CONED	**3800 MW**	
Impacts Total Transfer Capability	4015 MW	
TTC with All Lines In Service	7815 MW	

LINDN_CG-LNDVFT___345_V-3022

Sun 04/09/2023 to Sat 04/15/2023
1400 Continuous 1400
Work scheduled by: PJM

	FWD (Import)	REV (Export)
SCH - PJM_VFT	**0 MW**	**0 MW**
Impacts Total Transfer Capability	315 MW	315 MW
TTC with All Lines In Service	315 MW	315 MW

DYSINGER-STA_255__345_DH1

Mon 04/10/2023 to Fri 04/14/2023
0500 Continuous 2000
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
DYSINGER EAST	**2850 MW**	
Impacts Total Transfer Capability	350 MW	
TTC with All Lines In Service	3200 MW	

FROST_BR-LONG_MTN_345_352

Mon 04/10/2023 to Tue 04/18/2023
0830 Continuous 1300
Work scheduled by: ISONE

UPDATED by ISONE 01/13/2023 10:41

	FWD (Import)	REV (Export)
SCH - NE - NY	**1300 MW**	
Impacts Total Transfer Capability	300 MW	
TTC with All Lines In Service	1600 MW	

SCH-NYISO-NE_LIMIT_600

Mon 04/10/2023 to Tue 04/18/2023
0830 Continuous 1300
Work scheduled by: ISONE

UPDATED by ISONE 01/13/2023 10:41

	FWD (Import)	REV (Export)
SCH - NE - NY		**800 MW**
Impacts Total Transfer Capability		1000 MW
TTC with All Lines In Service		1800 MW

DUNWODIE_345KV_3

Wed 04/12/2023 to Wed 04/12/2023
0201 Continuous 0230
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	**3800 MW**	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits **Saturday, January 28, 2023 to Saturday, July 27, 2024**

CENTRAL EAST	**2650 MW**
CENTRAL EAST - VC	**2585 MW**
TOTAL EAST	**6000 MW**
UPNY CONED	**7815 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3150 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_4

				FWD (Import)	REV (Export)
Wed 04/12/2023	to	Wed 04/12/2023	SPR/DUN-SOUTH	**3800 MW**	
0201	Continuous	0230	Impacts Total Transfer Capability	800 MW	
Work scheduled by:	ConEd		TTC with All Lines In Service	4600 MW	

PLSNTVLE-DUNWODIE_345_W89

				FWD (Import)	REV (Export)
Wed 04/12/2023	to	Wed 04/12/2023	UPNY CONED	**4000 MW**	
0201	Continuous	0230	Impacts Total Transfer Capability	3815 MW	
Work scheduled by:	ConEd		TTC with All Lines In Service	7815 MW	

PLSNTVLY_345KV_RNS5

				FWD (Import)	REV (Export)
Sun 04/16/2023	to	Sun 04/16/2023	UPNY CONED	**3800 MW**	
0100	Continuous	0200	Impacts Total Transfer Capability	4015 MW	
Work scheduled by:	ConEd		TTC with All Lines In Service	7815 MW	

PLSNTVLY_345KV_RNS4

				FWD (Import)	REV (Export)
Sun 04/16/2023	to	Sun 04/16/2023	UPNY CONED	**3800 MW**	
0130	Continuous	0200	Impacts Total Transfer Capability	4015 MW	
Work scheduled by:	NGrid		TTC with All Lines In Service	7815 MW	

LEEDS___-PLSNTVLY_345_92

				FWD (Import)	REV (Export)
Sun 04/16/2023	to	Sun 04/30/2023	UPNY CONED	**3800 MW**	
0700	Continuous	1900	Impacts Total Transfer Capability	4015 MW	
Work scheduled by:	NGrid		TTC with All Lines In Service	7815 MW	

PLSNTVLY_345KV_RNS5

				FWD (Import)	REV (Export)
Sun 04/16/2023	to	Sun 04/16/2023	UPNY CONED	**3800 MW**	
0700	Continuous	0730	Impacts Total Transfer Capability	4015 MW	
Work scheduled by:	NGrid		TTC with All Lines In Service	7815 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits **Saturday, January 28, 2023 to Saturday, July 27, 2024**

CENTRAL EAST	**2650 MW**
CENTRAL EAST - VC	**2585 MW**
TOTAL EAST	**6000 MW**
UPNY CONED	**7815 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3150 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DYSINGER-STA_255__345_DH2

				FWD (Import)	REV (Export)
Mon 04/17/2023	to	Fri 04/21/2023	DYSINGER EAST	**2850 MW**	
0500	Continuous	2000	Impacts Total Transfer Capability	350 MW	
Work scheduled by:	NYPA		TTC with All Lines In Service	3200 MW	

CLAY____-EDIC_____345_2-15

				FWD (Import)	REV (Export)
Mon 04/17/2023	to	Fri 04/28/2023	OSWEGO EXPORT	**4850 MW**	
0600	Continuous	1800	Impacts Total Transfer Capability	400 MW	
Work scheduled by:	NGrid		TTC with All Lines In Service	5250 MW	

DUNWODIE_345KV_3

				FWD (Import)	REV (Export)
Thu 04/20/2023	to	Thu 04/20/2023	SPR/DUN-SOUTH	**3800 MW**	
0130	Continuous	0200	Impacts Total Transfer Capability	800 MW	
Work scheduled by:	ConEd		TTC with All Lines In Service	4600 MW	

DUNWODIE_345KV_4

				FWD (Import)	REV (Export)
Thu 04/20/2023	to	Thu 04/20/2023	SPR/DUN-SOUTH	**3800 MW**	
0130	Continuous	0200	Impacts Total Transfer Capability	800 MW	
Work scheduled by:	ConEd		TTC with All Lines In Service	4600 MW	

PLSNTVLE-DUNWODIE_345_W89

				FWD (Import)	REV (Export)
Thu 04/20/2023	to	Thu 04/20/2023	UPNY CONED	**4000 MW**	
0130	Continuous	0200	Impacts Total Transfer Capability	3815 MW	
Work scheduled by:	ConEd		TTC with All Lines In Service	7815 MW	

BUCHAN_S-MILLWOOD_345_W98

				FWD (Import)	REV (Export)
Mon 04/24/2023	to	Wed 04/26/2023	UPNY CONED	**7680 MW**	
0001	Continuous	0200	Impacts Total Transfer Capability	135 MW	
Work scheduled by:	ConEd		TTC with All Lines In Service	7815 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits **Saturday, January 28, 2023 to Saturday, July 27, 2024**

CENTRAL EAST	**2650 MW**
CENTRAL EAST - VC	**2585 MW**
TOTAL EAST	**6000 MW**
UPNY CONED	**7815 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3150 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MILLWOOD_345KV_18

				FWD (Import)	REV (Export)
Mon 04/24/2023	to	Wed 04/26/2023	UPNY CONED	**4350 MW**	
0001	Continuous	0200	Impacts Total Transfer Capability	3465 MW	
Work scheduled by:	ConEd		TTC with All Lines In Service	7815 MW	

PANNELL_-CLAY____345_1

				FWD (Import)	REV (Export)
Mon 04/24/2023	to	Fri 04/28/2023	WEST CENTRAL	**1300 MW**	
0700	Continuous	1530	Impacts Total Transfer Capability	950 MW	
Work scheduled by:	NYPA		TTC with All Lines In Service	2250 MW	

PLSNTVLY_345KV_RNS5

				FWD (Import)	REV (Export)
Sun 04/30/2023	to	Sun 04/30/2023	UPNY CONED	**3800 MW**	
1830	Continuous	1900	Impacts Total Transfer Capability	4015 MW	
Work scheduled by:	NGrid		TTC with All Lines In Service	7815 MW	

BUCHAN_N-EASTVIEW_345_W93

				FWD (Import)	REV (Export)
Mon 05/01/2023	to	Fri 05/12/2023	UPNY CONED	**4350 MW**	
0001	Continuous	2200	Impacts Total Transfer Capability	3465 MW	
Work scheduled by:	ConEd		TTC with All Lines In Service	7815 MW	

EASTVIEW-SPRNBRK__345_W79

				FWD (Import)	REV (Export)
Mon 05/01/2023	to	Mon 05/01/2023	UPNY CONED	**4350 MW**	
0001	Continuous	0030	Impacts Total Transfer Capability	3465 MW	
Work scheduled by:	ConEd		TTC with All Lines In Service	7815 MW	

FRASANNX-COOPERS__345_UCC2-41

				FWD (Import)	REV (Export)
Mon 05/01/2023	to	Fri 05/26/2023	CENTRAL EAST - VC	**2275 MW**	
0600	Continuous	1730	Impacts Total Transfer Capability	310 MW	
Work scheduled by:	NYPA		TTC with All Lines In Service	2585 MW	

ARR: 19

NYISO TRANSFER LIMITATIONS

Seasonal Limits **Saturday, January 28, 2023 to Saturday, July 27, 2024**

CENTRAL EAST	**2650 MW**
CENTRAL EAST - VC	**2585 MW**
TOTAL EAST	**6000 MW**
UPNY CONED	**7815 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3150 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___-FRASANNX_345_UCC2-41

				FWD (Import)	REV (Export)
Mon 05/01/2023	to	Fri 05/26/2023	CENTRAL EAST - VC	**2275 MW**	
0600	Continuous	1730	Impacts Total Transfer Capability	310 MW	
Work scheduled by: NYPA		**ARR: 19**	TTC with All Lines In Service	2585 MW	

SHOR_NPX-SHOREHAM_138_CSC

				FWD (Import)	REV (Export)
Mon 05/01/2023	to	Fri 05/05/2023	SCH - NPX_CSC	**0 MW**	**0 MW**
0600	Continuous	1800	Impacts Total Transfer Capability	330 MW	330 MW
Work scheduled by: LI			TTC with All Lines In Service	330 MW	330 MW

PANNELL_-CLAY____345_2

				FWD (Import)	REV (Export)
Mon 05/01/2023	to	Fri 05/05/2023	WEST CENTRAL	**1300 MW**	
0700	Continuous	1530	Impacts Total Transfer Capability	950 MW	
Work scheduled by: NYPA			TTC with All Lines In Service	2250 MW	

LEEDS___-HURLYAVE_345_301

				FWD (Import)	REV (Export)
Mon 05/01/2023	to	Fri 06/02/2023	UPNY CONED	**4100 MW**	
0800	Continuous	1700	Impacts Total Transfer Capability	3715 MW	
Work scheduled by: CHGE			TTC with All Lines In Service	7815 MW	

W49TH_ST_345KV_6

				FWD (Import)	REV (Export)
Sat 05/06/2023	to	Sat 05/06/2023	SCH - PJM_HTP	**300 MW**	
0001	Continuous	0030	Impacts Total Transfer Capability	360 MW	
Work scheduled by: ConEd			TTC with All Lines In Service	660 MW	

W49TH_ST_345KV_8

				FWD (Import)	REV (Export)
Sat 05/06/2023	to	Sat 05/06/2023	SCH - PJM_HTP	**450 MW**	
0001	Continuous	0030	Impacts Total Transfer Capability	210 MW	
Work scheduled by: ConEd			TTC with All Lines In Service	660 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits **Saturday, January 28, 2023 to Saturday, July 27, 2024**

CENTRAL EAST	**2650 MW**
CENTRAL EAST - VC	**2585 MW**
TOTAL EAST	**6000 MW**
UPNY CONED	**7815 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3150 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

COOPERS_-DOLSONAV_345_CCDA42

				FWD (Import)	REV (Export)
Mon 05/08/2023	to	Sun 05/21/2023	CENTRAL EAST - VC	**2485 MW**	
0700	Continuous	1530	Impacts Total Transfer Capability	100 MW	
Work scheduled by:	NYPA		TTC with All Lines In Service	2585 MW	

DOLSONAV-ROCKTVRN_345_DART44

				FWD (Import)	REV (Export)
Mon 05/08/2023	to	Sat 05/13/2023	CENTRAL EAST - VC	**2485 MW**	
0700	Continuous	1530	Impacts Total Transfer Capability	100 MW	
Work scheduled by:	NYPA		TTC with All Lines In Service	2585 MW	

W49TH_ST_345KV_6

				FWD (Import)	REV (Export)
Thu 05/11/2023	to	Fri 05/12/2023	SCH - PJM_HTP	**300 MW**	
0001	Continuous	0100	Impacts Total Transfer Capability	360 MW	
Work scheduled by:	ConEd		TTC with All Lines In Service	660 MW	

W49TH_ST-E13THSTA_345_M55

				FWD (Import)	REV (Export)
Thu 05/11/2023	to	Fri 05/12/2023	SPR/DUN-SOUTH	**3800 MW**	
0001	Continuous	0100	Impacts Total Transfer Capability	800 MW	
Work scheduled by:	ConEd		TTC with All Lines In Service	4600 MW	

EASTVIEW-SPRNBRK__345_W79

				FWD (Import)	REV (Export)
Fri 05/12/2023	to	Fri 05/12/2023	UPNY CONED	**4350 MW**	
2130	Continuous	2200	Impacts Total Transfer Capability	3465 MW	
Work scheduled by:	ConEd		TTC with All Lines In Service	7815 MW	

SPRNBRK__345KV_RNS4

					FWD (Import)	REV (Export)
Sat 05/13/2023	to	Mon 05/15/2023	**UPDATED by ConEd 01/04/2023 11:31**	SPR/DUN-SOUTH	**3200 MW**	
0001	Continuous	0300		Impacts Total Transfer Capability	1400 MW	
Work scheduled by:	ConEd			TTC with All Lines In Service	4600 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits **Saturday, January 28, 2023 to Saturday, July 27, 2024**

CENTRAL EAST	**2650 MW**
CENTRAL EAST - VC	**2585 MW**
TOTAL EAST	**6000 MW**
UPNY CONED	**7815 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3150 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBRK_-W49TH_ST_345_M52

Sat 05/13/2023 to Mon 05/15/2023
0001 Continuous 0300
Work scheduled by: ConEd

UPDATED by ConEd 01/04/2023 11:31

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	**3200 MW**	
Impacts Total Transfer Capability	1400 MW	
TTC with All Lines In Service	4600 MW	

W49TH_ST_345KV_5

Sat 05/13/2023 to Mon 05/15/2023
0001 Continuous 0300
Work scheduled by: ConEd

UPDATED by ConEd 01/04/2023 11:31

	FWD (Import)	REV (Export)
SCH - PJM_HTP	**300 MW**	
Impacts Total Transfer Capability	360 MW	
TTC with All Lines In Service	660 MW	

W49TH_ST_345KV_6

Sat 05/13/2023 to Sat 05/13/2023
0130 Continuous 0200
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - PJM_HTP	**300 MW**	
Impacts Total Transfer Capability	360 MW	
TTC with All Lines In Service	660 MW	

W49TH_ST_345KV_8

Sat 05/13/2023 to Sat 05/13/2023
0130 Continuous 0200
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - PJM_HTP	**450 MW**	
Impacts Total Transfer Capability	210 MW	
TTC with All Lines In Service	660 MW	

W49TH_ST_345KV_6

Mon 05/15/2023 to Mon 05/15/2023
0301 Continuous 0330
Work scheduled by: ConEd

UPDATED by ConEd 01/04/2023 11:05

	FWD (Import)	REV (Export)
SCH - PJM_HTP	**300 MW**	
Impacts Total Transfer Capability	360 MW	
TTC with All Lines In Service	660 MW	

W49TH_ST-E13THSTA_345_M55

Mon 05/15/2023 to Wed 05/17/2023
0301 Continuous 0200
Work scheduled by: ConEd

UPDATED by ConEd 01/04/2023 11:05

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	**3800 MW**	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits **Saturday, January 28, 2023 to Saturday, July 27, 2024**

CENTRAL EAST	**2650 MW**
CENTRAL EAST - VC	**2585 MW**
TOTAL EAST	**6000 MW**
UPNY CONED	**7815 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3150 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LADENTWN-BUCHAN_S_345_Y88

				FWD (Import)	REV (Export)
Mon 05/15/2023	to	Mon 05/15/2023	UPNY CONED	**7560 MW**	
0600	Continuous	0630	Impacts Total Transfer Capability	255 MW	
Work scheduled by: ORU			TTC with All Lines In Service	7815 MW	

LADENTWN-BUCHAN_S_345_Y88

				FWD (Import)	REV (Export)
Mon 05/15/2023	to	Mon 05/15/2023	UPNY CONED	**7560 MW**	
2030	Continuous	2100	Impacts Total Transfer Capability	255 MW	
Work scheduled by: ORU			TTC with All Lines In Service	7815 MW	

MOTTHAVN-RAINEY___345_Q11

				FWD (Import)	REV (Export)
Wed 05/17/2023	to	Sat 05/20/2023	SPR/DUN-SOUTH	**3800 MW**	
0001	Continuous	0200	Impacts Total Transfer Capability	800 MW	
Work scheduled by: ConEd			TTC with All Lines In Service	4600 MW	

W49TH_ST_345KV_6

				FWD (Import)	REV (Export)
Wed 05/17/2023	to	Wed 05/17/2023	**UPDATED by ConEd 01/04/2023 11:05**	SCH - PJM_HTP	**300 MW**
0130	Continuous	0200		Impacts Total Transfer Capability	360 MW
Work scheduled by: ConEd				TTC with All Lines In Service	660 MW

BECK___-NIAGARA__230_PA27

				FWD (Import)	REV (Export)
Tue 05/30/2023	to	Fri 06/02/2023	SCH - OH - NY		
0500	Continuous	2100	Impacts Total Transfer Capability		
Work scheduled by: NYPA			TTC with All Lines In Service		

CHATGUAY-MASSENA__765_7040

				FWD (Import)	REV (Export)
Tue 05/30/2023	to	Tue 05/30/2023	**UPDATED by NYPA 12/13/2022 09:46**	SCH - HQ - NY	**0 MW**	**0 MW**
0600	Continuous	1930		Impacts Total Transfer Capability	1500 MW	1000 MW
Work scheduled by: NYPA				TTC with All Lines In Service	1500 MW	1000 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits **Saturday, January 28, 2023 to Saturday, July 27, 2024**

CENTRAL EAST	**2650 MW**
CENTRAL EAST - VC	**2585 MW**
TOTAL EAST	**6000 MW**
UPNY CONED	**7815 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3150 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHATGUAY-MASSENA__765_7040

Tue 05/30/2023 to Tue 05/30/2023
0600 Continuous 1930
Work scheduled by: NYPA

UPDATED by NYPA 12/13/2022 09:46

	FWD (Import)	REV (Export)
MOSES SOUTH	**1550 MW**	
Impacts Total Transfer Capability	1600 MW	
TTC with All Lines In Service	3150 MW	

CHATGUAY-MASSENA__765_7040 , MASSENA_-MARCY___765_MSU1

Tue 05/30/2023 to Tue 05/30/2023
0600 1930
Work scheduled by:

	FWD (Import)	REV (Export)
MOSES SOUTH	**500 MW**	
Impacts Total Transfer Capability	2650 MW	
TTC with All Lines In Service	3150 MW	

MARCY___765_345_AT1

Tue 05/30/2023 to Tue 05/30/2023
0600 Continuous 1930
Work scheduled by: NYPA

UPDATED by NYPA 12/13/2022 09:46

ARR: 19

	FWD (Import)	REV (Export)
MOSES SOUTH	**1750 MW**	
Impacts Total Transfer Capability	1400 MW	
TTC with All Lines In Service	3150 MW	

MARCY___765_345_AT2

Tue 05/30/2023 to Tue 05/30/2023
0600 Continuous 1930
Work scheduled by: NYPA

UPDATED by NYPA 12/13/2022 16:34

ARR: 19

	FWD (Import)	REV (Export)
MOSES SOUTH	**1700 MW**	
Impacts Total Transfer Capability	1450 MW	
TTC with All Lines In Service	3150 MW	

MASSENA_-MARCY___765_MSU1

Tue 05/30/2023 to Tue 05/30/2023
0600 Continuous 1930
Work scheduled by: NYPA

UPDATED by NYPA 12/13/2022 09:46

	FWD (Import)	REV (Export)
CENTRAL EAST - VC	**1720 MW**	
Impacts Total Transfer Capability	865 MW	
TTC with All Lines In Service	2585 MW	

MASSENA_-MARCY___765_MSU1

Tue 05/30/2023 to Tue 05/30/2023
0600 Continuous 1930
Work scheduled by: NYPA

UPDATED by NYPA 12/13/2022 09:46

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS	**90 MW**	
Impacts Total Transfer Capability	180 MW	
TTC with All Lines In Service	270 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits **Saturday, January 28, 2023 to Saturday, July 27, 2024**

CENTRAL EAST	**2650 MW**
CENTRAL EAST - VC	**2585 MW**
TOTAL EAST	**6000 MW**
UPNY CONED	**7815 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3150 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA_-MARCY___765_MSU1

Tue 05/30/2023 to Tue 05/30/2023
0600 Continuous 1930
Work scheduled by: NYPA

UPDATED by NYPA 12/13/2022 09:46

	FWD (Import)	REV (Export)
SCH - HQ - NY	**475 MW**	**1000 MW**
Impacts Total Transfer Capability	1025 MW	0 MW
TTC with All Lines In Service	1500 MW	1000 MW

MASSENA_-MARCY___765_MSU1

Tue 05/30/2023 to Tue 05/30/2023
0600 Continuous 1930
Work scheduled by: NYPA

UPDATED by NYPA 12/13/2022 09:46

	FWD (Import)	REV (Export)
MOSES SOUTH	**500 MW**	
Impacts Total Transfer Capability	2650 MW	
TTC with All Lines In Service	3150 MW	

MASSENA_-MARCY___765_MSU1 , CHASLAKE-PORTER__230_11

Tue 05/30/2023 to Tue 05/30/2023
0600 1930
Work scheduled by:

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS	**90 MW**	
Impacts Total Transfer Capability	180 MW	
TTC with All Lines In Service	270 MW	

MASSENA_-MARCY___765_MSU1 , STLAWRNC-MOSES___230_L34P

Tue 05/30/2023 to Tue 05/30/2023
0600 1930
Work scheduled by:

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS	**90 MW**	
Impacts Total Transfer Capability	180 MW	
TTC with All Lines In Service	270 MW	

MASSENA_-MARCY___765_MSU1 , STLAWRNC-MOSES___230_L34P , CHASLAKE-PORTER__230_11

Tue 05/30/2023 to Tue 05/30/2023
0600 1930
Work scheduled by:

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS	**90 MW**	
Impacts Total Transfer Capability	180 MW	
TTC with All Lines In Service	270 MW	

MOSES__-MASSENA__230_MMS1 , MOSES__-MASSENA__230_MMS2

Tue 05/30/2023 to Tue 05/30/2023
0600 1930
Work scheduled by:

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS	**90 MW**	
Impacts Total Transfer Capability	180 MW	
TTC with All Lines In Service	270 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits **Saturday, January 28, 2023 to Saturday, July 27, 2024**

CENTRAL EAST	**2650 MW**
CENTRAL EAST - VC	**2585 MW**
TOTAL EAST	**6000 MW**
UPNY CONED	**7815 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3150 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES___-MASSENA__230_MMS1 , MOSES___-MASSENA__230_MMS2

Tue 05/30/2023 to Tue 05/30/2023
0600 1930
Work scheduled by:

	FWD (Import)	REV (Export)
SCH - HQ - NY	**850 MW**	**0 MW**
Impacts Total Transfer Capability	650 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

MOSES___-MASSENA__230_MMS1 , MOSES___-MASSENA__230_MMS2 , CHASLAKE-PORTER___230_11

Tue 05/30/2023 to Tue 05/30/2023
0600 1930
Work scheduled by:

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS	**90 MW**	
Impacts Total Transfer Capability	180 MW	
TTC with All Lines In Service	270 MW	

MOSES___-MASSENA__230_MMS1 , MOSES___-MASSENA__230_MMS2 , STLAWRNC-MOSES____230_L34P

Tue 05/30/2023 to Tue 05/30/2023
0600 1930
Work scheduled by:

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS	**90 MW**	
Impacts Total Transfer Capability	180 MW	
TTC with All Lines In Service	270 MW	

MOSES___-MASSENA__230_MMS1 , MOSES___-MASSENA__230_MMS2 , STLAWRNC-MOSES____230_L34P , CHASLAKE-PORTER___230_11

Tue 05/30/2023 to Tue 05/30/2023
0600 1930
Work scheduled by:

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS	**90 MW**	
Impacts Total Transfer Capability	180 MW	
TTC with All Lines In Service	270 MW	

NIAGARA_-PACKARD__230_62

Mon 06/26/2023 to Fri 06/30/2023
0500 Continuous 1900
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - OH - NY	**1500 MW**	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1900 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits **Saturday, January 28, 2023 to Saturday, July 27, 2024**

CENTRAL EAST	**2650 MW**
CENTRAL EAST - VC	**2585 MW**
TOTAL EAST	**6000 MW**
UPNY CONED	**7815 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3150 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA__345_230_AT4

				FWD (Import)	REV (Export)
Wed 06/28/2023	to	Thu 06/29/2023	SCH - OH - NY		**1150 MW**
0500	Continuous	1900	Impacts Total Transfer Capability		400 MW
Work scheduled by:	NYPA		TTC with All Lines In Service		1550 MW

ADIRNDCK-PORTER___230_12

UPDATED by NYPA 12/14/2022 14:55

				FWD (Import)	REV (Export)
Sun 07/16/2023	to	Sun 07/16/2023	MOSES SOUTH	**2100 MW**	
0700	Continuous	1530	Impacts Total Transfer Capability	1050 MW	
Work scheduled by:	NYPA		TTC with All Lines In Service	3150 MW	

MOSES___-ADIRNDCK_230_MA2

				FWD (Import)	REV (Export)
Sun 07/16/2023	to	Sun 07/16/2023	MOSES SOUTH	**2100 MW**	
0700	Continuous	1530	Impacts Total Transfer Capability	1050 MW	
Work scheduled by:	NYPA		TTC with All Lines In Service	3150 MW	

SCH-IMO_NY_NIAG_CB_3122_W/BB

				FWD (Import)	REV (Export)
Mon 07/17/2023	to	Fri 07/28/2023	SCH - OH - NY	**1800 MW**	**1300 MW**
0500	Continuous	2100	Impacts Total Transfer Capability	100 MW	250 MW
Work scheduled by:	NYPA		TTC with All Lines In Service	1900 MW	1550 MW

ADIRNDCK-CHASLAKE_230_13

				FWD (Import)	REV (Export)
Tue 07/18/2023	to	Fri 09/15/2023	MOSES SOUTH	**2100 MW**	
0630	Continuous	1600	Impacts Total Transfer Capability	1050 MW	
Work scheduled by:	NGrid		TTC with All Lines In Service	3150 MW	

HURLYAVE-ROSETON__345_303

				FWD (Import)	REV (Export)
Mon 07/31/2023	to	Fri 08/25/2023	UPNY CONED	**4100 MW**	
0800	Continuous	1600	Impacts Total Transfer Capability	3715 MW	
Work scheduled by:	CHGE		TTC with All Lines In Service	7815 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits **Saturday, January 28, 2023 to Saturday, July 27, 2024**

CENTRAL EAST	**2650 MW**
CENTRAL EAST - VC	**2585 MW**
TOTAL EAST	**6000 MW**
UPNY CONED	**7815 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3150 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA__345_230_AT4

Mon 08/21/2023 to Fri 08/25/2023
0500 Continuous 2100
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - OH - NY		**1150 MW**
Impacts Total Transfer Capability		400 MW
TTC with All Lines In Service		1550 MW

CLAY___-EDIC____345_1-16

Mon 09/11/2023 to Fri 09/15/2023
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
OSWEGO EXPORT	**4850 MW**	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	5250 MW	

FRASER__-GILBOA___345_GF5-35

Mon 09/11/2023 to Sun 09/17/2023
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
CENTRAL EAST - VC	**2450 MW**	
Impacts Total Transfer Capability	135 MW	
TTC with All Lines In Service	2585 MW	

SPRNBRK__345KV_RNS5

Fri 09/15/2023 to Mon 10/23/2023
0001 Continuous 0200
Work scheduled by: ConEd

UPDATED by ConEd 08/10/2022 13:51

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	**3200 MW**	
Impacts Total Transfer Capability	1400 MW	
TTC with All Lines In Service	4600 MW	

SPRNBRK_-W49TH_ST_345_M51

Fri 09/15/2023 to Mon 10/23/2023
0001 Continuous 0200
Work scheduled by: ConEd

UPDATED by ConEd 08/10/2022 13:51

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	**3200 MW**	
Impacts Total Transfer Capability	1400 MW	
TTC with All Lines In Service	4600 MW	

CHASLAKE-PORTER___230_11

Sat 09/16/2023 to Sun 10/15/2023
0630 Continuous 1730
Work scheduled by: NGrid

UPDATED by NGrid 01/27/2023 13:52

	FWD (Import)	REV (Export)
MOSES SOUTH	**2100 MW**	
Impacts Total Transfer Capability	1050 MW	
TTC with All Lines In Service	3150 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits **Saturday, January 28, 2023 to Saturday, July 27, 2024**

CENTRAL EAST	**2650 MW**
CENTRAL EAST - VC	**2585 MW**
TOTAL EAST	**6000 MW**
UPNY CONED	**7815 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3150 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CLAY___-EDIC____345_2-15

				FWD (Import)	REV (Export)
Mon 09/18/2023	to	Fri 09/22/2023	OSWEGO EXPORT	**4850 MW**	
0700	Continuous	1530	Impacts Total Transfer Capability	400 MW	
Work scheduled by:	NYPA		TTC with All Lines In Service	5250 MW	

MARCY___-EDIC____345_UE1-7

				FWD (Import)	REV (Export)
Sat 09/23/2023	to	Sun 09/24/2023	OSWEGO EXPORT	**5250 MW**	
0500	Continuous	1900	Impacts Total Transfer Capability	0 MW	
Work scheduled by:	NYPA		TTC with All Lines In Service	5250 MW	

ARR: 19,16

NIAGARA_-DYSINGER_345_ND2

				FWD (Import)	REV (Export)
Mon 09/25/2023	to	Fri 09/29/2023	DYSINGER EAST	**2700 MW**	
0500	Continuous	2000	Impacts Total Transfer Capability	500 MW	
Work scheduled by:	NYPA		TTC with All Lines In Service	3200 MW	

MARCY___345KV_CSC

				FWD (Import)	REV (Export)
Mon 09/25/2023	to	Sat 10/07/2023	CENTRAL EAST - VC	**2535 MW**	
0700	Continuous	1530	Impacts Total Transfer Capability	50 MW	
Work scheduled by:	NYPA		TTC with All Lines In Service	2585 MW	

SHOR_NPX-SHOREHAM_138_CSC

				FWD (Import)	REV (Export)
Mon 10/02/2023	to	Fri 10/06/2023	SCH - NPX_CSC	**0 MW**	**0 MW**
0600	Continuous	1800	Impacts Total Transfer Capability	330 MW	330 MW
Work scheduled by:	LI		TTC with All Lines In Service	330 MW	330 MW

ROSETON_-ROCKTVRN_345_311

				FWD (Import)	REV (Export)
Mon 10/02/2023	to	Fri 11/03/2023	UPNY CONED	**4400 MW**	
0800	Continuous	1600	Impacts Total Transfer Capability	3415 MW	
Work scheduled by:	CHGE		TTC with All Lines In Service	7815 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits **Saturday, January 28, 2023 to Saturday, July 27, 2024**

CENTRAL EAST	**2650 MW**
CENTRAL EAST - VC	**2585 MW**
TOTAL EAST	**6000 MW**
UPNY CONED	**7815 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3150 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEPTUNE_-DUFFYAVE_345_NEPTUNE

				FWD (Import)	REV (Export)
Mon 10/09/2023	to	Fri 10/13/2023	SCH - PJM_NEPTUNE	**0 MW**	
0600	Continuous	1600	Impacts Total Transfer Capability	660 MW	
Work scheduled by: LI			TTC with All Lines In Service	660 MW	

NEWBRDGE_345_138_BK_1

				FWD (Import)	REV (Export)
Mon 10/09/2023	to	Fri 10/13/2023	SCH - PJM_NEPTUNE	**375 MW**	
0600	Continuous	1600	Impacts Total Transfer Capability	285 MW	
Work scheduled by: LI			TTC with All Lines In Service	660 MW	

NEWBRDGE_345_138_BK_2

				FWD (Import)	REV (Export)
Mon 10/09/2023	to	Fri 10/13/2023	SCH - PJM_NEPTUNE	**375 MW**	
0600	Continuous	1600	Impacts Total Transfer Capability	285 MW	
Work scheduled by: LI			TTC with All Lines In Service	660 MW	

NEWBRDGE-DUFFYAVE_345_501

				FWD (Import)	REV (Export)
Mon 10/09/2023	to	Fri 10/13/2023	SCH - PJM_NEPTUNE	**0 MW**	
0600	Continuous	1600	Impacts Total Transfer Capability	660 MW	
Work scheduled by: LI			TTC with All Lines In Service	660 MW	

GILBOA__-N.SCTLND_345_GNS-1

				FWD (Import)	REV (Export)
Mon 10/09/2023	to	Fri 10/13/2023	CENTRAL EAST - VC	**2300 MW**	
0700	Continuous	1530	Impacts Total Transfer Capability	285 MW	
Work scheduled by: NYPA			TTC with All Lines In Service	2585 MW	

NIAGARA_-PACKARD__230_61

				FWD (Import)	REV (Export)
Fri 10/13/2023	to	Fri 10/13/2023	SCH - OH - NY		**1350 MW**
0500	Continuous	1900	Impacts Total Transfer Capability		200 MW
Work scheduled by: NYPA			TTC with All Lines In Service		1550 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits **Saturday, January 28, 2023 to Saturday, July 27, 2024**

CENTRAL EAST	**2650 MW**
CENTRAL EAST - VC	**2585 MW**
TOTAL EAST	**6000 MW**
UPNY CONED	**7815 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3150 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ADIRNDCK-CHASLAKE_230_13

Mon 10/16/2023 to Tue 11/14/2023
0630 Continuous 1730
Work scheduled by: NGrid

UPDATED by NGrid 11/07/2022 15:17

	FWD (Import)	REV (Export)
MOSES SOUTH	**2100 MW**	
Impacts Total Transfer Capability	1050 MW	
TTC with All Lines In Service	3150 MW	

HURLYAVE-ROSETON__345_303

Mon 11/13/2023 to Fri 12/22/2023
0800 Continuous 1600
Work scheduled by: CHGE

	FWD (Import)	REV (Export)
UPNY CONED	**4100 MW**	
Impacts Total Transfer Capability	3715 MW	
TTC with All Lines In Service	7815 MW	

CHATGUAY-MASSENA__765_7040

Wed 11/15/2023 to Mon 11/27/2023
0700 Continuous 1730
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - HQ - NY	**0 MW**	**0 MW**
Impacts Total Transfer Capability	1500 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

CHATGUAY-MASSENA__765_7040

Wed 11/15/2023 to Mon 11/27/2023
0700 Continuous 1730
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
MOSES SOUTH	**1550 MW**	
Impacts Total Transfer Capability	1600 MW	
TTC with All Lines In Service	3150 MW	

CHATGUAY-MASSENA__765_7040 , MASSENA_-MARCY___765_MSU1

Wed 11/15/2023 to Mon 11/27/2023
0700 1730
Work scheduled by:

	FWD (Import)	REV (Export)
MOSES SOUTH	**500 MW**	
Impacts Total Transfer Capability	2650 MW	
TTC with All Lines In Service	3150 MW	

MASSENA_-MARCY___765_MSU1

Wed 11/15/2023 to Mon 11/27/2023
0700 Continuous 1730
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
CENTRAL EAST - VC	**1720 MW**	
Impacts Total Transfer Capability	865 MW	
TTC with All Lines In Service	2585 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits **Saturday, January 28, 2023 to Saturday, July 27, 2024**

CENTRAL EAST	**2650 MW**
CENTRAL EAST - VC	**2585 MW**
TOTAL EAST	**6000 MW**
UPNY CONED	**7815 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3150 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA_-MARCY___765_MSU1

Wed 11/15/2023 to Mon 11/27/2023
0700 Continuous 1730
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS	**90 MW**	
Impacts Total Transfer Capability	189 MW	
TTC with All Lines In Service	279 MW	

MASSENA_-MARCY___765_MSU1

Wed 11/15/2023 to Mon 11/27/2023
0700 Continuous 1730
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - HQ - NY	**475 MW**	**1000 MW**
Impacts Total Transfer Capability	1025 MW	0 MW
TTC with All Lines In Service	1500 MW	1000 MW

MASSENA_-MARCY___765_MSU1

Wed 11/15/2023 to Mon 11/27/2023
0700 Continuous 1730
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
MOSES SOUTH	**500 MW**	
Impacts Total Transfer Capability	2650 MW	
TTC with All Lines In Service	3150 MW	

MOSES__-MASSENA__230_MMS1 , MOSES__-MASSENA__230_MMS2

Wed 11/15/2023 to Mon 11/20/2023
0700 1530
Work scheduled by:

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS	**90 MW**	
Impacts Total Transfer Capability	189 MW	
TTC with All Lines In Service	279 MW	

MOSES__-MASSENA__230_MMS1 , MOSES__-MASSENA__230_MMS2

Wed 11/15/2023 to Mon 11/20/2023
0700 1530
Work scheduled by:

	FWD (Import)	REV (Export)
SCH - HQ - NY	**850 MW**	**0 MW**
Impacts Total Transfer Capability	650 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

NIAGARA__345_230_AT4

Mon 11/27/2023 to Fri 12/01/2023
0500 Continuous 1900
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - OH - NY		**1750 MW**
Impacts Total Transfer Capability		250 MW
TTC with All Lines In Service		2000 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits **Saturday, January 28, 2023 to Saturday, July 27, 2024**

CENTRAL EAST	**2650 MW**
CENTRAL EAST - VC	**2585 MW**
TOTAL EAST	**6000 MW**
UPNY CONED	**7815 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3150 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HOMR_NYW-PIERC_NY_345_48

Fri 12/08/2023 to Fri 12/15/2023
0800 Continuous 1600
Work scheduled by: PJM

UPDATED by PJM 07/28/2022 14:08

	FWD (Import)	REV (Export)
SCH - PJ - NY		
Impacts Total Transfer Capability		
TTC with All Lines In Service		

HOMRC_NY-MAINS_NY_345_47

Fri 12/08/2023 to Fri 12/15/2023
0800 Continuous 1600
Work scheduled by: PJM

UPDATED by PJM 07/28/2022 14:08

	FWD (Import)	REV (Export)
SCH - PJ - NY		
Impacts Total Transfer Capability		
TTC with All Lines In Service		

LONG_MTN-CRICKVLY_345_398

Tue 12/12/2023 to Thu 12/21/2023
0001 Continuous 2200
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - NPX_1385	**100 MW**	**100 MW**
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

LONG_MTN-CRICKVLY_345_398

Tue 12/12/2023 to Thu 12/21/2023
0001 Continuous 2200
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - NE - NY	**700 MW**	**1300 MW**
Impacts Total Transfer Capability	900 MW	500 MW
TTC with All Lines In Service	1600 MW	1800 MW

W49TH_ST_345KV_6

Mon 01/08/2024 to Mon 02/19/2024
0001 Continuous 0201
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - PJM_HTP	**310 MW**	
Impacts Total Transfer Capability	350 MW	
TTC with All Lines In Service	660 MW	

W49TH_ST-E13THSTA_345_M55

Mon 01/08/2024 to Mon 02/19/2024
0001 Continuous 0201
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	**3800 MW**	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits **Saturday, January 28, 2023 to Saturday, July 27, 2024**

CENTRAL EAST	**2650 MW**
CENTRAL EAST - VC	**2585 MW**
TOTAL EAST	**6000 MW**
UPNY CONED	**7815 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3150 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_8

				FWD (Import)	REV (Export)
Sat 02/03/2024	to	Mon 02/19/2024	SCH - PJM_HTP	**310 MW**	
0001	Continuous	0201	Impacts Total Transfer Capability	350 MW	
Work scheduled by:	ConEd		TTC with All Lines In Service	660 MW	

SHOR_NPX-SHOREHAM_138_CSC

				FWD (Import)	REV (Export)
Mon 05/06/2024	to	Fri 05/10/2024	SCH - NPX_CSC	**0 MW**	**0 MW**
0600	Continuous	1800	Impacts Total Transfer Capability	330 MW	330 MW
Work scheduled by:	LI		TTC with All Lines In Service	330 MW	330 MW