

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Wednesday, April 19, 2023 to Friday, October 18, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONP_-FARRAGUT_345_B3402

Mon 01/15/2018 to Sat 09/30/2023
0001 Continuous 2359
Work scheduled by: ConEd

EXT FORCED by ConEd 08/06/2022 16:26

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Sat 09/30/2023
0001 Continuous 2359
Work scheduled by: ConEd

EXT FORCED by ConEd 08/06/2022 16:26

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

MARION_-FARRAGUT_345_C3403 , HUDSONP_-FARRAGUT_345_B3402

Mon 01/15/2018 to Sat 09/30/2023
0001 2359
Work scheduled by:

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
2350 MW **2050 MW**
100 MW 100 MW
2450 MW 2150 MW

EGRDNCTY_345_138_AT1

Sat 10/01/2022 to Wed 05/31/2023
0001 Continuous 2359
Work scheduled by: LI

UPDATED by ConEd 10/01/2022 09:02

CONED - LIPA
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
1250 MW
250 MW
1500 MW

EGRDNCTY_345_138_AT2

Sat 10/01/2022 to Wed 05/31/2023
0001 Continuous 2359
Work scheduled by: LI

UPDATED by ConEd 10/01/2022 09:02

CONED - LIPA
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
1250 MW
250 MW
1500 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Wednesday, April 19, 2023 to Friday, October 18, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK_EGRDNCTR_345_Y49

Sat 10/01/2022 to Wed 05/31/2023
0001 Continuous 2359

UPDATED by ConEd 10/01/2022 09:02

CONED - LIPA

FWD (Import)

REV (Export)

775 MW

Impacts Total Transfer Capability

725 MW

TTC with All Lines In Service

1500 MW

Work scheduled by: LI

STLAWRNC-MOSES_230_L34P

Mon 10/03/2022 to Mon 11/06/2023
1800 Continuous 0800

UPDATED by IESO 03/07/2023 10:12

SCH - OH - NY

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: IESO

SCH-IMO-NYISO_LIMIT_1750

Fri 01/20/2023 to Sun 04/30/2023
1601 Continuous 2359

UPDATED by IESO 01/18/2023 16:31

SCH - OH - NY

FWD (Import)

REV (Export)

2050 MW

Impacts Total Transfer Capability

350 MW

TTC with All Lines In Service

2400 MW

Work scheduled by: IESO

SCH-NYISO-IMO_LIMIT_1600

Sat 01/21/2023 to Sun 04/30/2023
1800 Continuous 2359

UPDATED by IESO 01/18/2023 16:31

SCH - OH - NY

FWD (Import)

REV (Export)

1900 MW

Impacts Total Transfer Capability

100 MW

TTC with All Lines In Service

2000 MW

Work scheduled by: IESO

PRINCTWN-N.SCTLND_345_361

Tue 02/14/2023 to Tue 05/02/2023
1128 Continuous 1200

UPDATED by LS 02/21/2023 14:36

CENTRAL EAST - VC

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: LS

PRINCTWN-N.SCTLND_345_362

Tue 02/14/2023 to Tue 05/02/2023
1129 Continuous 1600

UPDATED by LS 02/21/2023 14:36

CENTRAL EAST - VC

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: LS

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Wednesday, April 19, 2023 to Friday, October 18, 2024

| | |
|-------------------|---------|
| CENTRAL EAST | 2650 MW |
| CENTRAL EAST - VC | 2720 MW |
| TOTAL EAST | 6000 MW |
| UPNY CONED | 7815 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3150 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHASLAKE-PORTER__230_11

Tue 02/21/2023 to Sat 07/15/2023
0630 Continuous 1730

UPDATED by NGrid 02/01/2023 11:03

MOSES SOUTH

FWD (Import)

REV (Export)

2300 MW

Impacts Total Transfer Capability

850 MW

TTC with All Lines In Service

3150 MW

N.SCTLND-KNICRBKR_345_2

Mon 02/27/2023 to Fri 04/28/2023
0700 Continuous 0900

UPDATED by NGrid 04/10/2023 15:47

SCH - NPX_1385

FWD (Import)

REV (Export)

100 MW

100 MW

Impacts Total Transfer Capability

100 MW

100 MW

TTC with All Lines In Service

200 MW

200 MW

N.SCTLND-KNICRBKR_345_2

Mon 02/27/2023 to Fri 04/28/2023
0700 Continuous 0900

UPDATED by NGrid 04/10/2023 15:47

SCH - NE - NY

FWD (Import)

REV (Export)

900 MW

Impacts Total Transfer Capability

700 MW

TTC with All Lines In Service

1600 MW

MOSES__-ADIRNDCK_230_MA1

Sun 03/05/2023 to Fri 05/26/2023
2000 Continuous 1930

MOSES SOUTH

FWD (Import)

REV (Export)

2300 MW

Impacts Total Transfer Capability

850 MW

TTC with All Lines In Service

3150 MW

GORDONRD-PRINCTWN_345_371

Mon 03/20/2023 to Wed 04/19/2023
0700 Continuous 1000

UPDATED by NYISO 02/21/2023 14:40

CENTRAL EAST - VC

FWD (Import)

REV (Export)

2045 MW

Impacts Total Transfer Capability

540 MW

TTC with All Lines In Service

2585 MW

PRINCTWN-N.SCTLND_345_55

Mon 03/20/2023 to Wed 04/19/2023
0700 Continuous 1000

UPDATED by NYISO 02/21/2023 14:40

CENTRAL EAST - VC

FWD (Import)

REV (Export)

2045 MW

Impacts Total Transfer Capability

540 MW

TTC with All Lines In Service

2585 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Wednesday, April 19, 2023 to Friday, October 18, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NE-NYISO_LIMIT_500

Fri 03/24/2023 to Fri 04/28/2023

0001 Continuous 0900

Work scheduled by: NGrid

UPDATED by NGrid 04/10/2023 15:47

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

700 MW

900 MW

1600 MW

MOTTHAVN-RAINEY__345_Q12

Sat 04/08/2023 to Tue 04/25/2023

0344 Continuous 0200

Work scheduled by: ConEd

UPDATED by ConEd 04/07/2023 17:18

SPR/DUN-SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

3800 MW

800 MW

4600 MW

FRASANNX-COOPERS_345_UCC2-41

Wed 04/12/2023 to Fri 05/05/2023

0600 Continuous 1730

Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

2275 MW

310 MW

2585 MW

MARCY__FRASANNX_345_UCC2-41

Wed 04/12/2023 to Fri 05/05/2023

0600 Continuous 1730

Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

2275 MW

310 MW

2585 MW

SCH-NPX_1385-NYISO_LIMIT_100

Thu 04/13/2023 to Fri 04/28/2023

2030 Continuous 2000

Work scheduled by: ISONE

SCH - NPX_1385

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

100 MW

100 MW

200 MW

LEEDS__VNWAGNER_345_92

Sun 04/16/2023 to Sun 04/30/2023

0700 Continuous 2200

Work scheduled by: NGrid

UPDATED by ConEd 03/10/2023 10:36

UPNY CONED

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

3800 MW

4015 MW

7815 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Wednesday, April 19, 2023 to Friday, October 18, 2024

| | |
|-------------------|---------|
| CENTRAL EAST | 2650 MW |
| CENTRAL EAST - VC | 2720 MW |
| TOTAL EAST | 6000 MW |
| UPNY CONED | 7815 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3150 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY_345KV_RNS5

Sun 04/16/2023 to Sun 04/30/2023
0700 Continuous 2200

UPDATED by ConEd 03/10/2023 10:36

FWD (Import) REV (Export)

Work scheduled by: NGrid

UPNY CONED **3800 MW**
Impacts Total Transfer Capability 4015 MW
TTC with All Lines In Service 7815 MW

DYSINGER-STA_255_345_DH2

Mon 04/17/2023 to Fri 04/21/2023
0500 Continuous 2000

FWD (Import) REV (Export)

Work scheduled by: NYPA

DYSINGER EAST **2850 MW**
Impacts Total Transfer Capability 350 MW
TTC with All Lines In Service 3200 MW

CLAY__-EDIC__345_2-15

Mon 04/17/2023 to Fri 04/28/2023
0600 Continuous 1800

UPDATED by NGrid 03/20/2023 14:42

FWD (Import) REV (Export)

Work scheduled by: NGrid

OSWEGO EXPORT **4850 MW**
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 5250 MW

PLSNTVLE-DUNWODIE_345_W89

Tue 04/18/2023 to Sat 04/29/2023
0143 Continuous 0200

FWD (Import) REV (Export)

Work scheduled by: ConEd

UPNY CONED **4000 MW**
Impacts Total Transfer Capability 3815 MW
TTC with All Lines In Service 7815 MW

BECK__-NIAGARA_230_PA27

Tue 04/18/2023 to Fri 05/05/2023
0400 Continuous 1600

FWD (Import) REV (Export)

Work scheduled by: IESO

SCH - OH - NY **2100 MW**
Impacts Total Transfer Capability 300 MW
TTC with All Lines In Service 2400 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Wednesday, April 19, 2023 to Friday, October 18, 2024

| | |
|-------------------|---------|
| CENTRAL EAST | 2650 MW |
| CENTRAL EAST - VC | 2720 MW |
| TOTAL EAST | 6000 MW |
| UPNY CONED | 7815 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3150 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-IMO-NYISO_LIMIT_1200

Tue 04/18/2023 to Fri 05/05/2023
0400 Continuous 1600
Work scheduled by: IESO

| | | |
|-----------------------------------|----------------|--------------|
| SCH - OH - NY | FWD (Import) | REV (Export) |
| | 1500 MW | |
| Impacts Total Transfer Capability | 900 MW | |
| TTC with All Lines In Service | 2400 MW | |

SCH-NYISO-IMO_LIMIT_1400

Tue 04/18/2023 to Fri 05/05/2023
0400 Continuous 1600
Work scheduled by: IESO

| | | |
|-----------------------------------|--------------|----------------|
| SCH - OH - NY | FWD (Import) | REV (Export) |
| | | 1700 MW |
| Impacts Total Transfer Capability | | 300 MW |
| TTC with All Lines In Service | | 2000 MW |

SCH-NYISO-NE_LIMIT_600

Tue 04/18/2023 to Wed 04/19/2023
2300 Continuous 0659
Work scheduled by: ISONE

| | | |
|-----------------------------------|--------------|---------------|
| SCH - NE - NY | FWD (Import) | REV (Export) |
| | | 800 MW |
| Impacts Total Transfer Capability | | 1000 MW |
| TTC with All Lines In Service | | 1800 MW |

NEPTUNE_DUFFYAVE_345_NEPTUNE

Wed 04/19/2023 to Wed 04/19/2023
0800 Continuous 1200
Work scheduled by: LI

| | | |
|-----------------------------------|--------------|--------------|
| SCH - PJM_NEPTUNE | FWD (Import) | REV (Export) |
| | 0 MW | |
| Impacts Total Transfer Capability | 660 MW | |
| TTC with All Lines In Service | 660 MW | |

NEWBRDGE_345_138_BK_1

Wed 04/19/2023 to Wed 04/19/2023
0800 Continuous 1200
Work scheduled by: LI

| | | |
|-----------------------------------|---------------|--------------|
| SCH - PJM_NEPTUNE | FWD (Import) | REV (Export) |
| | 375 MW | |
| Impacts Total Transfer Capability | 285 MW | |
| TTC with All Lines In Service | 660 MW | |

NEWBRDGE_345_138_BK_2

Wed 04/19/2023 to Wed 04/19/2023
0800 Continuous 1200
Work scheduled by: LI

| | | |
|-----------------------------------|---------------|--------------|
| SCH - PJM_NEPTUNE | FWD (Import) | REV (Export) |
| | 375 MW | |
| Impacts Total Transfer Capability | 285 MW | |
| TTC with All Lines In Service | 660 MW | |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Wednesday, April 19, 2023 to Friday, October 18, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEWBRDGE-DUFFYAVE_345_501

Wed 04/19/2023 to Wed 04/19/2023
0800 Continuous 1200

Work scheduled by: LI

SCH - PJM_NEPTUNE

FWD (Import)

REV (Export)

0 MW

Impacts Total Transfer Capability

660 MW

TTC with All Lines In Service

660 MW

KNICRBKR-ALPS___345_6

Wed 04/19/2023 to Fri 04/28/2023
1630 Continuous 0900

Work scheduled by: NGrid

UPDATED by NGrid 04/10/2023 15:47

SCH - NE - NY

FWD (Import)

REV (Export)

900 MW

Impacts Total Transfer Capability

700 MW

TTC with All Lines In Service

1600 MW

KNICRBKR-ALPS___345_6

Wed 04/19/2023 to Fri 04/28/2023
1630 Continuous 0900

Work scheduled by: NGrid

UPDATED by NGrid 04/10/2023 15:47

SCH - NPX_1385

FWD (Import)

REV (Export)

100 MW

100 MW

Impacts Total Transfer Capability

100 MW

100 MW

TTC with All Lines In Service

200 MW

200 MW

VNWAGNER-PLSNTVLY_345_Y59

Wed 04/19/2023 to Sun 04/30/2023
1636 Continuous 2200

Work scheduled by: NYISO

UPNY CONED

FWD (Import)

REV (Export)

3800 MW

Impacts Total Transfer Capability

4015 MW

TTC with All Lines In Service

7815 MW

NINEMILE-CLAY___345_8

Wed 04/19/2023 to Wed 04/19/2023
1700 Continuous 1900

Work scheduled by: NGrid

UPDATED by NGrid 04/16/2023 07:41

OSWEGO EXPORT

FWD (Import)

REV (Export)

5150 MW

Impacts Total Transfer Capability

100 MW

TTC with All Lines In Service

5250 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Wednesday, April 19, 2023 to Friday, October 18, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NINEMILE-CLAY__345_8

Wed 04/19/2023 to Wed 04/19/2023
2300 Continuous 2359

UPDATED by NGrid 04/16/2023 07:41

FWD (Import) REV (Export)

OSWEGO EXPORT **5150 MW**
Impacts Total Transfer Capability 100 MW
TTC with All Lines In Service 5250 MW

Work scheduled by: NGrid

SCH-NYISO-NE_LIMIT_600

Wed 04/19/2023 to Thu 04/20/2023
2300 Continuous 0659

FWD (Import) REV (Export)

SCH - NE - NY **800 MW**
Impacts Total Transfer Capability 1000 MW
TTC with All Lines In Service 1800 MW

Work scheduled by: ISONE

ADIRNDCK-PORTER__230_12

Thu 04/20/2023 to Tue 04/25/2023
1700 Continuous 0700

UPDATED by NGrid 04/11/2023 10:11

FWD (Import) REV (Export)

MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

Work scheduled by: LS

ADIRNDCK-PORTER__230_12 , CHASLAKE-PORTER__230_11

Thu 04/20/2023 to Tue 04/25/2023
1700 0700

FWD (Import) REV (Export)

SCH - HQ_CEDARS **140 MW**
Impacts Total Transfer Capability 139 MW
TTC with All Lines In Service 279 MW

Work scheduled by:

ADIRNDCK-PORTER__230_12 , CHASLAKE-PORTER__230_11

Thu 04/20/2023 to Tue 04/25/2023
1700 0700

FWD (Import) REV (Export)

MOSES SOUTH **500 MW**
Impacts Total Transfer Capability 2650 MW
TTC with All Lines In Service 3150 MW

Work scheduled by:

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Wednesday, April 19, 2023 to Friday, October 18, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ADIRNDCK-PORTER__230_12 , STLAWRNC-MOSES__230_L34P ,
CHASLAKE-PORTER__230_11

Thu 04/20/2023 to Tue 04/25/2023
1700 0700

Work scheduled by:

SCH - HQ_CEDARS

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

140 MW

139 MW

279 MW

REV (Export)

SCH-NYISO-NE_LIMIT_600

Thu 04/20/2023 to Fri 04/21/2023
2300 Continuous 0659

Work scheduled by: ISONE

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

800 MW

1000 MW

1800 MW

SCH-NYISO-NE_LIMIT_600

Fri 04/21/2023 to Sat 04/22/2023
2300 Continuous 0659

Work scheduled by: ISONE

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

800 MW

1000 MW

1800 MW

SCH-NYISO-NE_LIMIT_600

Sat 04/22/2023 to Sun 04/23/2023
2300 Continuous 0659

Work scheduled by: ISONE

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

800 MW

1000 MW

1800 MW

CHAT_DC_GC1

Sun 04/23/2023 to Sun 04/23/2023
0001 Continuous 0200

Work scheduled by: HQ

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

2850 MW

300 MW

3150 MW

CHAT_DC_GC1

Sun 04/23/2023 to Sun 04/23/2023
0001 Continuous 0200

Work scheduled by: HQ

SCH - HQ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

500 MW

500 MW

1000 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Wednesday, April 19, 2023 to Friday, October 18, 2024

| | |
|-------------------|---------|
| CENTRAL EAST | 2650 MW |
| CENTRAL EAST - VC | 2720 MW |
| TOTAL EAST | 6000 MW |
| UPNY CONED | 7815 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3150 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHAT_DC_GC1 , CHAT_DC_GC2

Sun 04/23/2023 to Sun 04/23/2023
0001 0200

Work scheduled by:

MOSES SOUTH

FWD (Import)

REV (Export)

2550 MW

Impacts Total Transfer Capability

600 MW

TTC with All Lines In Service

3150 MW

CHAT_DC_GC1 , CHAT_DC_GC2

Sun 04/23/2023 to Sun 04/23/2023
0001 0200

Work scheduled by:

SCH - HQ - NY

FWD (Import)

REV (Export)

1370 MW

0 MW

Impacts Total Transfer Capability

130 MW

1000 MW

TTC with All Lines In Service

1500 MW

1000 MW

CHAT_DC_GC2

Sun 04/23/2023 to Sun 04/23/2023
0001 Continuous 0200

Work scheduled by: HQ

MOSES SOUTH

FWD (Import)

REV (Export)

2850 MW

Impacts Total Transfer Capability

300 MW

TTC with All Lines In Service

3150 MW

CHAT_DC_GC2

Sun 04/23/2023 to Sun 04/23/2023
0001 Continuous 0200

Work scheduled by: HQ

SCH - HQ - NY

FWD (Import)

REV (Export)

500 MW

Impacts Total Transfer Capability

500 MW

TTC with All Lines In Service

1000 MW

DUNWODIE_345KV_3

Sun 04/23/2023 to Sun 04/23/2023
0001 Continuous 0030

Work scheduled by: ConEd

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

3800 MW

Impacts Total Transfer Capability

800 MW

TTC with All Lines In Service

4600 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Wednesday, April 19, 2023 to Friday, October 18, 2024

| | |
|-------------------|---------|
| CENTRAL EAST | 2650 MW |
| CENTRAL EAST - VC | 2720 MW |
| TOTAL EAST | 6000 MW |
| UPNY CONED | 7815 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3150 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_4

Sun 04/23/2023 to Sun 04/23/2023
0001 Continuous 0030
Work scheduled by: ConEd

| | | |
|-----------------------------------|----------------|--------------|
| | FWD (Import) | REV (Export) |
| SPR/DUN-SOUTH | 3800 MW | |
| Impacts Total Transfer Capability | 800 MW | |
| TTC with All Lines In Service | 4600 MW | |

EFISHKIL-WOOD_ST_345_F38

Sun 04/23/2023 to Sat 04/29/2023
0001 Continuous 0200
Work scheduled by: ConEd

| | | |
|-----------------------------------|----------------|--------------|
| | FWD (Import) | REV (Export) |
| UPNY CONED | 4000 MW | |
| Impacts Total Transfer Capability | 3815 MW | |
| TTC with All Lines In Service | 7815 MW | |

SCH-HQ-NYISO_LIMIT_1150

Sun 04/23/2023 to Sun 04/23/2023
0001 Continuous 0200
Work scheduled by: HQ

| | | |
|-----------------------------------|----------------|--------------|
| | FWD (Import) | REV (Export) |
| SCH - HQ - NY | 1150 MW | |
| Impacts Total Transfer Capability | 350 MW | |
| TTC with All Lines In Service | 1500 MW | |

WOOD_ST_-PLSNTVLE_345_Y86

Sun 04/23/2023 to Sat 04/29/2023
0001 Continuous 0200
Work scheduled by: ConEd

| | | |
|-----------------------------------|----------------|--------------|
| | FWD (Import) | REV (Export) |
| UPNY CONED | 7210 MW | |
| Impacts Total Transfer Capability | 605 MW | |
| TTC with All Lines In Service | 7815 MW | |

SCH-NYISO-NE_LIMIT_600

Sun 04/23/2023 to Mon 04/24/2023
2300 Continuous 0659
Work scheduled by: ISONE

| | | |
|-----------------------------------|---------------|--------------|
| | FWD (Import) | REV (Export) |
| SCH - NE - NY | 800 MW | |
| Impacts Total Transfer Capability | 1000 MW | |
| TTC with All Lines In Service | 1800 MW | |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Wednesday, April 19, 2023 to Friday, October 18, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BUCHAN_S-MILLWOOD_345_W98

Mon 04/24/2023 to Wed 04/26/2023
0001 Continuous 0200

Work scheduled by: ConEd

UPNY CONED FWD (Import) REV (Export)
Impacts Total Transfer Capability **7680 MW** 135 MW
TTC with All Lines In Service 7815 MW

MILLWOOD_345KV_18

Mon 04/24/2023 to Wed 04/26/2023
0001 Continuous 0200

Work scheduled by: ConEd

UPNY CONED FWD (Import) REV (Export)
Impacts Total Transfer Capability **4350 MW** 3465 MW
TTC with All Lines In Service 7815 MW

DUNWODIE_345KV_3

Mon 04/24/2023 to Mon 04/24/2023
0130 Continuous 0200

Work scheduled by: ConEd

UPDATED by ConEd 04/11/2023 10:17

SPR/DUN-SOUTH FWD (Import) REV (Export)
Impacts Total Transfer Capability **3800 MW** 800 MW
TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_4

Mon 04/24/2023 to Mon 04/24/2023
0130 Continuous 0200

Work scheduled by: ConEd

UPDATED by ConEd 04/11/2023 10:17

SPR/DUN-SOUTH FWD (Import) REV (Export)
Impacts Total Transfer Capability **3800 MW** 800 MW
TTC with All Lines In Service 4600 MW

PANNELL-CLAY_345_1

Mon 04/24/2023 to Fri 04/28/2023
0700 Continuous 1530

Work scheduled by: NYPA

WEST CENTRAL FWD (Import) REV (Export)
Impacts Total Transfer Capability **1300 MW** 950 MW
TTC with All Lines In Service 2250 MW

SCH-NYISO-NE_LIMIT_600

Mon 04/24/2023 to Tue 04/25/2023
2300 Continuous 0659

Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)
Impacts Total Transfer Capability **800 MW** 1000 MW
TTC with All Lines In Service 1800 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Wednesday, April 19, 2023 to Friday, October 18, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_ROBNSNRD_230_64

Tue 04/25/2023 to Tue 04/25/2023
0500 Continuous 1700
Work scheduled by: NYPA

FWD (Import) REV (Export)
SCH - OH - NY **1900 MW**
Impacts Total Transfer Capability 100 MW
TTC with All Lines In Service 2000 MW

SCH-NYISO-NE_LIMIT_600

Tue 04/25/2023 to Wed 04/26/2023
2300 Continuous 0659
Work scheduled by: ISONE

FWD (Import) REV (Export)
SCH - NE - NY **800 MW**
Impacts Total Transfer Capability 1000 MW
TTC with All Lines In Service 1800 MW

S.RIPLEY-DUNKIRK_230_68

Wed 04/26/2023 to Wed 05/10/2023
0700 Continuous 1630
Work scheduled by: NGrid

UPDATED by NGrid 03/21/2023 12:58

FWD (Import) REV (Export)
SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

SCH-NYISO-NE_LIMIT_600

Wed 04/26/2023 to Thu 04/27/2023
2300 Continuous 0659
Work scheduled by: ISONE

FWD (Import) REV (Export)
SCH - NE - NY **800 MW**
Impacts Total Transfer Capability 1000 MW
TTC with All Lines In Service 1800 MW

SCH-NYISO-NE_LIMIT_600

Thu 04/27/2023 to Fri 04/28/2023
2300 Continuous 0659
Work scheduled by: ISONE

FWD (Import) REV (Export)
SCH - NE - NY **800 MW**
Impacts Total Transfer Capability 1000 MW
TTC with All Lines In Service 1800 MW

PLSNTVLY_345KV_RN4 , PLSNTVLY_345KV_RN5

Fri 04/28/2023 to Sat 04/29/2023
0001 2200
Work scheduled by:

FWD (Import) REV (Export)
UPNY CONED **3800 MW**
Impacts Total Transfer Capability 4015 MW
TTC with All Lines In Service 7815 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Wednesday, April 19, 2023 to Friday, October 18, 2024

| | |
|-------------------|---------|
| CENTRAL EAST | 2650 MW |
| CENTRAL EAST - VC | 2720 MW |
| TOTAL EAST | 6000 MW |
| UPNY CONED | 7815 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3150 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_3

Sat 04/29/2023 to Sat 04/29/2023
0130 Continuous 0200
Work scheduled by: ConEd

| | | |
|-----------------------------------|----------------|--------------|
| SPR/DUN-SOUTH | FWD (Import) | REV (Export) |
| | 3800 MW | |
| Impacts Total Transfer Capability | 800 MW | |
| TTC with All Lines In Service | 4600 MW | |

DUNWODIE_345KV_4

Sat 04/29/2023 to Sat 04/29/2023
0130 Continuous 0200
Work scheduled by: ConEd

| | | |
|-----------------------------------|----------------|--------------|
| SPR/DUN-SOUTH | FWD (Import) | REV (Export) |
| | 3800 MW | |
| Impacts Total Transfer Capability | 800 MW | |
| TTC with All Lines In Service | 4600 MW | |

CHAT_DC_GC2

Sun 04/30/2023 to Sun 05/21/2023
0500 Continuous 2000
Work scheduled by: HQ

| | | |
|-----------------------------------|----------------|--------------|
| MOSES SOUTH | FWD (Import) | REV (Export) |
| | 2850 MW | |
| Impacts Total Transfer Capability | 300 MW | |
| TTC with All Lines In Service | 3150 MW | |

CHAT_DC_GC2

Sun 04/30/2023 to Sun 05/21/2023
0500 Continuous 2000
Work scheduled by: HQ

| | | |
|-----------------------------------|--------------|---------------|
| SCH - HQ - NY | FWD (Import) | REV (Export) |
| | | 500 MW |
| Impacts Total Transfer Capability | | 500 MW |
| TTC with All Lines In Service | | 1000 MW |

SCH-HQ-NYISO_LIMIT_1150

Sun 04/30/2023 to Sun 05/21/2023
0500 Continuous 2000
Work scheduled by: HQ

| | | |
|-----------------------------------|----------------|--------------|
| SCH - HQ - NY | FWD (Import) | REV (Export) |
| | 1150 MW | |
| Impacts Total Transfer Capability | 350 MW | |
| TTC with All Lines In Service | 1500 MW | |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Wednesday, April 19, 2023 to Friday, October 18, 2024

| | |
|-------------------|---------|
| CENTRAL EAST | 2650 MW |
| CENTRAL EAST - VC | 2720 MW |
| TOTAL EAST | 6000 MW |
| UPNY CONED | 7815 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3150 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-HQ-NYISO_LIMIT_1400

Sun 04/30/2023 to Fri 05/05/2023
0500 Continuous 1659

Work scheduled by: HQ

SCH - HQ - NY

FWD (Import)

REV (Export)

1400 MW

Impacts Total Transfer Capability

100 MW

TTC with All Lines In Service

1500 MW

HUDSONTP-W49TH_ST_345_Y56

Mon 05/01/2023 to Fri 05/05/2023
0600 Continuous 1800

Work scheduled by: ConEd

SCH - PJM_HTP

FWD (Import)

REV (Export)

0 MW

Impacts Total Transfer Capability

660 MW

TTC with All Lines In Service

660 MW

W49TH_ST_345KV_7

Mon 05/01/2023 to Mon 05/01/2023
0600 Continuous 0630

Work scheduled by: ConEd

SCH - PJM_HTP

FWD (Import)

REV (Export)

300 MW

Impacts Total Transfer Capability

360 MW

TTC with All Lines In Service

660 MW

W49TH_ST_345KV_8

Mon 05/01/2023 to Mon 05/01/2023
0600 Continuous 0630

Work scheduled by: ConEd

SCH - PJM_HTP

FWD (Import)

REV (Export)

450 MW

Impacts Total Transfer Capability

210 MW

TTC with All Lines In Service

660 MW

PANNELL_-CLAY_345_2

Mon 05/01/2023 to Fri 05/05/2023
0700 Continuous 1730

Work scheduled by: NYPA

WEST CENTRAL

FWD (Import)

REV (Export)

1300 MW

Impacts Total Transfer Capability

950 MW

TTC with All Lines In Service

2250 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Wednesday, April 19, 2023 to Friday, October 18, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HURLYAVE-ROSETON_345_303

Mon 05/01/2023 to Sun 05/07/2023
0800 Continuous 1600
Work scheduled by: CHGE

UPNY CONED
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) 4100 MW
3715 MW
7815 MW

LEEDS__HURLYAVE_345_301

Mon 05/01/2023 to Fri 06/02/2023
0800 Continuous 1700
Work scheduled by: CHGE

UPNY CONED
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) 4100 MW
3715 MW
7815 MW

PIERCBRK-FIVEMILE_345_37

Tue 05/02/2023 to Tue 05/02/2023
0830 Continuous 1230
Work scheduled by: NGrid

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

E13THSTA-FARRAGUT_345_46

Wed 05/03/2023 to Fri 05/05/2023
0301 Continuous 0200
Work scheduled by: ConEd

UPDATED by ConEd 04/18/2023 10:42

SPR/DUN-SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) 3800 MW
800 MW
4600 MW

LONG_MTN-CRICKVLY_345_398

Wed 05/03/2023 to Wed 05/03/2023
0830 Continuous 1600
Work scheduled by: ISONE

SCH - NPX_1385
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) 100 MW
100 MW
200 MW

REV (Export) 100 MW
100 MW
200 MW

LONG_MTN-CRICKVLY_345_398

Wed 05/03/2023 to Wed 05/03/2023
0830 Continuous 1600
Work scheduled by: ISONE

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) 500 MW
900 MW
1400 MW

REV (Export) 1150 MW
450 MW
1600 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Wednesday, April 19, 2023 to Friday, October 18, 2024

| | |
|-------------------|---------|
| CENTRAL EAST | 2650 MW |
| CENTRAL EAST - VC | 2720 MW |
| TOTAL EAST | 6000 MW |
| UPNY CONED | 7815 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3150 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_7

Fri 05/05/2023 to Fri 05/05/2023
1730 Continuous 1800
Work scheduled by: ConEd

| | | |
|-----------------------------------|---------------|--------------|
| SCH - PJM_HTP | FWD (Import) | REV (Export) |
| | 300 MW | |
| Impacts Total Transfer Capability | 360 MW | |
| TTC with All Lines In Service | 660 MW | |

W49TH_ST_345KV_8

Fri 05/05/2023 to Fri 05/05/2023
1730 Continuous 1800
Work scheduled by: ConEd

| | | |
|-----------------------------------|---------------|--------------|
| SCH - PJM_HTP | FWD (Import) | REV (Export) |
| | 450 MW | |
| Impacts Total Transfer Capability | 210 MW | |
| TTC with All Lines In Service | 660 MW | |

MARCY_SO_SERIES_COMP_I/S

Fri 05/05/2023 to Tue 10/31/2023
1800 Continuous 2359
Work scheduled by: NYISO

| | | |
|-----------------------------------|----------------|--------------|
| CENTRAL EAST - VC | FWD (Import) | REV (Export) |
| | 2360 MW | |
| Impacts Total Transfer Capability | 360 MW | |
| TTC with All Lines In Service | 2720 MW | |

DUNWODIE_345KV_5

Sat 05/06/2023 to Sat 05/06/2023
0001 Continuous 1800
Work scheduled by: ConEd

| | | |
|-----------------------------------|----------------|--------------|
| SPR/DUN-SOUTH | FWD (Import) | REV (Export) |
| | 3800 MW | |
| Impacts Total Transfer Capability | 800 MW | |
| TTC with All Lines In Service | 4600 MW | |

DUNWODIE_345KV_7

Sat 05/06/2023 to Sat 05/06/2023
0001 Continuous 1800
Work scheduled by: ConEd

| | | |
|-----------------------------------|----------------|--------------|
| SPR/DUN-SOUTH | FWD (Import) | REV (Export) |
| | 3800 MW | |
| Impacts Total Transfer Capability | 800 MW | |
| TTC with All Lines In Service | 4600 MW | |

SPRNBK_345KV_RNS3

Sat 05/06/2023 to Sat 05/06/2023
0001 Continuous 0030
Work scheduled by: ConEd

| | | |
|-----------------------------------|----------------|--------------|
| SPR/DUN-SOUTH | FWD (Import) | REV (Export) |
| | 3800 MW | |
| Impacts Total Transfer Capability | 800 MW | |
| TTC with All Lines In Service | 4600 MW | |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Wednesday, April 19, 2023 to Friday, October 18, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK_-DUNWODIE_345_W75

Sat 05/06/2023 to Sat 05/06/2023
0001 Continuous 1800
Work scheduled by: ConEd

FWD (Import) REV (Export)
SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

W49TH_ST_345KV_6

Sat 05/06/2023 to Sat 05/06/2023
0001 Continuous 0030
Work scheduled by: ConEd

FWD (Import) REV (Export)
SCH - PJM_HTP **300 MW**
Impacts Total Transfer Capability 360 MW
TTC with All Lines In Service 660 MW

W49TH_ST_345KV_8

Sat 05/06/2023 to Sat 05/06/2023
0001 Continuous 0030
Work scheduled by: ConEd

FWD (Import) REV (Export)
SCH - PJM_HTP **450 MW**
Impacts Total Transfer Capability 210 MW
TTC with All Lines In Service 660 MW

VOLNEY_-MARCY_345_19

Sat 05/06/2023 to Sun 05/28/2023
0500 Continuous 1900
Work scheduled by: NYPA

ARR: 19

FWD (Import) REV (Export)
OSWEGO EXPORT **4900 MW**
Impacts Total Transfer Capability 350 MW
TTC with All Lines In Service 5250 MW

VOLNEY_-MARCY_345_19

Sat 05/06/2023 to Sun 05/28/2023
0500 Continuous 1900
Work scheduled by: NYPA

ARR: 19

FWD (Import) REV (Export)
CENTRAL EAST - VC **2475 MW**
Impacts Total Transfer Capability 245 MW
TTC with All Lines In Service 2720 MW

VOLNEY_-MARCY_345_19 , MARCY_SO_SERIES_COMP_I/S

Sat 05/06/2023 to Sun 05/28/2023
0500 1900
Work scheduled by:

ARR: 19

FWD (Import) REV (Export)
CENTRAL EAST - VC **2250 MW**
Impacts Total Transfer Capability 470 MW
TTC with All Lines In Service 2720 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Wednesday, April 19, 2023 to Friday, October 18, 2024

| | |
|-------------------|---------|
| CENTRAL EAST | 2650 MW |
| CENTRAL EAST - VC | 2720 MW |
| TOTAL EAST | 6000 MW |
| UPNY CONED | 7815 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3150 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK_345KV_RNS3

Sat 05/06/2023 to Sat 05/06/2023
1730 Continuous 1800
Work scheduled by: ConEd

| | | |
|-----------------------------------|----------------|--------------|
| SPR/DUN-SOUTH | FWD (Import) | REV (Export) |
| | 3800 MW | |
| Impacts Total Transfer Capability | 800 MW | |
| TTC with All Lines In Service | 4600 MW | |

EASTVIEW-SPRNBK_345_W65

Sun 05/07/2023 to Sun 05/07/2023
0001 Continuous 0030
Work scheduled by: ConEd

| | | |
|-----------------------------------|----------------|--------------|
| UPNY CONED | FWD (Import) | REV (Export) |
| | 4350 MW | |
| Impacts Total Transfer Capability | 3465 MW | |
| TTC with All Lines In Service | 7815 MW | |

MILLWOOD-EASTVIEW_345_W82

Sun 05/07/2023 to Mon 05/08/2023
0001 Continuous 0200
Work scheduled by: ConEd

| | | |
|-----------------------------------|----------------|--------------|
| UPNY CONED | FWD (Import) | REV (Export) |
| | 7550 MW | |
| Impacts Total Transfer Capability | 265 MW | |
| TTC with All Lines In Service | 7815 MW | |

SPRNBK_345KV_RNS4

Sun 05/07/2023 to Sun 05/07/2023
0001 Continuous 0030
Work scheduled by: ConEd

| | | |
|-----------------------------------|----------------|--------------|
| SPR/DUN-SOUTH | FWD (Import) | REV (Export) |
| | 3200 MW | |
| Impacts Total Transfer Capability | 1400 MW | |
| TTC with All Lines In Service | 4600 MW | |

ATHENS_-VNWAGNER_345_91

Mon 05/08/2023 to Thu 05/18/2023
0001 Continuous 2200
Work scheduled by: NGrid

UPDATED by ConEd 02/21/2023 15:27

| | | |
|-----------------------------------|----------------|--------------|
| UPNY CONED | FWD (Import) | REV (Export) |
| | 3800 MW | |
| Impacts Total Transfer Capability | 4015 MW | |
| TTC with All Lines In Service | 7815 MW | |

PLSNTVLY_345KV_RNS4

Mon 05/08/2023 to Thu 05/18/2023
0001 Continuous 2200
Work scheduled by: NGrid

UPDATED by ConEd 02/21/2023 15:27

| | | |
|-----------------------------------|----------------|--------------|
| UPNY CONED | FWD (Import) | REV (Export) |
| | 3800 MW | |
| Impacts Total Transfer Capability | 4015 MW | |
| TTC with All Lines In Service | 7815 MW | |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Wednesday, April 19, 2023 to Friday, October 18, 2024

| | |
|-------------------|---------|
| CENTRAL EAST | 2650 MW |
| CENTRAL EAST - VC | 2720 MW |
| TOTAL EAST | 6000 MW |
| UPNY CONED | 7815 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3150 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

VNWAGNER-PLSNTVLY_345_Y58

Mon 05/08/2023 to Thu 05/18/2023
0001 Continuous 2200

UPDATED by ConEd 02/21/2023 15:27

FWD (Import) REV (Export)

Work scheduled by: NGrid

UPNY CONED **3800 MW**
Impacts Total Transfer Capability 4015 MW
TTC with All Lines In Service 7815 MW

EASTVIEW-SPRNBK_345_W65

Mon 05/08/2023 to Mon 05/08/2023
0130 Continuous 0200

FWD (Import) REV (Export)

Work scheduled by: ConEd

UPNY CONED **4350 MW**
Impacts Total Transfer Capability 3465 MW
TTC with All Lines In Service 7815 MW

SPRNBK_345KV_RNS4

Mon 05/08/2023 to Mon 05/08/2023
0130 Continuous 0200

FWD (Import) REV (Export)

Work scheduled by: ConEd

SPR/DUN-SOUTH **3200 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

SCH-NYISO-HQ_LIMIT_300

Mon 05/08/2023 to Tue 05/09/2023
0600 Continuous 1900

FWD (Import) REV (Export)

Work scheduled by: HQ

SCH - HQ - NY **300 MW**
Impacts Total Transfer Capability 700 MW
TTC with All Lines In Service 1000 MW

COOPERS-DOLSONAV_345_CCDA42

Mon 05/08/2023 to Sun 05/21/2023
0700 Continuous 1530

FWD (Import) REV (Export)

Work scheduled by: NYPA

CENTRAL EAST - VC **2485 MW**
Impacts Total Transfer Capability 235 MW
TTC with All Lines In Service 2720 MW

DOLSONAV-ROCKTVRN_345_DART44

Mon 05/08/2023 to Sat 05/13/2023
0700 Continuous 1530

FWD (Import) REV (Export)

Work scheduled by: NYPA

CENTRAL EAST - VC **2485 MW**
Impacts Total Transfer Capability 235 MW
TTC with All Lines In Service 2720 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Wednesday, April 19, 2023 to Friday, October 18, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

OAKDALE_FRASER__345_32

Tue 05/09/2023 to Tue 05/09/2023
0700 Daily 1800

UPDATED by NYSEG 03/07/2023 14:15

CENTRAL EAST - VC

FWD (Import)

REV (Export)

2450 MW

Impacts Total Transfer Capability

270 MW

TTC with All Lines In Service

2720 MW

Work scheduled by: NYSEG

LADENTWN-BUCHAN_S_345_Y88

Wed 05/10/2023 to Sat 05/13/2023
0101 Continuous 0100

UPDATED by ConEd 03/27/2023 15:57

UPNY CONED

FWD (Import)

REV (Export)

7560 MW

Impacts Total Transfer Capability

255 MW

TTC with All Lines In Service

7815 MW

Work scheduled by: ORU

SPRNBK_345KV_RNS4

Sat 05/13/2023 to Mon 05/15/2023
0001 Continuous 0300

UPDATED by ConEd 01/04/2023 11:31

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

3200 MW

Impacts Total Transfer Capability

1400 MW

TTC with All Lines In Service

4600 MW

Work scheduled by: ConEd

SPRNBK-W49TH_ST_345_M52

Sat 05/13/2023 to Mon 05/15/2023
0001 Continuous 0300

UPDATED by ConEd 01/04/2023 11:31

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

3200 MW

Impacts Total Transfer Capability

1400 MW

TTC with All Lines In Service

4600 MW

Work scheduled by: ConEd

W49TH_ST_345KV_5

Sat 05/13/2023 to Mon 05/15/2023
0001 Continuous 0300

UPDATED by ConEd 01/04/2023 11:31

SCH - PJM_HTP

FWD (Import)

REV (Export)

300 MW

Impacts Total Transfer Capability

360 MW

TTC with All Lines In Service

660 MW

Work scheduled by: ConEd

W49TH_ST_345KV_6

Sat 05/13/2023 to Sat 05/13/2023
0130 Continuous 0200

SCH - PJM_HTP

FWD (Import)

REV (Export)

300 MW

Impacts Total Transfer Capability

360 MW

TTC with All Lines In Service

660 MW

Work scheduled by: ConEd

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Wednesday, April 19, 2023 to Friday, October 18, 2024

| | |
|-------------------|---------|
| CENTRAL EAST | 2650 MW |
| CENTRAL EAST - VC | 2720 MW |
| TOTAL EAST | 6000 MW |
| UPNY CONED | 7815 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3150 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_8

Sat 05/13/2023 to Sat 05/13/2023
0130 Continuous 0200

Work scheduled by: ConEd

SCH - PJM_HTP

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

450 MW

210 MW

660 MW

W49TH_ST_345KV_6

Mon 05/15/2023 to Mon 05/15/2023
0001 Continuous 0030

Work scheduled by: ConEd

SCH - PJM_HTP

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

300 MW

360 MW

660 MW

W49TH_ST-E13THSTA_345_M55

Mon 05/15/2023 to Mon 05/15/2023
0001 Continuous 0030

Work scheduled by: ConEd

SPR/DUN-SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

3800 MW

800 MW

4600 MW

W49TH_ST_345KV_6

Mon 05/15/2023 to Mon 05/15/2023
0301 Continuous 0330

Work scheduled by: ConEd

UPDATED by ConEd 03/20/2023 09:13

SCH - PJM_HTP

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

300 MW

360 MW

660 MW

W49TH_ST-E13THSTA_345_M55

Mon 05/15/2023 to Wed 05/17/2023
0301 Continuous 0200

Work scheduled by: ConEd

UPDATED by ConEd 03/20/2023 09:13

SPR/DUN-SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

3800 MW

800 MW

4600 MW

W49TH_ST_345KV_6

Tue 05/16/2023 to Wed 05/17/2023
0001 Continuous 0200

Work scheduled by: ConEd

UPDATED by ConEd 03/20/2023 09:13

SCH - PJM_HTP

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

300 MW

360 MW

660 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Wednesday, April 19, 2023 to Friday, October 18, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SHOR_NPX-SHOREHAM_138_CSC

Tue 05/16/2023 to Sun 05/21/2023
0500 Continuous 1500

Work scheduled by: LI

SCH - NPX_CSC

FWD (Import)

REV (Export)

0 MW

0 MW

Impacts Total Transfer Capability

330 MW

330 MW

TTC with All Lines In Service

330 MW

330 MW

MOTTHAVN-RAINEY__345_Q11

Fri 05/19/2023 to Sat 05/20/2023
0001 Continuous 0200

Work scheduled by: ConEd

UPDATED by ConEd 02/18/2023 08:38

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

3800 MW

Impacts Total Transfer Capability

800 MW

TTC with All Lines In Service

4600 MW

MARCY__345KV_CSC

Fri 05/19/2023 to Tue 05/23/2023
0500 Continuous 1900

Work scheduled by: NYPA

UPDATED by NYPA 10/05/2022 11:11

CENTRAL EAST - VC

FWD (Import)

REV (Export)

2535 MW

Impacts Total Transfer Capability

185 MW

TTC with All Lines In Service

2720 MW

MARCY__345KV_CSC , MARCY_SO_SERIES_COMP_I/S

Fri 05/19/2023 to Tue 05/23/2023
0500 Continuous 1900

Work scheduled by:

CENTRAL EAST - VC

FWD (Import)

REV (Export)

2315 MW

Impacts Total Transfer Capability

405 MW

TTC with All Lines In Service

2720 MW

LEEDS__VNWAGNER_345_92

Sat 05/20/2023 to Mon 05/29/2023
0001 Continuous 0259

Work scheduled by: NGrid

UPDATED by ConEd 02/21/2023 15:21

UPNY CONED

FWD (Import)

REV (Export)

3800 MW

Impacts Total Transfer Capability

4015 MW

TTC with All Lines In Service

7815 MW

PLSNTVLY_345KV_RNS5

Sat 05/20/2023 to Mon 05/29/2023
0001 Continuous 0259

Work scheduled by: NGrid

UPDATED by ConEd 02/21/2023 15:21

UPNY CONED

FWD (Import)

REV (Export)

3800 MW

Impacts Total Transfer Capability

4015 MW

TTC with All Lines In Service

7815 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Wednesday, April 19, 2023 to Friday, October 18, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK_-TREMONT_345_X28

Sat 05/20/2023 to Sat 05/20/2023
0001 Continuous 0030
Work scheduled by: ConEd

FWD (Import) REV (Export)
SPR/DUN-SOUTH **4200 MW**
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 4600 MW

VNWAGNER-PLSNTVLY_345_Y59

Sat 05/20/2023 to Mon 05/29/2023
0001 Continuous 0259
Work scheduled by: NGrid

UPDATED by ConEd 02/21/2023 15:21

FWD (Import) REV (Export)
UPNY CONED **3800 MW**
Impacts Total Transfer Capability 4015 MW
TTC with All Lines In Service 7815 MW

SPRNBK_-TREMONT_345_X28

Sat 05/20/2023 to Sat 05/20/2023
1230 Continuous 1300
Work scheduled by: ConEd

FWD (Import) REV (Export)
SPR/DUN-SOUTH **4200 MW**
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 4600 MW

CHATGUAY-MASSENA_765_7040

Tue 05/30/2023 to Tue 05/30/2023
0600 Continuous 1930
Work scheduled by: NYPA

UPDATED by NYPA 12/13/2022 09:46

FWD (Import) REV (Export)
SCH - HQ - NY **0 MW** **0 MW**
Impacts Total Transfer Capability 1500 MW 1000 MW
TTC with All Lines In Service 1500 MW 1000 MW

CHATGUAY-MASSENA_765_7040

Tue 05/30/2023 to Tue 05/30/2023
0600 Continuous 1930
Work scheduled by: NYPA

UPDATED by NYPA 12/13/2022 09:46

FWD (Import) REV (Export)
MOSES SOUTH **1550 MW**
Impacts Total Transfer Capability 1600 MW
TTC with All Lines In Service 3150 MW

CHATGUAY-MASSENA_765_7040 , MASSENA-MARCY_765_MSU1

Tue 05/30/2023 to Tue 05/30/2023
0600 1930
Work scheduled by:

FWD (Import) REV (Export)
MOSES SOUTH **500 MW**
Impacts Total Transfer Capability 2650 MW
TTC with All Lines In Service 3150 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Wednesday, April 19, 2023 to Friday, October 18, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___765_345_AT1

Tue 05/30/2023 to Tue 05/30/2023
0600 Continuous 1930
Work scheduled by: NYPA

UPDATED by NYPA 12/13/2022 09:46

ARR: 19

MOSES SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
1750 MW
1400 MW
3150 MW

MARCY___765_345_AT2

Tue 05/30/2023 to Tue 05/30/2023
0600 Continuous 1930
Work scheduled by: NYPA

UPDATED by NYPA 12/13/2022 16:34

ARR: 19

MOSES SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
1700 MW
1450 MW
3150 MW

MASSENA_-MARCY___765_MSU1

Tue 05/30/2023 to Tue 05/30/2023
0600 Continuous 1930
Work scheduled by: NYPA

UPDATED by NYPA 12/13/2022 09:46

CENTRAL EAST - VC
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
1720 MW
1000 MW
2720 MW

MASSENA_-MARCY___765_MSU1

Tue 05/30/2023 to Tue 05/30/2023
0600 Continuous 1930
Work scheduled by: NYPA

UPDATED by NYPA 12/13/2022 09:46

SCH - HQ_CEDARS
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
90 MW
180 MW
270 MW

MASSENA_-MARCY___765_MSU1

Tue 05/30/2023 to Tue 05/30/2023
0600 Continuous 1930
Work scheduled by: NYPA

UPDATED by NYPA 12/13/2022 09:46

SCH - HQ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
475 MW 1000 MW
1025 MW 0 MW
1500 MW 1000 MW

MASSENA_-MARCY___765_MSU1

Tue 05/30/2023 to Tue 05/30/2023
0600 Continuous 1930
Work scheduled by: NYPA

UPDATED by NYPA 12/13/2022 09:46

MOSES SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
500 MW
2650 MW
3150 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Wednesday, April 19, 2023 to Friday, October 18, 2024

| | |
|-------------------|---------|
| CENTRAL EAST | 2650 MW |
| CENTRAL EAST - VC | 2720 MW |
| TOTAL EAST | 6000 MW |
| UPNY CONED | 7815 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3150 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

| | | | | | |
|--|----|----------------|-----------------------------------|-------------------------------|--------------|
| MASSENA_-MARCY__765_MSU1 , CHASLAKE-PORTER__230_11 | | | | FWD (Import) | REV (Export) |
| Tue 05/30/2023 | to | Tue 05/30/2023 | SCH - HQ_CEDARS | 90 MW | |
| 0600 | | 1930 | Impacts Total Transfer Capability | 180 MW | |
| Work scheduled by: | | | | TTC with All Lines In Service | 270 MW |
| MASSENA_-MARCY__765_MSU1 , MARCY_SO_SERIES_COMP_I/S | | | | FWD (Import) | REV (Export) |
| Tue 05/30/2023 | to | Tue 05/30/2023 | CENTRAL EAST - VC | 1500 MW | |
| 0600 | | 1930 | Impacts Total Transfer Capability | 1220 MW | |
| Work scheduled by: | | | | TTC with All Lines In Service | 2720 MW |
| MASSENA_-MARCY__765_MSU1 , STLAWRNC-MOSES__230_L34P | | | | FWD (Import) | REV (Export) |
| Tue 05/30/2023 | to | Tue 05/30/2023 | SCH - HQ_CEDARS | 90 MW | |
| 0600 | | 1930 | Impacts Total Transfer Capability | 180 MW | |
| Work scheduled by: | | | | TTC with All Lines In Service | 270 MW |
| MASSENA_-MARCY__765_MSU1 , STLAWRNC-MOSES__230_L34P , CHASLAKE-PORTER__230_11 | | | | FWD (Import) | REV (Export) |
| Tue 05/30/2023 | to | Tue 05/30/2023 | SCH - HQ_CEDARS | 90 MW | |
| 0600 | | 1930 | Impacts Total Transfer Capability | 180 MW | |
| Work scheduled by: | | | | TTC with All Lines In Service | 270 MW |
| MOSES__-MASSENA__230_MMS1 , MOSES__-MASSENA__230_MMS2 | | | | FWD (Import) | REV (Export) |
| Tue 05/30/2023 | to | Tue 05/30/2023 | SCH - HQ_CEDARS | 90 MW | |
| 0600 | | 1930 | Impacts Total Transfer Capability | 180 MW | |
| Work scheduled by: | | | | TTC with All Lines In Service | 270 MW |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Wednesday, April 19, 2023 to Friday, October 18, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES__-MASSENA_230_MMS1 , MOSES__-MASSENA_230_MMS2

Tue 05/30/2023 to Tue 05/30/2023
0600 1930

Work scheduled by:

SCH - HQ - NY

FWD (Import)

REV (Export)

850 MW

0 MW

Impacts Total Transfer Capability

650 MW

1000 MW

TTC with All Lines In Service

1500 MW

1000 MW

MOSES__-MASSENA_230_MMS1 , MOSES__-MASSENA_230_MMS2 ,
CHASLAKE-PORTER_230_11

Tue 05/30/2023 to Tue 05/30/2023
0600 1930

Work scheduled by:

SCH - HQ_CEDARS

FWD (Import)

REV (Export)

90 MW

Impacts Total Transfer Capability

180 MW

TTC with All Lines In Service

270 MW

MOSES__-MASSENA_230_MMS1 , MOSES__-MASSENA_230_MMS2 ,
STLAWRNC-MOSES_230_L34P

Tue 05/30/2023 to Tue 05/30/2023
0600 1930

Work scheduled by:

SCH - HQ_CEDARS

FWD (Import)

REV (Export)

90 MW

Impacts Total Transfer Capability

180 MW

TTC with All Lines In Service

270 MW

MOSES__-MASSENA_230_MMS1 , MOSES__-MASSENA_230_MMS2 ,
STLAWRNC-MOSES_230_L34P , CHASLAKE-PORTER_230_11

Tue 05/30/2023 to Tue 05/30/2023
0600 1930

Work scheduled by:

SCH - HQ_CEDARS

FWD (Import)

REV (Export)

90 MW

Impacts Total Transfer Capability

180 MW

TTC with All Lines In Service

270 MW

VOLNEY_-MARCY_345_19

Sat 06/03/2023 to Sun 06/04/2023
0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

OSWEGO EXPORT

FWD (Import)

REV (Export)

4900 MW

Impacts Total Transfer Capability

350 MW

TTC with All Lines In Service

5250 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Wednesday, April 19, 2023 to Friday, October 18, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

VOLNEY_-MARCY__345_19

Sat 06/03/2023 to Sun 06/04/2023

0500 Continuous 1730

Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

2475 MW

245 MW

2720 MW

VOLNEY_-MARCY__345_19, MARCY_SO_SERIES_COMP_I/S

Sat 06/03/2023 to Sun 06/04/2023

0500 1730

Work scheduled by:

ARR: 19

CENTRAL EAST - VC

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

2250 MW

470 MW

2720 MW

LEEDS__345KV_R94301

Mon 06/05/2023 to Tue 06/06/2023

0830 Continuous 1400

Work scheduled by: NGrid

UPNY CONED

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

3800 MW

4015 MW

7815 MW

ELBRIDGE-LAFAYTTE_345_17-LE

Wed 06/07/2023 to Wed 06/07/2023

0630 Daily 1800

Work scheduled by: NGrid

ARR: 75

OSWEGO EXPORT

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

5250 MW

0 MW

5250 MW

OSWEGO_-ELBRIDGE_345_17

Wed 06/07/2023 to Wed 06/07/2023

0630 Daily 1800

Work scheduled by: NGrid

ARR: 75

OSWEGO EXPORT

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

5250 MW

0 MW

5250 MW

NIAGARA_-PACKARD__230_62

Mon 06/26/2023 to Fri 06/30/2023

0500 Continuous 1900

Work scheduled by: NYPA

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

1500 MW

400 MW

1900 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Wednesday, April 19, 2023 to Friday, October 18, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_345_230_AT4

Wed 06/28/2023 to Thu 06/29/2023
0500 Continuous 1900
Work scheduled by: NYPA

SCH - OH - NY
Impacts Total Transfer Capability 1150 MW
TTC with All Lines In Service 400 MW
1550 MW

MARCY_-EDIC_345_UE1-7

Sat 07/08/2023 to Sun 07/09/2023
0500 Continuous 1900
Work scheduled by: NYPA
UPDATED by NYPA 10/28/2022 10:56
ARR: 19,16

OSWEGO EXPORT
Impacts Total Transfer Capability 5250 MW
TTC with All Lines In Service 0 MW
5250 MW

MARCY_-EDIC_345_UE1-7

Sat 07/15/2023 to Sun 07/16/2023
0500 Continuous 1930
Work scheduled by: NYPA
UPDATED by NYPA 10/28/2022 11:17
ARR: 19,16

OSWEGO EXPORT
Impacts Total Transfer Capability 5250 MW
TTC with All Lines In Service 0 MW
5250 MW

ADIRNDCK-PORTER_230_12

Sun 07/16/2023 to Sun 07/16/2023
0700 Continuous 1530
Work scheduled by: NYPA
UPDATED by NYPA 12/14/2022 14:55

MOSES SOUTH
Impacts Total Transfer Capability 2100 MW
TTC with All Lines In Service 1050 MW
3150 MW

MOSES_-ADIRNDCK_230_MA2

Sun 07/16/2023 to Sun 07/16/2023
0700 Continuous 1530
Work scheduled by: NYPA

MOSES SOUTH
Impacts Total Transfer Capability 2100 MW
TTC with All Lines In Service 1050 MW
3150 MW

SCH-IMO_NY_NIAG_CB_3122_W/BB

Mon 07/17/2023 to Fri 07/28/2023
0500 Continuous 2100
Work scheduled by: NYPA

SCH - OH - NY
Impacts Total Transfer Capability 1800 MW 1300 MW
TTC with All Lines In Service 100 MW 250 MW
1900 MW 1550 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Wednesday, April 19, 2023 to Friday, October 18, 2024

| | |
|-------------------|---------|
| CENTRAL EAST | 2650 MW |
| CENTRAL EAST - VC | 2720 MW |
| TOTAL EAST | 6000 MW |
| UPNY CONED | 7815 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3150 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

| | | | | | | |
|---------------------------------------|------------|----------------|---|-----------------------------------|----------------|----------------|
| ADIRNDCK-CHASLAKE_230_13 | | | | | FWD (Import) | REV (Export) |
| Mon 07/17/2023 | to | Mon 07/17/2023 | <u>UPDATED by NYPA 02/17/2023 15:10</u> | MOSES SOUTH | 2100 MW | |
| 0700 | Continuous | 1730 | | Impacts Total Transfer Capability | 1050 MW | |
| Work scheduled by: NYPA | | | | TTC with All Lines In Service | 3150 MW | |
| MOSES__ADIRNDCK_230_MA1 | | | | | FWD (Import) | REV (Export) |
| Mon 07/17/2023 | to | Mon 07/17/2023 | <u>UPDATED by NYPA 02/17/2023 15:10</u> | MOSES SOUTH | 2100 MW | |
| 0700 | Continuous | 1730 | | Impacts Total Transfer Capability | 1050 MW | |
| Work scheduled by: NYPA | | | | TTC with All Lines In Service | 3150 MW | |
| ADIRNDCK-CHASLAKE_230_13 | | | | | FWD (Import) | REV (Export) |
| Tue 07/18/2023 | to | Fri 09/15/2023 | | MOSES SOUTH | 2100 MW | |
| 0630 | Continuous | 1600 | | Impacts Total Transfer Capability | 1050 MW | |
| Work scheduled by: NGrid | | | | TTC with All Lines In Service | 3150 MW | |
| HURLYAVE-ROSETON_345_303 | | | | | FWD (Import) | REV (Export) |
| Mon 07/31/2023 | to | Fri 08/25/2023 | | UPNY CONED | 4100 MW | |
| 0800 | Continuous | 1600 | | Impacts Total Transfer Capability | 3715 MW | |
| Work scheduled by: CHGE | | | | TTC with All Lines In Service | 7815 MW | |
| DYSINGER-STA_255_345_DH2 | | | | | FWD (Import) | REV (Export) |
| Fri 08/04/2023 | to | Mon 08/14/2023 | | DYSINGER EAST | 2850 MW | |
| 0500 | Continuous | 2300 | | Impacts Total Transfer Capability | 350 MW | |
| Work scheduled by: NYPA | | | | TTC with All Lines In Service | 3200 MW | |
| SCH-IMO_NY_NIAG_SOUTH_BUS_W/BB | | | | | FWD (Import) | REV (Export) |
| Mon 08/07/2023 | to | Fri 08/11/2023 | | SCH - OH - NY | 1300 MW | 1100 MW |
| 0500 | Continuous | 1900 | | Impacts Total Transfer Capability | 600 MW | 450 MW |
| Work scheduled by: NYPA | | | | TTC with All Lines In Service | 1900 MW | 1550 MW |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Wednesday, April 19, 2023 to Friday, October 18, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DYSINGER-STA_255_345_DH1

Tue 08/15/2023 to Fri 08/25/2023
0500 Continuous 2300
Work scheduled by: NYPA

| | | |
|-----------------------------------|----------------|--------------|
| | FWD (Import) | REV (Export) |
| DYSINGER EAST | 2850 MW | |
| Impacts Total Transfer Capability | 350 MW | |
| TTC with All Lines In Service | 3200 MW | |

MARCY__345KV_CSC

Sat 08/19/2023 to Sun 08/20/2023
0500 Continuous 1930
Work scheduled by: NYPA

| | | |
|-----------------------------------|----------------|--------------|
| | FWD (Import) | REV (Export) |
| CENTRAL EAST - VC | 2535 MW | |
| Impacts Total Transfer Capability | 185 MW | |
| TTC with All Lines In Service | 2720 MW | |

MARCY__345KV_CSC , MARCY_SO_SERIES_COMP_I/S

Sat 08/19/2023 to Sun 08/20/2023
0500 1930
Work scheduled by:

| | | |
|-----------------------------------|----------------|--------------|
| | FWD (Import) | REV (Export) |
| CENTRAL EAST - VC | 2315 MW | |
| Impacts Total Transfer Capability | 405 MW | |
| TTC with All Lines In Service | 2720 MW | |

MARCY__-EDIC__345_UE1-7

Sat 08/19/2023 to Sun 08/20/2023
0500 Continuous 1930
Work scheduled by: NYPA

ARR: 19,16

| | | |
|-----------------------------------|----------------|--------------|
| | FWD (Import) | REV (Export) |
| OSWEGO EXPORT | 5250 MW | |
| Impacts Total Transfer Capability | 0 MW | |
| TTC with All Lines In Service | 5250 MW | |

NIAGARA_345_230_AT4

Mon 08/28/2023 to Fri 09/01/2023
0500 Continuous 2100
Work scheduled by: NYPA

UPDATED by NYPA 03/16/2023 08:43

| | | |
|-----------------------------------|--------------|----------------|
| | FWD (Import) | REV (Export) |
| SCH - OH - NY | | 1150 MW |
| Impacts Total Transfer Capability | | 400 MW |
| TTC with All Lines In Service | | 1550 MW |

CLAY__-EDIC__345_1-16

Mon 09/11/2023 to Fri 09/15/2023
0700 Continuous 1530
Work scheduled by: NYPA

UPDATED by NYISO 02/22/2023 09:21

| | | |
|-----------------------------------|----------------|--------------|
| | FWD (Import) | REV (Export) |
| OSWEGO EXPORT | 4850 MW | |
| Impacts Total Transfer Capability | 400 MW | |
| TTC with All Lines In Service | 5250 MW | |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Wednesday, April 19, 2023 to Friday, October 18, 2024

| | |
|-------------------|---------|
| CENTRAL EAST | 2650 MW |
| CENTRAL EAST - VC | 2720 MW |
| TOTAL EAST | 6000 MW |
| UPNY CONED | 7815 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3150 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FRASER_-GILBOA_345_GF5-35

Mon 09/11/2023 to Sun 09/17/2023
0700 Continuous 1530
Work scheduled by: NYPA

CENTRAL EAST - VC
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
2450 MW
270 MW
2720 MW

LONG_MTN-CRICKVLY_345_398

Fri 09/15/2023 to Sun 10/01/2023
0001 Continuous 2200
Work scheduled by: ConEd

SCH - NPX_1385
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
100 MW **100 MW**
100 MW 100 MW
200 MW 200 MW

LONG_MTN-CRICKVLY_345_398

Fri 09/15/2023 to Sun 10/01/2023
0001 Continuous 2200
Work scheduled by: ConEd

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
500 MW **1150 MW**
900 MW 450 MW
1400 MW 1600 MW

SPRNBK_345KV_RNS5

Fri 09/15/2023 to Wed 10/25/2023
0001 Continuous 0100
Work scheduled by: ConEd

UPDATED by ConEd 04/18/2023 07:42

SPR/DUN-SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
3200 MW
1400 MW
4600 MW

SPRNBK_-W49TH_ST_345_M51

Fri 09/15/2023 to Wed 10/25/2023
0001 Continuous 0100
Work scheduled by: ConEd

UPDATED by ConEd 04/18/2023 07:42

SPR/DUN-SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
3200 MW
1400 MW
4600 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Wednesday, April 19, 2023 to Friday, October 18, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHASLAKE-PORTER__230_11

Sat 09/16/2023 to Sun 10/15/2023
0630 Continuous 1730

UPDATED by NGrid 02/01/2023 11:03

MOSES SOUTH

FWD (Import)

REV (Export)

2100 MW

Impacts Total Transfer Capability

1050 MW

TTC with All Lines In Service

3150 MW

Work scheduled by: NGrid

CLAY__-EDIC__345_2-15

Mon 09/18/2023 to Fri 09/22/2023
0700 Continuous 1530

OSWEGO EXPORT

FWD (Import)

REV (Export)

4850 MW

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

5250 MW

Work scheduled by: NYPA

MARCY__-EDIC__345_UE1-7

Sat 09/23/2023 to Sun 09/24/2023
0500 Continuous 1900

UPDATED by NYPA 10/28/2022 11:09

OSWEGO EXPORT

FWD (Import)

REV (Export)

5250 MW

Impacts Total Transfer Capability

0 MW

TTC with All Lines In Service

5250 MW

Work scheduled by: NYPA

ARR: 19,16

NIAGARA_-DYSINGER_345_ND2

Mon 09/25/2023 to Fri 09/29/2023
0500 Continuous 2000

DYSINGER EAST

FWD (Import)

REV (Export)

2700 MW

Impacts Total Transfer Capability

500 MW

TTC with All Lines In Service

3200 MW

Work scheduled by: NYPA

MARCY__345KV_CSC

Mon 09/25/2023 to Sat 10/07/2023
0700 Continuous 1530

CENTRAL EAST - VC

FWD (Import)

REV (Export)

2535 MW

Impacts Total Transfer Capability

185 MW

TTC with All Lines In Service

2720 MW

Work scheduled by: NYPA

MARCY__345KV_CSC , MARCY_SO_SERIES_COMP_I/S

Mon 09/25/2023 to Sat 10/07/2023
0700 Continuous 1530

CENTRAL EAST - VC

FWD (Import)

REV (Export)

2315 MW

Impacts Total Transfer Capability

405 MW

TTC with All Lines In Service

2720 MW

Work scheduled by:

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Wednesday, April 19, 2023 to Friday, October 18, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ROSETON_EFISHKIL_345_RFK305

Mon 09/25/2023 to Fri 10/13/2023
0700 Continuous 1530
Work scheduled by: NYPA

UPNY CONED
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) 6680 MW
REV (Export) 1135 MW
7815 MW

SHOR_NPX-SHOREHAM_138_CSC

Mon 10/02/2023 to Fri 10/06/2023
0600 Continuous 1800
Work scheduled by: LI

SCH - NPX_CSC
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) 0 MW
REV (Export) 0 MW
330 MW
330 MW

ROSETON_ROCKTVRN_345_311

Mon 10/02/2023 to Fri 11/03/2023
0800 Continuous 1600
Work scheduled by: CHGE

UPNY CONED
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) 4400 MW
REV (Export) 3415 MW
7815 MW

GILBOA_-N.SCTLND_345_GNS-1

Mon 10/09/2023 to Fri 10/13/2023
0700 Continuous 1530
Work scheduled by: NYPA

CENTRAL EAST - VC
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) 2300 MW
REV (Export) 420 MW
2720 MW

NIAGARA_PACKARD_230_61

Fri 10/13/2023 to Fri 10/13/2023
0500 Continuous 1900
Work scheduled by: NYPA

SCH - OH - NY
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) 1350 MW
REV (Export) 200 MW
1550 MW

ADIRNDCK-CHASLAKE_230_13

Mon 10/16/2023 to Tue 11/14/2023
0630 Continuous 1730
Work scheduled by: NGrid

UPDATED by NGrid 11/07/2022 15:17

MOSES SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) 2100 MW
REV (Export) 1050 MW
3150 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Wednesday, April 19, 2023 to Friday, October 18, 2024

| | |
|-------------------|---------|
| CENTRAL EAST | 2650 MW |
| CENTRAL EAST - VC | 2720 MW |
| TOTAL EAST | 6000 MW |
| UPNY CONED | 7815 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3150 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEPTUNE_DUFFYAVE_345_NEPTUNE

Sun 10/29/2023 to Fri 11/17/2023

0001 Continuous 2359

Work scheduled by: LI

SCH - PJM_NEPTUNE

FWD (Import)

REV (Export)

0 MW

Impacts Total Transfer Capability

660 MW

TTC with All Lines In Service

660 MW

NEWBRDGE_345_138_BK_1

Sun 10/29/2023 to Fri 11/17/2023

0001 Continuous 2359

Work scheduled by: LI

SCH - PJM_NEPTUNE

FWD (Import)

REV (Export)

375 MW

Impacts Total Transfer Capability

285 MW

TTC with All Lines In Service

660 MW

NEWBRDGE_345_138_BK_2

Sun 10/29/2023 to Fri 11/17/2023

0001 Continuous 2359

Work scheduled by: LI

SCH - PJM_NEPTUNE

FWD (Import)

REV (Export)

375 MW

Impacts Total Transfer Capability

285 MW

TTC with All Lines In Service

660 MW

NEWBRDGE-DUFFYAVE_345_501

Sun 10/29/2023 to Fri 11/17/2023

0001 Continuous 2359

Work scheduled by: LI

SCH - PJM_NEPTUNE

FWD (Import)

REV (Export)

0 MW

Impacts Total Transfer Capability

660 MW

TTC with All Lines In Service

660 MW

LONG_MTN-CRICKVLY_345_398

Mon 11/06/2023 to Thu 11/30/2023

0001 Continuous 2200

Work scheduled by: ConEd

SCH - NPX_1385

FWD (Import)

REV (Export)

100 MW

100 MW

Impacts Total Transfer Capability

100 MW

100 MW

TTC with All Lines In Service

200 MW

200 MW

LONG_MTN-CRICKVLY_345_398

Mon 11/06/2023 to Thu 11/30/2023

0001 Continuous 2200

Work scheduled by: ConEd

SCH - NE - NY

FWD (Import)

REV (Export)

700 MW

1200 MW

Impacts Total Transfer Capability

900 MW

600 MW

TTC with All Lines In Service

1600 MW

1800 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Wednesday, April 19, 2023 to Friday, October 18, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LINDN_CG-LNDVFT__345_V-3022

Mon 11/06/2023 to Thu 11/09/2023
0800 Continuous 1500
Work scheduled by: PJM

| | FWD (Import) | REV (Export) |
|-----------------------------------|--------------|--------------|
| SCH - PJM_VFT | 0 MW | 0 MW |
| Impacts Total Transfer Capability | 315 MW | 315 MW |
| TTC with All Lines In Service | 315 MW | 315 MW |

HURLYAVE-ROSETON__345_303

Mon 11/13/2023 to Fri 12/22/2023
0800 Continuous 1600
Work scheduled by: CHGE

| | FWD (Import) | REV (Export) |
|-----------------------------------|--------------|--------------|
| UPNY CONED | 4100 MW | |
| Impacts Total Transfer Capability | 3715 MW | |
| TTC with All Lines In Service | 7815 MW | |

CHATGUAY-MASSENA__765_7040

Wed 11/15/2023 to Mon 11/27/2023
0700 Continuous 1730
Work scheduled by: NYPA

| | FWD (Import) | REV (Export) |
|-----------------------------------|--------------|--------------|
| SCH - HQ - NY | 0 MW | 0 MW |
| Impacts Total Transfer Capability | 1500 MW | 1000 MW |
| TTC with All Lines In Service | 1500 MW | 1000 MW |

CHATGUAY-MASSENA__765_7040

Wed 11/15/2023 to Mon 11/27/2023
0700 Continuous 1730
Work scheduled by: NYPA

| | FWD (Import) | REV (Export) |
|-----------------------------------|--------------|--------------|
| MOSES SOUTH | 1550 MW | |
| Impacts Total Transfer Capability | 1600 MW | |
| TTC with All Lines In Service | 3150 MW | |

CHATGUAY-MASSENA__765_7040 , MASSENA-MARCY__765_MSU1

Wed 11/15/2023 to Mon 11/27/2023
0700 Continuous 1730
Work scheduled by:

| | FWD (Import) | REV (Export) |
|-----------------------------------|--------------|--------------|
| MOSES SOUTH | 500 MW | |
| Impacts Total Transfer Capability | 2650 MW | |
| TTC with All Lines In Service | 3150 MW | |

MASSENA-MARCY__765_MSU1

Wed 11/15/2023 to Mon 11/27/2023
0700 Continuous 1730
Work scheduled by: NYPA

| | FWD (Import) | REV (Export) |
|-----------------------------------|--------------|--------------|
| CENTRAL EAST - VC | 1720 MW | |
| Impacts Total Transfer Capability | 865 MW | |
| TTC with All Lines In Service | 2585 MW | |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Wednesday, April 19, 2023 to Friday, October 18, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

| | | | | | | |
|--|------------|----------------|--|-----------------------------------|---------------|----------------|
| MASSENA_-MARCY___765_MSU1 | | | | | FWD (Import) | REV (Export) |
| Wed 11/15/2023 | to | Mon 11/27/2023 | | SCH - HQ_CEDARS | 90 MW | |
| 0700 | Continuous | 1730 | | Impacts Total Transfer Capability | 189 MW | |
| Work scheduled by: NYPA | | | | TTC with All Lines In Service | 279 MW | |
| MASSENA_-MARCY___765_MSU1 | | | | | FWD (Import) | REV (Export) |
| Wed 11/15/2023 | to | Mon 11/27/2023 | | SCH - HQ - NY | 475 MW | 1000 MW |
| 0700 | Continuous | 1730 | | Impacts Total Transfer Capability | 1025 MW | 0 MW |
| Work scheduled by: NYPA | | | | TTC with All Lines In Service | 1500 MW | 1000 MW |
| MASSENA_-MARCY___765_MSU1 | | | | | FWD (Import) | REV (Export) |
| Wed 11/15/2023 | to | Mon 11/27/2023 | | MOSES SOUTH | 500 MW | |
| 0700 | Continuous | 1730 | | Impacts Total Transfer Capability | 2650 MW | |
| Work scheduled by: NYPA | | | | TTC with All Lines In Service | 3150 MW | |
| MOSES___-MASSENA_230_MMS1 , MOSES___-MASSENA_230_MMS2 | | | | | FWD (Import) | REV (Export) |
| Wed 11/15/2023 | to | Mon 11/20/2023 | | SCH - HQ_CEDARS | 90 MW | |
| 0700 | | 1530 | | Impacts Total Transfer Capability | 189 MW | |
| Work scheduled by: | | | | TTC with All Lines In Service | 279 MW | |
| MOSES___-MASSENA_230_MMS1 , MOSES___-MASSENA_230_MMS2 | | | | | FWD (Import) | REV (Export) |
| Wed 11/15/2023 | to | Mon 11/20/2023 | | SCH - HQ - NY | 850 MW | 0 MW |
| 0700 | | 1530 | | Impacts Total Transfer Capability | 650 MW | 1000 MW |
| Work scheduled by: | | | | TTC with All Lines In Service | 1500 MW | 1000 MW |
| LINDN_CG-LNDVFT___345_V-3022 | | | | | FWD (Import) | REV (Export) |
| Wed 11/15/2023 | to | Wed 11/15/2023 | | SCH - PJM_VFT | 0 MW | 0 MW |
| 1500 | Continuous | 1700 | | Impacts Total Transfer Capability | 315 MW | 315 MW |
| Work scheduled by: PJM | | | | TTC with All Lines In Service | 315 MW | 315 MW |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Wednesday, April 19, 2023 to Friday, October 18, 2024

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6000 MW
UPNY CONED 7815 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_345_230_AT4

Mon 12/04/2023 to Fri 12/08/2023
0500 Continuous 1900
Work scheduled by: NYPA

UPDATED by NYPA 03/21/2023 14:25

SCH - OH - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
1650 MW
350 MW
2000 MW

S.RIPLEY-DUNKIRK_230_68

Mon 12/04/2023 to Fri 12/08/2023
0800 Continuous 1600
Work scheduled by: PJM

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

HOMR_NYW-PIERC_NY_345_48

Fri 12/08/2023 to Fri 12/15/2023
0800 Continuous 1600
Work scheduled by: PJM

UPDATED by PJM 07/28/2022 14:08

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

LONG_MTN-CRICKVLY_345_398

Tue 12/12/2023 to Thu 12/21/2023
0001 Continuous 2200
Work scheduled by: ConEd

SCH - NPX_1385
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
100 MW **100 MW**
100 MW 100 MW
200 MW 200 MW

LONG_MTN-CRICKVLY_345_398

Tue 12/12/2023 to Thu 12/21/2023
0001 Continuous 2200
Work scheduled by: ConEd

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
700 MW **1200 MW**
900 MW 600 MW
1600 MW 1800 MW

S.RIPLEY-DUNKIRK_230_68

Wed 12/27/2023 to Fri 12/29/2023
0730 Continuous 1600
Work scheduled by: NGrid

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Wednesday, April 19, 2023 to Friday, October 18, 2024

| | |
|-------------------|---------|
| CENTRAL EAST | 2650 MW |
| CENTRAL EAST - VC | 2720 MW |
| TOTAL EAST | 6000 MW |
| UPNY CONED | 7815 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3150 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_6

Mon 01/08/2024 to Mon 02/19/2024
0001 Continuous 0201
Work scheduled by: ConEd

| | | |
|-----------------------------------|---------------|--------------|
| | FWD (Import) | REV (Export) |
| SCH - PJM_HTP | 310 MW | |
| Impacts Total Transfer Capability | 350 MW | |
| TTC with All Lines In Service | 660 MW | |

W49TH_ST-E13THSTA_345_M55

Mon 01/08/2024 to Mon 02/19/2024
0001 Continuous 0201
Work scheduled by: ConEd

| | | |
|-----------------------------------|----------------|--------------|
| | FWD (Import) | REV (Export) |
| SPR/DUN-SOUTH | 3800 MW | |
| Impacts Total Transfer Capability | 800 MW | |
| TTC with All Lines In Service | 4600 MW | |

W49TH_ST_345KV_8

Sat 02/03/2024 to Mon 02/19/2024
0001 Continuous 0201
Work scheduled by: ConEd

| | | |
|-----------------------------------|---------------|--------------|
| | FWD (Import) | REV (Export) |
| SCH - PJM_HTP | 310 MW | |
| Impacts Total Transfer Capability | 350 MW | |
| TTC with All Lines In Service | 660 MW | |

SHOR_NPX-SHOREHAM_138_CSC

Mon 05/06/2024 to Fri 05/10/2024
0600 Continuous 1800
Work scheduled by: LI

| | | |
|-----------------------------------|--------------|--------------|
| | FWD (Import) | REV (Export) |
| SCH - NPX_CSC | 0 MW | 0 MW |
| Impacts Total Transfer Capability | 330 MW | 330 MW |
| TTC with All Lines In Service | 330 MW | 330 MW |

NEPTUNE_DUFFYAVE_345_NEPTUNE

Mon 10/07/2024 to Fri 10/11/2024
0600 Continuous 1600
Work scheduled by: LI

| | | |
|-----------------------------------|--------------|--------------|
| | FWD (Import) | REV (Export) |
| SCH - PJM_NEPTUNE | 0 MW | |
| Impacts Total Transfer Capability | 660 MW | |
| TTC with All Lines In Service | 660 MW | |

NEWBRDGE_345_138_BK_1

Mon 10/07/2024 to Fri 10/11/2024
0600 Continuous 1600
Work scheduled by: LI

| | | |
|-----------------------------------|---------------|--------------|
| | FWD (Import) | REV (Export) |
| SCH - PJM_NEPTUNE | 375 MW | |
| Impacts Total Transfer Capability | 285 MW | |
| TTC with All Lines In Service | 660 MW | |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Wednesday, April 19, 2023 to Friday, October 18, 2024

| | |
|-------------------|---------|
| CENTRAL EAST | 2650 MW |
| CENTRAL EAST - VC | 2720 MW |
| TOTAL EAST | 6000 MW |
| UPNY CONED | 7815 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3150 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEWBRDGE_345_138_BK_2

Mon 10/07/2024 to Fri 10/11/2024
0600 Continuous 1600
Work scheduled by: LI

| | FWD (Import) | REV (Export) |
|-----------------------------------|---------------|--------------|
| SCH - PJM_NEPTUNE | 375 MW | |
| Impacts Total Transfer Capability | 285 MW | |
| TTC with All Lines In Service | 660 MW | |

NEWBRDGE-DUFFYAVE_345_501

Mon 10/07/2024 to Fri 10/11/2024
0600 Continuous 1600
Work scheduled by: LI

| | FWD (Import) | REV (Export) |
|-----------------------------------|--------------|--------------|
| SCH - PJM_NEPTUNE | 0 MW | |
| Impacts Total Transfer Capability | 660 MW | |
| TTC with All Lines In Service | 660 MW | |

SHOR_NPX-SHOREHAM_138_CSC

Mon 10/07/2024 to Fri 10/11/2024
0600 Continuous 1800
Work scheduled by: LI

| | FWD (Import) | REV (Export) |
|-----------------------------------|--------------|--------------|
| SCH - NPX_CSC | 0 MW | 0 MW |
| Impacts Total Transfer Capability | 330 MW | 330 MW |
| TTC with All Lines In Service | 330 MW | 330 MW |