

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, May 20, 2023 to Tuesday, November 19, 2024

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6000 MW  
UPNY CONED 7815 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE\_345KV\_10\_BYPASS , DUNWODIE\_345KV\_9\_BYPASS ,  
SPRNBK\_345KV\_R4S3\_BYPASS , SPRNBK\_345KV\_R5S3\_BYPASS

Sun 02/01/2015 to Sat 02/01/2025  
0000 0000

Work scheduled by:

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

**4350 MW**

Impacts Total Transfer Capability

250 MW

TTC with All Lines In Service

4600 MW

DUNWODIE\_345KV\_10\_BYPASS , DUNWODIE\_345KV\_9\_BYPASS ,  
SPRNBK\_345KV\_R4S3\_BYPASS , SPRNBK\_345KV\_R5S3\_BYPASS

Sun 02/01/2015 to Sat 02/01/2025  
0000 0000

Work scheduled by:

UPNY CONED

FWD (Import)

REV (Export)

**7505 MW**

Impacts Total Transfer Capability

310 MW

TTC with All Lines In Service

7815 MW

HUDSONP\_-FARRAGUT\_345\_B3402

Mon 01/15/2018 to Sat 09/30/2023  
0001 Continuous 2359

Work scheduled by: ConEd

EXT FORCED by ConEd 08/06/2022 16:26

SCH - PJ - NY

FWD (Import)

REV (Export)

**2050 MW**

Impacts Total Transfer Capability

200 MW

TTC with All Lines In Service

2250 MW

MARION\_-FARRAGUT\_345\_C3403

Mon 01/15/2018 to Sat 09/30/2023  
0001 Continuous 2359

Work scheduled by: ConEd

EXT FORCED by ConEd 08/06/2022 16:26

SCH - PJ - NY

FWD (Import)

REV (Export)

**2050 MW**

Impacts Total Transfer Capability

200 MW

TTC with All Lines In Service

2250 MW

MARION\_-FARRAGUT\_345\_C3403 , HUDSONP\_-  
FARRAGUT\_345\_B3402

Mon 01/15/2018 to Sat 09/30/2023  
0001 2359

Work scheduled by:

SCH - PJ - NY

FWD (Import)

REV (Export)

**2000 MW**

**1150 MW**

Impacts Total Transfer Capability

250 MW

50 MW

TTC with All Lines In Service

2250 MW

1200 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, May 20, 2023 to Tuesday, November 19, 2024

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6000 MW  
UPNY CONED 7815 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### EGRDNCTY\_345\_138\_AT1

Sat 10/01/2022 to Wed 05/31/2023  
0001 Continuous 2359

UPDATED by ConEd 10/01/2022 09:02

CONED - LIPA

FWD (Import)

REV (Export)

**1250 MW**

Impacts Total Transfer Capability

250 MW

TTC with All Lines In Service

1500 MW

Work scheduled by: LI

### EGRDNCTY\_345\_138\_AT2

Sat 10/01/2022 to Wed 05/31/2023  
0001 Continuous 2359

UPDATED by ConEd 10/01/2022 09:02

CONED - LIPA

FWD (Import)

REV (Export)

**1250 MW**

Impacts Total Transfer Capability

250 MW

TTC with All Lines In Service

1500 MW

Work scheduled by: LI

### SPRNBK\_-EGRDNCTR\_345\_Y49

Sat 10/01/2022 to Wed 05/31/2023  
0001 Continuous 2359

UPDATED by ConEd 10/01/2022 09:02

CONED - LIPA

FWD (Import)

REV (Export)

**775 MW**

Impacts Total Transfer Capability

725 MW

TTC with All Lines In Service

1500 MW

Work scheduled by: LI

### STLAWRNC-MOSES\_230\_L34P

Mon 10/03/2022 to Mon 11/06/2023  
1800 Continuous 0800

UPDATED by IESO 03/07/2023 10:12

SCH - OH - NY

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: IESO

### CHASLAKE-PORTER\_230\_11

Tue 02/21/2023 to Sat 07/15/2023  
0630 Continuous 1730

UPDATED by NGrid 02/01/2023 11:03

MOSES SOUTH

FWD (Import)

REV (Export)

**2100 MW**

Impacts Total Transfer Capability

1050 MW

TTC with All Lines In Service

3150 MW

Work scheduled by: NGrid

### MOSES\_-ADIRNDCK\_230\_MA1

Sun 03/05/2023 to Fri 05/26/2023  
2000 Continuous 1930

MOSES SOUTH

FWD (Import)

REV (Export)

**2100 MW**

Impacts Total Transfer Capability

1050 MW

TTC with All Lines In Service

3150 MW

Work scheduled by: NYPA



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, May 20, 2023 to Tuesday, November 19, 2024

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6000 MW  
UPNY CONED 7815 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### S.RIPLEY-DUNKIRK\_\_230\_68

Wed 04/26/2023 to Sun 05/21/2023  
0700 Continuous 1600

EXTENDED by NGrid 05/19/2023 13:11

SCH - PJ - NY

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

TTC with All Lines In Service

### LEEDS\_\_HURLYAVE\_345\_301

Tue 05/02/2023 to Fri 06/02/2023  
0800 Continuous 1700

UPNY CONED

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

TTC with All Lines In Service

**4100 MW**

3715 MW

7815 MW

### SCH-IMO-NYISO\_LIMIT\_1450

Fri 05/05/2023 to Tue 10/31/2023  
0001 Continuous 2359

SCH - OH - NY

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

TTC with All Lines In Service

**1750 MW**

150 MW

1900 MW

### VOLNEY\_\_MARCY\_\_345\_19

Sat 05/06/2023 to Sun 05/28/2023  
0500 Continuous 1900

ARR: 19

OSWEGO EXPORT

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

TTC with All Lines In Service

**4900 MW**

350 MW

5250 MW

### VOLNEY\_\_MARCY\_\_345\_19

Sat 05/06/2023 to Sun 05/28/2023  
0500 Continuous 1900

ARR: 19

CENTRAL EAST - VC

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

TTC with All Lines In Service

**2575 MW**

145 MW

2720 MW

### SHOR\_NPX-SHOREHAM\_138\_CSC

Tue 05/16/2023 to Sun 05/21/2023  
0500 Continuous 1600

SCH - NPX\_CSC

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

TTC with All Lines In Service

**0 MW**

330 MW

330 MW

**0 MW**

330 MW

330 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, May 20, 2023 to Tuesday, November 19, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2720 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NYISO-HQ\_LIMIT\_800

Thu 05/18/2023 to Fri 05/26/2023  
1901 Continuous 1800  
Work scheduled by: HQ

SCH - HQ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) REV (Export)  
**800 MW**  
200 MW  
1000 MW

### W49TH\_ST\_345KV\_6

Fri 05/19/2023 to Sat 05/20/2023  
0201 Continuous 0100  
Work scheduled by: ConEd  
CANCELLED by TO 05/19/2023 07:20

SCH - PJM\_HTP  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) REV (Export)  
**300 MW**  
360 MW  
660 MW

### W49TH\_ST-E13THSTA\_345\_M55

Fri 05/19/2023 to Sat 05/20/2023  
0201 Continuous 0100  
Work scheduled by: ConEd  
CANCELLED by TO 05/19/2023 07:20

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) REV (Export)  
**3800 MW**  
800 MW  
4600 MW

### MARCY\_345KV\_CSC

Fri 05/19/2023 to Tue 05/23/2023  
0500 Continuous 1900  
Work scheduled by: NYPA  
UPDATED by NYPA 10/05/2022 11:11

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) REV (Export)  
**2535 MW**  
185 MW  
2720 MW

### SPRNBK-TREMONT\_345\_X28

Sat 05/20/2023 to Sat 05/20/2023  
0001 Continuous 1200  
Work scheduled by: ConEd  
CANCELLED by TO 05/20/2023 13:54

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) REV (Export)  
**4200 MW**  
400 MW  
4600 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, May 20, 2023 to Tuesday, November 19, 2024

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6000 MW  
UPNY CONED 7815 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### NRTH1385-NOR HBR\_138\_601

Mon 05/22/2023 to Fri 06/30/2023  
0500 Continuous 2359

FWD (Import) REV (Export)

SCH - NPX\_1385 100 MW 100 MW  
Impacts Total Transfer Capability 100 MW 100 MW  
TTC with All Lines In Service 200 MW 200 MW

Work scheduled by: LI

### NRTH1385-NOR HBR\_138\_602

Mon 05/22/2023 to Fri 06/30/2023  
0500 Continuous 2359

FWD (Import) REV (Export)

SCH - NPX\_1385 100 MW 100 MW  
Impacts Total Transfer Capability 100 MW 100 MW  
TTC with All Lines In Service 200 MW 200 MW

Work scheduled by: LI

### NRTH1385-NOR HBR\_138\_603

Mon 05/22/2023 to Fri 06/30/2023  
0500 Continuous 2359

FWD (Import) REV (Export)

SCH - NPX\_1385 100 MW 100 MW  
Impacts Total Transfer Capability 100 MW 100 MW  
TTC with All Lines In Service 200 MW 200 MW

Work scheduled by: LI

### NRTH1385-NORHBR\_138\_601, NRTH1385-NORHBR\_138\_602

Mon 05/22/2023 to Fri 06/30/2023  
0500 2359

FWD (Import) REV (Export)

SCH - NPX\_1385 0 MW 0 MW  
Impacts Total Transfer Capability 200 MW 200 MW  
TTC with All Lines In Service 200 MW 200 MW

Work scheduled by:

### NRTH1385-NORHBR\_138\_601, NRTH1385-NORHBR\_138\_603

Mon 05/22/2023 to Fri 06/30/2023  
0500 2359

FWD (Import) REV (Export)

SCH - NPX\_1385 0 MW 0 MW  
Impacts Total Transfer Capability 200 MW 200 MW  
TTC with All Lines In Service 200 MW 200 MW

Work scheduled by:

### NRTH1385-NORHBR\_138\_602, NRTH1385-NORHBR\_138\_603

Mon 05/22/2023 to Fri 06/30/2023  
0500 2359

FWD (Import) REV (Export)

SCH - NPX\_1385 0 MW 0 MW  
Impacts Total Transfer Capability 200 MW 200 MW  
TTC with All Lines In Service 200 MW 200 MW

Work scheduled by:



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, May 20, 2023 to Tuesday, November 19, 2024

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6000 MW  
UPNY CONED 7815 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### NRTH1385-NRTHPORT\_138\_NNC

Mon 05/22/2023 to Fri 06/30/2023  
0500 Continuous 2359

Work scheduled by: LI

SCH - NPX\_1385

FWD (Import)

REV (Export)

0 MW

0 MW

Impacts Total Transfer Capability

200 MW

200 MW

TTC with All Lines In Service

200 MW

200 MW

### MOTTHAVN-RAINEY\_\_345\_Q12

Mon 05/22/2023 to Tue 05/23/2023  
2200 Continuous 0400

Work scheduled by: ConEd

UPDATED by ConEd 05/19/2023 09:07

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

3800 MW

Impacts Total Transfer Capability

800 MW

TTC with All Lines In Service

4600 MW

### ATHENS\_-VNWAGNER\_345\_91

Thu 05/25/2023 to Tue 06/06/2023  
0001 Continuous 1200

Work scheduled by: NGrid

UPDATED by NYISO 05/04/2023 16:03

UPNY CONED

FWD (Import)

REV (Export)

3800 MW

Impacts Total Transfer Capability

4015 MW

TTC with All Lines In Service

7815 MW

### PLSNTVLY\_345KV\_RNS4

Thu 05/25/2023 to Tue 06/06/2023  
0001 Continuous 1200

Work scheduled by: NGrid

UPDATED by NYISO 05/04/2023 16:03

UPNY CONED

FWD (Import)

REV (Export)

3800 MW

Impacts Total Transfer Capability

4015 MW

TTC with All Lines In Service

7815 MW

### VNWAGNER-PLSNTVLY\_345\_Y58

Thu 05/25/2023 to Tue 06/06/2023  
0001 Continuous 1200

Work scheduled by: NGrid

UPDATED by NYISO 05/04/2023 16:03

UPNY CONED

FWD (Import)

REV (Export)

3800 MW

Impacts Total Transfer Capability

4015 MW

TTC with All Lines In Service

7815 MW

### CHATGUAY-MASSENA\_765\_7040

Tue 05/30/2023 to Tue 05/30/2023  
0001 Continuous 2359

Work scheduled by: NYPA

UPDATED by NYPA 05/11/2023 11:43

SCH - HQ - NY

FWD (Import)

REV (Export)

0 MW

0 MW

Impacts Total Transfer Capability

1500 MW

1000 MW

TTC with All Lines In Service

1500 MW

1000 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, May 20, 2023 to Tuesday, November 19, 2024

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6000 MW  
UPNY CONED 7815 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### CHATGUAY-MASSENA\_765\_7040

Tue 05/30/2023 to Tue 05/30/2023  
0001 Continuous 2359

UPDATED by NYPA 05/11/2023 11:43

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1550 MW**  
1600 MW  
3150 MW

Work scheduled by: NYPA

### CHATGUAY-MASSENA\_765\_7040 , MASSENA-MARCY\_765\_MSU1

Tue 05/30/2023 to Tue 05/30/2023  
0001 2359

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**500 MW**  
2650 MW  
3150 MW

Work scheduled by:

### MARCY\_765\_345\_AT1

Tue 05/30/2023 to Tue 05/30/2023  
0001 Continuous 2359

UPDATED by NYPA 05/11/2023 11:43

ARR: 19

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1750 MW**  
1400 MW  
3150 MW

Work scheduled by: NYPA

### MARCY\_765\_345\_AT2

Tue 05/30/2023 to Tue 05/30/2023  
0001 Continuous 2359

UPDATED by NYPA 05/11/2023 11:50

ARR: 19

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1700 MW**  
1450 MW  
3150 MW

Work scheduled by: NYPA

### MASSENA-MARCY\_765\_MSU1

Tue 05/30/2023 to Tue 05/30/2023  
0001 Continuous 2359

UPDATED by NYPA 05/11/2023 11:43

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1720 MW**  
1000 MW  
2720 MW

Work scheduled by: NYPA

### MASSENA-MARCY\_765\_MSU1

Tue 05/30/2023 to Tue 05/30/2023  
0001 Continuous 2359

UPDATED by NYPA 05/11/2023 11:43

SCH - HQ\_CEDARS  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**90 MW**  
180 MW  
270 MW

Work scheduled by: NYPA



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, May 20, 2023 to Tuesday, November 19, 2024

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6000 MW  
UPNY CONED 7815 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MASSENA\_-MARCY\_\_\_765\_MSU1

Tue 05/30/2023 to Tue 05/30/2023

0001 Continuous 2359

Work scheduled by: NYPA

UPDATED by NYPA 05/11/2023 11:43

SCH - HQ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

**475 MW**

1025 MW

1500 MW

REV (Export)

**1000 MW**

0 MW

1000 MW

### MASSENA\_-MARCY\_\_\_765\_MSU1

Tue 05/30/2023 to Tue 05/30/2023

0001 Continuous 2359

Work scheduled by: NYPA

UPDATED by NYPA 05/11/2023 11:43

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

**500 MW**

2650 MW

3150 MW

REV (Export)

### MASSENA\_-MARCY\_\_\_765\_MSU1 , CHASLAKE-PORTER\_\_\_230\_11

Tue 05/30/2023 to Tue 05/30/2023

0001 2359

Work scheduled by:

SCH - HQ\_CEDARS

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

**90 MW**

180 MW

270 MW

REV (Export)

### MASSENA\_-MARCY\_\_\_765\_MSU1 , STLAWRNC-MOSES\_\_\_230\_L34P

Tue 05/30/2023 to Tue 05/30/2023

0001 2359

Work scheduled by:

SCH - HQ\_CEDARS

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

**90 MW**

180 MW

270 MW

REV (Export)

### MASSENA\_-MARCY\_\_\_765\_MSU1 , STLAWRNC-MOSES\_\_\_230\_L34P , CHASLAKE-PORTER\_\_\_230\_11

Tue 05/30/2023 to Tue 05/30/2023

0001 2359

Work scheduled by:

SCH - HQ\_CEDARS

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

**90 MW**

180 MW

270 MW

REV (Export)



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, May 20, 2023 to Tuesday, November 19, 2024

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6000 MW  
UPNY CONED 7815 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES__-MASSENA__230_MMS1 , MOSES__-MASSENA__230_MMS2			SCH - HQ_CEDARS	FWD (Import)	REV (Export)
Tue 05/30/2023	to	Tue 05/30/2023		<b>90 MW</b>	
0001		2359	Impacts Total Transfer Capability	180 MW	
Work scheduled by:			TTC with All Lines In Service	270 MW	
MOSES__-MASSENA__230_MMS1 , MOSES__-MASSENA__230_MMS2			SCH - HQ - NY	FWD (Import)	REV (Export)
Tue 05/30/2023	to	Tue 05/30/2023		<b>850 MW</b>	<b>0 MW</b>
0001		2359	Impacts Total Transfer Capability	650 MW	1000 MW
Work scheduled by:			TTC with All Lines In Service	1500 MW	1000 MW
MOSES__-MASSENA__230_MMS1 , MOSES__-MASSENA__230_MMS2 , CHASLAKE-PORTER__230_11			SCH - HQ_CEDARS	FWD (Import)	REV (Export)
Tue 05/30/2023	to	Tue 05/30/2023		<b>90 MW</b>	
0001		2359	Impacts Total Transfer Capability	180 MW	
Work scheduled by:			TTC with All Lines In Service	270 MW	
MOSES__-MASSENA__230_MMS1 , MOSES__-MASSENA__230_MMS2 , STLAWRNC-MOSES__230_L34P			SCH - HQ_CEDARS	FWD (Import)	REV (Export)
Tue 05/30/2023	to	Tue 05/30/2023		<b>90 MW</b>	
0001		2359	Impacts Total Transfer Capability	180 MW	
Work scheduled by:			TTC with All Lines In Service	270 MW	
MOSES__-MASSENA__230_MMS1 , MOSES__-MASSENA__230_MMS2 , STLAWRNC-MOSES__230_L34P , CHASLAKE-PORTER__230_11			SCH - HQ_CEDARS	FWD (Import)	REV (Export)
Tue 05/30/2023	to	Tue 05/30/2023		<b>90 MW</b>	
0001		2359	Impacts Total Transfer Capability	180 MW	
Work scheduled by:			TTC with All Lines In Service	270 MW	



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, May 20, 2023 to Tuesday, November 19, 2024

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6000 MW  
UPNY CONED 7815 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### CHAT\_DC\_GC1

Tue 05/30/2023 to Tue 05/30/2023  
0600 Continuous 2000  
Work scheduled by: HQ

FWD (Import) REV (Export)  
MOSES SOUTH **2850 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

### CHAT\_DC\_GC1

Tue 05/30/2023 to Tue 05/30/2023  
0600 Continuous 2000  
Work scheduled by: HQ

FWD (Import) REV (Export)  
SCH - HQ - NY **500 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1000 MW

### MOTTHAVN-RAINEY\_\_345\_Q12

Thu 06/01/2023 to Thu 06/01/2023  
0101 Continuous 0130  
Work scheduled by: ConEd

FWD (Import) REV (Export)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

### VOLNEY\_-MARCY\_\_345\_19

Sat 06/03/2023 to Sun 06/04/2023  
0500 Continuous 1730  
Work scheduled by: NYPA

ARR: 19

FWD (Import) REV (Export)  
OSWEGO EXPORT **4900 MW**  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 5250 MW

### VOLNEY\_-MARCY\_\_345\_19

Sat 06/03/2023 to Sun 06/04/2023  
0500 Continuous 1730  
Work scheduled by: NYPA

ARR: 19

FWD (Import) REV (Export)  
CENTRAL EAST - VC **2575 MW**  
Impacts Total Transfer Capability 145 MW  
TTC with All Lines In Service 2720 MW

### ELBRIDGE-LAFAYTTE\_345\_17-LE

Wed 06/07/2023 to Wed 06/07/2023  
0630 Daily 1800  
Work scheduled by: NGrid

ARR: 75

FWD (Import) REV (Export)  
OSWEGO EXPORT **5250 MW**  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, May 20, 2023 to Tuesday, November 19, 2024

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6000 MW  
UPNY CONED 7815 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### OSWEGO\_\_ELBRIDGE\_345\_17

Wed 06/07/2023 to Wed 06/07/2023  
0630 Daily 1800

ARR: 75

FWD (Import) REV (Export)

OSWEGO EXPORT **5250 MW**  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

Work scheduled by: NGrid

### LEEDS\_\_VNWAGNER\_345\_92

Thu 06/08/2023 to Sat 06/17/2023  
0001 Continuous 1200

UPDATED by NYISO 05/04/2023 16:11

FWD (Import) REV (Export)

UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

Work scheduled by: NGrid

### PLSNTVLY\_345KV\_RNS5

Thu 06/08/2023 to Sat 06/17/2023  
0001 Continuous 1200

UPDATED by NYISO 05/04/2023 16:11

FWD (Import) REV (Export)

UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

Work scheduled by: NGrid

### VNWAGNER-PLSNTVLY\_345\_Y59

Thu 06/08/2023 to Sat 06/17/2023  
0001 Continuous 1200

UPDATED by NYISO 05/04/2023 16:11

FWD (Import) REV (Export)

UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

Work scheduled by: NGrid

### MARCY\_\_765\_345\_AT1

Sat 06/10/2023 to Sat 06/10/2023  
0500 Continuous 1930

ARR: 19

FWD (Import) REV (Export)

MOSES SOUTH **1750 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA

### MARCY\_\_765\_345\_AT2

Sun 06/11/2023 to Sun 06/11/2023  
0500 Continuous 1930

ARR: 19

FWD (Import) REV (Export)

MOSES SOUTH **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

Work scheduled by: NYPA



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, May 20, 2023 to Tuesday, November 19, 2024

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6000 MW  
UPNY CONED 7815 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MOTTHAVN-RAINEY\_\_345\_Q12

Fri 06/16/2023 to Fri 06/16/2023  
0130 Continuous 0200  
Work scheduled by: ConEd

SPR/DUN-SOUTH FWD (Import) REV (Export)  
**3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

### LEEDS\_\_345KV\_R94301

Tue 06/20/2023 to Tue 06/20/2023  
0830 Continuous 1100  
Work scheduled by: NGrid

UPNY CONED FWD (Import) REV (Export)  
**3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

### NIAGARA\_-PACKARD\_\_230\_62

Mon 06/26/2023 to Fri 06/30/2023  
0500 Continuous 1900  
Work scheduled by: NYPA

SCH - OH - NY FWD (Import) REV (Export)  
**1500 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 1900 MW

### NIAGARA\_345\_230\_AT4

Wed 06/28/2023 to Thu 06/29/2023  
0500 Continuous 1900  
Work scheduled by: NYPA

SCH - OH - NY FWD (Import) REV (Export)  
**1150 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 1550 MW

### MARCY\_-EDIC\_\_345\_UE1-7

Sat 07/08/2023 to Sun 07/09/2023 UPDATED by NYPA 10/28/2022 10:56  
0500 Continuous 1900  
Work scheduled by: NYPA ARR: 19,16

OSWEGO EXPORT FWD (Import) REV (Export)  
**5250 MW**  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

### OSWEGO\_-VOLNEY\_\_345\_11

Tue 07/11/2023 to Mon 07/31/2023  
0600 Continuous 1700  
Work scheduled by: NGrid

OSWEGO EXPORT FWD (Import) REV (Export)  
**5250 MW**  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, May 20, 2023 to Tuesday, November 19, 2024

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6000 MW  
UPNY CONED 7815 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MARCY\_\_-EDIC\_\_345\_UE1-7

Sat 07/15/2023 to Sun 07/16/2023  
0500 Continuous 1930  
Work scheduled by: NYPA

UPDATED by NYPA 10/28/2022 11:17

ARR: 19,16

OSWEGO EXPORT  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**5250 MW**  
0 MW  
5250 MW

### ADIRNDCK-PORTER\_\_230\_12

Sun 07/16/2023 to Sun 07/16/2023  
0700 Continuous 1530  
Work scheduled by: NYPA

UPDATED by NYPA 12/14/2022 14:55

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**2100 MW**  
1050 MW  
3150 MW

### MOSES\_\_-ADIRNDCK\_230\_MA2

Sun 07/16/2023 to Sun 07/16/2023  
0700 Continuous 1530  
Work scheduled by: NYPA

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**2100 MW**  
1050 MW  
3150 MW

### SCH-IMO\_NY\_NIAG\_CB\_3122\_W/BB

Mon 07/17/2023 to Fri 07/28/2023  
0500 Continuous 2100  
Work scheduled by: NYPA

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1800 MW** **1300 MW**  
100 MW 250 MW  
1900 MW 1550 MW

### ADIRNDCK-CHASLAKE\_230\_13

Mon 07/17/2023 to Mon 07/17/2023  
0700 Continuous 1730  
Work scheduled by: NYPA

UPDATED by NYPA 02/17/2023 15:10

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**2100 MW**  
1050 MW  
3150 MW

### MOSES\_\_-ADIRNDCK\_230\_MA1

Mon 07/17/2023 to Mon 07/17/2023  
0700 Continuous 1730  
Work scheduled by: NYPA

UPDATED by NYPA 02/17/2023 15:10

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**2100 MW**  
1050 MW  
3150 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, May 20, 2023 to Tuesday, November 19, 2024

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6000 MW  
UPNY CONED 7815 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### ADIRNDCK-CHASLAKE\_230\_13

Tue 07/18/2023 to Fri 09/15/2023  
0630 Continuous 1600  
Work scheduled by: NGrid

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
2100 MW	
1050 MW	
3150 MW	

### HURLYAVE-ROSETON\_345\_303

Mon 07/31/2023 to Fri 08/25/2023  
0800 Continuous 1600  
Work scheduled by: CHGE

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
4100 MW	
3715 MW	
7815 MW	

### DYSINGER-STA\_255\_345\_DH2

Fri 08/04/2023 to Mon 08/14/2023  
0500 Continuous 2300  
Work scheduled by: NYPA

DYSINGER EAST  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
2850 MW	
350 MW	
3200 MW	

### SCH-IMO\_NY\_NIAG\_SOUTH\_BUS\_W/BB

Mon 08/07/2023 to Fri 08/11/2023  
0500 Continuous 1900  
Work scheduled by: NYPA

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
1300 MW	1100 MW
600 MW	450 MW
1900 MW	1550 MW

### OSWEGO\_-VOLNEY\_345\_12

Tue 08/08/2023 to Mon 08/28/2023  
0600 Continuous 1700  
Work scheduled by: NGrid

OSWEGO EXPORT  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
5250 MW	
0 MW	
5250 MW	

### DYSINGER-STA\_255\_345\_DH1

Tue 08/15/2023 to Fri 08/25/2023  
0500 Continuous 2300  
Work scheduled by: NYPA

DYSINGER EAST  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
2850 MW	
350 MW	
3200 MW	



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, May 20, 2023 to Tuesday, November 19, 2024

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6000 MW  
UPNY CONED 7815 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MARCY\_\_-EDIC\_\_345\_UE1-7

Sat 08/19/2023 to Sun 08/20/2023  
0500 Continuous 1930  
Work scheduled by: NYPA

UPDATED by NYPA 04/26/2023 09:32

ARR: 19,16

OSWEGO EXPORT  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**5250 MW**  
0 MW  
5250 MW

### NIAGARA\_345\_230\_AT4

Mon 08/28/2023 to Fri 09/01/2023  
0500 Continuous 2100  
Work scheduled by: NYPA

UPDATED by NYPA 03/16/2023 08:43

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1150 MW**  
400 MW  
1550 MW

### BUCHAN\_N-EASTVIEW\_345\_W93

Mon 09/04/2023 to Mon 09/04/2023  
0001 Continuous 0030  
Work scheduled by: ConEd

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**4350 MW**  
3465 MW  
7815 MW

### RAMAPO\_-BUCHAN\_N\_345\_Y94

Mon 09/04/2023 to Fri 09/22/2023  
0001 Continuous 0200  
Work scheduled by: ConEd

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**7580 MW**  
235 MW  
7815 MW

### SPRNBK\_345KV\_RNS4

Mon 09/11/2023 to Wed 09/13/2023  
0001 Continuous 0100  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3200 MW**  
1400 MW  
4600 MW

### SPRNBK\_-W49TH\_ST\_345\_M52

Mon 09/11/2023 to Wed 09/13/2023  
0001 Continuous 0100  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3200 MW**  
1400 MW  
4600 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, May 20, 2023 to Tuesday, November 19, 2024

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6000 MW  
UPNY CONED 7815 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### W49TH\_ST\_345KV\_5

Mon 09/11/2023 to Wed 09/13/2023

0001 Continuous 0100

Work scheduled by: ConEd

SCH - PJM\_HTP

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**300 MW**

360 MW

660 MW

### CLAY\_\_-EDIC\_\_345\_1-16

Mon 09/11/2023 to Fri 09/15/2023

0700 Continuous 1530

Work scheduled by: NYPA

UPDATED by NYISO 02/22/2023 09:21

OSWEGO EXPORT

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**4850 MW**

400 MW

5250 MW

### FRASER\_\_GILBOA\_\_345\_GF5-35

Mon 09/11/2023 to Sun 09/17/2023

0700 Continuous 1530

Work scheduled by: NYPA

CENTRAL EAST - VC

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**2450 MW**

270 MW

2720 MW

### LONG\_MTN-CRICKVLY\_345\_398

Fri 09/15/2023 to Sun 10/01/2023

0001 Continuous 2200

Work scheduled by: ConEd

SCH - NPX\_1385

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**100 MW**

**100 MW**

100 MW

100 MW

200 MW

200 MW

### LONG\_MTN-CRICKVLY\_345\_398

Fri 09/15/2023 to Sun 10/01/2023

0001 Continuous 2200

Work scheduled by: ConEd

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**500 MW**

**1150 MW**

900 MW

450 MW

1400 MW

1600 MW

### SPRNBK\_345KV\_RNS5

Fri 09/15/2023 to Wed 10/25/2023

0001 Continuous 0100

Work scheduled by: ConEd

UPDATED by ConEd 04/21/2023 14:42

SPR/DUN-SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**3200 MW**

1400 MW

4600 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, May 20, 2023 to Tuesday, November 19, 2024

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6000 MW  
UPNY CONED 7815 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SPRNBK\_W49TH\_ST\_345\_M51

Fri 09/15/2023 to Wed 10/25/2023  
0001 Continuous 0100

UPDATED by ConEd 04/21/2023 14:42

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

**3200 MW**

Impacts Total Transfer Capability

1400 MW

TTC with All Lines In Service

4600 MW

Work scheduled by: ConEd

### CHASLAKE-PORTER\_\_230\_11

Sat 09/16/2023 to Sun 10/15/2023  
0630 Continuous 1730

UPDATED by NGrid 02/01/2023 11:03

MOSES SOUTH

FWD (Import)

REV (Export)

**2100 MW**

Impacts Total Transfer Capability

1050 MW

TTC with All Lines In Service

3150 MW

Work scheduled by: NGrid

### CLAY\_\_EDIC\_\_345\_2-15

Mon 09/18/2023 to Fri 09/22/2023  
0700 Continuous 1530

OSWEGO EXPORT

FWD (Import)

REV (Export)

**4850 MW**

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

5250 MW

Work scheduled by: NYPA

### BUCHAN\_N-EASTVIEW\_345\_W93

Fri 09/22/2023 to Fri 09/22/2023  
0130 Continuous 0200

UPNY CONED

FWD (Import)

REV (Export)

**4350 MW**

Impacts Total Transfer Capability

3465 MW

TTC with All Lines In Service

7815 MW

Work scheduled by: ConEd

### MARCY\_\_EDIC\_\_345\_UE1-7

Sat 09/23/2023 to Sun 09/24/2023  
0500 Continuous 1900

UPDATED by NYPA 10/28/2022 11:09

OSWEGO EXPORT

FWD (Import)

REV (Export)

**5250 MW**

Impacts Total Transfer Capability

0 MW

TTC with All Lines In Service

5250 MW

Work scheduled by: NYPA

ARR: 19,16

### NIAGARA\_DYSINGER\_345\_ND2

Mon 09/25/2023 to Fri 09/29/2023  
0500 Continuous 2000

DYSINGER EAST

FWD (Import)

REV (Export)

**2700 MW**

Impacts Total Transfer Capability

500 MW

TTC with All Lines In Service

3200 MW

Work scheduled by: NYPA



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, May 20, 2023 to Tuesday, November 19, 2024

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6000 MW  
UPNY CONED 7815 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MARCY\_\_345KV\_CSC

Mon 09/25/2023 to Sat 10/07/2023  
0700 Continuous 1530  
Work scheduled by: NYPA

FWD (Import) REV (Export)  
CENTRAL EAST - VC **2535 MW**  
Impacts Total Transfer Capability 185 MW  
TTC with All Lines In Service 2720 MW

### ROSETON\_-EFISHKIL\_345\_RFK305

Mon 09/25/2023 to Fri 10/13/2023  
0700 Continuous 1530  
Work scheduled by: NYPA

FWD (Import) REV (Export)  
UPNY CONED **6680 MW**  
Impacts Total Transfer Capability 1135 MW  
TTC with All Lines In Service 7815 MW

### SHOR\_NPX-SHOREHAM\_138\_CSC

Mon 10/02/2023 to Fri 10/06/2023  
0600 Continuous 1800  
Work scheduled by: LI

FWD (Import) REV (Export)  
SCH - NPX\_CSC **0 MW** **0 MW**  
Impacts Total Transfer Capability 330 MW 330 MW  
TTC with All Lines In Service 330 MW 330 MW

### ROSETON\_-ROCKTVRN\_345\_311

Mon 10/02/2023 to Fri 11/03/2023  
0800 Continuous 1600  
Work scheduled by: CHGE

FWD (Import) REV (Export)  
UPNY CONED **4400 MW**  
Impacts Total Transfer Capability 3415 MW  
TTC with All Lines In Service 7815 MW

### DUNWODIE\_345KV\_4

Wed 10/04/2023 to Fri 11/10/2023  
0001 Continuous 2200  
Work scheduled by: ConEd

FWD (Import) REV (Export)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

### GILBOA\_-N.SCTLND\_345\_GNS-1

Mon 10/09/2023 to Fri 10/13/2023  
0700 Continuous 1530  
Work scheduled by: NYPA

FWD (Import) REV (Export)  
CENTRAL EAST - VC **2300 MW**  
Impacts Total Transfer Capability 420 MW  
TTC with All Lines In Service 2720 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, May 20, 2023 to Tuesday, November 19, 2024

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6000 MW  
UPNY CONED 7815 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### NIAGARA\_PACKARD\_230\_61

Fri 10/13/2023 to Fri 10/13/2023  
0500 Continuous 1900  
Work scheduled by: NYPA

SCH - OH - NY  
Impacts Total Transfer Capability 1350 MW  
TTC with All Lines In Service 200 MW  
1550 MW

### FRASANNX-COOPERS\_345\_UCC2-41

Mon 10/16/2023 to Fri 10/27/2023  
0600 Continuous 1730  
Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC  
Impacts Total Transfer Capability 2275 MW  
TTC with All Lines In Service 445 MW  
2720 MW

### MARCY\_-FRASANNX\_345\_UCC2-41

Mon 10/16/2023 to Fri 10/27/2023  
0600 Continuous 1730  
Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC  
Impacts Total Transfer Capability 2275 MW  
TTC with All Lines In Service 445 MW  
2720 MW

### ADIRNDCK-CHASLAKE\_230\_13

Mon 10/16/2023 to Tue 11/14/2023  
0630 Continuous 1730  
Work scheduled by: NGrid

UPDATED by NGrid 11/07/2022 15:17

MOSES SOUTH  
Impacts Total Transfer Capability 2100 MW  
TTC with All Lines In Service 1050 MW  
3150 MW

### DUNWODIE\_345KV\_6

Mon 10/23/2023 to Thu 11/09/2023  
0001 Continuous 2200  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability 3800 MW  
TTC with All Lines In Service 800 MW  
4600 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, May 20, 2023 to Tuesday, November 19, 2024

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6000 MW  
UPNY CONED 7815 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### DUNWODIE-SHORE\_RD\_345\_Y50

Mon 10/23/2023 to Thu 11/09/2023

0001 Continuous 2200

Work scheduled by: ConEd

CONED - LIPA

FWD (Import)

REV (Export)

**800 MW**

Impacts Total Transfer Capability

700 MW

TTC with All Lines In Service

1500 MW

### SHORE\_RD\_345\_138\_BK 1

Mon 10/23/2023 to Thu 11/09/2023

0001 Continuous 2200

Work scheduled by: ConEd

CONED - LIPA

FWD (Import)

REV (Export)

**1350 MW**

Impacts Total Transfer Capability

150 MW

TTC with All Lines In Service

1500 MW

### SHORE\_RD\_345\_138\_BK 2

Mon 10/23/2023 to Thu 11/09/2023

0001 Continuous 2200

Work scheduled by: ConEd

CONED - LIPA

FWD (Import)

REV (Export)

**1350 MW**

Impacts Total Transfer Capability

150 MW

TTC with All Lines In Service

1500 MW

### NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE

Wed 11/01/2023 to Mon 11/20/2023

0001 Continuous 2359

Work scheduled by: LI

UPDATED by LI 04/22/2023 14:51

SCH - PJM\_NEPTUNE

FWD (Import)

REV (Export)

**0 MW**

Impacts Total Transfer Capability

660 MW

TTC with All Lines In Service

660 MW

### NEWBRDGE\_345\_138\_BK\_1

Wed 11/01/2023 to Mon 11/20/2023

0001 Continuous 2359

Work scheduled by: LI

UPDATED by LI 04/22/2023 14:51

SCH - PJM\_NEPTUNE

FWD (Import)

REV (Export)

**375 MW**

Impacts Total Transfer Capability

285 MW

TTC with All Lines In Service

660 MW

### NEWBRDGE\_345\_138\_BK\_2

Wed 11/01/2023 to Mon 11/20/2023

0001 Continuous 2359

Work scheduled by: LI

UPDATED by LI 04/22/2023 14:51

SCH - PJM\_NEPTUNE

FWD (Import)

REV (Export)

**375 MW**

Impacts Total Transfer Capability

285 MW

TTC with All Lines In Service

660 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, May 20, 2023 to Tuesday, November 19, 2024

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6000 MW  
UPNY CONED 7815 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### NEWBRDGE-DUFFYAVE\_345\_501

Wed 11/01/2023 to Mon 11/20/2023  
0001 Continuous 2359

UPDATED by LI 04/22/2023 14:51

SCH - PJM\_NEPTUNE

FWD (Import)

REV (Export)

**0 MW**

Impacts Total Transfer Capability

660 MW

TTC with All Lines In Service

660 MW

Work scheduled by: LI

### DUNWODIE\_345KV\_3

Mon 11/06/2023 to Thu 11/09/2023  
0001 Continuous 2200

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

**3800 MW**

Impacts Total Transfer Capability

800 MW

TTC with All Lines In Service

4600 MW

Work scheduled by: ConEd

### LONG\_MTN-CRICKVLY\_345\_398

Mon 11/06/2023 to Thu 11/30/2023  
0001 Continuous 2200

SCH - NPX\_1385

FWD (Import)

REV (Export)

**100 MW**

**100 MW**

Impacts Total Transfer Capability

100 MW

100 MW

TTC with All Lines In Service

200 MW

200 MW

Work scheduled by: ConEd

### LONG\_MTN-CRICKVLY\_345\_398

Mon 11/06/2023 to Thu 11/30/2023  
0001 Continuous 2200

SCH - NE - NY

FWD (Import)

REV (Export)

**700 MW**

**1200 MW**

Impacts Total Transfer Capability

900 MW

600 MW

TTC with All Lines In Service

1600 MW

1800 MW

Work scheduled by: ConEd

### PLSNTVLE-DUNWODIE\_345\_W89

Mon 11/06/2023 to Thu 11/09/2023  
0001 Continuous 2200

UPNY CONED

FWD (Import)

REV (Export)

**4000 MW**

Impacts Total Transfer Capability

3815 MW

TTC with All Lines In Service

7815 MW

Work scheduled by: ConEd

### LINDN\_CG-LNDVFT\_\_345\_V-3022

Mon 11/06/2023 to Thu 11/09/2023  
0800 Continuous 1500

SCH - PJM\_VFT

FWD (Import)

REV (Export)

**0 MW**

**0 MW**

Impacts Total Transfer Capability

315 MW

315 MW

TTC with All Lines In Service

315 MW

315 MW

Work scheduled by: PJM



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, May 20, 2023 to Tuesday, November 19, 2024

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6000 MW  
UPNY CONED 7815 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### HURLYAVE-ROSETON\_345\_303

Mon 11/13/2023 to Fri 12/22/2023  
0800 Continuous 1600  
Work scheduled by: CHGE

UPNY CONED  
Impacts Total Transfer Capability 4100 MW  
TTC with All Lines In Service 3715 MW  
7815 MW

FWD (Import) REV (Export)

### CHATGUAY-MASSENA\_765\_7040

Wed 11/15/2023 to Mon 11/27/2023  
0700 Continuous 1730  
Work scheduled by: NYPA

SCH - HQ - NY  
Impacts Total Transfer Capability 0 MW 0 MW  
TTC with All Lines In Service 1500 MW 1000 MW  
1500 MW 1000 MW

FWD (Import) REV (Export)

### CHATGUAY-MASSENA\_765\_7040

Wed 11/15/2023 to Mon 11/27/2023  
0700 Continuous 1730  
Work scheduled by: NYPA

MOSES SOUTH  
Impacts Total Transfer Capability 1550 MW  
TTC with All Lines In Service 1600 MW  
3150 MW

FWD (Import) REV (Export)

### CHATGUAY-MASSENA\_765\_7040 , MASSENA-MARCY\_765\_MSU1

Wed 11/15/2023 to Mon 11/27/2023  
0700 Continuous 1730  
Work scheduled by:

MOSES SOUTH  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 2650 MW  
3150 MW

FWD (Import) REV (Export)

### MASSENA-MARCY\_765\_MSU1

Wed 11/15/2023 to Mon 11/27/2023  
0700 Continuous 1730  
Work scheduled by: NYPA

CENTRAL EAST - VC  
Impacts Total Transfer Capability 1720 MW  
TTC with All Lines In Service 1000 MW  
2720 MW

FWD (Import) REV (Export)



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, May 20, 2023 to Tuesday, November 19, 2024

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6000 MW  
UPNY CONED 7815 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MASSENA\_-MARCY\_\_\_765\_MSU1

Wed 11/15/2023 to Mon 11/27/2023  
0700 Continuous 1730  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS	<b>90 MW</b>	
Impacts Total Transfer Capability	189 MW	
TTC with All Lines In Service	279 MW	

### MASSENA\_-MARCY\_\_\_765\_MSU1

Wed 11/15/2023 to Mon 11/27/2023  
0700 Continuous 1730  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - HQ - NY	<b>475 MW</b>	<b>1000 MW</b>
Impacts Total Transfer Capability	1025 MW	0 MW
TTC with All Lines In Service	1500 MW	1000 MW

### MASSENA\_-MARCY\_\_\_765\_MSU1

Wed 11/15/2023 to Mon 11/27/2023  
0700 Continuous 1730  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
MOSES SOUTH	<b>500 MW</b>	
Impacts Total Transfer Capability	2650 MW	
TTC with All Lines In Service	3150 MW	

### MOSES\_-MASSENA\_230\_MMS1 , MOSES\_-MASSENA\_230\_MMS2

Wed 11/15/2023 to Mon 11/20/2023  
0700 1530  
Work scheduled by:

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS	<b>90 MW</b>	
Impacts Total Transfer Capability	189 MW	
TTC with All Lines In Service	279 MW	

### MOSES\_-MASSENA\_230\_MMS1 , MOSES\_-MASSENA\_230\_MMS2

Wed 11/15/2023 to Mon 11/20/2023  
0700 1530  
Work scheduled by:

	FWD (Import)	REV (Export)
SCH - HQ - NY	<b>850 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	650 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

### LINDN\_CG-LNDVFT\_\_\_345\_V-3022

Wed 11/15/2023 to Wed 11/15/2023  
1500 Continuous 1700  
Work scheduled by: PJM

	FWD (Import)	REV (Export)
SCH - PJM_VFT	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	315 MW	315 MW
TTC with All Lines In Service	315 MW	315 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, May 20, 2023 to Tuesday, November 19, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2720 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### ADIRNDCK-PORTER\_\_230\_12

Fri 12/01/2023 to Fri 05/31/2024  
0530 Continuous 1700  
Work scheduled by: NGrid

	FWD (Import)	REV (Export)
MOSES SOUTH	<b>2300 MW</b>	
Impacts Total Transfer Capability	850 MW	
TTC with All Lines In Service	3150 MW	

### NIAGARA\_345\_230\_AT4

Mon 12/04/2023 to Fri 12/08/2023  
0500 Continuous 1900  
Work scheduled by: NYPA

UPDATED by NYPA 03/21/2023 14:25

	FWD (Import)	REV (Export)
SCH - OH - NY		<b>1650 MW</b>
Impacts Total Transfer Capability		350 MW
TTC with All Lines In Service		2000 MW

### S.RIPLEY-DUNKIRK\_\_230\_68

Mon 12/04/2023 to Fri 12/08/2023  
0800 Continuous 1600  
Work scheduled by: PJM

	FWD (Import)	REV (Export)
SCH - PJ - NY		
Impacts Total Transfer Capability		
TTC with All Lines In Service		

### HOMR\_NYW-PIERC\_NY\_345\_48

Fri 12/08/2023 to Fri 12/15/2023  
0800 Continuous 1600  
Work scheduled by: PJM

UPDATED by PJM 07/28/2022 14:08

	FWD (Import)	REV (Export)
SCH - PJ - NY		
Impacts Total Transfer Capability		
TTC with All Lines In Service		

### LONG\_MTN-CRICKVLY\_345\_398

Tue 12/12/2023 to Thu 12/21/2023  
0001 Continuous 2200  
Work scheduled by: ConEd

CANCELLED by TO 05/18/2023 16:03

	FWD (Import)	REV (Export)
SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, May 20, 2023 to Tuesday, November 19, 2024

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6000 MW  
UPNY CONED 7815 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### LONG\_MTN-CRICKVLY\_345\_398

Tue 12/12/2023 to Thu 12/21/2023  
0001 Continuous 2200

CANCELLED by TO 05/18/2023 16:03

SCH - NE - NY

FWD (Import)

REV (Export)

**700 MW**

**1200 MW**

Impacts Total Transfer Capability

900 MW

600 MW

TTC with All Lines In Service

1600 MW

1800 MW

Work scheduled by: ConEd

### RAMAPO\_-LADENTWN\_345\_W72

Thu 12/21/2023 to Fri 12/22/2023  
0001 Continuous 0259

UPNY CONED

FWD (Import)

REV (Export)

**4400 MW**

Impacts Total Transfer Capability

3415 MW

TTC with All Lines In Service

7815 MW

Work scheduled by: ConEd

### E13THSTA-FARRAGUT\_345\_46

Sat 12/23/2023 to Mon 12/25/2023  
0001 Continuous 0300

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

**3800 MW**

Impacts Total Transfer Capability

800 MW

TTC with All Lines In Service

4600 MW

Work scheduled by: ConEd

### S.RIPLEY-DUNKIRK\_230\_68

Wed 12/27/2023 to Fri 12/29/2023  
0730 Continuous 1600

SCH - PJ - NY

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: NGrid

### PLSNTVLY\_345KV\_RNS5

Tue 01/02/2024 to Tue 01/02/2024  
0001 Continuous 0030

UPNY CONED

FWD (Import)

REV (Export)

**3800 MW**

Impacts Total Transfer Capability

4015 MW

TTC with All Lines In Service

7815 MW

Work scheduled by: ConEd

### PLSNTVLY-WOOD\_ST\_345\_F30

Tue 01/02/2024 to Tue 01/16/2024  
0001 Continuous 2000

UPNY CONED

FWD (Import)

REV (Export)

**4000 MW**

Impacts Total Transfer Capability

3815 MW

TTC with All Lines In Service

7815 MW

Work scheduled by: ConEd



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, May 20, 2023 to Tuesday, November 19, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2720 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### W49TH\_ST\_345KV\_6

Mon 01/15/2024 to Mon 02/19/2024  
0201 Continuous 0201  
Work scheduled by: ConEd

SCH - PJM_HTP	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	310 MW	
TTC with All Lines In Service	350 MW	
	660 MW	

### W49TH\_ST-E13THSTA\_345\_M55

Mon 01/15/2024 to Mon 02/19/2024  
0201 Continuous 0201  
Work scheduled by: ConEd

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	3800 MW	
TTC with All Lines In Service	800 MW	
	4600 MW	

### BECK\_\_PACKARD\_230\_BP76

Mon 01/15/2024 to Fri 01/19/2024  
0400 Continuous 1700  
Work scheduled by: NGrid

SCH - OH - NY	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	1800 MW	1350 MW
TTC with All Lines In Service	600 MW	650 MW
	2400 MW	2000 MW

### PLSNTVLY\_345KV\_RNS5

Tue 01/16/2024 to Tue 01/16/2024  
1930 Continuous 2000  
Work scheduled by: ConEd

UPNY CONED	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	3800 MW	
TTC with All Lines In Service	4015 MW	
	7815 MW	

### PLSNTVLY\_345KV\_RNS5

Wed 01/17/2024 to Wed 01/17/2024  
0001 Continuous 0030  
Work scheduled by: ConEd

UPNY CONED	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	3800 MW	
TTC with All Lines In Service	4015 MW	
	7815 MW	

### PLSNTVLY-WOOD\_ST\_345\_F30

Wed 01/17/2024 to Wed 01/17/2024  
0001 Continuous 0030  
Work scheduled by: ConEd

UPNY CONED	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	4000 MW	
TTC with All Lines In Service	3815 MW	
	7815 MW	



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, May 20, 2023 to Tuesday, November 19, 2024

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6000 MW  
UPNY CONED 7815 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### E13THSTA-FARRAGUT\_345\_46

Tue 01/30/2024 to Sun 02/04/2024  
0700 Continuous 0300  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
**3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

### PLSNTVLY\_345KV\_RNS5

Wed 01/31/2024 to Wed 01/31/2024  
1930 Continuous 2000  
Work scheduled by: ConEd

UPNY CONED  
**3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

### PLSNTVLY-WOOD\_ST\_345\_F30

Wed 01/31/2024 to Wed 01/31/2024  
1930 Continuous 2000  
Work scheduled by: ConEd

UPNY CONED  
**4000 MW**  
Impacts Total Transfer Capability 3815 MW  
TTC with All Lines In Service 7815 MW

### ATHENS\_-VNWAGNER\_345\_91

Thu 02/15/2024 to Sat 02/17/2024  
0001 Continuous 0200  
Work scheduled by: ConEd

UPNY CONED  
**3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

### EASTVIEW-SPRNBK\_345\_W78

Thu 02/15/2024 to Thu 02/15/2024  
0001 Continuous 0030  
Work scheduled by: ConEd

UPNY CONED  
**4350 MW**  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

### MILLWOOD-EASTVIEW\_345\_W85

Thu 02/15/2024 to Sat 02/17/2024  
0001 Continuous 0200  
Work scheduled by: ConEd

UPNY CONED  
**7550 MW**  
Impacts Total Transfer Capability 265 MW  
TTC with All Lines In Service 7815 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, May 20, 2023 to Tuesday, November 19, 2024

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6000 MW  
UPNY CONED 7815 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### PLSNTVLY\_345KV\_RNS4

Thu 02/15/2024 to Thu 03/28/2024

0001 Continuous 0200

Work scheduled by: ConEd

UPNY CONED

FWD (Import)

REV (Export)

**3800 MW**

Impacts Total Transfer Capability

4015 MW

TTC with All Lines In Service

7815 MW

### PLSNTVLY-WOOD\_ST\_345\_F31

Thu 02/15/2024 to Thu 03/28/2024

0001 Continuous 0200

Work scheduled by: ConEd

UPNY CONED

FWD (Import)

REV (Export)

**4000 MW**

Impacts Total Transfer Capability

3815 MW

TTC with All Lines In Service

7815 MW

### VNWAGNER-PLSNTVLY\_345\_Y58

Thu 02/15/2024 to Sat 02/17/2024

0001 Continuous 0200

Work scheduled by: ConEd

UPNY CONED

FWD (Import)

REV (Export)

**3800 MW**

Impacts Total Transfer Capability

4015 MW

TTC with All Lines In Service

7815 MW

### W49TH\_ST\_345KV\_8

Thu 02/15/2024 to Thu 02/22/2024

0001 Continuous 0200

Work scheduled by: ConEd

SCH - PJM\_HTP

FWD (Import)

REV (Export)

**310 MW**

Impacts Total Transfer Capability

350 MW

TTC with All Lines In Service

660 MW

### MILLWOOD\_345KV\_18

Sat 02/17/2024 to Sun 02/25/2024

0001 Continuous 0200

Work scheduled by: ConEd

UPNY CONED

FWD (Import)

REV (Export)

**4350 MW**

Impacts Total Transfer Capability

3465 MW

TTC with All Lines In Service

7815 MW

### EASTVIEW-SPRNBK\_345\_W78

Sat 02/17/2024 to Sat 02/17/2024

0130 Continuous 0200

Work scheduled by: ConEd

UPNY CONED

FWD (Import)

REV (Export)

**4350 MW**

Impacts Total Transfer Capability

3465 MW

TTC with All Lines In Service

7815 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, May 20, 2023 to Tuesday, November 19, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2720 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### W49TH\_ST\_345KV\_6

Thu 02/29/2024 to Mon 04/01/2024  
0001 Continuous 0200  
Work scheduled by: ConEd

SCH - PJM_HTP	FWD (Import)	REV (Export)
	<b>310 MW</b>	
Impacts Total Transfer Capability	350 MW	
TTC with All Lines In Service	660 MW	

### MILLWOOD\_345KV\_18

Sun 03/17/2024 to Fri 03/22/2024  
0001 Continuous 0200  
Work scheduled by: ConEd

UPNY CONED	FWD (Import)	REV (Export)
	<b>4350 MW</b>	
Impacts Total Transfer Capability	3465 MW	
TTC with All Lines In Service	7815 MW	

### ATHENS\_VNWAGNER\_345\_91

Tue 03/19/2024 to Sat 03/23/2024  
0001 Continuous 2359  
Work scheduled by: ConEd

UPNY CONED	FWD (Import)	REV (Export)
	<b>3800 MW</b>	
Impacts Total Transfer Capability	4015 MW	
TTC with All Lines In Service	7815 MW	

### VNWAGNER-PLSNTVLY\_345\_Y58

Tue 03/19/2024 to Sat 03/23/2024  
0001 Continuous 2359  
Work scheduled by: ConEd

UPNY CONED	FWD (Import)	REV (Export)
	<b>3800 MW</b>	
Impacts Total Transfer Capability	4015 MW	
TTC with All Lines In Service	7815 MW	

### EASTVIEW-SPRNBK\_345\_W78

Fri 03/22/2024 to Fri 03/22/2024  
0201 Continuous 0230  
Work scheduled by: ConEd

UPNY CONED	FWD (Import)	REV (Export)
	<b>4350 MW</b>	
Impacts Total Transfer Capability	3465 MW	
TTC with All Lines In Service	7815 MW	

### MILLWOOD-EASTVIEW\_345\_W85

Fri 03/22/2024 to Thu 03/28/2024  
0201 Continuous 0200  
Work scheduled by: ConEd

UPNY CONED	FWD (Import)	REV (Export)
	<b>7550 MW</b>	
Impacts Total Transfer Capability	265 MW	
TTC with All Lines In Service	7815 MW	



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, May 20, 2023 to Tuesday, November 19, 2024

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6000 MW  
UPNY CONED 7815 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SPRNBK\_345KV\_RNS3

Fri 03/22/2024 to Fri 03/22/2024  
0201 Continuous 0230  
Work scheduled by: ConEd

SPR/DUN-SOUTH FWD (Import) REV (Export)  
**3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

### W49TH\_ST\_345KV\_8

Tue 03/26/2024 to Mon 04/01/2024  
0001 Continuous 0200  
Work scheduled by: ConEd

SCH - PJM\_HTP FWD (Import) REV (Export)  
**310 MW**  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 660 MW

### W49TH\_ST-E13THSTA\_345\_M55

Wed 03/27/2024 to Sat 03/30/2024  
0001 Continuous 0200  
Work scheduled by: ConEd

SPR/DUN-SOUTH FWD (Import) REV (Export)  
**3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

### EASTVIEW-SPRNBK\_345\_W78

Thu 03/28/2024 to Thu 03/28/2024  
0130 Continuous 0200  
Work scheduled by: ConEd

UPNY CONED FWD (Import) REV (Export)  
**4350 MW**  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

### PANNELL\_-CLAY\_345\_1

Mon 04/22/2024 to Fri 04/26/2024  
0700 Continuous 1530  
Work scheduled by: NYPA

WEST CENTRAL FWD (Import) REV (Export)  
**1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

### PANNELL\_-CLAY\_345\_2

Mon 04/29/2024 to Fri 05/03/2024  
0700 Continuous 1530  
Work scheduled by: NYPA

WEST CENTRAL FWD (Import) REV (Export)  
**1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, May 20, 2023 to Tuesday, November 19, 2024

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6000 MW  
UPNY CONED 7815 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SHOR\_NPX-SHOREHAM\_138\_CSC

Mon 05/06/2024 to Fri 05/10/2024  
0600 Continuous 1800

Work scheduled by: LI

SCH - NPX\_CSC

FWD (Import)

REV (Export)

0 MW

0 MW

Impacts Total Transfer Capability

330 MW

330 MW

TTC with All Lines In Service

330 MW

330 MW

### FITZPTRK-EDIC\_345\_FE-1

Mon 05/20/2024 to Fri 05/24/2024  
0700 Continuous 1530

Work scheduled by: NYPA

OSWEGO EXPORT

FWD (Import)

REV (Export)

4800 MW

Impacts Total Transfer Capability

450 MW

TTC with All Lines In Service

5250 MW

### FITZPTRK-EDIC\_345\_FE-1

Mon 05/20/2024 to Fri 05/24/2024  
0700 Continuous 1530

Work scheduled by: NYPA

CENTRAL EAST - VC

FWD (Import)

REV (Export)

2480 MW

Impacts Total Transfer Capability

240 MW

TTC with All Lines In Service

2720 MW

### FITZPTRK-EDIC\_345\_FE-1

Tue 05/28/2024 to Fri 05/31/2024  
0700 Continuous 1530

Work scheduled by: NYPA

OSWEGO EXPORT

FWD (Import)

REV (Export)

4800 MW

Impacts Total Transfer Capability

450 MW

TTC with All Lines In Service

5250 MW

### FITZPTRK-EDIC\_345\_FE-1

Tue 05/28/2024 to Fri 05/31/2024  
0700 Continuous 1530

Work scheduled by: NYPA

CENTRAL EAST - VC

FWD (Import)

REV (Export)

2480 MW

Impacts Total Transfer Capability

240 MW

TTC with All Lines In Service

2720 MW

### CHASLAKE-PORTER\_230\_11

Sat 06/01/2024 to Fri 11/15/2024  
0530 Continuous 1700

Work scheduled by: NGrid

MOSES SOUTH

FWD (Import)

REV (Export)

2100 MW

Impacts Total Transfer Capability

1050 MW

TTC with All Lines In Service

3150 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, May 20, 2023 to Tuesday, November 19, 2024

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6000 MW  
UPNY CONED 7815 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### ROCHESTR-PANNELL\_345\_RP1

Mon 09/09/2024 to Fri 09/13/2024  
0700 Continuous 1530  
Work scheduled by: NYPA

DYSINGER EAST  
**2300 MW**  
Impacts Total Transfer Capability 900 MW  
TTC with All Lines In Service 3200 MW

### ROCHESTR-PANNELL\_345\_RP2

Mon 09/16/2024 to Fri 09/20/2024  
0700 Continuous 1530  
Work scheduled by: NYPA

DYSINGER EAST  
**2300 MW**  
Impacts Total Transfer Capability 900 MW  
TTC with All Lines In Service 3200 MW

### PANNELL-CLAY\_345\_1

Mon 09/23/2024 to Fri 09/27/2024  
0700 Continuous 1530  
Work scheduled by: NYPA

WEST CENTRAL  
**1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

### FITZPTRK-EDIC\_345\_FE-1

Mon 09/30/2024 to Fri 10/04/2024  
1700 Continuous 1530  
Work scheduled by: NYPA

OSWEGO EXPORT  
**4800 MW**  
Impacts Total Transfer Capability 450 MW  
TTC with All Lines In Service 5250 MW

### FITZPTRK-EDIC\_345\_FE-1

Mon 09/30/2024 to Fri 10/04/2024  
1700 Continuous 1530  
Work scheduled by: NYPA

CENTRAL EAST - VC  
**2480 MW**  
Impacts Total Transfer Capability 240 MW  
TTC with All Lines In Service 2720 MW

### NEPTUNE-DUFFYAVE\_345\_NEPTUNE

Mon 10/07/2024 to Fri 10/11/2024  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE  
**0 MW**  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, May 20, 2023 to Tuesday, November 19, 2024

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6000 MW  
UPNY CONED 7815 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### NEWBRDGE\_345\_138\_BK\_1

Mon 10/07/2024 to Fri 10/11/2024  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
375 MW	
285 MW	
660 MW	

### NEWBRDGE\_345\_138\_BK\_2

Mon 10/07/2024 to Fri 10/11/2024  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
375 MW	
285 MW	
660 MW	

### NEWBRDGE-DUFFYAVE\_345\_501

Mon 10/07/2024 to Fri 10/11/2024  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
0 MW	
660 MW	
660 MW	

### SHOR\_NPX-SHOREHAM\_138\_CSC

Mon 10/07/2024 to Fri 10/11/2024  
0600 Continuous 1800  
Work scheduled by: LI

SCH - NPX\_CSC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
0 MW	0 MW
330 MW	330 MW
330 MW	330 MW

### GILBOA\_-N.SCTLND\_345\_GNS-1

Mon 10/07/2024 to Fri 10/11/2024  
0700 Continuous 1530  
Work scheduled by: NYPA

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
2300 MW	
420 MW	
2720 MW	