

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, May 22, 2023 to Thursday, November 21, 2024

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6000 MW  
UPNY CONED 7815 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE\_345KV\_10\_BYPASS , DUNWODIE\_345KV\_9\_BYPASS ,  
SPRNBK\_345KV\_R4S3\_BYPASS , SPRNBK\_345KV\_R5S3\_BYPASS  
Sun 02/01/2015 to Sat 02/01/2025  
0000 0000  
Work scheduled by:

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	<b>4350 MW</b>	
Impacts Total Transfer Capability	250 MW	
TTC with All Lines In Service	4600 MW	

DUNWODIE\_345KV\_10\_BYPASS , DUNWODIE\_345KV\_9\_BYPASS ,  
SPRNBK\_345KV\_R4S3\_BYPASS , SPRNBK\_345KV\_R5S3\_BYPASS  
Sun 02/01/2015 to Sat 02/01/2025  
0000 0000  
Work scheduled by:

	FWD (Import)	REV (Export)
UPNY CONED	<b>7505 MW</b>	
Impacts Total Transfer Capability	310 MW	
TTC with All Lines In Service	7815 MW	

HUDSONP\_-FARRAGUT\_345\_B3402  
Mon 01/15/2018 to Sat 09/30/2023  
0001 Continuous 2359 EXT FORCED by ConEd 08/06/2022 16:26  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - PJ - NY	<b>2050 MW</b>	
Impacts Total Transfer Capability	200 MW	
TTC with All Lines In Service	2250 MW	

MARION\_-FARRAGUT\_345\_C3403  
Mon 01/15/2018 to Sat 09/30/2023  
0001 Continuous 2359 EXT FORCED by ConEd 08/06/2022 16:26  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - PJ - NY	<b>2050 MW</b>	
Impacts Total Transfer Capability	200 MW	
TTC with All Lines In Service	2250 MW	

MARION\_-FARRAGUT\_345\_C3403 , HUDSONP\_-  
FARRAGUT\_345\_B3402  
Mon 01/15/2018 to Sat 09/30/2023  
0001 2359  
Work scheduled by:

	FWD (Import)	REV (Export)
SCH - PJ - NY	<b>2000 MW</b>	<b>1150 MW</b>
Impacts Total Transfer Capability	250 MW	50 MW
TTC with All Lines In Service	2250 MW	1200 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, May 22, 2023 to Thursday, November 21, 2024

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6000 MW  
UPNY CONED 7815 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### EGRDNCTY\_345\_138\_AT1

Sat 10/01/2022 to Wed 05/31/2023  
0001 Continuous 2359

UPDATED by ConEd 10/01/2022 09:02

CONED - LIPA

FWD (Import)

REV (Export)

**1250 MW**

Impacts Total Transfer Capability

250 MW

TTC with All Lines In Service

1500 MW

Work scheduled by: LI

### EGRDNCTY\_345\_138\_AT2

Sat 10/01/2022 to Wed 05/31/2023  
0001 Continuous 2359

UPDATED by ConEd 10/01/2022 09:02

CONED - LIPA

FWD (Import)

REV (Export)

**1250 MW**

Impacts Total Transfer Capability

250 MW

TTC with All Lines In Service

1500 MW

Work scheduled by: LI

### SPRNBK\_-EGRDNCTR\_345\_Y49

Sat 10/01/2022 to Wed 05/31/2023  
0001 Continuous 2359

UPDATED by ConEd 10/01/2022 09:02

CONED - LIPA

FWD (Import)

REV (Export)

**775 MW**

Impacts Total Transfer Capability

725 MW

TTC with All Lines In Service

1500 MW

Work scheduled by: LI

### STLAWRNC-MOSES\_230\_L34P

Mon 10/03/2022 to Mon 11/06/2023  
1800 Continuous 0800

UPDATED by IESO 03/07/2023 10:12

SCH - OH - NY

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: IESO

### CHASLAKE-PORTER\_230\_11

Tue 02/21/2023 to Sat 07/15/2023  
0630 Continuous 1730

UPDATED by NGrid 02/01/2023 11:03

MOSES SOUTH

FWD (Import)

REV (Export)

**2100 MW**

Impacts Total Transfer Capability

1050 MW

TTC with All Lines In Service

3150 MW

Work scheduled by: NGrid

### MOSES\_-ADIRNDCK\_230\_MA1

Sun 03/05/2023 to Fri 05/26/2023  
2000 Continuous 1930

MOSES SOUTH

FWD (Import)

REV (Export)

**2100 MW**

Impacts Total Transfer Capability

1050 MW

TTC with All Lines In Service

3150 MW

Work scheduled by: NYPA

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, May 22, 2023 to Thursday, November 21, 2024

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6000 MW  
UPNY CONED 7815 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### LEEDS\_\_HURLYAVE\_345\_301

Tue 05/02/2023 to Fri 06/02/2023  
0800 Continuous 1700  
Work scheduled by: CHGE

FWD (Import) REV (Export)  
UPNY CONED **4100 MW**  
Impacts Total Transfer Capability 3715 MW  
TTC with All Lines In Service 7815 MW

### SCH-IMO-NYISO\_LIMIT\_1450

Fri 05/05/2023 to Tue 10/31/2023  
0001 Continuous 2359  
Work scheduled by: NYISO

FWD (Import) REV (Export)  
SCH - OH - NY **1750 MW**  
Impacts Total Transfer Capability 150 MW  
TTC with All Lines In Service 1900 MW

### VOLNEY\_\_MARCY\_\_345\_19

Sat 05/06/2023 to Sun 05/28/2023  
0500 Continuous 1900  
Work scheduled by: NYPA

ARR: 19

FWD (Import) REV (Export)  
OSWEGO EXPORT **4900 MW**  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 5250 MW

### VOLNEY\_\_MARCY\_\_345\_19

Sat 05/06/2023 to Sun 05/28/2023  
0500 Continuous 1900  
Work scheduled by: NYPA

ARR: 19

FWD (Import) REV (Export)  
CENTRAL EAST - VC **2575 MW**  
Impacts Total Transfer Capability 145 MW  
TTC with All Lines In Service 2720 MW

### SCH-NYISO-HQ\_LIMIT\_800

Thu 05/18/2023 to Fri 05/26/2023  
1901 Continuous 1800  
Work scheduled by: HQ

FWD (Import) REV (Export)  
SCH - HQ - NY **800 MW**  
Impacts Total Transfer Capability 200 MW  
TTC with All Lines In Service 1000 MW

### MARCY\_\_345KV\_CSC

Fri 05/19/2023 to Tue 05/23/2023  
0500 Continuous 1900  
Work scheduled by: NYPA

UPDATED by NYPA 10/05/2022 11:11

FWD (Import) REV (Export)  
CENTRAL EAST - VC **2535 MW**  
Impacts Total Transfer Capability 185 MW  
TTC with All Lines In Service 2720 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, May 22, 2023 to Thursday, November 21, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2720 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>NRTH1385-NOR HBR_138_601</b>					FWD (Import)	REV (Export)
Mon 05/22/2023	to	Fri 06/30/2023		SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
0500	Continuous	2359		Impacts Total Transfer Capability	100 MW	100 MW
Work scheduled by: LI				TTC with All Lines In Service	200 MW	200 MW
<b>NRTH1385-NOR HBR_138_602</b>					FWD (Import)	REV (Export)
Mon 05/22/2023	to	Fri 06/30/2023		SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
0500	Continuous	2359		Impacts Total Transfer Capability	100 MW	100 MW
Work scheduled by: LI				TTC with All Lines In Service	200 MW	200 MW
<b>NRTH1385-NOR HBR_138_603</b>					FWD (Import)	REV (Export)
Mon 05/22/2023	to	Fri 06/30/2023		SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
0500	Continuous	2359		Impacts Total Transfer Capability	100 MW	100 MW
Work scheduled by: LI				TTC with All Lines In Service	200 MW	200 MW
<b>NRTH1385-NORHBR_138_601 , NRTH1385-NORHBR_138_602</b>					FWD (Import)	REV (Export)
Mon 05/22/2023	to	Fri 06/30/2023		SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
0500		2359		Impacts Total Transfer Capability	200 MW	200 MW
Work scheduled by:				TTC with All Lines In Service	200 MW	200 MW
<b>NRTH1385-NORHBR_138_601 , NRTH1385-NORHBR_138_603</b>					FWD (Import)	REV (Export)
Mon 05/22/2023	to	Fri 06/30/2023		SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
0500		2359		Impacts Total Transfer Capability	200 MW	200 MW
Work scheduled by:				TTC with All Lines In Service	200 MW	200 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, May 22, 2023 to Thursday, November 21, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2720 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### NRTH1385-NORHBR\_\_138\_602 , NRTH1385-NORHBR\_\_138\_603

Mon 05/22/2023 to Fri 06/30/2023  
0500 2359

Work scheduled by:

SCH - NPX\_1385

FWD (Import)

REV (Export)

**0 MW**

**0 MW**

Impacts Total Transfer Capability

200 MW

200 MW

TTC with All Lines In Service

200 MW

200 MW

### NRTH1385-NRTHPORT\_138\_NNC

Mon 05/22/2023 to Fri 06/30/2023  
0500 Continuous 2359

Work scheduled by: LI

SCH - NPX\_1385

FWD (Import)

REV (Export)

**0 MW**

**0 MW**

Impacts Total Transfer Capability

200 MW

200 MW

TTC with All Lines In Service

200 MW

200 MW

### MOTTHAVN-RAINEY\_\_345\_Q12

Mon 05/22/2023 to Tue 05/23/2023  
2200 Continuous 0400

Work scheduled by: ConEd

UPDATED by ConEd 05/19/2023 09:07

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

**3800 MW**

Impacts Total Transfer Capability

800 MW

TTC with All Lines In Service

4600 MW

### ATHENS\_-VNWAGNER\_345\_91

Thu 05/25/2023 to Tue 06/06/2023  
0001 Continuous 1200

Work scheduled by: NGrid

UPDATED by NYISO 05/04/2023 16:03

UPNY CONED

FWD (Import)

REV (Export)

**3800 MW**

Impacts Total Transfer Capability

4015 MW

TTC with All Lines In Service

7815 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, May 22, 2023 to Thursday, November 21, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2720 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### PLSNTVLY\_345KV\_RNS4

Thu 05/25/2023 to Tue 06/06/2023

0001 Continuous 1200

Work scheduled by: NGrid

UPDATED by NYISO 05/04/2023 16:03

UPNY CONED

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**3800 MW**

4015 MW

7815 MW

### VNWAGNER-PLSNTVLY\_345\_Y58

Thu 05/25/2023 to Tue 06/06/2023

0001 Continuous 1200

Work scheduled by: NGrid

UPDATED by NYISO 05/04/2023 16:03

UPNY CONED

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**3800 MW**

4015 MW

7815 MW

### CHATGUAY-MASSENA\_765\_7040

Tue 05/30/2023 to Tue 05/30/2023

0001 Continuous 2359

Work scheduled by: NYPA

UPDATED by NYPA 05/11/2023 11:43

SCH - HQ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**0 MW**

1500 MW

1500 MW

**0 MW**

1000 MW

1000 MW

### CHATGUAY-MASSENA\_765\_7040

Tue 05/30/2023 to Tue 05/30/2023

0001 Continuous 2359

Work scheduled by: NYPA

UPDATED by NYPA 05/11/2023 11:43

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**1550 MW**

1600 MW

3150 MW

### CHATGUAY-MASSENA\_765\_7040 , MASSENA-MARCY\_765\_MSU1

Tue 05/30/2023 to Tue 05/30/2023

0001 2359

Work scheduled by:

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**500 MW**

2650 MW

3150 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, May 22, 2023 to Thursday, November 21, 2024

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6000 MW  
UPNY CONED 7815 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MARCY\_\_\_765\_345\_AT1

Tue 05/30/2023 to Tue 05/30/2023  
0001 Continuous 2359  
Work scheduled by: NYPA

UPDATED by NYPA 05/11/2023 11:43

ARR: 19

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1750 MW**  
1400 MW  
3150 MW

### MARCY\_\_\_765\_345\_AT2

Tue 05/30/2023 to Tue 05/30/2023  
0001 Continuous 2359  
Work scheduled by: NYPA

UPDATED by NYPA 05/11/2023 11:50

ARR: 19

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1700 MW**  
1450 MW  
3150 MW

### MASSENA\_-MARCY\_\_\_765\_MSU1

Tue 05/30/2023 to Tue 05/30/2023  
0001 Continuous 2359  
Work scheduled by: NYPA

UPDATED by NYPA 05/11/2023 11:43

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1720 MW**  
1000 MW  
2720 MW

### MASSENA\_-MARCY\_\_\_765\_MSU1

Tue 05/30/2023 to Tue 05/30/2023  
0001 Continuous 2359  
Work scheduled by: NYPA

UPDATED by NYPA 05/11/2023 11:43

SCH - HQ\_CEDARS  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**90 MW**  
180 MW  
270 MW

### MASSENA\_-MARCY\_\_\_765\_MSU1

Tue 05/30/2023 to Tue 05/30/2023  
0001 Continuous 2359  
Work scheduled by: NYPA

UPDATED by NYPA 05/11/2023 11:43

SCH - HQ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**475 MW 1000 MW**  
1025 MW 0 MW  
1500 MW 1000 MW

### MASSENA\_-MARCY\_\_\_765\_MSU1

Tue 05/30/2023 to Tue 05/30/2023  
0001 Continuous 2359  
Work scheduled by: NYPA

UPDATED by NYPA 05/11/2023 11:43

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**500 MW**  
2650 MW  
3150 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, May 22, 2023 to Thursday, November 21, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2720 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MASSENA_-MARCY__765_MSU1 , CHASLAKE-PORTER__230_11</b>				FWD (Import)	REV (Export)
Tue 05/30/2023	to	Tue 05/30/2023	SCH - HQ_CEDARS	<b>90 MW</b>	
0001		2359	Impacts Total Transfer Capability	180 MW	
Work scheduled by:			TTC with All Lines In Service	270 MW	
<b>MASSENA_-MARCY__765_MSU1 , STLAWRNC-MOSES__230_L34P</b>				FWD (Import)	REV (Export)
Tue 05/30/2023	to	Tue 05/30/2023	SCH - HQ_CEDARS	<b>90 MW</b>	
0001		2359	Impacts Total Transfer Capability	180 MW	
Work scheduled by:			TTC with All Lines In Service	270 MW	
<b>MASSENA_-MARCY__765_MSU1 , STLAWRNC-MOSES__230_L34P , CHASLAKE-PORTER__230_11</b>				FWD (Import)	REV (Export)
Tue 05/30/2023	to	Tue 05/30/2023	SCH - HQ_CEDARS	<b>90 MW</b>	
0001		2359	Impacts Total Transfer Capability	180 MW	
Work scheduled by:			TTC with All Lines In Service	270 MW	
<b>MOSES_-MASSENA_230_MMS1 , MOSES_-MASSENA_230_MMS2</b>				FWD (Import)	REV (Export)
Tue 05/30/2023	to	Tue 05/30/2023	SCH - HQ_CEDARS	<b>90 MW</b>	
0001		2359	Impacts Total Transfer Capability	180 MW	
Work scheduled by:			TTC with All Lines In Service	270 MW	



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, May 22, 2023 to Thursday, November 21, 2024

CENTRAL EAST 2650 MW  
 CENTRAL EAST - VC 2720 MW  
 TOTAL EAST 6000 MW  
 UPNY CONED 7815 MW  
 SPR/DUN-SOUTH 4600 MW  
 DYSINGER EAST 3200 MW  
 MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES\_\_-MASSENA\_230\_MMS1 , MOSES\_\_-MASSENA\_230\_MMS2

Tue 05/30/2023 to Tue 05/30/2023  
 0001 2359

Work scheduled by:

SCH - HQ - NY	FWD (Import)	REV (Export)
	<b>850 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	650 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

MOSES\_\_-MASSENA\_230\_MMS1 , MOSES\_\_-MASSENA\_230\_MMS2 ,  
 CHASLAKE-PORTER\_230\_11

Tue 05/30/2023 to Tue 05/30/2023  
 0001 2359

Work scheduled by:

SCH - HQ_CEDARS	FWD (Import)	REV (Export)
	<b>90 MW</b>	
Impacts Total Transfer Capability	180 MW	
TTC with All Lines In Service	270 MW	

MOSES\_\_-MASSENA\_230\_MMS1 , MOSES\_\_-MASSENA\_230\_MMS2 ,  
 STLAWRNC-MOSES\_230\_L34P

Tue 05/30/2023 to Tue 05/30/2023  
 0001 2359

Work scheduled by:

SCH - HQ_CEDARS	FWD (Import)	REV (Export)
	<b>90 MW</b>	
Impacts Total Transfer Capability	180 MW	
TTC with All Lines In Service	270 MW	

MOSES\_\_-MASSENA\_230\_MMS1 , MOSES\_\_-MASSENA\_230\_MMS2 ,  
 STLAWRNC-MOSES\_230\_L34P , CHASLAKE-PORTER\_230\_11

Tue 05/30/2023 to Tue 05/30/2023  
 0001 2359

Work scheduled by:

SCH - HQ_CEDARS	FWD (Import)	REV (Export)
	<b>90 MW</b>	
Impacts Total Transfer Capability	180 MW	
TTC with All Lines In Service	270 MW	

CHAT\_DC\_GC1

Tue 05/30/2023 to Tue 05/30/2023  
 0600 Continuous 2000

Work scheduled by: HQ

MOSES SOUTH	FWD (Import)	REV (Export)
	<b>2850 MW</b>	
Impacts Total Transfer Capability	300 MW	
TTC with All Lines In Service	3150 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, May 22, 2023 to Thursday, November 21, 2024

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6000 MW  
UPNY CONED 7815 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### CHAT\_DC\_GC1

Tue 05/30/2023 to Tue 05/30/2023  
0600 Continuous 2000

SCH - HQ - NY

FWD (Import)

REV (Export)

**500 MW**

Impacts Total Transfer Capability

500 MW

Work scheduled by: HQ

TTC with All Lines In Service

1000 MW

### MOTTHAVN-RAINEY\_\_345\_Q12

Thu 06/01/2023 to Thu 06/01/2023  
0101 Continuous 0130

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

**3800 MW**

Impacts Total Transfer Capability

800 MW

Work scheduled by: ConEd

TTC with All Lines In Service

4600 MW

### VOLNEY\_-MARCY\_\_345\_19

Sat 06/03/2023 to Sun 06/04/2023  
0500 Continuous 1730

ARR: 19

OSWEGO EXPORT

FWD (Import)

REV (Export)

**4900 MW**

Impacts Total Transfer Capability

350 MW

Work scheduled by: NYPA

TTC with All Lines In Service

5250 MW

### VOLNEY\_-MARCY\_\_345\_19

Sat 06/03/2023 to Sun 06/04/2023  
0500 Continuous 1730

ARR: 19

CENTRAL EAST - VC

FWD (Import)

REV (Export)

**2575 MW**

Impacts Total Transfer Capability

145 MW

Work scheduled by: NYPA

TTC with All Lines In Service

2720 MW

### ELBRIDGE-LAFAYTTE\_345\_17-LE

Wed 06/07/2023 to Wed 06/07/2023  
0630 Daily 1800

ARR: 75

OSWEGO EXPORT

FWD (Import)

REV (Export)

**5250 MW**

Impacts Total Transfer Capability

0 MW

Work scheduled by: NGrid

TTC with All Lines In Service

5250 MW

### OSWEGO\_-ELBRIDGE\_345\_17

Wed 06/07/2023 to Wed 06/07/2023  
0630 Daily 1800

ARR: 75

OSWEGO EXPORT

FWD (Import)

REV (Export)

**5250 MW**

Impacts Total Transfer Capability

0 MW

Work scheduled by: NGrid

TTC with All Lines In Service

5250 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, May 22, 2023 to Thursday, November 21, 2024

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6000 MW  
UPNY CONED 7815 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### LEEDS\_\_-VNWAGNER\_345\_92

Thu 06/08/2023 to Sat 06/17/2023

0001 Continuous 1200

Work scheduled by: NGrid

UPDATED by NYISO 05/04/2023 16:11

UPNY CONED

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**3800 MW**

4015 MW

7815 MW

### PLSNTVLY\_345KV\_RNS5

Thu 06/08/2023 to Sat 06/17/2023

0001 Continuous 1200

Work scheduled by: NGrid

UPDATED by NYISO 05/04/2023 16:11

UPNY CONED

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**3800 MW**

4015 MW

7815 MW

### VNWAGNER-PLSNTVLY\_345\_Y59

Thu 06/08/2023 to Sat 06/17/2023

0001 Continuous 1200

Work scheduled by: NGrid

UPDATED by NYISO 05/04/2023 16:11

UPNY CONED

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**3800 MW**

4015 MW

7815 MW

### MARCY\_\_765\_345\_AT1

Sat 06/10/2023 to Sat 06/10/2023

0500 Continuous 1930

Work scheduled by: NYPA

ARR: 19

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**1750 MW**

1400 MW

3150 MW

### MARCY\_\_765\_345\_AT2

Sun 06/11/2023 to Sun 06/11/2023

0500 Continuous 1930

Work scheduled by: NYPA

ARR: 19

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**1700 MW**

1450 MW

3150 MW

### MOTTHAVN-RAINEY\_\_345\_Q12

Fri 06/16/2023 to Fri 06/16/2023

0130 Continuous 0200

Work scheduled by: ConEd

SPR/DUN-SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**3800 MW**

800 MW

4600 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, May 22, 2023 to Thursday, November 21, 2024

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6000 MW  
UPNY CONED 7815 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### LEEDS\_\_345KV\_R94301

Tue 06/20/2023 to Tue 06/20/2023  
0830 Continuous 1100

Work scheduled by: NGrid

	FWD (Import)	REV (Export)
UPNY CONED	<b>3800 MW</b>	
Impacts Total Transfer Capability	4015 MW	
TTC with All Lines In Service	7815 MW	

### NIAGARA\_\_PACKARD\_\_230\_62

Mon 06/26/2023 to Fri 06/30/2023  
0500 Continuous 1900

Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - OH - NY	<b>1500 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1900 MW	

### NIAGARA\_\_345\_230\_AT4

Wed 06/28/2023 to Thu 06/29/2023  
0500 Continuous 1900

Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - OH - NY		<b>1150 MW</b>
Impacts Total Transfer Capability		400 MW
TTC with All Lines In Service		1550 MW

### MARCY\_\_EDIC\_\_345\_UE1-7

Sat 07/08/2023 to Sun 07/09/2023  
0500 Continuous 1900

Work scheduled by: NYPA

UPDATED by NYPA 10/28/2022 10:56

ARR: 19,16

	FWD (Import)	REV (Export)
OSWEGO EXPORT	<b>5250 MW</b>	
Impacts Total Transfer Capability	0 MW	
TTC with All Lines In Service	5250 MW	

### OSWEGO\_\_VOLNEY\_\_345\_11

Tue 07/11/2023 to Mon 07/31/2023  
0600 Continuous 1700

Work scheduled by: NGrid

	FWD (Import)	REV (Export)
OSWEGO EXPORT	<b>5250 MW</b>	
Impacts Total Transfer Capability	0 MW	
TTC with All Lines In Service	5250 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, May 22, 2023 to Thursday, November 21, 2024

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6000 MW  
UPNY CONED 7815 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MARCY\_\_-EDIC\_\_345\_UE1-7

Sat 07/15/2023 to Sun 07/16/2023

0500 Continuous 1930

Work scheduled by: NYPA

UPDATED by NYPA 10/28/2022 11:17

ARR: 19,16

OSWEGO EXPORT

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**5250 MW**

0 MW

5250 MW

### ADIRNDCK-PORTER\_\_230\_12

Sun 07/16/2023 to Sun 07/16/2023

0700 Continuous 1530

Work scheduled by: NYPA

UPDATED by NYPA 12/14/2022 14:55

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**2100 MW**

1050 MW

3150 MW

### MOSES\_\_-ADIRNDCK\_230\_MA2

Sun 07/16/2023 to Sun 07/16/2023

0700 Continuous 1530

Work scheduled by: NYPA

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**2100 MW**

1050 MW

3150 MW

### SCH-IMO\_NY\_NIAG\_CB\_3122\_W/BB

Mon 07/17/2023 to Fri 07/28/2023

0500 Continuous 2100

Work scheduled by: NYPA

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**1800 MW**

**1300 MW**

100 MW

250 MW

1900 MW

1550 MW

### ADIRNDCK-CHASLAKE\_230\_13

Mon 07/17/2023 to Mon 07/17/2023

0700 Continuous 1730

Work scheduled by: NYPA

UPDATED by NYPA 02/17/2023 15:10

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**2100 MW**

1050 MW

3150 MW

### MOSES\_\_-ADIRNDCK\_230\_MA1

Mon 07/17/2023 to Mon 07/17/2023

0700 Continuous 1730

Work scheduled by: NYPA

UPDATED by NYPA 02/17/2023 15:10

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**2100 MW**

1050 MW

3150 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, May 22, 2023 to Thursday, November 21, 2024

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6000 MW  
UPNY CONED 7815 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### ADIRNDCK-CHASLAKE\_230\_13

Tue 07/18/2023 to Fri 09/15/2023  
0630 Continuous 1600  
Work scheduled by: NGrid

MOSES SOUTH FWD (Import) REV (Export)  
**2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

### HURLYAVE-ROSETON\_345\_303

Mon 07/31/2023 to Fri 08/25/2023  
0800 Continuous 1600  
Work scheduled by: CHGE

UPNY CONED FWD (Import) REV (Export)  
**4100 MW**  
Impacts Total Transfer Capability 3715 MW  
TTC with All Lines In Service 7815 MW

### DYSINGER-STA\_255\_345\_DH2

Fri 08/04/2023 to Mon 08/14/2023  
0500 Continuous 2300  
Work scheduled by: NYPA

DYSINGER EAST FWD (Import) REV (Export)  
**2850 MW**  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 3200 MW

### SCH-IMO\_NY\_NIAG\_SOUTH\_BUS\_W/BB

Mon 08/07/2023 to Fri 08/11/2023  
0500 Continuous 1900  
Work scheduled by: NYPA

SCH - OH - NY FWD (Import) REV (Export)  
**1300 MW 1100 MW**  
Impacts Total Transfer Capability 600 MW 450 MW  
TTC with All Lines In Service 1900 MW 1550 MW

### OSWEGO\_-VOLNEY\_345\_12

Tue 08/08/2023 to Mon 08/28/2023  
0600 Continuous 1700  
Work scheduled by: NGrid

OSWEGO EXPORT FWD (Import) REV (Export)  
**5250 MW**  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

### DYSINGER-STA\_255\_345\_DH1

Tue 08/15/2023 to Fri 08/25/2023  
0500 Continuous 2300  
Work scheduled by: NYPA

DYSINGER EAST FWD (Import) REV (Export)  
**2850 MW**  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 3200 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, May 22, 2023 to Thursday, November 21, 2024

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6000 MW  
UPNY CONED 7815 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MARCY\_\_-EDIC\_\_345\_UE1-7

Sat 08/19/2023 to Sun 08/20/2023  
0500 Continuous 1930  
Work scheduled by: NYPA

UPDATED by NYPA 04/26/2023 09:32

ARR: 19,16

OSWEGO EXPORT  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**5250 MW**  
0 MW  
5250 MW

### NIAGARA\_345\_230\_AT4

Mon 08/28/2023 to Fri 09/01/2023  
0500 Continuous 2100  
Work scheduled by: NYPA

UPDATED by NYPA 03/16/2023 08:43

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1150 MW**  
400 MW  
1550 MW

### BUCHAN\_N-EASTVIEW\_345\_W93

Mon 09/04/2023 to Mon 09/04/2023  
0001 Continuous 0030  
Work scheduled by: ConEd

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**4350 MW**  
3465 MW  
7815 MW

### RAMAPO\_-BUCHAN\_N\_345\_Y94

Mon 09/04/2023 to Fri 09/22/2023  
0001 Continuous 0200  
Work scheduled by: ConEd

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**7580 MW**  
235 MW  
7815 MW

### E13THSTA-FARRAGUT\_345\_46

Sat 09/09/2023 to Sat 09/09/2023  
0101 Continuous 0130  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3800 MW**  
800 MW  
4600 MW

### E13THSTA-FARRAGUT\_345\_46

Sat 09/09/2023 to Sat 09/09/2023  
0530 Continuous 0600  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3800 MW**  
800 MW  
4600 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, May 22, 2023 to Thursday, November 21, 2024

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6000 MW  
UPNY CONED 7815 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SPRNBK\_345KV\_RNS4

Mon 09/11/2023 to Wed 09/13/2023  
0001 Continuous 0100  
Work scheduled by: ConEd

FWD (Import) REV (Export)  
SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

### SPRNBK\_-W49TH\_ST\_345\_M52

Mon 09/11/2023 to Wed 09/13/2023  
0001 Continuous 0100  
Work scheduled by: ConEd

FWD (Import) REV (Export)  
SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

### W49TH\_ST\_345KV\_5

Mon 09/11/2023 to Wed 09/13/2023  
0001 Continuous 0100  
Work scheduled by: ConEd

FWD (Import) REV (Export)  
SCH - PJM\_HTP **300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

### CLAY\_-EDIC\_345\_1-16

Mon 09/11/2023 to Fri 09/15/2023  
0700 Continuous 1530  
Work scheduled by: NYPA

UPDATED by NYISO 02/22/2023 09:21

FWD (Import) REV (Export)  
OSWEGO EXPORT **4850 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

### FRASER\_-GILBOA\_345\_GF5-35

Mon 09/11/2023 to Sun 09/17/2023  
0700 Continuous 1530  
Work scheduled by: NYPA

FWD (Import) REV (Export)  
CENTRAL EAST - VC **2450 MW**  
Impacts Total Transfer Capability 270 MW  
TTC with All Lines In Service 2720 MW

### LONG\_MTN-CRICKVLY\_345\_398

Fri 09/15/2023 to Sun 10/01/2023  
0001 Continuous 2200  
Work scheduled by: ConEd

FWD (Import) REV (Export)  
SCH - NPX\_1385 **100 MW** **100 MW**  
Impacts Total Transfer Capability 100 MW 100 MW  
TTC with All Lines In Service 200 MW 200 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, May 22, 2023 to Thursday, November 21, 2024

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6000 MW  
UPNY CONED 7815 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### LONG\_MTN-CRICKVLY\_345\_398

Fri 09/15/2023 to Sun 10/01/2023  
0001 Continuous 2200  
Work scheduled by: ConEd

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 500 MW  
REV (Export) 1150 MW  
900 MW 450 MW  
1400 MW 1600 MW

### SPRNBKR\_345KV\_RNS5

Fri 09/15/2023 to Wed 10/25/2023  
0001 Continuous 0100  
Work scheduled by: ConEd  
UPDATED by ConEd 04/21/2023 14:42

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 3200 MW  
REV (Export)  
1400 MW  
4600 MW

### SPRNBKR-W49TH\_ST\_345\_M51

Fri 09/15/2023 to Wed 10/25/2023  
0001 Continuous 0100  
Work scheduled by: ConEd  
UPDATED by ConEd 04/21/2023 14:42

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 3200 MW  
REV (Export)  
1400 MW  
4600 MW

### CHASLAKE-PORTER\_230\_11

Sat 09/16/2023 to Sun 10/15/2023  
0630 Continuous 1730  
Work scheduled by: NGrid  
UPDATED by NGrid 02/01/2023 11:03

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 2100 MW  
REV (Export)  
1050 MW  
3150 MW

### CLAY\_-EDIC\_345\_2-15

Mon 09/18/2023 to Fri 09/22/2023  
0700 Continuous 1530  
Work scheduled by: NYPA

OSWEGO EXPORT  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 4850 MW  
REV (Export)  
400 MW  
5250 MW

### BUCHAN\_N-EASTVIEW\_345\_W93

Fri 09/22/2023 to Fri 09/22/2023  
0130 Continuous 0200  
Work scheduled by: ConEd

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 4350 MW  
REV (Export)  
3465 MW  
7815 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, May 22, 2023 to Thursday, November 21, 2024

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6000 MW  
UPNY CONED 7815 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MARCY\_\_-EDIC\_\_345\_UE1-7

Sat 09/23/2023 to Sun 09/24/2023  
0500 Continuous 1900  
Work scheduled by: NYPA

UPDATED by NYPA 10/28/2022 11:09

ARR: 19,16

OSWEGO EXPORT  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**5250 MW**  
0 MW  
5250 MW

### NIAGARA\_-DYSINGER\_345\_ND2

Mon 09/25/2023 to Fri 09/29/2023  
0500 Continuous 2000  
Work scheduled by: NYPA

DYSINGER EAST  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**2700 MW**  
500 MW  
3200 MW

### MARCY\_\_345KV\_CSC

Mon 09/25/2023 to Sat 10/07/2023  
0700 Continuous 1530  
Work scheduled by: NYPA

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**2535 MW**  
185 MW  
2720 MW

### ROSETON\_-EFISHKIL\_345\_RFK305

Mon 09/25/2023 to Fri 10/13/2023  
0700 Continuous 1530  
Work scheduled by: NYPA

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**6680 MW**  
1135 MW  
7815 MW

### SHOR\_NPX-SHOREHAM\_138\_CSC

Mon 10/02/2023 to Fri 10/06/2023  
0600 Continuous 1800  
Work scheduled by: LI

SCH - NPX\_CSC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**0 MW** **0 MW**  
330 MW 330 MW  
330 MW 330 MW

### ROSETON\_-ROCKTVRN\_345\_311

Mon 10/02/2023 to Fri 11/03/2023  
0800 Continuous 1600  
Work scheduled by: CHGE

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**4400 MW**  
3415 MW  
7815 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, May 22, 2023 to Thursday, November 21, 2024

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6000 MW  
UPNY CONED 7815 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### DUNWODIE\_345KV\_4

Wed 10/04/2023 to Fri 11/10/2023  
0001 Continuous 2200  
Work scheduled by: ConEd

FWD (Import) REV (Export)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

### GILBOA\_-N.SCTLND\_345\_GNS-1

Mon 10/09/2023 to Fri 10/13/2023  
0700 Continuous 1530  
Work scheduled by: NYPA

FWD (Import) REV (Export)  
CENTRAL EAST - VC **2300 MW**  
Impacts Total Transfer Capability 420 MW  
TTC with All Lines In Service 2720 MW

### NIAGARA\_-PACKARD\_230\_61

Fri 10/13/2023 to Fri 10/13/2023  
0500 Continuous 1900  
Work scheduled by: NYPA

FWD (Import) REV (Export)  
SCH - OH - NY **1350 MW**  
Impacts Total Transfer Capability 200 MW  
TTC with All Lines In Service 1550 MW

### FRASANNX-COOPERS\_345\_UCC2-41

Mon 10/16/2023 to Fri 10/27/2023  
0600 Continuous 1730  
Work scheduled by: NYPA

ARR: 19

FWD (Import) REV (Export)  
CENTRAL EAST - VC **2275 MW**  
Impacts Total Transfer Capability 445 MW  
TTC with All Lines In Service 2720 MW

### MARCY\_-FRASANNX\_345\_UCC2-41

Mon 10/16/2023 to Fri 10/27/2023  
0600 Continuous 1730  
Work scheduled by: NYPA

ARR: 19

FWD (Import) REV (Export)  
CENTRAL EAST - VC **2275 MW**  
Impacts Total Transfer Capability 445 MW  
TTC with All Lines In Service 2720 MW

### ADIRNDCK-CHASLAKE\_230\_13

Mon 10/16/2023 to Tue 11/14/2023  
0630 Continuous 1730  
Work scheduled by: NGrid

UPDATED by NGrid 11/07/2022 15:17

FWD (Import) REV (Export)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, May 22, 2023 to Thursday, November 21, 2024

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6000 MW  
UPNY CONED 7815 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### DUNWODIE\_345KV\_6

Mon 10/23/2023 to Thu 11/09/2023  
0001 Continuous 2200  
Work scheduled by: ConEd

SPR/DUN-SOUTH FWD (Import) REV (Export)  
**3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

### DUNWODIE-SHORE\_RD\_345\_Y50

Mon 10/23/2023 to Thu 11/09/2023  
0001 Continuous 2200  
Work scheduled by: ConEd

CONED - LIPA FWD (Import) REV (Export)  
**800 MW**  
Impacts Total Transfer Capability 700 MW  
TTC with All Lines In Service 1500 MW

### SHORE\_RD\_345\_138\_BK 1

Mon 10/23/2023 to Thu 11/09/2023  
0001 Continuous 2200  
Work scheduled by: ConEd

CONED - LIPA FWD (Import) REV (Export)  
**1350 MW**  
Impacts Total Transfer Capability 150 MW  
TTC with All Lines In Service 1500 MW

### SHORE\_RD\_345\_138\_BK 2

Mon 10/23/2023 to Thu 11/09/2023  
0001 Continuous 2200  
Work scheduled by: ConEd

CONED - LIPA FWD (Import) REV (Export)  
**1350 MW**  
Impacts Total Transfer Capability 150 MW  
TTC with All Lines In Service 1500 MW

### NEPTUNE\_DUFFYAVE\_345\_NEPTUNE

Wed 11/01/2023 to Mon 11/20/2023  
0001 Continuous 2359 UPDATED by LI 04/22/2023 14:51  
Work scheduled by: LI

SCH - PJM\_NEPTUNE FWD (Import) REV (Export)  
**0 MW**  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

### NEWBRDGE\_345\_138\_BK\_1

Wed 11/01/2023 to Mon 11/20/2023  
0001 Continuous 2359 UPDATED by LI 04/22/2023 14:51  
Work scheduled by: LI

SCH - PJM\_NEPTUNE FWD (Import) REV (Export)  
**375 MW**  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 660 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, May 22, 2023 to Thursday, November 21, 2024

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6000 MW  
UPNY CONED 7815 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### NEWBRDGE\_345\_138\_BK\_2

Wed 11/01/2023 to Mon 11/20/2023  
0001 Continuous 2359

UPDATED by LI 04/22/2023 14:51

SCH - PJM\_NEPTUNE

FWD (Import)

REV (Export)

375 MW

Impacts Total Transfer Capability

285 MW

TTC with All Lines In Service

660 MW

Work scheduled by: LI

### NEWBRDGE-DUFFYAVE\_345\_501

Wed 11/01/2023 to Mon 11/20/2023  
0001 Continuous 2359

UPDATED by LI 04/22/2023 14:51

SCH - PJM\_NEPTUNE

FWD (Import)

REV (Export)

0 MW

Impacts Total Transfer Capability

660 MW

TTC with All Lines In Service

660 MW

Work scheduled by: LI

### DUNWODIE\_345KV\_3

Mon 11/06/2023 to Thu 11/09/2023  
0001 Continuous 2200

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

3800 MW

Impacts Total Transfer Capability

800 MW

TTC with All Lines In Service

4600 MW

Work scheduled by: ConEd

### LONG\_MTN-CRICKVLY\_345\_398

Mon 11/06/2023 to Thu 11/30/2023  
0001 Continuous 2200

SCH - NPX\_1385

FWD (Import)

REV (Export)

100 MW

100 MW

Impacts Total Transfer Capability

100 MW

100 MW

TTC with All Lines In Service

200 MW

200 MW

Work scheduled by: ConEd

### LONG\_MTN-CRICKVLY\_345\_398

Mon 11/06/2023 to Thu 11/30/2023  
0001 Continuous 2200

SCH - NE - NY

FWD (Import)

REV (Export)

700 MW

1200 MW

Impacts Total Transfer Capability

900 MW

600 MW

TTC with All Lines In Service

1600 MW

1800 MW

Work scheduled by: ConEd

### PLSNTVLE-DUNWODIE\_345\_W89

Mon 11/06/2023 to Thu 11/09/2023  
0001 Continuous 2200

UPNY CONED

FWD (Import)

REV (Export)

4000 MW

Impacts Total Transfer Capability

3815 MW

TTC with All Lines In Service

7815 MW

Work scheduled by: ConEd

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, May 22, 2023 to Thursday, November 21, 2024

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6000 MW  
UPNY CONED 7815 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### LINDN\_CG-LNDVFT\_\_345\_V-3022

Mon 11/06/2023 to Thu 11/09/2023  
0800 Continuous 1500  
Work scheduled by: PJM

	FWD (Import)	REV (Export)
SCH - PJM_VFT	0 MW	0 MW
Impacts Total Transfer Capability	315 MW	315 MW
TTC with All Lines In Service	315 MW	315 MW

### HURLYAVE-ROSETON\_\_345\_303

Mon 11/13/2023 to Fri 12/22/2023  
0800 Continuous 1600  
Work scheduled by: CHGE

	FWD (Import)	REV (Export)
UPNY CONED	4100 MW	
Impacts Total Transfer Capability	3715 MW	
TTC with All Lines In Service	7815 MW	

### CHATGUAY-MASSENA\_\_765\_7040

Wed 11/15/2023 to Mon 11/27/2023  
0700 Continuous 1730  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - HQ - NY	0 MW	0 MW
Impacts Total Transfer Capability	1500 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

### CHATGUAY-MASSENA\_\_765\_7040

Wed 11/15/2023 to Mon 11/27/2023  
0700 Continuous 1730  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
MOSES SOUTH	1550 MW	
Impacts Total Transfer Capability	1600 MW	
TTC with All Lines In Service	3150 MW	

### CHATGUAY-MASSENA\_\_765\_7040 , MASSENA\_-MARCY\_\_765\_MSU1

Wed 11/15/2023 to Mon 11/27/2023  
0700 1730  
Work scheduled by:

	FWD (Import)	REV (Export)
MOSES SOUTH	500 MW	
Impacts Total Transfer Capability	2650 MW	
TTC with All Lines In Service	3150 MW	

### MASSENA\_-MARCY\_\_765\_MSU1

Wed 11/15/2023 to Mon 11/27/2023  
0700 Continuous 1730  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
CENTRAL EAST - VC	1720 MW	
Impacts Total Transfer Capability	1000 MW	
TTC with All Lines In Service	2720 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, May 22, 2023 to Thursday, November 21, 2024

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6000 MW  
UPNY CONED 7815 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MASSENA\_MARCY\_\_765\_MSU1

Wed 11/15/2023 to Mon 11/27/2023  
0700 Continuous 1730  
Work scheduled by: NYPA

SCH - HQ\_CEDARS  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
90 MW	
189 MW	
279 MW	

### MASSENA\_MARCY\_\_765\_MSU1

Wed 11/15/2023 to Mon 11/27/2023  
0700 Continuous 1730  
Work scheduled by: NYPA

SCH - HQ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
475 MW	1000 MW
1025 MW	0 MW
1500 MW	1000 MW

### MASSENA\_MARCY\_\_765\_MSU1

Wed 11/15/2023 to Mon 11/27/2023  
0700 Continuous 1730  
Work scheduled by: NYPA

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
500 MW	
2650 MW	
3150 MW	

### MOSES\_-MASSENA\_230\_MMS1 , MOSES\_-MASSENA\_230\_MMS2

Wed 11/15/2023 to Mon 11/20/2023  
0700 1530  
Work scheduled by:

SCH - HQ\_CEDARS  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
90 MW	
189 MW	
279 MW	

### MOSES\_-MASSENA\_230\_MMS1 , MOSES\_-MASSENA\_230\_MMS2

Wed 11/15/2023 to Mon 11/20/2023  
0700 1530  
Work scheduled by:

SCH - HQ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
850 MW	0 MW
650 MW	1000 MW
1500 MW	1000 MW

### LINDN\_CG-LNDVFT\_\_345\_V-3022

Wed 11/15/2023 to Wed 11/15/2023  
1500 Continuous 1700  
Work scheduled by: PJM

SCH - PJM\_VFT  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
0 MW	0 MW
315 MW	315 MW
315 MW	315 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, May 22, 2023 to Thursday, November 21, 2024

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6000 MW  
UPNY CONED 7815 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### ADIRNDCK-PORTER\_\_230\_12

Fri 12/01/2023 to Fri 05/31/2024  
0530 Continuous 1700  
Work scheduled by: NGrid

MOSES SOUTH FWD (Import) REV (Export)  
**2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

### NIAGARA\_345\_230\_AT4

Mon 12/04/2023 to Fri 12/08/2023  
0500 Continuous 1900  
Work scheduled by: NYPA

UPDATED by NYPA 03/21/2023 14:25

SCH - OH - NY FWD (Import) REV (Export)  
**1650 MW**  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 2000 MW

### S.RIPLEY-DUNKIRK\_230\_68

Mon 12/04/2023 to Fri 12/08/2023  
0800 Continuous 1600  
Work scheduled by: PJM

SCH - PJ - NY FWD (Import) REV (Export)  
Impacts Total Transfer Capability  
TTC with All Lines In Service

### HOMR\_NYW-PIERC\_NY\_345\_48

Fri 12/08/2023 to Fri 12/15/2023  
0800 Continuous 1600  
Work scheduled by: PJM

UPDATED by PJM 07/28/2022 14:08

SCH - PJ - NY FWD (Import) REV (Export)  
Impacts Total Transfer Capability  
TTC with All Lines In Service

### LONG\_MTN-CRICKVLY\_345\_398

Tue 12/12/2023 to Thu 12/21/2023  
0001 Continuous 2200  
Work scheduled by: ConEd

CANCELLED by TO 05/18/2023 16:03

SCH - NPX\_1385 FWD (Import) REV (Export)  
**100 MW 100 MW**  
Impacts Total Transfer Capability 100 MW 100 MW  
TTC with All Lines In Service 200 MW 200 MW

### LONG\_MTN-CRICKVLY\_345\_398

Tue 12/12/2023 to Thu 12/21/2023  
0001 Continuous 2200  
Work scheduled by: ConEd

CANCELLED by TO 05/18/2023 16:03

SCH - NE - NY FWD (Import) REV (Export)  
**700 MW 1200 MW**  
Impacts Total Transfer Capability 900 MW 600 MW  
TTC with All Lines In Service 1600 MW 1800 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, May 22, 2023 to Thursday, November 21, 2024

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6000 MW  
UPNY CONED 7815 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### RAMAPO\_-LADENTWN\_345\_W72

Thu 12/21/2023 to Fri 12/22/2023  
0001 Continuous 0259

Work scheduled by: ConEd

UPNY CONED

FWD (Import)

REV (Export)

**4400 MW**

Impacts Total Transfer Capability

3415 MW

TTC with All Lines In Service

7815 MW

### E13THSTA-FARRAGUT\_345\_46

Sat 12/23/2023 to Mon 12/25/2023  
0001 Continuous 0300

Work scheduled by: ConEd

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

**3800 MW**

Impacts Total Transfer Capability

800 MW

TTC with All Lines In Service

4600 MW

### S.RIPLEY-DUNKIRK\_230\_68

Wed 12/27/2023 to Fri 12/29/2023  
0730 Continuous 1600

Work scheduled by: NGrid

SCH - PJ - NY

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

TTC with All Lines In Service

### PLSNTVLY\_345KV\_RNS5

Tue 01/02/2024 to Tue 01/02/2024  
0001 Continuous 0030

Work scheduled by: ConEd

UPNY CONED

FWD (Import)

REV (Export)

**3800 MW**

Impacts Total Transfer Capability

4015 MW

TTC with All Lines In Service

7815 MW

### PLSNTVLY-WOOD\_ST\_345\_F30

Tue 01/02/2024 to Tue 01/16/2024  
0001 Continuous 2000

Work scheduled by: ConEd

UPNY CONED

FWD (Import)

REV (Export)

**4000 MW**

Impacts Total Transfer Capability

3815 MW

TTC with All Lines In Service

7815 MW

### W49TH\_ST\_345KV\_6

Mon 01/15/2024 to Mon 02/19/2024  
0201 Continuous 0201

Work scheduled by: ConEd

SCH - PJM\_HTP

FWD (Import)

REV (Export)

**310 MW**

Impacts Total Transfer Capability

350 MW

TTC with All Lines In Service

660 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, May 22, 2023 to Thursday, November 21, 2024

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6000 MW  
UPNY CONED 7815 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>W49TH_ST-E13THSTA_345_M55</b>					FWD (Import)	REV (Export)
Mon 01/15/2024	to	Mon 02/19/2024		SPR/DUN-SOUTH	<b>3800 MW</b>	
0201	Continuous	0201		Impacts Total Transfer Capability	800 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	4600 MW	
<b>BECK__-PACKARD_230_BP76</b>					FWD (Import)	REV (Export)
Mon 01/15/2024	to	Fri 01/19/2024		SCH - OH - NY	<b>1800 MW</b>	<b>1350 MW</b>
0400	Continuous	1700		Impacts Total Transfer Capability	600 MW	650 MW
Work scheduled by: NGrid				TTC with All Lines In Service	2400 MW	2000 MW
<b>PLSNTVLY_345KV_RNS5</b>					FWD (Import)	REV (Export)
Tue 01/16/2024	to	Tue 01/16/2024		UPNY CONED	<b>3800 MW</b>	
1930	Continuous	2000		Impacts Total Transfer Capability	4015 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	7815 MW	
<b>PLSNTVLY_345KV_RNS5</b>					FWD (Import)	REV (Export)
Wed 01/17/2024	to	Wed 01/17/2024		UPNY CONED	<b>3800 MW</b>	
0001	Continuous	0030		Impacts Total Transfer Capability	4015 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	7815 MW	
<b>PLSNTVLY-WOOD_ST_345_F30</b>					FWD (Import)	REV (Export)
Wed 01/17/2024	to	Wed 01/17/2024		UPNY CONED	<b>4000 MW</b>	
0001	Continuous	0030		Impacts Total Transfer Capability	3815 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	7815 MW	
<b>E13THSTA-FARRAGUT_345_46</b>					FWD (Import)	REV (Export)
Tue 01/30/2024	to	Sun 02/04/2024		SPR/DUN-SOUTH	<b>3800 MW</b>	
0700	Continuous	0300		Impacts Total Transfer Capability	800 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	4600 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, May 22, 2023 to Thursday, November 21, 2024

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6000 MW  
UPNY CONED 7815 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### PLSNTVLY\_345KV\_RNS5

Wed 01/31/2024 to Wed 01/31/2024  
1930 Continuous 2000  
Work scheduled by: ConEd

FWD (Import) REV (Export)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

### PLSNTVLY-WOOD\_ST\_345\_F30

Wed 01/31/2024 to Wed 01/31/2024  
1930 Continuous 2000  
Work scheduled by: ConEd

FWD (Import) REV (Export)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 3815 MW  
TTC with All Lines In Service 7815 MW

### ATHENS\_-VNWAGNER\_345\_91

Thu 02/15/2024 to Sat 02/17/2024  
0001 Continuous 0200  
Work scheduled by: ConEd

FWD (Import) REV (Export)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

### EASTVIEW-SPRNBK\_345\_W78

Thu 02/15/2024 to Thu 02/15/2024  
0001 Continuous 0030  
Work scheduled by: ConEd

FWD (Import) REV (Export)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

### MILLWOOD-EASTVIEW\_345\_W85

Thu 02/15/2024 to Sat 02/17/2024  
0001 Continuous 0200  
Work scheduled by: ConEd

FWD (Import) REV (Export)  
UPNY CONED **7550 MW**  
Impacts Total Transfer Capability 265 MW  
TTC with All Lines In Service 7815 MW

### PLSNTVLY\_345KV\_RNS4

Thu 02/15/2024 to Thu 03/28/2024  
0001 Continuous 0200  
Work scheduled by: ConEd

FWD (Import) REV (Export)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, May 22, 2023 to Thursday, November 21, 2024

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6000 MW  
UPNY CONED 7815 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### PLSNTVLY-WOOD\_ST\_345\_F31

Thu 02/15/2024 to Thu 03/28/2024  
0001 Continuous 0200  
Work scheduled by: ConEd

FWD (Import) REV (Export)  
UPNY CONED **4000 MW**  
Impacts Total Transfer Capability 3815 MW  
TTC with All Lines In Service 7815 MW

### VNWAGNER-PLSNTVLY\_345\_Y58

Thu 02/15/2024 to Sat 02/17/2024  
0001 Continuous 0200  
Work scheduled by: ConEd

FWD (Import) REV (Export)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

### W49TH\_ST\_345KV\_8

Thu 02/15/2024 to Thu 02/22/2024  
0001 Continuous 0200  
Work scheduled by: ConEd

FWD (Import) REV (Export)  
SCH - PJM\_HTP **310 MW**  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 660 MW

### MILLWOOD\_345KV\_18

Sat 02/17/2024 to Sun 02/25/2024  
0001 Continuous 0200  
Work scheduled by: ConEd

FWD (Import) REV (Export)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

### EASTVIEW-SPRNBK\_345\_W78

Sat 02/17/2024 to Sat 02/17/2024  
0130 Continuous 0200  
Work scheduled by: ConEd

FWD (Import) REV (Export)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

### W49TH\_ST\_345KV\_6

Thu 02/29/2024 to Mon 04/01/2024  
0001 Continuous 0200  
Work scheduled by: ConEd

FWD (Import) REV (Export)  
SCH - PJM\_HTP **310 MW**  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 660 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, May 22, 2023 to Thursday, November 21, 2024

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6000 MW  
UPNY CONED 7815 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MILLWOOD\_345KV\_18

Sun 03/17/2024 to Fri 03/22/2024  
0001 Continuous 0200  
Work scheduled by: ConEd

FWD (Import) REV (Export)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

### ATHENS\_-VNWAGNER\_345\_91

Tue 03/19/2024 to Sat 03/23/2024  
0001 Continuous 2359  
Work scheduled by: ConEd

FWD (Import) REV (Export)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

### VNWAGNER-PLSNTVLY\_345\_Y58

Tue 03/19/2024 to Sat 03/23/2024  
0001 Continuous 2359  
Work scheduled by: ConEd

FWD (Import) REV (Export)  
UPNY CONED **3800 MW**  
Impacts Total Transfer Capability 4015 MW  
TTC with All Lines In Service 7815 MW

### EASTVIEW-SPRNBK\_345\_W78

Fri 03/22/2024 to Fri 03/22/2024  
0201 Continuous 0230  
Work scheduled by: ConEd

FWD (Import) REV (Export)  
UPNY CONED **4350 MW**  
Impacts Total Transfer Capability 3465 MW  
TTC with All Lines In Service 7815 MW

### MILLWOOD-EASTVIEW\_345\_W85

Fri 03/22/2024 to Thu 03/28/2024  
0201 Continuous 0200  
Work scheduled by: ConEd

FWD (Import) REV (Export)  
UPNY CONED **7550 MW**  
Impacts Total Transfer Capability 265 MW  
TTC with All Lines In Service 7815 MW

### SPRNBK\_345KV\_RNS3

Fri 03/22/2024 to Fri 03/22/2024  
0201 Continuous 0230  
Work scheduled by: ConEd

FWD (Import) REV (Export)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, May 22, 2023 to Thursday, November 21, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2720 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### W49TH\_ST\_345KV\_8

Tue 03/26/2024 to Mon 04/01/2024  
0001 Continuous 0200  
Work scheduled by: ConEd

SCH - PJM_HTP	FWD (Import)	REV (Export)
	<b>310 MW</b>	
Impacts Total Transfer Capability	350 MW	
TTC with All Lines In Service	660 MW	

### W49TH\_ST-E13THSTA\_345\_M55

Wed 03/27/2024 to Sat 03/30/2024  
0001 Continuous 0200  
Work scheduled by: ConEd

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

### EASTVIEW-SPRNBK\_345\_W78

Thu 03/28/2024 to Thu 03/28/2024  
0130 Continuous 0200  
Work scheduled by: ConEd

UPNY CONED	FWD (Import)	REV (Export)
	<b>4350 MW</b>	
Impacts Total Transfer Capability	3465 MW	
TTC with All Lines In Service	7815 MW	

### PANNELL-CLAY\_345\_1

Mon 04/22/2024 to Fri 04/26/2024  
0700 Continuous 1530  
Work scheduled by: NYPA

WEST CENTRAL	FWD (Import)	REV (Export)
	<b>1300 MW</b>	
Impacts Total Transfer Capability	950 MW	
TTC with All Lines In Service	2250 MW	

### PANNELL-CLAY\_345\_2

Mon 04/29/2024 to Fri 05/03/2024  
0700 Continuous 1530  
Work scheduled by: NYPA

WEST CENTRAL	FWD (Import)	REV (Export)
	<b>1300 MW</b>	
Impacts Total Transfer Capability	950 MW	
TTC with All Lines In Service	2250 MW	

### SHOR\_NPX-SHOREHAM\_138\_CSC

Mon 05/06/2024 to Fri 05/10/2024  
0600 Continuous 1800  
Work scheduled by: LI

SCH - NPX_CSC	FWD (Import)	REV (Export)
	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	330 MW	330 MW
TTC with All Lines In Service	330 MW	330 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, May 22, 2023 to Thursday, November 21, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2720 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### FITZPTRK-EDIC\_\_345\_FE-1

Mon 05/20/2024 to Fri 05/24/2024  
0700 Continuous 1530  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
OSWEGO EXPORT	<b>4800 MW</b>	
Impacts Total Transfer Capability	450 MW	
TTC with All Lines In Service	5250 MW	

### FITZPTRK-EDIC\_\_345\_FE-1

Mon 05/20/2024 to Fri 05/24/2024  
0700 Continuous 1530  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
CENTRAL EAST - VC	<b>2480 MW</b>	
Impacts Total Transfer Capability	240 MW	
TTC with All Lines In Service	2720 MW	

### FITZPTRK-EDIC\_\_345\_FE-1

Tue 05/28/2024 to Fri 05/31/2024  
0700 Continuous 1530  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
OSWEGO EXPORT	<b>4800 MW</b>	
Impacts Total Transfer Capability	450 MW	
TTC with All Lines In Service	5250 MW	

### FITZPTRK-EDIC\_\_345\_FE-1

Tue 05/28/2024 to Fri 05/31/2024  
0700 Continuous 1530  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
CENTRAL EAST - VC	<b>2480 MW</b>	
Impacts Total Transfer Capability	240 MW	
TTC with All Lines In Service	2720 MW	

### CHASLAKE-PORTER\_\_230\_11

Sat 06/01/2024 to Fri 11/15/2024  
0530 Continuous 1700  
Work scheduled by: NGrid

	FWD (Import)	REV (Export)
MOSES SOUTH	<b>2100 MW</b>	
Impacts Total Transfer Capability	1050 MW	
TTC with All Lines In Service	3150 MW	

### ROCHESTR-PANNELL\_\_345\_RP1

Mon 09/09/2024 to Fri 09/13/2024  
0700 Continuous 1530  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
DYSINGER EAST	<b>2300 MW</b>	
Impacts Total Transfer Capability	900 MW	
TTC with All Lines In Service	3200 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, May 22, 2023 to Thursday, November 21, 2024

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2720 MW
TOTAL EAST	6000 MW
UPNY CONED	7815 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### ROCHESTR-PANNELL\_345\_RP2

Mon 09/16/2024 to Fri 09/20/2024  
0700 Continuous 1530  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
DYSINGER EAST	<b>2300 MW</b>	
Impacts Total Transfer Capability	900 MW	
TTC with All Lines In Service	3200 MW	

### PANNELL-CLAY\_345\_1

Mon 09/23/2024 to Fri 09/27/2024  
0700 Continuous 1530  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
WEST CENTRAL	<b>1300 MW</b>	
Impacts Total Transfer Capability	950 MW	
TTC with All Lines In Service	2250 MW	

### FITZPTRK-EDIC\_345\_FE-1

Mon 09/30/2024 to Fri 10/04/2024  
1700 Continuous 1530  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
OSWEGO EXPORT	<b>4800 MW</b>	
Impacts Total Transfer Capability	450 MW	
TTC with All Lines In Service	5250 MW	

### FITZPTRK-EDIC\_345\_FE-1

Mon 09/30/2024 to Fri 10/04/2024  
1700 Continuous 1530  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
CENTRAL EAST - VC	<b>2480 MW</b>	
Impacts Total Transfer Capability	240 MW	
TTC with All Lines In Service	2720 MW	

### NEPTUNE-DUFFYAVE\_345\_NEPTUNE

Mon 10/07/2024 to Fri 10/11/2024  
0600 Continuous 1600  
Work scheduled by: LI

	FWD (Import)	REV (Export)
SCH - PJM_NEPTUNE	<b>0 MW</b>	
Impacts Total Transfer Capability	660 MW	
TTC with All Lines In Service	660 MW	



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, May 22, 2023 to Thursday, November 21, 2024

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6000 MW  
UPNY CONED 7815 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### NEWBRDGE\_345\_138\_BK\_1

Mon 10/07/2024 to Fri 10/11/2024  
0600 Continuous 1600  
Work scheduled by: LI

	FWD (Import)	REV (Export)
SCH - PJM_NEPTUNE	<b>375 MW</b>	
Impacts Total Transfer Capability	285 MW	
TTC with All Lines In Service	660 MW	

### NEWBRDGE\_345\_138\_BK\_2

Mon 10/07/2024 to Fri 10/11/2024  
0600 Continuous 1600  
Work scheduled by: LI

	FWD (Import)	REV (Export)
SCH - PJM_NEPTUNE	<b>375 MW</b>	
Impacts Total Transfer Capability	285 MW	
TTC with All Lines In Service	660 MW	

### NEWBRDGE-DUFFYAVE\_345\_501

Mon 10/07/2024 to Fri 10/11/2024  
0600 Continuous 1600  
Work scheduled by: LI

	FWD (Import)	REV (Export)
SCH - PJM_NEPTUNE	<b>0 MW</b>	
Impacts Total Transfer Capability	660 MW	
TTC with All Lines In Service	660 MW	

### SHOR\_NPX-SHOREHAM\_138\_CSC

Mon 10/07/2024 to Fri 10/11/2024  
0600 Continuous 1800  
Work scheduled by: LI

	FWD (Import)	REV (Export)
SCH - NPX_CSC	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	330 MW	330 MW
TTC with All Lines In Service	330 MW	330 MW

### GILBOA\_-N.SCTLND\_345\_GNS-1

Mon 10/07/2024 to Fri 10/11/2024  
0700 Continuous 1530  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
CENTRAL EAST - VC	<b>2300 MW</b>	
Impacts Total Transfer Capability	420 MW	
TTC with All Lines In Service	2720 MW	