

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, July 31, 2023 to Thursday, January 30, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE\_345KV\_10\_BYPASS , DUNWODIE\_345KV\_9\_BYPASS ,  
SPRNBK\_345KV\_R4S3\_BYPASS , SPRNBK\_345KV\_R5S3\_BYPASS

Sun 02/01/2015 to Sat 02/01/2025  
0000 0000

Work scheduled by:

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

**4350 MW**

Impacts Total Transfer Capability

250 MW

TTC with All Lines In Service

4600 MW

DUNWODIE\_345KV\_10\_BYPASS , DUNWODIE\_345KV\_9\_BYPASS ,  
SPRNBK\_345KV\_R4S3\_BYPASS , SPRNBK\_345KV\_R5S3\_BYPASS

Sun 02/01/2015 to Sat 02/01/2025  
0000 0000

Work scheduled by:

UPNY CONED

FWD (Import)

REV (Export)

**7505 MW**

Impacts Total Transfer Capability

545 MW

TTC with All Lines In Service

8050 MW

HUDSONP\_-FARRAGUT\_345\_B3402

Mon 01/15/2018 to Sat 09/30/2023  
0001 Continuous 2359

Work scheduled by: ConEd

EXT FORCED by ConEd 08/06/2022 16:26

SCH - PJ - NY

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

TTC with All Lines In Service

MARION\_-FARRAGUT\_345\_C3403

Mon 01/15/2018 to Sat 09/30/2023  
0001 Continuous 2359

Work scheduled by: ConEd

EXT FORCED by ConEd 08/06/2022 16:26

SCH - PJ - NY

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

TTC with All Lines In Service

MARION\_-FARRAGUT\_345\_C3403 , HUDSONP\_-  
FARRAGUT\_345\_B3402

Mon 01/15/2018 to Sat 09/30/2023  
0001 2359

Work scheduled by:

SCH - PJ - NY

FWD (Import)

REV (Export)

**2200 MW**

Impacts Total Transfer Capability

50 MW

TTC with All Lines In Service

2250 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, July 31, 2023 to Thursday, January 30, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### STLAWRNC-MOSES\_\_230\_L34P

Mon 10/03/2022 to Mon 11/06/2023  
1800 Continuous 0800

UPDATED by IESO 03/07/2023 10:12

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

Work scheduled by: IESO

### SCH-NYISO-IMO\_LIMIT\_1300

Mon 06/26/2023 to Tue 10/31/2023  
0001 Continuous 2359

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

Work scheduled by: IESO

**1600 MW**

50 MW

1650 MW

### MARCY\_SO\_SERIES\_COMP\_I/S

Mon 06/26/2023 to Mon 10/09/2023  
1302 Continuous 0659

EXTENDED by NYSEG 06/29/2023 14:33

CENTRAL EAST - VC

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

Work scheduled by: NYSEG

**2450 MW**

270 MW

2720 MW

### SCH-IMO-NYISO\_LIMIT\_1600

Wed 06/28/2023 to Tue 10/31/2023  
1801 Continuous 2359

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

Work scheduled by: IESO

**1900 MW**

150 MW

2050 MW

### ADIRNDCK-CHASLAKE\_230\_13

Mon 07/31/2023 to Sat 09/02/2023  
0700 Continuous 1600

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

Work scheduled by: NGrid

**2100 MW**

1050 MW

3150 MW

### MAINESBG-WATRCURE\_345\_30

Mon 07/31/2023 to Tue 08/01/2023  
0700 Continuous 1400

CANCELLED by TO 07/28/2023 07:50

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

Work scheduled by: NYSEG

**1950 MW**

300 MW

2250 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, July 31, 2023 to Thursday, January 30, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### ELBRIDGE-LAFAYTTE\_345\_17-LE

Thu 08/03/2023 to Thu 08/03/2023  
0630 Continuous 0930  
Work scheduled by: NGrid

ARR: 75

OSWEGO EXPORT 5250 MW  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

FWD (Import) REV (Export)

### OSWEGO\_-ELBRIDGE\_345\_17

Thu 08/03/2023 to Thu 08/03/2023  
0630 Continuous 1800  
Work scheduled by: NGrid

ARR: 75

OSWEGO EXPORT 5250 MW  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

FWD (Import) REV (Export)

### ELBRIDGE-LAFAYTTE\_345\_17-LE

Thu 08/03/2023 to Thu 08/03/2023  
1500 Continuous 1800  
Work scheduled by: NGrid

ARR: 75

OSWEGO EXPORT 5250 MW  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

FWD (Import) REV (Export)

### DYSINGER-ST\_255\_345\_DH2

Mon 08/07/2023 to Fri 08/11/2023  
0500 Continuous 1600  
Work scheduled by: NYPA

UPDATED by NYPA 07/19/2023 10:57

DYSINGER EAST 2850 MW  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 3200 MW

FWD (Import) REV (Export)

### SCH-IMO\_NY\_NIAG\_SOUTH\_BUS\_W/BB

Mon 08/07/2023 to Fri 08/11/2023  
0500 Continuous 1900  
Work scheduled by: NYPA

SCH - OH - NY 1350 MW 1200 MW  
Impacts Total Transfer Capability 700 MW 450 MW  
TTC with All Lines In Service 2050 MW 1650 MW

FWD (Import) REV (Export)

### OSWEGO\_-VOLNEY\_345\_12

Tue 08/08/2023 to Mon 08/28/2023  
0600 Continuous 1700  
Work scheduled by: NGrid

OSWEGO EXPORT 5250 MW  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

FWD (Import) REV (Export)

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, July 31, 2023 to Thursday, January 30, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### CHAT\_DC\_GC1

Sun 08/13/2023 to Sun 08/13/2023  
0001 Continuous 0200

UPDATED by HQ 07/18/2023 13:00

MOSES SOUTH

FWD (Import)

REV (Export)

**2850 MW**

Impacts Total Transfer Capability

300 MW

TTC with All Lines In Service

3150 MW

Work scheduled by: HQ

### CHAT\_DC\_GC1

Sun 08/13/2023 to Sun 08/13/2023  
0001 Continuous 0200

UPDATED by HQ 07/18/2023 13:00

SCH - HQ - NY

FWD (Import)

REV (Export)

**500 MW**

Impacts Total Transfer Capability

500 MW

TTC with All Lines In Service

1000 MW

Work scheduled by: HQ

### CHAT\_DC\_GC1 , CHAT\_DC\_GC2

Sun 08/13/2023 to Sun 08/13/2023  
0001 0200

MOSES SOUTH

FWD (Import)

REV (Export)

**2550 MW**

Impacts Total Transfer Capability

600 MW

TTC with All Lines In Service

3150 MW

Work scheduled by:

### CHAT\_DC\_GC1 , CHAT\_DC\_GC2

Sun 08/13/2023 to Sun 08/13/2023  
0001 0200

SCH - HQ - NY

FWD (Import)

REV (Export)

**1370 MW**

**0 MW**

Impacts Total Transfer Capability

130 MW

1000 MW

TTC with All Lines In Service

1500 MW

1000 MW

Work scheduled by:

### CHAT\_DC\_GC2

Sun 08/13/2023 to Sun 08/13/2023  
0001 Continuous 0200

UPDATED by HQ 07/18/2023 13:00

MOSES SOUTH

FWD (Import)

REV (Export)

**2850 MW**

Impacts Total Transfer Capability

300 MW

TTC with All Lines In Service

3150 MW

Work scheduled by: HQ

### CHAT\_DC\_GC2

Sun 08/13/2023 to Sun 08/13/2023  
0001 Continuous 0200

UPDATED by HQ 07/18/2023 13:00

SCH - HQ - NY

FWD (Import)

REV (Export)

**500 MW**

Impacts Total Transfer Capability

500 MW

TTC with All Lines In Service

1000 MW

Work scheduled by: HQ

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, July 31, 2023 to Thursday, January 30, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-HQ-NYISO\_LIMIT\_1100

Sun 08/13/2023 to Sun 08/13/2023  
0001 Continuous 0200

UPDATED by HQ 07/18/2023 13:00

SCH - HQ - NY

FWD (Import)

REV (Export)

**1100 MW**

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

1500 MW

Work scheduled by: HQ

### MARCY\_-EDIC\_345\_UE1-7

Sat 08/19/2023 to Sun 08/20/2023  
0500 Continuous 1900

UPDATED by NYPA 04/26/2023 09:32

OSWEGO EXPORT

FWD (Import)

REV (Export)

**5250 MW**

Impacts Total Transfer Capability

0 MW

TTC with All Lines In Service

5250 MW

Work scheduled by: NYPA

ARR: 19,16

### DYSINGER-STA\_255\_345\_DH1

Mon 08/21/2023 to Fri 08/25/2023  
0500 Continuous 1600

UPDATED by NYPA 07/19/2023 10:47

DYSINGER EAST

FWD (Import)

REV (Export)

**2850 MW**

Impacts Total Transfer Capability

350 MW

TTC with All Lines In Service

3200 MW

Work scheduled by: NYPA

### SPRNBK\_345KV\_RNS5

Sun 08/27/2023 to Mon 08/28/2023  
0001 Continuous 0200

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

**3200 MW**

Impacts Total Transfer Capability

1400 MW

TTC with All Lines In Service

4600 MW

Work scheduled by: ConEd

### SPRNBK\_-W49TH\_ST\_345\_M51

Sun 08/27/2023 to Mon 08/28/2023  
0001 Continuous 0200

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

**3200 MW**

Impacts Total Transfer Capability

1400 MW

TTC with All Lines In Service

4600 MW

Work scheduled by: ConEd

### NIAGARA\_345\_230\_AT4

Mon 08/28/2023 to Fri 09/01/2023  
0500 Continuous 2100

UPDATED by NYPA 03/16/2023 08:43

SCH - OH - NY

FWD (Import)

REV (Export)

**1200 MW**

Impacts Total Transfer Capability

450 MW

TTC with All Lines In Service

1650 MW

Work scheduled by: NYPA

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, July 31, 2023 to Thursday, January 30, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### HOPATCON-RAMAPO\_\_500\_5018

Sat 09/02/2023 to Sat 09/02/2023  
0001 Continuous 2200  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
TOTAL EAST	<b>5400 MW</b>	
Impacts Total Transfer Capability	750 MW	
TTC with All Lines In Service	6150 MW	

### HOPATCON-RAMAPO\_\_500\_5018

Sat 09/02/2023 to Sat 09/02/2023  
0001 Continuous 2200  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - PJ - NY	<b>1100 MW</b>	<b>1000 MW</b>
Impacts Total Transfer Capability	1150 MW	200 MW
TTC with All Lines In Service	2250 MW	1200 MW

### HOPATCON-RAMAPO\_\_500\_5018

Sat 09/02/2023 to Sat 09/02/2023  
0001 Continuous 2200  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
UPNY CONED	<b>7795 MW</b>	
Impacts Total Transfer Capability	255 MW	
TTC with All Lines In Service	8050 MW	

### RAMAPO\_\_345\_345\_PAR3500

Sat 09/02/2023 to Sat 09/02/2023  
0001 Continuous 2200  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - PJ - NY	<b>1750 MW</b>	
Impacts Total Transfer Capability	500 MW	
TTC with All Lines In Service	2250 MW	

### RAMAPO\_\_345\_345\_PAR4500

Sat 09/02/2023 to Sat 09/02/2023  
0001 Continuous 2200  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - PJ - NY	<b>1750 MW</b>	
Impacts Total Transfer Capability	500 MW	
TTC with All Lines In Service	2250 MW	

### RAMAPO\_\_500\_345\_BK 1500

Sat 09/02/2023 to Sat 09/02/2023  
0001 Continuous 2200  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - PJ - NY	<b>1100 MW</b>	<b>1000 MW</b>
Impacts Total Transfer Capability	1150 MW	200 MW
TTC with All Lines In Service	2250 MW	1200 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, July 31, 2023 to Thursday, January 30, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### RAMAPO\_\_500\_345\_BK\_1500

Sat 09/02/2023 to Sat 09/02/2023  
0001 Continuous 2200  
Work scheduled by: ConEd

FWD (Import) REV (Export)  
UPNY CONED **7795 MW**  
Impacts Total Transfer Capability 255 MW  
TTC with All Lines In Service 8050 MW

### RAMAPO\_\_BUCHAN\_N\_345\_Y94

Mon 09/04/2023 to Fri 09/22/2023  
0001 Continuous 0200  
Work scheduled by: ConEd

FWD (Import) REV (Export)  
UPNY CONED **7755 MW**  
Impacts Total Transfer Capability 295 MW  
TTC with All Lines In Service 8050 MW

### ADIRNDCK-CHASLAKE\_230\_13

Tue 09/05/2023 to Sat 10/21/2023  
0700 Continuous 1600  
Work scheduled by: NGrid

FWD (Import) REV (Export)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

### SCH-IMO-NYISO\_LIMIT\_1450

Tue 09/05/2023 to Sat 10/21/2023  
0700 Continuous 1600  
Work scheduled by: IESO

FWD (Import) REV (Export)  
SCH - OH - NY **1750 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 2050 MW

### OSWEGO\_\_VOLNEY\_\_345\_12

Thu 09/07/2023 to Thu 09/07/2023  
0630 Daily 2000  
Work scheduled by: NGrid

FWD (Import) REV (Export)  
OSWEGO EXPORT **5250 MW**  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

### E13THSTA-FARRAGUT\_345\_46

Sat 09/09/2023 to Mon 09/11/2023  
0001 Continuous 0200  
Work scheduled by: ConEd

FWD (Import) REV (Export)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, July 31, 2023 to Thursday, January 30, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### W49TH\_ST\_345KV\_6

Sat 09/09/2023 to Sun 09/10/2023  
0001 Continuous 0100  
Work scheduled by: ConEd

SCH - PJM\_HTP  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) 300 MW  
REV (Export) 360 MW  
660 MW

### W49TH\_ST-E13THSTA\_345\_M55

Sat 09/09/2023 to Mon 09/11/2023  
0101 Continuous 0200  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) 3800 MW  
REV (Export) 800 MW  
4600 MW

### W49TH\_ST\_345KV\_6

Mon 09/11/2023 to Mon 09/11/2023  
0130 Continuous 0200  
Work scheduled by: ConEd

SCH - PJM\_HTP  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) 300 MW  
REV (Export) 360 MW  
660 MW

### SPRNBK\_345KV\_RNS4

Mon 09/11/2023 to Wed 09/13/2023  
0201 Continuous 0100  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) 3200 MW  
REV (Export) 1400 MW  
4600 MW

### SPRNBK-W49TH\_ST\_345\_M52

Mon 09/11/2023 to Wed 09/13/2023  
0201 Continuous 0100  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) 3200 MW  
REV (Export) 1400 MW  
4600 MW

### W49TH\_ST\_345KV\_5

Mon 09/11/2023 to Wed 09/13/2023  
0201 Continuous 0100  
Work scheduled by: ConEd

SCH - PJM\_HTP  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) 300 MW  
REV (Export) 360 MW  
660 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, July 31, 2023 to Thursday, January 30, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### CLAY\_\_-EDIC\_\_345\_1-16

Mon 09/11/2023 to Fri 09/15/2023  
0700 Continuous 1530

UPDATED by NYISO 02/22/2023 09:21

OSWEGO EXPORT

FWD (Import)

REV (Export)

**4850 MW**

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

5250 MW

Work scheduled by: NYPA

### FRASER\_-GILBOA\_\_345\_GF5-35

Mon 09/11/2023 to Sun 09/17/2023  
0700 Continuous 1530

CENTRAL EAST - VC

FWD (Import)

REV (Export)

**2450 MW**

Impacts Total Transfer Capability

270 MW

TTC with All Lines In Service

2720 MW

Work scheduled by: NYPA

### LONG\_MTN-CRICKVLY\_345\_398

Fri 09/15/2023 to Sun 10/01/2023  
0001 Continuous 2200

CANCELLED by TO 07/28/2023 09:55

SCH - NPX\_1385

FWD (Import)

REV (Export)

**100 MW**

**100 MW**

Impacts Total Transfer Capability

100 MW

100 MW

TTC with All Lines In Service

200 MW

200 MW

Work scheduled by: ConEd

### LONG\_MTN-CRICKVLY\_345\_398

Fri 09/15/2023 to Sun 10/01/2023  
0001 Continuous 2200

CANCELLED by TO 07/28/2023 09:55

SCH - NE - NY

FWD (Import)

REV (Export)

**800 MW**

**1200 MW**

Impacts Total Transfer Capability

600 MW

400 MW

TTC with All Lines In Service

1400 MW

1600 MW

Work scheduled by: ConEd

### SPRNBK\_345KV\_RNS5

Fri 09/15/2023 to Wed 10/25/2023  
0001 Continuous 0100

UPDATED by ConEd 04/21/2023 14:42

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

**3200 MW**

Impacts Total Transfer Capability

1400 MW

TTC with All Lines In Service

4600 MW

Work scheduled by: ConEd

### SPRNBK\_-W49TH\_ST\_345\_M51

Fri 09/15/2023 to Wed 10/25/2023  
0001 Continuous 0100

UPDATED by ConEd 04/21/2023 14:42

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

**3200 MW**

Impacts Total Transfer Capability

1400 MW

TTC with All Lines In Service

4600 MW

Work scheduled by: ConEd

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, July 31, 2023 to Thursday, January 30, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### CLAY\_\_-EDIC\_\_345\_2-15

Mon 09/18/2023 to Fri 09/22/2023  
0700 Continuous 1530  
Work scheduled by: NYPA

OSWEGO EXPORT FWD (Import) REV (Export)  
**4850 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

### BECK\_\_-NIAGARA\_345\_PA301

Wed 09/20/2023 to Thu 09/21/2023  
0500 Continuous 2100  
Work scheduled by: NYPA

SCH - OH - NY FWD (Import) REV (Export)  
**1000 MW 850 MW**  
Impacts Total Transfer Capability 1050 MW 800 MW  
TTC with All Lines In Service 2050 MW 1650 MW

### MARCY\_\_-EDIC\_\_345\_UE1-7

Sat 09/23/2023 to Sun 09/24/2023  
0500 Continuous 1900  
Work scheduled by: NYPA  
UPDATED by NYPA 10/28/2022 11:09  
ARR: 19,16

OSWEGO EXPORT FWD (Import) REV (Export)  
**5250 MW**  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

### NIAGARA\_-DYSINGER\_345\_ND2

Mon 09/25/2023 to Fri 09/29/2023  
0500 Continuous 2000  
Work scheduled by: NYPA

DYSINGER EAST FWD (Import) REV (Export)  
**2700 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 3200 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, July 31, 2023 to Thursday, January 30, 2025

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2720 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MARCY\_\_345KV\_CSC

Mon 09/25/2023 to Sat 10/07/2023  
0700 Continuous 1530  
Work scheduled by: NYPA

CENTRAL EAST - VC	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	2650 MW	
TTC with All Lines In Service	70 MW	
	2720 MW	

### MARCY\_\_345KV\_CSC , MARCY\_SO\_SERIES\_COMP\_I/S

Mon 09/25/2023 to Sat 10/07/2023  
0700 1530  
Work scheduled by:

CENTRAL EAST - VC	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	2380 MW	
TTC with All Lines In Service	340 MW	
	2720 MW	

### ROSETON\_-EFISHKIL\_345\_RFK305

Mon 09/25/2023 to Fri 10/13/2023  
0700 Continuous 1530  
Work scheduled by: NYPA

UPNY CONED	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	7215 MW	
TTC with All Lines In Service	835 MW	
	8050 MW	

### MILLWOOD-EASTVIEW\_345\_W82

Wed 09/27/2023 to Wed 09/27/2023  
0001 Continuous 2200  
Work scheduled by: ConEd

UPNY CONED	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	7810 MW	
TTC with All Lines In Service	240 MW	
	8050 MW	

### ELBRIDGE-LAFAYTTE\_345\_17-LE

Thu 09/28/2023 to Fri 09/29/2023  
0600 Continuous 1700  
Work scheduled by: NGrid

ARR: 75

OSWEGO EXPORT	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	5250 MW	
TTC with All Lines In Service	0 MW	
	5250 MW	

### OSWEGO\_-ELBRIDGE\_345\_17

Thu 09/28/2023 to Thu 09/28/2023  
0600 Continuous 0900  
Work scheduled by: NGrid

ARR: 75

OSWEGO EXPORT	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	5250 MW	
TTC with All Lines In Service	0 MW	
	5250 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, July 31, 2023 to Thursday, January 30, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MILLWOOD-EASTVIEW\_345\_W99

Fri 09/29/2023 to Sat 09/30/2023  
0001 Continuous 1800  
Work scheduled by: ConEd

UPNY CONED  
**7810 MW**  
Impacts Total Transfer Capability 240 MW  
TTC with All Lines In Service 8050 MW

### OSWEGO\_-ELBRIDGE\_345\_17

Fri 09/29/2023 to Fri 09/29/2023  
1400 Continuous 1700  
Work scheduled by: NGrid

ARR: 75

OSWEGO EXPORT  
**5250 MW**  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

### E13THSTA-FARRAGUT\_345\_45

Sat 09/30/2023 to Sat 09/30/2023  
0201 Continuous 0231  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
**3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

### E13THSTA-FARRAGUT\_345\_45

Sat 09/30/2023 to Sat 09/30/2023  
0730 Continuous 0800  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
**3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

### DYSINGER-STA\_255\_345\_DH2

Mon 10/02/2023 to Thu 10/12/2023  
0500 Continuous 1900  
Work scheduled by: NYPA

DYSINGER EAST  
**2850 MW**  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 3200 MW

### SHOR\_NPX-SHOREHAM\_138\_CSC

Mon 10/02/2023 to Fri 10/13/2023  
0600 Continuous 2200  
Work scheduled by: LI

EXTENDED by LI 07/14/2023 09:47

SCH - NPX\_CSC  
**0 MW** **0 MW**  
Impacts Total Transfer Capability 330 MW 330 MW  
TTC with All Lines In Service 330 MW 330 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, July 31, 2023 to Thursday, January 30, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### HOMR\_NYW-PIERC\_NY\_345\_48

Mon 10/02/2023 to Fri 10/06/2023  
0800 Continuous 1600  
Work scheduled by: NYSEG

UPDATED by PJM 07/21/2023 09:35

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### FROST\_BR-LONG\_MTN\_345\_352

Mon 10/02/2023 to Sat 11/04/2023  
0830 Continuous 1200  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### ELBRIDGE-LAFAYTTE\_345\_17-LE

Tue 10/03/2023 to Fri 10/06/2023  
0600 Continuous 1800  
Work scheduled by: NGrid

ARR: 75

OSWEGO EXPORT  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

5250 MW  
0 MW  
5250 MW

### OSWEGO\_-ELBRIDGE\_345\_17

Tue 10/03/2023 to Tue 10/03/2023  
0600 Continuous 0900  
Work scheduled by: NGrid

ARR: 75

OSWEGO EXPORT  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

5250 MW  
0 MW  
5250 MW

### SCRIBA\_-VOLNEY\_\_345\_20

Tue 10/03/2023 to Tue 10/03/2023  
0730 Continuous 1700  
Work scheduled by: NGrid

OSWEGO EXPORT  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

5250 MW  
0 MW  
5250 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, July 31, 2023 to Thursday, January 30, 2025

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2720 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### DUNWODIE\_345KV\_4

Wed 10/04/2023 to Fri 11/10/2023  
0001 Continuous 2200  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

### OSWEGO\_-ELBRIDGE\_345\_17

Fri 10/06/2023 to Fri 10/06/2023  
1730 Continuous 1800  
Work scheduled by: NGrid  
ARR: 75

	FWD (Import)	REV (Export)
OSWEGO EXPORT	<b>5250 MW</b>	
Impacts Total Transfer Capability	0 MW	
TTC with All Lines In Service	5250 MW	

### GILBOA\_-N.SCTLND\_345\_GNS-1

Mon 10/09/2023 to Fri 10/13/2023  
0700 Continuous 1530  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
CENTRAL EAST - VC	<b>2300 MW</b>	
Impacts Total Transfer Capability	420 MW	
TTC with All Lines In Service	2720 MW	

### ELBRIDGE-LAFAYTTE\_345\_17-LE

Tue 10/10/2023 to Wed 10/11/2023  
0600 Continuous 1700  
Work scheduled by: NGrid  
ARR: 75

	FWD (Import)	REV (Export)
OSWEGO EXPORT	<b>5250 MW</b>	
Impacts Total Transfer Capability	0 MW	
TTC with All Lines In Service	5250 MW	

### OSWEGO\_-ELBRIDGE\_345\_17

Tue 10/10/2023 to Fri 10/27/2023  
0600 Continuous 1700  
Work scheduled by: NGrid  
ARR: 75

	FWD (Import)	REV (Export)
OSWEGO EXPORT	<b>5250 MW</b>	
Impacts Total Transfer Capability	0 MW	
TTC with All Lines In Service	5250 MW	

### NIAGARA\_-PACKARD\_230\_61

Fri 10/13/2023 to Fri 10/13/2023  
0500 Continuous 1900  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - OH - NY	<b>1900 MW</b>	<b>1450 MW</b>
Impacts Total Transfer Capability	150 MW	200 MW
TTC with All Lines In Service	2050 MW	1650 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, July 31, 2023 to Thursday, January 30, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### DYSINGER-STA\_255\_345\_DH1

Sat 10/14/2023 to Tue 10/24/2023  
0500 Continuous 1900  
Work scheduled by: NYPA

DYSINGER EAST  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) 2850 MW  
350 MW  
3200 MW

### LADENTWN-BUCHAN\_S\_345\_Y88

Mon 10/16/2023 to Mon 11/06/2023  
0201 Continuous 0200  
Work scheduled by: ConEd

UPDATED by ConEd 06/16/2023 08:29

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) 7695 MW  
355 MW  
8050 MW

### FRASANNX-COOPERS\_345\_UCC2-41

Mon 10/16/2023 to Fri 10/27/2023  
0600 Continuous 1730  
Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) 2275 MW  
445 MW  
2720 MW

### MARCY\_-FRASANNX\_345\_UCC2-41

Mon 10/16/2023 to Fri 10/27/2023  
0600 Continuous 1730  
Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) 2275 MW  
445 MW  
2720 MW

### CHASLAKE-PORTER\_230\_11

Sun 10/22/2023 to Tue 11/14/2023  
0630 Continuous 1730  
Work scheduled by: NGrid

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) 2100 MW  
1050 MW  
3150 MW

### SCH-IMO-NYISO\_LIMIT\_1450

Sun 10/22/2023 to Tue 10/31/2023  
0630 Continuous 2359  
Work scheduled by: IESO

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) 1750 MW  
300 MW  
2050 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, July 31, 2023 to Thursday, January 30, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### DUNWODIE\_345KV\_6

Mon 10/23/2023 to Thu 11/09/2023  
0001 Continuous 2200  
Work scheduled by: ConEd

FWD (Import) REV (Export)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

### DUNWODIE-SHORE\_RD\_345\_Y50

Mon 10/23/2023 to Thu 11/09/2023  
0001 Continuous 2200  
Work scheduled by: ConEd

FWD (Import) REV (Export)  
CONED - LIPA **800 MW**  
Impacts Total Transfer Capability 700 MW  
TTC with All Lines In Service 1500 MW

### SHORE\_RD\_345\_138\_BK 1

Mon 10/23/2023 to Thu 11/09/2023  
0001 Continuous 2200  
Work scheduled by: ConEd

FWD (Import) REV (Export)  
CONED - LIPA **1350 MW**  
Impacts Total Transfer Capability 150 MW  
TTC with All Lines In Service 1500 MW

### SHORE\_RD\_345\_138\_BK 2

Mon 10/23/2023 to Thu 11/09/2023  
0001 Continuous 2200  
Work scheduled by: ConEd

FWD (Import) REV (Export)  
CONED - LIPA **1350 MW**  
Impacts Total Transfer Capability 150 MW  
TTC with All Lines In Service 1500 MW

### E13THSTA-FARRAGUT\_345\_45

Thu 10/26/2023 to Thu 10/26/2023  
0001 Continuous 0030  
Work scheduled by: ConEd

FWD (Import) REV (Export)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

### ELBRIDGE-LAFAYTTE\_345\_17-LE

Fri 10/27/2023 to Fri 10/27/2023  
1400 Continuous 1700  
Work scheduled by: NGrid

ARR: 75

FWD (Import) REV (Export)  
OSWEGO EXPORT **5250 MW**  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, July 31, 2023 to Thursday, January 30, 2025

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2720 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MOSES\_\_-ADIRNDCK\_230\_MA1

Sun 10/29/2023 to Sat 11/04/2023  
0700 Continuous 1930  
Work scheduled by: NYPA

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**2100 MW**  
1050 MW  
3150 MW

### E13THSTA-FARRAGUT\_345\_45

Mon 10/30/2023 to Mon 10/30/2023  
0230 Continuous 0300  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3800 MW**  
800 MW  
4600 MW

### NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE

Wed 11/01/2023 to Mon 11/20/2023  
0001 Continuous 2359  
Work scheduled by: LI  
UPDATED by LI 04/22/2023 14:51

SCH - PJM\_NEPTUNE  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**0 MW**  
660 MW  
660 MW

### NEWBRIDGE\_345\_138\_BK\_1

Wed 11/01/2023 to Mon 11/20/2023  
0001 Continuous 2359  
Work scheduled by: LI  
UPDATED by LI 04/22/2023 14:51

SCH - PJM\_NEPTUNE  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**375 MW**  
285 MW  
660 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, July 31, 2023 to Thursday, January 30, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### NEWBRDGE\_345\_138\_BK\_2

Wed 11/01/2023 to Mon 11/20/2023  
0001 Continuous 2359

UPDATED by LI 04/22/2023 14:51

SCH - PJM\_NEPTUNE

FWD (Import)

REV (Export)

**375 MW**

Impacts Total Transfer Capability

285 MW

TTC with All Lines In Service

660 MW

Work scheduled by: LI

### NEWBRDGE-DUFFYAVE\_345\_501

Wed 11/01/2023 to Mon 11/20/2023  
0001 Continuous 2359

UPDATED by LI 04/22/2023 14:51

SCH - PJM\_NEPTUNE

FWD (Import)

REV (Export)

**0 MW**

Impacts Total Transfer Capability

660 MW

TTC with All Lines In Service

660 MW

Work scheduled by: LI

### MOSES\_\_ADIRNDCK\_230\_MA2

Sun 11/05/2023 to Sat 11/11/2023  
0700 Continuous 1930

MOSES SOUTH

FWD (Import)

REV (Export)

**2300 MW**

Impacts Total Transfer Capability

850 MW

TTC with All Lines In Service

3150 MW

Work scheduled by: NYPA

### LONG\_MTN-CRICKVLY\_345\_398

Mon 11/06/2023 to Thu 11/30/2023  
0001 Continuous 2200

CANCELLED by TO 07/28/2023 09:56

SCH - NPX\_1385

FWD (Import)

REV (Export)

**100 MW**

**100 MW**

Impacts Total Transfer Capability

100 MW

100 MW

TTC with All Lines In Service

200 MW

200 MW

Work scheduled by: ConEd

### LONG\_MTN-CRICKVLY\_345\_398

Mon 11/06/2023 to Thu 11/30/2023  
0001 Continuous 2200

CANCELLED by TO 07/28/2023 09:56

SCH - NE - NY

FWD (Import)

REV (Export)

**700 MW**

**1200 MW**

Impacts Total Transfer Capability

900 MW

600 MW

TTC with All Lines In Service

1600 MW

1800 MW

Work scheduled by: ConEd

### SPRNBK-TREMONT\_345\_X28

Mon 11/06/2023 to Mon 11/06/2023  
0001 Continuous 0400

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

**4200 MW**

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

4600 MW

Work scheduled by: ConEd

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, July 31, 2023 to Thursday, January 30, 2025

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2720 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### DUNWODIE\_345KV\_3

Mon 11/06/2023 to Thu 11/09/2023  
0201 Continuous 2200  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

### LINDN\_CG-LNDVFT\_\_345\_V-3022

Mon 11/06/2023 to Thu 11/09/2023  
0800 Continuous 1500  
Work scheduled by: PJM

	FWD (Import)	REV (Export)
SCH - PJM_VFT	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	315 MW	315 MW
TTC with All Lines In Service	315 MW	315 MW

### RAMAPO\_\_BUCHAN\_N\_345\_Y94

Sat 11/11/2023 to Mon 12/18/2023  
0201 Continuous 0200  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
UPNY CONED	<b>7755 MW</b>	
Impacts Total Transfer Capability	295 MW	
TTC with All Lines In Service	8050 MW	

### CHATGUAY-MASSENA\_765\_7040

Wed 11/15/2023 to Mon 11/27/2023  
0700 Continuous 1730  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - HQ - NY	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	1500 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

### CHATGUAY-MASSENA\_765\_7040

Wed 11/15/2023 to Mon 11/27/2023  
0700 Continuous 1730  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
MOSES SOUTH	<b>1550 MW</b>	
Impacts Total Transfer Capability	1600 MW	
TTC with All Lines In Service	3150 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, July 31, 2023 to Thursday, January 30, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### CHATGUAY-MASSENA\_\_765\_7040 , MASSENA\_-MARCY\_\_765\_MSU1

Wed 11/15/2023 to Mon 11/27/2023  
0700 1730

Work scheduled by:

MOSES SOUTH  
Impacts Total Transfer Capability 2650 MW  
TTC with All Lines In Service 3150 MW

FWD (Import) REV (Export)

**500 MW**

### MASSENA\_-MARCY\_\_765\_MSU1

Wed 11/15/2023 to Mon 11/27/2023  
0700 Continuous 1730

Work scheduled by: NYPA

CENTRAL EAST - VC  
Impacts Total Transfer Capability 1000 MW  
TTC with All Lines In Service 2720 MW

FWD (Import) REV (Export)

**1720 MW**

### MASSENA\_-MARCY\_\_765\_MSU1

Wed 11/15/2023 to Mon 11/27/2023  
0700 Continuous 1730

Work scheduled by: NYPA

SCH - HQ\_CEDARS  
Impacts Total Transfer Capability 189 MW  
TTC with All Lines In Service 279 MW

FWD (Import) REV (Export)

**90 MW**

### MASSENA\_-MARCY\_\_765\_MSU1

Wed 11/15/2023 to Mon 11/27/2023  
0700 Continuous 1730

Work scheduled by: NYPA

SCH - HQ - NY  
Impacts Total Transfer Capability 1025 MW 0 MW  
TTC with All Lines In Service 1500 MW 1000 MW

FWD (Import) REV (Export)

**475 MW**

**1000 MW**

### MASSENA\_-MARCY\_\_765\_MSU1

Wed 11/15/2023 to Mon 11/27/2023  
0700 Continuous 1730

Work scheduled by: NYPA

MOSES SOUTH  
Impacts Total Transfer Capability 2650 MW  
TTC with All Lines In Service 3150 MW

FWD (Import) REV (Export)

**500 MW**

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, July 31, 2023 to Thursday, January 30, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MOSES\_\_-MASSENA\_230\_MMS1 , MOSES\_\_-MASSENA\_230\_MMS2

Wed 11/15/2023 to Mon 11/20/2023  
0700 1530

Work scheduled by:

SCH - HQ\_CEDARS  
**90 MW**  
Impacts Total Transfer Capability 189 MW  
TTC with All Lines In Service 279 MW

FWD (Import) REV (Export)

### MOSES\_\_-MASSENA\_230\_MMS1 , MOSES\_\_-MASSENA\_230\_MMS2

Wed 11/15/2023 to Mon 11/20/2023  
0700 1530

Work scheduled by:

SCH - HQ - NY  
**850 MW** **0 MW**  
Impacts Total Transfer Capability 650 MW 1000 MW  
TTC with All Lines In Service 1500 MW 1000 MW

FWD (Import) REV (Export)

### LINDN\_CG-LNDVFT\_\_345\_V-3022

Wed 11/15/2023 to Wed 11/15/2023  
1500 Continuous 1700

Work scheduled by: PJM

SCH - PJM\_VFT  
**0 MW** **0 MW**  
Impacts Total Transfer Capability 315 MW 315 MW  
TTC with All Lines In Service 315 MW 315 MW

FWD (Import) REV (Export)

### BECK\_\_-NIAGARA\_345\_PA301

Sun 11/19/2023 to Sun 11/19/2023  
0500 Continuous 2200

Work scheduled by: NYPA

SCH - OH - NY  
**1100 MW** **950 MW**  
Impacts Total Transfer Capability 1300 MW 1050 MW  
TTC with All Lines In Service 2400 MW 2000 MW

FWD (Import) REV (Export)

### ADIRNDCK-PORTER\_\_230\_12

Fri 12/01/2023 to Fri 12/22/2023  
0530 Continuous 1700

Work scheduled by: NGrid

UPDATED by NGrid 07/11/2023 11:44

MOSES SOUTH  
**2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

FWD (Import) REV (Export)

### NIAGARA\_345\_230\_AT4

Mon 12/04/2023 to Fri 12/08/2023  
0500 Continuous 1900

Work scheduled by: NYPA

UPDATED by NYPA 03/21/2023 14:25

SCH - OH - NY  
**1650 MW**  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 2000 MW

FWD (Import) REV (Export)

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, July 31, 2023 to Thursday, January 30, 2025

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2720 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### S.RIPLEY-DUNKIRK\_\_230\_68

Mon 12/04/2023 to Fri 12/08/2023  
0800 Continuous 1600  
Work scheduled by: PJM

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### BERKSHIR-ALPS\_\_345\_393

Tue 12/05/2023 to Sun 12/10/2023  
0630 Continuous 1730  
Work scheduled by: NGrid

ARR: 78

SCH - NPX\_1385  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**100 MW** **100 MW**  
100 MW 100 MW  
200 MW 200 MW

### BERKSHIR-ALPS\_\_345\_393

Tue 12/05/2023 to Sun 12/10/2023  
0630 Continuous 1730  
Work scheduled by: NGrid

ARR: 78

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1100 MW** **1700 MW**  
500 MW 100 MW  
1600 MW 1800 MW

### E13THSTA-FARRAGUT\_345\_46

Sat 12/23/2023 to Mon 12/25/2023  
0001 Continuous 0300  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3800 MW**  
800 MW  
4600 MW

### S.RIPLEY-DUNKIRK\_\_230\_68

Wed 12/27/2023 to Fri 12/29/2023  
0730 Continuous 1600  
Work scheduled by: NGrid

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, July 31, 2023 to Thursday, January 30, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### WOOD\_ST\_PLSNTVLE\_345\_Y87

Fri 12/29/2023 to Sun 12/31/2023  
2200 Continuous 0259  
Work scheduled by: ConEd

UPNY CONED  
Impacts Total Transfer Capability 7470 MW  
TTC with All Lines In Service 580 MW  
8050 MW

### ADIRNDCK-PORTER\_230\_12

Tue 01/02/2024 to Fri 05/31/2024  
0630 Continuous 1730  
Work scheduled by: NGrid

UPDATED by NGrid 07/11/2023 11:44

MOSES SOUTH  
Impacts Total Transfer Capability 2300 MW  
TTC with All Lines In Service 850 MW  
3150 MW

### FRASER\_345\_FRASER SVC

Tue 01/02/2024 to Fri 03/01/2024  
0700 Continuous 1530  
Work scheduled by: NYPA

CENTRAL EAST - VC  
Impacts Total Transfer Capability 2690 MW  
TTC with All Lines In Service 30 MW  
2720 MW

### BECK\_\_PACKARD\_230\_BP76

Mon 01/15/2024 to Fri 01/19/2024  
0400 Continuous 1700  
Work scheduled by: NGrid

SCH - OH - NY  
Impacts Total Transfer Capability 1800 MW  
TTC with All Lines In Service 1350 MW  
600 MW  
2400 MW  
2000 MW

### SCH-IMO\_NY\_NIAG\_NRTH\_BUS\_W/BB

Fri 01/26/2024 to Fri 01/26/2024  
0500 Continuous 1900  
Work scheduled by: NYPA

SCH - OH - NY  
Impacts Total Transfer Capability 1550 MW  
TTC with All Lines In Service 1450 MW  
850 MW  
2400 MW  
2000 MW

### E13THSTA-FARRAGUT\_345\_46

Tue 01/30/2024 to Sun 02/04/2024  
0700 Continuous 0300  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability 3800 MW  
TTC with All Lines In Service 800 MW  
4600 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, July 31, 2023 to Thursday, January 30, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-IMO\_NY\_NIAG\_SOUTH\_BUS\_W/BB

Fri 02/09/2024 to Fri 02/09/2024  
0500 Continuous 1900  
Work scheduled by: NYPA

SCH - OH - NY  
**1550 MW** **1450 MW**  
Impacts Total Transfer Capability 850 MW 550 MW  
TTC with All Lines In Service 2400 MW 2000 MW

### MILLWOOD-EASTVIEW\_345\_W85

Thu 02/15/2024 to Sat 02/17/2024  
0001 Continuous 0200  
Work scheduled by: ConEd

UPNY CONED  
**7810 MW**  
Impacts Total Transfer Capability 240 MW  
TTC with All Lines In Service 8050 MW

### W49TH\_ST\_345KV\_8

Thu 02/15/2024 to Thu 02/22/2024  
0001 Continuous 0200  
Work scheduled by: ConEd

UPDATED by ConEd 06/13/2023 08:30

SCH - PJM\_HTP  
**310 MW**  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 660 MW

### NIAGARA\_PACKARD\_230\_62

Fri 02/16/2024 to Fri 02/16/2024  
0500 Continuous 1900  
Work scheduled by: NYPA

SCH - OH - NY  
**1750 MW** **1850 MW**  
Impacts Total Transfer Capability 650 MW 150 MW  
TTC with All Lines In Service 2400 MW 2000 MW

### CLAY\_-EDIC\_345\_2-15

Mon 02/26/2024 to Sat 03/30/2024  
0600 Continuous 1700  
Work scheduled by: NGrid

OSWEGO EXPORT  
**4850 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

### W49TH\_ST\_345KV\_6

Thu 02/29/2024 to Mon 04/01/2024  
0001 Continuous 0200  
Work scheduled by: ConEd

UPDATED by ConEd 06/13/2023 08:30

SCH - PJM\_HTP  
**310 MW**  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 660 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, July 31, 2023 to Thursday, January 30, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### W49TH\_ST-E13THSTA\_345\_M55

Thu 02/29/2024 to Mon 04/01/2024  
0001 Continuous 0200  
Work scheduled by: ConEd

UPDATED by ConEd 06/13/2023 08:30

SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

### BECK\_\_-NIAGARA\_230\_PA27

Mon 03/04/2024 to Fri 04/19/2024  
0500 Continuous 1900  
Work scheduled by: NYPA

SCH - OH - NY **2100 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 2400 MW

FWD (Import) REV (Export)

### MILLWOOD-EASTVIEW\_345\_W85

Fri 03/22/2024 to Thu 03/28/2024  
0201 Continuous 0200  
Work scheduled by: ConEd

UPNY CONED **7810 MW**  
Impacts Total Transfer Capability 240 MW  
TTC with All Lines In Service 8050 MW

FWD (Import) REV (Export)

### SPRNBK\_345KV\_RNS3

Fri 03/22/2024 to Fri 03/22/2024  
0201 Continuous 0230  
Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

### W49TH\_ST\_345KV\_8

Tue 03/26/2024 to Mon 04/01/2024  
0001 Continuous 0200  
Work scheduled by: ConEd

UPDATED by ConEd 06/13/2023 08:30

SCH - PJM\_HTP **310 MW**  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

### LADENTWN-BUCHAN\_S\_345\_Y88

Mon 04/01/2024 to Fri 05/17/2024  
0001 Continuous 2359  
Work scheduled by: ConEd

UPNY CONED **7695 MW**  
Impacts Total Transfer Capability 355 MW  
TTC with All Lines In Service 8050 MW

FWD (Import) REV (Export)

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, July 31, 2023 to Thursday, January 30, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### FRASER\_-GILBOA\_345\_GF5-35

Sun 04/07/2024 to Sat 04/27/2024  
0700 Continuous 1530  
Work scheduled by: NYPA

FWD (Import) REV (Export)  
CENTRAL EAST - VC **2450 MW**  
Impacts Total Transfer Capability 270 MW  
TTC with All Lines In Service 2720 MW

### NIAGARA\_-DYSINGER\_345\_ND1

Mon 04/08/2024 to Fri 04/12/2024  
0500 Continuous 1900  
Work scheduled by: NYPA

FWD (Import) REV (Export)  
DYSINGER EAST **2700 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 3200 MW

### CLAY\_-EDIC\_345\_1-16

Mon 04/08/2024 to Sat 05/11/2024  
0600 Continuous 1700  
Work scheduled by: NGrid

FWD (Import) REV (Export)  
OSWEGO EXPORT **4850 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

### NIAGARA\_-DYSINGER\_345\_ND2

Mon 04/15/2024 to Fri 04/19/2024  
0500 Continuous 1900  
Work scheduled by: NYPA

FWD (Import) REV (Export)  
DYSINGER EAST **2700 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 3200 MW

### GOETHALS\_345KV\_5

Thu 04/18/2024 to Thu 04/18/2024  
0001 Continuous 0030  
Work scheduled by: ConEd

FWD (Import) REV (Export)  
STATEN ISLAND  
Impacts Total Transfer Capability  
TTC with All Lines In Service

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, July 31, 2023 to Thursday, January 30, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### LINDEN\_-GOETHALS\_230\_A2253

FWD (Import) REV (Export)

Thu 04/18/2024 to Thu 04/25/2024

0001 Continuous 0200

Work scheduled by: ConEd

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

### PANNELL\_-CLAY\_\_\_345\_1

FWD (Import) REV (Export)

Mon 04/22/2024 to Fri 04/26/2024

0700 Continuous 1530

Work scheduled by: NYPA

WEST CENTRAL

**1300 MW**

Impacts Total Transfer Capability

950 MW

TTC with All Lines In Service

2250 MW

### GOETHALS\_345KV\_5

FWD (Import) REV (Export)

Thu 04/25/2024 to Thu 04/25/2024

0130 Continuous 0200

Work scheduled by: ConEd

STATEN ISLAND

Impacts Total Transfer Capability

TTC with All Lines In Service

### DYSINGER-STA\_255\_345\_DH1

FWD (Import) REV (Export)

Fri 04/26/2024 to Tue 05/07/2024

0500 Continuous 1900

Work scheduled by: NYPA

DYSINGER EAST

**2850 MW**

Impacts Total Transfer Capability

350 MW

TTC with All Lines In Service

3200 MW

### FRASANNX-COOPERS\_345\_UCC2-41

FWD (Import) REV (Export)

Mon 04/29/2024 to Tue 07/16/2024

0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC

**2275 MW**

Impacts Total Transfer Capability

445 MW

TTC with All Lines In Service

2720 MW

### MARCY\_-FRASANNX\_345\_UCC2-41

FWD (Import) REV (Export)

Mon 04/29/2024 to Tue 07/16/2024

0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC

**2275 MW**

Impacts Total Transfer Capability

445 MW

TTC with All Lines In Service

2720 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, July 31, 2023 to Thursday, January 30, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### PANNELL\_-CLAY\_\_\_345\_2

Mon 04/29/2024 to Fri 05/03/2024  
0700 Continuous 1530  
Work scheduled by: NYPA

WEST CENTRAL  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) 1300 MW  
950 MW  
2250 MW

### SHOR\_NPX-SHOREHAM\_138\_CSC

Mon 05/06/2024 to Fri 05/10/2024  
0600 Continuous 1800  
Work scheduled by: LI

SCH - NPX\_CSC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) 0 MW  
330 MW  
330 MW

### FITZPTRK-EDIC\_\_\_345\_FE-1

Mon 05/20/2024 to Fri 05/24/2024  
0700 Continuous 1530  
Work scheduled by: NYPA

OSWEGO EXPORT  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) 4800 MW  
450 MW  
5250 MW

### FITZPTRK-EDIC\_\_\_345\_FE-1

Mon 05/20/2024 to Fri 05/24/2024  
0700 Continuous 1530  
Work scheduled by: NYPA

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) 2480 MW  
240 MW  
2720 MW

### FITZPTRK-EDIC\_\_\_345\_FE-1

Tue 05/28/2024 to Fri 05/31/2024  
0700 Continuous 1530  
Work scheduled by: NYPA

OSWEGO EXPORT  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) 4800 MW  
450 MW  
5250 MW

### FITZPTRK-EDIC\_\_\_345\_FE-1

Tue 05/28/2024 to Fri 05/31/2024  
0700 Continuous 1530  
Work scheduled by: NYPA

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) 2480 MW  
240 MW  
2720 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, July 31, 2023 to Thursday, January 30, 2025

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2720 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>BECK__PACKARD_230_BP76</b>				FWD (Import)	REV (Export)
Fri 05/31/2024	to	Fri 05/31/2024	SCH - OH - NY	<b>1600 MW</b>	<b>1050 MW</b>
0730	Continuous	1630	Impacts Total Transfer Capability	450 MW	600 MW
Work scheduled by: NGrid				TTC with All Lines In Service	2050 MW
<b>CHASLAKE-PORTER_230_11</b>				FWD (Import)	REV (Export)
Sat 06/01/2024	to	Wed 07/03/2024	MOSES SOUTH	<b>2100 MW</b>	
0530	Continuous	1600	Impacts Total Transfer Capability	1050 MW	
Work scheduled by: NGrid				TTC with All Lines In Service	3150 MW
<b>NIAGARA_345_230_AT4</b>				FWD (Import)	REV (Export)
Tue 06/11/2024	to	Wed 06/12/2024	SCH - OH - NY		<b>1200 MW</b>
0500	Continuous	1900	Impacts Total Transfer Capability		450 MW
Work scheduled by: NYPA				TTC with All Lines In Service	1650 MW
<b>CHASLAKE-PORTER_230_11</b>				FWD (Import)	REV (Export)
Mon 07/08/2024	to	Fri 11/15/2024	MOSES SOUTH	<b>2100 MW</b>	
0530	Continuous	2000	Impacts Total Transfer Capability	1050 MW	
Work scheduled by: NGrid				TTC with All Lines In Service	3150 MW
<b>MOSES__ADIRNDCK_230_MA2</b>				FWD (Import)	REV (Export)
Mon 09/02/2024	to	Mon 09/02/2024	MOSES SOUTH	<b>2100 MW</b>	
0700	Continuous	1730	Impacts Total Transfer Capability	1050 MW	
Work scheduled by: NYPA				TTC with All Lines In Service	3150 MW
<b>ROCHESTR-PANNELL_345_RP1</b>				FWD (Import)	REV (Export)
Mon 09/09/2024	to	Fri 09/13/2024	DYSINGER EAST	<b>2300 MW</b>	
0700	Continuous	1530	Impacts Total Transfer Capability	900 MW	
Work scheduled by: NYPA				TTC with All Lines In Service	3200 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, July 31, 2023 to Thursday, January 30, 2025

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2720 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### ROCHESTR-PANNELL\_345\_RP2

Mon 09/16/2024 to Fri 09/20/2024  
0700 Continuous 1530  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
DYSINGER EAST	<b>2300 MW</b>	
Impacts Total Transfer Capability	900 MW	
TTC with All Lines In Service	3200 MW	

### PANNELL-CLAY\_345\_1

Mon 09/23/2024 to Fri 09/27/2024  
0700 Continuous 1530  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
WEST CENTRAL	<b>1300 MW</b>	
Impacts Total Transfer Capability	950 MW	
TTC with All Lines In Service	2250 MW	

### FITZPTRK-EDIC\_345\_FE-1

Mon 09/30/2024 to Fri 10/04/2024  
1700 Continuous 1530  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
OSWEGO EXPORT	<b>4800 MW</b>	
Impacts Total Transfer Capability	450 MW	
TTC with All Lines In Service	5250 MW	

### FITZPTRK-EDIC\_345\_FE-1

Mon 09/30/2024 to Fri 10/04/2024  
1700 Continuous 1530  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
CENTRAL EAST - VC	<b>2480 MW</b>	
Impacts Total Transfer Capability	240 MW	
TTC with All Lines In Service	2720 MW	

### NEPTUNE-DUFFYAVE\_345\_NEPTUNE

Mon 10/07/2024 to Fri 10/11/2024  
0600 Continuous 1600  
Work scheduled by: LI

	FWD (Import)	REV (Export)
SCH - PJM_NEPTUNE	<b>0 MW</b>	
Impacts Total Transfer Capability	660 MW	
TTC with All Lines In Service	660 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, July 31, 2023 to Thursday, January 30, 2025

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2720 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### NEWBRDGE\_345\_138\_BK\_1

Mon 10/07/2024 to Fri 10/11/2024  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM_NEPTUNE	FWD (Import)	REV (Export)
	<b>375 MW</b>	
Impacts Total Transfer Capability	285 MW	
TTC with All Lines In Service	660 MW	

### NEWBRDGE\_345\_138\_BK\_2

Mon 10/07/2024 to Fri 10/11/2024  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM_NEPTUNE	FWD (Import)	REV (Export)
	<b>375 MW</b>	
Impacts Total Transfer Capability	285 MW	
TTC with All Lines In Service	660 MW	

### NEWBRDGE-DUFFYAVE\_345\_501

Mon 10/07/2024 to Fri 10/11/2024  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM_NEPTUNE	FWD (Import)	REV (Export)
	<b>0 MW</b>	
Impacts Total Transfer Capability	660 MW	
TTC with All Lines In Service	660 MW	

### SHOR\_NPX-SHOREHAM\_138\_CSC

Mon 10/07/2024 to Fri 10/11/2024  
0600 Continuous 1800  
Work scheduled by: LI

SCH - NPX_CSC	FWD (Import)	REV (Export)
	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	330 MW	330 MW
TTC with All Lines In Service	330 MW	330 MW

### GILBOA\_-N.SCTLND\_345\_GNS-1

Mon 10/07/2024 to Fri 10/11/2024  
0700 Continuous 1530  
Work scheduled by: NYPA

CENTRAL EAST - VC	FWD (Import)	REV (Export)
	<b>2300 MW</b>	
Impacts Total Transfer Capability	420 MW	
TTC with All Lines In Service	2720 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, July 31, 2023 to Thursday, January 30, 2025

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2720 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>FRASANNX-COOPERS_345_UCC2-41</b>					FWD (Import)	REV (Export)
Wed 10/09/2024	to	Thu 10/10/2024		CENTRAL EAST - VC	<b>2275 MW</b>	
0700	Continuous	1530	ARR: 19	Impacts Total Transfer Capability	445 MW	
Work scheduled by: NYPA				TTC with All Lines In Service	2720 MW	
<b>MARCY__-FRASANNX_345_UCC2-41</b>					FWD (Import)	REV (Export)
Wed 10/09/2024	to	Thu 10/10/2024		CENTRAL EAST - VC	<b>2275 MW</b>	
0700	Continuous	1530	ARR: 19	Impacts Total Transfer Capability	445 MW	
Work scheduled by: NYPA				TTC with All Lines In Service	2720 MW	
<b>MARCY__-N.SCTLND_345_18</b>					FWD (Import)	REV (Export)
Tue 10/15/2024	to	Thu 10/17/2024		CENTRAL EAST - VC	<b>1345 MW</b>	
0700	Continuous	1530	ARR: 19	Impacts Total Transfer Capability	1375 MW	
Work scheduled by: NYPA				TTC with All Lines In Service	2720 MW	
<b>MARCY__-N.SCTLND_345_18</b>					FWD (Import)	REV (Export)
Mon 10/21/2024	to	Fri 10/25/2024		CENTRAL EAST - VC	<b>1345 MW</b>	
0700	Continuous	1530	ARR: 19	Impacts Total Transfer Capability	1375 MW	
Work scheduled by: NYPA				TTC with All Lines In Service	2720 MW	
<b>COOPERS_-MIDDLETP_345_CCRT34</b>					FWD (Import)	REV (Export)
Sun 10/27/2024	to	Sat 11/02/2024		CENTRAL EAST - VC	<b>2485 MW</b>	
0700	Continuous	1530		Impacts Total Transfer Capability	235 MW	
Work scheduled by: NYPA				TTC with All Lines In Service	2720 MW	



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, July 31, 2023 to Thursday, January 30, 2025

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2720 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MARCY\_\_345KV\_CSC

Mon 10/28/2024 to Sun 11/10/2024  
0700 Continuous 1530  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
CENTRAL EAST - VC	<b>2650 MW</b>	
Impacts Total Transfer Capability	70 MW	
TTC with All Lines In Service	2720 MW	

### BECK\_\_-NIAGARA\_230\_PA27

Fri 11/15/2024 to Fri 11/15/2024  
0500 Continuous 1900  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - OH - NY	<b>2100 MW</b>	
Impacts Total Transfer Capability	300 MW	
TTC with All Lines In Service	2400 MW	

### ADIRNDCK-PORTER\_\_230\_12

Sun 12/01/2024 to Sat 05/31/2025  
0530 Continuous 1700  
Work scheduled by: NGrid

	FWD (Import)	REV (Export)
MOSES SOUTH	<b>2300 MW</b>	
Impacts Total Transfer Capability	850 MW	
TTC with All Lines In Service	3150 MW	