

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, September 17, 2023 to Sunday, March 16, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_10_BYPASS , DUNWODIE_345KV_9_BYPASS ,
SPRNBK_345KV_R4S3_BYPASS , SPRNBK_345KV_R5S3_BYPASS

Sun 02/01/2015 to Sat 02/01/2025
0000 0000

Work scheduled by:

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

4350 MW

Impacts Total Transfer Capability

250 MW

TTC with All Lines In Service

4600 MW

DUNWODIE_345KV_10_BYPASS , DUNWODIE_345KV_9_BYPASS ,
SPRNBK_345KV_R4S3_BYPASS , SPRNBK_345KV_R5S3_BYPASS

Sun 02/01/2015 to Sat 02/01/2025
0000 0000

Work scheduled by:

UPNY CONED

FWD (Import)

REV (Export)

7505 MW

Impacts Total Transfer Capability

545 MW

TTC with All Lines In Service

8050 MW

HUDSONP_-FARRAGUT_345_B3402

Mon 01/15/2018 to Sat 09/30/2023
0001 Continuous 2359

Work scheduled by: ConEd

EXT FORCED by ConEd 08/06/2022 16:26

SCH - PJ - NY

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

TTC with All Lines In Service

MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Sat 09/30/2023
0001 Continuous 2359

Work scheduled by: ConEd

EXT FORCED by ConEd 08/06/2022 16:26

SCH - PJ - NY

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

TTC with All Lines In Service

MARION_-FARRAGUT_345_C3403 , HUDSONP_-
FARRAGUT_345_B3402

Mon 01/15/2018 to Sat 09/30/2023
0001 2359

Work scheduled by:

SCH - PJ - NY

FWD (Import)

REV (Export)

2200 MW

Impacts Total Transfer Capability

50 MW

TTC with All Lines In Service

2250 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, September 17, 2023 to Sunday, March 16, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

STLAWRNC-MOSES__230_L34P

Mon 10/03/2022 to Mon 11/06/2023
1800 Continuous 0800

UPDATED by IESO 03/07/2023 10:12

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

Work scheduled by: IESO

SCH-NYISO-IMO_LIMIT_1300

Mon 06/26/2023 to Tue 10/31/2023
0001 Continuous 2359

UPDATED by IESO 08/20/2023 08:38

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

Work scheduled by: IESO

1600 MW

50 MW

1650 MW

SCH-IMO-NYISO_LIMIT_1600

Wed 06/28/2023 to Tue 10/31/2023
1801 Continuous 2359

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

Work scheduled by: IESO

1900 MW

150 MW

2050 MW

SHOR_NPX-SHOREHAM_138_CSC

Sat 08/05/2023 to Mon 10/02/2023
2124 Continuous 0559

EXT FORCED by ISONE 08/31/2023 06:50

SCH - NPX_CSC

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

Work scheduled by: ISONE

0 MW

0 MW

330 MW

330 MW

330 MW

330 MW

MARCY_SO_SERIES_COMP_I/S

Tue 08/22/2023 to Mon 10/09/2023
0001 Continuous 0659

EXTENDED by NYSEG 06/29/2023 14:33

CENTRAL EAST - VC

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

Work scheduled by: NYSEG

2450 MW

270 MW

2720 MW

SCH-NYISO-HQ_CEDARS_LIMIT_0

Tue 09/05/2023 to Thu 09/28/2023
0700 Continuous 2200

UPDATED by HQ 09/09/2023 10:50

SCH - HQ_CEDARS

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

Work scheduled by: HQ

0 MW

100 MW

100 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, September 17, 2023 to Sunday, March 16, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ADIRNDCK-CHASLAKE_230_13

Fri 09/08/2023 to Sat 10/21/2023
0700 Continuous 1600

Work scheduled by: NGrid

MOSES SOUTH
Impacts Total Transfer Capability 2100 MW
TTC with All Lines In Service 1050 MW
3150 MW

SCH-IMO-NYISO_LIMIT_1450

Fri 09/08/2023 to Sat 10/21/2023
0700 Continuous 1600

Work scheduled by: IESO

UPDATED by IESO 08/20/2023 08:38

SCH - OH - NY
Impacts Total Transfer Capability 1750 MW
TTC with All Lines In Service 300 MW
2050 MW

HOMRC_NY-MAINS_NY_345_47

Fri 09/08/2023 to Mon 09/18/2023
1612 Continuous 1600

Work scheduled by: PJM

FORCED by PJM 09/09/2023 07:29

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

SCH-HQ_CEDARS-NYISO_LIMIT_200

Mon 09/11/2023 to Thu 09/28/2023
0001 Continuous 2200

Work scheduled by: HQ

UPDATED by HQ 09/09/2023 10:50

SCH - HQ_CEDARS
Impacts Total Transfer Capability 200 MW
TTC with All Lines In Service 70 MW
270 MW

FRASER_-GILBOA_345_GF5-35

Mon 09/11/2023 to Sun 09/17/2023
0700 Continuous 1530

Work scheduled by: NYPA

CENTRAL EAST - VC
Impacts Total Transfer Capability 2450 MW
TTC with All Lines In Service 270 MW
2720 MW

SCH-IMO-NYISO_NIAG_CB_3008_W/BB

Thu 09/14/2023 to Mon 09/18/2023
0500 Continuous 0459

Work scheduled by: NYPA

UPDATED by NYPA 08/01/2023 08:11

SCH - OH - NY
Impacts Total Transfer Capability 1200 MW
TTC with All Lines In Service 450 MW
1650 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, September 17, 2023 to Sunday, March 16, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK_345KV_RNS5

Fri 09/15/2023 to Wed 10/25/2023

0001 Continuous 0100

Work scheduled by: ConEd

UPDATED by ConEd 04/21/2023 14:42

SPR/DUN-SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

3200 MW

1400 MW

4600 MW

SPRNBK_-W49TH_ST_345_M51

Fri 09/15/2023 to Wed 10/25/2023

0001 Continuous 0100

Work scheduled by: ConEd

UPDATED by ConEd 04/21/2023 14:42

SPR/DUN-SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

3200 MW

1400 MW

4600 MW

SCH-IMO-NYISO_LIMIT_600

Mon 09/18/2023 to Tue 09/19/2023

0500 Continuous 2000

Work scheduled by: NYPA

UPDATED by NYPA 08/03/2023 12:04

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

900 MW

1150 MW

2050 MW

SCH-NYISO-IMO_LIMIT_500

Mon 09/18/2023 to Tue 09/19/2023

0500 Continuous 2000

Work scheduled by: NYPA

UPDATED by NYPA 08/03/2023 12:04

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

800 MW

850 MW

1650 MW

SCH-NYISO-IMO_NIAGARA_NORTH_BUS

Mon 09/18/2023 to Tue 09/19/2023

0500 Continuous 2000

Work scheduled by: NYPA

UPDATED by NYPA 08/03/2023 12:04

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

1000 MW

850 MW

1050 MW

800 MW

2050 MW

1650 MW

CLAY_-EDIC_345_2-15

Mon 09/18/2023 to Fri 09/22/2023

0700 Continuous 1530

Work scheduled by: NYPA

OSWEGO EXPORT

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

4850 MW

400 MW

5250 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, September 17, 2023 to Sunday, March 16, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DOLSONAV-ROCKTVRN_345_DART44

Tue 09/19/2023 to Wed 09/20/2023
0700 Continuous 1600
Work scheduled by: CHGE

FWD (Import) REV (Export)
CENTRAL EAST - VC **2485 MW**
Impacts Total Transfer Capability 235 MW
TTC with All Lines In Service 2720 MW

BECK__-NIAGARA_345_PA301

Wed 09/20/2023 to Thu 09/21/2023
0500 Continuous 2100
Work scheduled by: NYPA
UPDATED by NYPA 08/04/2023 13:08

FWD (Import) REV (Export)
SCH - OH - NY **1000 MW** **850 MW**
Impacts Total Transfer Capability 1050 MW 800 MW
TTC with All Lines In Service 2050 MW 1650 MW

SCH-IMO-NYISO_LIMIT_600

Wed 09/20/2023 to Thu 09/21/2023
0500 Continuous 2100
Work scheduled by: NYPA
UPDATED by NYPA 08/04/2023 13:08

FWD (Import) REV (Export)
SCH - OH - NY **900 MW**
Impacts Total Transfer Capability 1150 MW
TTC with All Lines In Service 2050 MW

SCH-NYISO-IMO_LIMIT_500

Wed 09/20/2023 to Thu 09/21/2023
0500 Continuous 2100
Work scheduled by: NYPA
UPDATED by NYPA 08/04/2023 13:08

FWD (Import) REV (Export)
SCH - OH - NY **800 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 1650 MW

MARCY__-EDIC__345_UE1-7

Sat 09/23/2023 to Sun 09/24/2023
0500 Continuous 1900
Work scheduled by: NYPA
UPDATED by NYPA 10/28/2022 11:09
ARR: 19,16

FWD (Import) REV (Export)
OSWEGO EXPORT **5250 MW**
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 5250 MW

MARCY__345KV_CSC

Mon 09/25/2023 to Sat 10/07/2023
0500 Continuous 1530
Work scheduled by: NYPA

FWD (Import) REV (Export)
CENTRAL EAST - VC **2650 MW**
Impacts Total Transfer Capability 70 MW
TTC with All Lines In Service 2720 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, September 17, 2023 to Sunday, March 16, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY__345KV_CSC , MARCY_SO_SERIES_COMP_I/S

Mon 09/25/2023 to Sat 10/07/2023
0500 1530

FWD (Import) REV (Export)

CENTRAL EAST - VC **2380 MW**
Impacts Total Transfer Capability 340 MW
TTC with All Lines In Service 2720 MW

Work scheduled by:

NIAGARA_DYSINGER_345_ND2

Mon 09/25/2023 to Fri 09/29/2023
0500 Continuous 2000

FWD (Import) REV (Export)

DYSINGER EAST **2700 MW**
Impacts Total Transfer Capability 500 MW
TTC with All Lines In Service 3200 MW

Work scheduled by: NYPA

MAINESBG-WATRCURE_345_30

Mon 09/25/2023 to Tue 09/26/2023
0700 Continuous 1400

FWD (Import) REV (Export)

SCH - PJ - NY **1950 MW**
Impacts Total Transfer Capability 300 MW
TTC with All Lines In Service 2250 MW

Work scheduled by: PJM

ROSETON_EFISHKIL_345_RFK305

Mon 09/25/2023 to Fri 10/13/2023
0700 Continuous 1730

FWD (Import) REV (Export)

UPNY CONED **7215 MW**
Impacts Total Transfer Capability 835 MW
TTC with All Lines In Service 8050 MW

Work scheduled by: NYPA

UPDATED by ConEd 08/31/2023 13:41

MILLWOOD-EASTVIEW_345_W82

Wed 09/27/2023 to Thu 09/28/2023
0001 Continuous 1800

FWD (Import) REV (Export)

UPNY CONED **7810 MW**
Impacts Total Transfer Capability 240 MW
TTC with All Lines In Service 8050 MW

Work scheduled by: ConEd

ELBRIDGE-LAFAYTTE_345_17-LE

Thu 09/28/2023 to Fri 09/29/2023
0600 Continuous 1700

FWD (Import) REV (Export)

OSWEGO EXPORT **5250 MW**
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 5250 MW

Work scheduled by: NGrid

ARR: 75

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, September 17, 2023 to Sunday, March 16, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

OSWEGO_-ELBRIDGE_345_17

Thu 09/28/2023 to Thu 09/28/2023
0600 Continuous 0900

ARR: 75

FWD (Import) REV (Export)

OSWEGO EXPORT **5250 MW**
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 5250 MW

Work scheduled by: NGrid

MILLWOOD-EASTVIEW_345_W99

Fri 09/29/2023 to Sat 09/30/2023
0001 Continuous 1800

FWD (Import) REV (Export)

UPNY CONED **7810 MW**
Impacts Total Transfer Capability 240 MW
TTC with All Lines In Service 8050 MW

Work scheduled by: ConEd

OSWEGO_-ELBRIDGE_345_17

Fri 09/29/2023 to Fri 09/29/2023
1400 Continuous 1700

ARR: 75

FWD (Import) REV (Export)

OSWEGO EXPORT **5250 MW**
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 5250 MW

Work scheduled by: NGrid

E13THSTA-FARRAGUT_345_45

Sat 09/30/2023 to Sat 09/30/2023
0201 Continuous 0231

FWD (Import) REV (Export)

SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

E13THSTA-FARRAGUT_345_45

Sat 09/30/2023 to Sat 09/30/2023
0730 Continuous 0800

FWD (Import) REV (Export)

SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

DYSINGER-STA_255_345_DH2

Mon 10/02/2023 to Thu 10/12/2023
0500 Continuous 1900

FWD (Import) REV (Export)

DYSINGER EAST **2850 MW**
Impacts Total Transfer Capability 350 MW
TTC with All Lines In Service 3200 MW

Work scheduled by: NYPA

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, September 17, 2023 to Sunday, March 16, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SHOR_NPX-SHOREHAM_138_CSC

Mon 10/02/2023 to Fri 10/13/2023
0600 Continuous 2200

EXTENDED by LI 07/14/2023 09:47

SCH - NPX_CSC

FWD (Import)

REV (Export)

0 MW

0 MW

Impacts Total Transfer Capability

330 MW

330 MW

TTC with All Lines In Service

330 MW

330 MW

Work scheduled by: LI

NIAGARA_DYSINGER_345_ND2

Mon 10/02/2023 to Mon 10/02/2023
0800 Continuous 1159

DYSINGER EAST

FWD (Import)

REV (Export)

2700 MW

Impacts Total Transfer Capability

500 MW

TTC with All Lines In Service

3200 MW

Work scheduled by: NT

NIAGARA_DYSINGER_345_ND2 , DYSINGER-STA_255_345_DH2

Mon 10/02/2023 to Mon 10/02/2023
0800 1159

DYSINGER EAST

FWD (Import)

REV (Export)

2500 MW

Impacts Total Transfer Capability

700 MW

TTC with All Lines In Service

3200 MW

Work scheduled by:

FROST_BR-LONG_MTN_345_352

Mon 10/02/2023 to Sat 11/04/2023
0830 Continuous 1200

SCH - NE - NY

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: ISONE

ELBRIDGE-LAFAYTTE_345_17-LE

Tue 10/03/2023 to Fri 10/06/2023
0600 Continuous 1800

ARR: 75

OSWEGO EXPORT

FWD (Import)

REV (Export)

5250 MW

Impacts Total Transfer Capability

0 MW

TTC with All Lines In Service

5250 MW

Work scheduled by: NGrid

OSWEGO_-ELBRIDGE_345_17

Tue 10/03/2023 to Tue 10/03/2023
0600 Continuous 0900

ARR: 75

OSWEGO EXPORT

FWD (Import)

REV (Export)

5250 MW

Impacts Total Transfer Capability

0 MW

TTC with All Lines In Service

5250 MW

Work scheduled by: NGrid

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, September 17, 2023 to Sunday, March 16, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NE-NYISO_LIMIT_900

Tue 10/03/2023 to Wed 10/18/2023
0700 Continuous 1500

UPDATED by ISONE 08/03/2023 14:24

SCH - NE - NY

FWD (Import)

REV (Export)

1100 MW

Impacts Total Transfer Capability

300 MW

TTC with All Lines In Service

1400 MW

Work scheduled by: ISONE

SCRIBA_-VOLNEY__345_20

Tue 10/03/2023 to Tue 10/03/2023
0730 Continuous 1700

OSWEGO EXPORT

FWD (Import)

REV (Export)

5250 MW

Impacts Total Transfer Capability

0 MW

TTC with All Lines In Service

5250 MW

Work scheduled by: NGrid

DUNWODIE_345KV_4

Wed 10/04/2023 to Fri 11/10/2023
0001 Continuous 2200

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

3800 MW

Impacts Total Transfer Capability

800 MW

TTC with All Lines In Service

4600 MW

Work scheduled by: ConEd

KNICRBKR-PLSNTVLY_345_Y57

Wed 10/04/2023 to Fri 10/06/2023
0001 Continuous 2359

ARR: 78

UPNY CONED

FWD (Import)

REV (Export)

7885 MW

Impacts Total Transfer Capability

165 MW

TTC with All Lines In Service

8050 MW

Work scheduled by: NGrid

OSWEGO_-ELBRIDGE_345_17

Fri 10/06/2023 to Fri 10/06/2023
1730 Continuous 1800

ARR: 75

OSWEGO EXPORT

FWD (Import)

REV (Export)

5250 MW

Impacts Total Transfer Capability

0 MW

TTC with All Lines In Service

5250 MW

Work scheduled by: NGrid

BEAR SWP-EASTOVER_230_E205W

Mon 10/09/2023 to Mon 11/06/2023
0600 Continuous 1530

SCH - NE - NY

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: ISONE

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, September 17, 2023 to Sunday, March 16, 2025

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2720 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NE-NYISO_LIMIT_800

Mon 10/09/2023 to Mon 10/09/2023
0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY

FWD (Import)

REV (Export)

1000 MW

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

1400 MW

SCH-NYISO-NE_LIMIT_900

Mon 10/09/2023 to Mon 10/09/2023
0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY

FWD (Import)

REV (Export)

1100 MW

Impacts Total Transfer Capability

500 MW

TTC with All Lines In Service

1600 MW

OAKDALE_FRASER_345_32

Mon 10/09/2023 to Wed 10/11/2023
0900 Continuous 1500

Work scheduled by: NYSEG

CENTRAL EAST - VC

FWD (Import)

REV (Export)

2450 MW

Impacts Total Transfer Capability

270 MW

TTC with All Lines In Service

2720 MW

SCH-NE-NYISO_LIMIT_800

Mon 10/09/2023 to Tue 10/10/2023
2300 Daily 0659

Work scheduled by: ISONE

SCH - NE - NY

FWD (Import)

REV (Export)

1000 MW

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

1400 MW

SCH-NYISO-NE_LIMIT_900

Mon 10/09/2023 to Tue 10/10/2023
2300 Daily 0659

Work scheduled by: ISONE

SCH - NE - NY

FWD (Import)

REV (Export)

1100 MW

Impacts Total Transfer Capability

500 MW

TTC with All Lines In Service

1600 MW

ELBRIDGE-LAFAYTTE_345_17-LE

Tue 10/10/2023 to Wed 10/11/2023
0600 Continuous 1700

Work scheduled by: NGrid

ARR: 75

OSWEGO EXPORT

FWD (Import)

REV (Export)

5250 MW

Impacts Total Transfer Capability

0 MW

TTC with All Lines In Service

5250 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, September 17, 2023 to Sunday, March 16, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

OSWEGO_-ELBRIDGE_345_17

Tue 10/10/2023 to Fri 10/27/2023
0600 Continuous 2100

ARR: 75

FWD (Import) REV (Export)

OSWEGO EXPORT **5250 MW**
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 5250 MW

SCH-NE-NYISO_LIMIT_800

Tue 10/10/2023 to Tue 10/10/2023
0700 Daily 2259

FWD (Import) REV (Export)

SCH - NE - NY **1000 MW**
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 1400 MW

SCH-NYISO-NE_LIMIT_900

Tue 10/10/2023 to Tue 10/10/2023
0700 Daily 2259

FWD (Import) REV (Export)

SCH - NE - NY **1100 MW**
Impacts Total Transfer Capability 500 MW
TTC with All Lines In Service 1600 MW

SCH-NE-NYISO_LIMIT_800

Tue 10/10/2023 to Wed 10/11/2023
2300 Daily 0659

FWD (Import) REV (Export)

SCH - NE - NY **1000 MW**
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 1400 MW

SCH-NYISO-NE_LIMIT_900

Tue 10/10/2023 to Wed 10/11/2023
2300 Daily 0659

FWD (Import) REV (Export)

SCH - NE - NY **1100 MW**
Impacts Total Transfer Capability 500 MW
TTC with All Lines In Service 1600 MW

LINDEN_-GOETHALS_230_A2253

Wed 10/11/2023 to Wed 10/11/2023
0200 Continuous 2300

FWD (Import) REV (Export)

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

Work scheduled by: ConEd

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, September 17, 2023 to Sunday, March 16, 2025

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2720 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NE-NYISO_LIMIT_800

Wed 10/11/2023 to Wed 10/11/2023
0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
	1000 MW	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

SCH-NYISO-NE_LIMIT_900

Wed 10/11/2023 to Wed 10/11/2023
0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
	1100 MW	
Impacts Total Transfer Capability	500 MW	
TTC with All Lines In Service	1600 MW	

SCH-NE-NYISO_LIMIT_800

Wed 10/11/2023 to Thu 10/12/2023
2300 Daily 0659

Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
	1000 MW	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

SCH-NYISO-NE_LIMIT_900

Wed 10/11/2023 to Thu 10/12/2023
2300 Daily 0659

Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
	1100 MW	
Impacts Total Transfer Capability	500 MW	
TTC with All Lines In Service	1600 MW	

SCH-NE-NYISO_LIMIT_800

Thu 10/12/2023 to Thu 10/12/2023
0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
	1000 MW	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

SCH-NYISO-NE_LIMIT_900

Thu 10/12/2023 to Thu 10/12/2023
0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
	1100 MW	
Impacts Total Transfer Capability	500 MW	
TTC with All Lines In Service	1600 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, September 17, 2023 to Sunday, March 16, 2025

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2720 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NE-NYISO_LIMIT_800

Thu 10/12/2023 to Fri 10/13/2023
2300 Daily 0659
Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
	1000 MW	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

SCH-NYISO-NE_LIMIT_900

Thu 10/12/2023 to Fri 10/13/2023
2300 Daily 0659
Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
		1100 MW
Impacts Total Transfer Capability		500 MW
TTC with All Lines In Service		1600 MW

NIAGARA_PACKARD_230_61

Fri 10/13/2023 to Fri 10/13/2023
0500 Continuous 1900
Work scheduled by: NYPA

SCH - OH - NY	FWD (Import)	REV (Export)
	1900 MW	1450 MW
Impacts Total Transfer Capability	150 MW	200 MW
TTC with All Lines In Service	2050 MW	1650 MW

SCH-NE-NYISO_LIMIT_800

Fri 10/13/2023 to Fri 10/13/2023
0700 Daily 2259
Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
	1000 MW	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

SCH-NYISO-NE_LIMIT_900

Fri 10/13/2023 to Fri 10/13/2023
0700 Daily 2259
Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
		1100 MW
Impacts Total Transfer Capability		500 MW
TTC with All Lines In Service		1600 MW

SCH-NE-NYISO_LIMIT_800

Fri 10/13/2023 to Sat 10/14/2023
2300 Daily 0659
Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
	1000 MW	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, September 17, 2023 to Sunday, March 16, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-NE_LIMIT_900

Fri 10/13/2023 to Sat 10/14/2023
2300 Daily 0659
Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)
Impacts Total Transfer Capability 1100 MW
TTC with All Lines In Service 500 MW
1600 MW

DYSINGER-STA_255_345_DH1

Sat 10/14/2023 to Tue 10/24/2023
0500 Continuous 1900
Work scheduled by: NYPA

DYSINGER EAST FWD (Import) REV (Export)
Impacts Total Transfer Capability 2850 MW
TTC with All Lines In Service 350 MW
3200 MW

SCH-NE-NYISO_LIMIT_800

Sat 10/14/2023 to Sat 10/14/2023
0700 Daily 2259
Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)
Impacts Total Transfer Capability 1000 MW
TTC with All Lines In Service 400 MW
1400 MW

SCH-NYISO-NE_LIMIT_900

Sat 10/14/2023 to Sat 10/14/2023
0700 Daily 2259
Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)
Impacts Total Transfer Capability 1100 MW
TTC with All Lines In Service 500 MW
1600 MW

SCH-NE-NYISO_LIMIT_800

Sat 10/14/2023 to Sun 10/15/2023
2300 Daily 0659
Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)
Impacts Total Transfer Capability 1000 MW
TTC with All Lines In Service 400 MW
1400 MW

SCH-NYISO-NE_LIMIT_900

Sat 10/14/2023 to Sun 10/15/2023
2300 Daily 0659
Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)
Impacts Total Transfer Capability 1100 MW
TTC with All Lines In Service 500 MW
1600 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, September 17, 2023 to Sunday, March 16, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHAT_DC_GC1

Sun 10/15/2023 to Sun 10/15/2023
0001 Continuous 0200

Work scheduled by: HQ

MOSES SOUTH FWD (Import) REV (Export)
2850 MW
Impacts Total Transfer Capability 300 MW
TTC with All Lines In Service 3150 MW

CHAT_DC_GC1

Sun 10/15/2023 to Sun 10/15/2023
0001 Continuous 0200

Work scheduled by: HQ

SCH - HQ - NY FWD (Import) REV (Export)
500 MW
Impacts Total Transfer Capability 500 MW
TTC with All Lines In Service 1000 MW

CHAT_DC_GC1 , CHAT_DC_GC2

Sun 10/15/2023 to Sun 10/15/2023
0001 0200

Work scheduled by:

MOSES SOUTH FWD (Import) REV (Export)
2550 MW
Impacts Total Transfer Capability 600 MW
TTC with All Lines In Service 3150 MW

CHAT_DC_GC1 , CHAT_DC_GC2

Sun 10/15/2023 to Sun 10/15/2023
0001 0200

Work scheduled by:

SCH - HQ - NY FWD (Import) REV (Export)
1370 MW 0 MW
Impacts Total Transfer Capability 130 MW 1000 MW
TTC with All Lines In Service 1500 MW 1000 MW

CHAT_DC_GC2

Sun 10/15/2023 to Sun 10/15/2023
0001 Continuous 0200

Work scheduled by: HQ

MOSES SOUTH FWD (Import) REV (Export)
2850 MW
Impacts Total Transfer Capability 300 MW
TTC with All Lines In Service 3150 MW

CHAT_DC_GC2

Sun 10/15/2023 to Sun 10/15/2023
0001 Continuous 0200

Work scheduled by: HQ

SCH - HQ - NY FWD (Import) REV (Export)
500 MW
Impacts Total Transfer Capability 500 MW
TTC with All Lines In Service 1000 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, September 17, 2023 to Sunday, March 16, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HOPATCON-RAMAPO__500_5018

Sun 10/15/2023 to Sun 10/15/2023

0001 Continuous 2200

Work scheduled by: ConEd

TOTAL EAST	FWD (Import)	REV (Export)
	5400 MW	
Impacts Total Transfer Capability	750 MW	
TTC with All Lines In Service	6150 MW	

HOPATCON-RAMAPO__500_5018

Sun 10/15/2023 to Sun 10/15/2023

0001 Continuous 2200

Work scheduled by: ConEd

SCH - PJ - NY	FWD (Import)	REV (Export)
	1100 MW	1000 MW
Impacts Total Transfer Capability	1150 MW	200 MW
TTC with All Lines In Service	2250 MW	1200 MW

HOPATCON-RAMAPO__500_5018

Sun 10/15/2023 to Sun 10/15/2023

0001 Continuous 2200

Work scheduled by: ConEd

UPNY CONED	FWD (Import)	REV (Export)
	7795 MW	
Impacts Total Transfer Capability	255 MW	
TTC with All Lines In Service	8050 MW	

RAMAPO__345_345_PAR3500

Sun 10/15/2023 to Sun 10/15/2023

0001 Continuous 2200

Work scheduled by: ConEd

SCH - PJ - NY	FWD (Import)	REV (Export)
	1750 MW	
Impacts Total Transfer Capability	500 MW	
TTC with All Lines In Service	2250 MW	

RAMAPO__345_345_PAR4500

Sun 10/15/2023 to Sun 10/15/2023

0001 Continuous 2200

Work scheduled by: ConEd

SCH - PJ - NY	FWD (Import)	REV (Export)
	1750 MW	
Impacts Total Transfer Capability	500 MW	
TTC with All Lines In Service	2250 MW	

RAMAPO__500_345_BK 1500

Sun 10/15/2023 to Sun 10/15/2023

0001 Continuous 2200

Work scheduled by: ConEd

SCH - PJ - NY	FWD (Import)	REV (Export)
	1100 MW	1000 MW
Impacts Total Transfer Capability	1150 MW	200 MW
TTC with All Lines In Service	2250 MW	1200 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, September 17, 2023 to Sunday, March 16, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

RAMAPO__500_345_BK 1500

Sun 10/15/2023 to Sun 10/15/2023

0001 Continuous 2200

Work scheduled by: ConEd

UPNY CONED

FWD (Import)

REV (Export)

7795 MW

Impacts Total Transfer Capability

255 MW

TTC with All Lines In Service

8050 MW

SCH-HQ-NYISO_LIMIT_1150

Sun 10/15/2023 to Sun 10/15/2023

0001 Continuous 0200

Work scheduled by: HQ

SCH - HQ - NY

FWD (Import)

REV (Export)

1150 MW

Impacts Total Transfer Capability

350 MW

TTC with All Lines In Service

1500 MW

SCH-NE-NYISO_LIMIT_800

Sun 10/15/2023 to Sun 10/15/2023

0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY

FWD (Import)

REV (Export)

1000 MW

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

1400 MW

SCH-NYISO-NE_LIMIT_900

Sun 10/15/2023 to Sun 10/15/2023

0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY

FWD (Import)

REV (Export)

1100 MW

Impacts Total Transfer Capability

500 MW

TTC with All Lines In Service

1600 MW

SCH-NE-NYISO_LIMIT_800

Sun 10/15/2023 to Mon 10/16/2023

2300 Daily 0659

Work scheduled by: ISONE

SCH - NE - NY

FWD (Import)

REV (Export)

1000 MW

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

1400 MW

SCH-NYISO-NE_LIMIT_900

Sun 10/15/2023 to Mon 10/16/2023

2300 Daily 0659

Work scheduled by: ISONE

SCH - NE - NY

FWD (Import)

REV (Export)

1100 MW

Impacts Total Transfer Capability

500 MW

TTC with All Lines In Service

1600 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, September 17, 2023 to Sunday, March 16, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LADENTWN-BUCHAN_S_345_Y88

Mon 10/16/2023 to Mon 11/06/2023
0201 Continuous 0200

UPDATED by ConEd 06/16/2023 08:29

UPNY CONED

FWD (Import)

REV (Export)

7695 MW

Impacts Total Transfer Capability

355 MW

TTC with All Lines In Service

8050 MW

Work scheduled by: ConEd

FRASANNX-COOPERS_345_UCC2-41

Mon 10/16/2023 to Fri 10/27/2023
0600 Continuous 1730

ARR: 19

CENTRAL EAST - VC

FWD (Import)

REV (Export)

2275 MW

Impacts Total Transfer Capability

445 MW

TTC with All Lines In Service

2720 MW

Work scheduled by: NYPA

MARCY_-FRASANNX_345_UCC2-41

Mon 10/16/2023 to Fri 10/27/2023
0600 Continuous 1730

ARR: 19

CENTRAL EAST - VC

FWD (Import)

REV (Export)

2275 MW

Impacts Total Transfer Capability

445 MW

TTC with All Lines In Service

2720 MW

Work scheduled by: NYPA

MOSES_-ADIRNDCK_230_MA2

Mon 10/16/2023 to Mon 10/16/2023
0700 Continuous 1730

MOSES SOUTH

FWD (Import)

REV (Export)

2100 MW

Impacts Total Transfer Capability

1050 MW

TTC with All Lines In Service

3150 MW

Work scheduled by: NYPA

SCH-NE-NYISO_LIMIT_800

Mon 10/16/2023 to Mon 10/16/2023
0700 Daily 2259

SCH - NE - NY

FWD (Import)

REV (Export)

1000 MW

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

1400 MW

Work scheduled by: ISONE

SCH-NYISO-NE_LIMIT_900

Mon 10/16/2023 to Mon 10/16/2023
0700 Daily 2259

SCH - NE - NY

FWD (Import)

REV (Export)

1100 MW

Impacts Total Transfer Capability

500 MW

TTC with All Lines In Service

1600 MW

Work scheduled by: ISONE

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, September 17, 2023 to Sunday, March 16, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HOMR_NYW-PIERC_NY_345_48

Mon 10/16/2023 to Fri 10/20/2023
0800 Continuous 1600
Work scheduled by: PJM

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

SCH-NE-NYISO_LIMIT_800

Mon 10/16/2023 to Tue 10/17/2023
2300 Daily 0659
Work scheduled by: ISONE

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
1000 MW
400 MW
1400 MW

SCH-NYISO-NE_LIMIT_900

Mon 10/16/2023 to Tue 10/17/2023
2300 Daily 0659
Work scheduled by: ISONE

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
1100 MW
500 MW
1600 MW

SCH-NE-NYISO_LIMIT_800

Tue 10/17/2023 to Tue 10/17/2023
0700 Daily 2259
Work scheduled by: ISONE

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
1000 MW
400 MW
1400 MW

SCH-NYISO-NE_LIMIT_900

Tue 10/17/2023 to Tue 10/17/2023
0700 Daily 2259
Work scheduled by: ISONE

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
1100 MW
500 MW
1600 MW

SCH-NE-NYISO_LIMIT_800

Tue 10/17/2023 to Wed 10/18/2023
2300 Daily 0659
Work scheduled by: ISONE

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
1000 MW
400 MW
1400 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, September 17, 2023 to Sunday, March 16, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-NE_LIMIT_900

Tue 10/17/2023 to Wed 10/18/2023
2300 Daily 0659
Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)
Impacts Total Transfer Capability **1100 MW**
TTC with All Lines In Service 500 MW
1600 MW

SCH-NE-NYISO_LIMIT_800

Wed 10/18/2023 to Wed 10/18/2023
0700 Daily 2259
Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)
Impacts Total Transfer Capability **1000 MW**
TTC with All Lines In Service 400 MW
1400 MW

SCH-NYISO-NE_LIMIT_900

Wed 10/18/2023 to Wed 10/18/2023
0700 Daily 2259
Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)
Impacts Total Transfer Capability **1100 MW**
TTC with All Lines In Service 500 MW
1600 MW

SCH-NE-NYISO_LIMIT_800

Wed 10/18/2023 to Thu 10/19/2023
2300 Daily 0659
Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)
Impacts Total Transfer Capability **1000 MW**
TTC with All Lines In Service 400 MW
1400 MW

SCH-NYISO-NE_LIMIT_900

Wed 10/18/2023 to Thu 10/19/2023
2300 Daily 0659
Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)
Impacts Total Transfer Capability **1100 MW**
TTC with All Lines In Service 500 MW
1600 MW

SCH-NE-NYISO_LIMIT_800

Thu 10/19/2023 to Thu 10/19/2023
0700 Daily 2259
Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)
Impacts Total Transfer Capability **1000 MW**
TTC with All Lines In Service 400 MW
1400 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, September 17, 2023 to Sunday, March 16, 2025

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2720 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-NE_LIMIT_900					FWD (Import)	REV (Export)
Thu 10/19/2023	to	Thu 10/19/2023		SCH - NE - NY		1100 MW
0700	Daily	2259		Impacts Total Transfer Capability		500 MW
Work scheduled by: ISONE				TTC with All Lines In Service		1600 MW
SCH-NE-NYISO_LIMIT_900					FWD (Import)	REV (Export)
Thu 10/19/2023	to	Mon 10/30/2023		SCH - NE - NY		1100 MW
0830	Continuous	0900		Impacts Total Transfer Capability	300 MW	
Work scheduled by: ISONE				TTC with All Lines In Service	1400 MW	
SCH-NE-NYISO_LIMIT_800					FWD (Import)	REV (Export)
Thu 10/19/2023	to	Fri 10/20/2023		SCH - NE - NY		1000 MW
2300	Daily	0659		Impacts Total Transfer Capability	400 MW	
Work scheduled by: ISONE				TTC with All Lines In Service	1400 MW	
SCH-NYISO-NE_LIMIT_900					FWD (Import)	REV (Export)
Thu 10/19/2023	to	Fri 10/20/2023		SCH - NE - NY		1100 MW
2300	Daily	0659		Impacts Total Transfer Capability	500 MW	
Work scheduled by: ISONE				TTC with All Lines In Service	1600 MW	
SCH-NE-NYISO_LIMIT_800					FWD (Import)	REV (Export)
Fri 10/20/2023	to	Fri 10/20/2023		SCH - NE - NY		1000 MW
0700	Daily	2259		Impacts Total Transfer Capability	400 MW	
Work scheduled by: ISONE				TTC with All Lines In Service	1400 MW	
SCH-NYISO-NE_LIMIT_900					FWD (Import)	REV (Export)
Fri 10/20/2023	to	Fri 10/20/2023		SCH - NE - NY		1100 MW
0700	Daily	2259		Impacts Total Transfer Capability	500 MW	
Work scheduled by: ISONE				TTC with All Lines In Service	1600 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, September 17, 2023 to Sunday, March 16, 2025

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2720 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NE-NYISO_LIMIT_800

Fri 10/20/2023 to Sat 10/21/2023
2300 Daily 0659

Work scheduled by: ISONE

SCH - NE - NY

FWD (Import)

REV (Export)

1000 MW

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

1400 MW

SCH-NYISO-NE_LIMIT_900

Fri 10/20/2023 to Sat 10/21/2023
2300 Daily 0659

Work scheduled by: ISONE

SCH - NE - NY

FWD (Import)

REV (Export)

1100 MW

Impacts Total Transfer Capability

500 MW

TTC with All Lines In Service

1600 MW

SCH-NE-NYISO_LIMIT_800

Sat 10/21/2023 to Sat 10/21/2023
0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY

FWD (Import)

REV (Export)

1000 MW

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

1400 MW

SCH-NYISO-NE_LIMIT_900

Sat 10/21/2023 to Sat 10/21/2023
0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY

FWD (Import)

REV (Export)

1100 MW

Impacts Total Transfer Capability

500 MW

TTC with All Lines In Service

1600 MW

SCH-NE-NYISO_LIMIT_800

Sat 10/21/2023 to Sun 10/22/2023
2300 Daily 0659

Work scheduled by: ISONE

SCH - NE - NY

FWD (Import)

REV (Export)

1000 MW

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

1400 MW

SCH-NYISO-NE_LIMIT_900

Sat 10/21/2023 to Sun 10/22/2023
2300 Daily 0659

Work scheduled by: ISONE

SCH - NE - NY

FWD (Import)

REV (Export)

1100 MW

Impacts Total Transfer Capability

500 MW

TTC with All Lines In Service

1600 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, September 17, 2023 to Sunday, March 16, 2025

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2720 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHASLAKE-PORTER__230_11

Sun 10/22/2023 to Tue 11/14/2023
0630 Continuous 1730

Work scheduled by: NGrid

MOSES SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

2100 MW
1050 MW
3150 MW

SCH-IMO-NYISO_LIMIT_1450

Sun 10/22/2023 to Tue 10/31/2023
0630 Continuous 2359

Work scheduled by: IESO

UPDATED by IESO 08/20/2023 08:38

SCH - OH - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

1750 MW
300 MW
2050 MW

SCH-NE-NYISO_LIMIT_800

Sun 10/22/2023 to Sun 10/22/2023
0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

1000 MW
400 MW
1400 MW

SCH-NYISO-NE_LIMIT_900

Sun 10/22/2023 to Sun 10/22/2023
0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

1100 MW
500 MW
1600 MW

SCH-NE-NYISO_LIMIT_800

Sun 10/22/2023 to Mon 10/23/2023
2300 Daily 0659

Work scheduled by: ISONE

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

1000 MW
400 MW
1400 MW

SCH-NYISO-NE_LIMIT_900

Sun 10/22/2023 to Mon 10/23/2023
2300 Daily 0659

Work scheduled by: ISONE

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

1100 MW
500 MW
1600 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, September 17, 2023 to Sunday, March 16, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_6

Mon 10/23/2023 to Thu 11/09/2023
0001 Continuous 2200
Work scheduled by: ConEd

SPR/DUN-SOUTH FWD (Import) REV (Export)
3800 MW
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

DUNWODIE-SHORE_RD_345_Y50

Mon 10/23/2023 to Thu 11/09/2023
0001 Continuous 2200
Work scheduled by: ConEd

CONED - LIPA FWD (Import) REV (Export)
800 MW
Impacts Total Transfer Capability 700 MW
TTC with All Lines In Service 1500 MW

SHORE_RD_345_138_BK 1

Mon 10/23/2023 to Thu 11/09/2023
0001 Continuous 2200
Work scheduled by: ConEd

CONED - LIPA FWD (Import) REV (Export)
1350 MW
Impacts Total Transfer Capability 150 MW
TTC with All Lines In Service 1500 MW

SHORE_RD_345_138_BK 2

Mon 10/23/2023 to Thu 11/09/2023
0001 Continuous 2200
Work scheduled by: ConEd

CONED - LIPA FWD (Import) REV (Export)
1350 MW
Impacts Total Transfer Capability 150 MW
TTC with All Lines In Service 1500 MW

PANNELL-CLAY_345_2

Mon 10/23/2023 to Fri 10/27/2023
0600 Continuous 1800
Work scheduled by: NYPA

WEST CENTRAL FWD (Import) REV (Export)
1300 MW
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

SCH-NE-NYISO_LIMIT_800

Mon 10/23/2023 to Mon 10/23/2023
0700 Daily 2259
Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)
1000 MW
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 1400 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, September 17, 2023 to Sunday, March 16, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-NE_LIMIT_900

Mon 10/23/2023 to Mon 10/23/2023
0700 Daily 2259

FWD (Import) REV (Export)

SCH - NE - NY **1100 MW**
Impacts Total Transfer Capability 500 MW
TTC with All Lines In Service 1600 MW

Work scheduled by: ISONE

SCH-NE-NYISO_LIMIT_800

Mon 10/23/2023 to Tue 10/24/2023
2300 Daily 0659

FWD (Import) REV (Export)

SCH - NE - NY **1000 MW**
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 1400 MW

Work scheduled by: ISONE

SCH-NYISO-NE_LIMIT_900

Mon 10/23/2023 to Tue 10/24/2023
2300 Daily 0659

FWD (Import) REV (Export)

SCH - NE - NY **1100 MW**
Impacts Total Transfer Capability 500 MW
TTC with All Lines In Service 1600 MW

Work scheduled by: ISONE

SCH-NE-NYISO_LIMIT_800

Tue 10/24/2023 to Tue 10/24/2023
0700 Daily 2259

FWD (Import) REV (Export)

SCH - NE - NY **1000 MW**
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 1400 MW

Work scheduled by: ISONE

SCH-NYISO-NE_LIMIT_900

Tue 10/24/2023 to Tue 10/24/2023
0700 Daily 2259

FWD (Import) REV (Export)

SCH - NE - NY **1100 MW**
Impacts Total Transfer Capability 500 MW
TTC with All Lines In Service 1600 MW

Work scheduled by: ISONE

SCH-NE-NYISO_LIMIT_800

Tue 10/24/2023 to Wed 10/25/2023
2300 Daily 0659

FWD (Import) REV (Export)

SCH - NE - NY **1000 MW**
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 1400 MW

Work scheduled by: ISONE

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, September 17, 2023 to Sunday, March 16, 2025

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2720 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-NE_LIMIT_900

Tue 10/24/2023 to Wed 10/25/2023
2300 Daily 0659
Work scheduled by: ISONE

	FWD (Import)	REV (Export)
SCH - NE - NY		1100 MW
Impacts Total Transfer Capability		500 MW
TTC with All Lines In Service		1600 MW

SCH-NE-NYISO_LIMIT_800

Wed 10/25/2023 to Wed 10/25/2023
0700 Daily 2259
Work scheduled by: ISONE

	FWD (Import)	REV (Export)
SCH - NE - NY		1000 MW
Impacts Total Transfer Capability		400 MW
TTC with All Lines In Service		1400 MW

SCH-NYISO-NE_LIMIT_900

Wed 10/25/2023 to Wed 10/25/2023
0700 Daily 2259
Work scheduled by: ISONE

	FWD (Import)	REV (Export)
SCH - NE - NY		1100 MW
Impacts Total Transfer Capability		500 MW
TTC with All Lines In Service		1600 MW

SCH-NE-NYISO_LIMIT_800

Wed 10/25/2023 to Thu 10/26/2023
2300 Daily 0659
Work scheduled by: ISONE

	FWD (Import)	REV (Export)
SCH - NE - NY		1000 MW
Impacts Total Transfer Capability		400 MW
TTC with All Lines In Service		1400 MW

SCH-NYISO-NE_LIMIT_900

Wed 10/25/2023 to Thu 10/26/2023
2300 Daily 0659
Work scheduled by: ISONE

	FWD (Import)	REV (Export)
SCH - NE - NY		1100 MW
Impacts Total Transfer Capability		500 MW
TTC with All Lines In Service		1600 MW

E13THSTA-FARRAGUT_345_45

Thu 10/26/2023 to Thu 10/26/2023
0001 Continuous 0030
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH		3800 MW
Impacts Total Transfer Capability		800 MW
TTC with All Lines In Service		4600 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, September 17, 2023 to Sunday, March 16, 2025

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2720 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NE-NYISO_LIMIT_800

Thu 10/26/2023 to Thu 10/26/2023
0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	1000 MW	
TTC with All Lines In Service	400 MW	
	1400 MW	

SCH-NYISO-NE_LIMIT_900

Thu 10/26/2023 to Thu 10/26/2023
0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	1100 MW	
TTC with All Lines In Service	500 MW	
	1600 MW	

SCH-NE-NYISO_LIMIT_800

Thu 10/26/2023 to Fri 10/27/2023
2300 Daily 0659

Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	1000 MW	
TTC with All Lines In Service	400 MW	
	1400 MW	

SCH-NYISO-NE_LIMIT_900

Thu 10/26/2023 to Fri 10/27/2023
2300 Daily 0659

Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	1100 MW	
TTC with All Lines In Service	500 MW	
	1600 MW	

SCH-NE-NYISO_LIMIT_800

Fri 10/27/2023 to Fri 10/27/2023
0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	1000 MW	
TTC with All Lines In Service	400 MW	
	1400 MW	

SCH-NYISO-NE_LIMIT_900

Fri 10/27/2023 to Fri 10/27/2023
0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	1100 MW	
TTC with All Lines In Service	500 MW	
	1600 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, September 17, 2023 to Sunday, March 16, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ELBRIDGE-LAFAYTTE_345_17-LE

Fri 10/27/2023 to Fri 10/27/2023
1800 Continuous 2100

ARR: 75

Work scheduled by: NGrid

OSWEGO EXPORT

FWD (Import)

REV (Export)

5250 MW

Impacts Total Transfer Capability

0 MW

TTC with All Lines In Service

5250 MW

LAFAYTTE-CLRKSCRN_345_4-46

Fri 10/27/2023 to Fri 10/27/2023
1800 Continuous 2100

Work scheduled by: NGrid

CENTRAL EAST - VC

FWD (Import)

REV (Export)

2450 MW

Impacts Total Transfer Capability

270 MW

TTC with All Lines In Service

2720 MW

SCH-NE-NYISO_LIMIT_800

Fri 10/27/2023 to Sat 10/28/2023
2300 Daily 0659

Work scheduled by: ISONE

SCH - NE - NY

FWD (Import)

REV (Export)

1000 MW

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

1400 MW

SCH-NYISO-NE_LIMIT_900

Fri 10/27/2023 to Sat 10/28/2023
2300 Daily 0659

Work scheduled by: ISONE

SCH - NE - NY

FWD (Import)

REV (Export)

1100 MW

Impacts Total Transfer Capability

500 MW

TTC with All Lines In Service

1600 MW

SCH-NE-NYISO_LIMIT_800

Sat 10/28/2023 to Sat 10/28/2023
0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY

FWD (Import)

REV (Export)

1000 MW

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

1400 MW

SCH-NYISO-NE_LIMIT_900

Sat 10/28/2023 to Sat 10/28/2023
0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY

FWD (Import)

REV (Export)

1100 MW

Impacts Total Transfer Capability

500 MW

TTC with All Lines In Service

1600 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, September 17, 2023 to Sunday, March 16, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NE-NYISO_LIMIT_800

Sat 10/28/2023 to Sun 10/29/2023
2300 Daily 0659

Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)
1000 MW
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 1400 MW

SCH-NYISO-NE_LIMIT_900

Sat 10/28/2023 to Sun 10/29/2023
2300 Daily 0659

Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)
1100 MW
Impacts Total Transfer Capability 500 MW
TTC with All Lines In Service 1600 MW

MOSES__-ADIRNDCK_230_MA1

Sun 10/29/2023 to Sat 11/04/2023
0700 Continuous 1930

Work scheduled by: NYPA

MOSES SOUTH FWD (Import) REV (Export)
2100 MW
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

SCH-NE-NYISO_LIMIT_800

Sun 10/29/2023 to Sun 10/29/2023
0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)
1000 MW
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 1400 MW

SCH-NYISO-NE_LIMIT_900

Sun 10/29/2023 to Sun 10/29/2023
0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)
1100 MW
Impacts Total Transfer Capability 500 MW
TTC with All Lines In Service 1600 MW

SCH-NE-NYISO_LIMIT_800

Sun 10/29/2023 to Mon 10/30/2023
2300 Daily 0659

Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)
1000 MW
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 1400 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, September 17, 2023 to Sunday, March 16, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-NE_LIMIT_900

Sun 10/29/2023 to Mon 10/30/2023
2300 Daily 0659

SCH - NE - NY FWD (Import) REV (Export)
Impacts Total Transfer Capability 1100 MW
TTC with All Lines In Service 500 MW
1600 MW

Work scheduled by: ISONE

SPRNBK-TREMONT_345_X28

Mon 10/30/2023 to Mon 10/30/2023
0001 Continuous 0400

UPDATED by ConEd 08/01/2023 16:11

SPR/DUN-SOUTH FWD (Import) REV (Export)
Impacts Total Transfer Capability 4200 MW
TTC with All Lines In Service 400 MW
4600 MW

Work scheduled by: ConEd

E13THSTA-FARRAGUT_345_45

Mon 10/30/2023 to Mon 10/30/2023
0230 Continuous 0300

SPR/DUN-SOUTH FWD (Import) REV (Export)
Impacts Total Transfer Capability 3800 MW
TTC with All Lines In Service 800 MW
4600 MW

Work scheduled by: ConEd

SCH-NE-NYISO_LIMIT_800

Mon 10/30/2023 to Mon 10/30/2023
0700 Daily 2259

SCH - NE - NY FWD (Import) REV (Export)
Impacts Total Transfer Capability 1000 MW
TTC with All Lines In Service 400 MW
1400 MW

Work scheduled by: ISONE

SCH-NYISO-NE_LIMIT_900

Mon 10/30/2023 to Mon 10/30/2023
0700 Daily 2259

SCH - NE - NY FWD (Import) REV (Export)
Impacts Total Transfer Capability 1100 MW
TTC with All Lines In Service 500 MW
1600 MW

Work scheduled by: ISONE

SCH-NE-NYISO_LIMIT_800

Mon 10/30/2023 to Tue 10/31/2023
2300 Daily 0659

SCH - NE - NY FWD (Import) REV (Export)
Impacts Total Transfer Capability 1000 MW
TTC with All Lines In Service 400 MW
1400 MW

Work scheduled by: ISONE

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, September 17, 2023 to Sunday, March 16, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-NE_LIMIT_900

Mon 10/30/2023 to Tue 10/31/2023
2300 Daily 0659

FWD (Import) REV (Export)

SCH - NE - NY **1100 MW**
Impacts Total Transfer Capability 500 MW
TTC with All Lines In Service 1600 MW

Work scheduled by: ISONE

SCH-NE-NYISO_LIMIT_800

Tue 10/31/2023 to Tue 10/31/2023
0700 Daily 2259

FWD (Import) REV (Export)

SCH - NE - NY **1000 MW**
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 1400 MW

Work scheduled by: ISONE

SCH-NYISO-NE_LIMIT_900

Tue 10/31/2023 to Tue 10/31/2023
0700 Daily 2259

FWD (Import) REV (Export)

SCH - NE - NY **1100 MW**
Impacts Total Transfer Capability 500 MW
TTC with All Lines In Service 1600 MW

Work scheduled by: ISONE

SCH-NE-NYISO_LIMIT_800

Tue 10/31/2023 to Wed 11/01/2023
2300 Daily 0659

FWD (Import) REV (Export)

SCH - NE - NY **1000 MW**
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 1400 MW

Work scheduled by: ISONE

SCH-NYISO-NE_LIMIT_900

Tue 10/31/2023 to Wed 11/01/2023
2300 Daily 0659

FWD (Import) REV (Export)

SCH - NE - NY **1100 MW**
Impacts Total Transfer Capability 500 MW
TTC with All Lines In Service 1600 MW

Work scheduled by: ISONE

NEPTUNE_DUFFYAVE_345_NEPTUNE

Wed 11/01/2023 to Mon 11/20/2023
0001 Continuous 2359

FWD (Import) REV (Export)

SCH - PJM_NEPTUNE **0 MW**
Impacts Total Transfer Capability 660 MW
TTC with All Lines In Service 660 MW

Work scheduled by: LI

UPDATED by LI 04/22/2023 14:51

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, September 17, 2023 to Sunday, March 16, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEWBRDGE_345_138_BK_1						FWD (Import)	REV (Export)
Wed 11/01/2023	to	Mon 11/20/2023			SCH - PJM_NEPTUNE	375 MW	
0001	Continuous	2359	<u>UPDATED by LI 04/22/2023 14:51</u>		Impacts Total Transfer Capability	285 MW	
Work scheduled by: LI					TTC with All Lines In Service	660 MW	
NEWBRDGE_345_138_BK_2						FWD (Import)	REV (Export)
Wed 11/01/2023	to	Mon 11/20/2023			SCH - PJM_NEPTUNE	375 MW	
0001	Continuous	2359	<u>UPDATED by LI 04/22/2023 14:51</u>		Impacts Total Transfer Capability	285 MW	
Work scheduled by: LI					TTC with All Lines In Service	660 MW	
NEWBRDGE-DUFFYAVE_345_501						FWD (Import)	REV (Export)
Wed 11/01/2023	to	Mon 11/20/2023			SCH - PJM_NEPTUNE	0 MW	
0001	Continuous	2359	<u>UPDATED by LI 04/22/2023 14:51</u>		Impacts Total Transfer Capability	660 MW	
Work scheduled by: LI					TTC with All Lines In Service	660 MW	
SCH-NE-NYISO_LIMIT_800						FWD (Import)	REV (Export)
Wed 11/01/2023	to	Wed 11/01/2023			SCH - NE - NY	1000 MW	
0700	Daily	2259			Impacts Total Transfer Capability	600 MW	
Work scheduled by: ISONE					TTC with All Lines In Service	1600 MW	
SCH-NYISO-NE_LIMIT_900						FWD (Import)	REV (Export)
Wed 11/01/2023	to	Wed 11/01/2023			SCH - NE - NY	1100 MW	
0700	Daily	2259			Impacts Total Transfer Capability	700 MW	
Work scheduled by: ISONE					TTC with All Lines In Service	1800 MW	
SPRNBK_-TREMONT_345_X28						FWD (Import)	REV (Export)
Wed 11/01/2023	to	Wed 11/01/2023			SPR/DUN-SOUTH	4200 MW	
1730	Continuous	1800	<u>UPDATED by ConEd 08/01/2023 16:11</u>		Impacts Total Transfer Capability	400 MW	
Work scheduled by: ConEd					TTC with All Lines In Service	4600 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, September 17, 2023 to Sunday, March 16, 2025

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2720 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NE-NYISO_LIMIT_800					FWD (Import)	REV (Export)
Wed 11/01/2023	to	Thu 11/02/2023		SCH - NE - NY	1000 MW	
2300	Daily	0659		Impacts Total Transfer Capability	600 MW	
Work scheduled by: ISONE				TTC with All Lines In Service	1600 MW	
SCH-NYISO-NE_LIMIT_900					FWD (Import)	REV (Export)
Wed 11/01/2023	to	Thu 11/02/2023		SCH - NE - NY	1100 MW	
2300	Daily	0659		Impacts Total Transfer Capability	700 MW	
Work scheduled by: ISONE				TTC with All Lines In Service	1800 MW	
SCH-NE-NYISO_LIMIT_800					FWD (Import)	REV (Export)
Thu 11/02/2023	to	Thu 11/02/2023		SCH - NE - NY	1000 MW	
0700	Daily	2259		Impacts Total Transfer Capability	600 MW	
Work scheduled by: ISONE				TTC with All Lines In Service	1600 MW	
SCH-NYISO-NE_LIMIT_900					FWD (Import)	REV (Export)
Thu 11/02/2023	to	Thu 11/02/2023		SCH - NE - NY	1100 MW	
0700	Daily	2259		Impacts Total Transfer Capability	700 MW	
Work scheduled by: ISONE				TTC with All Lines In Service	1800 MW	
SCH-NE-NYISO_LIMIT_800					FWD (Import)	REV (Export)
Thu 11/02/2023	to	Fri 11/03/2023		SCH - NE - NY	1000 MW	
2300	Daily	0659		Impacts Total Transfer Capability	600 MW	
Work scheduled by: ISONE				TTC with All Lines In Service	1600 MW	
SCH-NYISO-NE_LIMIT_900					FWD (Import)	REV (Export)
Thu 11/02/2023	to	Fri 11/03/2023		SCH - NE - NY	1100 MW	
2300	Daily	0659		Impacts Total Transfer Capability	700 MW	
Work scheduled by: ISONE				TTC with All Lines In Service	1800 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, September 17, 2023 to Sunday, March 16, 2025

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2720 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NE-NYISO_LIMIT_800

Fri 11/03/2023 to Fri 11/03/2023
0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	1000 MW	
TTC with All Lines In Service	600 MW	
	1600 MW	

SCH-NYISO-NE_LIMIT_900

Fri 11/03/2023 to Fri 11/03/2023
0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	1100 MW	
TTC with All Lines In Service	700 MW	
	1800 MW	

SCH-NE-NYISO_LIMIT_800

Fri 11/03/2023 to Sat 11/04/2023
2300 Daily 0659

Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	1000 MW	
TTC with All Lines In Service	600 MW	
	1600 MW	

SCH-NYISO-NE_LIMIT_900

Fri 11/03/2023 to Sat 11/04/2023
2300 Daily 0659

Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	1100 MW	
TTC with All Lines In Service	700 MW	
	1800 MW	

SCH-NE-NYISO_LIMIT_800

Sat 11/04/2023 to Sat 11/04/2023
0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	1000 MW	
TTC with All Lines In Service	600 MW	
	1600 MW	

SCH-NYISO-NE_LIMIT_900

Sat 11/04/2023 to Sat 11/04/2023
0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	1100 MW	
TTC with All Lines In Service	700 MW	
	1800 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, September 17, 2023 to Sunday, March 16, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NE-NYISO_LIMIT_800

Sat 11/04/2023 to Sun 11/05/2023
2300 Daily 0659

Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)
1000 MW
Impacts Total Transfer Capability 600 MW
TTC with All Lines In Service 1600 MW

SCH-NYISO-NE_LIMIT_900

Sat 11/04/2023 to Sun 11/05/2023
2300 Daily 0659

Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)
1100 MW
Impacts Total Transfer Capability 700 MW
TTC with All Lines In Service 1800 MW

MOSES__-ADIRNDCK_230_MA2

Sun 11/05/2023 to Sat 11/11/2023
0700 Continuous 1930

Work scheduled by: NYPA

MOSES SOUTH FWD (Import) REV (Export)
2300 MW
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

SCH-NE-NYISO_LIMIT_800

Sun 11/05/2023 to Sun 11/05/2023
0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)
1000 MW
Impacts Total Transfer Capability 600 MW
TTC with All Lines In Service 1600 MW

SCH-NYISO-NE_LIMIT_900

Sun 11/05/2023 to Sun 11/05/2023
0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)
1100 MW
Impacts Total Transfer Capability 700 MW
TTC with All Lines In Service 1800 MW

SCH-NE-NYISO_LIMIT_800

Sun 11/05/2023 to Mon 11/06/2023
2300 Daily 0659

Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)
1000 MW
Impacts Total Transfer Capability 600 MW
TTC with All Lines In Service 1600 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, September 17, 2023 to Sunday, March 16, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-NE_LIMIT_900

Sun 11/05/2023 to Mon 11/06/2023
2300 Daily 0659
Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)
1100 MW
Impacts Total Transfer Capability 700 MW
TTC with All Lines In Service 1800 MW

DUNWODIE_345KV_3

Mon 11/06/2023 to Thu 11/09/2023
0201 Continuous 2200
Work scheduled by: ConEd

SPR/DUN-SOUTH FWD (Import) REV (Export)
3800 MW
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

SCH-NE-NYISO_LIMIT_800

Mon 11/06/2023 to Mon 11/06/2023
0700 Daily 2259
Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)
1000 MW
Impacts Total Transfer Capability 600 MW
TTC with All Lines In Service 1600 MW

SCH-NYISO-NE_LIMIT_900

Mon 11/06/2023 to Mon 11/06/2023
0700 Daily 1500
Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)
1100 MW
Impacts Total Transfer Capability 700 MW
TTC with All Lines In Service 1800 MW

LINDN_CG-LNDVFT__345_V-3022

Mon 11/06/2023 to Thu 11/09/2023
0800 Continuous 1500
Work scheduled by: PJM

SCH - PJM_VFT FWD (Import) REV (Export)
0 MW **0 MW**
Impacts Total Transfer Capability 315 MW 315 MW
TTC with All Lines In Service 315 MW 315 MW

RAMAPO__BUCHAN_N_345_Y94

Tue 11/14/2023 to Thu 12/21/2023
0201 Continuous 0200
Work scheduled by: ConEd

UPNY CONED FWD (Import) REV (Export)
7755 MW
Impacts Total Transfer Capability 295 MW
TTC with All Lines In Service 8050 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, September 17, 2023 to Sunday, March 16, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHATGUAY-MASSENA_765_7040

Wed 11/15/2023 to Mon 11/27/2023
0700 Continuous 1730
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - HQ - NY	0 MW	0 MW
Impacts Total Transfer Capability	1500 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

CHATGUAY-MASSENA_765_7040

Wed 11/15/2023 to Mon 11/27/2023
0700 Continuous 1730
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
MOSES SOUTH	1550 MW	
Impacts Total Transfer Capability	1600 MW	
TTC with All Lines In Service	3150 MW	

CHATGUAY-MASSENA_765_7040 , MASSENA_-MARCY_765_MSU1

Wed 11/15/2023 to Mon 11/27/2023
0700 1730
Work scheduled by:

	FWD (Import)	REV (Export)
MOSES SOUTH	500 MW	
Impacts Total Transfer Capability	2650 MW	
TTC with All Lines In Service	3150 MW	

MASSENA_-MARCY_765_MSU1

Wed 11/15/2023 to Mon 11/27/2023
0700 Continuous 1730
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
CENTRAL EAST - VC	1720 MW	
Impacts Total Transfer Capability	1000 MW	
TTC with All Lines In Service	2720 MW	

MASSENA_-MARCY_765_MSU1

Wed 11/15/2023 to Mon 11/27/2023
0700 Continuous 1730
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS	90 MW	
Impacts Total Transfer Capability	189 MW	
TTC with All Lines In Service	279 MW	

MASSENA_-MARCY_765_MSU1

Wed 11/15/2023 to Mon 11/27/2023
0700 Continuous 1730
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - HQ - NY	475 MW	1000 MW
Impacts Total Transfer Capability	1025 MW	0 MW
TTC with All Lines In Service	1500 MW	1000 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, September 17, 2023 to Sunday, March 16, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA_-MARCY___765_MSU1

Wed 11/15/2023 to Mon 11/27/2023
0700 Continuous 1730
Work scheduled by: NYPA

MOSES SOUTH FWD (Import) REV (Export)
500 MW
Impacts Total Transfer Capability 2650 MW
TTC with All Lines In Service 3150 MW

MOSES_-MASSENA_230_MMS1 , MOSES_-MASSENA_230_MMS2

Wed 11/15/2023 to Mon 11/20/2023
0700 1530
Work scheduled by:

SCH - HQ_CEDARS FWD (Import) REV (Export)
90 MW
Impacts Total Transfer Capability 189 MW
TTC with All Lines In Service 279 MW

MOSES_-MASSENA_230_MMS1 , MOSES_-MASSENA_230_MMS2

Wed 11/15/2023 to Mon 11/20/2023
0700 1530
Work scheduled by:

SCH - HQ - NY FWD (Import) REV (Export)
850 MW **0 MW**
Impacts Total Transfer Capability 650 MW 1000 MW
TTC with All Lines In Service 1500 MW 1000 MW

LINDN_CG-LNDVFT___345_V-3022

Wed 11/15/2023 to Wed 11/15/2023
1500 Continuous 1700
Work scheduled by: PJM

SCH - PJM_VFT FWD (Import) REV (Export)
0 MW **0 MW**
Impacts Total Transfer Capability 315 MW 315 MW
TTC with All Lines In Service 315 MW 315 MW

SCH-NYISO-IMO_NIAGARA_NORTH_BUS

Sat 11/18/2023 to Sun 11/19/2023
0500 Continuous 2200
Work scheduled by: NYPA
UPDATED by NYPA 08/03/2023 12:04

SCH - OH - NY FWD (Import) REV (Export)
1100 MW **950 MW**
Impacts Total Transfer Capability 1300 MW 1050 MW
TTC with All Lines In Service 2400 MW 2000 MW

BECK_-NIAGARA_345_PA301

Sat 11/25/2023 to Sun 11/26/2023
0500 Continuous 2200
Work scheduled by: NYPA
UPDATED by NYPA 08/04/2023 13:08

SCH - OH - NY FWD (Import) REV (Export)
1100 MW **950 MW**
Impacts Total Transfer Capability 1300 MW 1050 MW
TTC with All Lines In Service 2400 MW 2000 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, September 17, 2023 to Sunday, March 16, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

GILBOA_-N.SCTLND_345_GNS-1

Mon 11/27/2023 to Fri 12/01/2023
0700 Continuous 1530

FWD (Import) REV (Export)

Work scheduled by: NYPA

CENTRAL EAST - VC **2300 MW**
Impacts Total Transfer Capability 420 MW
TTC with All Lines In Service 2720 MW

OSWEGO_-VOLNEY__345_11

Tue 11/28/2023 to Fri 12/15/2023
0730 Continuous 1630

FWD (Import) REV (Export)

Work scheduled by: NGrid

OSWEGO EXPORT **5250 MW**
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 5250 MW

ADIRNDCK-PORTER__230_12

Fri 12/01/2023 to Fri 12/22/2023
0530 Continuous 1700

FWD (Import) REV (Export)

Work scheduled by: NGrid

UPDATED by NGrid 07/11/2023 11:44

MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

KNICRBKR-PLSNTVLY_345_Y57

Mon 12/04/2023 to Wed 12/06/2023
0400 Continuous 1700

FWD (Import) REV (Export)

Work scheduled by: NGrid

ARR: 78

UPNY CONED **7885 MW**
Impacts Total Transfer Capability 165 MW
TTC with All Lines In Service 8050 MW

NIAGARA_345_230_AT4

Mon 12/04/2023 to Fri 12/08/2023
0500 Continuous 1900

FWD (Import) REV (Export)

Work scheduled by: NYPA

UPDATED by NYPA 03/21/2023 14:25

SCH - OH - NY **1650 MW**
Impacts Total Transfer Capability 350 MW
TTC with All Lines In Service 2000 MW

S.RIPLEY-DUNKIRK_230_68

Mon 12/04/2023 to Fri 12/08/2023
0800 Continuous 1600

FWD (Import) REV (Export)

Work scheduled by: PJM

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, September 17, 2023 to Sunday, March 16, 2025

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2720 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BERKSHIR-ALPS___345_393					FWD (Import)	REV (Export)
Tue 12/05/2023	to	Sun 12/10/2023		SCH - NPX_1385	100 MW	100 MW
0630	Continuous	1800	ARR: 78	Impacts Total Transfer Capability	100 MW	100 MW
Work scheduled by: NGrid				TTC with All Lines In Service	200 MW	200 MW
BERKSHIR-ALPS___345_393					FWD (Import)	REV (Export)
Tue 12/05/2023	to	Sun 12/10/2023		SCH - NE - NY	1100 MW	1700 MW
0630	Continuous	1800	ARR: 78	Impacts Total Transfer Capability	500 MW	100 MW
Work scheduled by: NGrid				TTC with All Lines In Service	1600 MW	1800 MW
CLAY___EDIC___345_2-15					FWD (Import)	REV (Export)
Tue 12/05/2023	to	Thu 12/07/2023		OSWEGO EXPORT	4850 MW	
0700	Continuous	1630		Impacts Total Transfer Capability	400 MW	
Work scheduled by: NGrid				TTC with All Lines In Service	5250 MW	
BERKSHIR-ALPS___345_393 , BERKSHIR-NORTHFLD_345_312					FWD (Import)	REV (Export)
Tue 12/05/2023	to	Sun 12/10/2023		SCH - NE - NY	1100 MW	1100 MW
0800		1800	ARR: 78	Impacts Total Transfer Capability	500 MW	700 MW
Work scheduled by:				TTC with All Lines In Service	1600 MW	1800 MW
BERKSHIR-NORTHFLD_345_312					FWD (Import)	REV (Export)
Tue 12/05/2023	to	Sun 12/10/2023		SCH - NPX_1385	100 MW	100 MW
0800	Continuous	1800		Impacts Total Transfer Capability	100 MW	100 MW
Work scheduled by: NGrid				TTC with All Lines In Service	200 MW	200 MW
BERKSHIR-NORTHFLD_345_312					FWD (Import)	REV (Export)
Tue 12/05/2023	to	Sun 12/10/2023		SCH - NE - NY	1300 MW	
0800	Continuous	1800		Impacts Total Transfer Capability	300 MW	
Work scheduled by: NGrid				TTC with All Lines In Service	1600 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, September 17, 2023 to Sunday, March 16, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

E13THSTA-FARRAGUT_345_46

Sat 12/23/2023 to Mon 12/25/2023
0001 Continuous 0300
Work scheduled by: ConEd

SPR/DUN-SOUTH FWD (Import) REV (Export)
3800 MW
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

S.RIPLEY-DUNKIRK_230_68

Wed 12/27/2023 to Fri 12/29/2023
0730 Continuous 1600
Work scheduled by: NGrid

SCH - PJ - NY FWD (Import) REV (Export)
Impacts Total Transfer Capability
TTC with All Lines In Service

WOOD_ST-PLSNTVLE_345_Y87

Fri 12/29/2023 to Sun 12/31/2023
2200 Continuous 0259
Work scheduled by: ConEd

UPNY CONED FWD (Import) REV (Export)
7470 MW
Impacts Total Transfer Capability 580 MW
TTC with All Lines In Service 8050 MW

ADIRNDCK-PORTER_230_12

Tue 01/02/2024 to Fri 05/31/2024
0630 Continuous 1730
Work scheduled by: NGrid

UPDATED by NGrid 07/11/2023 11:44

MOSES SOUTH FWD (Import) REV (Export)
2300 MW
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

FRASER_345_FRASER SVC

Tue 01/02/2024 to Fri 03/01/2024
0700 Continuous 1530
Work scheduled by: NYPA

CENTRAL EAST - VC FWD (Import) REV (Export)
2690 MW
Impacts Total Transfer Capability 30 MW
TTC with All Lines In Service 2720 MW

BECK__PACKARD_230_BP76

Mon 01/15/2024 to Fri 01/19/2024
0400 Continuous 1700
Work scheduled by: NGrid

SCH - OH - NY FWD (Import) REV (Export)
1800 MW 1350 MW
Impacts Total Transfer Capability 600 MW 650 MW
TTC with All Lines In Service 2400 MW 2000 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, September 17, 2023 to Sunday, March 16, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-IMO_NY_NIAG_NRTH_BUS_W/BB

Fri 01/26/2024 to Fri 01/26/2024
0500 Continuous 1900
Work scheduled by: NYPA

SCH - OH - NY
FWD (Import) 1550 MW REV (Export) 1450 MW
Impacts Total Transfer Capability 850 MW 550 MW
TTC with All Lines In Service 2400 MW 2000 MW

E13THSTA-FARRAGUT_345_46

Tue 01/30/2024 to Sun 02/04/2024
0700 Continuous 0300
Work scheduled by: ConEd

SPR/DUN-SOUTH
FWD (Import) 3800 MW REV (Export)
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

CLAY__-EDIC__345_2-15

Mon 02/05/2024 to Fri 03/08/2024
0700 Continuous 1600
Work scheduled by: NGrid

OSWEGO EXPORT
FWD (Import) 4850 MW REV (Export)
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 5250 MW

SCH-IMO_NY_NIAG_SOUTH_BUS_W/BB

Fri 02/09/2024 to Fri 02/09/2024
0500 Continuous 1900
Work scheduled by: NYPA

SCH - OH - NY
FWD (Import) 1550 MW REV (Export) 1450 MW
Impacts Total Transfer Capability 850 MW 550 MW
TTC with All Lines In Service 2400 MW 2000 MW

MILLWOOD-EASTVIEW_345_W85

Thu 02/15/2024 to Sat 02/17/2024
0001 Continuous 0200
Work scheduled by: ConEd

UPNY CONED
FWD (Import) 7810 MW REV (Export)
Impacts Total Transfer Capability 240 MW
TTC with All Lines In Service 8050 MW

W49TH_ST_345KV_8

Thu 02/15/2024 to Thu 02/22/2024
0001 Continuous 0200
Work scheduled by: ConEd

UPDATED by ConEd 06/13/2023 08:30

SCH - PJM_HTP
FWD (Import) 310 MW REV (Export)
Impacts Total Transfer Capability 350 MW
TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, September 17, 2023 to Sunday, March 16, 2025

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2720 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_PACKARD_230_62					FWD (Import)	REV (Export)
Fri 02/16/2024	to	Fri 02/16/2024		SCH - OH - NY	1750 MW	1850 MW
0500	Continuous	1900		Impacts Total Transfer Capability	650 MW	150 MW
Work scheduled by: NYPA				TTC with All Lines In Service	2400 MW	2000 MW
W49TH_ST_345KV_6					FWD (Import)	REV (Export)
Thu 02/22/2024	to	Mon 04/01/2024	<u>UPDATED by ConEd 06/13/2023 08:30</u>	SCH - PJM_HTP	310 MW	
0201	Continuous	0200		Impacts Total Transfer Capability	350 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	660 MW	
W49TH_ST-E13THSTA_345_M55					FWD (Import)	REV (Export)
Thu 02/22/2024	to	Mon 04/01/2024	<u>UPDATED by ConEd 06/13/2023 08:30</u>	SPR/DUN-SOUTH	3800 MW	
0201	Continuous	0200		Impacts Total Transfer Capability	800 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	4600 MW	
BECK__PACKARD_230_BP76					FWD (Import)	REV (Export)
Mon 03/04/2024	to	Fri 05/24/2024		SCH - OH - NY	1800 MW	1350 MW
0800	Continuous	1600		Impacts Total Transfer Capability	600 MW	650 MW
Work scheduled by: NGrid				TTC with All Lines In Service	2400 MW	2000 MW
CLAY__EDIC__345_1-16					FWD (Import)	REV (Export)
Mon 03/11/2024	to	Mon 04/22/2024		OSWEGO EXPORT	4850 MW	
0700	Continuous	1600		Impacts Total Transfer Capability	400 MW	
Work scheduled by: NGrid				TTC with All Lines In Service	5250 MW	
MILLWOOD-EASTVIEW_345_W85					FWD (Import)	REV (Export)
Fri 03/22/2024	to	Thu 03/28/2024		UPNY CONED	7810 MW	
0201	Continuous	0200		Impacts Total Transfer Capability	240 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	8050 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, September 17, 2023 to Sunday, March 16, 2025

CENTRAL EAST 2650 MW
 CENTRAL EAST - VC 2720 MW
 TOTAL EAST 6150 MW
 UPNY CONED 8050 MW
 SPR/DUN-SOUTH 4600 MW
 DYSINGER EAST 3200 MW
 MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK_345KV_RNS3

Fri 03/22/2024 to Fri 03/22/2024
 0201 Continuous 0230
 Work scheduled by: ConEd

SPR/DUN-SOUTH FWD (Import) REV (Export)
3800 MW
 Impacts Total Transfer Capability 800 MW
 TTC with All Lines In Service 4600 MW

W49TH_ST_345KV_8

Tue 03/26/2024 to Mon 04/01/2024
 0001 Continuous 0200
 Work scheduled by: ConEd

UPDATED by ConEd 06/13/2023 08:30

SCH - PJM_HTP FWD (Import) REV (Export)
310 MW
 Impacts Total Transfer Capability 350 MW
 TTC with All Lines In Service 660 MW

LADENTWN-BUCHAN_S_345_Y88

Mon 04/01/2024 to Fri 05/17/2024
 0001 Continuous 2359
 Work scheduled by: ConEd

UPNY CONED FWD (Import) REV (Export)
7695 MW
 Impacts Total Transfer Capability 355 MW
 TTC with All Lines In Service 8050 MW

FRASER_-GILBOA_345_GF5-35

Sun 04/07/2024 to Sat 04/27/2024
 0700 Continuous 1530
 Work scheduled by: NYPA

CENTRAL EAST - VC FWD (Import) REV (Export)
2450 MW
 Impacts Total Transfer Capability 270 MW
 TTC with All Lines In Service 2720 MW

NIAGARA_-DYSINGER_345_ND1

Mon 04/08/2024 to Fri 04/12/2024
 0500 Continuous 1900
 Work scheduled by: NYPA

DYSINGER EAST FWD (Import) REV (Export)
2700 MW
 Impacts Total Transfer Capability 500 MW
 TTC with All Lines In Service 3200 MW

NIAGARA_-DYSINGER_345_ND2

Mon 04/15/2024 to Fri 04/19/2024
 0500 Continuous 1900
 Work scheduled by: NYPA

DYSINGER EAST FWD (Import) REV (Export)
2700 MW
 Impacts Total Transfer Capability 500 MW
 TTC with All Lines In Service 3200 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, September 17, 2023 to Sunday, March 16, 2025

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2720 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

GOETHALS_345KV_5

Thu 04/18/2024 to Thu 04/18/2024
0001 Continuous 0030
Work scheduled by: ConEd

STATEN ISLAND
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

LINDEN_-GOETHALS_230_A2253

Thu 04/18/2024 to Thu 04/25/2024
0001 Continuous 0200
Work scheduled by: ConEd

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

PANNELL_-CLAY____345_1

Mon 04/22/2024 to Fri 04/26/2024
0700 Continuous 1530
Work scheduled by: NYPA

WEST CENTRAL
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
1300 MW
950 MW
2250 MW

GOETHALS_345KV_5

Thu 04/25/2024 to Thu 04/25/2024
0130 Continuous 0200
Work scheduled by: ConEd

STATEN ISLAND
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

DYSINGER-STA_255_345_DH1

Fri 04/26/2024 to Tue 05/07/2024
0500 Continuous 1900
Work scheduled by: NYPA

DYSINGER EAST
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
2850 MW
350 MW
3200 MW

FRASANNX-COOPERS_345_UCC2-41

Mon 04/29/2024 to Tue 07/16/2024
0700 Continuous 1530
Work scheduled by: NYPA

CENTRAL EAST - VC
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
2275 MW
445 MW
2720 MW

ARR: 19

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, September 17, 2023 to Sunday, March 16, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY__FRASANNX_345_UCC2-41					FWD (Import)	REV (Export)
Mon 04/29/2024	to	Tue 07/16/2024		CENTRAL EAST - VC	2275 MW	
0700	Continuous	1530	ARR: 19	Impacts Total Transfer Capability	445 MW	
Work scheduled by: NYPA				TTC with All Lines In Service	2720 MW	
PANNELL__CLAY__345_2					FWD (Import)	REV (Export)
Mon 04/29/2024	to	Fri 05/03/2024		WEST CENTRAL	1300 MW	
0700	Continuous	1530		Impacts Total Transfer Capability	950 MW	
Work scheduled by: NYPA				TTC with All Lines In Service	2250 MW	
SHOR_NPX-SHOREHAM_138_CSC					FWD (Import)	REV (Export)
Mon 05/06/2024	to	Fri 05/10/2024		SCH - NPX_CSC	0 MW	0 MW
0600	Continuous	1800		Impacts Total Transfer Capability	330 MW	330 MW
Work scheduled by: LI				TTC with All Lines In Service	330 MW	330 MW
FITZPTRK-EDIC__345_FE-1					FWD (Import)	REV (Export)
Mon 05/20/2024	to	Fri 05/24/2024		OSWEGO EXPORT	4800 MW	
0700	Continuous	1530		Impacts Total Transfer Capability	450 MW	
Work scheduled by: NYPA				TTC with All Lines In Service	5250 MW	
FITZPTRK-EDIC__345_FE-1					FWD (Import)	REV (Export)
Mon 05/20/2024	to	Fri 05/24/2024		CENTRAL EAST - VC	2480 MW	
0700	Continuous	1530		Impacts Total Transfer Capability	240 MW	
Work scheduled by: NYPA				TTC with All Lines In Service	2720 MW	
FITZPTRK-EDIC__345_FE-1					FWD (Import)	REV (Export)
Tue 05/28/2024	to	Fri 05/31/2024		OSWEGO EXPORT	4800 MW	
0700	Continuous	1530		Impacts Total Transfer Capability	450 MW	
Work scheduled by: NYPA				TTC with All Lines In Service	5250 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, September 17, 2023 to Sunday, March 16, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FITZPTRK-EDIC__345_FE-1					FWD (Import)	REV (Export)
Tue 05/28/2024	to	Fri 05/31/2024		CENTRAL EAST - VC	2480 MW	
0700	Continuous	1530		Impacts Total Transfer Capability	240 MW	
Work scheduled by: NYPA				TTC with All Lines In Service	2720 MW	
BECK__PACKARD_230_BP76					FWD (Import)	REV (Export)
Fri 05/31/2024	to	Fri 05/31/2024		SCH - OH - NY	1600 MW	1050 MW
0730	Continuous	1630		Impacts Total Transfer Capability	450 MW	600 MW
Work scheduled by: NGrid				TTC with All Lines In Service	2050 MW	1650 MW
CHASLAKE-PORTER__230_11					FWD (Import)	REV (Export)
Sat 06/01/2024	to	Wed 07/03/2024		MOSES SOUTH	2100 MW	
0530	Continuous	1600		Impacts Total Transfer Capability	1050 MW	
Work scheduled by: NGrid				TTC with All Lines In Service	3150 MW	
NIAGARA_345_230_AT4					FWD (Import)	REV (Export)
Tue 06/11/2024	to	Wed 06/12/2024		SCH - OH - NY		1200 MW
0500	Continuous	1900		Impacts Total Transfer Capability		450 MW
Work scheduled by: NYPA				TTC with All Lines In Service		1650 MW
CHASLAKE-PORTER__230_11					FWD (Import)	REV (Export)
Mon 07/08/2024	to	Fri 08/30/2024		MOSES SOUTH	2100 MW	
0530	Continuous	2000		Impacts Total Transfer Capability	1050 MW	
Work scheduled by: NGrid				TTC with All Lines In Service	3150 MW	
MOSES__ADIRNDCK_230_MA2					FWD (Import)	REV (Export)
Mon 09/02/2024	to	Mon 09/02/2024		MOSES SOUTH	2100 MW	
0700	Continuous	1730		Impacts Total Transfer Capability	1050 MW	
Work scheduled by: NYPA				TTC with All Lines In Service	3150 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, September 17, 2023 to Sunday, March 16, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ROCHESTR-PANNELL_345_RP1					FWD (Import)	REV (Export)
Mon 09/09/2024	to	Fri 09/13/2024		DYSINGER EAST	2300 MW	
0700	Continuous	1530		Impacts Total Transfer Capability	900 MW	
Work scheduled by: NYPA				TTC with All Lines In Service	3200 MW	
ROCHESTR-PANNELL_345_RP2					FWD (Import)	REV (Export)
Mon 09/16/2024	to	Fri 09/20/2024		DYSINGER EAST	2300 MW	
0700	Continuous	1530		Impacts Total Transfer Capability	900 MW	
Work scheduled by: NYPA				TTC with All Lines In Service	3200 MW	
PANNELL-CLAY_345_1					FWD (Import)	REV (Export)
Mon 09/23/2024	to	Fri 09/27/2024		WEST CENTRAL	1300 MW	
0700	Continuous	1530		Impacts Total Transfer Capability	950 MW	
Work scheduled by: NYPA				TTC with All Lines In Service	2250 MW	
FITZPTRK-EDIC_345_FE-1					FWD (Import)	REV (Export)
Mon 09/30/2024	to	Fri 10/04/2024		OSWEGO EXPORT	4800 MW	
1700	Continuous	1530		Impacts Total Transfer Capability	450 MW	
Work scheduled by: NYPA				TTC with All Lines In Service	5250 MW	
FITZPTRK-EDIC_345_FE-1					FWD (Import)	REV (Export)
Mon 09/30/2024	to	Fri 10/04/2024		CENTRAL EAST - VC	2480 MW	
1700	Continuous	1530		Impacts Total Transfer Capability	240 MW	
Work scheduled by: NYPA				TTC with All Lines In Service	2720 MW	
BECK_-NIAGARA_345_PA302					FWD (Import)	REV (Export)
Mon 10/07/2024	to	Fri 10/11/2024		SCH - OH - NY	1000 MW	850 MW
0500	Continuous	1900		Impacts Total Transfer Capability	1050 MW	800 MW
Work scheduled by: NYPA				TTC with All Lines In Service	2050 MW	1650 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, September 17, 2023 to Sunday, March 16, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEPTUNE_DUFFYAVE_345_NEPTUNE					FWD (Import)	REV (Export)
Mon 10/07/2024	to	Fri 10/11/2024		SCH - PJM_NEPTUNE	0 MW	
0600	Continuous	1600		Impacts Total Transfer Capability	660 MW	
Work scheduled by: LI				TTC with All Lines In Service	660 MW	
NEWBRDGE_345_138_BK_1					FWD (Import)	REV (Export)
Mon 10/07/2024	to	Fri 10/11/2024		SCH - PJM_NEPTUNE	375 MW	
0600	Continuous	1600		Impacts Total Transfer Capability	285 MW	
Work scheduled by: LI				TTC with All Lines In Service	660 MW	
NEWBRDGE_345_138_BK_2					FWD (Import)	REV (Export)
Mon 10/07/2024	to	Fri 10/11/2024		SCH - PJM_NEPTUNE	375 MW	
0600	Continuous	1600		Impacts Total Transfer Capability	285 MW	
Work scheduled by: LI				TTC with All Lines In Service	660 MW	
NEWBRDGE-DUFFYAVE_345_501					FWD (Import)	REV (Export)
Mon 10/07/2024	to	Fri 10/11/2024		SCH - PJM_NEPTUNE	0 MW	
0600	Continuous	1600		Impacts Total Transfer Capability	660 MW	
Work scheduled by: LI				TTC with All Lines In Service	660 MW	
SHOR_NPX-SHOREHAM_138_CSC					FWD (Import)	REV (Export)
Mon 10/07/2024	to	Fri 10/11/2024		SCH - NPX_CSC	0 MW	0 MW
0600	Continuous	1800		Impacts Total Transfer Capability	330 MW	330 MW
Work scheduled by: LI				TTC with All Lines In Service	330 MW	330 MW
GILBOA_-N.SCTLND_345_GNS-1					FWD (Import)	REV (Export)
Mon 10/07/2024	to	Fri 10/11/2024		CENTRAL EAST - VC	2300 MW	
0700	Continuous	1530		Impacts Total Transfer Capability	420 MW	
Work scheduled by: NYPA				TTC with All Lines In Service	2720 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, September 17, 2023 to Sunday, March 16, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FRASANNX-COOPERS_345_UCC2-41

Wed 10/09/2024 to Thu 10/10/2024
0700 Continuous 1530

ARR: 19

FWD (Import) REV (Export)

CENTRAL EAST - VC **2275 MW**
Impacts Total Transfer Capability 445 MW
TTC with All Lines In Service 2720 MW

Work scheduled by: NYPA

MARCY_-FRASANNX_345_UCC2-41

Wed 10/09/2024 to Thu 10/10/2024
0700 Continuous 1530

ARR: 19

FWD (Import) REV (Export)

CENTRAL EAST - VC **2275 MW**
Impacts Total Transfer Capability 445 MW
TTC with All Lines In Service 2720 MW

Work scheduled by: NYPA

MARCY_-N.SCTLND_345_18

Tue 10/15/2024 to Thu 10/17/2024
0700 Continuous 1530

ARR: 19

FWD (Import) REV (Export)

CENTRAL EAST - VC **1345 MW**
Impacts Total Transfer Capability 1375 MW
TTC with All Lines In Service 2720 MW

Work scheduled by: NYPA

MARCY_-N.SCTLND_345_18

Mon 10/21/2024 to Fri 10/25/2024
0700 Continuous 1530

ARR: 19

FWD (Import) REV (Export)

CENTRAL EAST - VC **1345 MW**
Impacts Total Transfer Capability 1375 MW
TTC with All Lines In Service 2720 MW

Work scheduled by: NYPA

COOPERS_-MIDDLETP_345_CCRT34

Sun 10/27/2024 to Sat 11/02/2024
0700 Continuous 1530

FWD (Import) REV (Export)

CENTRAL EAST - VC **2485 MW**
Impacts Total Transfer Capability 235 MW
TTC with All Lines In Service 2720 MW

Work scheduled by: NYPA

MARCY_345KV_CSC

Mon 10/28/2024 to Sun 11/10/2024
0700 Continuous 1530

FWD (Import) REV (Export)

CENTRAL EAST - VC **2650 MW**
Impacts Total Transfer Capability 70 MW
TTC with All Lines In Service 2720 MW

Work scheduled by: NYPA

NYISO TRANSFER LIMITATIONS

Seasonal Limits		Sunday, September 17, 2023 to Sunday, March 16, 2025			
CENTRAL EAST	2650 MW	The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.			
CENTRAL EAST - VC	2720 MW				
TOTAL EAST	6150 MW				
UPNY CONED	8050 MW				
SPR/DUN-SOUTH	4600 MW				
DYSINGER EAST	3200 MW				
MOSES SOUTH	3150 MW				
<hr/>					
BECK__-NIAGARA__230_PA27				FWD (Import)	REV (Export)
Fri 11/15/2024	to	Fri 11/15/2024	SCH - OH - NY	2100 MW	
0500	Continuous	1900	Impacts Total Transfer Capability	300 MW	
Work scheduled by: NYPA			TTC with All Lines In Service	2400 MW	
<hr/>					
ADIRNDCK-PORTER__230_12				FWD (Import)	REV (Export)
Sun 12/01/2024	to	Sat 05/31/2025	MOSES SOUTH	2300 MW	
0530	Continuous	1700	Impacts Total Transfer Capability	850 MW	
Work scheduled by: NGrid			TTC with All Lines In Service	3150 MW	