

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, September 24, 2023 to Sunday, March 23, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE\_345KV\_10\_BYPASS , DUNWODIE\_345KV\_9\_BYPASS ,  
SPRNBK\_345KV\_R4S3\_BYPASS , SPRNBK\_345KV\_R5S3\_BYPASS  
Sun 02/01/2015 to Sat 02/01/2025  
0000 0000  
Work scheduled by:

SPR/DUN-SOUTH FWD (Import) REV (Export)  
**4350 MW**  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 4600 MW

DUNWODIE\_345KV\_10\_BYPASS , DUNWODIE\_345KV\_9\_BYPASS ,  
SPRNBK\_345KV\_R4S3\_BYPASS , SPRNBK\_345KV\_R5S3\_BYPASS  
Sun 02/01/2015 to Sat 02/01/2025  
0000 0000  
Work scheduled by:

UPNY CONED FWD (Import) REV (Export)  
**7505 MW**  
Impacts Total Transfer Capability 545 MW  
TTC with All Lines In Service 8050 MW

HUDSONP\_-FARRAGUT\_345\_B3402  
Mon 01/15/2018 to Sun 12/31/2023  
0001 Continuous 2359 EXT FORCED by ConEd 09/21/2023 10:34  
Work scheduled by: ConEd

SCH - PJ - NY FWD (Import) REV (Export)  
Impacts Total Transfer Capability  
TTC with All Lines In Service

MARION\_-FARRAGUT\_345\_C3403  
Mon 01/15/2018 to Sun 12/31/2023  
0001 Continuous 2359 EXT FORCED by ConEd 09/21/2023 10:34  
Work scheduled by: ConEd

SCH - PJ - NY FWD (Import) REV (Export)  
Impacts Total Transfer Capability  
TTC with All Lines In Service

MARION\_-FARRAGUT\_345\_C3403 , HUDSONP\_-  
FARRAGUT\_345\_B3402  
Mon 01/15/2018 to Sun 12/31/2023  
0001 2359  
Work scheduled by:

SCH - PJ - NY FWD (Import) REV (Export)  
**2200 MW**  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 2250 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, September 24, 2023 to Sunday, March 23, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### STLAWRNC-MOSES\_\_230\_L34P

Mon 10/03/2022 to Mon 11/06/2023  
1800 Continuous 0800  
Work scheduled by: IESO

UPDATED by IESO 03/07/2023 10:12

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### SCH-NYISO-IMO\_LIMIT\_1300

Mon 06/26/2023 to Tue 10/31/2023  
0001 Continuous 2359  
Work scheduled by: IESO

UPDATED by IESO 08/20/2023 08:38

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1600 MW**  
50 MW  
1650 MW

### SCH-IMO-NYISO\_LIMIT\_1600

Wed 06/28/2023 to Tue 10/31/2023  
1801 Continuous 2359  
Work scheduled by: IESO

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1900 MW**  
150 MW  
2050 MW

### SHOR\_NPX-SHOREHAM\_138\_CSC

Sat 08/05/2023 to Mon 10/02/2023  
2124 Continuous 0559  
Work scheduled by: ISONE

EXT FORCED by ISONE 08/31/2023 06:50

SCH - NPX\_CSC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**0 MW** **0 MW**  
330 MW 330 MW  
330 MW 330 MW

### MARCY\_SO\_SERIES\_COMP\_I/S

Tue 08/22/2023 to Mon 10/09/2023  
0001 Continuous 0659  
Work scheduled by: NYSEG

EXTENDED by NYSEG 06/29/2023 14:33

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**2450 MW**  
270 MW  
2720 MW

### SCH-NYISO-HQ\_CEDARS\_LIMIT\_0

Tue 09/05/2023 to Thu 10/05/2023  
0700 Continuous 1700  
Work scheduled by: HQ

UPDATED by HQ 09/09/2023 10:50

SCH - HQ\_CEDARS  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**0 MW**  
100 MW  
100 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, September 24, 2023 to Sunday, March 23, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### ADIRNDCK-CHASLAKE\_230\_13

Fri 09/08/2023 to Sat 10/21/2023

0700 Continuous 1600

Work scheduled by: NGrid

MOSES SOUTH

FWD (Import)

REV (Export)

**2100 MW**

Impacts Total Transfer Capability

1050 MW

TTC with All Lines In Service

3150 MW

### SCH-IMO-NYISO\_LIMIT\_1450

Fri 09/08/2023 to Sat 10/21/2023

0700 Continuous 1600

Work scheduled by: IESO

UPDATED by IESO 08/20/2023 08:38

SCH - OH - NY

FWD (Import)

REV (Export)

**1750 MW**

Impacts Total Transfer Capability

300 MW

TTC with All Lines In Service

2050 MW

### HOMRC\_NY-MAINS\_NY\_345\_47

Fri 09/08/2023 to Thu 11/30/2023

1612 Continuous 1600

Work scheduled by: PJM

FORCED by PJM 09/09/2023 07:29

SCH - PJ - NY

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

TTC with All Lines In Service

### SCH-HQ\_CEDARS-NYISO\_LIMIT\_200

Mon 09/11/2023 to Thu 10/05/2023

0001 Continuous 1700

Work scheduled by: HQ

UPDATED by HQ 09/09/2023 10:50

SCH - HQ\_CEDARS

FWD (Import)

REV (Export)

**200 MW**

Impacts Total Transfer Capability

70 MW

TTC with All Lines In Service

270 MW

### SPRNBK\_345KV\_RNS5

Fri 09/15/2023 to Wed 10/25/2023

0001 Continuous 0100

Work scheduled by: ConEd

UPDATED by ConEd 04/21/2023 14:42

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

**3200 MW**

Impacts Total Transfer Capability

1400 MW

TTC with All Lines In Service

4600 MW

### SPRNBK\_-W49TH\_ST\_345\_M51

Fri 09/15/2023 to Wed 10/25/2023

0001 Continuous 0100

Work scheduled by: ConEd

UPDATED by ConEd 04/21/2023 14:42

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

**3200 MW**

Impacts Total Transfer Capability

1400 MW

TTC with All Lines In Service

4600 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, September 24, 2023 to Sunday, March 23, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-IMO-NYISO\_NIAG\_CB\_3008\_W/BB

Tue 09/19/2023 to Sat 11/18/2023

2001 Continuous 0459

Work scheduled by: NYPA

UPDATED by NYPA 08/01/2023 08:11

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**1200 MW**

450 MW

1650 MW

### MARCY\_\_EDIC\_\_345\_UE1-7

Sat 09/23/2023 to Sun 09/24/2023

0500 Continuous 1900

Work scheduled by: NYPA

UPDATED by NYPA 10/28/2022 11:09

ARR: 19,16

OSWEGO EXPORT

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**5250 MW**

0 MW

5250 MW

### MARCY\_\_345KV\_CSC

Mon 09/25/2023 to Sat 10/07/2023

0500 Continuous 1530

Work scheduled by: NYPA

CENTRAL EAST - VC

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**2650 MW**

70 MW

2720 MW

### MARCY\_\_345KV\_CSC , MARCY\_SO\_SERIES\_COMP\_I/S

Mon 09/25/2023 to Sat 10/07/2023

0500 1530

Work scheduled by:

CENTRAL EAST - VC

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**2380 MW**

340 MW

2720 MW

### NIAGARA\_DYSINGER\_345\_ND2

Mon 09/25/2023 to Fri 09/29/2023

0500 Continuous 2000

Work scheduled by: NYPA

DYSINGER EAST

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**2700 MW**

500 MW

3200 MW

### MAINESBG-WATRCURE\_345\_30

Mon 09/25/2023 to Tue 09/26/2023

0700 Continuous 1400

Work scheduled by: PJM

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**1950 MW**

300 MW

2250 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, September 24, 2023 to Sunday, March 23, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### ROSETON\_EFISHKIL\_345\_RFK305

Mon 09/25/2023 to Fri 10/13/2023  
0700 Continuous 1730

UPDATED by ConEd 08/31/2023 13:41

UPNY CONED

FWD (Import)

REV (Export)

**7215 MW**

Impacts Total Transfer Capability

835 MW

TTC with All Lines In Service

8050 MW

Work scheduled by: NYPA

### SCH-HQ\_CEDARS-NYISO\_LIMIT\_80

Mon 09/25/2023 to Mon 09/25/2023  
0900 Continuous 1600

SCH - HQ\_CEDARS

FWD (Import)

REV (Export)

**80 MW**

Impacts Total Transfer Capability

190 MW

TTC with All Lines In Service

270 MW

Work scheduled by: HQ

### ELBRIDGE-LAFAYTTE\_345\_17-LE

Thu 09/28/2023 to Fri 09/29/2023  
0600 Continuous 1700

ARR: 75

OSWEGO EXPORT

FWD (Import)

REV (Export)

**5250 MW**

Impacts Total Transfer Capability

0 MW

TTC with All Lines In Service

5250 MW

Work scheduled by: NGrid

### OSWEGO\_-ELBRIDGE\_345\_17

Thu 09/28/2023 to Thu 09/28/2023  
0600 Continuous 0900

ARR: 75

OSWEGO EXPORT

FWD (Import)

REV (Export)

**5250 MW**

Impacts Total Transfer Capability

0 MW

TTC with All Lines In Service

5250 MW

Work scheduled by: NGrid

### MILLWOOD-EASTVIEW\_345\_W99

Fri 09/29/2023 to Sat 09/30/2023  
0001 Continuous 1800

CANCELLED by TO 09/20/2023 08:25

UPNY CONED

FWD (Import)

REV (Export)

**7810 MW**

Impacts Total Transfer Capability

240 MW

TTC with All Lines In Service

8050 MW

Work scheduled by: ConEd

### OSWEGO\_-ELBRIDGE\_345\_17

Fri 09/29/2023 to Fri 09/29/2023  
1400 Continuous 1700

ARR: 75

OSWEGO EXPORT

FWD (Import)

REV (Export)

**5250 MW**

Impacts Total Transfer Capability

0 MW

TTC with All Lines In Service

5250 MW

Work scheduled by: NGrid

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, September 24, 2023 to Sunday, March 23, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### E13THSTA-FARRAGUT\_345\_45

Sat 09/30/2023 to Sat 09/30/2023  
0201 Continuous 0231  
Work scheduled by: ConEd

SPR/DUN-SOUTH FWD (Import) REV (Export)  
**3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

### E13THSTA-FARRAGUT\_345\_45

Sat 09/30/2023 to Sat 09/30/2023  
0730 Continuous 0800  
Work scheduled by: ConEd

SPR/DUN-SOUTH FWD (Import) REV (Export)  
**3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

### DYSINGER-STA\_255\_345\_DH2

Mon 10/02/2023 to Thu 10/12/2023  
0500 Continuous 1900  
Work scheduled by: NYPA

DYSINGER EAST FWD (Import) REV (Export)  
**2850 MW**  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 3200 MW

### SHOR\_NPX-SHOREHAM\_138\_CSC

Mon 10/02/2023 to Fri 10/13/2023  
0600 Continuous 2200 EXTENDED by LI 07/14/2023 09:47  
Work scheduled by: LI

SCH - NPX\_CSC FWD (Import) REV (Export)  
**0 MW 0 MW**  
Impacts Total Transfer Capability 330 MW 330 MW  
TTC with All Lines In Service 330 MW 330 MW

### NIAGARA\_DYSINGER\_345\_ND2

Mon 10/02/2023 to Mon 10/02/2023  
0800 Continuous 1159  
Work scheduled by: NT

DYSINGER EAST FWD (Import) REV (Export)  
**2700 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 3200 MW

### NIAGARA\_DYSINGER\_345\_ND2 , DYSINGER-STA\_255\_345\_DH2

Mon 10/02/2023 to Mon 10/02/2023  
0800 1159  
Work scheduled by:

DYSINGER EAST FWD (Import) REV (Export)  
**2500 MW**  
Impacts Total Transfer Capability 700 MW  
TTC with All Lines In Service 3200 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, September 24, 2023 to Sunday, March 23, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### FROST\_BR-LONG\_MTN\_345\_352

Mon 10/02/2023 to Sat 11/04/2023  
0830 Continuous 1200  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### ELBRIDGE-LAFAYTTE\_345\_17-LE

Tue 10/03/2023 to Fri 10/06/2023  
0600 Continuous 1800  
Work scheduled by: NGrid

ARR: 75

OSWEGO EXPORT  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**5250 MW**  
0 MW  
5250 MW

### OSWEGO\_-ELBRIDGE\_345\_17

Tue 10/03/2023 to Tue 10/03/2023  
0600 Continuous 0900  
Work scheduled by: NGrid

ARR: 75

OSWEGO EXPORT  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**5250 MW**  
0 MW  
5250 MW

### SCH-NE-NYISO\_LIMIT\_900

Tue 10/03/2023 to Wed 10/18/2023  
0700 Continuous 1500  
Work scheduled by: ISONE

UPDATED by ISONE 08/03/2023 14:24

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**1100 MW**  
300 MW  
1400 MW

### SCRIBA\_-VOLNEY\_345\_20

Tue 10/03/2023 to Tue 10/03/2023  
0730 Continuous 1700  
Work scheduled by: NGrid

OSWEGO EXPORT  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**5250 MW**  
0 MW  
5250 MW

### DUNWODIE\_345KV\_4

Wed 10/04/2023 to Fri 11/10/2023  
0001 Continuous 2200  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**3800 MW**  
800 MW  
4600 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, September 24, 2023 to Sunday, March 23, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### KNICRBKR-PLSNTVLY\_345\_Y57

Wed 10/04/2023 to Fri 10/06/2023

0001 Continuous 2359

Work scheduled by: NGrid

ARR: 78

UPNY CONED

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**7885 MW**

165 MW

8050 MW

### OSWEGO\_\_ELBRIDGE\_345\_17

Fri 10/06/2023 to Fri 10/06/2023

1730 Continuous 1800

Work scheduled by: NGrid

ARR: 75

OSWEGO EXPORT

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**5250 MW**

0 MW

5250 MW

### BEAR SWP-EASTOVER\_230\_E205W

Mon 10/09/2023 to Mon 11/06/2023

0600 Continuous 1530

Work scheduled by: ISONE

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

### SCH-NE-NYISO\_LIMIT\_800

Mon 10/09/2023 to Mon 10/09/2023

0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**1000 MW**

400 MW

1400 MW

### SCH-NYISO-NE\_LIMIT\_900

Mon 10/09/2023 to Mon 10/09/2023

0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**1100 MW**

500 MW

1600 MW

### OAKDALE\_-FRASER\_\_345\_32

Mon 10/09/2023 to Wed 10/11/2023

0900 Continuous 1500

Work scheduled by: NYSEG

CENTRAL EAST - VC

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**2450 MW**

270 MW

2720 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, September 24, 2023 to Sunday, March 23, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_800

Mon 10/09/2023 to Tue 10/10/2023  
2300 Daily 0659

Work scheduled by: ISONE

SCH - NE - NY

FWD (Import)

REV (Export)

**1000 MW**

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

1400 MW

### SCH-NYISO-NE\_LIMIT\_900

Mon 10/09/2023 to Tue 10/10/2023  
2300 Daily 0659

Work scheduled by: ISONE

SCH - NE - NY

FWD (Import)

REV (Export)

**1100 MW**

Impacts Total Transfer Capability

500 MW

TTC with All Lines In Service

1600 MW

### ELBRIDGE-LAFAYTTE\_345\_17-LE

Tue 10/10/2023 to Wed 10/11/2023  
0600 Continuous 1700

Work scheduled by: NGrid

ARR: 75

OSWEGO EXPORT

FWD (Import)

REV (Export)

**5250 MW**

Impacts Total Transfer Capability

0 MW

TTC with All Lines In Service

5250 MW

### OSWEGO\_-ELBRIDGE\_345\_17

Tue 10/10/2023 to Fri 10/27/2023  
0600 Continuous 2100

Work scheduled by: NGrid

ARR: 75

OSWEGO EXPORT

FWD (Import)

REV (Export)

**5250 MW**

Impacts Total Transfer Capability

0 MW

TTC with All Lines In Service

5250 MW

### SCH-NE-NYISO\_LIMIT\_800

Tue 10/10/2023 to Tue 10/10/2023  
0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY

FWD (Import)

REV (Export)

**1000 MW**

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

1400 MW

### SCH-NYISO-NE\_LIMIT\_900

Tue 10/10/2023 to Tue 10/10/2023  
0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY

FWD (Import)

REV (Export)

**1100 MW**

Impacts Total Transfer Capability

500 MW

TTC with All Lines In Service

1600 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, September 24, 2023 to Sunday, March 23, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_800

Tue 10/10/2023 to Wed 10/11/2023  
2300 Daily 0659

Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) 1000 MW  
400 MW  
1400 MW

### SCH-NYISO-NE\_LIMIT\_900

Tue 10/10/2023 to Wed 10/11/2023  
2300 Daily 0659

Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) 1100 MW  
500 MW  
1600 MW

### HUDSONP\_-FARRAGUT\_345\_B3402 , LINDEN\_-GOETHALS\_230\_A2253

Wed 10/11/2023 to Wed 10/11/2023  
0200 2300

Work scheduled by:

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) 2200 MW  
50 MW  
2250 MW

### LINDEN\_-GOETHALS\_230\_A2253

Wed 10/11/2023 to Wed 10/11/2023  
0200 Continuous 2300

Work scheduled by: ConEd

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### MARION\_-FARRAGUT\_345\_C3403 , HUDSONP\_-FARRAGUT\_345\_B3402 , LINDEN\_-GOETHALS\_230\_A2253

Wed 10/11/2023 to Wed 10/11/2023  
0200 2300

Work scheduled by:

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) 2200 MW  
50 MW  
2250 MW

### MARION\_-FARRAGUT\_345\_C3403 , LINDEN\_-GOETHALS\_230\_A2253

Wed 10/11/2023 to Wed 10/11/2023  
0200 2300

Work scheduled by:

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) 2200 MW  
50 MW  
2250 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, September 24, 2023 to Sunday, March 23, 2025

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2720 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SCH-NE-NYISO_LIMIT_800</b>					FWD (Import)	REV (Export)
Wed 10/11/2023	to	Wed 10/11/2023		SCH - NE - NY	<b>1000 MW</b>	
0700	Daily	2259		Impacts Total Transfer Capability	400 MW	
Work scheduled by: ISONE				TTC with All Lines In Service	1400 MW	
<b>SCH-NYISO-NE_LIMIT_900</b>					FWD (Import)	REV (Export)
Wed 10/11/2023	to	Wed 10/11/2023		SCH - NE - NY	<b>1100 MW</b>	
0700	Daily	2259		Impacts Total Transfer Capability	500 MW	
Work scheduled by: ISONE				TTC with All Lines In Service	1600 MW	
<b>SCH-NE-NYISO_LIMIT_800</b>					FWD (Import)	REV (Export)
Wed 10/11/2023	to	Thu 10/12/2023		SCH - NE - NY	<b>1000 MW</b>	
2300	Daily	0659		Impacts Total Transfer Capability	400 MW	
Work scheduled by: ISONE				TTC with All Lines In Service	1400 MW	
<b>SCH-NYISO-NE_LIMIT_900</b>					FWD (Import)	REV (Export)
Wed 10/11/2023	to	Thu 10/12/2023		SCH - NE - NY	<b>1100 MW</b>	
2300	Daily	0659		Impacts Total Transfer Capability	500 MW	
Work scheduled by: ISONE				TTC with All Lines In Service	1600 MW	
<b>SCH-NE-NYISO_LIMIT_800</b>					FWD (Import)	REV (Export)
Thu 10/12/2023	to	Thu 10/12/2023		SCH - NE - NY	<b>1000 MW</b>	
0700	Daily	2259		Impacts Total Transfer Capability	400 MW	
Work scheduled by: ISONE				TTC with All Lines In Service	1400 MW	
<b>SCH-NYISO-NE_LIMIT_900</b>					FWD (Import)	REV (Export)
Thu 10/12/2023	to	Thu 10/12/2023		SCH - NE - NY	<b>1100 MW</b>	
0700	Daily	2259		Impacts Total Transfer Capability	500 MW	
Work scheduled by: ISONE				TTC with All Lines In Service	1600 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, September 24, 2023 to Sunday, March 23, 2025

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2720 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_800

Thu 10/12/2023 to Fri 10/13/2023  
2300 Daily 0659

Work scheduled by: ISONE

SCH - NE - NY

FWD (Import)

REV (Export)

**1000 MW**

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

1400 MW

### SCH-NYISO-NE\_LIMIT\_900

Thu 10/12/2023 to Fri 10/13/2023  
2300 Daily 0659

Work scheduled by: ISONE

SCH - NE - NY

FWD (Import)

REV (Export)

**1100 MW**

Impacts Total Transfer Capability

500 MW

TTC with All Lines In Service

1600 MW

### NIAGARA\_PACKARD\_230\_61

Fri 10/13/2023 to Fri 10/13/2023  
0500 Continuous 1900

Work scheduled by: NYPA

SCH - OH - NY

FWD (Import)

REV (Export)

**1900 MW**

**1450 MW**

Impacts Total Transfer Capability

150 MW

200 MW

TTC with All Lines In Service

2050 MW

1650 MW

### SCH-NE-NYISO\_LIMIT\_800

Fri 10/13/2023 to Fri 10/13/2023  
0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY

FWD (Import)

REV (Export)

**1000 MW**

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

1400 MW

### SCH-NYISO-NE\_LIMIT\_900

Fri 10/13/2023 to Fri 10/13/2023  
0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY

FWD (Import)

REV (Export)

**1100 MW**

Impacts Total Transfer Capability

500 MW

TTC with All Lines In Service

1600 MW

### SCH-NE-NYISO\_LIMIT\_800

Fri 10/13/2023 to Sat 10/14/2023  
2300 Daily 0659

Work scheduled by: ISONE

SCH - NE - NY

FWD (Import)

REV (Export)

**1000 MW**

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

1400 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, September 24, 2023 to Sunday, March 23, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NYISO-NE\_LIMIT\_900

Fri 10/13/2023 to Sat 10/14/2023  
2300 Daily 0659

FWD (Import) REV (Export)

Work scheduled by: ISONE

SCH - NE - NY **1100 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1600 MW

### DYSINGER-ST\_A\_255\_345\_DH1

Sat 10/14/2023 to Tue 10/24/2023  
0500 Continuous 1900

FWD (Import) REV (Export)

Work scheduled by: NYPA

DYSINGER EAST **2850 MW**  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 3200 MW

### SCH-NE-NYISO\_LIMIT\_800

Sat 10/14/2023 to Sat 10/14/2023  
0700 Daily 2259

FWD (Import) REV (Export)

Work scheduled by: ISONE

SCH - NE - NY **1000 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 1400 MW

### SCH-NYISO-NE\_LIMIT\_900

Sat 10/14/2023 to Sat 10/14/2023  
0700 Daily 2259

FWD (Import) REV (Export)

Work scheduled by: ISONE

SCH - NE - NY **1100 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1600 MW

### SCH-NE-NYISO\_LIMIT\_800

Sat 10/14/2023 to Sun 10/15/2023  
2300 Daily 0659

FWD (Import) REV (Export)

Work scheduled by: ISONE

SCH - NE - NY **1000 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 1400 MW

### SCH-NYISO-NE\_LIMIT\_900

Sat 10/14/2023 to Sun 10/15/2023  
2300 Daily 0659

FWD (Import) REV (Export)

Work scheduled by: ISONE

SCH - NE - NY **1100 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1600 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, September 24, 2023 to Sunday, March 23, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>CHAT_DC_GC1</b>				FWD (Import)	REV (Export)
Sun 10/15/2023	to	Sun 10/15/2023	MOSES SOUTH	<b>2850 MW</b>	
0001	Continuous	0200	Impacts Total Transfer Capability	300 MW	
Work scheduled by: HQ				TTC with All Lines In Service	3150 MW
<b>CHAT_DC_GC1</b>				FWD (Import)	REV (Export)
Sun 10/15/2023	to	Sun 10/15/2023	SCH - HQ - NY		<b>500 MW</b>
0001	Continuous	0200	Impacts Total Transfer Capability		500 MW
Work scheduled by: HQ				TTC with All Lines In Service	1000 MW
<b>CHAT_DC_GC1 , CHAT_DC_GC2</b>				FWD (Import)	REV (Export)
Sun 10/15/2023	to	Sun 10/15/2023	MOSES SOUTH	<b>2550 MW</b>	
0001		0200	Impacts Total Transfer Capability	600 MW	
Work scheduled by:				TTC with All Lines In Service	3150 MW
<b>CHAT_DC_GC1 , CHAT_DC_GC2</b>				FWD (Import)	REV (Export)
Sun 10/15/2023	to	Sun 10/15/2023	SCH - HQ - NY	<b>1370 MW</b>	<b>0 MW</b>
0001		0200	Impacts Total Transfer Capability	130 MW	1000 MW
Work scheduled by:				TTC with All Lines In Service	1500 MW
<b>CHAT_DC_GC2</b>				FWD (Import)	REV (Export)
Sun 10/15/2023	to	Sun 10/15/2023	MOSES SOUTH	<b>2850 MW</b>	
0001	Continuous	0200	Impacts Total Transfer Capability	300 MW	
Work scheduled by: HQ				TTC with All Lines In Service	3150 MW
<b>CHAT_DC_GC2</b>				FWD (Import)	REV (Export)
Sun 10/15/2023	to	Sun 10/15/2023	SCH - HQ - NY		<b>500 MW</b>
0001	Continuous	0200	Impacts Total Transfer Capability		500 MW
Work scheduled by: HQ				TTC with All Lines In Service	1000 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, September 24, 2023 to Sunday, March 23, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### HOPATCON-RAMAPO\_\_500\_5018

Sun 10/15/2023 to Sun 10/15/2023

0001 Continuous 2200

Work scheduled by: ConEd

TOTAL EAST	FWD (Import)	REV (Export)
	<b>5400 MW</b>	
Impacts Total Transfer Capability	750 MW	
TTC with All Lines In Service	6150 MW	

### HOPATCON-RAMAPO\_\_500\_5018

Sun 10/15/2023 to Sun 10/15/2023

0001 Continuous 2200

Work scheduled by: ConEd

SCH - PJ - NY	FWD (Import)	REV (Export)
	<b>1100 MW</b>	<b>1000 MW</b>
Impacts Total Transfer Capability	1150 MW	200 MW
TTC with All Lines In Service	2250 MW	1200 MW

### HOPATCON-RAMAPO\_\_500\_5018

Sun 10/15/2023 to Sun 10/15/2023

0001 Continuous 2200

Work scheduled by: ConEd

UPNY CONED	FWD (Import)	REV (Export)
	<b>7795 MW</b>	
Impacts Total Transfer Capability	255 MW	
TTC with All Lines In Service	8050 MW	

### RAMAPO\_\_345\_345\_PAR3500

Sun 10/15/2023 to Sun 10/15/2023

0001 Continuous 2200

Work scheduled by: ConEd

SCH - PJ - NY	FWD (Import)	REV (Export)
	<b>1750 MW</b>	
Impacts Total Transfer Capability	500 MW	
TTC with All Lines In Service	2250 MW	

### RAMAPO\_\_345\_345\_PAR4500

Sun 10/15/2023 to Sun 10/15/2023

0001 Continuous 2200

Work scheduled by: ConEd

SCH - PJ - NY	FWD (Import)	REV (Export)
	<b>1750 MW</b>	
Impacts Total Transfer Capability	500 MW	
TTC with All Lines In Service	2250 MW	

### RAMAPO\_\_500\_345\_BK 1500

Sun 10/15/2023 to Sun 10/15/2023

0001 Continuous 2200

Work scheduled by: ConEd

SCH - PJ - NY	FWD (Import)	REV (Export)
	<b>1100 MW</b>	<b>1000 MW</b>
Impacts Total Transfer Capability	1150 MW	200 MW
TTC with All Lines In Service	2250 MW	1200 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, September 24, 2023 to Sunday, March 23, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### RAMAPO\_\_500\_345\_BK 1500

Sun 10/15/2023 to Sun 10/15/2023  
0001 Continuous 2200  
Work scheduled by: ConEd

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **7795 MW**  
255 MW  
8050 MW

### SCH-HQ-NYISO\_LIMIT\_1150

Sun 10/15/2023 to Sun 10/15/2023  
0001 Continuous 0200  
Work scheduled by: HQ

SCH - HQ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **1150 MW**  
350 MW  
1500 MW

### SCH-NE-NYISO\_LIMIT\_800

Sun 10/15/2023 to Sun 10/15/2023  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **1000 MW**  
400 MW  
1400 MW

### SCH-NYISO-NE\_LIMIT\_900

Sun 10/15/2023 to Sun 10/15/2023  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **1100 MW**  
500 MW  
1600 MW

### SCH-NE-NYISO\_LIMIT\_800

Sun 10/15/2023 to Mon 10/16/2023  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **1000 MW**  
400 MW  
1400 MW

### SCH-NYISO-NE\_LIMIT\_900

Sun 10/15/2023 to Mon 10/16/2023  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **1100 MW**  
500 MW  
1600 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, September 24, 2023 to Sunday, March 23, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### LADENTWN-BUCHAN\_S\_345\_Y88

Mon 10/16/2023 to Mon 11/06/2023  
0201 Continuous 0200

UPDATED by ConEd 06/16/2023 08:29

UPNY CONED

FWD (Import)

REV (Export)

**7695 MW**

Impacts Total Transfer Capability

355 MW

TTC with All Lines In Service

8050 MW

Work scheduled by: ConEd

### FRASANNX-COOPERS\_345\_UCC2-41

Mon 10/16/2023 to Fri 10/27/2023  
0600 Continuous 1730

ARR: 19

CENTRAL EAST - VC

FWD (Import)

REV (Export)

**2275 MW**

Impacts Total Transfer Capability

445 MW

TTC with All Lines In Service

2720 MW

Work scheduled by: NYPA

### MARCY\_-FRASANNX\_345\_UCC2-41

Mon 10/16/2023 to Fri 10/27/2023  
0600 Continuous 1730

ARR: 19

CENTRAL EAST - VC

FWD (Import)

REV (Export)

**2275 MW**

Impacts Total Transfer Capability

445 MW

TTC with All Lines In Service

2720 MW

Work scheduled by: NYPA

### MOSES\_-ADIRNDCK\_230\_MA2

Mon 10/16/2023 to Mon 10/16/2023  
0700 Continuous 1730

MOSES SOUTH

FWD (Import)

REV (Export)

**2100 MW**

Impacts Total Transfer Capability

1050 MW

TTC with All Lines In Service

3150 MW

Work scheduled by: NYPA

### SCH-NE-NYISO\_LIMIT\_800

Mon 10/16/2023 to Mon 10/16/2023  
0700 Daily 2259

SCH - NE - NY

FWD (Import)

REV (Export)

**1000 MW**

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

1400 MW

Work scheduled by: ISONE

### SCH-NYISO-NE\_LIMIT\_900

Mon 10/16/2023 to Mon 10/16/2023  
0700 Daily 2259

SCH - NE - NY

FWD (Import)

REV (Export)

**1100 MW**

Impacts Total Transfer Capability

500 MW

TTC with All Lines In Service

1600 MW

Work scheduled by: ISONE

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, September 24, 2023 to Sunday, March 23, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### HOMR\_NYW-PIERC\_NY\_345\_48

Mon 10/16/2023 to Fri 10/20/2023  
0800 Continuous 1600  
Work scheduled by: PJM

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### SCH-NE-NYISO\_LIMIT\_800

Mon 10/16/2023 to Tue 10/17/2023  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1000 MW**  
400 MW  
1400 MW

### SCH-NYISO-NE\_LIMIT\_900

Mon 10/16/2023 to Tue 10/17/2023  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1100 MW**  
500 MW  
1600 MW

### SCH-NE-NYISO\_LIMIT\_800

Tue 10/17/2023 to Tue 10/17/2023  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1000 MW**  
400 MW  
1400 MW

### SCH-NYISO-NE\_LIMIT\_900

Tue 10/17/2023 to Tue 10/17/2023  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1100 MW**  
500 MW  
1600 MW

### SCH-NE-NYISO\_LIMIT\_800

Tue 10/17/2023 to Wed 10/18/2023  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1000 MW**  
400 MW  
1400 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, September 24, 2023 to Sunday, March 23, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NYISO-NE\_LIMIT\_900

Tue 10/17/2023 to Wed 10/18/2023  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)  
Impacts Total Transfer Capability 1100 MW  
TTC with All Lines In Service 500 MW  
1600 MW

### SCH-NE-NYISO\_LIMIT\_800

Wed 10/18/2023 to Wed 10/18/2023  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)  
Impacts Total Transfer Capability 1000 MW  
TTC with All Lines In Service 400 MW  
1400 MW

### SCH-NYISO-NE\_LIMIT\_900

Wed 10/18/2023 to Wed 10/18/2023  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)  
Impacts Total Transfer Capability 1100 MW  
TTC with All Lines In Service 500 MW  
1600 MW

### SCH-NE-NYISO\_LIMIT\_800

Wed 10/18/2023 to Thu 10/19/2023  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)  
Impacts Total Transfer Capability 1000 MW  
TTC with All Lines In Service 400 MW  
1400 MW

### SCH-NYISO-NE\_LIMIT\_900

Wed 10/18/2023 to Thu 10/19/2023  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)  
Impacts Total Transfer Capability 1100 MW  
TTC with All Lines In Service 500 MW  
1600 MW

### SCH-NE-NYISO\_LIMIT\_800

Thu 10/19/2023 to Thu 10/19/2023  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)  
Impacts Total Transfer Capability 1000 MW  
TTC with All Lines In Service 400 MW  
1400 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, September 24, 2023 to Sunday, March 23, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SCH-NYISO-NE_LIMIT_900</b>					FWD (Import)	REV (Export)
Thu 10/19/2023	to	Thu 10/19/2023		SCH - NE - NY		<b>1100 MW</b>
0700	Daily	2259		Impacts Total Transfer Capability		500 MW
Work scheduled by: ISONE				TTC with All Lines In Service		1600 MW
<b>SCH-NE-NYISO_LIMIT_900</b>					FWD (Import)	REV (Export)
Thu 10/19/2023	to	Mon 10/30/2023		SCH - NE - NY		<b>1100 MW</b>
0830	Continuous	0900		Impacts Total Transfer Capability		300 MW
Work scheduled by: ISONE				TTC with All Lines In Service		1400 MW
<b>SCH-NE-NYISO_LIMIT_800</b>					FWD (Import)	REV (Export)
Thu 10/19/2023	to	Fri 10/20/2023		SCH - NE - NY		<b>1000 MW</b>
2300	Daily	0659		Impacts Total Transfer Capability		400 MW
Work scheduled by: ISONE				TTC with All Lines In Service		1400 MW
<b>SCH-NYISO-NE_LIMIT_900</b>					FWD (Import)	REV (Export)
Thu 10/19/2023	to	Fri 10/20/2023		SCH - NE - NY		<b>1100 MW</b>
2300	Daily	0659		Impacts Total Transfer Capability		500 MW
Work scheduled by: ISONE				TTC with All Lines In Service		1600 MW
<b>SCH-NE-NYISO_LIMIT_800</b>					FWD (Import)	REV (Export)
Fri 10/20/2023	to	Fri 10/20/2023		SCH - NE - NY		<b>1000 MW</b>
0700	Daily	2259		Impacts Total Transfer Capability		400 MW
Work scheduled by: ISONE				TTC with All Lines In Service		1400 MW
<b>SCH-NYISO-NE_LIMIT_900</b>					FWD (Import)	REV (Export)
Fri 10/20/2023	to	Fri 10/20/2023		SCH - NE - NY		<b>1100 MW</b>
0700	Daily	2259		Impacts Total Transfer Capability		500 MW
Work scheduled by: ISONE				TTC with All Lines In Service		1600 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, September 24, 2023 to Sunday, March 23, 2025

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2720 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SCH-NE-NYISO_LIMIT_800</b>					FWD (Import)	REV (Export)
Fri 10/20/2023	to	Sat 10/21/2023		SCH - NE - NY	<b>1000 MW</b>	
2300	Daily	0659		Impacts Total Transfer Capability	400 MW	
Work scheduled by: ISONE				TTC with All Lines In Service	1400 MW	
<b>SCH-NYISO-NE_LIMIT_900</b>					FWD (Import)	REV (Export)
Fri 10/20/2023	to	Sat 10/21/2023		SCH - NE - NY	<b>1100 MW</b>	
2300	Daily	0659		Impacts Total Transfer Capability	500 MW	
Work scheduled by: ISONE				TTC with All Lines In Service	1600 MW	
<b>SCH-NE-NYISO_LIMIT_800</b>					FWD (Import)	REV (Export)
Sat 10/21/2023	to	Sat 10/21/2023		SCH - NE - NY	<b>1000 MW</b>	
0700	Daily	2259		Impacts Total Transfer Capability	400 MW	
Work scheduled by: ISONE				TTC with All Lines In Service	1400 MW	
<b>SCH-NYISO-NE_LIMIT_900</b>					FWD (Import)	REV (Export)
Sat 10/21/2023	to	Sat 10/21/2023		SCH - NE - NY	<b>1100 MW</b>	
0700	Daily	2259		Impacts Total Transfer Capability	500 MW	
Work scheduled by: ISONE				TTC with All Lines In Service	1600 MW	
<b>SCH-NE-NYISO_LIMIT_800</b>					FWD (Import)	REV (Export)
Sat 10/21/2023	to	Sun 10/22/2023		SCH - NE - NY	<b>1000 MW</b>	
2300	Daily	0659		Impacts Total Transfer Capability	400 MW	
Work scheduled by: ISONE				TTC with All Lines In Service	1400 MW	
<b>SCH-NYISO-NE_LIMIT_900</b>					FWD (Import)	REV (Export)
Sat 10/21/2023	to	Sun 10/22/2023		SCH - NE - NY	<b>1100 MW</b>	
2300	Daily	0659		Impacts Total Transfer Capability	500 MW	
Work scheduled by: ISONE				TTC with All Lines In Service	1600 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, September 24, 2023 to Sunday, March 23, 2025

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2720 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### CHASLAKE-PORTER\_\_230\_11

Sun 10/22/2023 to Tue 11/14/2023  
0630 Continuous 1730  
Work scheduled by: NGrid

	FWD (Import)	REV (Export)
MOSES SOUTH	<b>2100 MW</b>	
Impacts Total Transfer Capability	1050 MW	
TTC with All Lines In Service	3150 MW	

### SCH-IMO-NYISO\_LIMIT\_1450

Sun 10/22/2023 to Tue 10/31/2023  
0630 Continuous 2359  
Work scheduled by: IESO

UPDATED by IESO 08/20/2023 08:38

	FWD (Import)	REV (Export)
SCH - OH - NY	<b>1750 MW</b>	
Impacts Total Transfer Capability	300 MW	
TTC with All Lines In Service	2050 MW	

### SCH-NE-NYISO\_LIMIT\_800

Sun 10/22/2023 to Sun 10/22/2023  
0700 Daily 2259  
Work scheduled by: ISONE

	FWD (Import)	REV (Export)
SCH - NE - NY	<b>1000 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NYISO-NE\_LIMIT\_900

Sun 10/22/2023 to Sun 10/22/2023  
0700 Daily 2259  
Work scheduled by: ISONE

	FWD (Import)	REV (Export)
SCH - NE - NY	<b>1100 MW</b>	
Impacts Total Transfer Capability	500 MW	
TTC with All Lines In Service	1600 MW	

### SCH-NE-NYISO\_LIMIT\_800

Sun 10/22/2023 to Mon 10/23/2023  
2300 Daily 0659  
Work scheduled by: ISONE

	FWD (Import)	REV (Export)
SCH - NE - NY	<b>1000 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NYISO-NE\_LIMIT\_900

Sun 10/22/2023 to Mon 10/23/2023  
2300 Daily 0659  
Work scheduled by: ISONE

	FWD (Import)	REV (Export)
SCH - NE - NY	<b>1100 MW</b>	
Impacts Total Transfer Capability	500 MW	
TTC with All Lines In Service	1600 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, September 24, 2023 to Sunday, March 23, 2025

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2720 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### DUNWODIE\_345KV\_6

Mon 10/23/2023 to Thu 11/09/2023  
0001 Continuous 2200  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

### DUNWODIE-SHORE\_RD\_345\_Y50

Mon 10/23/2023 to Thu 11/09/2023  
0001 Continuous 2200  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
CONED - LIPA	<b>800 MW</b>	
Impacts Total Transfer Capability	700 MW	
TTC with All Lines In Service	1500 MW	

### SHORE\_RD\_345\_138\_BK 1

Mon 10/23/2023 to Thu 11/09/2023  
0001 Continuous 2200  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
CONED - LIPA	<b>1350 MW</b>	
Impacts Total Transfer Capability	150 MW	
TTC with All Lines In Service	1500 MW	

### SHORE\_RD\_345\_138\_BK 2

Mon 10/23/2023 to Thu 11/09/2023  
0001 Continuous 2200  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
CONED - LIPA	<b>1350 MW</b>	
Impacts Total Transfer Capability	150 MW	
TTC with All Lines In Service	1500 MW	

### SCH-NE-NYISO\_LIMIT\_800

Mon 10/23/2023 to Mon 10/23/2023  
0700 Daily 2259  
Work scheduled by: ISONE

	FWD (Import)	REV (Export)
SCH - NE - NY	<b>1000 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NYISO-NE\_LIMIT\_900

Mon 10/23/2023 to Mon 10/23/2023  
0700 Daily 2259  
Work scheduled by: ISONE

	FWD (Import)	REV (Export)
SCH - NE - NY	<b>1100 MW</b>	
Impacts Total Transfer Capability	500 MW	
TTC with All Lines In Service	1600 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, September 24, 2023 to Sunday, March 23, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_800

Mon 10/23/2023 to Tue 10/24/2023  
2300 Daily 0659

Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>1000 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NYISO-NE\_LIMIT\_900

Mon 10/23/2023 to Tue 10/24/2023  
2300 Daily 0659

Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
		<b>1100 MW</b>
Impacts Total Transfer Capability		500 MW
TTC with All Lines In Service		1600 MW

### SCH-NE-NYISO\_LIMIT\_800

Tue 10/24/2023 to Tue 10/24/2023  
0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>1000 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NYISO-NE\_LIMIT\_900

Tue 10/24/2023 to Tue 10/24/2023  
0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
		<b>1100 MW</b>
Impacts Total Transfer Capability		500 MW
TTC with All Lines In Service		1600 MW

### SCH-NE-NYISO\_LIMIT\_800

Tue 10/24/2023 to Wed 10/25/2023  
2300 Daily 0659

Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>1000 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NYISO-NE\_LIMIT\_900

Tue 10/24/2023 to Wed 10/25/2023  
2300 Daily 0659

Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
		<b>1100 MW</b>
Impacts Total Transfer Capability		500 MW
TTC with All Lines In Service		1600 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, September 24, 2023 to Sunday, March 23, 2025

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2720 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_800

Wed 10/25/2023 to Wed 10/25/2023  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>1000 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NYISO-NE\_LIMIT\_900

Wed 10/25/2023 to Wed 10/25/2023  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
		<b>1100 MW</b>
Impacts Total Transfer Capability		500 MW
TTC with All Lines In Service		1600 MW

### SCH-NE-NYISO\_LIMIT\_800

Wed 10/25/2023 to Thu 10/26/2023  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>1000 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NYISO-NE\_LIMIT\_900

Wed 10/25/2023 to Thu 10/26/2023  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
		<b>1100 MW</b>
Impacts Total Transfer Capability		500 MW
TTC with All Lines In Service		1600 MW

### E13THSTA-FARRAGUT\_345\_45

Thu 10/26/2023 to Thu 10/26/2023  
0001 Continuous 0030  
Work scheduled by: ConEd

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

### SCH-NE-NYISO\_LIMIT\_800

Thu 10/26/2023 to Thu 10/26/2023  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>1000 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, September 24, 2023 to Sunday, March 23, 2025

CENTRAL EAST 2650 MW  
 CENTRAL EAST - VC 2720 MW  
 TOTAL EAST 6150 MW  
 UPNY CONED 8050 MW  
 SPR/DUN-SOUTH 4600 MW  
 DYSINGER EAST 3200 MW  
 MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NYISO-NE\_LIMIT\_900

Thu 10/26/2023 to Thu 10/26/2023  
 0700 Daily 2259  
 Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)  
 Impacts Total Transfer Capability 1100 MW  
 500 MW  
 TTC with All Lines In Service 1600 MW

### SCH-NE-NYISO\_LIMIT\_800

Thu 10/26/2023 to Fri 10/27/2023  
 2300 Daily 0659  
 Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)  
 Impacts Total Transfer Capability 1000 MW  
 400 MW  
 TTC with All Lines In Service 1400 MW

### SCH-NYISO-NE\_LIMIT\_900

Thu 10/26/2023 to Fri 10/27/2023  
 2300 Daily 0659  
 Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)  
 Impacts Total Transfer Capability 1100 MW  
 500 MW  
 TTC with All Lines In Service 1600 MW

### SCH-NE-NYISO\_LIMIT\_800

Fri 10/27/2023 to Fri 10/27/2023  
 0700 Daily 2259  
 Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)  
 Impacts Total Transfer Capability 1000 MW  
 400 MW  
 TTC with All Lines In Service 1400 MW

### SCH-NYISO-NE\_LIMIT\_900

Fri 10/27/2023 to Fri 10/27/2023  
 0700 Daily 2259  
 Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)  
 Impacts Total Transfer Capability 1100 MW  
 500 MW  
 TTC with All Lines In Service 1600 MW

### ELBRIDGE-LAFAYTTE\_345\_17-LE

Fri 10/27/2023 to Fri 10/27/2023  
 1800 Continuous 2100  
 Work scheduled by: NGrid

ARR: 75

OSWEGO EXPORT FWD (Import) REV (Export)  
 Impacts Total Transfer Capability 5250 MW  
 0 MW  
 TTC with All Lines In Service 5250 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, September 24, 2023 to Sunday, March 23, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### LAFAYTTE-CLRKSCRN\_345\_4-46

Fri 10/27/2023 to Fri 10/27/2023  
1800 Continuous 2100  
Work scheduled by: NGrid

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) 2450 MW  
270 MW  
2720 MW

### SCH-NE-NYISO\_LIMIT\_800

Fri 10/27/2023 to Sat 10/28/2023  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) 1000 MW  
400 MW  
1400 MW

### SCH-NYISO-NE\_LIMIT\_900

Fri 10/27/2023 to Sat 10/28/2023  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) 1100 MW  
500 MW  
1600 MW

### SCH-NE-NYISO\_LIMIT\_800

Sat 10/28/2023 to Sat 10/28/2023  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) 1000 MW  
400 MW  
1400 MW

### SCH-NYISO-NE\_LIMIT\_900

Sat 10/28/2023 to Sat 10/28/2023  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) 1100 MW  
500 MW  
1600 MW

### SCH-NE-NYISO\_LIMIT\_800

Sat 10/28/2023 to Sun 10/29/2023  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) 1000 MW  
400 MW  
1400 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, September 24, 2023 to Sunday, March 23, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NYISO-NE\_LIMIT\_900

Sat 10/28/2023 to Sun 10/29/2023  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)  
Impacts Total Transfer Capability 1100 MW  
TTC with All Lines In Service 500 MW  
1600 MW

### MOSES\_\_-ADIRNDCK\_230\_MA1

Sun 10/29/2023 to Sat 11/04/2023  
0700 Continuous 1930  
Work scheduled by: NYPA

MOSES SOUTH FWD (Import) REV (Export)  
Impacts Total Transfer Capability 2100 MW  
TTC with All Lines In Service 1050 MW  
3150 MW

### SCH-NE-NYISO\_LIMIT\_800

Sun 10/29/2023 to Sun 10/29/2023  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)  
Impacts Total Transfer Capability 1000 MW  
TTC with All Lines In Service 400 MW  
1400 MW

### SCH-NYISO-NE\_LIMIT\_900

Sun 10/29/2023 to Sun 10/29/2023  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)  
Impacts Total Transfer Capability 1100 MW  
TTC with All Lines In Service 500 MW  
1600 MW

### SCH-NE-NYISO\_LIMIT\_800

Sun 10/29/2023 to Mon 10/30/2023  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)  
Impacts Total Transfer Capability 1000 MW  
TTC with All Lines In Service 400 MW  
1400 MW

### SCH-NYISO-NE\_LIMIT\_900

Sun 10/29/2023 to Mon 10/30/2023  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)  
Impacts Total Transfer Capability 1100 MW  
TTC with All Lines In Service 500 MW  
1600 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, September 24, 2023 to Sunday, March 23, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SPRNBK\_TREMONT\_345\_X28

Mon 10/30/2023 to Mon 10/30/2023  
0001 Continuous 0400  
Work scheduled by: ConEd

UPDATED by ConEd 08/01/2023 16:11

SPR/DUN-SOUTH  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

4200 MW

### E13THSTA-FARRAGUT\_345\_45

Mon 10/30/2023 to Mon 10/30/2023  
0230 Continuous 0300  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

3800 MW

### SCH-NE-NYISO\_LIMIT\_800

Mon 10/30/2023 to Mon 10/30/2023  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 1400 MW

FWD (Import) REV (Export)

1000 MW

### SCH-NYISO-NE\_LIMIT\_900

Mon 10/30/2023 to Mon 10/30/2023  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1600 MW

FWD (Import) REV (Export)

1100 MW

### SCH-NE-NYISO\_LIMIT\_800

Mon 10/30/2023 to Tue 10/31/2023  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 1400 MW

FWD (Import) REV (Export)

1000 MW

### SCH-NYISO-NE\_LIMIT\_900

Mon 10/30/2023 to Tue 10/31/2023  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1600 MW

FWD (Import) REV (Export)

1100 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, September 24, 2023 to Sunday, March 23, 2025

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2720 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_800

Tue 10/31/2023 to Tue 10/31/2023  
0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>1000 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NYISO-NE\_LIMIT\_900

Tue 10/31/2023 to Tue 10/31/2023  
0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
		<b>1100 MW</b>
Impacts Total Transfer Capability		500 MW
TTC with All Lines In Service		1600 MW

### SCH-NE-NYISO\_LIMIT\_800

Tue 10/31/2023 to Wed 11/01/2023  
2300 Daily 0659

Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>1000 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NYISO-NE\_LIMIT\_900

Tue 10/31/2023 to Wed 11/01/2023  
2300 Daily 0659

Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
		<b>1100 MW</b>
Impacts Total Transfer Capability		500 MW
TTC with All Lines In Service		1600 MW

### NEPTUNE\_DUFFYAVE\_345\_NEPTUNE

Wed 11/01/2023 to Mon 11/20/2023  
0001 Continuous 2359

Work scheduled by: LI

UPDATED by LI 04/22/2023 14:51

SCH - PJM_NEPTUNE	FWD (Import)	REV (Export)
	<b>0 MW</b>	
Impacts Total Transfer Capability	660 MW	
TTC with All Lines In Service	660 MW	

### NEWBRDGE\_345\_138\_BK\_1

Wed 11/01/2023 to Mon 11/20/2023  
0001 Continuous 2359

Work scheduled by: LI

UPDATED by LI 04/22/2023 14:51

SCH - PJM_NEPTUNE	FWD (Import)	REV (Export)
	<b>375 MW</b>	
Impacts Total Transfer Capability	285 MW	
TTC with All Lines In Service	660 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, September 24, 2023 to Sunday, March 23, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### NEWBRDGE\_345\_138\_BK\_2

Wed 11/01/2023 to Mon 11/20/2023  
0001 Continuous 2359

UPDATED by LI 04/22/2023 14:51

SCH - PJM\_NEPTUNE

FWD (Import)

REV (Export)

**375 MW**

Impacts Total Transfer Capability

285 MW

TTC with All Lines In Service

660 MW

Work scheduled by: LI

### NEWBRDGE-DUFFYAVE\_345\_501

Wed 11/01/2023 to Mon 11/20/2023  
0001 Continuous 2359

UPDATED by LI 04/22/2023 14:51

SCH - PJM\_NEPTUNE

FWD (Import)

REV (Export)

**0 MW**

Impacts Total Transfer Capability

660 MW

TTC with All Lines In Service

660 MW

Work scheduled by: LI

### SCH-NE-NYISO\_LIMIT\_800

Wed 11/01/2023 to Wed 11/01/2023  
0700 Daily 2259

SCH - NE - NY

FWD (Import)

REV (Export)

**1000 MW**

Impacts Total Transfer Capability

600 MW

TTC with All Lines In Service

1600 MW

Work scheduled by: ISONE

### SCH-NYISO-NE\_LIMIT\_900

Wed 11/01/2023 to Wed 11/01/2023  
0700 Daily 2259

SCH - NE - NY

FWD (Import)

REV (Export)

**1100 MW**

Impacts Total Transfer Capability

700 MW

TTC with All Lines In Service

1800 MW

Work scheduled by: ISONE

### SPRNBK\_-TREMONT\_345\_X28

Wed 11/01/2023 to Wed 11/01/2023  
1730 Continuous 1800

UPDATED by ConEd 08/01/2023 16:11

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

**4200 MW**

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

4600 MW

Work scheduled by: ConEd

### SCH-NE-NYISO\_LIMIT\_800

Wed 11/01/2023 to Thu 11/02/2023  
2300 Daily 0659

SCH - NE - NY

FWD (Import)

REV (Export)

**1000 MW**

Impacts Total Transfer Capability

600 MW

TTC with All Lines In Service

1600 MW

Work scheduled by: ISONE

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, September 24, 2023 to Sunday, March 23, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NYISO-NE\_LIMIT\_900

Wed 11/01/2023 to Thu 11/02/2023  
2300 Daily 0659  
Work scheduled by: ISONE

	FWD (Import)	REV (Export)
SCH - NE - NY		<b>1100 MW</b>
Impacts Total Transfer Capability		700 MW
TTC with All Lines In Service		1800 MW

### SCH-NE-NYISO\_LIMIT\_800

Thu 11/02/2023 to Thu 11/02/2023  
0700 Daily 2259  
Work scheduled by: ISONE

	FWD (Import)	REV (Export)
SCH - NE - NY		<b>1000 MW</b>
Impacts Total Transfer Capability		600 MW
TTC with All Lines In Service		1600 MW

### SCH-NYISO-NE\_LIMIT\_900

Thu 11/02/2023 to Thu 11/02/2023  
0700 Daily 2259  
Work scheduled by: ISONE

	FWD (Import)	REV (Export)
SCH - NE - NY		<b>1100 MW</b>
Impacts Total Transfer Capability		700 MW
TTC with All Lines In Service		1800 MW

### SCH-NE-NYISO\_LIMIT\_800

Thu 11/02/2023 to Fri 11/03/2023  
2300 Daily 0659  
Work scheduled by: ISONE

	FWD (Import)	REV (Export)
SCH - NE - NY		<b>1000 MW</b>
Impacts Total Transfer Capability		600 MW
TTC with All Lines In Service		1600 MW

### SCH-NYISO-NE\_LIMIT\_900

Thu 11/02/2023 to Fri 11/03/2023  
2300 Daily 0659  
Work scheduled by: ISONE

	FWD (Import)	REV (Export)
SCH - NE - NY		<b>1100 MW</b>
Impacts Total Transfer Capability		700 MW
TTC with All Lines In Service		1800 MW

### SCH-NE-NYISO\_LIMIT\_800

Fri 11/03/2023 to Fri 11/03/2023  
0700 Daily 2259  
Work scheduled by: ISONE

	FWD (Import)	REV (Export)
SCH - NE - NY		<b>1000 MW</b>
Impacts Total Transfer Capability		600 MW
TTC with All Lines In Service		1600 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, September 24, 2023 to Sunday, March 23, 2025

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2720 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SCH-NYISO-NE_LIMIT_900</b>				FWD (Import)	REV (Export)
Fri 11/03/2023	to	Fri 11/03/2023	SCH - NE - NY		<b>1100 MW</b>
0700	Daily	2259	Impacts Total Transfer Capability		700 MW
Work scheduled by: ISONE				TTC with All Lines In Service	1800 MW
<b>SCH-NE-NYISO_LIMIT_800</b>				FWD (Import)	REV (Export)
Fri 11/03/2023	to	Sat 11/04/2023	SCH - NE - NY		<b>1000 MW</b>
2300	Daily	0659	Impacts Total Transfer Capability	600 MW	
Work scheduled by: ISONE				TTC with All Lines In Service	1600 MW
<b>SCH-NYISO-NE_LIMIT_900</b>				FWD (Import)	REV (Export)
Fri 11/03/2023	to	Sat 11/04/2023	SCH - NE - NY		<b>1100 MW</b>
2300	Daily	0659	Impacts Total Transfer Capability	700 MW	
Work scheduled by: ISONE				TTC with All Lines In Service	1800 MW
<b>SCH-NE-NYISO_LIMIT_800</b>				FWD (Import)	REV (Export)
Sat 11/04/2023	to	Sat 11/04/2023	SCH - NE - NY		<b>1000 MW</b>
0700	Daily	2259	Impacts Total Transfer Capability	600 MW	
Work scheduled by: ISONE				TTC with All Lines In Service	1600 MW
<b>SCH-NYISO-NE_LIMIT_900</b>				FWD (Import)	REV (Export)
Sat 11/04/2023	to	Sat 11/04/2023	SCH - NE - NY		<b>1100 MW</b>
0700	Daily	2259	Impacts Total Transfer Capability	700 MW	
Work scheduled by: ISONE				TTC with All Lines In Service	1800 MW
<b>SCH-NE-NYISO_LIMIT_800</b>				FWD (Import)	REV (Export)
Sat 11/04/2023	to	Sun 11/05/2023	SCH - NE - NY		<b>1000 MW</b>
2300	Daily	0659	Impacts Total Transfer Capability	600 MW	
Work scheduled by: ISONE				TTC with All Lines In Service	1600 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, September 24, 2023 to Sunday, March 23, 2025

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2720 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NYISO-NE\_LIMIT\_900

Sat 11/04/2023 to Sun 11/05/2023  
2300 Daily 0659  
Work scheduled by: ISONE

	FWD (Import)	REV (Export)
SCH - NE - NY		<b>1100 MW</b>
Impacts Total Transfer Capability		700 MW
TTC with All Lines In Service		1800 MW

### MOSES\_\_-ADIRNDCK\_230\_MA2

Sun 11/05/2023 to Sat 11/11/2023  
0700 Continuous 1930  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
MOSES SOUTH		<b>2300 MW</b>
Impacts Total Transfer Capability		850 MW
TTC with All Lines In Service		3150 MW

### SCH-NE-NYISO\_LIMIT\_800

Sun 11/05/2023 to Sun 11/05/2023  
0700 Daily 2259  
Work scheduled by: ISONE

	FWD (Import)	REV (Export)
SCH - NE - NY		<b>1000 MW</b>
Impacts Total Transfer Capability		600 MW
TTC with All Lines In Service		1600 MW

### SCH-NYISO-NE\_LIMIT\_900

Sun 11/05/2023 to Sun 11/05/2023  
0700 Daily 2259  
Work scheduled by: ISONE

	FWD (Import)	REV (Export)
SCH - NE - NY		<b>1100 MW</b>
Impacts Total Transfer Capability		700 MW
TTC with All Lines In Service		1800 MW

### SCH-NE-NYISO\_LIMIT\_800

Sun 11/05/2023 to Mon 11/06/2023  
2300 Daily 0659  
Work scheduled by: ISONE

	FWD (Import)	REV (Export)
SCH - NE - NY		<b>1000 MW</b>
Impacts Total Transfer Capability		600 MW
TTC with All Lines In Service		1600 MW

### SCH-NYISO-NE\_LIMIT\_900

Sun 11/05/2023 to Mon 11/06/2023  
2300 Daily 0659  
Work scheduled by: ISONE

	FWD (Import)	REV (Export)
SCH - NE - NY		<b>1100 MW</b>
Impacts Total Transfer Capability		700 MW
TTC with All Lines In Service		1800 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, September 24, 2023 to Sunday, March 23, 2025

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2720 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>DUNWODIE_345KV_3</b>				FWD (Import)	REV (Export)
Mon 11/06/2023	to	Thu 11/09/2023	SPR/DUN-SOUTH	<b>3800 MW</b>	
0201	Continuous	2200	Impacts Total Transfer Capability	800 MW	
Work scheduled by: ConEd			TTC with All Lines In Service	4600 MW	
<b>SCH-NE-NYISO_LIMIT_800</b>				FWD (Import)	REV (Export)
Mon 11/06/2023	to	Mon 11/06/2023	SCH - NE - NY	<b>1000 MW</b>	
0700	Daily	2259	Impacts Total Transfer Capability	600 MW	
Work scheduled by: ISONE			TTC with All Lines In Service	1600 MW	
<b>SCH-NYISO-NE_LIMIT_900</b>				FWD (Import)	REV (Export)
Mon 11/06/2023	to	Mon 11/06/2023	SCH - NE - NY	<b>1100 MW</b>	
0700	Daily	1500	Impacts Total Transfer Capability	700 MW	
Work scheduled by: ISONE			TTC with All Lines In Service	1800 MW	
<b>LINDN_CG-LNDVFT__345_V-3022</b>				FWD (Import)	REV (Export)
Mon 11/06/2023	to	Thu 11/09/2023	SCH - PJM_VFT	<b>0 MW</b>	<b>0 MW</b>
0800	Continuous	1500	Impacts Total Transfer Capability	315 MW	315 MW
Work scheduled by: PJM			TTC with All Lines In Service	315 MW	315 MW
<b>PANNELL_-CLAY__345_2</b>				FWD (Import)	REV (Export)
Thu 11/09/2023	to	Mon 11/13/2023	WEST CENTRAL	<b>1300 MW</b>	
0600	Continuous	1800	Impacts Total Transfer Capability	950 MW	
Work scheduled by: NYPA			TTC with All Lines In Service	2250 MW	
<b>RAMAPO_-BUCHAN_N_345_Y94</b>				FWD (Import)	REV (Export)
Tue 11/14/2023	to	Thu 12/21/2023	UPNY CONED	<b>7755 MW</b>	
0201	Continuous	0200	Impacts Total Transfer Capability	295 MW	
Work scheduled by: ConEd			TTC with All Lines In Service	8050 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, September 24, 2023 to Sunday, March 23, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### CHATGUAY-MASSENA\_\_765\_7040

Wed 11/15/2023 to Mon 11/27/2023  
0700 Continuous 1730  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - HQ - NY	0 MW	0 MW
Impacts Total Transfer Capability	1500 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

### CHATGUAY-MASSENA\_\_765\_7040

Wed 11/15/2023 to Mon 11/27/2023  
0700 Continuous 1730  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
MOSES SOUTH	1550 MW	
Impacts Total Transfer Capability	1600 MW	
TTC with All Lines In Service	3150 MW	

### CHATGUAY-MASSENA\_\_765\_7040 , MASSENA-MARCY\_\_765\_MSU1

Wed 11/15/2023 to Mon 11/27/2023  
0700 1730  
Work scheduled by:

	FWD (Import)	REV (Export)
MOSES SOUTH	500 MW	
Impacts Total Transfer Capability	2650 MW	
TTC with All Lines In Service	3150 MW	

### MASSENA-MARCY\_\_765\_MSU1

Wed 11/15/2023 to Mon 11/27/2023  
0700 Continuous 1730  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
CENTRAL EAST - VC	1720 MW	
Impacts Total Transfer Capability	1000 MW	
TTC with All Lines In Service	2720 MW	

### MASSENA-MARCY\_\_765\_MSU1

Wed 11/15/2023 to Mon 11/27/2023  
0700 Continuous 1730  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS	90 MW	
Impacts Total Transfer Capability	189 MW	
TTC with All Lines In Service	279 MW	

### MASSENA-MARCY\_\_765\_MSU1

Wed 11/15/2023 to Mon 11/27/2023  
0700 Continuous 1730  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - HQ - NY	475 MW	1000 MW
Impacts Total Transfer Capability	1025 MW	0 MW
TTC with All Lines In Service	1500 MW	1000 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, September 24, 2023 to Sunday, March 23, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MASSENA\_-MARCY\_\_765\_MSU1

Wed 11/15/2023 to Mon 11/27/2023  
0700 Continuous 1730  
Work scheduled by: NYPA

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) 500 MW  
2650 MW  
3150 MW

### MOSES\_-MASSENA\_230\_MMS1 , MOSES\_-MASSENA\_230\_MMS2

Wed 11/15/2023 to Mon 11/20/2023  
0700 1530  
Work scheduled by:

SCH - HQ\_CEDARS  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) 90 MW  
189 MW  
279 MW

### MOSES\_-MASSENA\_230\_MMS1 , MOSES\_-MASSENA\_230\_MMS2

Wed 11/15/2023 to Mon 11/20/2023  
0700 1530  
Work scheduled by:

SCH - HQ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) 850 MW  
650 MW  
1500 MW

REV (Export) 0 MW  
1000 MW  
1000 MW

### LINDN\_CG-LNDVFT\_\_345\_V-3022

Wed 11/15/2023 to Wed 11/15/2023  
1500 Continuous 1700  
Work scheduled by: PJM

SCH - PJM\_VFT  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) 0 MW  
315 MW  
315 MW

REV (Export) 0 MW  
315 MW  
315 MW

### SCH-NYISO-IMO\_NIAGARA\_NORTH\_BUS

Sat 11/18/2023 to Sun 11/19/2023  
0500 Continuous 2200  
Work scheduled by: NYPA

UPDATED by NYPA 08/03/2023 12:04

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) 1100 MW  
1300 MW  
2400 MW

REV (Export) 950 MW  
1050 MW  
2000 MW

### BECK\_-NIAGARA\_345\_PA301

Sat 11/25/2023 to Sun 11/26/2023  
0500 Continuous 2200  
Work scheduled by: NYPA

UPDATED by NYPA 08/04/2023 13:08

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) 1100 MW  
1300 MW  
2400 MW

REV (Export) 950 MW  
1050 MW  
2000 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, September 24, 2023 to Sunday, March 23, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### GILBOA\_-N.SCTLND\_345\_GNS-1

Mon 11/27/2023 to Fri 12/01/2023  
0700 Continuous 1530  
Work scheduled by: NYPA

CENTRAL EAST - VC FWD (Import) REV (Export)  
2300 MW  
Impacts Total Transfer Capability 420 MW  
TTC with All Lines In Service 2720 MW

### OSWEGO\_-VOLNEY\_\_345\_11

Tue 11/28/2023 to Fri 12/15/2023  
0730 Continuous 1630  
Work scheduled by: NGrid

OSWEGO EXPORT FWD (Import) REV (Export)  
5250 MW  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

### ADIRNDCK-PORTER\_\_230\_12

Fri 12/01/2023 to Fri 12/22/2023  
0530 Continuous 1700  
Work scheduled by: NGrid  
UPDATED by NGrid 07/11/2023 11:44

MOSES SOUTH FWD (Import) REV (Export)  
2300 MW  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

### KNICRBKR-PLSNTVLY\_345\_Y57

Mon 12/04/2023 to Wed 12/06/2023  
0400 Continuous 1700  
Work scheduled by: NGrid  
ARR: 78

UPNY CONED FWD (Import) REV (Export)  
7885 MW  
Impacts Total Transfer Capability 165 MW  
TTC with All Lines In Service 8050 MW

### NIAGARA\_345\_230\_AT4

Mon 12/04/2023 to Fri 12/08/2023  
0500 Continuous 1900  
Work scheduled by: NYPA  
UPDATED by NYPA 03/21/2023 14:25

SCH - OH - NY FWD (Import) REV (Export)  
1650 MW  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 2000 MW

### S.RIPLEY-DUNKIRK\_230\_68

Mon 12/04/2023 to Fri 12/08/2023  
0800 Continuous 1600  
Work scheduled by: PJM

SCH - PJ - NY FWD (Import) REV (Export)  
Impacts Total Transfer Capability  
TTC with All Lines In Service

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, September 24, 2023 to Sunday, March 23, 2025

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2720 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>BERKSHIR-ALPS___345_393</b>					FWD (Import)	REV (Export)
Tue 12/05/2023	to	Sun 12/10/2023		SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
0630	Continuous	1800	ARR: 78	Impacts Total Transfer Capability	100 MW	100 MW
Work scheduled by: NGrid				TTC with All Lines In Service	200 MW	200 MW
<b>BERKSHIR-ALPS___345_393</b>					FWD (Import)	REV (Export)
Tue 12/05/2023	to	Sun 12/10/2023		SCH - NE - NY	<b>1100 MW</b>	<b>1700 MW</b>
0630	Continuous	1800	ARR: 78	Impacts Total Transfer Capability	500 MW	100 MW
Work scheduled by: NGrid				TTC with All Lines In Service	1600 MW	1800 MW
<b>CLAY___EDIC___345_2-15</b>					FWD (Import)	REV (Export)
Tue 12/05/2023	to	Thu 12/07/2023		OSWEGO EXPORT	<b>4850 MW</b>	
0700	Continuous	1630		Impacts Total Transfer Capability	400 MW	
Work scheduled by: NGrid				TTC with All Lines In Service	5250 MW	
<b>BERKSHIR-ALPS___345_393 , BERKSHIR-NORTHFLD_345_312</b>					FWD (Import)	REV (Export)
Tue 12/05/2023	to	Sun 12/10/2023		SCH - NE - NY	<b>1100 MW</b>	<b>1100 MW</b>
0800		1800	ARR: 78	Impacts Total Transfer Capability	500 MW	700 MW
Work scheduled by:				TTC with All Lines In Service	1600 MW	1800 MW
<b>BERKSHIR-NORTHFLD_345_312</b>					FWD (Import)	REV (Export)
Tue 12/05/2023	to	Sun 12/10/2023		SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
0800	Continuous	1800		Impacts Total Transfer Capability	100 MW	100 MW
Work scheduled by: NGrid				TTC with All Lines In Service	200 MW	200 MW
<b>BERKSHIR-NORTHFLD_345_312</b>					FWD (Import)	REV (Export)
Tue 12/05/2023	to	Sun 12/10/2023		SCH - NE - NY	<b>1300 MW</b>	
0800	Continuous	1800		Impacts Total Transfer Capability	300 MW	
Work scheduled by: NGrid				TTC with All Lines In Service	1600 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, September 24, 2023 to Sunday, March 23, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### E13THSTA-FARRAGUT\_345\_46

Sat 12/23/2023 to Mon 12/25/2023  
0001 Continuous 0300  
Work scheduled by: ConEd

UPDATED by ConEd 09/18/2023 08:57

SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

### S.RIPLEY-DUNKIRK\_230\_68

Wed 12/27/2023 to Fri 12/29/2023  
0730 Continuous 1600  
Work scheduled by: NGrid

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### WOOD\_ST-PLSNTVLE\_345\_Y87

Fri 12/29/2023 to Sun 12/31/2023  
2200 Continuous 0259  
Work scheduled by: ConEd

UPNY CONED **7470 MW**  
Impacts Total Transfer Capability 580 MW  
TTC with All Lines In Service 8050 MW

FWD (Import) REV (Export)

### ADIRNDCK-PORTER\_230\_12

Tue 01/02/2024 to Fri 05/31/2024  
0630 Continuous 1730  
Work scheduled by: NGrid

UPDATED by NGrid 07/11/2023 11:44

MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

FWD (Import) REV (Export)

### FRASER\_345\_FRASER SVC

Tue 01/02/2024 to Fri 03/01/2024  
0700 Continuous 1530  
Work scheduled by: NYPA

CENTRAL EAST - VC **2690 MW**  
Impacts Total Transfer Capability 30 MW  
TTC with All Lines In Service 2720 MW

FWD (Import) REV (Export)

### BECK\_\_PACKARD\_230\_BP76

Mon 01/15/2024 to Fri 01/19/2024  
0400 Continuous 1700  
Work scheduled by: NGrid

SCH - OH - NY **1800 MW** **1350 MW**  
Impacts Total Transfer Capability 600 MW 650 MW  
TTC with All Lines In Service 2400 MW 2000 MW

FWD (Import) REV (Export)



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, September 24, 2023 to Sunday, March 23, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-IMO\_NY\_NIAG\_NRTH\_BUS\_W/BB

Fri 01/26/2024 to Fri 01/26/2024  
0500 Continuous 1900  
Work scheduled by: NYPA

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 1550 MW  
REV (Export) 1450 MW  
850 MW 550 MW  
2400 MW 2000 MW

### E13THSTA-FARRAGUT\_345\_46

Tue 01/30/2024 to Sun 02/04/2024  
0700 Continuous 0300  
Work scheduled by: ConEd

UPDATED by ConEd 09/18/2023 08:57

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 3800 MW  
REV (Export)  
800 MW  
4600 MW

### MOTTHAVN-RAINEY\_345\_Q12

Thu 02/01/2024 to Sat 03/02/2024  
0001 Continuous 0200  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 3800 MW  
REV (Export)  
800 MW  
4600 MW

### CLAY\_-EDIC\_345\_2-15

Mon 02/05/2024 to Fri 03/08/2024  
0700 Continuous 1600  
Work scheduled by: NGrid

OSWEGO EXPORT  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 4850 MW  
REV (Export)  
400 MW  
5250 MW

### SCH-IMO\_NY\_NIAG\_SOUTH\_BUS\_W/BB

Fri 02/09/2024 to Fri 02/09/2024  
0500 Continuous 1900  
Work scheduled by: NYPA

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 1550 MW  
REV (Export) 1450 MW  
850 MW 550 MW  
2400 MW 2000 MW

### MILLWOOD-EASTVIEW\_345\_W85

Thu 02/15/2024 to Sat 02/17/2024  
0001 Continuous 0200  
Work scheduled by: ConEd

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 7810 MW  
REV (Export)  
240 MW  
8050 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, September 24, 2023 to Sunday, March 23, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### W49TH\_ST\_345KV\_8

Thu 02/15/2024 to Thu 02/22/2024  
0001 Continuous 0200

CANCELLED by TO 09/20/2023 15:40

SCH - PJM\_HTP

FWD (Import)

REV (Export)

**310 MW**

Impacts Total Transfer Capability

350 MW

TTC with All Lines In Service

660 MW

Work scheduled by: ConEd

### NIAGARA\_PACKARD\_230\_62

Fri 02/16/2024 to Fri 02/16/2024  
0500 Continuous 1900

SCH - OH - NY

FWD (Import)

REV (Export)

**1750 MW**

**1850 MW**

Impacts Total Transfer Capability

650 MW

150 MW

TTC with All Lines In Service

2400 MW

2000 MW

Work scheduled by: NYPA

### W49TH\_ST\_345KV\_6

Thu 02/22/2024 to Mon 04/01/2024  
0201 Continuous 0200

CANCELLED by TO 09/20/2023 15:40

SCH - PJM\_HTP

FWD (Import)

REV (Export)

**310 MW**

Impacts Total Transfer Capability

350 MW

TTC with All Lines In Service

660 MW

Work scheduled by: ConEd

### W49TH\_ST-E13THSTA\_345\_M55

Thu 02/22/2024 to Mon 04/01/2024  
0201 Continuous 0200

CANCELLED by TO 09/20/2023 15:40

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

**3800 MW**

Impacts Total Transfer Capability

800 MW

TTC with All Lines In Service

4600 MW

Work scheduled by: ConEd

### BECK\_\_-PACKARD\_230\_BP76

Mon 03/04/2024 to Fri 05/24/2024  
0800 Continuous 1600

SCH - OH - NY

FWD (Import)

REV (Export)

**1800 MW**

**1350 MW**

Impacts Total Transfer Capability

600 MW

650 MW

TTC with All Lines In Service

2400 MW

2000 MW

Work scheduled by: NGrid

### CLAY\_\_-EDIC\_\_345\_1-16

Mon 03/11/2024 to Mon 04/22/2024  
0700 Continuous 1600

OSWEGO EXPORT

FWD (Import)

REV (Export)

**4850 MW**

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

5250 MW

Work scheduled by: NGrid

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, September 24, 2023 to Sunday, March 23, 2025

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2720 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MILLWOOD-EASTVIEW\_345\_W85

Fri 03/22/2024 to Thu 03/28/2024  
0201 Continuous 0200  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
UPNY CONED	<b>7810 MW</b>	
Impacts Total Transfer Capability	240 MW	
TTC with All Lines In Service	8050 MW	

### SPRNBK\_345KV\_RNS3

Fri 03/22/2024 to Fri 03/22/2024  
0201 Continuous 0230  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

### W49TH\_ST\_345KV\_8

Tue 03/26/2024 to Mon 04/01/2024  
0001 Continuous 0200  
Work scheduled by: ConEd

CANCELLED by TO 09/20/2023 15:40

	FWD (Import)	REV (Export)
SCH - PJM_HTP	<b>310 MW</b>	
Impacts Total Transfer Capability	350 MW	
TTC with All Lines In Service	660 MW	

### LADENTWN-BUCHAN\_S\_345\_Y88

Mon 04/01/2024 to Fri 05/17/2024  
0001 Continuous 2359  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
UPNY CONED	<b>7695 MW</b>	
Impacts Total Transfer Capability	355 MW	
TTC with All Lines In Service	8050 MW	

### FRASER\_-GILBOA\_345\_GF5-35

Sun 04/07/2024 to Sat 04/27/2024  
0700 Continuous 1530  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
CENTRAL EAST - VC	<b>2450 MW</b>	
Impacts Total Transfer Capability	270 MW	
TTC with All Lines In Service	2720 MW	

### NIAGARA\_-DYSINGER\_345\_ND1

Mon 04/08/2024 to Fri 04/12/2024  
0500 Continuous 1900  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
DYSINGER EAST	<b>2700 MW</b>	
Impacts Total Transfer Capability	500 MW	
TTC with All Lines In Service	3200 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, September 24, 2023 to Sunday, March 23, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### LINDN\_CG-LNDVFT\_\_345\_V-3022

Mon 04/08/2024 to Sat 04/13/2024  
0800 Continuous 1500  
Work scheduled by: PJM

	FWD (Import)	REV (Export)
SCH - PJM_VFT	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	315 MW	315 MW
TTC with All Lines In Service	315 MW	315 MW

### NIAGARA\_DYSINGER\_345\_ND2

Mon 04/15/2024 to Fri 04/19/2024  
0500 Continuous 1900  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
DYSINGER EAST	<b>2700 MW</b>	
Impacts Total Transfer Capability	500 MW	
TTC with All Lines In Service	3200 MW	

### GOETHALS\_345KV\_5

Thu 04/18/2024 to Thu 04/18/2024  
0001 Continuous 0030  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
STATEN ISLAND		
Impacts Total Transfer Capability		
TTC with All Lines In Service		

### LINDEN\_-GOETHALS\_230\_A2253

Thu 04/18/2024 to Thu 04/25/2024  
0001 Continuous 0200  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - PJ - NY		
Impacts Total Transfer Capability		
TTC with All Lines In Service		

### LINDN\_CG-LNDVFT\_\_345\_V-3022

Thu 04/18/2024 to Thu 04/18/2024  
1500 Continuous 1800  
Work scheduled by: PJM

	FWD (Import)	REV (Export)
SCH - PJM_VFT	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	315 MW	315 MW
TTC with All Lines In Service	315 MW	315 MW

### PANNELL\_-CLAY\_\_345\_1

Mon 04/22/2024 to Fri 04/26/2024  
0700 Continuous 1530  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
WEST CENTRAL	<b>1300 MW</b>	
Impacts Total Transfer Capability	950 MW	
TTC with All Lines In Service	2250 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, September 24, 2023 to Sunday, March 23, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### GOETHALS\_345KV\_5

Thu 04/25/2024 to Thu 04/25/2024  
0130 Continuous 0200  
Work scheduled by: ConEd

STATEN ISLAND  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### DYSINGER-STA\_255\_345\_DH1

Fri 04/26/2024 to Tue 05/07/2024  
0500 Continuous 1900  
Work scheduled by: NYPA

DYSINGER EAST  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**2850 MW**  
350 MW  
3200 MW

### FRASANNX-COOPERS\_345\_UCC2-41

Mon 04/29/2024 to Tue 07/16/2024  
0700 Continuous 1530  
Work scheduled by: NYPA

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**2275 MW**  
445 MW  
2720 MW

### MARCY\_\_FRASANNX\_345\_UCC2-41

Mon 04/29/2024 to Tue 07/16/2024  
0700 Continuous 1530  
Work scheduled by: NYPA

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**2275 MW**  
445 MW  
2720 MW

### PANNELL\_-CLAY\_345\_2

Mon 04/29/2024 to Fri 05/03/2024  
0700 Continuous 1530  
Work scheduled by: NYPA

WEST CENTRAL  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1300 MW**  
950 MW  
2250 MW

### SHOR\_NPX-SHOREHAM\_138\_CSC

Mon 05/06/2024 to Fri 05/10/2024  
0600 Continuous 1800  
Work scheduled by: LI

SCH - NPX\_CSC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**0 MW** **0 MW**  
330 MW 330 MW  
330 MW 330 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, September 24, 2023 to Sunday, March 23, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>FITZPTRK-EDIC__345_FE-1</b>				FWD (Import)	REV (Export)
Mon 05/20/2024	to	Fri 05/24/2024	OSWEGO EXPORT	<b>4800 MW</b>	
0700	Continuous	1530	Impacts Total Transfer Capability	450 MW	
Work scheduled by: NYPA			TTC with All Lines In Service	5250 MW	
<b>FITZPTRK-EDIC__345_FE-1</b>				FWD (Import)	REV (Export)
Mon 05/20/2024	to	Fri 05/24/2024	CENTRAL EAST - VC	<b>2480 MW</b>	
0700	Continuous	1530	Impacts Total Transfer Capability	240 MW	
Work scheduled by: NYPA			TTC with All Lines In Service	2720 MW	
<b>FITZPTRK-EDIC__345_FE-1</b>				FWD (Import)	REV (Export)
Tue 05/28/2024	to	Fri 05/31/2024	OSWEGO EXPORT	<b>4800 MW</b>	
0700	Continuous	1530	Impacts Total Transfer Capability	450 MW	
Work scheduled by: NYPA			TTC with All Lines In Service	5250 MW	
<b>FITZPTRK-EDIC__345_FE-1</b>				FWD (Import)	REV (Export)
Tue 05/28/2024	to	Fri 05/31/2024	CENTRAL EAST - VC	<b>2480 MW</b>	
0700	Continuous	1530	Impacts Total Transfer Capability	240 MW	
Work scheduled by: NYPA			TTC with All Lines In Service	2720 MW	
<b>BECK__-PACKARD__230_BP76</b>				FWD (Import)	REV (Export)
Fri 05/31/2024	to	Fri 05/31/2024	SCH - OH - NY	<b>1600 MW</b>	<b>1050 MW</b>
0730	Continuous	1630	Impacts Total Transfer Capability	450 MW	600 MW
Work scheduled by: NGrid			TTC with All Lines In Service	2050 MW	1650 MW
<b>CHASLAKE-PORTER__230_11</b>				FWD (Import)	REV (Export)
Sat 06/01/2024	to	Wed 07/03/2024	MOSES SOUTH	<b>2100 MW</b>	
0530	Continuous	1600	Impacts Total Transfer Capability	1050 MW	
Work scheduled by: NGrid			TTC with All Lines In Service	3150 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, September 24, 2023 to Sunday, March 23, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### NIAGARA\_345\_230\_AT4

Tue 06/11/2024 to Wed 06/12/2024  
0500 Continuous 1900  
Work scheduled by: NYPA

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
1200 MW  
450 MW  
1650 MW

### CHASLAKE-PORTER\_\_230\_11

Mon 07/08/2024 to Fri 08/30/2024  
0700 Continuous 1900  
Work scheduled by: NGrid

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
2100 MW  
1050 MW  
3150 MW

### MOSES\_\_ADIRNDCK\_230\_MA2

Mon 09/02/2024 to Mon 09/02/2024  
0700 Continuous 1730  
Work scheduled by: NYPA

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
2100 MW  
1050 MW  
3150 MW

### CHASLAKE-PORTER\_\_230\_11

Tue 09/03/2024 to Fri 11/15/2024  
0530 Continuous 2000  
Work scheduled by: NGrid

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
2100 MW  
1050 MW  
3150 MW

### ROCHESTR-PANNELL\_345\_RP1

Mon 09/09/2024 to Fri 09/13/2024  
0700 Continuous 1530  
Work scheduled by: NYPA

DYSINGER EAST  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
2300 MW  
900 MW  
3200 MW

### ROCHESTR-PANNELL\_345\_RP2

Mon 09/16/2024 to Fri 09/20/2024  
0700 Continuous 1530  
Work scheduled by: NYPA

DYSINGER EAST  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
2300 MW  
900 MW  
3200 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, September 24, 2023 to Sunday, March 23, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### PANNELL\_-CLAY\_\_\_345\_1

Mon 09/23/2024 to Fri 09/27/2024

0700 Continuous 1530

Work scheduled by: NYPA

WEST CENTRAL

FWD (Import)

REV (Export)

**1300 MW**

Impacts Total Transfer Capability

950 MW

TTC with All Lines In Service

2250 MW

### FITZPTRK-EDIC\_\_\_345\_FE-1

Mon 09/30/2024 to Fri 10/04/2024

1700 Continuous 1530

Work scheduled by: NYPA

OSWEGO EXPORT

FWD (Import)

REV (Export)

**4800 MW**

Impacts Total Transfer Capability

450 MW

TTC with All Lines In Service

5250 MW

### FITZPTRK-EDIC\_\_\_345\_FE-1

Mon 09/30/2024 to Fri 10/04/2024

1700 Continuous 1530

Work scheduled by: NYPA

CENTRAL EAST - VC

FWD (Import)

REV (Export)

**2480 MW**

Impacts Total Transfer Capability

240 MW

TTC with All Lines In Service

2720 MW

### BECK\_\_\_-NIAGARA\_345\_PA302

Mon 10/07/2024 to Fri 10/11/2024

0500 Continuous 1900

Work scheduled by: NYPA

SCH - OH - NY

FWD (Import)

REV (Export)

**1000 MW**

**850 MW**

Impacts Total Transfer Capability

1050 MW

800 MW

TTC with All Lines In Service

2050 MW

1650 MW

### NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE

Mon 10/07/2024 to Fri 10/11/2024

0600 Continuous 1600

Work scheduled by: LI

SCH - PJM\_NEPTUNE

FWD (Import)

REV (Export)

**0 MW**

Impacts Total Transfer Capability

660 MW

TTC with All Lines In Service

660 MW

### NEWBRDGE\_345\_138\_BK\_1

Mon 10/07/2024 to Fri 10/11/2024

0600 Continuous 1600

Work scheduled by: LI

SCH - PJM\_NEPTUNE

FWD (Import)

REV (Export)

**375 MW**

Impacts Total Transfer Capability

285 MW

TTC with All Lines In Service

660 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, September 24, 2023 to Sunday, March 23, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### NEWBRDGE\_345\_138\_BK\_2

Mon 10/07/2024 to Fri 10/11/2024  
0600 Continuous 1600

Work scheduled by: LI

SCH - PJM\_NEPTUNE

FWD (Import)

REV (Export)

**375 MW**

Impacts Total Transfer Capability

285 MW

TTC with All Lines In Service

660 MW

### NEWBRDGE-DUFFYAVE\_345\_501

Mon 10/07/2024 to Fri 10/11/2024  
0600 Continuous 1600

Work scheduled by: LI

SCH - PJM\_NEPTUNE

FWD (Import)

REV (Export)

**0 MW**

Impacts Total Transfer Capability

660 MW

TTC with All Lines In Service

660 MW

### SHOR\_NPX-SHOREHAM\_138\_CSC

Mon 10/07/2024 to Fri 10/11/2024  
0600 Continuous 1800

Work scheduled by: LI

SCH - NPX\_CSC

FWD (Import)

REV (Export)

**0 MW**

**0 MW**

Impacts Total Transfer Capability

330 MW

330 MW

TTC with All Lines In Service

330 MW

330 MW

### GILBOA\_-N.SCTLND\_345\_GNS-1

Mon 10/07/2024 to Fri 10/11/2024  
0700 Continuous 1530

Work scheduled by: NYPA

CENTRAL EAST - VC

FWD (Import)

REV (Export)

**2300 MW**

Impacts Total Transfer Capability

420 MW

TTC with All Lines In Service

2720 MW

### FRASANNX-COOPERS\_345\_UCC2-41

Wed 10/09/2024 to Thu 10/10/2024  
0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC

FWD (Import)

REV (Export)

**2275 MW**

Impacts Total Transfer Capability

445 MW

TTC with All Lines In Service

2720 MW

### MARCY\_-FRASANNX\_345\_UCC2-41

Wed 10/09/2024 to Thu 10/10/2024  
0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC

FWD (Import)

REV (Export)

**2275 MW**

Impacts Total Transfer Capability

445 MW

TTC with All Lines In Service

2720 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, September 24, 2023 to Sunday, March 23, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MARCY\_\_N.SCTLND\_345\_18

Tue 10/15/2024 to Thu 10/17/2024

0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC

FWD (Import)

REV (Export)

**1345 MW**

Impacts Total Transfer Capability

1375 MW

TTC with All Lines In Service

2720 MW

### MARCY\_\_N.SCTLND\_345\_18

Mon 10/21/2024 to Fri 10/25/2024

0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC

FWD (Import)

REV (Export)

**1345 MW**

Impacts Total Transfer Capability

1375 MW

TTC with All Lines In Service

2720 MW

### COOPERS\_-MIDDLETP\_345\_CCRT34

Sun 10/27/2024 to Sat 11/02/2024

0700 Continuous 1530

Work scheduled by: NYPA

CENTRAL EAST - VC

FWD (Import)

REV (Export)

**2485 MW**

Impacts Total Transfer Capability

235 MW

TTC with All Lines In Service

2720 MW

### MARCY\_\_345KV\_CSC

Mon 10/28/2024 to Sun 11/10/2024

0700 Continuous 1530

Work scheduled by: NYPA

CENTRAL EAST - VC

FWD (Import)

REV (Export)

**2650 MW**

Impacts Total Transfer Capability

70 MW

TTC with All Lines In Service

2720 MW

### BECK\_\_NIAGARA\_230\_PA27

Fri 11/15/2024 to Fri 11/15/2024

0500 Continuous 1900

Work scheduled by: NYPA

SCH - OH - NY

FWD (Import)

REV (Export)

**2100 MW**

Impacts Total Transfer Capability

300 MW

TTC with All Lines In Service

2400 MW

### ADIRNDCK-PORTER\_\_230\_12

Sun 12/01/2024 to Sat 05/31/2025

0530 Continuous 1700

Work scheduled by: NGrid

MOSES SOUTH

FWD (Import)

REV (Export)

**2300 MW**

Impacts Total Transfer Capability

850 MW

TTC with All Lines In Service

3150 MW