

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Monday, September 25, 2023 to Monday, March 24, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_10_BYPASS , DUNWODIE_345KV_9_BYPASS ,
SPRNBK_345KV_R4S3_BYPASS , SPRNBK_345KV_R5S3_BYPASS

Sun 02/01/2015 to Sat 02/01/2025
0000 0000

Work scheduled by:

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

4350 MW

Impacts Total Transfer Capability

250 MW

TTC with All Lines In Service

4600 MW

DUNWODIE_345KV_10_BYPASS , DUNWODIE_345KV_9_BYPASS ,
SPRNBK_345KV_R4S3_BYPASS , SPRNBK_345KV_R5S3_BYPASS

Sun 02/01/2015 to Sat 02/01/2025
0000 0000

Work scheduled by:

UPNY CONED

FWD (Import)

REV (Export)

7505 MW

Impacts Total Transfer Capability

545 MW

TTC with All Lines In Service

8050 MW

HUDSONP_-FARRAGUT_345_B3402

Mon 01/15/2018 to Sun 12/31/2023
0001 Continuous 2359

Work scheduled by: ConEd

EXT FORCED by ConEd 09/21/2023 10:34

SCH - PJ - NY

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

TTC with All Lines In Service

MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Sun 12/31/2023
0001 Continuous 2359

Work scheduled by: ConEd

EXT FORCED by ConEd 09/21/2023 10:34

SCH - PJ - NY

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

TTC with All Lines In Service

MARION_-FARRAGUT_345_C3403 , HUDSONP_-
FARRAGUT_345_B3402

Mon 01/15/2018 to Sun 12/31/2023
0001 2359

Work scheduled by:

SCH - PJ - NY

FWD (Import)

REV (Export)

2200 MW

Impacts Total Transfer Capability

50 MW

TTC with All Lines In Service

2250 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Monday, September 25, 2023 to Monday, March 24, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

STLAWRNC-MOSES__230_L34P

Mon 10/03/2022 to Mon 11/06/2023
1800 Continuous 0800
Work scheduled by: IESO

UPDATED by IESO 03/07/2023 10:12

SCH - OH - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

SCH-NYISO-IMO_LIMIT_1300

Mon 06/26/2023 to Tue 10/31/2023
0001 Continuous 2359
Work scheduled by: IESO

UPDATED by IESO 08/20/2023 08:38

SCH - OH - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
1600 MW
50 MW
1650 MW

SCH-IMO-NYISO_LIMIT_1600

Wed 06/28/2023 to Tue 10/31/2023
1801 Continuous 2359
Work scheduled by: IESO

SCH - OH - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
1900 MW
150 MW
2050 MW

SHOR_NPX-SHOREHAM_138_CSC

Sat 08/05/2023 to Mon 10/02/2023
2124 Continuous 0559
Work scheduled by: ISONE

EXT FORCED by ISONE 08/31/2023 06:50

SCH - NPX_CSC
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
0 MW **0 MW**
330 MW 330 MW
330 MW 330 MW

MARCY_SO_SERIES_COMP_I/S

Tue 08/22/2023 to Mon 10/09/2023
0001 Continuous 0659
Work scheduled by: NYSEG

EXTENDED by NYSEG 06/29/2023 14:33

CENTRAL EAST - VC
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
2450 MW
270 MW
2720 MW

SCH-NYISO-HQ_CEDARS_LIMIT_0

Tue 09/05/2023 to Thu 10/05/2023
0700 Continuous 1700
Work scheduled by: HQ

UPDATED by HQ 09/09/2023 10:50

SCH - HQ_CEDARS
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
0 MW
100 MW
100 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Monday, September 25, 2023 to Monday, March 24, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ADIRNDCK-CHASLAKE_230_13

Fri 09/08/2023 to Sat 10/21/2023
0700 Continuous 1600

Work scheduled by: NGrid

MOSES SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
2100 MW
1050 MW
3150 MW

SCH-IMO-NYISO_LIMIT_1450

Fri 09/08/2023 to Sat 10/21/2023
0700 Continuous 1600

Work scheduled by: IESO

UPDATED by IESO 08/20/2023 08:38

SCH - OH - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
1750 MW
300 MW
2050 MW

HOMRC_NY-MAINS_NY_345_47

Fri 09/08/2023 to Thu 11/30/2023
1612 Continuous 1600

Work scheduled by: PJM

FORCED by PJM 09/09/2023 07:29

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
200 MW
70 MW
270 MW

SCH-HQ_CEDARS-NYISO_LIMIT_200

Mon 09/11/2023 to Thu 10/05/2023
0001 Continuous 1700

Work scheduled by: HQ

UPDATED by HQ 09/09/2023 10:50

SCH - HQ_CEDARS
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
3200 MW
1400 MW
4600 MW

SPRNBK_345KV_RNS5

Fri 09/15/2023 to Wed 10/25/2023
0001 Continuous 0100

Work scheduled by: ConEd

UPDATED by ConEd 04/21/2023 14:42

SPR/DUN-SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
3200 MW
1400 MW
4600 MW

SPRNBK_W49TH_ST_345_M51

Fri 09/15/2023 to Wed 10/25/2023
0001 Continuous 0100

Work scheduled by: ConEd

UPDATED by ConEd 04/21/2023 14:42

SPR/DUN-SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
3200 MW
1400 MW
4600 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Monday, September 25, 2023 to Monday, March 24, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-IMO-NYISO_NIAG_CB_3008_W/BB

Tue 09/19/2023 to Sat 11/18/2023
2001 Continuous 0459
Work scheduled by: NYPA

UPDATED by NYPA 08/01/2023 08:11

SCH - OH - NY

Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
1200 MW
450 MW
1650 MW

MARCY_345KV_CSC

Mon 09/25/2023 to Sat 10/07/2023
0500 Continuous 1530
Work scheduled by: NYPA

UPDATED by NYPA 09/25/2023 13:52

CENTRAL EAST - VC

Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
2650 MW
70 MW
2720 MW

MARCY_345KV_CSC , MARCY_SO_SERIES_COMP_I/S

Mon 09/25/2023 to Sat 10/07/2023
0500 Continuous 1530
Work scheduled by:

CENTRAL EAST - VC

Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
2380 MW
340 MW
2720 MW

NIAGARA_DYSINGER_345_ND2

Mon 09/25/2023 to Fri 09/29/2023
0500 Continuous 2000
Work scheduled by: NYPA

DYSINGER EAST

Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
2700 MW
500 MW
3200 MW

MAINESBG-WATRCURE_345_30

Mon 09/25/2023 to Tue 09/26/2023
0700 Continuous 1400
Work scheduled by: PJM

UPDATED by PJM 09/25/2023 16:17

SCH - PJ - NY

Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
1950 MW
300 MW
2250 MW

ROSETON_EFISHKIL_345_RFK305

Mon 09/25/2023 to Fri 10/13/2023
0700 Continuous 1730
Work scheduled by: NYPA

UPDATED by ConEd 08/31/2023 13:41

UPNY CONED

Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
7215 MW
835 MW
8050 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Monday, September 25, 2023 to Monday, March 24, 2025

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2720 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-HQ_CEDARS-NYISO_LIMIT_80

Mon 09/25/2023 to Mon 09/25/2023
0900 Continuous 1600

Work scheduled by: HQ

SCH - HQ_CEDARS

FWD (Import)

REV (Export)

80 MW

Impacts Total Transfer Capability

190 MW

TTC with All Lines In Service

270 MW

ELBRIDGE-LAFAYTTE_345_17-LE

Thu 09/28/2023 to Fri 09/29/2023
0600 Continuous 1700

Work scheduled by: NGrid

ARR: 75

OSWEGO EXPORT

FWD (Import)

REV (Export)

5250 MW

Impacts Total Transfer Capability

0 MW

TTC with All Lines In Service

5250 MW

OSWEGO_-ELBRIDGE_345_17

Thu 09/28/2023 to Thu 09/28/2023
0600 Continuous 0900

Work scheduled by: NGrid

ARR: 75

OSWEGO EXPORT

FWD (Import)

REV (Export)

5250 MW

Impacts Total Transfer Capability

0 MW

TTC with All Lines In Service

5250 MW

OSWEGO_-ELBRIDGE_345_17

Fri 09/29/2023 to Fri 09/29/2023
1400 Continuous 1700

Work scheduled by: NGrid

ARR: 75

OSWEGO EXPORT

FWD (Import)

REV (Export)

5250 MW

Impacts Total Transfer Capability

0 MW

TTC with All Lines In Service

5250 MW

E13THSTA-FARRAGUT_345_45

Sat 09/30/2023 to Sat 09/30/2023
0201 Continuous 0231

Work scheduled by: ConEd

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

3800 MW

Impacts Total Transfer Capability

800 MW

TTC with All Lines In Service

4600 MW

E13THSTA-FARRAGUT_345_45

Sat 09/30/2023 to Sat 09/30/2023
0730 Continuous 0800

Work scheduled by: ConEd

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

3800 MW

Impacts Total Transfer Capability

800 MW

TTC with All Lines In Service

4600 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Monday, September 25, 2023 to Monday, March 24, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DYSINGER-STA_255_345_DH2

Mon 10/02/2023 to Thu 10/12/2023
0500 Continuous 1900
Work scheduled by: NYPA

DYSINGER EAST
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
2850 MW	
350 MW	
3200 MW	

SHOR_NPX-SHOREHAM_138_CSC

Mon 10/02/2023 to Fri 10/13/2023
0600 Continuous 2200
Work scheduled by: LI
EXTENDED by LI 07/14/2023 09:47

SCH - NPX_CSC
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
0 MW	0 MW
330 MW	330 MW
330 MW	330 MW

NIAGARA_DYSINGER_345_ND2

Mon 10/02/2023 to Mon 10/02/2023
0800 Continuous 1159
Work scheduled by: NT

DYSINGER EAST
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
2700 MW	
500 MW	
3200 MW	

NIAGARA_DYSINGER_345_ND2 , DYSINGER-STA_255_345_DH2

Mon 10/02/2023 to Mon 10/02/2023
0800 Continuous 1159
Work scheduled by:

DYSINGER EAST
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
2500 MW	
700 MW	
3200 MW	

FROST_BR-LONG_MTN_345_352

Mon 10/02/2023 to Sat 11/04/2023
0830 Continuous 1200
Work scheduled by: ISONE

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)

ELBRIDGE-LAFAYTTE_345_17-LE

Tue 10/03/2023 to Fri 10/06/2023
0600 Continuous 1800
Work scheduled by: NGrid

ARR: 75

OSWEGO EXPORT
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
5250 MW	
0 MW	
5250 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Monday, September 25, 2023 to Monday, March 24, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

OSWEGO__ELBRIDGE_345_17

Tue 10/03/2023 to Tue 10/03/2023
0600 Continuous 0900

ARR: 75

FWD (Import) REV (Export)

OSWEGO EXPORT **5250 MW**
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 5250 MW

SCH-NE-NYISO_LIMIT_900

Tue 10/03/2023 to Wed 10/18/2023
0700 Continuous 1500

UPDATED by ISONE 08/03/2023 14:24

FWD (Import) REV (Export)

SCH - NE - NY **1100 MW**
Impacts Total Transfer Capability 300 MW
TTC with All Lines In Service 1400 MW

SCRIBA__VOLNEY__345_20

Tue 10/03/2023 to Tue 10/03/2023
0730 Continuous 1700

FWD (Import) REV (Export)

OSWEGO EXPORT **5250 MW**
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 5250 MW

DUNWODIE_345KV_4

Wed 10/04/2023 to Fri 11/10/2023
0001 Continuous 2200

FWD (Import) REV (Export)

SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

KNICRBKR-PLSNTVLY_345_Y57

Wed 10/04/2023 to Fri 10/06/2023
0001 Continuous 2359

ARR: 78

FWD (Import) REV (Export)

UPNY CONED **7885 MW**
Impacts Total Transfer Capability 165 MW
TTC with All Lines In Service 8050 MW

OSWEGO__ELBRIDGE_345_17

Fri 10/06/2023 to Fri 10/06/2023
1730 Continuous 1800

ARR: 75

FWD (Import) REV (Export)

OSWEGO EXPORT **5250 MW**
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 5250 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Monday, September 25, 2023 to Monday, March 24, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BEAR SWP-EASTOVER_230_E205W

Mon 10/09/2023 to Mon 11/06/2023
0600 Continuous 1530
Work scheduled by: ISONE

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

SCH-NE-NYISO_LIMIT_800

Mon 10/09/2023 to Mon 10/09/2023
0700 Daily 2259
Work scheduled by: ISONE

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
1000 MW
400 MW
1400 MW

SCH-NYISO-NE_LIMIT_900

Mon 10/09/2023 to Mon 10/09/2023
0700 Daily 2259
Work scheduled by: ISONE

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
1100 MW
500 MW
1600 MW

OAKDALE_FRASER__345_32

Mon 10/09/2023 to Wed 10/11/2023
0900 Continuous 1500
Work scheduled by: NYSEG

CENTRAL EAST - VC
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
2450 MW
270 MW
2720 MW

SCH-NE-NYISO_LIMIT_800

Mon 10/09/2023 to Tue 10/10/2023
2300 Daily 0659
Work scheduled by: ISONE

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
1000 MW
400 MW
1400 MW

SCH-NYISO-NE_LIMIT_900

Mon 10/09/2023 to Tue 10/10/2023
2300 Daily 0659
Work scheduled by: ISONE

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
1100 MW
500 MW
1600 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Monday, September 25, 2023 to Monday, March 24, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ELBRIDGE-LAFAYTTE_345_17-LE

Tue 10/10/2023 to Wed 10/11/2023
0600 Continuous 1700

ARR: 75

FWD (Import) REV (Export)

OSWEGO EXPORT 5250 MW
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 5250 MW

Work scheduled by: NGrid

OSWEGO_-ELBRIDGE_345_17

Tue 10/10/2023 to Fri 10/27/2023
0600 Continuous 2100

ARR: 75

FWD (Import) REV (Export)

OSWEGO EXPORT 5250 MW
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 5250 MW

Work scheduled by: NGrid

SCH-NE-NYISO_LIMIT_800

Tue 10/10/2023 to Tue 10/10/2023
0700 Daily 2259

FWD (Import) REV (Export)

SCH - NE - NY 1000 MW
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 1400 MW

Work scheduled by: ISONE

SCH-NYISO-NE_LIMIT_900

Tue 10/10/2023 to Tue 10/10/2023
0700 Daily 2259

FWD (Import) REV (Export)

SCH - NE - NY 1100 MW
Impacts Total Transfer Capability 500 MW
TTC with All Lines In Service 1600 MW

Work scheduled by: ISONE

SCH-NE-NYISO_LIMIT_800

Tue 10/10/2023 to Wed 10/11/2023
2300 Daily 0659

FWD (Import) REV (Export)

SCH - NE - NY 1000 MW
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 1400 MW

Work scheduled by: ISONE

SCH-NYISO-NE_LIMIT_900

Tue 10/10/2023 to Wed 10/11/2023
2300 Daily 0659

FWD (Import) REV (Export)

SCH - NE - NY 1100 MW
Impacts Total Transfer Capability 500 MW
TTC with All Lines In Service 1600 MW

Work scheduled by: ISONE

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Monday, September 25, 2023 to Monday, March 24, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONP_-FARRAGUT_345_B3402 , LINDEN_-GOETHALS_230_A2253

Wed 10/11/2023 to Wed 10/11/2023
0200 2300

Work scheduled by:

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

2200 MW

50 MW

2250 MW

LINDEN_-GOETHALS_230_A2253

Wed 10/11/2023 to Wed 10/11/2023
0200 Continuous 2300

Work scheduled by: ConEd

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

2200 MW

50 MW

2250 MW

MARION_-FARRAGUT_345_C3403 , HUDSONP_-FARRAGUT_345_B3402 , LINDEN_-GOETHALS_230_A2253

Wed 10/11/2023 to Wed 10/11/2023
0200 2300

Work scheduled by:

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

2200 MW

50 MW

2250 MW

MARION_-FARRAGUT_345_C3403 , LINDEN_-GOETHALS_230_A2253

Wed 10/11/2023 to Wed 10/11/2023
0200 2300

Work scheduled by:

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

2200 MW

50 MW

2250 MW

SCH-NE-NYISO_LIMIT_800

Wed 10/11/2023 to Wed 10/11/2023
0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

1000 MW

400 MW

1400 MW

SCH-NYISO-NE_LIMIT_900

Wed 10/11/2023 to Wed 10/11/2023
0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

1100 MW

500 MW

1600 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Monday, September 25, 2023 to Monday, March 24, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DENNISON-ROSEMNTA_115_1/11

Wed 10/11/2023 to Wed 10/11/2023
0830 Continuous 1030
Work scheduled by: NGrid

SCH - HQ_CEDARS	FWD (Import)	REV (Export)
	95 MW	40 MW
Impacts Total Transfer Capability	175 MW	60 MW
TTC with All Lines In Service	270 MW	100 MW

SCH-NE-NYISO_LIMIT_800

Wed 10/11/2023 to Thu 10/12/2023
2300 Daily 0659
Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
	1000 MW	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

SCH-NYISO-NE_LIMIT_900

Wed 10/11/2023 to Thu 10/12/2023
2300 Daily 0659
Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
		1100 MW
Impacts Total Transfer Capability		500 MW
TTC with All Lines In Service		1600 MW

SCH-NE-NYISO_LIMIT_800

Thu 10/12/2023 to Thu 10/12/2023
0700 Daily 2259
Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
	1000 MW	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

SCH-NYISO-NE_LIMIT_900

Thu 10/12/2023 to Thu 10/12/2023
0700 Daily 2259
Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
		1100 MW
Impacts Total Transfer Capability		500 MW
TTC with All Lines In Service		1600 MW

SCH-NE-NYISO_LIMIT_800

Thu 10/12/2023 to Fri 10/13/2023
2300 Daily 0659
Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
	1000 MW	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Monday, September 25, 2023 to Monday, March 24, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-NE_LIMIT_900

Thu 10/12/2023 to Fri 10/13/2023
2300 Daily 0659
Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)
1100 MW
Impacts Total Transfer Capability 500 MW
TTC with All Lines In Service 1600 MW

NIAGARA_PACKARD_230_61

Fri 10/13/2023 to Fri 10/13/2023
0500 Continuous 1900
Work scheduled by: NYPA

SCH - OH - NY FWD (Import) REV (Export)
1900 MW 1450 MW
Impacts Total Transfer Capability 150 MW 200 MW
TTC with All Lines In Service 2050 MW 1650 MW

SCH-NE-NYISO_LIMIT_800

Fri 10/13/2023 to Fri 10/13/2023
0700 Daily 2259
Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)
1000 MW
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 1400 MW

SCH-NYISO-NE_LIMIT_900

Fri 10/13/2023 to Fri 10/13/2023
0700 Daily 2259
Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)
1100 MW
Impacts Total Transfer Capability 500 MW
TTC with All Lines In Service 1600 MW

SCH-NE-NYISO_LIMIT_800

Fri 10/13/2023 to Sat 10/14/2023
2300 Daily 0659
Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)
1000 MW
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 1400 MW

SCH-NYISO-NE_LIMIT_900

Fri 10/13/2023 to Sat 10/14/2023
2300 Daily 0659
Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)
1100 MW
Impacts Total Transfer Capability 500 MW
TTC with All Lines In Service 1600 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Monday, September 25, 2023 to Monday, March 24, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DYSINGER-STA_255_345_DH1

Sat 10/14/2023 to Tue 10/24/2023
0500 Continuous 1900
Work scheduled by: NYPA

DYSINGER EAST
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) 2850 MW
350 MW
3200 MW

SCH-NE-NYISO_LIMIT_800

Sat 10/14/2023 to Sat 10/14/2023
0700 Daily 2259
Work scheduled by: ISONE

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) 1000 MW
400 MW
1400 MW

SCH-NYISO-NE_LIMIT_900

Sat 10/14/2023 to Sat 10/14/2023
0700 Daily 2259
Work scheduled by: ISONE

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) 1100 MW
500 MW
1600 MW

SCH-NE-NYISO_LIMIT_800

Sat 10/14/2023 to Sun 10/15/2023
2300 Daily 0659
Work scheduled by: ISONE

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) 1000 MW
400 MW
1400 MW

SCH-NYISO-NE_LIMIT_900

Sat 10/14/2023 to Sun 10/15/2023
2300 Daily 0659
Work scheduled by: ISONE

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) 1100 MW
500 MW
1600 MW

CHAT_DC_GC1

Sun 10/15/2023 to Sun 10/15/2023
0001 Continuous 0200
Work scheduled by: HQ

MOSES SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) 2850 MW
300 MW
3150 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Monday, September 25, 2023 to Monday, March 24, 2025

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2720 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHAT_DC_GC1

Sun 10/15/2023 to Sun 10/15/2023
0001 Continuous 0200
Work scheduled by: HQ

	FWD (Import)	REV (Export)
SCH - HQ - NY		500 MW
Impacts Total Transfer Capability		500 MW
TTC with All Lines In Service		1000 MW

CHAT_DC_GC1 , CHAT_DC_GC2

Sun 10/15/2023 to Sun 10/15/2023
0001 0200
Work scheduled by:

	FWD (Import)	REV (Export)
MOSES SOUTH	2550 MW	
Impacts Total Transfer Capability	600 MW	
TTC with All Lines In Service	3150 MW	

CHAT_DC_GC1 , CHAT_DC_GC2

Sun 10/15/2023 to Sun 10/15/2023
0001 0200
Work scheduled by:

	FWD (Import)	REV (Export)
SCH - HQ - NY	1370 MW	0 MW
Impacts Total Transfer Capability	130 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

CHAT_DC_GC2

Sun 10/15/2023 to Sun 10/15/2023
0001 Continuous 0200
Work scheduled by: HQ

	FWD (Import)	REV (Export)
MOSES SOUTH	2850 MW	
Impacts Total Transfer Capability	300 MW	
TTC with All Lines In Service	3150 MW	

CHAT_DC_GC2

Sun 10/15/2023 to Sun 10/15/2023
0001 Continuous 0200
Work scheduled by: HQ

	FWD (Import)	REV (Export)
SCH - HQ - NY		500 MW
Impacts Total Transfer Capability		500 MW
TTC with All Lines In Service		1000 MW

HOPATCON-RAMAPO__500_5018

Sun 10/15/2023 to Sun 10/15/2023
0001 Continuous 2200
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
TOTAL EAST	5400 MW	
Impacts Total Transfer Capability	750 MW	
TTC with All Lines In Service	6150 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Monday, September 25, 2023 to Monday, March 24, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HOPATCON-RAMAPO__500_5018

Sun 10/15/2023 to Sun 10/15/2023

0001 Continuous 2200

Work scheduled by: ConEd

SCH - PJ - NY

FWD (Import)

REV (Export)

1100 MW

1000 MW

Impacts Total Transfer Capability

1150 MW

200 MW

TTC with All Lines In Service

2250 MW

1200 MW

HOPATCON-RAMAPO__500_5018

Sun 10/15/2023 to Sun 10/15/2023

0001 Continuous 2200

Work scheduled by: ConEd

UPNY CONED

FWD (Import)

REV (Export)

7795 MW

Impacts Total Transfer Capability

255 MW

TTC with All Lines In Service

8050 MW

RAMAPO__345_345_PAR3500

Sun 10/15/2023 to Sun 10/15/2023

0001 Continuous 2200

Work scheduled by: ConEd

SCH - PJ - NY

FWD (Import)

REV (Export)

1750 MW

Impacts Total Transfer Capability

500 MW

TTC with All Lines In Service

2250 MW

RAMAPO__345_345_PAR4500

Sun 10/15/2023 to Sun 10/15/2023

0001 Continuous 2200

Work scheduled by: ConEd

SCH - PJ - NY

FWD (Import)

REV (Export)

1750 MW

Impacts Total Transfer Capability

500 MW

TTC with All Lines In Service

2250 MW

RAMAPO__500_345_BK 1500

Sun 10/15/2023 to Sun 10/15/2023

0001 Continuous 2200

Work scheduled by: ConEd

SCH - PJ - NY

FWD (Import)

REV (Export)

1100 MW

1000 MW

Impacts Total Transfer Capability

1150 MW

200 MW

TTC with All Lines In Service

2250 MW

1200 MW

RAMAPO__500_345_BK 1500

Sun 10/15/2023 to Sun 10/15/2023

0001 Continuous 2200

Work scheduled by: ConEd

UPNY CONED

FWD (Import)

REV (Export)

7795 MW

Impacts Total Transfer Capability

255 MW

TTC with All Lines In Service

8050 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Monday, September 25, 2023 to Monday, March 24, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-HQ-NYISO_LIMIT_1150

Sun 10/15/2023 to Sun 10/15/2023
0001 Continuous 0200

Work scheduled by: HQ

SCH - HQ - NY

FWD (Import)

REV (Export)

1150 MW

Impacts Total Transfer Capability

350 MW

TTC with All Lines In Service

1500 MW

SCH-NE-NYISO_LIMIT_800

Sun 10/15/2023 to Sun 10/15/2023
0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY

FWD (Import)

REV (Export)

1000 MW

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

1400 MW

SCH-NYISO-NE_LIMIT_900

Sun 10/15/2023 to Sun 10/15/2023
0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY

FWD (Import)

REV (Export)

1100 MW

Impacts Total Transfer Capability

500 MW

TTC with All Lines In Service

1600 MW

SCH-NE-NYISO_LIMIT_800

Sun 10/15/2023 to Mon 10/16/2023
2300 Daily 0659

Work scheduled by: ISONE

SCH - NE - NY

FWD (Import)

REV (Export)

1000 MW

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

1400 MW

SCH-NYISO-NE_LIMIT_900

Sun 10/15/2023 to Mon 10/16/2023
2300 Daily 0659

Work scheduled by: ISONE

SCH - NE - NY

FWD (Import)

REV (Export)

1100 MW

Impacts Total Transfer Capability

500 MW

TTC with All Lines In Service

1600 MW

LADENTWN-BUCHAN_S_345_Y88

Mon 10/16/2023 to Mon 11/06/2023
0201 Continuous 0200

Work scheduled by: ConEd

UPDATED by ConEd 06/16/2023 08:29

UPNY CONED

FWD (Import)

REV (Export)

7695 MW

Impacts Total Transfer Capability

355 MW

TTC with All Lines In Service

8050 MW

NYISO TRANSFER LIMITATIONS

Page 17 of 50
Number Of Records: 295
Report Run Date: 09/25/2023 23:03 (EPT)

Seasonal Limits

Monday, September 25, 2023 to Monday, March 24, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FRASANNX-COOPERS_345_UCC2-41

Mon 10/16/2023 to Fri 10/27/2023

0600 Continuous 1730

Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

2275 MW

445 MW

2720 MW

MARCY__FRASANNX_345_UCC2-41

Mon 10/16/2023 to Fri 10/27/2023

0600 Continuous 1730

Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

2275 MW

445 MW

2720 MW

MOSES__ADIRNDCK_230_MA2

Mon 10/16/2023 to Mon 10/16/2023

0700 Continuous 1730

Work scheduled by: NYPA

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

2100 MW

1050 MW

3150 MW

SCH-NE-NYISO_LIMIT_800

Mon 10/16/2023 to Mon 10/16/2023

0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

1000 MW

400 MW

1400 MW

SCH-NYISO-NE_LIMIT_900

Mon 10/16/2023 to Mon 10/16/2023

0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

1100 MW

500 MW

1600 MW

HOMR_NYW-PIERC_NY_345_48

Mon 10/16/2023 to Fri 10/20/2023

0800 Continuous 1600

Work scheduled by: PJM

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Monday, September 25, 2023 to Monday, March 24, 2025

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2720 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NE-NYISO_LIMIT_800

Mon 10/16/2023 to Tue 10/17/2023
2300 Daily 0659

Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
	1000 MW	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

SCH-NYISO-NE_LIMIT_900

Mon 10/16/2023 to Tue 10/17/2023
2300 Daily 0659

Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
		1100 MW
Impacts Total Transfer Capability		500 MW
TTC with All Lines In Service		1600 MW

SCH-NE-NYISO_LIMIT_800

Tue 10/17/2023 to Tue 10/17/2023
0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
	1000 MW	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

SCH-NYISO-NE_LIMIT_900

Tue 10/17/2023 to Tue 10/17/2023
0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
		1100 MW
Impacts Total Transfer Capability		500 MW
TTC with All Lines In Service		1600 MW

SCH-NE-NYISO_LIMIT_800

Tue 10/17/2023 to Wed 10/18/2023
2300 Daily 0659

Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
	1000 MW	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

SCH-NYISO-NE_LIMIT_900

Tue 10/17/2023 to Wed 10/18/2023
2300 Daily 0659

Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
		1100 MW
Impacts Total Transfer Capability		500 MW
TTC with All Lines In Service		1600 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Monday, September 25, 2023 to Monday, March 24, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NE-NYISO_LIMIT_800

Wed 10/18/2023 to Wed 10/18/2023
0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
	1000 MW	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

SCH-NYISO-NE_LIMIT_900

Wed 10/18/2023 to Wed 10/18/2023
0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
		1100 MW
Impacts Total Transfer Capability		500 MW
TTC with All Lines In Service		1600 MW

SCH-NE-NYISO_LIMIT_800

Wed 10/18/2023 to Thu 10/19/2023
2300 Daily 0659

Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
	1000 MW	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

SCH-NYISO-NE_LIMIT_900

Wed 10/18/2023 to Thu 10/19/2023
2300 Daily 0659

Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
		1100 MW
Impacts Total Transfer Capability		500 MW
TTC with All Lines In Service		1600 MW

SCH-NE-NYISO_LIMIT_800

Thu 10/19/2023 to Thu 10/19/2023
0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
	1000 MW	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

SCH-NYISO-NE_LIMIT_900

Thu 10/19/2023 to Thu 10/19/2023
0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
		1100 MW
Impacts Total Transfer Capability		500 MW
TTC with All Lines In Service		1600 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Monday, September 25, 2023 to Monday, March 24, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NE-NYISO_LIMIT_900

Thu 10/19/2023 to Mon 10/30/2023
0830 Continuous 0900
Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)
Impacts Total Transfer Capability 1100 MW 300 MW
TTC with All Lines In Service 1400 MW

SCH-NE-NYISO_LIMIT_800

Thu 10/19/2023 to Fri 10/20/2023
2300 Daily 0659
Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)
Impacts Total Transfer Capability 1000 MW 400 MW
TTC with All Lines In Service 1400 MW

SCH-NYISO-NE_LIMIT_900

Thu 10/19/2023 to Fri 10/20/2023
2300 Daily 0659
Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)
Impacts Total Transfer Capability 1100 MW 500 MW
TTC with All Lines In Service 1600 MW

SCH-NE-NYISO_LIMIT_800

Fri 10/20/2023 to Fri 10/20/2023
0700 Daily 2259
Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)
Impacts Total Transfer Capability 1000 MW 400 MW
TTC with All Lines In Service 1400 MW

SCH-NYISO-NE_LIMIT_900

Fri 10/20/2023 to Fri 10/20/2023
0700 Daily 2259
Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)
Impacts Total Transfer Capability 1100 MW 500 MW
TTC with All Lines In Service 1600 MW

DENNISON-ROSEMNTA_115_1/11

Fri 10/20/2023 to Fri 10/20/2023
0830 Continuous 1030
Work scheduled by: NGrid

SCH - HQ_CEDARS FWD (Import) REV (Export)
Impacts Total Transfer Capability 95 MW 40 MW
TTC with All Lines In Service 175 MW 60 MW
270 MW 100 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Monday, September 25, 2023 to Monday, March 24, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NE-NYISO_LIMIT_800

Fri 10/20/2023 to Sat 10/21/2023
2300 Daily 0659

Work scheduled by: ISONE

SCH - NE - NY **1000 MW**
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 1400 MW

FWD (Import) REV (Export)

SCH-NYISO-NE_LIMIT_900

Fri 10/20/2023 to Sat 10/21/2023
2300 Daily 0659

Work scheduled by: ISONE

SCH - NE - NY **1100 MW**
Impacts Total Transfer Capability 500 MW
TTC with All Lines In Service 1600 MW

FWD (Import) REV (Export)

SCH-NE-NYISO_LIMIT_800

Sat 10/21/2023 to Sat 10/21/2023
0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY **1000 MW**
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 1400 MW

FWD (Import) REV (Export)

SCH-NYISO-NE_LIMIT_900

Sat 10/21/2023 to Sat 10/21/2023
0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY **1100 MW**
Impacts Total Transfer Capability 500 MW
TTC with All Lines In Service 1600 MW

FWD (Import) REV (Export)

SCH-NE-NYISO_LIMIT_800

Sat 10/21/2023 to Sun 10/22/2023
2300 Daily 0659

Work scheduled by: ISONE

SCH - NE - NY **1000 MW**
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 1400 MW

FWD (Import) REV (Export)

SCH-NYISO-NE_LIMIT_900

Sat 10/21/2023 to Sun 10/22/2023
2300 Daily 0659

Work scheduled by: ISONE

SCH - NE - NY **1100 MW**
Impacts Total Transfer Capability 500 MW
TTC with All Lines In Service 1600 MW

FWD (Import) REV (Export)

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Monday, September 25, 2023 to Monday, March 24, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHASLAKE-PORTER__230_11

Sun 10/22/2023 to Tue 11/14/2023
0630 Continuous 1730

Work scheduled by: NGrid

MOSES SOUTH
Impacts Total Transfer Capability 2100 MW
TTC with All Lines In Service 1050 MW
3150 MW

FWD (Import) REV (Export)

SCH-IMO-NYISO_LIMIT_1450

Sun 10/22/2023 to Tue 10/31/2023
0630 Continuous 2359

Work scheduled by: IESO

UPDATED by IESO 08/20/2023 08:38

SCH - OH - NY
Impacts Total Transfer Capability 1750 MW
TTC with All Lines In Service 300 MW
2050 MW

FWD (Import) REV (Export)

SCH-NE-NYISO_LIMIT_800

Sun 10/22/2023 to Sun 10/22/2023
0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY
Impacts Total Transfer Capability 1000 MW
TTC with All Lines In Service 400 MW
1400 MW

FWD (Import) REV (Export)

SCH-NYISO-NE_LIMIT_900

Sun 10/22/2023 to Sun 10/22/2023
0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY
Impacts Total Transfer Capability 1100 MW
TTC with All Lines In Service 500 MW
1600 MW

FWD (Import) REV (Export)

SCH-NE-NYISO_LIMIT_800

Sun 10/22/2023 to Mon 10/23/2023
2300 Daily 0659

Work scheduled by: ISONE

SCH - NE - NY
Impacts Total Transfer Capability 1000 MW
TTC with All Lines In Service 400 MW
1400 MW

FWD (Import) REV (Export)

SCH-NYISO-NE_LIMIT_900

Sun 10/22/2023 to Mon 10/23/2023
2300 Daily 0659

Work scheduled by: ISONE

SCH - NE - NY
Impacts Total Transfer Capability 1100 MW
TTC with All Lines In Service 500 MW
1600 MW

FWD (Import) REV (Export)

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Monday, September 25, 2023 to Monday, March 24, 2025

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2720 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_6

Mon 10/23/2023 to Thu 11/09/2023
0001 Continuous 2200
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	3800 MW	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

DUNWODIE-SHORE_RD_345_Y50

Mon 10/23/2023 to Thu 11/09/2023
0001 Continuous 2200
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
CONED - LIPA	800 MW	
Impacts Total Transfer Capability	700 MW	
TTC with All Lines In Service	1500 MW	

SHORE_RD_345_138_BK 1

Mon 10/23/2023 to Thu 11/09/2023
0001 Continuous 2200
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
CONED - LIPA	1350 MW	
Impacts Total Transfer Capability	150 MW	
TTC with All Lines In Service	1500 MW	

SHORE_RD_345_138_BK 2

Mon 10/23/2023 to Thu 11/09/2023
0001 Continuous 2200
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
CONED - LIPA	1350 MW	
Impacts Total Transfer Capability	150 MW	
TTC with All Lines In Service	1500 MW	

SCH-NE-NYISO_LIMIT_800

Mon 10/23/2023 to Mon 10/23/2023
0700 Daily 2259
Work scheduled by: ISONE

	FWD (Import)	REV (Export)
SCH - NE - NY	1000 MW	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

SCH-NYISO-NE_LIMIT_900

Mon 10/23/2023 to Mon 10/23/2023
0700 Daily 2259
Work scheduled by: ISONE

	FWD (Import)	REV (Export)
SCH - NE - NY		1100 MW
Impacts Total Transfer Capability		500 MW
TTC with All Lines In Service		1600 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Monday, September 25, 2023 to Monday, March 24, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NE-NYISO_LIMIT_800

Mon 10/23/2023 to Tue 10/24/2023
2300 Daily 0659

Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)
1000 MW
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 1400 MW

SCH-NYISO-NE_LIMIT_900

Mon 10/23/2023 to Tue 10/24/2023
2300 Daily 0659

Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)
1100 MW
Impacts Total Transfer Capability 500 MW
TTC with All Lines In Service 1600 MW

SCH-NE-NYISO_LIMIT_800

Tue 10/24/2023 to Tue 10/24/2023
0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)
1000 MW
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 1400 MW

SCH-NYISO-NE_LIMIT_900

Tue 10/24/2023 to Tue 10/24/2023
0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)
1100 MW
Impacts Total Transfer Capability 500 MW
TTC with All Lines In Service 1600 MW

SCH-NE-NYISO_LIMIT_800

Tue 10/24/2023 to Wed 10/25/2023
2300 Daily 0659

Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)
1000 MW
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 1400 MW

SCH-NYISO-NE_LIMIT_900

Tue 10/24/2023 to Wed 10/25/2023
2300 Daily 0659

Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)
1100 MW
Impacts Total Transfer Capability 500 MW
TTC with All Lines In Service 1600 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Monday, September 25, 2023 to Monday, March 24, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NE-NYISO_LIMIT_800

Wed 10/25/2023 to Wed 10/25/2023
0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
	1000 MW	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

SCH-NYISO-NE_LIMIT_900

Wed 10/25/2023 to Wed 10/25/2023
0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
		1100 MW
Impacts Total Transfer Capability		500 MW
TTC with All Lines In Service		1600 MW

SCH-NE-NYISO_LIMIT_800

Wed 10/25/2023 to Thu 10/26/2023
2300 Daily 0659

Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
	1000 MW	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

SCH-NYISO-NE_LIMIT_900

Wed 10/25/2023 to Thu 10/26/2023
2300 Daily 0659

Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
		1100 MW
Impacts Total Transfer Capability		500 MW
TTC with All Lines In Service		1600 MW

E13THSTA-FARRAGUT_345_45

Thu 10/26/2023 to Thu 10/26/2023
0001 Continuous 0030

Work scheduled by: ConEd

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	3800 MW	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

SCH-NE-NYISO_LIMIT_800

Thu 10/26/2023 to Thu 10/26/2023
0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
	1000 MW	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Monday, September 25, 2023 to Monday, March 24, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-NE_LIMIT_900

Thu 10/26/2023 to Thu 10/26/2023
0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)
Impacts Total Transfer Capability 1100 MW
TTC with All Lines In Service 500 MW
1600 MW

SCH-NE-NYISO_LIMIT_800

Thu 10/26/2023 to Fri 10/27/2023
2300 Daily 0659

Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)
Impacts Total Transfer Capability 1000 MW
TTC with All Lines In Service 400 MW
1400 MW

SCH-NYISO-NE_LIMIT_900

Thu 10/26/2023 to Fri 10/27/2023
2300 Daily 0659

Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)
Impacts Total Transfer Capability 1100 MW
TTC with All Lines In Service 500 MW
1600 MW

SCH-NE-NYISO_LIMIT_800

Fri 10/27/2023 to Fri 10/27/2023
0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)
Impacts Total Transfer Capability 1000 MW
TTC with All Lines In Service 400 MW
1400 MW

SCH-NYISO-NE_LIMIT_900

Fri 10/27/2023 to Fri 10/27/2023
0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)
Impacts Total Transfer Capability 1100 MW
TTC with All Lines In Service 500 MW
1600 MW

ELBRIDGE-LAFAYTTE_345_17-LE

Fri 10/27/2023 to Fri 10/27/2023
1800 Continuous 2100

Work scheduled by: NGrid

ARR: 75

OSWEGO EXPORT FWD (Import) REV (Export)
Impacts Total Transfer Capability 5250 MW
TTC with All Lines In Service 0 MW
5250 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Monday, September 25, 2023 to Monday, March 24, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LAFAYTTE-CLRKSCRN_345_4-46

Fri 10/27/2023 to Fri 10/27/2023
1800 Continuous 2100
Work scheduled by: NGrid

CENTRAL EAST - VC
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) 2450 MW
270 MW
2720 MW

SCH-NE-NYISO_LIMIT_800

Fri 10/27/2023 to Sat 10/28/2023
2300 Daily 0659
Work scheduled by: ISONE

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) 1000 MW
400 MW
1400 MW

SCH-NYISO-NE_LIMIT_900

Fri 10/27/2023 to Sat 10/28/2023
2300 Daily 0659
Work scheduled by: ISONE

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) 1100 MW
500 MW
1600 MW

SCH-NE-NYISO_LIMIT_800

Sat 10/28/2023 to Sat 10/28/2023
0700 Daily 2259
Work scheduled by: ISONE

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) 1000 MW
400 MW
1400 MW

SCH-NYISO-NE_LIMIT_900

Sat 10/28/2023 to Sat 10/28/2023
0700 Daily 2259
Work scheduled by: ISONE

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) 1100 MW
500 MW
1600 MW

SCH-NE-NYISO_LIMIT_800

Sat 10/28/2023 to Sun 10/29/2023
2300 Daily 0659
Work scheduled by: ISONE

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) 1000 MW
400 MW
1400 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Monday, September 25, 2023 to Monday, March 24, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-NE_LIMIT_900

Sat 10/28/2023 to Sun 10/29/2023
2300 Daily 0659

Work scheduled by: ISONE

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

1100 MW

500 MW

1600 MW

MOSES__-ADIRNDCK_230_MA1

Sun 10/29/2023 to Sat 11/04/2023
0700 Continuous 1930

Work scheduled by: NYPA

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

2100 MW

1050 MW

3150 MW

SCH-NE-NYISO_LIMIT_800

Sun 10/29/2023 to Sun 10/29/2023
0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

1000 MW

400 MW

1400 MW

SCH-NYISO-NE_LIMIT_900

Sun 10/29/2023 to Sun 10/29/2023
0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

1100 MW

500 MW

1600 MW

SCH-NE-NYISO_LIMIT_800

Sun 10/29/2023 to Mon 10/30/2023
2300 Daily 0659

Work scheduled by: ISONE

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

1000 MW

400 MW

1400 MW

SCH-NYISO-NE_LIMIT_900

Sun 10/29/2023 to Mon 10/30/2023
2300 Daily 0659

Work scheduled by: ISONE

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

1100 MW

500 MW

1600 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Monday, September 25, 2023 to Monday, March 24, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK_TREMONT_345_X28

Mon 10/30/2023 to Mon 10/30/2023
0001 Continuous 0400

UPDATED by ConEd 08/01/2023 16:11

FWD (Import) REV (Export)

4200 MW

400 MW

4600 MW

Work scheduled by: ConEd

SPR/DUN-SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

E13THSTA-FARRAGUT_345_45

Mon 10/30/2023 to Mon 10/30/2023
0230 Continuous 0300

FWD (Import) REV (Export)

3800 MW

800 MW

4600 MW

Work scheduled by: ConEd

SPR/DUN-SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

SCH-NE-NYISO_LIMIT_800

Mon 10/30/2023 to Mon 10/30/2023
0700 Daily 2259

FWD (Import) REV (Export)

1000 MW

400 MW

1400 MW

Work scheduled by: ISONE

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

SCH-NYISO-NE_LIMIT_900

Mon 10/30/2023 to Mon 10/30/2023
0700 Daily 2259

FWD (Import) REV (Export)

1100 MW

500 MW

1600 MW

Work scheduled by: ISONE

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

SCH-NE-NYISO_LIMIT_800

Mon 10/30/2023 to Tue 10/31/2023
2300 Daily 0659

FWD (Import) REV (Export)

1000 MW

400 MW

1400 MW

Work scheduled by: ISONE

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

SCH-NYISO-NE_LIMIT_900

Mon 10/30/2023 to Tue 10/31/2023
2300 Daily 0659

FWD (Import) REV (Export)

1100 MW

500 MW

1600 MW

Work scheduled by: ISONE

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Monday, September 25, 2023 to Monday, March 24, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NE-NYISO_LIMIT_800

Tue 10/31/2023 to Tue 10/31/2023
0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY

FWD (Import)

REV (Export)

1000 MW

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

1400 MW

SCH-NYISO-NE_LIMIT_900

Tue 10/31/2023 to Tue 10/31/2023
0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY

FWD (Import)

REV (Export)

1100 MW

Impacts Total Transfer Capability

500 MW

TTC with All Lines In Service

1600 MW

SCH-NE-NYISO_LIMIT_800

Tue 10/31/2023 to Wed 11/01/2023
2300 Daily 0659

Work scheduled by: ISONE

SCH - NE - NY

FWD (Import)

REV (Export)

1000 MW

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

1400 MW

SCH-NYISO-NE_LIMIT_900

Tue 10/31/2023 to Wed 11/01/2023
2300 Daily 0659

Work scheduled by: ISONE

SCH - NE - NY

FWD (Import)

REV (Export)

1100 MW

Impacts Total Transfer Capability

500 MW

TTC with All Lines In Service

1600 MW

NEPTUNE_-DUFFYAVE_345_NEPTUNE

Wed 11/01/2023 to Mon 11/20/2023
0001 Continuous 2359

Work scheduled by: LI

UPDATED by LI 04/22/2023 14:51

SCH - PJM_NEPTUNE

FWD (Import)

REV (Export)

0 MW

Impacts Total Transfer Capability

660 MW

TTC with All Lines In Service

660 MW

NEWBRIDGE_345_138_BK_1

Wed 11/01/2023 to Mon 11/20/2023
0001 Continuous 2359

Work scheduled by: LI

UPDATED by LI 04/22/2023 14:51

SCH - PJM_NEPTUNE

FWD (Import)

REV (Export)

375 MW

Impacts Total Transfer Capability

285 MW

TTC with All Lines In Service

660 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Monday, September 25, 2023 to Monday, March 24, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEWBRDGE_345_138_BK_2

Wed 11/01/2023 to Mon 11/20/2023
0001 Continuous 2359

UPDATED by LI 04/22/2023 14:51

SCH - PJM_NEPTUNE

FWD (Import)

REV (Export)

375 MW

Impacts Total Transfer Capability

285 MW

TTC with All Lines In Service

660 MW

Work scheduled by: LI

NEWBRDGE-DUFFYAVE_345_501

Wed 11/01/2023 to Mon 11/20/2023
0001 Continuous 2359

UPDATED by LI 04/22/2023 14:51

SCH - PJM_NEPTUNE

FWD (Import)

REV (Export)

0 MW

Impacts Total Transfer Capability

660 MW

TTC with All Lines In Service

660 MW

Work scheduled by: LI

SCH-NE-NYISO_LIMIT_800

Wed 11/01/2023 to Wed 11/01/2023
0700 Daily 2259

SCH - NE - NY

FWD (Import)

REV (Export)

1000 MW

Impacts Total Transfer Capability

600 MW

TTC with All Lines In Service

1600 MW

Work scheduled by: ISONE

SCH-NYISO-NE_LIMIT_900

Wed 11/01/2023 to Wed 11/01/2023
0700 Daily 2259

SCH - NE - NY

FWD (Import)

REV (Export)

1100 MW

Impacts Total Transfer Capability

700 MW

TTC with All Lines In Service

1800 MW

Work scheduled by: ISONE

SPRNBK-TREMONT_345_X28

Wed 11/01/2023 to Wed 11/01/2023
1730 Continuous 1800

UPDATED by ConEd 08/01/2023 16:11

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

4200 MW

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

4600 MW

Work scheduled by: ConEd

SCH-NE-NYISO_LIMIT_800

Wed 11/01/2023 to Thu 11/02/2023
2300 Daily 0659

SCH - NE - NY

FWD (Import)

REV (Export)

1000 MW

Impacts Total Transfer Capability

600 MW

TTC with All Lines In Service

1600 MW

Work scheduled by: ISONE

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Monday, September 25, 2023 to Monday, March 24, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-NE_LIMIT_900

Wed 11/01/2023 to Thu 11/02/2023
2300 Daily 0659
Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)
1100 MW
Impacts Total Transfer Capability 700 MW
TTC with All Lines In Service 1800 MW

SCH-NE-NYISO_LIMIT_800

Thu 11/02/2023 to Thu 11/02/2023
0700 Daily 2259
Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)
1000 MW
Impacts Total Transfer Capability 600 MW
TTC with All Lines In Service 1600 MW

SCH-NYISO-NE_LIMIT_900

Thu 11/02/2023 to Thu 11/02/2023
0700 Daily 2259
Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)
1100 MW
Impacts Total Transfer Capability 700 MW
TTC with All Lines In Service 1800 MW

SCH-NE-NYISO_LIMIT_800

Thu 11/02/2023 to Fri 11/03/2023
2300 Daily 0659
Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)
1000 MW
Impacts Total Transfer Capability 600 MW
TTC with All Lines In Service 1600 MW

SCH-NYISO-NE_LIMIT_900

Thu 11/02/2023 to Fri 11/03/2023
2300 Daily 0659
Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)
1100 MW
Impacts Total Transfer Capability 700 MW
TTC with All Lines In Service 1800 MW

SCH-NE-NYISO_LIMIT_800

Fri 11/03/2023 to Fri 11/03/2023
0700 Daily 2259
Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)
1000 MW
Impacts Total Transfer Capability 600 MW
TTC with All Lines In Service 1600 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Monday, September 25, 2023 to Monday, March 24, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-NE_LIMIT_900					FWD (Import)	REV (Export)
Fri 11/03/2023	to	Fri 11/03/2023		SCH - NE - NY		1100 MW
0700	Daily	2259		Impacts Total Transfer Capability		700 MW
Work scheduled by: ISONE				TTC with All Lines In Service		1800 MW
SCH-NE-NYISO_LIMIT_800					FWD (Import)	REV (Export)
Fri 11/03/2023	to	Sat 11/04/2023		SCH - NE - NY		1000 MW
2300	Daily	0659		Impacts Total Transfer Capability	600 MW	
Work scheduled by: ISONE				TTC with All Lines In Service	1600 MW	
SCH-NYISO-NE_LIMIT_900					FWD (Import)	REV (Export)
Fri 11/03/2023	to	Sat 11/04/2023		SCH - NE - NY		1100 MW
2300	Daily	0659		Impacts Total Transfer Capability	700 MW	
Work scheduled by: ISONE				TTC with All Lines In Service	1800 MW	
SCH-NE-NYISO_LIMIT_800					FWD (Import)	REV (Export)
Sat 11/04/2023	to	Sat 11/04/2023		SCH - NE - NY		1000 MW
0700	Daily	2259		Impacts Total Transfer Capability	600 MW	
Work scheduled by: ISONE				TTC with All Lines In Service	1600 MW	
SCH-NYISO-NE_LIMIT_900					FWD (Import)	REV (Export)
Sat 11/04/2023	to	Sat 11/04/2023		SCH - NE - NY		1100 MW
0700	Daily	2259		Impacts Total Transfer Capability	700 MW	
Work scheduled by: ISONE				TTC with All Lines In Service	1800 MW	
SCH-NE-NYISO_LIMIT_800					FWD (Import)	REV (Export)
Sat 11/04/2023	to	Sun 11/05/2023		SCH - NE - NY		1000 MW
2300	Daily	0659		Impacts Total Transfer Capability	600 MW	
Work scheduled by: ISONE				TTC with All Lines In Service	1600 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Monday, September 25, 2023 to Monday, March 24, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-NE_LIMIT_900

Sat 11/04/2023 to Sun 11/05/2023
2300 Daily 0659

Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)
Impacts Total Transfer Capability **1100 MW**
TTC with All Lines In Service 700 MW
1800 MW

MOSES__-ADIRNDCK_230_MA2

Sun 11/05/2023 to Sat 11/11/2023
0700 Continuous 1930

Work scheduled by: NYPA

MOSES SOUTH FWD (Import) REV (Export)
Impacts Total Transfer Capability **2300 MW**
TTC with All Lines In Service 850 MW
3150 MW

SCH-NE-NYISO_LIMIT_800

Sun 11/05/2023 to Sun 11/05/2023
0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)
Impacts Total Transfer Capability **1000 MW**
TTC with All Lines In Service 600 MW
1600 MW

SCH-NYISO-NE_LIMIT_900

Sun 11/05/2023 to Sun 11/05/2023
0700 Daily 2259

Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)
Impacts Total Transfer Capability **1100 MW**
TTC with All Lines In Service 700 MW
1800 MW

SCH-NE-NYISO_LIMIT_800

Sun 11/05/2023 to Mon 11/06/2023
2300 Daily 0659

Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)
Impacts Total Transfer Capability **1000 MW**
TTC with All Lines In Service 600 MW
1600 MW

SCH-NYISO-NE_LIMIT_900

Sun 11/05/2023 to Mon 11/06/2023
2300 Daily 0659

Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)
Impacts Total Transfer Capability **1100 MW**
TTC with All Lines In Service 700 MW
1800 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Monday, September 25, 2023 to Monday, March 24, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_3

Mon 11/06/2023 to Thu 11/09/2023
0201 Continuous 2200
Work scheduled by: ConEd

SPR/DUN-SOUTH FWD (Import) REV (Export)
3800 MW
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

SCH-NE-NYISO_LIMIT_800

Mon 11/06/2023 to Mon 11/06/2023
0700 Daily 2259
Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)
1000 MW
Impacts Total Transfer Capability 600 MW
TTC with All Lines In Service 1600 MW

SCH-NYISO-NE_LIMIT_900

Mon 11/06/2023 to Mon 11/06/2023
0700 Daily 1500
Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)
1100 MW
Impacts Total Transfer Capability 700 MW
TTC with All Lines In Service 1800 MW

LINDN_CG-LNDVFT__345_V-3022

Mon 11/06/2023 to Thu 11/09/2023
0800 Continuous 1500
Work scheduled by: PJM

SCH - PJM_VFT FWD (Import) REV (Export)
0 MW 0 MW
Impacts Total Transfer Capability 315 MW 315 MW
TTC with All Lines In Service 315 MW 315 MW

PANNELL_-CLAY__345_2

Thu 11/09/2023 to Mon 11/13/2023
0600 Continuous 1800
Work scheduled by: NYPA

WEST CENTRAL FWD (Import) REV (Export)
1300 MW
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

RAMAPO_-BUCHAN_N_345_Y94

Tue 11/14/2023 to Thu 12/21/2023
0201 Continuous 0200
Work scheduled by: ConEd

UPNY CONED FWD (Import) REV (Export)
7755 MW
Impacts Total Transfer Capability 295 MW
TTC with All Lines In Service 8050 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Monday, September 25, 2023 to Monday, March 24, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHATGUAY-MASSENA_765_7040

Wed 11/15/2023 to Mon 11/27/2023
0700 Continuous 1730
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - HQ - NY	0 MW	0 MW
Impacts Total Transfer Capability	1500 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

CHATGUAY-MASSENA_765_7040

Wed 11/15/2023 to Mon 11/27/2023
0700 Continuous 1730
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
MOSES SOUTH	1550 MW	
Impacts Total Transfer Capability	1600 MW	
TTC with All Lines In Service	3150 MW	

CHATGUAY-MASSENA_765_7040 , MASSENA-MARCY_765_MSU1

Wed 11/15/2023 to Mon 11/27/2023
0700 1730
Work scheduled by:

	FWD (Import)	REV (Export)
MOSES SOUTH	500 MW	
Impacts Total Transfer Capability	2650 MW	
TTC with All Lines In Service	3150 MW	

MASSENA-MARCY_765_MSU1

Wed 11/15/2023 to Mon 11/27/2023
0700 Continuous 1730
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
CENTRAL EAST - VC	1720 MW	
Impacts Total Transfer Capability	1000 MW	
TTC with All Lines In Service	2720 MW	

MASSENA-MARCY_765_MSU1

Wed 11/15/2023 to Mon 11/27/2023
0700 Continuous 1730
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS	90 MW	
Impacts Total Transfer Capability	189 MW	
TTC with All Lines In Service	279 MW	

MASSENA-MARCY_765_MSU1

Wed 11/15/2023 to Mon 11/27/2023
0700 Continuous 1730
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - HQ - NY	475 MW	1000 MW
Impacts Total Transfer Capability	1025 MW	0 MW
TTC with All Lines In Service	1500 MW	1000 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Monday, September 25, 2023 to Monday, March 24, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA_MARCY__765_MSU1

Wed 11/15/2023 to Mon 11/27/2023
0700 Continuous 1730
Work scheduled by: NYPA

MOSES SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) 500 MW
REV (Export) 2650 MW
3150 MW

MOSES_-MASSENA_230_MMS1 , MOSES_-MASSENA_230_MMS2

Wed 11/15/2023 to Mon 11/20/2023
0700 1530
Work scheduled by:

SCH - HQ_CEDARS
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) 90 MW
REV (Export) 189 MW
279 MW

MOSES_-MASSENA_230_MMS1 , MOSES_-MASSENA_230_MMS2

Wed 11/15/2023 to Mon 11/20/2023
0700 1530
Work scheduled by:

SCH - HQ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) 850 MW
REV (Export) 0 MW
650 MW 1000 MW
1500 MW 1000 MW

LINDN_CG-LNDVFT__345_V-3022

Wed 11/15/2023 to Wed 11/15/2023
1500 Continuous 1700
Work scheduled by: PJM

SCH - PJM_VFT
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) 0 MW
REV (Export) 0 MW
315 MW 315 MW
315 MW 315 MW

SCH-NYISO-IMO_NIAGARA_NORTH_BUS

Sat 11/18/2023 to Sun 11/19/2023
0500 Continuous 2200
Work scheduled by: NYPA
UPDATED by NYPA 08/03/2023 12:04

SCH - OH - NY
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) 1100 MW
REV (Export) 950 MW
1300 MW 1050 MW
2400 MW 2000 MW

BECK_-NIAGARA_345_PA301

Sat 11/25/2023 to Sun 11/26/2023
0500 Continuous 2200
Work scheduled by: NYPA
UPDATED by NYPA 08/04/2023 13:08

SCH - OH - NY
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) 1100 MW
REV (Export) 950 MW
1300 MW 1050 MW
2400 MW 2000 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Monday, September 25, 2023 to Monday, March 24, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

GILBOA_-N.SCTLND_345_GNS-1

Mon 11/27/2023 to Fri 12/01/2023
0700 Continuous 1530

Work scheduled by: NYPA

CENTRAL EAST - VC FWD (Import) REV (Export)
Impacts Total Transfer Capability 2300 MW 420 MW
TTC with All Lines In Service 2720 MW

OSWEGO_-VOLNEY__345_11

Tue 11/28/2023 to Fri 12/15/2023
0730 Continuous 1630

Work scheduled by: NGrid

OSWEGO EXPORT FWD (Import) REV (Export)
Impacts Total Transfer Capability 5250 MW 0 MW
TTC with All Lines In Service 5250 MW

ADIRNDCK-PORTER__230_12

Fri 12/01/2023 to Fri 12/22/2023
0530 Continuous 1700

Work scheduled by: NGrid

UPDATED by NGrid 07/11/2023 11:44

MOSES SOUTH FWD (Import) REV (Export)
Impacts Total Transfer Capability 2300 MW 850 MW
TTC with All Lines In Service 3150 MW

KNICRBKR-PLSNTVLY_345_Y57

Mon 12/04/2023 to Wed 12/06/2023
0400 Continuous 1700

Work scheduled by: NGrid

ARR: 78

UPNY CONED FWD (Import) REV (Export)
Impacts Total Transfer Capability 7885 MW 165 MW
TTC with All Lines In Service 8050 MW

NIAGARA_345_230_AT4

Mon 12/04/2023 to Fri 12/08/2023
0500 Continuous 1900

Work scheduled by: NYPA

UPDATED by NYPA 03/21/2023 14:25

SCH - OH - NY FWD (Import) REV (Export)
Impacts Total Transfer Capability 1650 MW 350 MW
TTC with All Lines In Service 2000 MW

S.RIPLEY-DUNKIRK_230_68

Mon 12/04/2023 to Fri 12/08/2023
0800 Continuous 1600

Work scheduled by: PJM

SCH - PJ - NY FWD (Import) REV (Export)
Impacts Total Transfer Capability
TTC with All Lines In Service

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Monday, September 25, 2023 to Monday, March 24, 2025

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2720 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BERKSHIR-ALPS___345_393					FWD (Import)	REV (Export)
Tue 12/05/2023	to	Sun 12/10/2023		SCH - NPX_1385	100 MW	100 MW
0630	Continuous	1800	ARR: 78	Impacts Total Transfer Capability	100 MW	100 MW
Work scheduled by: NGrid				TTC with All Lines In Service	200 MW	200 MW
BERKSHIR-ALPS___345_393					FWD (Import)	REV (Export)
Tue 12/05/2023	to	Sun 12/10/2023		SCH - NE - NY	1100 MW	1700 MW
0630	Continuous	1800	ARR: 78	Impacts Total Transfer Capability	500 MW	100 MW
Work scheduled by: NGrid				TTC with All Lines In Service	1600 MW	1800 MW
CLAY___EDIC___345_2-15					FWD (Import)	REV (Export)
Tue 12/05/2023	to	Thu 12/07/2023		OSWEGO EXPORT	4850 MW	
0700	Continuous	1630		Impacts Total Transfer Capability	400 MW	
Work scheduled by: NGrid				TTC with All Lines In Service	5250 MW	
BERKSHIR-ALPS___345_393 , BERKSHIR-NORTHFLD_345_312					FWD (Import)	REV (Export)
Tue 12/05/2023	to	Sun 12/10/2023		SCH - NE - NY	1100 MW	1100 MW
0800		1800	ARR: 78	Impacts Total Transfer Capability	500 MW	700 MW
Work scheduled by:				TTC with All Lines In Service	1600 MW	1800 MW
BERKSHIR-NORTHFLD_345_312					FWD (Import)	REV (Export)
Tue 12/05/2023	to	Sun 12/10/2023		SCH - NPX_1385	100 MW	100 MW
0800	Continuous	1800		Impacts Total Transfer Capability	100 MW	100 MW
Work scheduled by: NGrid				TTC with All Lines In Service	200 MW	200 MW
BERKSHIR-NORTHFLD_345_312					FWD (Import)	REV (Export)
Tue 12/05/2023	to	Sun 12/10/2023		SCH - NE - NY	1300 MW	
0800	Continuous	1800		Impacts Total Transfer Capability	300 MW	
Work scheduled by: NGrid				TTC with All Lines In Service	1600 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Monday, September 25, 2023 to Monday, March 24, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

E13THSTA-FARRAGUT_345_46

Sat 12/23/2023 to Mon 12/25/2023
0001 Continuous 0300

UPDATED by ConEd 09/18/2023 08:57

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

3800 MW

Impacts Total Transfer Capability

800 MW

TTC with All Lines In Service

4600 MW

Work scheduled by: ConEd

S.RIPLEY-DUNKIRK_230_68

Wed 12/27/2023 to Fri 12/29/2023
0730 Continuous 1600

SCH - PJ - NY

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: NGrid

WOOD_ST_-PLSNTVLE_345_Y87

Fri 12/29/2023 to Sun 12/31/2023
2200 Continuous 0259

UPNY CONED

FWD (Import)

REV (Export)

7470 MW

Impacts Total Transfer Capability

TTC with All Lines In Service

580 MW

8050 MW

Work scheduled by: ConEd

ADIRNDCK-PORTER_230_12

Tue 01/02/2024 to Fri 05/31/2024
0630 Continuous 1730

UPDATED by NGrid 07/11/2023 11:44

MOSES SOUTH

FWD (Import)

REV (Export)

2300 MW

Impacts Total Transfer Capability

TTC with All Lines In Service

850 MW

3150 MW

Work scheduled by: NGrid

FRASER_345_FRASER SVC

Tue 01/02/2024 to Fri 03/01/2024
0700 Continuous 1530

CENTRAL EAST - VC

FWD (Import)

REV (Export)

2690 MW

Impacts Total Transfer Capability

TTC with All Lines In Service

30 MW

2720 MW

Work scheduled by: NYPA

BECK_-PACKARD_230_BP76

Mon 01/15/2024 to Fri 01/19/2024
0400 Continuous 1700

SCH - OH - NY

FWD (Import)

REV (Export)

1800 MW

1350 MW

Impacts Total Transfer Capability

TTC with All Lines In Service

600 MW

650 MW

2400 MW

2000 MW

Work scheduled by: NGrid

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Monday, September 25, 2023 to Monday, March 24, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-IMO_NY_NIAG_NRTH_BUS_W/BB

Fri 01/26/2024 to Fri 01/26/2024
0500 Continuous 1900
Work scheduled by: NYPA

SCH - OH - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
1550 MW	1450 MW
850 MW	550 MW
2400 MW	2000 MW

E13THSTA-FARRAGUT_345_46

Tue 01/30/2024 to Sun 02/04/2024
0700 Continuous 0300
Work scheduled by: ConEd

UPDATED by ConEd 09/18/2023 08:57

SPR/DUN-SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
3800 MW	
800 MW	
4600 MW	

MOTTHAVN-RAINEY_345_Q12

Thu 02/01/2024 to Sat 03/02/2024
0001 Continuous 0200
Work scheduled by: ConEd

SPR/DUN-SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
3800 MW	
800 MW	
4600 MW	

CLAY_-EDIC_345_2-15

Mon 02/05/2024 to Fri 03/08/2024
0700 Continuous 1600
Work scheduled by: NGrid

OSWEGO EXPORT
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
4850 MW	
400 MW	
5250 MW	

SCH-IMO_NY_NIAG_SOUTH_BUS_W/BB

Fri 02/09/2024 to Fri 02/09/2024
0500 Continuous 1900
Work scheduled by: NYPA

SCH - OH - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
1550 MW	1450 MW
850 MW	550 MW
2400 MW	2000 MW

MILLWOOD-EASTVIEW_345_W85

Thu 02/15/2024 to Sat 02/17/2024
0001 Continuous 0200
Work scheduled by: ConEd

UPNY CONED
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
7810 MW	
240 MW	
8050 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Monday, September 25, 2023 to Monday, March 24, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_PACKARD_230_62

Fri 02/16/2024 to Fri 02/16/2024
0500 Continuous 1900
Work scheduled by: NYPA

SCH - OH - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
1750 MW	1850 MW
650 MW	150 MW
2400 MW	2000 MW

BECK__PACKARD_230_BP76

Mon 03/04/2024 to Fri 05/24/2024
0800 Continuous 1600
Work scheduled by: NGrid

SCH - OH - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
1800 MW	1350 MW
600 MW	650 MW
2400 MW	2000 MW

CLAY__EDIC__345_1-16

Mon 03/11/2024 to Mon 04/22/2024
0700 Continuous 1600
Work scheduled by: NGrid

OSWEGO EXPORT
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
4850 MW	
400 MW	
5250 MW	

MILLWOOD-EASTVIEW_345_W85

Fri 03/22/2024 to Thu 03/28/2024
0201 Continuous 0200
Work scheduled by: ConEd

UPNY CONED
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
7810 MW	
240 MW	
8050 MW	

SPRNBK_345KV_RNS3

Fri 03/22/2024 to Fri 03/22/2024
0201 Continuous 0230
Work scheduled by: ConEd

SPR/DUN-SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
3800 MW	
800 MW	
4600 MW	

LADENTWN-BUCHAN_S_345_Y88

Mon 04/01/2024 to Fri 05/17/2024
0001 Continuous 2359
Work scheduled by: ConEd

UPNY CONED
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
7695 MW	
355 MW	
8050 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Monday, September 25, 2023 to Monday, March 24, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FRASER_-GILBOA__345_GF5-35

Sun 04/07/2024 to Sat 04/27/2024
0700 Continuous 1530

Work scheduled by: NYPA

CENTRAL EAST - VC

FWD (Import)

REV (Export)

2450 MW

Impacts Total Transfer Capability

270 MW

TTC with All Lines In Service

2720 MW

NIAGARA_-DYSINGER_345_ND1

Mon 04/08/2024 to Fri 04/12/2024
0500 Continuous 1900

Work scheduled by: NYPA

DYSINGER EAST

FWD (Import)

REV (Export)

2700 MW

Impacts Total Transfer Capability

500 MW

TTC with All Lines In Service

3200 MW

LINDN_-CG-LNDVFT__345_V-3022

Mon 04/08/2024 to Sat 04/13/2024
0800 Continuous 1500

Work scheduled by: PJM

SCH - PJM_VFT

FWD (Import)

REV (Export)

0 MW

0 MW

Impacts Total Transfer Capability

315 MW

315 MW

TTC with All Lines In Service

315 MW

315 MW

NIAGARA_-DYSINGER_345_ND2

Mon 04/15/2024 to Fri 04/19/2024
0500 Continuous 1900

Work scheduled by: NYPA

DYSINGER EAST

FWD (Import)

REV (Export)

2700 MW

Impacts Total Transfer Capability

500 MW

TTC with All Lines In Service

3200 MW

GOETHALS_345KV_5

Thu 04/18/2024 to Thu 04/18/2024
0001 Continuous 0030

Work scheduled by: ConEd

STATEN ISLAND

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

TTC with All Lines In Service

LINDEN_-GOETHALS_230_A2253

Thu 04/18/2024 to Thu 04/25/2024
0001 Continuous 0200

Work scheduled by: ConEd

SCH - PJ - NY

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

TTC with All Lines In Service

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Monday, September 25, 2023 to Monday, March 24, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LINDN_CG-LNDVFT__345_V-3022

Thu 04/18/2024 to Thu 04/18/2024
1500 Continuous 1800
Work scheduled by: PJM

	FWD (Import)	REV (Export)
SCH - PJM_VFT	0 MW	0 MW
Impacts Total Transfer Capability	315 MW	315 MW
TTC with All Lines In Service	315 MW	315 MW

PANNELL_-CLAY__345_1

Mon 04/22/2024 to Fri 04/26/2024
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
WEST CENTRAL	1300 MW	
Impacts Total Transfer Capability	950 MW	
TTC with All Lines In Service	2250 MW	

GOETHALS_345KV_5

Thu 04/25/2024 to Thu 04/25/2024
0130 Continuous 0200
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
STATEN ISLAND		
Impacts Total Transfer Capability		
TTC with All Lines In Service		

DYSINGER-STA_255_345_DH1

Fri 04/26/2024 to Tue 05/07/2024
0500 Continuous 1900
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
DYSINGER EAST	2850 MW	
Impacts Total Transfer Capability	350 MW	
TTC with All Lines In Service	3200 MW	

FRASANNX-COOPERS_345_UCC2-41

Mon 04/29/2024 to Tue 07/16/2024
0700 Continuous 1530
Work scheduled by: NYPA

ARR: 19

	FWD (Import)	REV (Export)
CENTRAL EAST - VC	2275 MW	
Impacts Total Transfer Capability	445 MW	
TTC with All Lines In Service	2720 MW	

MARCY_-FRASANNX_345_UCC2-41

Mon 04/29/2024 to Tue 07/16/2024
0700 Continuous 1530
Work scheduled by: NYPA

ARR: 19

	FWD (Import)	REV (Export)
CENTRAL EAST - VC	2275 MW	
Impacts Total Transfer Capability	445 MW	
TTC with All Lines In Service	2720 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Monday, September 25, 2023 to Monday, March 24, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PANNELL -CLAY___345_2

Mon 04/29/2024 to Fri 05/03/2024
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
WEST CENTRAL	1300 MW	
Impacts Total Transfer Capability	950 MW	
TTC with All Lines In Service	2250 MW	

SHOR_NPX-SHOREHAM_138_CSC

Mon 05/06/2024 to Fri 05/10/2024
0600 Continuous 1800
Work scheduled by: LI

	FWD (Import)	REV (Export)
SCH - NPX_CSC	0 MW	0 MW
Impacts Total Transfer Capability	330 MW	330 MW
TTC with All Lines In Service	330 MW	330 MW

FITZPTRK-EDIC___345_FE-1

Mon 05/20/2024 to Fri 05/24/2024
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
OSWEGO EXPORT	4800 MW	
Impacts Total Transfer Capability	450 MW	
TTC with All Lines In Service	5250 MW	

FITZPTRK-EDIC___345_FE-1

Mon 05/20/2024 to Fri 05/24/2024
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
CENTRAL EAST - VC	2480 MW	
Impacts Total Transfer Capability	240 MW	
TTC with All Lines In Service	2720 MW	

FITZPTRK-EDIC___345_FE-1

Tue 05/28/2024 to Fri 05/31/2024
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
OSWEGO EXPORT	4800 MW	
Impacts Total Transfer Capability	450 MW	
TTC with All Lines In Service	5250 MW	

FITZPTRK-EDIC___345_FE-1

Tue 05/28/2024 to Fri 05/31/2024
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
CENTRAL EAST - VC	2480 MW	
Impacts Total Transfer Capability	240 MW	
TTC with All Lines In Service	2720 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Monday, September 25, 2023 to Monday, March 24, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BECK__-PACKARD__230_BP76

Fri 05/31/2024 to Fri 05/31/2024
0730 Continuous 1630

Work scheduled by: NGrid

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

1600 MW

450 MW

2050 MW

REV (Export)

1050 MW

600 MW

1650 MW

CHASLAKE-PORTER__230_11

Sat 06/01/2024 to Wed 07/03/2024
0530 Continuous 1600

Work scheduled by: NGrid

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

2100 MW

1050 MW

3150 MW

REV (Export)

NIAGARA__345_230_AT4

Tue 06/11/2024 to Wed 06/12/2024
0500 Continuous 1900

Work scheduled by: NYPA

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

1200 MW

450 MW

1650 MW

CHASLAKE-PORTER__230_11

Mon 07/08/2024 to Fri 08/30/2024
0700 Continuous 1900

Work scheduled by: NGrid

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

2100 MW

1050 MW

3150 MW

REV (Export)

MOSES__-ADIRNDCK__230_MA2

Mon 09/02/2024 to Mon 09/02/2024
0700 Continuous 1730

Work scheduled by: NYPA

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

2100 MW

1050 MW

3150 MW

REV (Export)

CHASLAKE-PORTER__230_11

Tue 09/03/2024 to Fri 11/15/2024
0530 Continuous 2000

Work scheduled by: NGrid

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

2100 MW

1050 MW

3150 MW

REV (Export)

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Monday, September 25, 2023 to Monday, March 24, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ROCHESTR-PANNELL_345_RP1

Mon 09/09/2024 to Fri 09/13/2024
0700 Continuous 1530
Work scheduled by: NYPA

DYSINGER EAST **2300 MW**
Impacts Total Transfer Capability 900 MW
TTC with All Lines In Service 3200 MW

ROCHESTR-PANNELL_345_RP2

Mon 09/16/2024 to Fri 09/20/2024
0700 Continuous 1530
Work scheduled by: NYPA

DYSINGER EAST **2300 MW**
Impacts Total Transfer Capability 900 MW
TTC with All Lines In Service 3200 MW

PANNELL-CLAY_345_1

Mon 09/23/2024 to Fri 09/27/2024
0700 Continuous 1530
Work scheduled by: NYPA

WEST CENTRAL **1300 MW**
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

FITZPTRK-EDIC_345_FE-1

Mon 09/30/2024 to Fri 10/04/2024
1700 Continuous 1530
Work scheduled by: NYPA

OSWEGO EXPORT **4800 MW**
Impacts Total Transfer Capability 450 MW
TTC with All Lines In Service 5250 MW

FITZPTRK-EDIC_345_FE-1

Mon 09/30/2024 to Fri 10/04/2024
1700 Continuous 1530
Work scheduled by: NYPA

CENTRAL EAST - VC **2480 MW**
Impacts Total Transfer Capability 240 MW
TTC with All Lines In Service 2720 MW

BECK_-NIAGARA_345_PA302

Mon 10/07/2024 to Fri 10/11/2024
0500 Continuous 1900
Work scheduled by: NYPA

SCH - OH - NY **1000 MW** **850 MW**
Impacts Total Transfer Capability 1050 MW 800 MW
TTC with All Lines In Service 2050 MW 1650 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Monday, September 25, 2023 to Monday, March 24, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEPTUNE_DUFFYAVE_345_NEPTUNE

Mon 10/07/2024 to Fri 10/11/2024
0600 Continuous 1600
Work scheduled by: LI

SCH - PJM_NEPTUNE
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
0 MW	
660 MW	
660 MW	

NEWBRDGE_345_138_BK_1

Mon 10/07/2024 to Fri 10/11/2024
0600 Continuous 1600
Work scheduled by: LI

SCH - PJM_NEPTUNE
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
375 MW	
285 MW	
660 MW	

NEWBRDGE_345_138_BK_2

Mon 10/07/2024 to Fri 10/11/2024
0600 Continuous 1600
Work scheduled by: LI

SCH - PJM_NEPTUNE
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
375 MW	
285 MW	
660 MW	

NEWBRDGE-DUFFYAVE_345_501

Mon 10/07/2024 to Fri 10/11/2024
0600 Continuous 1600
Work scheduled by: LI

SCH - PJM_NEPTUNE
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
0 MW	
660 MW	
660 MW	

SHOR_NPX-SHOREHAM_138_CSC

Mon 10/07/2024 to Fri 10/11/2024
0600 Continuous 1800
Work scheduled by: LI

SCH - NPX_CSC
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
0 MW	0 MW
330 MW	330 MW
330 MW	330 MW

GILBOA_-N.SCTLND_345_GNS-1

Mon 10/07/2024 to Fri 10/11/2024
0700 Continuous 1530
Work scheduled by: NYPA

CENTRAL EAST - VC
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
2300 MW	
420 MW	
2720 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Monday, September 25, 2023 to Monday, March 24, 2025

CENTRAL EAST 2650 MW
CENTRAL EAST - VC 2720 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FRASANNX-COOPERS_345_UCC2-41

Wed 10/09/2024 to Thu 10/10/2024
0700 Continuous 1530

ARR: 19

FWD (Import) REV (Export)

CENTRAL EAST - VC 2275 MW
Impacts Total Transfer Capability 445 MW
TTC with All Lines In Service 2720 MW

Work scheduled by: NYPA

MARCY_-FRASANNX_345_UCC2-41

Wed 10/09/2024 to Thu 10/10/2024
0700 Continuous 1530

ARR: 19

FWD (Import) REV (Export)

CENTRAL EAST - VC 2275 MW
Impacts Total Transfer Capability 445 MW
TTC with All Lines In Service 2720 MW

Work scheduled by: NYPA

MARCY_-N.SCTLND_345_18

Tue 10/15/2024 to Thu 10/17/2024
0700 Continuous 1530

ARR: 19

FWD (Import) REV (Export)

CENTRAL EAST - VC 1345 MW
Impacts Total Transfer Capability 1375 MW
TTC with All Lines In Service 2720 MW

Work scheduled by: NYPA

MARCY_-N.SCTLND_345_18

Mon 10/21/2024 to Fri 10/25/2024
0700 Continuous 1530

ARR: 19

FWD (Import) REV (Export)

CENTRAL EAST - VC 1345 MW
Impacts Total Transfer Capability 1375 MW
TTC with All Lines In Service 2720 MW

Work scheduled by: NYPA

COOPERS_-MIDDLETP_345_CCRT34

Sun 10/27/2024 to Sat 11/02/2024
0700 Continuous 1530

FWD (Import) REV (Export)

CENTRAL EAST - VC 2485 MW
Impacts Total Transfer Capability 235 MW
TTC with All Lines In Service 2720 MW

Work scheduled by: NYPA

MARCY_345KV_CSC

Mon 10/28/2024 to Sun 11/10/2024
0700 Continuous 1530

FWD (Import) REV (Export)

CENTRAL EAST - VC 2650 MW
Impacts Total Transfer Capability 70 MW
TTC with All Lines In Service 2720 MW

Work scheduled by: NYPA

NYISO TRANSFER LIMITATIONS

Seasonal Limits Monday, September 25, 2023 to Monday, March 24, 2025

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2720 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BECK__-NIAGARA__230_PA27				FWD (Import)	REV (Export)
Fri 11/15/2024	to	Fri 11/15/2024	SCH - OH - NY	2100 MW	
0500	Continuous	1900	Impacts Total Transfer Capability	300 MW	
Work scheduled by: NYPA			TTC with All Lines In Service	2400 MW	
ADIRNDCK-PORTER__230_12				FWD (Import)	REV (Export)
Sun 12/01/2024	to	Sat 05/31/2025	MOSES SOUTH	2300 MW	
0530	Continuous	1700	Impacts Total Transfer Capability	850 MW	
Work scheduled by: NGrid			TTC with All Lines In Service	3150 MW	