

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, October 11, 2023 to Thursday, April 10, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE\_345KV\_10\_BYPASS , DUNWODIE\_345KV\_9\_BYPASS ,  
SPRNBK\_345KV\_R4S3\_BYPASS , SPRNBK\_345KV\_R5S3\_BYPASS  
Sun 02/01/2015 to Sat 02/01/2025  
0000 0000  
Work scheduled by:

SPR/DUN-SOUTH FWD (Import) REV (Export)  
**4350 MW**  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 4600 MW

DUNWODIE\_345KV\_10\_BYPASS , DUNWODIE\_345KV\_9\_BYPASS ,  
SPRNBK\_345KV\_R4S3\_BYPASS , SPRNBK\_345KV\_R5S3\_BYPASS  
Sun 02/01/2015 to Sat 02/01/2025  
0000 0000  
Work scheduled by:

UPNY CONED FWD (Import) REV (Export)  
**7505 MW**  
Impacts Total Transfer Capability 545 MW  
TTC with All Lines In Service 8050 MW

HUDSONP\_-FARRAGUT\_345\_B3402  
Mon 01/15/2018 to Sun 12/31/2023  
0001 Continuous 2359 EXT FORCED by ConEd 09/21/2023 10:34  
Work scheduled by: ConEd

SCH - PJ - NY FWD (Import) REV (Export)  
Impacts Total Transfer Capability  
TTC with All Lines In Service

MARION\_-FARRAGUT\_345\_C3403  
Mon 01/15/2018 to Sun 12/31/2023  
0001 Continuous 2359 EXT FORCED by ConEd 09/21/2023 10:34  
Work scheduled by: ConEd

SCH - PJ - NY FWD (Import) REV (Export)  
Impacts Total Transfer Capability  
TTC with All Lines In Service

MARION\_-FARRAGUT\_345\_C3403 , HUDSONP\_-  
FARRAGUT\_345\_B3402  
Mon 01/15/2018 to Sun 12/31/2023  
0001 2359  
Work scheduled by:

SCH - PJ - NY FWD (Import) REV (Export)  
**2200 MW**  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 2250 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, October 11, 2023 to Thursday, April 10, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### STLAWRNC-MOSES\_\_230\_L34P

Mon 10/03/2022 to Mon 11/06/2023  
1800 Continuous 0800  
Work scheduled by: IESO

UPDATED by IESO 03/07/2023 10:12

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### SCH-NYISO-IMO\_LIMIT\_1300

Mon 06/26/2023 to Tue 10/31/2023  
0001 Continuous 2359  
Work scheduled by: IESO

UPDATED by IESO 08/20/2023 08:38

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1600 MW**  
50 MW  
1650 MW

### SCH-IMO-NYISO\_LIMIT\_1600

Wed 06/28/2023 to Tue 10/31/2023  
1801 Continuous 2359  
Work scheduled by: IESO

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1900 MW**  
150 MW  
2050 MW

### MARCY\_SO\_SERIES\_COMP\_I/S

Tue 08/22/2023 to Mon 10/16/2023  
0001 Continuous 0559  
Work scheduled by: NYSEG

EXTENDED by NYSEG 06/29/2023 14:33

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**2450 MW**  
270 MW  
2720 MW

### SCH-NYISO-HQ\_CEDARS\_LIMIT\_0

Tue 09/05/2023 to Thu 11/16/2023  
0700 Continuous 1800  
Work scheduled by: HQ

EXTENDED by HQ 10/11/2023 11:47

SCH - HQ\_CEDARS  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**0 MW**  
100 MW  
100 MW

### ADIRNDCK-CHASLAKE\_230\_13

Fri 09/08/2023 to Sat 10/21/2023  
0700 Continuous 1600  
Work scheduled by: NGrid

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**2100 MW**  
1050 MW  
3150 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, October 11, 2023 to Thursday, April 10, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-IMO-NYISO\_LIMIT\_1450

Fri 09/08/2023 to Sat 10/21/2023  
0700 Continuous 1600

UPDATED by IESO 08/20/2023 08:38

SCH - OH - NY

FWD (Import)

REV (Export)

**1750 MW**

Impacts Total Transfer Capability

300 MW

TTC with All Lines In Service

2050 MW

Work scheduled by: IESO

### HOMRC\_NY-MAINS\_NY\_345\_47

Fri 09/08/2023 to Thu 11/30/2023  
1612 Continuous 1600

FORCED by PJM 09/09/2023 07:29

SCH - PJ - NY

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: PJM

### SCH-HQ\_CEDARS-NYISO\_LIMIT\_200

Mon 09/11/2023 to Thu 11/16/2023  
0001 Continuous 1800

EXTENDED by HQ 10/11/2023 11:47

SCH - HQ\_CEDARS

FWD (Import)

REV (Export)

**200 MW**

Impacts Total Transfer Capability

70 MW

TTC with All Lines In Service

270 MW

Work scheduled by: HQ

### SPRNBK\_345KV\_RNS5

Fri 09/15/2023 to Sun 10/29/2023  
0001 Continuous 0259

EXTENDED by ConEd 10/06/2023 11:07

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

**3200 MW**

Impacts Total Transfer Capability

1400 MW

TTC with All Lines In Service

4600 MW

Work scheduled by: ConEd

### SPRNBK-W49TH\_ST\_345\_M51

Fri 09/15/2023 to Sun 10/29/2023  
0001 Continuous 0259

EXTENDED by ConEd 10/06/2023 11:07

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

**3200 MW**

Impacts Total Transfer Capability

1400 MW

TTC with All Lines In Service

4600 MW

Work scheduled by: ConEd

### SCH-IMO-NYISO\_NIAG\_CB\_3008\_W/BB

Tue 09/19/2023 to Sat 11/18/2023  
2001 Continuous 0459

UPDATED by NYPA 08/01/2023 08:11

SCH - OH - NY

FWD (Import)

REV (Export)

**1200 MW**

Impacts Total Transfer Capability

450 MW

TTC with All Lines In Service

1650 MW

Work scheduled by: NYPA

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, October 11, 2023 to Thursday, April 10, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### ROSETON\_EFISHKIL\_345\_RFK305

Mon 09/25/2023 to Fri 10/13/2023

0700 Continuous 1730

Work scheduled by: NYPA

UPDATED by ConEd 08/31/2023 13:41

UPNY CONED

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**7215 MW**

835 MW

8050 MW

### DYSINGER-STA\_255\_345\_DH2

Mon 10/02/2023 to Wed 10/11/2023

0500 Continuous 0853

Work scheduled by: NYPA

UPDATED by NYPA 10/11/2023 09:02

DYSINGER EAST

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**2850 MW**

350 MW

3200 MW

### SHOR\_NPX-SHOREHAM\_138\_CSC

Mon 10/02/2023 to Fri 10/13/2023

0600 Continuous 2159

Work scheduled by: LI

EXTENDED by LI 10/11/2023 15:06

SCH - NPX\_CSC

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**0 MW**

330 MW

330 MW

**0 MW**

330 MW

330 MW

### DUNWODIE\_345KV\_4

Wed 10/04/2023 to Fri 11/10/2023

0001 Continuous 2200

Work scheduled by: ConEd

SPR/DUN-SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**3800 MW**

800 MW

4600 MW

### BEAR SWP-EASTOVER\_230\_E205W

Mon 10/09/2023 to Wed 11/15/2023

0600 Continuous 1500

Work scheduled by: ISONE

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

### SCH-NYISO-NE\_LIMIT\_1200

Mon 10/09/2023 to Tue 10/31/2023

0600 Continuous 2359

Work scheduled by: ISONE

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**1400 MW**

200 MW

1600 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, October 11, 2023 to Thursday, April 10, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### OAKDALE\_FRASER\_\_345\_32

Mon 10/09/2023 to Wed 10/11/2023  
0900 Continuous 1500

Work scheduled by: NYSEG

CENTRAL EAST - VC  
FWD (Import) **2450 MW**  
REV (Export)  
Impacts Total Transfer Capability 270 MW  
TTC with All Lines In Service 2720 MW

### SCH-NYISO-NE\_LIMIT\_900

Tue 10/10/2023 to Wed 10/11/2023  
2300 Daily 0659

Work scheduled by: ISONE

CANCELLED by NYISO 10/08/2023 16:39

SCH - NE - NY  
FWD (Import) **1100 MW**  
REV (Export)  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1600 MW

### HUDSONP\_FARRAGUT\_345\_B3402 , LINDEN\_-GOETHALS\_230\_A2253

Wed 10/11/2023 to Wed 10/11/2023  
0200 2300

Work scheduled by:

SCH - PJ - NY  
FWD (Import) **2200 MW**  
REV (Export)  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 2250 MW

### LINDEN\_-GOETHALS\_230\_A2253

Wed 10/11/2023 to Wed 10/11/2023  
0200 Continuous 2300

Work scheduled by: ConEd

SCH - PJ - NY  
FWD (Import) **2200 MW**  
REV (Export)  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 2250 MW

### MARION\_FARRAGUT\_345\_C3403 , HUDSONP\_FARRAGUT\_345\_B3402 , LINDEN\_-GOETHALS\_230\_A2253

Wed 10/11/2023 to Wed 10/11/2023  
0200 2300

Work scheduled by:

SCH - PJ - NY  
FWD (Import) **2200 MW**  
REV (Export)  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 2250 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, October 11, 2023 to Thursday, April 10, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MARION\_-FARRAGUT\_345\_C3403 , LINDEN\_-GOETHALS\_230\_A2253

Wed 10/11/2023 to Wed 10/11/2023  
0200 2300

Work scheduled by:

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**2200 MW**

50 MW

2250 MW

### ELBRIDGE-LAFAYTTE\_345\_17-LE

Wed 10/11/2023 to Thu 10/12/2023  
0700 Continuous 1600

Work scheduled by: NGrid

EXTENDED by NGrid 10/11/2023 16:20

ARR: 75

OSWEGO EXPORT

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**5250 MW**

0 MW

5250 MW

### OSWEGO\_-ELBRIDGE\_345\_17

Wed 10/11/2023 to Fri 10/27/2023  
0700 Continuous 2100

Work scheduled by: NGrid

EXTENDED by NGrid 10/11/2023 16:20

ARR: 75

OSWEGO EXPORT

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**5250 MW**

0 MW

5250 MW

### SCH-NE-NYISO\_LIMIT\_800

Wed 10/11/2023 to Wed 10/11/2023  
0700 Daily 2259

Work scheduled by: ISONE

CANCELLED by NYISO 10/08/2023 16:39

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**1000 MW**

400 MW

1400 MW

### DENNISON-ROSEMNTA\_115\_1/11

Wed 10/11/2023 to Wed 10/11/2023  
0830 Continuous 1030

Work scheduled by: NGrid

SCH - HQ\_CEDARS

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**95 MW**

175 MW

270 MW

**40 MW**

60 MW

100 MW

### CEDARS\_-ROSEMNTA\_115\_1/11

Wed 10/11/2023 to Wed 10/11/2023  
0900 Continuous 1000

Work scheduled by: HQ

SCH - HQ\_CEDARS

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**95 MW**

175 MW

270 MW

**40 MW**

60 MW

100 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, October 11, 2023 to Thursday, April 10, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-HQ\_CEDARS-NYISO\_LIMIT\_60

Wed 10/11/2023 to Wed 10/11/2023  
0900 Continuous 1000  
Work scheduled by: HQ

SCH - HQ\_CEDARS  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **60 MW**  
210 MW  
270 MW

### SCH-NYISO-NE\_LIMIT\_900

Wed 10/11/2023 to Thu 10/12/2023  
2300 Daily 0659  
Work scheduled by: ISONE  
CANCELLED by NYISO 10/08/2023 16:39

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **1100 MW**  
500 MW  
1600 MW

### SCH-NE-NYISO\_LIMIT\_800

Thu 10/12/2023 to Thu 10/12/2023  
0700 Daily 2259  
Work scheduled by: ISONE  
CANCELLED by NYISO 10/08/2023 16:39

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **1000 MW**  
400 MW  
1400 MW

### SCH-NYISO-NE\_LIMIT\_900

Thu 10/12/2023 to Fri 10/13/2023  
2300 Daily 0659  
Work scheduled by: ISONE  
CANCELLED by NYISO 10/08/2023 16:39

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **1100 MW**  
500 MW  
1600 MW

### NIAGARA\_PACKARD\_230\_61

Fri 10/13/2023 to Fri 10/13/2023  
0500 Continuous 1900  
Work scheduled by: NYPA

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **1900 MW** **1450 MW**  
150 MW 200 MW  
2050 MW 1650 MW

### SCH-NE-NYISO\_LIMIT\_800

Fri 10/13/2023 to Fri 10/13/2023  
0700 Daily 2259  
Work scheduled by: ISONE  
CANCELLED by NYISO 10/08/2023 16:39

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **1000 MW**  
400 MW  
1400 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, October 11, 2023 to Thursday, April 10, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SHOR\_NPX-SHOREHAM\_138\_CSC

Fri 10/13/2023 to Fri 10/20/2023  
2200 Continuous 2159

FORCED by LI 10/11/2023 15:28

SCH - NPX\_CSC

FWD (Import)

REV (Export)

**0 MW**

**0 MW**

Impacts Total Transfer Capability

330 MW

330 MW

TTC with All Lines In Service

330 MW

330 MW

### SCH-NYISO-NE\_LIMIT\_900

Fri 10/13/2023 to Sat 10/14/2023  
2300 Daily 0659

CANCELLED by NYISO 10/08/2023 16:39

SCH - NE - NY

FWD (Import)

REV (Export)

**1100 MW**

Impacts Total Transfer Capability

500 MW

TTC with All Lines In Service

1600 MW

### DYSINGER-STA\_255\_345\_DH1

Sat 10/14/2023 to Tue 10/24/2023  
0500 Continuous 1900

DYSINGER EAST

FWD (Import)

REV (Export)

**2850 MW**

Impacts Total Transfer Capability

350 MW

TTC with All Lines In Service

3200 MW

### SCH-NE-NYISO\_LIMIT\_800

Sat 10/14/2023 to Sat 10/14/2023  
0700 Daily 2259

CANCELLED by NYISO 10/08/2023 16:39

SCH - NE - NY

FWD (Import)

REV (Export)

**1000 MW**

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

1400 MW

### SCH-NYISO-NE\_LIMIT\_900

Sat 10/14/2023 to Sun 10/15/2023  
2300 Daily 0659

CANCELLED by NYISO 10/08/2023 16:39

SCH - NE - NY

FWD (Import)

REV (Export)

**1100 MW**

Impacts Total Transfer Capability

500 MW

TTC with All Lines In Service

1600 MW

### CHAT\_DC\_GC1

Sun 10/15/2023 to Sun 10/15/2023  
0001 Continuous 0200

MOSES SOUTH

FWD (Import)

REV (Export)

**2850 MW**

Impacts Total Transfer Capability

300 MW

TTC with All Lines In Service

3150 MW

Work scheduled by: HQ



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, October 11, 2023 to Thursday, April 10, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### CHAT\_DC\_GC1

Sun 10/15/2023 to Sun 10/15/2023  
0001 Continuous 0200  
Work scheduled by: HQ

SCH - HQ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**500 MW**  
500 MW  
1000 MW

### CHAT\_DC\_GC1 , CHAT\_DC\_GC2

Sun 10/15/2023 to Sun 10/15/2023  
0001 0200  
Work scheduled by:

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**2550 MW**  
600 MW  
3150 MW

### CHAT\_DC\_GC1 , CHAT\_DC\_GC2

Sun 10/15/2023 to Sun 10/15/2023  
0001 0200  
Work scheduled by:

SCH - HQ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1370 MW** **0 MW**  
130 MW 1000 MW  
1500 MW 1000 MW

### CHAT\_DC\_GC2

Sun 10/15/2023 to Sun 10/15/2023  
0001 Continuous 0200  
Work scheduled by: HQ

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**2850 MW**  
300 MW  
3150 MW

### CHAT\_DC\_GC2

Sun 10/15/2023 to Sun 10/15/2023  
0001 Continuous 0200  
Work scheduled by: HQ

SCH - HQ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**500 MW**  
500 MW  
1000 MW

### SCH-HQ-NYISO\_LIMIT\_1150

Sun 10/15/2023 to Sun 10/15/2023  
0001 Continuous 0200  
Work scheduled by: HQ

SCH - HQ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1150 MW**  
350 MW  
1500 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, October 11, 2023 to Thursday, April 10, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### CHAT\_DC\_GC1

Sun 10/15/2023 to Mon 11/27/2023  
0400 Continuous 2200  
Work scheduled by: HQ

FWD (Import) REV (Export)  
MOSES SOUTH **2850 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

### CHAT\_DC\_GC1

Sun 10/15/2023 to Mon 11/27/2023  
0400 Continuous 2200  
Work scheduled by: HQ

FWD (Import) REV (Export)  
SCH - HQ - NY **500 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1000 MW

### SCH-NE-NYISO\_LIMIT\_800

Sun 10/15/2023 to Sun 10/15/2023  
0700 Daily 2259  
Work scheduled by: ISONE  
CANCELLED by NYISO 10/08/2023 16:39

FWD (Import) REV (Export)  
SCH - NE - NY **1000 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 1400 MW

### SCH-NYISO-NE\_LIMIT\_900

Sun 10/15/2023 to Mon 10/16/2023  
2300 Daily 0659  
Work scheduled by: ISONE  
CANCELLED by NYISO 10/08/2023 16:39

FWD (Import) REV (Export)  
SCH - NE - NY **1100 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1600 MW

### LADENTWN-BUCHAN\_S\_345\_Y88

Mon 10/16/2023 to Mon 11/06/2023  
0201 Continuous 0200  
Work scheduled by: ConEd  
UPDATED by ConEd 06/16/2023 08:29

FWD (Import) REV (Export)  
UPNY CONED **7695 MW**  
Impacts Total Transfer Capability 355 MW  
TTC with All Lines In Service 8050 MW

### SCH-NYISO-HQ\_LIMIT\_300

Mon 10/16/2023 to Fri 10/27/2023  
0500 Continuous 2000  
Work scheduled by: HQ

FWD (Import) REV (Export)  
SCH - HQ - NY **300 MW**  
Impacts Total Transfer Capability 700 MW  
TTC with All Lines In Service 1000 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, October 11, 2023 to Thursday, April 10, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### FRASANNX-COOPERS\_345\_UCC2-41

Mon 10/16/2023 to Fri 10/27/2023  
0600 Continuous 1730

ARR: 19

FWD (Import) REV (Export)

CENTRAL EAST - VC **2275 MW**  
Impacts Total Transfer Capability 445 MW  
TTC with All Lines In Service 2720 MW

Work scheduled by: NYPA

### MARCY\_\_FRASANNX\_345\_UCC2-41

Mon 10/16/2023 to Fri 10/27/2023  
0600 Continuous 1730

ARR: 19

FWD (Import) REV (Export)

CENTRAL EAST - VC **2275 MW**  
Impacts Total Transfer Capability 445 MW  
TTC with All Lines In Service 2720 MW

Work scheduled by: NYPA

### SCH-HQ-NYISO\_LIMIT\_1400

Mon 10/16/2023 to Fri 10/27/2023  
0600 Continuous 1730

FWD (Import) REV (Export)

SCH - HQ - NY **1400 MW**  
Impacts Total Transfer Capability 100 MW  
TTC with All Lines In Service 1500 MW

Work scheduled by: HQ

### SCH-NE-NYISO\_LIMIT\_800

Mon 10/16/2023 to Mon 10/16/2023  
0700 Daily 2259

CANCELLED by NYISO 10/08/2023 16:39

FWD (Import) REV (Export)

SCH - NE - NY **1000 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 1400 MW

Work scheduled by: ISONE

### SCH-NYISO-NE\_LIMIT\_900

Mon 10/16/2023 to Tue 10/17/2023  
2300 Daily 0659

CANCELLED by NYISO 10/08/2023 16:39

FWD (Import) REV (Export)

SCH - NE - NY **1100 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1600 MW

Work scheduled by: ISONE

### EGRDNCTY\_345\_138\_AT1

Tue 10/17/2023 to Wed 10/18/2023  
0001 Continuous 2359

FWD (Import) REV (Export)

CONED - LIPA **1250 MW**  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 1500 MW

Work scheduled by: LI

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, October 11, 2023 to Thursday, April 10, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_800

Tue 10/17/2023 to Tue 10/17/2023  
0700 Daily 2259

CANCELLED by NYISO 10/08/2023 16:39

SCH - NE - NY

FWD (Import)

REV (Export)

**1000 MW**

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

1400 MW

Work scheduled by: ISONE

### SCH-NYISO-NE\_LIMIT\_900

Tue 10/17/2023 to Wed 10/18/2023  
2300 Daily 0659

CANCELLED by NYISO 10/08/2023 16:39

SCH - NE - NY

FWD (Import)

REV (Export)

**1100 MW**

Impacts Total Transfer Capability

500 MW

TTC with All Lines In Service

1600 MW

Work scheduled by: ISONE

### SCH-NE-NYISO\_LIMIT\_800

Wed 10/18/2023 to Wed 10/18/2023  
0700 Daily 2259

CANCELLED by NYISO 10/08/2023 16:39

SCH - NE - NY

FWD (Import)

REV (Export)

**1000 MW**

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

1400 MW

Work scheduled by: ISONE

### SCH-NYISO-NE\_LIMIT\_900

Wed 10/18/2023 to Thu 10/19/2023  
2300 Daily 0659

CANCELLED by NYISO 10/08/2023 16:39

SCH - NE - NY

FWD (Import)

REV (Export)

**1100 MW**

Impacts Total Transfer Capability

500 MW

TTC with All Lines In Service

1600 MW

Work scheduled by: ISONE

### EGRDNCTY\_345\_138\_AT2

Thu 10/19/2023 to Fri 10/20/2023  
0001 Continuous 2359

CONED - LIPA

FWD (Import)

REV (Export)

**1250 MW**

Impacts Total Transfer Capability

250 MW

TTC with All Lines In Service

1500 MW

Work scheduled by: LI

### SCH-NE-NYISO\_LIMIT\_800

Thu 10/19/2023 to Thu 10/19/2023  
0700 Daily 2259

CANCELLED by NYISO 10/08/2023 16:39

SCH - NE - NY

FWD (Import)

REV (Export)

**1000 MW**

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

1400 MW

Work scheduled by: ISONE

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, October 11, 2023 to Thursday, April 10, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_900

Thu 10/19/2023 to Mon 10/30/2023  
0830 Continuous 0900  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 1100 MW  
REV (Export) 300 MW  
1400 MW

### SCH-NYISO-NE\_LIMIT\_900

Thu 10/19/2023 to Fri 10/20/2023  
2300 Daily 0659  
Work scheduled by: ISONE  
CANCELLED by NYISO 10/08/2023 16:39

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 1100 MW  
REV (Export) 500 MW  
1600 MW

### MOSES\_\_-ADIRNDCK\_230\_MA2

Fri 10/20/2023 to Fri 10/20/2023  
0700 Continuous 1730  
Work scheduled by: NYPA  
UPDATED by NYPA 10/10/2023 12:33

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 2100 MW  
REV (Export) 1050 MW  
3150 MW

### SCH-NE-NYISO\_LIMIT\_800

Fri 10/20/2023 to Fri 10/20/2023  
0700 Daily 2259  
Work scheduled by: ISONE  
CANCELLED by NYISO 10/08/2023 16:39

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 1000 MW  
REV (Export) 400 MW  
1400 MW

### DENNISON-ROSEMNTA\_115\_1/11

Fri 10/20/2023 to Fri 10/20/2023  
0830 Continuous 1030  
Work scheduled by: NGrid

SCH - HQ\_CEDARS  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 95 MW  
REV (Export) 40 MW  
175 MW  
60 MW  
270 MW  
100 MW

### SCH-NYISO-NE\_LIMIT\_900

Fri 10/20/2023 to Sat 10/21/2023  
2300 Daily 0659  
Work scheduled by: ISONE  
CANCELLED by NYISO 10/08/2023 16:39

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 1100 MW  
REV (Export) 500 MW  
1600 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, October 11, 2023 to Thursday, April 10, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_800

Sat 10/21/2023 to Sat 10/21/2023  
0700 Daily 2259

CANCELLED by NYISO 10/08/2023 16:39

SCH - NE - NY

FWD (Import)

REV (Export)

**1000 MW**

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

1400 MW

Work scheduled by: ISONE

### SCH-NYISO-NE\_LIMIT\_900

Sat 10/21/2023 to Sun 10/22/2023  
2300 Daily 0659

CANCELLED by NYISO 10/08/2023 16:39

SCH - NE - NY

FWD (Import)

REV (Export)

**1100 MW**

Impacts Total Transfer Capability

500 MW

TTC with All Lines In Service

1600 MW

Work scheduled by: ISONE

### CHAT\_DC\_GC1 , CHAT\_DC\_GC2

Sun 10/22/2023 to Sun 10/22/2023  
0001 0200

MOSES SOUTH

FWD (Import)

REV (Export)

**2550 MW**

Impacts Total Transfer Capability

600 MW

TTC with All Lines In Service

3150 MW

Work scheduled by:

### CHAT\_DC\_GC1 , CHAT\_DC\_GC2

Sun 10/22/2023 to Sun 10/22/2023  
0001 0200

SCH - HQ - NY

FWD (Import)

REV (Export)

**1370 MW**

**0 MW**

Impacts Total Transfer Capability

130 MW

1000 MW

TTC with All Lines In Service

1500 MW

1000 MW

Work scheduled by:

### CHAT\_DC\_GC2

Sun 10/22/2023 to Sun 10/22/2023  
0001 Continuous 0200

MOSES SOUTH

FWD (Import)

REV (Export)

**2850 MW**

Impacts Total Transfer Capability

300 MW

TTC with All Lines In Service

3150 MW

Work scheduled by: HQ

### CHAT\_DC\_GC2

Sun 10/22/2023 to Sun 10/22/2023  
0001 Continuous 0200

SCH - HQ - NY

FWD (Import)

REV (Export)

**500 MW**

Impacts Total Transfer Capability

500 MW

TTC with All Lines In Service

1000 MW

Work scheduled by: HQ

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, October 11, 2023 to Thursday, April 10, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-HQ-NYISO\_LIMIT\_1150

Sun 10/22/2023 to Sun 10/22/2023  
0001 Continuous 0200

Work scheduled by: HQ

SCH - HQ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**1150 MW**

350 MW

1500 MW

### CHASLAKE-PORTER\_\_230\_11

Sun 10/22/2023 to Tue 11/14/2023  
0630 Continuous 1730

Work scheduled by: NGrid

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**2100 MW**

1050 MW

3150 MW

### SCH-IMO-NYISO\_LIMIT\_1450

Sun 10/22/2023 to Tue 10/31/2023  
0630 Continuous 2359

Work scheduled by: IESO

UPDATED by IESO 08/20/2023 08:38

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**1750 MW**

300 MW

2050 MW

### SCH-NE-NYISO\_LIMIT\_800

Sun 10/22/2023 to Sun 10/22/2023  
0700 Daily 2259

Work scheduled by: ISONE

CANCELLED by NYISO 10/08/2023 16:39

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**1000 MW**

400 MW

1400 MW

### SCH-NYISO-NE\_LIMIT\_900

Sun 10/22/2023 to Mon 10/23/2023  
2300 Daily 0659

Work scheduled by: ISONE

CANCELLED by NYISO 10/08/2023 16:39

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**1100 MW**

500 MW

1600 MW

### DUNWODIE\_345KV\_6

Mon 10/23/2023 to Thu 11/09/2023  
0001 Continuous 2200

Work scheduled by: ConEd

SPR/DUN-SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**3800 MW**

800 MW

4600 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, October 11, 2023 to Thursday, April 10, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### DUNWODIE-SHORE\_RD\_345\_Y50

Mon 10/23/2023 to Thu 11/09/2023  
0001 Continuous 2200  
Work scheduled by: ConEd

CONED - LIPA FWD (Import) REV (Export)  
800 MW  
Impacts Total Transfer Capability 700 MW  
TTC with All Lines In Service 1500 MW

### SHORE\_RD\_345\_138\_BK 1

Mon 10/23/2023 to Thu 11/09/2023  
0001 Continuous 2200  
Work scheduled by: ConEd

CONED - LIPA FWD (Import) REV (Export)  
1350 MW  
Impacts Total Transfer Capability 150 MW  
TTC with All Lines In Service 1500 MW

### SHORE\_RD\_345\_138\_BK 2

Mon 10/23/2023 to Thu 11/09/2023  
0001 Continuous 2200  
Work scheduled by: ConEd

CONED - LIPA FWD (Import) REV (Export)  
1350 MW  
Impacts Total Transfer Capability 150 MW  
TTC with All Lines In Service 1500 MW

### MOSES\_\_-ADIRNDCK\_230\_MA1

Mon 10/23/2023 to Mon 10/30/2023  
0700 Continuous 1530  
Work scheduled by: NYPA

UPDATED by NYPA 10/06/2023 13:04

MOSES SOUTH FWD (Import) REV (Export)  
2100 MW  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

### SCH-NE-NYISO\_LIMIT\_800

Mon 10/23/2023 to Mon 10/23/2023  
0700 Daily 2259  
Work scheduled by: ISONE

CANCELLED by NYISO 10/08/2023 16:39

SCH - NE - NY FWD (Import) REV (Export)  
1000 MW  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 1400 MW

### SCH-NYISO-NE\_LIMIT\_900

Mon 10/23/2023 to Tue 10/24/2023  
2300 Daily 0659  
Work scheduled by: ISONE

CANCELLED by NYISO 10/08/2023 16:39

SCH - NE - NY FWD (Import) REV (Export)  
1100 MW  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1600 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, October 11, 2023 to Thursday, April 10, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_800

Tue 10/24/2023 to Tue 10/24/2023  
0700 Daily 2259

CANCELLED by NYISO 10/08/2023 16:39

SCH - NE - NY

FWD (Import)

REV (Export)

**1000 MW**

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

1400 MW

Work scheduled by: ISONE

### SCH-NYISO-NE\_LIMIT\_900

Tue 10/24/2023 to Wed 10/25/2023  
2300 Daily 0659

CANCELLED by NYISO 10/08/2023 16:39

SCH - NE - NY

FWD (Import)

REV (Export)

**1100 MW**

Impacts Total Transfer Capability

500 MW

TTC with All Lines In Service

1600 MW

Work scheduled by: ISONE

### SCH-NE-NYISO\_LIMIT\_800

Wed 10/25/2023 to Wed 10/25/2023  
0700 Daily 2259

CANCELLED by NYISO 10/08/2023 16:39

SCH - NE - NY

FWD (Import)

REV (Export)

**1000 MW**

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

1400 MW

Work scheduled by: ISONE

### SCH-NYISO-NE\_LIMIT\_900

Wed 10/25/2023 to Thu 10/26/2023  
2300 Daily 0659

CANCELLED by NYISO 10/08/2023 16:39

SCH - NE - NY

FWD (Import)

REV (Export)

**1100 MW**

Impacts Total Transfer Capability

500 MW

TTC with All Lines In Service

1600 MW

Work scheduled by: ISONE

### E13THSTA-FARRAGUT\_345\_45

Thu 10/26/2023 to Thu 10/26/2023  
0001 Continuous 0030

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

**3800 MW**

Impacts Total Transfer Capability

800 MW

TTC with All Lines In Service

4600 MW

Work scheduled by: ConEd

### SCH-NE-NYISO\_LIMIT\_800

Thu 10/26/2023 to Thu 10/26/2023  
0700 Daily 2259

CANCELLED by NYISO 10/08/2023 16:39

SCH - NE - NY

FWD (Import)

REV (Export)

**1000 MW**

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

1400 MW

Work scheduled by: ISONE

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, October 11, 2023 to Thursday, April 10, 2025

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2720 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>NRTH1385-NOR HBR_138_601</b>				FWD (Import)	REV (Export)
Thu 10/26/2023	to	Thu 10/26/2023	SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
0800	Continuous	2359	Impacts Total Transfer Capability	100 MW	100 MW
Work scheduled by: LI				TTC with All Lines In Service	200 MW
<b>NRTH1385-NOR HBR_138_602</b>				FWD (Import)	REV (Export)
Thu 10/26/2023	to	Thu 10/26/2023	SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
0800	Continuous	2359	Impacts Total Transfer Capability	100 MW	100 MW
Work scheduled by: LI				TTC with All Lines In Service	200 MW
<b>NRTH1385-NOR HBR_138_603</b>				FWD (Import)	REV (Export)
Thu 10/26/2023	to	Thu 10/26/2023	SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
0800	Continuous	2359	Impacts Total Transfer Capability	100 MW	100 MW
Work scheduled by: LI				TTC with All Lines In Service	200 MW
<b>NRTH1385-NORHBR_138_602 , NRTH1385-NORHBR_138_601</b>				FWD (Import)	REV (Export)
Thu 10/26/2023	to	Thu 10/26/2023	SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
0800		2359	Impacts Total Transfer Capability	200 MW	200 MW
Work scheduled by:				TTC with All Lines In Service	200 MW
<b>NRTH1385-NORHBR_138_603 , NRTH1385-NORHBR_138_601</b>				FWD (Import)	REV (Export)
Thu 10/26/2023	to	Thu 10/26/2023	SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
0800		2359	Impacts Total Transfer Capability	200 MW	200 MW
Work scheduled by:				TTC with All Lines In Service	200 MW
<b>NRTH1385-NORHBR_138_603 , NRTH1385-NORHBR_138_602</b>				FWD (Import)	REV (Export)
Thu 10/26/2023	to	Thu 10/26/2023	SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
0800		2359	Impacts Total Transfer Capability	200 MW	200 MW
Work scheduled by:				TTC with All Lines In Service	200 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, October 11, 2023 to Thursday, April 10, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### NRTH1385-NRTHPORT\_138\_NNC

Thu 10/26/2023 to Thu 10/26/2023  
0800 Continuous 2359

Work scheduled by: LI

SCH - NPX\_1385

FWD (Import)

REV (Export)

0 MW

0 MW

Impacts Total Transfer Capability

200 MW

200 MW

TTC with All Lines In Service

200 MW

200 MW

### SCH-NYISO-NE\_LIMIT\_900

Thu 10/26/2023 to Fri 10/27/2023  
2300 Daily 0659

Work scheduled by: ISONE

CANCELLED by NYISO 10/08/2023 16:39

SCH - NE - NY

FWD (Import)

REV (Export)

1100 MW

Impacts Total Transfer Capability

500 MW

TTC with All Lines In Service

1600 MW

### SCH-NE-NYISO\_LIMIT\_800

Fri 10/27/2023 to Fri 10/27/2023  
0700 Daily 2259

Work scheduled by: ISONE

CANCELLED by NYISO 10/08/2023 16:39

SCH - NE - NY

FWD (Import)

REV (Export)

1000 MW

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

1400 MW

### ELBRIDGE-LAFAYTTE\_345\_17-LE

Fri 10/27/2023 to Fri 10/27/2023  
1800 Continuous 2100

Work scheduled by: NGrid

EXTENDED by NGrid 10/11/2023 16:20

ARR: 75

OSWEGO EXPORT

FWD (Import)

REV (Export)

5250 MW

Impacts Total Transfer Capability

0 MW

TTC with All Lines In Service

5250 MW

### LAFAYTTE-CLRKSCRN\_345\_4-46

Fri 10/27/2023 to Fri 10/27/2023  
1800 Continuous 2100

Work scheduled by: NGrid

EXTENDED by NGrid 10/11/2023 16:20

CENTRAL EAST - VC

FWD (Import)

REV (Export)

2450 MW

Impacts Total Transfer Capability

270 MW

TTC with All Lines In Service

2720 MW

### SCH-NYISO-NE\_LIMIT\_900

Fri 10/27/2023 to Sat 10/28/2023  
2300 Daily 0659

Work scheduled by: ISONE

CANCELLED by NYISO 10/08/2023 16:39

SCH - NE - NY

FWD (Import)

REV (Export)

1100 MW

Impacts Total Transfer Capability

500 MW

TTC with All Lines In Service

1600 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, October 11, 2023 to Thursday, April 10, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_800

Sat 10/28/2023 to Sat 10/28/2023  
0700 Daily 2259

CANCELLED by NYISO 10/08/2023 16:39

SCH - NE - NY

FWD (Import)

REV (Export)

**1000 MW**

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

1400 MW

Work scheduled by: ISONE

### SCH-NYISO-NE\_LIMIT\_900

Sat 10/28/2023 to Sun 10/29/2023  
2300 Daily 0659

CANCELLED by NYISO 10/08/2023 16:39

SCH - NE - NY

FWD (Import)

REV (Export)

**1100 MW**

Impacts Total Transfer Capability

500 MW

TTC with All Lines In Service

1600 MW

Work scheduled by: ISONE

### SCH-NE-NYISO\_LIMIT\_800

Sun 10/29/2023 to Sun 10/29/2023  
0700 Daily 2259

CANCELLED by NYISO 10/08/2023 16:39

SCH - NE - NY

FWD (Import)

REV (Export)

**1000 MW**

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

1400 MW

Work scheduled by: ISONE

### SCH-NYISO-NE\_LIMIT\_900

Sun 10/29/2023 to Mon 10/30/2023  
2300 Daily 0659

CANCELLED by NYISO 10/08/2023 16:39

SCH - NE - NY

FWD (Import)

REV (Export)

**1100 MW**

Impacts Total Transfer Capability

500 MW

TTC with All Lines In Service

1600 MW

Work scheduled by: ISONE

### SPRNBK\_-TREMONT\_345\_X28

Mon 10/30/2023 to Mon 10/30/2023  
0001 Continuous 0400

UPDATED by ConEd 08/01/2023 16:11

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

**4200 MW**

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

4600 MW

Work scheduled by: ConEd

### E13THSTA-FARRAGUT\_345\_45

Mon 10/30/2023 to Mon 10/30/2023  
0230 Continuous 0300

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

**3800 MW**

Impacts Total Transfer Capability

800 MW

TTC with All Lines In Service

4600 MW

Work scheduled by: ConEd

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, October 11, 2023 to Thursday, April 10, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_800

Mon 10/30/2023 to Mon 10/30/2023  
0700 Daily 2259

CANCELLED by NYISO 10/08/2023 16:39

SCH - NE - NY

FWD (Import)

REV (Export)

**1000 MW**

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

1400 MW

Work scheduled by: ISONE

### MOSES\_\_-ADIRNDCK\_230\_MA2

Mon 10/30/2023 to Wed 11/08/2023  
1600 Continuous 1730

UPDATED by NYPA 10/06/2023 13:10

MOSES SOUTH

FWD (Import)

REV (Export)

**2100 MW**

Impacts Total Transfer Capability

1050 MW

TTC with All Lines In Service

3150 MW

Work scheduled by: NYPA

### SCH-NYISO-NE\_LIMIT\_900

Mon 10/30/2023 to Tue 10/31/2023  
2300 Daily 0659

CANCELLED by NYISO 10/08/2023 16:39

SCH - NE - NY

FWD (Import)

REV (Export)

**1100 MW**

Impacts Total Transfer Capability

500 MW

TTC with All Lines In Service

1600 MW

Work scheduled by: ISONE

### SCH-NE-NYISO\_LIMIT\_800

Tue 10/31/2023 to Tue 10/31/2023  
0700 Daily 2259

CANCELLED by NYISO 10/08/2023 16:39

SCH - NE - NY

FWD (Import)

REV (Export)

**1000 MW**

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

1400 MW

Work scheduled by: ISONE

### SCH-NYISO-NE\_LIMIT\_900

Tue 10/31/2023 to Wed 11/01/2023  
2300 Daily 0659

CANCELLED by NYISO 10/08/2023 16:39

SCH - NE - NY

FWD (Import)

REV (Export)

**1100 MW**

Impacts Total Transfer Capability

500 MW

TTC with All Lines In Service

1600 MW

Work scheduled by: ISONE

### SCH-NE-NYISO\_LIMIT\_800

Wed 11/01/2023 to Wed 11/01/2023  
0700 Daily 2259

CANCELLED by NYISO 10/08/2023 16:39

SCH - NE - NY

FWD (Import)

REV (Export)

**1000 MW**

Impacts Total Transfer Capability

600 MW

TTC with All Lines In Service

1600 MW

Work scheduled by: ISONE

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, October 11, 2023 to Thursday, April 10, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### OSWEGO\_\_VOLNEY\_\_345\_12

Wed 11/01/2023 to Wed 11/01/2023  
0730 Daily 1630  
Work scheduled by: NGrid

FWD (Import) REV (Export)  
OSWEGO EXPORT **5250 MW**  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

### SPRNBK\_-TREMONT\_345\_X28

Wed 11/01/2023 to Wed 11/01/2023  
1730 Continuous 1800  
Work scheduled by: ConEd  
UPDATED by ConEd 08/01/2023 16:11

FWD (Import) REV (Export)  
SPR/DUN-SOUTH **4200 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 4600 MW

### SCH-NYISO-NE\_LIMIT\_900

Wed 11/01/2023 to Thu 11/02/2023  
2300 Daily 0659  
Work scheduled by: ISONE  
CANCELLED by NYISO 10/08/2023 16:39

FWD (Import) REV (Export)  
SCH - NE - NY **1100 MW**  
Impacts Total Transfer Capability 700 MW  
TTC with All Lines In Service 1800 MW

### SCH-NE-NYISO\_LIMIT\_800

Thu 11/02/2023 to Thu 11/02/2023  
0700 Daily 2259  
Work scheduled by: ISONE  
CANCELLED by NYISO 10/08/2023 16:39

FWD (Import) REV (Export)  
SCH - NE - NY **1000 MW**  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 1600 MW

### SCH-NYISO-NE\_LIMIT\_900

Thu 11/02/2023 to Fri 11/03/2023  
2300 Daily 0659  
Work scheduled by: ISONE  
CANCELLED by NYISO 10/08/2023 16:39

FWD (Import) REV (Export)  
SCH - NE - NY **1100 MW**  
Impacts Total Transfer Capability 700 MW  
TTC with All Lines In Service 1800 MW

### W49TH\_ST\_345KV\_5

Fri 11/03/2023 to Fri 11/03/2023  
0001 Continuous 0030  
Work scheduled by: ConEd

FWD (Import) REV (Export)  
SCH - PJM\_HTP **300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, October 11, 2023 to Thursday, April 10, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### W49TH\_ST\_345KV\_7

Fri 11/03/2023 to Fri 11/03/2023  
0001 Continuous 0030

Work scheduled by: ConEd

SCH - PJM\_HTP

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**300 MW**

360 MW

660 MW

### SCH-NE-NYISO\_LIMIT\_800

Fri 11/03/2023 to Fri 11/03/2023  
0700 Daily 2259

Work scheduled by: ISONE

CANCELLED by NYISO 10/08/2023 16:39

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**1000 MW**

600 MW

1600 MW

### SCH-NYISO-NE\_LIMIT\_900

Fri 11/03/2023 to Sat 11/04/2023  
2300 Daily 0659

Work scheduled by: ISONE

CANCELLED by NYISO 10/08/2023 16:39

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**1100 MW**

700 MW

1800 MW

### ROCHESTR-PANNELL\_345\_RP2

Sat 11/04/2023 to Tue 11/14/2023  
0500 Continuous 1900

Work scheduled by: NYPA

DYSINGER EAST

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**2300 MW**

900 MW

3200 MW

### SCH-NE-NYISO\_LIMIT\_800

Sat 11/04/2023 to Sat 11/04/2023  
0700 Daily 2259

Work scheduled by: ISONE

CANCELLED by NYISO 10/08/2023 16:39

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**1000 MW**

600 MW

1600 MW

### SCH-NYISO-NE\_LIMIT\_900

Sat 11/04/2023 to Sun 11/05/2023  
2300 Daily 0659

Work scheduled by: ISONE

CANCELLED by NYISO 10/08/2023 16:39

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**1100 MW**

700 MW

1800 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, October 11, 2023 to Thursday, April 10, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### W49TH\_ST\_345KV\_5

Sun 11/05/2023 to Sun 11/05/2023  
0030 Continuous 0059

Work scheduled by: ConEd

SCH - PJM\_HTP **300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

### W49TH\_ST\_345KV\_7

Sun 11/05/2023 to Sun 11/05/2023  
0030 Continuous 0059

Work scheduled by: ConEd

SCH - PJM\_HTP **300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

### SCH-NE-NYISO\_LIMIT\_800

Sun 11/05/2023 to Sun 11/05/2023  
0700 Daily 2259

Work scheduled by: ISONE

CANCELLED by NYISO 10/08/2023 16:39

SCH - NE - NY **1000 MW**  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 1600 MW

FWD (Import) REV (Export)

### SCH-NYISO-NE\_LIMIT\_900

Sun 11/05/2023 to Mon 11/06/2023  
2300 Daily 0659

Work scheduled by: ISONE

CANCELLED by NYISO 10/08/2023 16:39

SCH - NE - NY **1100 MW**  
Impacts Total Transfer Capability 700 MW  
TTC with All Lines In Service 1800 MW

FWD (Import) REV (Export)

### DUNWODIE\_345KV\_3

Mon 11/06/2023 to Thu 11/09/2023  
0201 Continuous 2200

Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

### NEPTUNE\_DUFFYAVE\_345\_NEPTUNE

Mon 11/06/2023 to Mon 11/20/2023  
0600 Continuous 2359

Work scheduled by: LI

UPDATED by LI 10/05/2023 09:19

SCH - PJM\_NEPTUNE **0 MW**  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, October 11, 2023 to Thursday, April 10, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### NEWBRDGE\_345\_138\_BK\_1

Mon 11/06/2023 to Mon 11/20/2023  
0600 Continuous 2359

UPDATED by LI 10/05/2023 09:19

SCH - PJM\_NEPTUNE

FWD (Import)

REV (Export)

**375 MW**

Impacts Total Transfer Capability

285 MW

TTC with All Lines In Service

660 MW

Work scheduled by: LI

### NEWBRDGE\_345\_138\_BK\_2

Mon 11/06/2023 to Mon 11/20/2023  
0600 Continuous 2359

UPDATED by LI 10/05/2023 09:19

SCH - PJM\_NEPTUNE

FWD (Import)

REV (Export)

**375 MW**

Impacts Total Transfer Capability

285 MW

TTC with All Lines In Service

660 MW

Work scheduled by: LI

### NEWBRDGE-DUFFYAVE\_345\_501

Mon 11/06/2023 to Mon 11/20/2023  
0600 Continuous 2359

UPDATED by LI 10/05/2023 09:19

SCH - PJM\_NEPTUNE

FWD (Import)

REV (Export)

**0 MW**

Impacts Total Transfer Capability

660 MW

TTC with All Lines In Service

660 MW

Work scheduled by: LI

### SCH-NE-NYISO\_LIMIT\_800

Mon 11/06/2023 to Mon 11/06/2023  
0700 Daily 1530

CANCELLED by NYISO 10/08/2023 16:39

SCH - NE - NY

FWD (Import)

REV (Export)

**1000 MW**

Impacts Total Transfer Capability

600 MW

TTC with All Lines In Service

1600 MW

Work scheduled by: ISONE

### LINDN\_CG-LNDVFT\_\_345\_V-3022

Mon 11/06/2023 to Thu 11/09/2023  
0800 Continuous 1500

SCH - PJM\_VFT

FWD (Import)

REV (Export)

**0 MW**

**0 MW**

Impacts Total Transfer Capability

315 MW

315 MW

TTC with All Lines In Service

315 MW

315 MW

Work scheduled by: PJM

### PANNELL\_-CLAY\_\_345\_2

Thu 11/09/2023 to Mon 11/13/2023  
0600 Continuous 1800

WEST CENTRAL

FWD (Import)

REV (Export)

**1300 MW**

Impacts Total Transfer Capability

950 MW

TTC with All Lines In Service

2250 MW

Work scheduled by: NYPA

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, October 11, 2023 to Thursday, April 10, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### DUNWODIE-SHORE\_RD\_345\_Y50

Fri 11/10/2023 to Tue 11/14/2023  
0700 Continuous 2100  
Work scheduled by: LI

CONED - LIPA **800 MW**  
Impacts Total Transfer Capability 700 MW  
TTC with All Lines In Service 1500 MW

FWD (Import) REV (Export)

### SHORE\_RD\_345\_138\_BK 1

Fri 11/10/2023 to Tue 11/14/2023  
0700 Continuous 2100  
Work scheduled by: LI

CONED - LIPA **1350 MW**  
Impacts Total Transfer Capability 150 MW  
TTC with All Lines In Service 1500 MW

FWD (Import) REV (Export)

### SHORE\_RD\_345\_138\_BK 2

Fri 11/10/2023 to Tue 11/14/2023  
0700 Continuous 2100  
Work scheduled by: LI

CONED - LIPA **1350 MW**  
Impacts Total Transfer Capability 150 MW  
TTC with All Lines In Service 1500 MW

FWD (Import) REV (Export)

### RAMAPO\_-BUCHAN\_N\_345\_Y94

Tue 11/14/2023 to Thu 12/21/2023  
0201 Continuous 0200  
Work scheduled by: ConEd

UPNY CONED **7755 MW**  
Impacts Total Transfer Capability 295 MW  
TTC with All Lines In Service 8050 MW

FWD (Import) REV (Export)

### GORDONRD-ROTTDAM\_230\_31

Tue 11/14/2023 to Thu 11/16/2023  
0830 Continuous 1430  
Work scheduled by: NGrid

CENTRAL EAST - VC **2695 MW**  
Impacts Total Transfer Capability 25 MW  
TTC with All Lines In Service 2720 MW

FWD (Import) REV (Export)

### CHATGUAY-MASSENA\_765\_7040

Wed 11/15/2023 to Mon 11/27/2023  
0001 Continuous 1730  
Work scheduled by: NYPA

UPDATED by NYPA 10/06/2023 08:23

SCH - HQ - NY **0 MW** **0 MW**  
Impacts Total Transfer Capability 1500 MW 1000 MW  
TTC with All Lines In Service 1500 MW 1000 MW

FWD (Import) REV (Export)

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, October 11, 2023 to Thursday, April 10, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### CHATGUAY-MASSENA\_765\_7040

Wed 11/15/2023 to Mon 11/27/2023  
0001 Continuous 1730

UPDATED by NYPA 10/06/2023 08:23

MOSES SOUTH

FWD (Import)

REV (Export)

**1550 MW**

Impacts Total Transfer Capability

1600 MW

TTC with All Lines In Service

3150 MW

Work scheduled by: NYPA

### CHATGUAY-MASSENA\_765\_7040 , MASSENA-MARCY\_765\_MSU1

Wed 11/15/2023 to Mon 11/27/2023  
0001 1730

MOSES SOUTH

FWD (Import)

REV (Export)

**500 MW**

Impacts Total Transfer Capability

2650 MW

TTC with All Lines In Service

3150 MW

Work scheduled by:

### MARCY\_765\_345\_AT1

Wed 11/15/2023 to Mon 11/27/2023  
0001 Continuous 1730

UPDATED by NYPA 10/06/2023 08:23

MOSES SOUTH

FWD (Import)

REV (Export)

**1750 MW**

Impacts Total Transfer Capability

1400 MW

TTC with All Lines In Service

3150 MW

Work scheduled by: NYPA

ARR: 19

### MARCY\_765\_345\_AT2

Wed 11/15/2023 to Mon 11/27/2023  
0001 Continuous 1730

MOSES SOUTH

FWD (Import)

REV (Export)

**1700 MW**

Impacts Total Transfer Capability

1450 MW

TTC with All Lines In Service

3150 MW

Work scheduled by: NYPA

ARR: 19

### MASSENA-MARCY\_765\_MSU1

Wed 11/15/2023 to Mon 11/27/2023  
0001 Continuous 1730

UPDATED by NYPA 10/06/2023 08:23

CENTRAL EAST - VC

FWD (Import)

REV (Export)

**1720 MW**

Impacts Total Transfer Capability

1000 MW

TTC with All Lines In Service

2720 MW

Work scheduled by: NYPA

### MASSENA-MARCY\_765\_MSU1

Wed 11/15/2023 to Mon 11/27/2023  
0001 Continuous 1730

UPDATED by NYPA 10/06/2023 08:23

SCH - HQ\_CEDARS

FWD (Import)

REV (Export)

**90 MW**

Impacts Total Transfer Capability

189 MW

TTC with All Lines In Service

279 MW

Work scheduled by: NYPA

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, October 11, 2023 to Thursday, April 10, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MASSENA\_-MARCY\_\_\_765\_MSU1

Wed 11/15/2023 to Mon 11/27/2023

0001 Continuous 1730

Work scheduled by: NYPA

UPDATED by NYPA 10/06/2023 08:23

SCH - HQ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**475 MW**

**1000 MW**

1025 MW

0 MW

1500 MW

1000 MW

### MASSENA\_-MARCY\_\_\_765\_MSU1

Wed 11/15/2023 to Mon 11/27/2023

0001 Continuous 1730

Work scheduled by: NYPA

UPDATED by NYPA 10/06/2023 08:23

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**500 MW**

2650 MW

3150 MW

### MOSES\_-MASSENA\_230\_MMS1 , MOSES\_-MASSENA\_230\_MMS2

Wed 11/15/2023 to Mon 11/27/2023

0001 1730

Work scheduled by:

SCH - HQ\_CEDARS

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**90 MW**

189 MW

279 MW

### MOSES\_-MASSENA\_230\_MMS1 , MOSES\_-MASSENA\_230\_MMS2

Wed 11/15/2023 to Mon 11/27/2023

0001 1730

Work scheduled by:

SCH - HQ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**850 MW**

**0 MW**

650 MW

1000 MW

1500 MW

1000 MW

### LINDN\_CG-LNDVFT\_\_\_345\_V-3022

Wed 11/15/2023 to Wed 11/15/2023

1500 Continuous 1700

Work scheduled by: PJM

SCH - PJM\_VFT

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**0 MW**

**0 MW**

315 MW

315 MW

315 MW

315 MW

### SCH-NYISO-IMO\_NIAGARA\_NORTH\_BUS

Sat 11/18/2023 to Sun 11/19/2023

0500 Continuous 2200

Work scheduled by: NYPA

UPDATED by NYPA 08/03/2023 12:04

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**1100 MW**

**950 MW**

1300 MW

1050 MW

2400 MW

2000 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, October 11, 2023 to Thursday, April 10, 2025

CENTRAL EAST 2650 MW  
 CENTRAL EAST - VC 2720 MW  
 TOTAL EAST 6150 MW  
 UPNY CONED 8050 MW  
 SPR/DUN-SOUTH 4600 MW  
 DYSINGER EAST 3200 MW  
 MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### BECK\_\_-NIAGARA\_345\_PA301

Sat 11/25/2023 to Sun 11/26/2023  
 0500 Continuous 2200

UPDATED by NYPA 08/04/2023 13:08

SCH - OH - NY

FWD (Import)

REV (Export)

**1100 MW**

**950 MW**

Impacts Total Transfer Capability

1300 MW

1050 MW

TTC with All Lines In Service

2400 MW

2000 MW

Work scheduled by: NYPA

### GILBOA\_-N.SCTLND\_345\_GNS-1

Mon 11/27/2023 to Fri 12/01/2023  
 0700 Continuous 1530

CENTRAL EAST - VC

FWD (Import)

REV (Export)

**2300 MW**

Impacts Total Transfer Capability

420 MW

TTC with All Lines In Service

2720 MW

Work scheduled by: NYPA

### OSWEGO\_-VOLNEY\_\_345\_11

Tue 11/28/2023 to Fri 12/15/2023  
 0730 Continuous 1630

OSWEGO EXPORT

FWD (Import)

REV (Export)

**5250 MW**

Impacts Total Transfer Capability

0 MW

TTC with All Lines In Service

5250 MW

Work scheduled by: NGrid

### ADIRNDCK-PORTER\_\_230\_12

Fri 12/01/2023 to Fri 12/22/2023  
 0530 Continuous 1700

UPDATED by NGrid 07/11/2023 11:44

MOSES SOUTH

FWD (Import)

REV (Export)

**2300 MW**

Impacts Total Transfer Capability

850 MW

TTC with All Lines In Service

3150 MW

Work scheduled by: NGrid

### KNICRBKR-PLSNTVLY\_345\_Y57

Mon 12/04/2023 to Wed 12/06/2023  
 0400 Continuous 1700

ARR: 78

UPNY CONED

FWD (Import)

REV (Export)

**7885 MW**

Impacts Total Transfer Capability

165 MW

TTC with All Lines In Service

8050 MW

Work scheduled by: NGrid

### NIAGARA\_345\_230\_AT4

Mon 12/04/2023 to Fri 12/08/2023  
 0500 Continuous 1900

UPDATED by NYPA 03/21/2023 14:25

SCH - OH - NY

FWD (Import)

REV (Export)

**1650 MW**

Impacts Total Transfer Capability

350 MW

TTC with All Lines In Service

2000 MW

Work scheduled by: NYPA

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, October 11, 2023 to Thursday, April 10, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### LEEDS\_\_345\_LEEDS SVC

Mon 12/04/2023 to Thu 12/07/2023  
0730 Continuous 1700

Work scheduled by: NGrid

CENTRAL EAST - VC

FWD (Import)

REV (Export)

**2700 MW**

Impacts Total Transfer Capability

20 MW

TTC with All Lines In Service

2720 MW

### HOMR\_NYW-PIERC\_NY\_345\_48

Mon 12/04/2023 to Fri 12/08/2023  
0800 Continuous 1600

Work scheduled by: PJM

SCH - PJ - NY

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

TTC with All Lines In Service

### S.RIPLEY-DUNKIRK\_230\_68

Mon 12/04/2023 to Fri 12/08/2023  
0800 Continuous 1600

Work scheduled by: PJM

SCH - PJ - NY

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

TTC with All Lines In Service

### BERKSHIR-ALPS\_\_345\_393

Tue 12/05/2023 to Sun 12/10/2023  
0630 Continuous 1800

Work scheduled by: NGrid

ARR: 78

SCH - NPX\_1385

FWD (Import)

REV (Export)

**100 MW**

**100 MW**

Impacts Total Transfer Capability

100 MW

100 MW

TTC with All Lines In Service

200 MW

200 MW

### BERKSHIR-ALPS\_\_345\_393

Tue 12/05/2023 to Sun 12/10/2023  
0630 Continuous 1800

Work scheduled by: NGrid

ARR: 78

SCH - NE - NY

FWD (Import)

REV (Export)

**1100 MW**

**1700 MW**

Impacts Total Transfer Capability

500 MW

100 MW

TTC with All Lines In Service

1600 MW

1800 MW

### CLAY\_\_-EDIC\_\_345\_2-15

Tue 12/05/2023 to Thu 12/07/2023  
0700 Continuous 1630

Work scheduled by: NGrid

OSWEGO EXPORT

FWD (Import)

REV (Export)

**4850 MW**

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

5250 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, October 11, 2023 to Thursday, April 10, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### BERKSHIR-ALPS\_\_\_345\_393 , BERKSHIR-NORTHFLD\_345\_312

Tue 12/05/2023 to Sun 12/10/2023  
0800 1800

ARR: 78

SCH - NE - NY

FWD (Import)

REV (Export)

**1100 MW**

**1100 MW**

Impacts Total Transfer Capability

500 MW

700 MW

TTC with All Lines In Service

1600 MW

1800 MW

### BERKSHIR-NORTHFLD\_345\_312

Tue 12/05/2023 to Sun 12/10/2023  
0800 Continuous 1800

FWD (Import)

REV (Export)

**100 MW**

**100 MW**

SCH - NPX\_1385

Impacts Total Transfer Capability

100 MW

100 MW

TTC with All Lines In Service

200 MW

200 MW

### BERKSHIR-NORTHFLD\_345\_312

Tue 12/05/2023 to Sun 12/10/2023  
0800 Continuous 1800

FWD (Import)

REV (Export)

**1300 MW**

SCH - NE - NY

Impacts Total Transfer Capability

300 MW

TTC with All Lines In Service

1600 MW

### EDIC\_\_\_-GORDONRD\_345\_14

Wed 12/13/2023 to Wed 12/13/2023  
0730 Continuous 1600

FWD (Import)

REV (Export)

**1670 MW**

CENTRAL EAST - VC

Impacts Total Transfer Capability

1050 MW

TTC with All Lines In Service

2720 MW

### E13THSTA-FARRAGUT\_345\_46

Sat 12/23/2023 to Mon 12/25/2023  
0001 Continuous 0300

UPDATED by ConEd 09/18/2023 08:57

FWD (Import)

REV (Export)

**3800 MW**

SPR/DUN-SOUTH

Impacts Total Transfer Capability

800 MW

TTC with All Lines In Service

4600 MW

### S.RIPLEY-DUNKIRK\_230\_68

Wed 12/27/2023 to Fri 12/29/2023  
0730 Continuous 1600

FWD (Import)

REV (Export)

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: NGrid

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, October 11, 2023 to Thursday, April 10, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### WOOD\_ST\_PLSNTVLE\_345\_Y87

Fri 12/29/2023 to Sun 12/31/2023  
2200 Continuous 0259  
Work scheduled by: ConEd

UPNY CONED  
Impacts Total Transfer Capability 7470 MW  
TTC with All Lines In Service 580 MW  
8050 MW

### ADIRNDCK-PORTER\_\_230\_12

Tue 01/02/2024 to Fri 05/31/2024  
0630 Continuous 1730  
Work scheduled by: NGrid

UPDATED by NGrid 07/11/2023 11:44

MOSES SOUTH  
Impacts Total Transfer Capability 2300 MW  
TTC with All Lines In Service 850 MW  
3150 MW

### FRASER\_\_345\_FRASER SVC

Tue 01/02/2024 to Fri 03/01/2024  
0700 Continuous 1530  
Work scheduled by: NYPA

CENTRAL EAST - VC  
Impacts Total Transfer Capability 2690 MW  
TTC with All Lines In Service 30 MW  
2720 MW

### BECK\_\_PACKARD\_230\_BP76

Mon 01/15/2024 to Fri 01/19/2024  
0400 Continuous 1700  
Work scheduled by: NGrid

SCH - OH - NY  
Impacts Total Transfer Capability 1800 MW  
TTC with All Lines In Service 600 MW  
2400 MW  
1350 MW  
650 MW  
2000 MW

### SCH-IMO\_NY\_NIAG\_NRTH\_BUS\_W/BB

Fri 01/26/2024 to Fri 01/26/2024  
0500 Continuous 1900  
Work scheduled by: NYPA

SCH - OH - NY  
Impacts Total Transfer Capability 1550 MW  
TTC with All Lines In Service 850 MW  
2400 MW  
1450 MW  
550 MW  
2000 MW

### E13THSTA-FARRAGUT\_345\_46

Tue 01/30/2024 to Sun 02/04/2024  
0700 Continuous 0300  
Work scheduled by: ConEd

UPDATED by ConEd 09/18/2023 08:57

SPR/DUN-SOUTH  
Impacts Total Transfer Capability 3800 MW  
TTC with All Lines In Service 800 MW  
4600 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, October 11, 2023 to Thursday, April 10, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MOTTHAVN-RAINEY\_\_345\_Q12

Thu 02/01/2024 to Sat 03/02/2024  
0001 Continuous 0200  
Work scheduled by: ConEd

SPR/DUN-SOUTH FWD (Import) REV (Export)  
**3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

### MILLWOOD-EASTVIEW\_345\_W82

Mon 02/05/2024 to Wed 02/14/2024  
0001 Continuous 2200  
Work scheduled by: ConEd

UPNY CONED FWD (Import) REV (Export)  
**7810 MW**  
Impacts Total Transfer Capability 240 MW  
TTC with All Lines In Service 8050 MW

### CLAY\_\_EDIC\_\_345\_2-15

Mon 02/05/2024 to Mon 03/11/2024  
0700 Continuous 1600  
Work scheduled by: NGrid

OSWEGO EXPORT FWD (Import) REV (Export)  
**4850 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

### SCH-IMO\_NY\_NIAG\_SOUTH\_BUS\_W/BB

Fri 02/09/2024 to Fri 02/09/2024  
0500 Continuous 1900  
Work scheduled by: NYPA

SCH - OH - NY FWD (Import) REV (Export)  
**1550 MW 1450 MW**  
Impacts Total Transfer Capability 850 MW 550 MW  
TTC with All Lines In Service 2400 MW 2000 MW

### MILLWOOD-EASTVIEW\_345\_W85

Thu 02/15/2024 to Sat 02/17/2024  
0001 Continuous 0200  
Work scheduled by: ConEd

UPNY CONED FWD (Import) REV (Export)  
**7810 MW**  
Impacts Total Transfer Capability 240 MW  
TTC with All Lines In Service 8050 MW

### NIAGARA\_PACKARD\_230\_62

Fri 02/16/2024 to Fri 02/16/2024  
0500 Continuous 1900  
Work scheduled by: NYPA

SCH - OH - NY FWD (Import) REV (Export)  
**1750 MW 1850 MW**  
Impacts Total Transfer Capability 650 MW 150 MW  
TTC with All Lines In Service 2400 MW 2000 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, October 11, 2023 to Thursday, April 10, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### BECK\_\_-PACKARD\_230\_BP76

Mon 03/04/2024 to Fri 05/24/2024

0800 Continuous 1600

Work scheduled by: NGrid

SCH - OH - NY

FWD (Import)

REV (Export)

**1800 MW**

**1350 MW**

Impacts Total Transfer Capability

600 MW

650 MW

TTC with All Lines In Service

2400 MW

2000 MW

### CLAY\_\_-EDIC\_345\_1-16

Mon 03/18/2024 to Mon 04/22/2024

0700 Continuous 1600

Work scheduled by: NGrid

OSWEGO EXPORT

FWD (Import)

REV (Export)

**4850 MW**

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

5250 MW

### DOLSONAV-ROCKTVRN\_345\_DART44

Mon 03/18/2024 to Fri 03/29/2024

0700 Continuous 1600

Work scheduled by: CHGE

CENTRAL EAST - VC

FWD (Import)

REV (Export)

**2485 MW**

Impacts Total Transfer Capability

235 MW

TTC with All Lines In Service

2720 MW

### MILLWOOD-EASTVIEW\_345\_W85

Fri 03/22/2024 to Thu 03/28/2024

0201 Continuous 0200

Work scheduled by: ConEd

UPNY CONED

FWD (Import)

REV (Export)

**7810 MW**

Impacts Total Transfer Capability

240 MW

TTC with All Lines In Service

8050 MW

### SPRNBK\_345KV\_RNS3

Fri 03/22/2024 to Fri 03/22/2024

0201 Continuous 0230

Work scheduled by: ConEd

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

**3800 MW**

Impacts Total Transfer Capability

800 MW

TTC with All Lines In Service

4600 MW

### LADENTWN-BUCHAN\_S\_345\_Y88

Mon 04/01/2024 to Fri 05/17/2024

0001 Continuous 2359

Work scheduled by: ConEd

UPNY CONED

FWD (Import)

REV (Export)

**7695 MW**

Impacts Total Transfer Capability

355 MW

TTC with All Lines In Service

8050 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, October 11, 2023 to Thursday, April 10, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### FRASER\_-GILBOA\_345\_GF5-35

Sun 04/07/2024 to Sat 04/27/2024  
0700 Continuous 1530  
Work scheduled by: NYPA

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) 2450 MW  
270 MW  
2720 MW

### NIAGARA\_-DYSINGER\_345\_ND1

Mon 04/08/2024 to Fri 04/12/2024  
0500 Continuous 1900  
Work scheduled by: NYPA

DYSINGER EAST  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) 2700 MW  
500 MW  
3200 MW

### LINDN\_CG-LNDVFT\_345\_V-3022

Mon 04/08/2024 to Sat 04/13/2024  
0800 Continuous 1500  
Work scheduled by: PJM

SCH - PJM\_VFT  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) 0 MW  
315 MW  
315 MW

### NIAGARA\_-DYSINGER\_345\_ND2

Mon 04/15/2024 to Fri 04/19/2024  
0500 Continuous 1900  
Work scheduled by: NYPA

DYSINGER EAST  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) 2700 MW  
500 MW  
3200 MW

### GOETHALS\_345KV\_5

Thu 04/18/2024 to Thu 04/18/2024  
0001 Continuous 0030  
Work scheduled by: ConEd

STATEN ISLAND  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### LINDEN\_-GOETHALS\_230\_A2253

Thu 04/18/2024 to Thu 04/25/2024  
0001 Continuous 0200  
Work scheduled by: ConEd

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, October 11, 2023 to Thursday, April 10, 2025

CENTRAL EAST 2650 MW  
 CENTRAL EAST - VC 2720 MW  
 TOTAL EAST 6150 MW  
 UPNY CONED 8050 MW  
 SPR/DUN-SOUTH 4600 MW  
 DYSINGER EAST 3200 MW  
 MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### LINDN\_CG-LNDVFT\_\_345\_V-3022

Thu 04/18/2024 to Thu 04/18/2024  
 1500 Continuous 1800  
 Work scheduled by: PJM

	FWD (Import)	REV (Export)
SCH - PJM_VFT	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	315 MW	315 MW
TTC with All Lines In Service	315 MW	315 MW

### PANNELL\_-CLAY\_\_345\_1

Mon 04/22/2024 to Fri 04/26/2024  
 0700 Continuous 1530  
 Work scheduled by: NYPA

	FWD (Import)	REV (Export)
WEST CENTRAL	<b>1300 MW</b>	
Impacts Total Transfer Capability	950 MW	
TTC with All Lines In Service	2250 MW	

### GOETHALS\_345KV\_5

Thu 04/25/2024 to Thu 04/25/2024  
 0130 Continuous 0200  
 Work scheduled by: ConEd

	FWD (Import)	REV (Export)
STATEN ISLAND		
Impacts Total Transfer Capability		
TTC with All Lines In Service		

### DYSINGER-STA\_255\_345\_DH1

Fri 04/26/2024 to Tue 05/07/2024  
 0500 Continuous 1900  
 Work scheduled by: NYPA

	FWD (Import)	REV (Export)
DYSINGER EAST	<b>2850 MW</b>	
Impacts Total Transfer Capability	350 MW	
TTC with All Lines In Service	3200 MW	

### FRASANNX-COOPERS\_345\_UCC2-41

Mon 04/29/2024 to Tue 07/16/2024  
 0700 Continuous 1530  
 Work scheduled by: NYPA

ARR: 19

	FWD (Import)	REV (Export)
CENTRAL EAST - VC	<b>2275 MW</b>	
Impacts Total Transfer Capability	445 MW	
TTC with All Lines In Service	2720 MW	

### MARCY\_-FRASANNX\_345\_UCC2-41

Mon 04/29/2024 to Tue 07/16/2024  
 0700 Continuous 1530  
 Work scheduled by: NYPA

ARR: 19

	FWD (Import)	REV (Export)
CENTRAL EAST - VC	<b>2275 MW</b>	
Impacts Total Transfer Capability	445 MW	
TTC with All Lines In Service	2720 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, October 11, 2023 to Thursday, April 10, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### PANNELL\_-CLAY\_\_\_345\_2

Mon 04/29/2024 to Fri 05/03/2024  
0700 Continuous 1530  
Work scheduled by: NYPA

WEST CENTRAL  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 1300 MW  
950 MW  
2250 MW

### SHOR\_NPX-SHOREHAM\_138\_CSC

Mon 05/06/2024 to Fri 05/10/2024  
0600 Continuous 1800  
Work scheduled by: LI

SCH - NPX\_CSC  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 0 MW  
330 MW  
330 MW  
REV (Export) 0 MW  
330 MW  
330 MW

### FITZPTRK-EDIC\_\_\_345\_FE-1

Mon 05/20/2024 to Fri 05/24/2024  
0700 Continuous 1530  
Work scheduled by: NYPA

OSWEGO EXPORT  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 4800 MW  
450 MW  
5250 MW

### FITZPTRK-EDIC\_\_\_345\_FE-1

Mon 05/20/2024 to Fri 05/24/2024  
0700 Continuous 1530  
Work scheduled by: NYPA

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 2480 MW  
240 MW  
2720 MW  
REV (Export)

### FITZPTRK-EDIC\_\_\_345\_FE-1

Tue 05/28/2024 to Fri 05/31/2024  
0700 Continuous 1530  
Work scheduled by: NYPA

OSWEGO EXPORT  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 4800 MW  
450 MW  
5250 MW  
REV (Export)

### FITZPTRK-EDIC\_\_\_345\_FE-1

Tue 05/28/2024 to Fri 05/31/2024  
0700 Continuous 1530  
Work scheduled by: NYPA

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 2480 MW  
240 MW  
2720 MW  
REV (Export)

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, October 11, 2023 to Thursday, April 10, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### BECK\_\_PACKARD\_\_230\_BP76

Fri 05/31/2024 to Fri 05/31/2024  
0730 Continuous 1630

Work scheduled by: NGrid

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

**1600 MW**

450 MW

2050 MW

REV (Export)

**1050 MW**

600 MW

1650 MW

### CHASLAKE-PORTER\_\_230\_11

Sat 06/01/2024 to Wed 07/03/2024  
0530 Continuous 1600

Work scheduled by: NGrid

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

**2100 MW**

1050 MW

3150 MW

REV (Export)

### NIAGARA\_\_345\_230\_AT4

Tue 06/11/2024 to Wed 06/12/2024  
0500 Continuous 1900

Work scheduled by: NYPA

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

**1200 MW**

450 MW

1650 MW

### CHASLAKE-PORTER\_\_230\_11

Mon 07/08/2024 to Fri 08/30/2024  
0700 Continuous 1900

Work scheduled by: NGrid

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

**2100 MW**

1050 MW

3150 MW

REV (Export)

### MOSES\_\_ADIRNDCK\_\_230\_MA2

Mon 09/02/2024 to Mon 09/02/2024  
0700 Continuous 1730

Work scheduled by: NYPA

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

**2100 MW**

1050 MW

3150 MW

REV (Export)

### CHASLAKE-PORTER\_\_230\_11

Tue 09/03/2024 to Fri 11/15/2024  
0530 Continuous 2000

Work scheduled by: NGrid

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

**2100 MW**

1050 MW

3150 MW

REV (Export)

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, October 11, 2023 to Thursday, April 10, 2025

CENTRAL EAST	2650 MW
CENTRAL EAST - VC	2720 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### ROCHESTR-PANNELL\_345\_RP1

Mon 09/09/2024 to Fri 09/13/2024  
0700 Continuous 1530  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
DYSINGER EAST	<b>2300 MW</b>	
Impacts Total Transfer Capability	900 MW	
TTC with All Lines In Service	3200 MW	

### ROCHESTR-PANNELL\_345\_RP2

Mon 09/16/2024 to Fri 09/20/2024  
0700 Continuous 1530  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
DYSINGER EAST	<b>2300 MW</b>	
Impacts Total Transfer Capability	900 MW	
TTC with All Lines In Service	3200 MW	

### PANNELL-CLAY\_345\_1

Mon 09/23/2024 to Fri 09/27/2024  
0700 Continuous 1530  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
WEST CENTRAL	<b>1300 MW</b>	
Impacts Total Transfer Capability	950 MW	
TTC with All Lines In Service	2250 MW	

### FITZPTRK-EDIC\_345\_FE-1

Mon 09/30/2024 to Fri 10/04/2024  
1700 Continuous 1530  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
OSWEGO EXPORT	<b>4800 MW</b>	
Impacts Total Transfer Capability	450 MW	
TTC with All Lines In Service	5250 MW	

### FITZPTRK-EDIC\_345\_FE-1

Mon 09/30/2024 to Fri 10/04/2024  
1700 Continuous 1530  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
CENTRAL EAST - VC	<b>2480 MW</b>	
Impacts Total Transfer Capability	240 MW	
TTC with All Lines In Service	2720 MW	

### BECK\_-NIAGARA\_345\_PA302

Mon 10/07/2024 to Fri 10/11/2024  
0500 Continuous 1900  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - OH - NY	<b>1000 MW</b>	<b>850 MW</b>
Impacts Total Transfer Capability	1050 MW	800 MW
TTC with All Lines In Service	2050 MW	1650 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, October 11, 2023 to Thursday, April 10, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### NEPTUNE\_DUFFYAVE\_345\_NEPTUNE

Mon 10/07/2024 to Fri 10/11/2024  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE FWD (Import) REV (Export)  
**0 MW**  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

### NEWBRDGE\_345\_138\_BK\_1

Mon 10/07/2024 to Fri 10/11/2024  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE FWD (Import) REV (Export)  
**375 MW**  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 660 MW

### NEWBRDGE\_345\_138\_BK\_2

Mon 10/07/2024 to Fri 10/11/2024  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE FWD (Import) REV (Export)  
**375 MW**  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 660 MW

### NEWBRDGE-DUFFYAVE\_345\_501

Mon 10/07/2024 to Fri 10/11/2024  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE FWD (Import) REV (Export)  
**0 MW**  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

### SHOR\_NPX-SHOREHAM\_138\_CSC

Mon 10/07/2024 to Fri 10/11/2024  
0600 Continuous 1800  
Work scheduled by: LI

SCH - NPX\_CSC FWD (Import) REV (Export)  
**0 MW** **0 MW**  
Impacts Total Transfer Capability 330 MW 330 MW  
TTC with All Lines In Service 330 MW 330 MW

### GILBOA\_-N.SCTLND\_345\_GNS-1

Mon 10/07/2024 to Fri 10/11/2024  
0700 Continuous 1530  
Work scheduled by: NYPA

CENTRAL EAST - VC FWD (Import) REV (Export)  
**2300 MW**  
Impacts Total Transfer Capability 420 MW  
TTC with All Lines In Service 2720 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, October 11, 2023 to Thursday, April 10, 2025

CENTRAL EAST 2650 MW  
CENTRAL EAST - VC 2720 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### FRASANNX-COOPERS\_345\_UCC2-41

Wed 10/09/2024 to Thu 10/10/2024  
0700 Continuous 1530

ARR: 19

FWD (Import) REV (Export)

CENTRAL EAST - VC **2275 MW**  
Impacts Total Transfer Capability 445 MW  
TTC with All Lines In Service 2720 MW

Work scheduled by: NYPA

### MARCY\_-FRASANNX\_345\_UCC2-41

Wed 10/09/2024 to Thu 10/10/2024  
0700 Continuous 1530

ARR: 19

FWD (Import) REV (Export)

CENTRAL EAST - VC **2275 MW**  
Impacts Total Transfer Capability 445 MW  
TTC with All Lines In Service 2720 MW

Work scheduled by: NYPA

### MARCY\_-N.SCTLND\_345\_18

Tue 10/15/2024 to Thu 10/17/2024  
0700 Continuous 1530

ARR: 19

FWD (Import) REV (Export)

CENTRAL EAST - VC **1345 MW**  
Impacts Total Transfer Capability 1375 MW  
TTC with All Lines In Service 2720 MW

Work scheduled by: NYPA

### MARCY\_-N.SCTLND\_345\_18

Mon 10/21/2024 to Fri 10/25/2024  
0700 Continuous 1530

ARR: 19

FWD (Import) REV (Export)

CENTRAL EAST - VC **1345 MW**  
Impacts Total Transfer Capability 1375 MW  
TTC with All Lines In Service 2720 MW

Work scheduled by: NYPA

### COOPERS\_-MIDDLETP\_345\_CCRT34

Sun 10/27/2024 to Sat 11/02/2024  
0700 Continuous 1530

FWD (Import) REV (Export)

CENTRAL EAST - VC **2485 MW**  
Impacts Total Transfer Capability 235 MW  
TTC with All Lines In Service 2720 MW

Work scheduled by: NYPA

### MARCY\_345KV\_CSC

Mon 10/28/2024 to Sun 11/10/2024  
0700 Continuous 1530

FWD (Import) REV (Export)

CENTRAL EAST - VC **2650 MW**  
Impacts Total Transfer Capability 70 MW  
TTC with All Lines In Service 2720 MW

Work scheduled by: NYPA

NYISO TRANSFER LIMITATIONS

Seasonal Limits		Wednesday, October 11, 2023 to Thursday, April 10, 2025			
CENTRAL EAST	2650 MW	<b>The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.</b>			
CENTRAL EAST - VC	2720 MW				
TOTAL EAST	6150 MW				
UPNY CONED	8050 MW				
SPR/DUN-SOUTH	4600 MW				
DYSINGER EAST	3200 MW				
MOSES SOUTH	3150 MW				
<hr/>					
<b>BECK__-NIAGARA__230_PA27</b>				FWD (Import)	REV (Export)
Fri 11/15/2024	to	Fri 11/15/2024	SCH - OH - NY	<b>2100 MW</b>	
0500	Continuous	1900	Impacts Total Transfer Capability	300 MW	
Work scheduled by: NYPA			TTC with All Lines In Service	2400 MW	
<hr/>					
<b>ADIRNDCK-PORTER__230_12</b>				FWD (Import)	REV (Export)
Sun 12/01/2024	to	Sat 05/31/2025	MOSES SOUTH	<b>2300 MW</b>	
0530	Continuous	1700	Impacts Total Transfer Capability	850 MW	
Work scheduled by: NGrid			TTC with All Lines In Service	3150 MW	