

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Saturday, December 23, 2023 to Sunday, June 22, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

| | | | | | | | |
|---|------------|----------------|---|--|-----------------------------------|-------------------------------|-----------------|
| HUDSONP_-FARRAGUT_345_B3402 | | | | | | FWD (Import) | REV (Export) |
| Mon 01/15/2018 | to | Sun 03/31/2024 | | | SCH - PJ - NY | | |
| 0001 | Continuous | 2359 | <u>EXT FORCED by ConEd 12/20/2023 15:20</u> | | Impacts Total Transfer Capability | | |
| Work scheduled by: ConEd | | | | | | TTC with All Lines In Service | |
| MARION_-FARRAGUT_345_C3403 | | | | | | FWD (Import) | REV (Export) |
| Mon 01/15/2018 | to | Sun 03/31/2024 | | | SCH - PJ - NY | | |
| 0001 | Continuous | 2359 | <u>EXT FORCED by ConEd 12/20/2023 15:20</u> | | Impacts Total Transfer Capability | | |
| Work scheduled by: ConEd | | | | | | TTC with All Lines In Service | |
| MARION_-FARRAGUT_345_C3403 , HUDSONP_-FARRAGUT_345_B3402 | | | | | | FWD (Import) | REV (Export) |
| Mon 01/15/2018 | to | Sun 03/31/2024 | | | SCH - PJ - NY | 2400 MW | 2400 MW |
| 0001 | | 2359 | | | Impacts Total Transfer Capability | 150 MW | 250 MW |
| Work scheduled by: | | | | | | TTC with All Lines In Service | 2550 MW 2650 MW |
| HOMRC_NY-MAINS_NY_345_47 | | | | | | FWD (Import) | REV (Export) |
| Fri 09/08/2023 | to | Wed 01/31/2024 | | | SCH - PJ - NY | | |
| 1612 | Continuous | 2359 | <u>EXT FORCED by PJM 12/14/2023 17:00</u> | | Impacts Total Transfer Capability | | |
| Work scheduled by: PJM | | | | | | TTC with All Lines In Service | |
| SCH-IMO-NYISO_LIMIT_1900 | | | | | | FWD (Import) | REV (Export) |
| Wed 11/01/2023 | to | Tue 04/30/2024 | | | SCH - OH - NY | 2200 MW | |
| 0001 | Continuous | 2359 | | | Impacts Total Transfer Capability | 250 MW | |
| Work scheduled by: IESO | | | | | | TTC with All Lines In Service | 2450 MW |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Saturday, December 23, 2023 to Sunday, June 22, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-IMO_LIMIT_1700

Wed 11/01/2023 to Tue 04/30/2024

0001 Continuous 2359

Work scheduled by: IESO

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

2000 MW

-100 MW

1900 MW

DUNWODIE_345KV_6

Fri 12/15/2023 to Fri 02/16/2024

0000 Continuous 2359

Work scheduled by: ConEd

EXT FORCED by ConEd 12/20/2023 15:29

SPR/DUN-SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

3800 MW

800 MW

4600 MW

DUNWODIE-SHORE_RD_345_Y50

Fri 12/15/2023 to Fri 02/16/2024

0000 Continuous 2359

Work scheduled by: ConEd

EXT FORCED by ConEd 12/20/2023 15:29

CONED - LIPA

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

800 MW

700 MW

1500 MW

SHORE_RD_345_138_BK 1

Fri 12/15/2023 to Fri 02/16/2024

0000 Continuous 2359

Work scheduled by: ConEd

EXT FORCED by ConEd 12/20/2023 15:29

CONED - LIPA

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

1350 MW

150 MW

1500 MW

SHORE_RD_345_138_BK 2

Fri 12/15/2023 to Fri 02/16/2024

0000 Continuous 2359

Work scheduled by: ConEd

EXT FORCED by ConEd 12/20/2023 15:29

CONED - LIPA

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

1350 MW

150 MW

1500 MW

SPRNBK_-W49TH_ST_345_M52

Fri 12/22/2023 to Mon 12/25/2023

0216 Continuous 0200

Work scheduled by: ConEd

SPR/DUN-SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

3200 MW

1400 MW

4600 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Saturday, December 23, 2023 to Sunday, June 22, 2025

CENTRAL EAST 7550 MW
 CENTRAL EAST - VC 3725 MW
 TOTAL EAST 6150 MW
 UPNY CONED 8050 MW
 SPR/DUN-SOUTH 4600 MW
 DYSINGER EAST 3200 MW
 MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK_345KV_RNS4

Fri 12/22/2023 to Mon 12/25/2023
 0218 Continuous 0200
 Work scheduled by: ConEd

SPR/DUN-SOUTH
 FWD (Import) 3200 MW
 REV (Export)
 Impacts Total Transfer Capability 1400 MW
 TTC with All Lines In Service 4600 MW

ADIRNDCK-PORTER__230_12

Tue 01/02/2024 to Fri 05/31/2024
 0630 Continuous 1730
 Work scheduled by: NGrid
UPDATED by NGrid 07/11/2023 11:44

MOSES SOUTH
 FWD (Import) 2300 MW
 REV (Export)
 Impacts Total Transfer Capability 850 MW
 TTC with All Lines In Service 3150 MW

FRASER__345_FRASER SVC

Tue 01/02/2024 to Fri 03/01/2024
 0700 Continuous 1530
 Work scheduled by: NYPA

CENTRAL EAST - VC
 FWD (Import) 3655 MW
 REV (Export)
 Impacts Total Transfer Capability 70 MW
 TTC with All Lines In Service 3725 MW

SCH-IMO-NYISO_NIAG_CB_3008_W/BB

Thu 01/11/2024 to Thu 01/11/2024
 1830 Continuous 1900
 Work scheduled by: NYPA
UPDATED by NYPA 11/07/2023 12:37

SCH - OH - NY
 FWD (Import) 1750 MW
 REV (Export)
 Impacts Total Transfer Capability 150 MW
 TTC with All Lines In Service 1900 MW

BECK__PACKARD_230_BP76

Mon 01/15/2024 to Fri 01/19/2024
 0400 Continuous 1700
 Work scheduled by: NGrid

SCH - OH - NY
 FWD (Import) 1800 MW
 REV (Export) 1350 MW
 Impacts Total Transfer Capability 650 MW
 TTC with All Lines In Service 2450 MW
 550 MW
 1900 MW

SCH-IMO_NY_NIAG_NRTH_BUS_W/BB

Fri 01/26/2024 to Fri 01/26/2024
 0500 Continuous 1900
 Work scheduled by: NYPA

SCH - OH - NY
 FWD (Import) 1550 MW
 REV (Export) 1450 MW
 Impacts Total Transfer Capability 900 MW
 TTC with All Lines In Service 2450 MW
 450 MW
 1900 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Saturday, December 23, 2023 to Sunday, June 22, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MILLWOOD-EASTVIEW_345_W82

Mon 02/05/2024 to Wed 02/14/2024
0001 Continuous 2200
Work scheduled by: ConEd

UPNY CONED FWD (Import) REV (Export)
7810 MW
Impacts Total Transfer Capability 240 MW
TTC with All Lines In Service 8050 MW

CLAY__-EDIC__345_2-15

Mon 02/05/2024 to Mon 03/11/2024
0700 Continuous 1600
Work scheduled by: NGrid

OSWEGO EXPORT FWD (Import) REV (Export)
4850 MW
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 5250 MW

EDIC__-PRINCTWN_345_352

Thu 02/08/2024 to Thu 02/08/2024
0700 Continuous 1700
Work scheduled by: NGrid

CENTRAL EAST - VC FWD (Import) REV (Export)
3335 MW
Impacts Total Transfer Capability 390 MW
TTC with All Lines In Service 3725 MW

SCH-IMO_NY_NIAG_SOUTH_BUS_W/BB

Fri 02/09/2024 to Fri 02/09/2024
0500 Continuous 1900
Work scheduled by: NYPA

SCH - OH - NY FWD (Import) REV (Export)
1550 MW 1450 MW
Impacts Total Transfer Capability 900 MW 450 MW
TTC with All Lines In Service 2450 MW 1900 MW

W49TH_ST-E13THSTA_345_M54

Mon 02/12/2024 to Mon 02/12/2024
0001 Continuous 0030
Work scheduled by: ConEd

SPR/DUN-SOUTH FWD (Import) REV (Export)
3800 MW
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

W49TH_ST-E13THSTA_345_M54

Mon 02/12/2024 to Mon 02/12/2024
0330 Continuous 0400
Work scheduled by: ConEd

SPR/DUN-SOUTH FWD (Import) REV (Export)
3800 MW
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Saturday, December 23, 2023 to Sunday, June 22, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MILLWOOD-EASTVIEW_345_W85

Thu 02/15/2024 to Sat 02/17/2024
0001 Continuous 0200
Work scheduled by: ConEd

UPNY CONED
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) **7810 MW**
240 MW
8050 MW

NIAGARA_PACKARD_230_62

Fri 02/16/2024 to Fri 02/16/2024
0500 Continuous 1900
Work scheduled by: NYPA

SCH - OH - NY
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) **1750 MW**
700 MW
2450 MW
REV (Export) **1850 MW**
50 MW
1900 MW

SPRNBK_345KV_RNS4

Mon 02/19/2024 to Mon 02/19/2024
0001 Continuous 0030
Work scheduled by: ConEd

SPR/DUN-SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) **3200 MW**
1400 MW
4600 MW

SPRNBK-W49TH_ST_345_M52

Mon 02/19/2024 to Mon 02/19/2024
0001 Continuous 1730
Work scheduled by: ConEd

SPR/DUN-SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) **3200 MW**
1400 MW
4600 MW

W49TH_ST_345KV_5

Mon 02/19/2024 to Mon 02/19/2024
0001 Continuous 1730
Work scheduled by: ConEd

SCH - PJM_HTP
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) **300 MW**
360 MW
660 MW

SPRNBK_345KV_RNS4

Mon 02/19/2024 to Mon 02/19/2024
1700 Continuous 1730
Work scheduled by: ConEd

SPR/DUN-SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) **3200 MW**
1400 MW
4600 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Saturday, December 23, 2023 to Sunday, June 22, 2025

CENTRAL EAST 7550 MW
 CENTRAL EAST - VC 3725 MW
 TOTAL EAST 6150 MW
 UPNY CONED 8050 MW
 SPR/DUN-SOUTH 4600 MW
 DYSINGER EAST 3200 MW
 MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

| | | | | | | |
|--|------------|----------------|--|-----------------------------------|----------------|----------------|
| BERKSHIR-ALPS___345_393 | | | | | FWD (Import) | REV (Export) |
| Wed 02/21/2024 | to | Thu 02/22/2024 | | SCH - NPX_1385 | 100 MW | 100 MW |
| 1201 | Continuous | 1600 | | Impacts Total Transfer Capability | 100 MW | 100 MW |
| Work scheduled by: NGrid | | | | TTC with All Lines In Service | 200 MW | 200 MW |
| BERKSHIR-ALPS___345_393 | | | | | FWD (Import) | REV (Export) |
| Wed 02/21/2024 | to | Thu 02/22/2024 | | SCH - NE - NY | 1100 MW | 1700 MW |
| 1201 | Continuous | 1600 | | Impacts Total Transfer Capability | 300 MW | 100 MW |
| Work scheduled by: NGrid | | | | TTC with All Lines In Service | 1400 MW | 1800 MW |
| BERKSHIR-ALPS___345_393 , BERKSHIR-NORTHFLD_345_312 | | | | | FWD (Import) | REV (Export) |
| Wed 02/21/2024 | to | Thu 02/22/2024 | | SCH - NE - NY | 1100 MW | 1100 MW |
| 1201 | | 1600 | | Impacts Total Transfer Capability | 300 MW | 700 MW |
| Work scheduled by: | | | | TTC with All Lines In Service | 1400 MW | 1800 MW |
| BERKSHIR-NORTHFLD_345_312 | | | | | FWD (Import) | REV (Export) |
| Wed 02/21/2024 | to | Thu 02/22/2024 | | SCH - NPX_1385 | 100 MW | 100 MW |
| 1201 | Continuous | 1600 | | Impacts Total Transfer Capability | 100 MW | 100 MW |
| Work scheduled by: NGrid | | | | TTC with All Lines In Service | 200 MW | 200 MW |
| BERKSHIR-NORTHFLD_345_312 | | | | | FWD (Import) | REV (Export) |
| Wed 02/21/2024 | to | Thu 02/22/2024 | | SCH - NE - NY | 1300 MW | |
| 1201 | Continuous | 1600 | | Impacts Total Transfer Capability | 100 MW | |
| Work scheduled by: NGrid | | | | TTC with All Lines In Service | 1400 MW | |
| SCH-NE-NYISO_LIMIT_1100 | | | | | FWD (Import) | REV (Export) |
| Wed 02/21/2024 | to | Thu 02/22/2024 | | SCH - NE - NY | 1300 MW | |
| 1201 | Continuous | 1600 | | Impacts Total Transfer Capability | 100 MW | |
| Work scheduled by: NGrid | | | | TTC with All Lines In Service | 1400 MW | |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Saturday, December 23, 2023 to Sunday, June 22, 2025

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 6150 MW |
| UPNY CONED | 8050 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3150 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NE-NYISO_LIMIT_900

Wed 02/21/2024 to Thu 02/22/2024
1201 Continuous 1600
Work scheduled by: NGrid

| | | |
|-----------------------------------|----------------|--------------|
| SCH - NE - NY | FWD (Import) | REV (Export) |
| | 1100 MW | |
| Impacts Total Transfer Capability | 300 MW | |
| TTC with All Lines In Service | 1400 MW | |

SCH-NYISO-NE_LIMIT_900

Wed 02/21/2024 to Thu 02/22/2024
1201 Continuous 1600
Work scheduled by: NGrid

| | | |
|-----------------------------------|--------------|----------------|
| SCH - NE - NY | FWD (Import) | REV (Export) |
| | | 1100 MW |
| Impacts Total Transfer Capability | | 700 MW |
| TTC with All Lines In Service | | 1800 MW |

MOTTHAVN-RAINEY__345_Q12

Sat 02/24/2024 to Fri 04/05/2024
0001 Continuous 0200
Work scheduled by: ConEd

| | | |
|-----------------------------------|----------------|--------------|
| SPR/DUN-SOUTH | FWD (Import) | REV (Export) |
| | 3800 MW | |
| Impacts Total Transfer Capability | 800 MW | |
| TTC with All Lines In Service | 4600 MW | |

W49TH_ST_345KV_6

Mon 02/26/2024 to Mon 02/26/2024
0001 Continuous 0030
Work scheduled by: ConEd

| | | |
|-----------------------------------|---------------|--------------|
| SCH - PJM_HTP | FWD (Import) | REV (Export) |
| | 310 MW | |
| Impacts Total Transfer Capability | 350 MW | |
| TTC with All Lines In Service | 660 MW | |

W49TH_ST_345KV_8

Mon 02/26/2024 to Mon 02/26/2024
0001 Continuous 0030
Work scheduled by: ConEd

| | | |
|-----------------------------------|---------------|--------------|
| SCH - PJM_HTP | FWD (Import) | REV (Export) |
| | 310 MW | |
| Impacts Total Transfer Capability | 350 MW | |
| TTC with All Lines In Service | 660 MW | |

W49TH_ST_345KV_6

Mon 03/04/2024 to Tue 04/30/2024
0001 Continuous 0200
Work scheduled by: ConEd

| | | |
|-----------------------------------|---------------|--------------|
| SCH - PJM_HTP | FWD (Import) | REV (Export) |
| | 310 MW | |
| Impacts Total Transfer Capability | 350 MW | |
| TTC with All Lines In Service | 660 MW | |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Saturday, December 23, 2023 to Sunday, June 22, 2025

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 6150 MW |
| UPNY CONED | 8050 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3150 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST-E13THSTA_345_M55

Mon 03/04/2024 to Tue 04/30/2024
0001 Continuous 0200
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|-----------------------------------|----------------|--------------|
| SPR/DUN-SOUTH | 3800 MW | |
| Impacts Total Transfer Capability | 800 MW | |
| TTC with All Lines In Service | 4600 MW | |

W49TH_ST_345KV_8

Mon 03/04/2024 to Mon 03/04/2024
0130 Continuous 0200
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|-----------------------------------|---------------|--------------|
| SCH - PJM_HTP | 310 MW | |
| Impacts Total Transfer Capability | 350 MW | |
| TTC with All Lines In Service | 660 MW | |

BECK__-PACKARD_230_BP76

Mon 03/04/2024 to Fri 05/24/2024
0800 Continuous 1600
Work scheduled by: NGrid

| | FWD (Import) | REV (Export) |
|-----------------------------------|----------------|----------------|
| SCH - OH - NY | 1800 MW | 1350 MW |
| Impacts Total Transfer Capability | 650 MW | 550 MW |
| TTC with All Lines In Service | 2450 MW | 1900 MW |

SCRIBA_-VOLNEY_345_21

Mon 03/04/2024 to Mon 03/11/2024
0800 Continuous 1630
Work scheduled by: NGrid

| | FWD (Import) | REV (Export) |
|-----------------------------------|----------------|--------------|
| OSWEGO EXPORT | 5250 MW | |
| Impacts Total Transfer Capability | 0 MW | |
| TTC with All Lines In Service | 5250 MW | |

SPRNBK_345KV_RS3 , SPRNBK_345KV_RS4

Mon 03/11/2024 to Mon 03/11/2024
0001 0030
Work scheduled by:

| | FWD (Import) | REV (Export) |
|-----------------------------------|----------------|--------------|
| SPR/DUN-SOUTH | 3800 MW | |
| Impacts Total Transfer Capability | 800 MW | |
| TTC with All Lines In Service | 4600 MW | |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Saturday, December 23, 2023 to Sunday, June 22, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

| | | | | | | |
|----------------------------------|------------|----------------|---------|-----------------------------------|----------------|----------------|
| CLAY__-EDIC__345_1-16 | | | | | FWD (Import) | REV (Export) |
| Mon 03/18/2024 | to | Mon 04/22/2024 | | OSWEGO EXPORT | 4850 MW | |
| 0700 | Continuous | 1600 | | Impacts Total Transfer Capability | 400 MW | |
| Work scheduled by: NGrid | | | | TTC with All Lines In Service | 5250 MW | |
| S.RIPLEY-DUNKIRK__230_68 | | | | | FWD (Import) | REV (Export) |
| Mon 03/18/2024 | to | Fri 03/22/2024 | | SCH - PJ - NY | | |
| 0800 | Continuous | 1600 | | Impacts Total Transfer Capability | | |
| Work scheduled by: PJM | | | | TTC with All Lines In Service | | |
| MILLWOOD-EASTVIEW_345_W85 | | | | | FWD (Import) | REV (Export) |
| Fri 03/22/2024 | to | Thu 03/28/2024 | | UPNY CONED | 7810 MW | |
| 0201 | Continuous | 0200 | | Impacts Total Transfer Capability | 240 MW | |
| Work scheduled by: ConEd | | | | TTC with All Lines In Service | 8050 MW | |
| SPRNBK__345KV_RNS3 | | | | | FWD (Import) | REV (Export) |
| Fri 03/22/2024 | to | Fri 03/22/2024 | | SPR/DUN-SOUTH | 3800 MW | |
| 0201 | Continuous | 0230 | | Impacts Total Transfer Capability | 800 MW | |
| Work scheduled by: ConEd | | | | TTC with All Lines In Service | 4600 MW | |
| BERKSHIR-ALPS__345_393 | | | | | FWD (Import) | REV (Export) |
| Wed 03/27/2024 | to | Thu 03/28/2024 | | SCH - NPX_1385 | 100 MW | 100 MW |
| 1201 | Continuous | 1600 | ARR: 78 | Impacts Total Transfer Capability | 100 MW | 100 MW |
| Work scheduled by: NGrid | | | | TTC with All Lines In Service | 200 MW | 200 MW |
| BERKSHIR-ALPS__345_393 | | | | | FWD (Import) | REV (Export) |
| Wed 03/27/2024 | to | Thu 03/28/2024 | | SCH - NE - NY | 1100 MW | 1700 MW |
| 1201 | Continuous | 1600 | ARR: 78 | Impacts Total Transfer Capability | 300 MW | 100 MW |
| Work scheduled by: NGrid | | | | TTC with All Lines In Service | 1400 MW | 1800 MW |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Saturday, December 23, 2023 to Sunday, June 22, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BERKSHIR-ALPS___345_393 , BERKSHIR-NORTHFLD_345_312

Wed 03/27/2024 to Thu 03/28/2024
1201 1600

ARR: 78

SCH - NE - NY

FWD (Import)

REV (Export)

1100 MW

1100 MW

Impacts Total Transfer Capability

300 MW

700 MW

TTC with All Lines In Service

1400 MW

1800 MW

BERKSHIR-NORTHFLD_345_312

Wed 03/27/2024 to Thu 03/28/2024
1201 Continuous 1600

FWD (Import)

REV (Export)

SCH - NPX_1385

100 MW

100 MW

Impacts Total Transfer Capability

100 MW

100 MW

TTC with All Lines In Service

200 MW

200 MW

BERKSHIR-NORTHFLD_345_312

Wed 03/27/2024 to Thu 03/28/2024
1201 Continuous 1600

FWD (Import)

REV (Export)

SCH - NE - NY

1300 MW

Impacts Total Transfer Capability

100 MW

TTC with All Lines In Service

1400 MW

BERKSHIR-NORTHFLD_345_312

Wed 03/27/2024 to Thu 03/28/2024
1201 Continuous 1500

CANCELLED by NYISO 12/19/2023 12:59

FWD (Import)

REV (Export)

SCH - NPX_1385

100 MW

100 MW

Impacts Total Transfer Capability

100 MW

100 MW

TTC with All Lines In Service

200 MW

200 MW

BERKSHIR-NORTHFLD_345_312

Wed 03/27/2024 to Thu 03/28/2024
1201 Continuous 1500

CANCELLED by NYISO 12/19/2023 12:59

FWD (Import)

REV (Export)

SCH - NE - NY

1300 MW

Impacts Total Transfer Capability

100 MW

TTC with All Lines In Service

1400 MW

SCH-NE-NYISO_LIMIT_1100

Wed 03/27/2024 to Thu 03/28/2024
1201 Continuous 1600

FWD (Import)

REV (Export)

SCH - NE - NY

1300 MW

Impacts Total Transfer Capability

100 MW

TTC with All Lines In Service

1400 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Saturday, December 23, 2023 to Sunday, June 22, 2025

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 6150 MW |
| UPNY CONED | 8050 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3150 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NE-NYISO_LIMIT_900

Wed 03/27/2024 to Thu 03/28/2024
1201 Continuous 1600
Work scheduled by: NGrid

| | | |
|-----------------------------------|----------------|--------------|
| SCH - NE - NY | FWD (Import) | REV (Export) |
| | 1100 MW | |
| Impacts Total Transfer Capability | 300 MW | |
| TTC with All Lines In Service | 1400 MW | |

SCH-NYISO-NE_LIMIT_900

Wed 03/27/2024 to Thu 03/28/2024
1201 Continuous 1600
Work scheduled by: NGrid

| | | |
|-----------------------------------|--------------|----------------|
| SCH - NE - NY | FWD (Import) | REV (Export) |
| | | 1100 MW |
| Impacts Total Transfer Capability | | 700 MW |
| TTC with All Lines In Service | | 1800 MW |

LADENTWN-BUCHAN_S_345_Y88

Mon 04/01/2024 to Fri 05/17/2024
0001 Continuous 2359
Work scheduled by: ConEd

| | | |
|-----------------------------------|----------------|--------------|
| UPNY CONED | FWD (Import) | REV (Export) |
| | 7695 MW | |
| Impacts Total Transfer Capability | 355 MW | |
| TTC with All Lines In Service | 8050 MW | |

SPRNBK_345KV_RS3 , SPRNBK_345KV_RS4

Mon 04/01/2024 to Mon 04/01/2024
2130 2200
Work scheduled by:

| | | |
|-----------------------------------|----------------|--------------|
| SPR/DUN-SOUTH | FWD (Import) | REV (Export) |
| | 3800 MW | |
| Impacts Total Transfer Capability | 800 MW | |
| TTC with All Lines In Service | 4600 MW | |

NIAGARA_DYSINGER_345_ND1

Mon 04/08/2024 to Fri 04/12/2024
0500 Continuous 1900
Work scheduled by: NYPA

| | | |
|-----------------------------------|----------------|--------------|
| DYSINGER EAST | FWD (Import) | REV (Export) |
| | 2700 MW | |
| Impacts Total Transfer Capability | 500 MW | |
| TTC with All Lines In Service | 3200 MW | |

LINDN_CG-LNDVFT__345_V-3022

Mon 04/08/2024 to Sat 04/13/2024
0800 Continuous 1500
Work scheduled by: PJM

| | | |
|-----------------------------------|--------------|--------------|
| SCH - PJM_VFT | FWD (Import) | REV (Export) |
| | 0 MW | 0 MW |
| Impacts Total Transfer Capability | 315 MW | 315 MW |
| TTC with All Lines In Service | 315 MW | 315 MW |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Saturday, December 23, 2023 to Sunday, June 22, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_DYSINGER_345_ND2

Mon 04/15/2024 to Fri 04/19/2024
0500 Continuous 1900
Work scheduled by: NYPA

DYSINGER EAST
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) **2700 MW**
500 MW
3200 MW
REV (Export)

SCH-NPX_1385-NYISO_LIMIT_100

Mon 04/15/2024 to Fri 04/26/2024
0600 Continuous 2200
Work scheduled by: ISONE

SCH - NPX_1385
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) **100 MW**
100 MW
200 MW
REV (Export)

GOETHALS_345KV_5

Thu 04/18/2024 to Thu 04/18/2024
0001 Continuous 0030
Work scheduled by: ConEd

STATEN ISLAND
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) **0 MW**
0 MW
REV (Export)

LINDEN_GOETHALS_230_A2253

Thu 04/18/2024 to Thu 04/25/2024
0001 Continuous 0200
Work scheduled by: ConEd

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) **0 MW**
0 MW
REV (Export)

LINDN_CG-LNDVFT_345_V-3022

Thu 04/18/2024 to Thu 04/18/2024
1500 Continuous 1800
Work scheduled by: PJM

SCH - PJM_VFT
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) **0 MW**
315 MW
315 MW
REV (Export) **0 MW**
315 MW
315 MW

W49TH_ST_345KV_8

Sat 04/20/2024 to Thu 04/25/2024
0001 Continuous 0200
Work scheduled by: ConEd

SCH - PJM_HTP
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) **310 MW**
350 MW
660 MW
REV (Export)

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Saturday, December 23, 2023 to Sunday, June 22, 2025

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 6150 MW |
| UPNY CONED | 8050 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3150 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PANNELL_-CLAY___345_1

Mon 04/22/2024 to Fri 04/26/2024
0700 Continuous 1530

Work scheduled by: NYPA

WEST CENTRAL
Impacts Total Transfer Capability 1300 MW
950 MW
TTC with All Lines In Service 2250 MW

FWD (Import) REV (Export)

GOETHALS_345KV_5

Thu 04/25/2024 to Thu 04/25/2024
0130 Continuous 0200

Work scheduled by: ConEd

STATEN ISLAND
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

DYSINGER-STA_255_345_DH1

Fri 04/26/2024 to Tue 05/07/2024
0500 Continuous 1900

Work scheduled by: NYPA

DYSINGER EAST
Impacts Total Transfer Capability 2850 MW
350 MW
TTC with All Lines In Service 3200 MW

FWD (Import) REV (Export)

MARCY_-FRASANNX_345_UCC2-41

Mon 04/29/2024 to Tue 07/16/2024
0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC
Impacts Total Transfer Capability 3225 MW
500 MW
TTC with All Lines In Service 3725 MW

FWD (Import) REV (Export)

PANNELL_-CLAY___345_2

Mon 04/29/2024 to Fri 05/03/2024
0700 Continuous 1530

Work scheduled by: NYPA

WEST CENTRAL
Impacts Total Transfer Capability 1300 MW
950 MW
TTC with All Lines In Service 2250 MW

FWD (Import) REV (Export)

SHOR_NPX-SHOREHAM_138_CSC

Mon 05/06/2024 to Fri 05/10/2024
0600 Continuous 1800

Work scheduled by: LI

SCH - NPX_CSC
Impacts Total Transfer Capability 0 MW 0 MW
330 MW 330 MW
TTC with All Lines In Service 330 MW 330 MW

FWD (Import) REV (Export)

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Saturday, December 23, 2023 to Sunday, June 22, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_ROBNSNRD_230_64

Mon 05/13/2024 to Fri 05/17/2024
0500 Continuous 1900
Work scheduled by: NYPA

SCH - OH - NY
Impacts Total Transfer Capability 1500 MW
TTC with All Lines In Service 150 MW
TTC with All Lines In Service 1650 MW

BUCHAN_S-MILLWOOD_345_W97

Fri 05/17/2024 to Sat 05/18/2024
0001 Continuous 0200
Work scheduled by: ConEd

UPNY CONED
Impacts Total Transfer Capability 8015 MW
TTC with All Lines In Service 35 MW
TTC with All Lines In Service 8050 MW

FITZPTRK-EDIC_345_FE-1

Mon 05/20/2024 to Fri 05/24/2024
0700 Continuous 1530
Work scheduled by: NYPA

OSWEGO EXPORT
Impacts Total Transfer Capability 4800 MW
TTC with All Lines In Service 450 MW
TTC with All Lines In Service 5250 MW

FITZPTRK-EDIC_345_FE-1

Mon 05/20/2024 to Fri 05/24/2024
0700 Continuous 1530
Work scheduled by: NYPA

CENTRAL EAST - VC
Impacts Total Transfer Capability 3520 MW
TTC with All Lines In Service 205 MW
TTC with All Lines In Service 3725 MW

FITZPTRK-EDIC_345_FE-1

Tue 05/28/2024 to Fri 05/31/2024
0700 Continuous 1530
Work scheduled by: NYPA

OSWEGO EXPORT
Impacts Total Transfer Capability 4800 MW
TTC with All Lines In Service 450 MW
TTC with All Lines In Service 5250 MW

FITZPTRK-EDIC_345_FE-1

Tue 05/28/2024 to Fri 05/31/2024
0700 Continuous 1530
Work scheduled by: NYPA

CENTRAL EAST - VC
Impacts Total Transfer Capability 3520 MW
TTC with All Lines In Service 205 MW
TTC with All Lines In Service 3725 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Saturday, December 23, 2023 to Sunday, June 22, 2025

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 6150 MW |
| UPNY CONED | 8050 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3150 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BECK__PACKARD_230_BP76

Fri 05/31/2024 to Fri 05/31/2024
0730 Continuous 1630
Work scheduled by: NGrid

| | FWD (Import) | REV (Export) |
|-----------------------------------|----------------|----------------|
| SCH - OH - NY | 1600 MW | 1050 MW |
| Impacts Total Transfer Capability | 450 MW | 600 MW |
| TTC with All Lines In Service | 2050 MW | 1650 MW |

CHASLAKE-PORTER_230_11

Sat 06/01/2024 to Wed 07/03/2024
0530 Continuous 1600
Work scheduled by: NGrid

| | FWD (Import) | REV (Export) |
|-----------------------------------|----------------|--------------|
| MOSES SOUTH | 2100 MW | |
| Impacts Total Transfer Capability | 1050 MW | |
| TTC with All Lines In Service | 3150 MW | |

NIAGARA_345_230_AT4

Tue 06/11/2024 to Wed 06/12/2024
0500 Continuous 1900
Work scheduled by: NYPA

| | FWD (Import) | REV (Export) |
|-----------------------------------|--------------|----------------|
| SCH - OH - NY | | 1200 MW |
| Impacts Total Transfer Capability | | 450 MW |
| TTC with All Lines In Service | | 1650 MW |

CHASLAKE-PORTER_230_11

Mon 07/08/2024 to Fri 08/30/2024
0700 Continuous 1900
Work scheduled by: NGrid

| | FWD (Import) | REV (Export) |
|-----------------------------------|----------------|--------------|
| MOSES SOUTH | 2100 MW | |
| Impacts Total Transfer Capability | 1050 MW | |
| TTC with All Lines In Service | 3150 MW | |

DYSINGER-STA_255_345_DH2

Mon 07/15/2024 to Sun 08/04/2024
0500 Continuous 1900
Work scheduled by: NYPA

| | FWD (Import) | REV (Export) |
|-----------------------------------|----------------|--------------|
| DYSINGER EAST | 2850 MW | |
| Impacts Total Transfer Capability | 350 MW | |
| TTC with All Lines In Service | 3200 MW | |

MOSES__ADIRNDCK_230_MA2

Mon 09/02/2024 to Mon 09/02/2024
0700 Continuous 1730
Work scheduled by: NYPA

| | FWD (Import) | REV (Export) |
|-----------------------------------|----------------|--------------|
| MOSES SOUTH | 2100 MW | |
| Impacts Total Transfer Capability | 1050 MW | |
| TTC with All Lines In Service | 3150 MW | |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Saturday, December 23, 2023 to Sunday, June 22, 2025

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 6150 MW |
| UPNY CONED | 8050 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3150 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHASLAKE-PORTER__230_11

Tue 09/03/2024 to Fri 11/15/2024
0530 Continuous 2000
Work scheduled by: NGrid

| | FWD (Import) | REV (Export) |
|-----------------------------------|----------------|--------------|
| MOSES SOUTH | 2100 MW | |
| Impacts Total Transfer Capability | 1050 MW | |
| TTC with All Lines In Service | 3150 MW | |

FITZPTRK-EDIC__345_FE-1

Mon 09/09/2024 to Mon 09/09/2024
0001 Continuous 0100
Work scheduled by: NYPA

| | FWD (Import) | REV (Export) |
|-----------------------------------|----------------|--------------|
| OSWEGO EXPORT | 4800 MW | |
| Impacts Total Transfer Capability | 450 MW | |
| TTC with All Lines In Service | 5250 MW | |

FITZPTRK-EDIC__345_FE-1

Mon 09/09/2024 to Mon 09/09/2024
0001 Continuous 0100
Work scheduled by: NYPA

| | FWD (Import) | REV (Export) |
|-----------------------------------|----------------|--------------|
| CENTRAL EAST - VC | 3520 MW | |
| Impacts Total Transfer Capability | 205 MW | |
| TTC with All Lines In Service | 3725 MW | |

ROCHESTR-PANNELL_345_RP1

Mon 09/09/2024 to Fri 09/13/2024
0700 Continuous 1530
Work scheduled by: NYPA

| | FWD (Import) | REV (Export) |
|-----------------------------------|----------------|--------------|
| DYSINGER EAST | 2300 MW | |
| Impacts Total Transfer Capability | 900 MW | |
| TTC with All Lines In Service | 3200 MW | |

MOTTHAVN-RAINEY__345_Q11

Sun 09/15/2024 to Sat 10/26/2024
0001 Continuous 0300
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|-----------------------------------|----------------|--------------|
| SPR/DUN-SOUTH | 3800 MW | |
| Impacts Total Transfer Capability | 800 MW | |
| TTC with All Lines In Service | 4600 MW | |

DYSINGER-STA_255_345_DH2

Mon 09/16/2024 to Mon 10/28/2024
0500 Continuous 1900
Work scheduled by: NYPA

| | FWD (Import) | REV (Export) |
|-----------------------------------|----------------|--------------|
| DYSINGER EAST | 2850 MW | |
| Impacts Total Transfer Capability | 350 MW | |
| TTC with All Lines In Service | 3200 MW | |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Saturday, December 23, 2023 to Sunday, June 22, 2025

CENTRAL EAST 7550 MW
 CENTRAL EAST - VC 3725 MW
 TOTAL EAST 6150 MW
 UPNY CONED 8050 MW
 SPR/DUN-SOUTH 4600 MW
 DYSINGER EAST 3200 MW
 MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ROCHESTR-PANNELL__345_RP2

Mon 09/16/2024 to Fri 09/20/2024
 0700 Continuous 1530
 Work scheduled by: NYPA

DYSINGER EAST
2300 MW
 Impacts Total Transfer Capability 900 MW
 TTC with All Lines In Service 3200 MW

STLAWRNC-MOSES__230_L34P

Mon 09/16/2024 to Fri 09/20/2024
 0700 Continuous 1530
 Work scheduled by: NYPA

SCH - OH - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

PANNELL-CLAY__345_1

Mon 09/23/2024 to Fri 09/27/2024
 0700 Continuous 1530
 Work scheduled by: NYPA

WEST CENTRAL
1300 MW
 Impacts Total Transfer Capability 950 MW
 TTC with All Lines In Service 2250 MW

STLAWRNC-MOSES__230_L34P

Mon 09/23/2024 to Fri 09/27/2024
 0700 Continuous 1530
 Work scheduled by: NYPA

SCH - OH - NY
 Impacts Total Transfer Capability
 TTC with All Lines In Service

FITZPTRK-EDIC__345_FE-1

Thu 09/26/2024 to Thu 09/26/2024
 0900 Continuous 1000
 Work scheduled by: NYPA

OSWEGO EXPORT
4800 MW
 Impacts Total Transfer Capability 450 MW
 TTC with All Lines In Service 5250 MW

FITZPTRK-EDIC__345_FE-1

Thu 09/26/2024 to Thu 09/26/2024
 0900 Continuous 1000
 Work scheduled by: NYPA

CENTRAL EAST - VC
3520 MW
 Impacts Total Transfer Capability 205 MW
 TTC with All Lines In Service 3725 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Saturday, December 23, 2023 to Sunday, June 22, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

STLAWRNC-MOSES__230_L34P

Mon 09/30/2024 to Fri 10/04/2024
0700 Continuous 1530
Work scheduled by: NYPA

SCH - OH - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

FITZPTRK-EDIC__345_FE-1

Mon 09/30/2024 to Fri 10/04/2024
1700 Continuous 1530
Work scheduled by: NYPA

OSWEGO EXPORT
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
4800 MW
450 MW
5250 MW

FITZPTRK-EDIC__345_FE-1

Mon 09/30/2024 to Fri 10/04/2024
1700 Continuous 1530
Work scheduled by: NYPA

CENTRAL EAST - VC
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
3520 MW
205 MW
3725 MW

BECK__-NIAGARA_345_PA302

Mon 10/07/2024 to Fri 10/11/2024
0500 Continuous 1900
Work scheduled by: NYPA

SCH - OH - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
1000 MW **850 MW**
1050 MW 800 MW
2050 MW 1650 MW

NEPTUNE_-DUFFYAVE_345_NEPTUNE

Mon 10/07/2024 to Fri 10/11/2024
0600 Continuous 1600
Work scheduled by: LI

SCH - PJM_NEPTUNE
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
0 MW
660 MW
660 MW

NEWBRDGE_345_138_BK_1

Mon 10/07/2024 to Fri 10/11/2024
0600 Continuous 1600
Work scheduled by: LI

SCH - PJM_NEPTUNE
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
375 MW
285 MW
660 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Saturday, December 23, 2023 to Sunday, June 22, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEWBRDGE_345_138_BK_2

Mon 10/07/2024 to Fri 10/11/2024
0600 Continuous 1600

Work scheduled by: LI

SCH - PJM_NEPTUNE

FWD (Import)

REV (Export)

375 MW

Impacts Total Transfer Capability

285 MW

TTC with All Lines In Service

660 MW

NEWBRDGE-DUFFYAVE_345_501

Mon 10/07/2024 to Fri 10/11/2024
0600 Continuous 1600

Work scheduled by: LI

SCH - PJM_NEPTUNE

FWD (Import)

REV (Export)

0 MW

Impacts Total Transfer Capability

660 MW

TTC with All Lines In Service

660 MW

SHOR_NPX-SHOREHAM_138_CSC

Mon 10/07/2024 to Fri 10/11/2024
0600 Continuous 1800

Work scheduled by: LI

SCH - NPX_CSC

FWD (Import)

REV (Export)

0 MW

0 MW

Impacts Total Transfer Capability

330 MW

330 MW

TTC with All Lines In Service

330 MW

330 MW

MARCY__FRASANNX_345_UCC2-41

Wed 10/09/2024 to Thu 10/10/2024
0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC

FWD (Import)

REV (Export)

3225 MW

Impacts Total Transfer Capability

500 MW

TTC with All Lines In Service

3725 MW

MARCY__N.SCTLND_345_18

Tue 10/15/2024 to Thu 10/17/2024
0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC

FWD (Import)

REV (Export)

2665 MW

Impacts Total Transfer Capability

1060 MW

TTC with All Lines In Service

3725 MW

MARCY__N.SCTLND_345_18

Mon 10/21/2024 to Fri 10/25/2024
0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC

FWD (Import)

REV (Export)

2665 MW

Impacts Total Transfer Capability

1060 MW

TTC with All Lines In Service

3725 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Saturday, December 23, 2023 to Sunday, June 22, 2025

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 6150 MW |
| UPNY CONED | 8050 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3150 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY__345KV_CSC

Mon 10/28/2024 to Sun 11/10/2024
0700 Continuous 1530
Work scheduled by: NYPA

| | | |
|-----------------------------------|----------------|--------------|
| | FWD (Import) | REV (Export) |
| CENTRAL EAST - VC | 3650 MW | |
| Impacts Total Transfer Capability | 75 MW | |
| TTC with All Lines In Service | 3725 MW | |

DYSINGER-STA_255_345_DH2

Tue 10/29/2024 to Thu 10/31/2024
0500 Continuous 2100
Work scheduled by: NYPA

| | | |
|-----------------------------------|----------------|--------------|
| | FWD (Import) | REV (Export) |
| DYSINGER EAST | 2850 MW | |
| Impacts Total Transfer Capability | 350 MW | |
| TTC with All Lines In Service | 3200 MW | |

DYSINGER-STA_255_345_DH1

Mon 11/04/2024 to Sat 11/16/2024
0500 Continuous 1900
Work scheduled by: NYPA

| | | |
|-----------------------------------|----------------|--------------|
| | FWD (Import) | REV (Export) |
| DYSINGER EAST | 2850 MW | |
| Impacts Total Transfer Capability | 350 MW | |
| TTC with All Lines In Service | 3200 MW | |

BECK__-NIAGARA_230_PA27

Fri 11/15/2024 to Fri 11/15/2024
0500 Continuous 1900
Work scheduled by: NYPA

| | | |
|-----------------------------------|----------------|--------------|
| | FWD (Import) | REV (Export) |
| SCH - OH - NY | 2100 MW | |
| Impacts Total Transfer Capability | 350 MW | |
| TTC with All Lines In Service | 2450 MW | |

CHATGUAY-MASSENA_765_7040

Sat 11/16/2024 to Fri 11/29/2024
0001 Continuous 2359
Work scheduled by: NYPA

| | | |
|-----------------------------------|--------------|--------------|
| | FWD (Import) | REV (Export) |
| SCH - HQ - NY | 0 MW | 0 MW |
| Impacts Total Transfer Capability | 1500 MW | 1000 MW |
| TTC with All Lines In Service | 1500 MW | 1000 MW |

CHATGUAY-MASSENA_765_7040

Sat 11/16/2024 to Fri 11/29/2024
0001 Continuous 2359
Work scheduled by: NYPA

| | | |
|-----------------------------------|----------------|--------------|
| | FWD (Import) | REV (Export) |
| MOSES SOUTH | 1550 MW | |
| Impacts Total Transfer Capability | 1600 MW | |
| TTC with All Lines In Service | 3150 MW | |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Saturday, December 23, 2023 to Sunday, June 22, 2025

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 6150 MW |
| UPNY CONED | 8050 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3150 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHATGUAY-MASSENA_765_7040 , MASSENA_-MARCY__765_MSU1

Sat 11/16/2024 to Fri 11/29/2024
0001 2359

Work scheduled by:

| | |
|-----------------------------------|---------------|
| MOSES SOUTH | 500 MW |
| Impacts Total Transfer Capability | 2650 MW |
| TTC with All Lines In Service | 3150 MW |

FWD (Import) REV (Export)

MARCY__765_345_AT1

Sat 11/16/2024 to Fri 11/29/2024
0001 Continuous 2359

Work scheduled by: NYPA

ARR: 19

| | |
|-----------------------------------|----------------|
| MOSES SOUTH | 1750 MW |
| Impacts Total Transfer Capability | 1400 MW |
| TTC with All Lines In Service | 3150 MW |

FWD (Import) REV (Export)

MARCY__765_345_AT2

Sat 11/16/2024 to Fri 11/29/2024
0001 Continuous 2359

Work scheduled by: NYPA

ARR: 19

| | |
|-----------------------------------|----------------|
| MOSES SOUTH | 1700 MW |
| Impacts Total Transfer Capability | 1450 MW |
| TTC with All Lines In Service | 3150 MW |

FWD (Import) REV (Export)

MASSENA_-MARCY__765_MSU1

Sat 11/16/2024 to Fri 11/29/2024
0001 Continuous 2359

Work scheduled by: NYPA

| | |
|-----------------------------------|--------------|
| SCH - HQ_CEDARS | 90 MW |
| Impacts Total Transfer Capability | 189 MW |
| TTC with All Lines In Service | 279 MW |

FWD (Import) REV (Export)

MASSENA_-MARCY__765_MSU1

Sat 11/16/2024 to Fri 11/29/2024
0001 Continuous 2359

Work scheduled by: NYPA

| | | |
|-----------------------------------|---------------|----------------|
| SCH - HQ - NY | 475 MW | 1000 MW |
| Impacts Total Transfer Capability | 1025 MW | 0 MW |
| TTC with All Lines In Service | 1500 MW | 1000 MW |

FWD (Import) REV (Export)

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Saturday, December 23, 2023 to Sunday, June 22, 2025

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 6150 MW |
| UPNY CONED | 8050 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3150 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA_-MARCY___765_MSU1

Sat 11/16/2024 to Fri 11/29/2024
0001 Continuous 2359
Work scheduled by: NYPA

| | | |
|-----------------------------------|---------------|--------------|
| | FWD (Import) | REV (Export) |
| MOSES SOUTH | 500 MW | |
| Impacts Total Transfer Capability | 2650 MW | |
| TTC with All Lines In Service | 3150 MW | |

MASSENA_-MARCY___765_MSU1

Sat 11/16/2024 to Fri 11/29/2024
0001 Continuous 2359
Work scheduled by: NYPA

| | | |
|-----------------------------------|----------------|--------------|
| | FWD (Import) | REV (Export) |
| CENTRAL EAST - VC | 2595 MW | |
| Impacts Total Transfer Capability | 1130 MW | |
| TTC with All Lines In Service | 3725 MW | |

MOSES___-MASSENA_230_MMS2 , MOSES___-MASSENA_230_MMS1

Sat 11/16/2024 to Fri 11/29/2024
0001 2359
Work scheduled by:

| | | |
|-----------------------------------|--------------|--------------|
| | FWD (Import) | REV (Export) |
| SCH - HQ_CEDARS | 90 MW | |
| Impacts Total Transfer Capability | 189 MW | |
| TTC with All Lines In Service | 279 MW | |

MOSES___-MASSENA_230_MMS2 , MOSES___-MASSENA_230_MMS1

Sat 11/16/2024 to Fri 11/29/2024
0001 2359
Work scheduled by:

| | | |
|-----------------------------------|---------------|--------------|
| | FWD (Import) | REV (Export) |
| SCH - HQ - NY | 850 MW | 0 MW |
| Impacts Total Transfer Capability | 650 MW | 1000 MW |
| TTC with All Lines In Service | 1500 MW | 1000 MW |

ADIRNDCK-PORTER___230_12

Sun 12/01/2024 to Sat 05/31/2025
0530 Continuous 1700
Work scheduled by: NGrid

| | | |
|-----------------------------------|----------------|--------------|
| | FWD (Import) | REV (Export) |
| MOSES SOUTH | 2300 MW | |
| Impacts Total Transfer Capability | 850 MW | |
| TTC with All Lines In Service | 3150 MW | |