

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Friday, January 12, 2024 to Friday, July 11, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### HUDSONP\_-FARRAGUT\_345\_B3402

Mon 01/15/2018 to Sun 03/31/2024  
0001 Continuous 2359  
Work scheduled by: ConEd

EXT FORCED by ConEd 12/20/2023 15:20

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### MARION\_-FARRAGUT\_345\_C3403

Mon 01/15/2018 to Sun 03/31/2024  
0001 Continuous 2359  
Work scheduled by: ConEd

EXT FORCED by ConEd 12/20/2023 15:20

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### MARION\_-FARRAGUT\_345\_C3403 , HUDSONP\_-FARRAGUT\_345\_B3402

Mon 01/15/2018 to Sun 03/31/2024  
0001 2359  
Work scheduled by:

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**2400 MW** **2400 MW**  
150 MW 250 MW  
2550 MW 2650 MW

### HOMRC\_NY-MAINS\_NY\_345\_47

Fri 09/08/2023 to Wed 01/31/2024  
1612 Continuous 2359  
Work scheduled by: PJM

EXT FORCED by PJM 12/14/2023 17:00

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### SCH-IMO-NYISO\_LIMIT\_1900

Wed 11/01/2023 to Tue 04/30/2024  
0001 Continuous 2359  
Work scheduled by: IESO

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**2200 MW**  
250 MW  
2450 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Friday, January 12, 2024 to Friday, July 11, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### DUNWODIE\_345KV\_6

Fri 12/15/2023 to Fri 02/16/2024  
0000 Continuous 2359

EXT FORCED by ConEd 12/20/2023 15:29

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

**3800 MW**

Impacts Total Transfer Capability

800 MW

TTC with All Lines In Service

4600 MW

Work scheduled by: ConEd

### DUNWODIE-SHORE\_RD\_345\_Y50

Fri 12/15/2023 to Fri 02/16/2024  
0000 Continuous 2359

EXT FORCED by ConEd 12/20/2023 15:29

CONED - LIPA

FWD (Import)

REV (Export)

**800 MW**

Impacts Total Transfer Capability

700 MW

TTC with All Lines In Service

1500 MW

Work scheduled by: ConEd

### SHORE\_RD\_345\_138\_BK 1

Fri 12/15/2023 to Fri 02/16/2024  
0000 Continuous 2359

EXT FORCED by ConEd 12/20/2023 15:29

CONED - LIPA

FWD (Import)

REV (Export)

**1350 MW**

Impacts Total Transfer Capability

150 MW

TTC with All Lines In Service

1500 MW

Work scheduled by: ConEd

### SHORE\_RD\_345\_138\_BK 2

Fri 12/15/2023 to Fri 02/16/2024  
0000 Continuous 2359

EXT FORCED by ConEd 12/20/2023 15:29

CONED - LIPA

FWD (Import)

REV (Export)

**1350 MW**

Impacts Total Transfer Capability

150 MW

TTC with All Lines In Service

1500 MW

Work scheduled by: ConEd

### DUNWODIE-MOTTHAVN\_345\_71

Sun 12/24/2023 to Fri 01/26/2024  
1827 Continuous 2300

EXT FORCED by ConEd 01/02/2024 14:46

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

**3800 MW**

Impacts Total Transfer Capability

800 MW

TTC with All Lines In Service

4600 MW

Work scheduled by: ConEd

### ADIRNDCK-PORTER\_\_230\_12

Tue 01/02/2024 to Fri 05/31/2024  
0630 Continuous 1730

UPDATED by NGrid 07/11/2023 11:44

MOSES SOUTH

FWD (Import)

REV (Export)

**2300 MW**

Impacts Total Transfer Capability

850 MW

TTC with All Lines In Service

3150 MW

Work scheduled by: NGrid

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Friday, January 12, 2024 to Friday, July 11, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-IMO-NYISO\_LIMIT\_1750

Tue 01/02/2024 to Fri 05/31/2024  
0630 Continuous 1730

UPDATED by NGrid 07/11/2023 11:44

FWD (Import) REV (Export)

**2050 MW**

400 MW

2450 MW

Work scheduled by: NGrid

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

### FRASER\_\_345\_FRASER SVC

Tue 01/02/2024 to Fri 03/01/2024  
0700 Continuous 1530

FWD (Import) REV (Export)

**3655 MW**

70 MW

3725 MW

Work scheduled by: NYPA

CENTRAL EAST - VC

Impacts Total Transfer Capability

TTC with All Lines In Service

### SCH-NE-NYISO\_LIMIT\_1100

Fri 01/12/2024 to Mon 01/22/2024  
0001 Continuous 2200

FWD (Import) REV (Export)

**1300 MW**

100 MW

1400 MW

Work scheduled by: ConEd

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

### SCH-NE-NYISO\_LIMIT\_400

Fri 01/12/2024 to Fri 01/12/2024  
0001 Continuous 0659

FWD (Import) REV (Export)

**600 MW**

800 MW

1400 MW

Work scheduled by: ConEd

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

### SCH-NE-NYISO\_LIMIT\_400

Fri 01/12/2024 to Sat 01/13/2024  
2300 Continuous 0659

FWD (Import) REV (Export)

**600 MW**

800 MW

1400 MW

Work scheduled by: ConEd

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

### SCH-NE-NYISO\_LIMIT\_400

Sat 01/13/2024 to Sun 01/14/2024  
2300 Continuous 0659

FWD (Import) REV (Export)

**600 MW**

800 MW

1400 MW

Work scheduled by: ConEd

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Friday, January 12, 2024 to Friday, July 11, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_400

Sun 01/14/2024 to Mon 01/15/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

SCH - NE - NY  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 1400 MW

FWD (Import) REV (Export)

**600 MW**

### BECK\_\_PACKARD\_230\_BP76

Mon 01/15/2024 to Sun 01/21/2024  
0400 Continuous 1700  
Work scheduled by: NGrid

SCH - OH - NY  
Impacts Total Transfer Capability 650 MW  
TTC with All Lines In Service 2450 MW

FWD (Import) REV (Export)

**1800 MW** **1350 MW**

550 MW

1900 MW

### SCH-IMO-NYISO\_LIMIT\_1300

Mon 01/15/2024 to Sun 01/21/2024  
0400 Continuous 1700  
Work scheduled by: NGrid

SCH - OH - NY  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 2450 MW

FWD (Import) REV (Export)

**1600 MW**

850 MW

2450 MW

### SCH-NE-NYISO\_LIMIT\_400

Mon 01/15/2024 to Tue 01/16/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

SCH - NE - NY  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 1400 MW

FWD (Import) REV (Export)

**600 MW**

800 MW

1400 MW

### SCH-NE-NYISO\_LIMIT\_400

Tue 01/16/2024 to Wed 01/17/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

SCH - NE - NY  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 1400 MW

FWD (Import) REV (Export)

**600 MW**

800 MW

1400 MW

### SCH-NE-NYISO\_LIMIT\_400

Wed 01/17/2024 to Thu 01/18/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

SCH - NE - NY  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 1400 MW

FWD (Import) REV (Export)

**600 MW**

800 MW

1400 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Friday, January 12, 2024 to Friday, July 11, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_400

Thu 01/18/2024 to Fri 01/19/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

SCH - NE - NY FWD (Import) REV (Export)  
**600 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 1400 MW

### SCH-NE-NYISO\_LIMIT\_400

Fri 01/19/2024 to Sat 01/20/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

SCH - NE - NY FWD (Import) REV (Export)  
**600 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 1400 MW

### SCH-NE-NYISO\_LIMIT\_400

Sat 01/20/2024 to Sun 01/21/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

SCH - NE - NY FWD (Import) REV (Export)  
**600 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 1400 MW

### SCH-NE-NYISO\_LIMIT\_400

Sun 01/21/2024 to Mon 01/22/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

SCH - NE - NY FWD (Import) REV (Export)  
**600 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 1400 MW

### SCH-IMO\_NY\_NIAG\_NRTH\_BUS\_W/BB

Fri 01/26/2024 to Fri 01/26/2024  
0500 Continuous 1900  
Work scheduled by: NYPA

SCH - OH - NY FWD (Import) REV (Export)  
**1550 MW 1450 MW**  
Impacts Total Transfer Capability 900 MW 450 MW  
TTC with All Lines In Service 2450 MW 1900 MW

### EDIC\_\_-PRINCTWN\_345\_351

Thu 02/01/2024 to Thu 02/01/2024  
0700 Daily 1600  
Work scheduled by: NGrid

CENTRAL EAST - VC FWD (Import) REV (Export)  
**3335 MW**  
Impacts Total Transfer Capability 390 MW  
TTC with All Lines In Service 3725 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Friday, January 12, 2024 to Friday, July 11, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### CLAY\_\_-EDIC\_\_345\_2-15

Mon 02/05/2024 to Mon 03/11/2024  
0700 Continuous 1600  
Work scheduled by: NGrid

OSWEGO EXPORT FWD (Import) REV (Export)  
**4850 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

### MILLWOOD-EASTVIEW\_345\_W82

Wed 02/07/2024 to Fri 02/16/2024  
0001 Continuous 2200  
Work scheduled by: ConEd  
UPDATED by ConEd 01/12/2024 08:51

UPNY CONED FWD (Import) REV (Export)  
**7810 MW**  
Impacts Total Transfer Capability 240 MW  
TTC with All Lines In Service 8050 MW

### EDIC\_\_-PRINCTWN\_345\_352

Thu 02/08/2024 to Thu 02/08/2024  
0700 Continuous 1700  
Work scheduled by: NGrid

CENTRAL EAST - VC FWD (Import) REV (Export)  
**3335 MW**  
Impacts Total Transfer Capability 390 MW  
TTC with All Lines In Service 3725 MW

### SCH-IMO\_NY\_NIAG\_SOUTH\_BUS\_W/BB

Fri 02/09/2024 to Fri 02/09/2024  
0500 Continuous 1900  
Work scheduled by: NYPA

SCH - OH - NY FWD (Import) REV (Export)  
**1550 MW 1450 MW**  
Impacts Total Transfer Capability 900 MW 450 MW  
TTC with All Lines In Service 2450 MW 1900 MW

### W49TH\_ST-E13THSTA\_345\_M54

Mon 02/12/2024 to Mon 02/12/2024  
0001 Continuous 0030  
Work scheduled by: ConEd

SPR/DUN-SOUTH FWD (Import) REV (Export)  
**3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

### W49TH\_ST-E13THSTA\_345\_M54

Mon 02/12/2024 to Mon 02/12/2024  
0330 Continuous 0400  
Work scheduled by: ConEd

SPR/DUN-SOUTH FWD (Import) REV (Export)  
**3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Friday, January 12, 2024 to Friday, July 11, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### NIAGARA\_PACKARD\_230\_62

Fri 02/16/2024 to Fri 02/16/2024  
0500 Continuous 1900  
Work scheduled by: NYPA

SCH - OH - NY  
FWD (Import) 1750 MW  
REV (Export) 1850 MW  
Impacts Total Transfer Capability 700 MW  
TTC with All Lines In Service 2450 MW  
50 MW  
1900 MW

### MILLWOOD-EASTVIEW\_345\_W85

Sat 02/17/2024 to Mon 02/19/2024  
0001 Continuous 0200  
Work scheduled by: ConEd

UPDATED by ConEd 01/12/2024 08:46

UPNY CONED  
FWD (Import) 7810 MW  
REV (Export)  
Impacts Total Transfer Capability 240 MW  
TTC with All Lines In Service 8050 MW

### SPRNBK\_345KV\_RNS4

Mon 02/19/2024 to Mon 02/19/2024  
0001 Continuous 0030  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
FWD (Import) 3200 MW  
REV (Export)  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

### SPRNBK-W49TH\_ST\_345\_M52

Mon 02/19/2024 to Mon 02/19/2024  
0001 Continuous 1930  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
FWD (Import) 3200 MW  
REV (Export)  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

### W49TH\_ST\_345KV\_5

Mon 02/19/2024 to Mon 02/19/2024  
0001 Continuous 1930  
Work scheduled by: ConEd

SCH - PJM\_HTP  
FWD (Import) 300 MW  
REV (Export)  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

### SPRNBK\_345KV\_RNS4

Mon 02/19/2024 to Mon 02/19/2024  
1900 Continuous 1930  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
FWD (Import) 3200 MW  
REV (Export)  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Friday, January 12, 2024 to Friday, July 11, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### BERKSHIR-ALPS\_\_\_345\_393

Wed 02/21/2024 to Thu 02/22/2024  
1201 Continuous 1600

ARR: 78

FWD (Import) REV (Export)

SCH - NPX\_1385 **100 MW** **100 MW**  
Impacts Total Transfer Capability 100 MW 100 MW  
TTC with All Lines In Service 200 MW 200 MW

Work scheduled by: NGrid

### BERKSHIR-ALPS\_\_\_345\_393

Wed 02/21/2024 to Thu 02/22/2024  
1201 Continuous 1600

ARR: 78

FWD (Import) REV (Export)

SCH - NE - NY **1100 MW** **1700 MW**  
Impacts Total Transfer Capability 300 MW 100 MW  
TTC with All Lines In Service 1400 MW 1800 MW

Work scheduled by: NGrid

### BERKSHIR-ALPS\_\_\_345\_393 , BERKSHIR-NORTHFLD\_345\_312

Wed 02/21/2024 to Thu 02/22/2024  
1201 1600

ARR: 78

FWD (Import) REV (Export)

SCH - NE - NY **1100 MW** **1100 MW**  
Impacts Total Transfer Capability 300 MW 700 MW  
TTC with All Lines In Service 1400 MW 1800 MW

Work scheduled by:

### BERKSHIR-NORTHFLD\_345\_312

Wed 02/21/2024 to Thu 02/22/2024  
1201 Continuous 1600

FWD (Import) REV (Export)

SCH - NPX\_1385 **100 MW** **100 MW**  
Impacts Total Transfer Capability 100 MW 100 MW  
TTC with All Lines In Service 200 MW 200 MW

Work scheduled by: NGrid

### BERKSHIR-NORTHFLD\_345\_312

Wed 02/21/2024 to Thu 02/22/2024  
1201 Continuous 1600

FWD (Import) REV (Export)

SCH - NE - NY **1300 MW**  
Impacts Total Transfer Capability 100 MW  
TTC with All Lines In Service 1400 MW

Work scheduled by: NGrid

### SCH-NE-NYISO\_LIMIT\_1100

Wed 02/21/2024 to Thu 02/22/2024  
1201 Continuous 1600

FWD (Import) REV (Export)

SCH - NE - NY **1300 MW**  
Impacts Total Transfer Capability 100 MW  
TTC with All Lines In Service 1400 MW

Work scheduled by: NGrid



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Friday, January 12, 2024 to Friday, July 11, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_900

Wed 02/21/2024 to Thu 02/22/2024  
1201 Continuous 1600  
Work scheduled by: NGrid

SCH - NE - NY FWD (Import) REV (Export)  
Impacts Total Transfer Capability 1100 MW 300 MW  
TTC with All Lines In Service 1400 MW

### SCH-NYISO-NE\_LIMIT\_900

Wed 02/21/2024 to Thu 02/22/2024  
1201 Continuous 1600  
Work scheduled by: NGrid

SCH - NE - NY FWD (Import) REV (Export)  
Impacts Total Transfer Capability 1100 MW 700 MW  
TTC with All Lines In Service 1800 MW

### MOTTHAVN-RAINEY\_\_345\_Q12

Sat 02/24/2024 to Fri 04/05/2024  
0001 Continuous 0200  
Work scheduled by: ConEd

SPR/DUN-SOUTH FWD (Import) REV (Export)  
Impacts Total Transfer Capability 3800 MW 800 MW  
TTC with All Lines In Service 4600 MW

### W49TH\_ST\_345KV\_6

Sat 02/24/2024 to Sun 03/03/2024  
0001 Continuous 2359  
Work scheduled by: ConEd

UPDATED by ConEd 12/29/2023 11:21

SCH - PJM\_HTP FWD (Import) REV (Export)  
Impacts Total Transfer Capability 310 MW 350 MW  
TTC with All Lines In Service 660 MW

### W49TH\_ST\_345KV\_8

Sat 02/24/2024 to Mon 03/04/2024  
0001 Continuous 0200  
Work scheduled by: ConEd

UPDATED by ConEd 12/29/2023 11:21

SCH - PJM\_HTP FWD (Import) REV (Export)  
Impacts Total Transfer Capability 310 MW 350 MW  
TTC with All Lines In Service 660 MW

### W49TH\_ST\_345KV\_6

Mon 03/04/2024 to Tue 04/30/2024  
0001 Continuous 0200  
Work scheduled by: ConEd

SCH - PJM\_HTP FWD (Import) REV (Export)  
Impacts Total Transfer Capability 310 MW 350 MW  
TTC with All Lines In Service 660 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Friday, January 12, 2024 to Friday, July 11, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### W49TH\_ST-E13THSTA\_345\_M55

Mon 03/04/2024 to Tue 04/30/2024

0001 Continuous 0200

Work scheduled by: ConEd

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

**3800 MW**

Impacts Total Transfer Capability

800 MW

TTC with All Lines In Service

4600 MW

### STLAWRNC-MOSES\_230\_L33P

Mon 03/04/2024 to Mon 03/04/2024

0700 Continuous 1930

Work scheduled by: NYPA

SCH - OH - NY

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

TTC with All Lines In Service

### BECK\_-PACKARD\_230\_BP76

Mon 03/04/2024 to Fri 05/24/2024

0800 Continuous 1600

Work scheduled by: NGrid

SCH - OH - NY

FWD (Import)

REV (Export)

**1800 MW**

**1350 MW**

Impacts Total Transfer Capability

650 MW

550 MW

TTC with All Lines In Service

2450 MW

1900 MW

### STLAWRNC-MOSES\_230\_L34P

Tue 03/05/2024 to Tue 03/05/2024

0700 Continuous 1930

Work scheduled by: NYPA

SCH - OH - NY

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

TTC with All Lines In Service

### SCRIBA\_-VOLNEY\_345\_21

Thu 03/07/2024 to Thu 03/14/2024

0800 Continuous 1630

Work scheduled by: NGrid

UPDATED by NGrid 12/29/2023 11:38

OSWEGO EXPORT

FWD (Import)

REV (Export)

**5250 MW**

Impacts Total Transfer Capability

0 MW

TTC with All Lines In Service

5250 MW

### SPRNBK\_345KV\_RS3 , SPRNBK\_345KV\_RS4

Mon 03/11/2024 to Mon 03/11/2024

0001 0030

Work scheduled by:

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

**3800 MW**

Impacts Total Transfer Capability

800 MW

TTC with All Lines In Service

4600 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Friday, January 12, 2024 to Friday, July 11, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### CLAY\_\_-EDIC\_\_345\_1-16

Mon 03/18/2024 to Mon 04/22/2024  
0700 Continuous 1600  
Work scheduled by: NGrid

OSWEGO EXPORT FWD (Import) REV (Export)  
**4850 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

### MOSES\_\_-ADIRNDCK\_230\_MA1

Mon 03/18/2024 to Mon 03/18/2024  
0700 Continuous 1730  
Work scheduled by: NYPA

MOSES SOUTH FWD (Import) REV (Export)  
**2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

### S.RIPLEY-DUNKIRK\_230\_68

Mon 03/18/2024 to Fri 03/22/2024  
0800 Continuous 1600  
Work scheduled by: PJM

SCH - PJ - NY FWD (Import) REV (Export)  
Impacts Total Transfer Capability  
TTC with All Lines In Service

### MILLWOOD-EASTVIEW\_345\_W85

Sun 03/24/2024 to Sat 03/30/2024  
0201 Continuous 0200  
Work scheduled by: ConEd  
UPDATED by ConEd 01/12/2024 07:57

UPNY CONED FWD (Import) REV (Export)  
**7810 MW**  
Impacts Total Transfer Capability 240 MW  
TTC with All Lines In Service 8050 MW

### SPRNBK\_345KV\_RNS3

Sun 03/24/2024 to Sun 03/24/2024  
0201 Continuous 0230  
Work scheduled by: ConEd  
UPDATED by ConEd 01/12/2024 07:57

SPR/DUN-SOUTH FWD (Import) REV (Export)  
**3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

### BERKSHIR-ALPS\_\_345\_393

Wed 03/27/2024 to Thu 03/28/2024  
1201 Continuous 1500  
Work scheduled by: NGrid  
UPDATED by ISONE 01/09/2024 16:12  
ARR: 78

SCH - NPX\_1385 FWD (Import) REV (Export)  
**100 MW 100 MW**  
Impacts Total Transfer Capability 100 MW 100 MW  
TTC with All Lines In Service 200 MW 200 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Friday, January 12, 2024 to Friday, July 11, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>BERKSHIR-ALPS___345_393</b>						FWD (Import)	REV (Export)
Wed 03/27/2024	to	Thu 03/28/2024	<u>UPDATED by ISONE 01/09/2024 16:12</u>	SCH - NE - NY		<b>1100 MW</b>	<b>1700 MW</b>
1201	Continuous	1500	ARR: 78	Impacts Total Transfer Capability		300 MW	100 MW
Work scheduled by: NGrid						TTC with All Lines In Service	1400 MW 1800 MW
<b>BERKSHIR-ALPS___345_393 , BERKSHIR-NORTHFLD_345_312</b>						FWD (Import)	REV (Export)
Wed 03/27/2024	to	Thu 03/28/2024		SCH - NE - NY		<b>1100 MW</b>	<b>1100 MW</b>
1201		1500	ARR: 78	Impacts Total Transfer Capability		300 MW	700 MW
Work scheduled by:						TTC with All Lines In Service	1400 MW 1800 MW
<b>BERKSHIR-NORTHFLD_345_312</b>						FWD (Import)	REV (Export)
Wed 03/27/2024	to	Thu 03/28/2024	<u>UPDATED by ISONE 01/09/2024 16:12</u>	SCH - NPX_1385		<b>100 MW</b>	<b>100 MW</b>
1201	Continuous	1500		Impacts Total Transfer Capability		100 MW	100 MW
Work scheduled by: NGrid						TTC with All Lines In Service	200 MW 200 MW
<b>BERKSHIR-NORTHFLD_345_312</b>						FWD (Import)	REV (Export)
Wed 03/27/2024	to	Thu 03/28/2024	<u>UPDATED by ISONE 01/09/2024 16:12</u>	SCH - NE - NY		<b>1300 MW</b>	
1201	Continuous	1500		Impacts Total Transfer Capability		100 MW	
Work scheduled by: NGrid						TTC with All Lines In Service	1400 MW
<b>SCH-NE-NYISO_LIMIT_1100</b>						FWD (Import)	REV (Export)
Wed 03/27/2024	to	Thu 03/28/2024	<u>UPDATED by ISONE 01/09/2024 16:12</u>	SCH - NE - NY		<b>1300 MW</b>	
1201	Continuous	1500		Impacts Total Transfer Capability		100 MW	
Work scheduled by: NGrid						TTC with All Lines In Service	1400 MW
<b>SCH-NE-NYISO_LIMIT_900</b>						FWD (Import)	REV (Export)
Wed 03/27/2024	to	Thu 03/28/2024	<u>UPDATED by ISONE 01/09/2024 16:12</u>	SCH - NE - NY		<b>1100 MW</b>	
1201	Continuous	1500		Impacts Total Transfer Capability		300 MW	
Work scheduled by: NGrid						TTC with All Lines In Service	1400 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Friday, January 12, 2024 to Friday, July 11, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NYISO-NE\_LIMIT\_900

Wed 03/27/2024 to Thu 03/28/2024  
1201 Continuous 1500  
Work scheduled by: NGrid

UPDATED by ISONE 01/09/2024 16:12

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1100 MW**  
700 MW  
1800 MW

### WOOD\_ST-PLSNTVLE\_345\_Y87

Wed 03/27/2024 to Sun 03/31/2024  
2200 Continuous 1800  
Work scheduled by: ConEd

CANCELLED by TO 01/12/2024 07:31

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**7470 MW**  
580 MW  
8050 MW

### SPRNBK\_345KV\_RNS3

Sat 03/30/2024 to Sat 03/30/2024  
0130 Continuous 0200  
Work scheduled by: ConEd

UPDATED by ConEd 01/12/2024 07:57

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3800 MW**  
800 MW  
4600 MW

### LADENTWN-BUCHAN\_S\_345\_Y88

Mon 04/01/2024 to Fri 05/17/2024  
0001 Continuous 2359  
Work scheduled by: ConEd

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**7695 MW**  
355 MW  
8050 MW

### SPRNBK\_345KV\_RS3 , SPRNBK\_345KV\_RS4

Mon 04/01/2024 to Mon 04/01/2024  
2130 2200  
Work scheduled by:

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3800 MW**  
800 MW  
4600 MW

### NIAGARA-DYSINGER\_345\_ND1

Mon 04/08/2024 to Fri 04/12/2024  
0500 Continuous 1900  
Work scheduled by: NYPA

DYSINGER EAST  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**2700 MW**  
500 MW  
3200 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Friday, January 12, 2024 to Friday, July 11, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### LINDN\_CG-LNDVFT\_\_345\_V-3022

Mon 04/08/2024 to Sat 04/13/2024  
0800 Continuous 1500  
Work scheduled by: PJM

	FWD (Import)	REV (Export)
SCH - PJM_VFT	0 MW	0 MW
Impacts Total Transfer Capability	315 MW	315 MW
TTC with All Lines In Service	315 MW	315 MW

### NIAGARA\_DYSINGER\_345\_ND2

Mon 04/15/2024 to Fri 04/19/2024  
0500 Continuous 1900  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
DYSINGER EAST	2700 MW	
Impacts Total Transfer Capability	500 MW	
TTC with All Lines In Service	3200 MW	

### SCH-NPX\_1385-NYISO\_LIMIT\_100

Mon 04/15/2024 to Fri 04/26/2024  
0600 Continuous 2200  
Work scheduled by: ISONE

	FWD (Import)	REV (Export)
SCH - NPX_1385	100 MW	
Impacts Total Transfer Capability	100 MW	
TTC with All Lines In Service	200 MW	

### GOETHALS\_345KV\_5

Thu 04/18/2024 to Thu 04/18/2024  
0001 Continuous 0030  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
STATEN ISLAND		
Impacts Total Transfer Capability		
TTC with All Lines In Service		

### LINDEN\_-GOETHALS\_230\_A2253

Thu 04/18/2024 to Thu 04/25/2024  
0001 Continuous 0200  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - PJ - NY		
Impacts Total Transfer Capability		
TTC with All Lines In Service		

### LINDN\_CG-LNDVFT\_\_345\_V-3022

Thu 04/18/2024 to Thu 04/18/2024  
1500 Continuous 1800  
Work scheduled by: PJM

	FWD (Import)	REV (Export)
SCH - PJM_VFT	0 MW	0 MW
Impacts Total Transfer Capability	315 MW	315 MW
TTC with All Lines In Service	315 MW	315 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Friday, January 12, 2024 to Friday, July 11, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### W49TH\_ST\_345KV\_8

Sat 04/20/2024 to Thu 04/25/2024  
0001 Continuous 0200  
Work scheduled by: ConEd

SCH - PJM\_HTP  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 310 MW  
REV (Export) 350 MW  
660 MW

### PANNELL\_-CLAY\_\_\_345\_1

Mon 04/22/2024 to Fri 04/26/2024  
0700 Continuous 1530  
Work scheduled by: NYPA

WEST CENTRAL  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 1300 MW  
REV (Export) 950 MW  
2250 MW

### GOETHALS\_345KV\_5

Thu 04/25/2024 to Thu 04/25/2024  
0130 Continuous 0200  
Work scheduled by: ConEd

STATEN ISLAND  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import)  
REV (Export)

### DYSINGER-STA\_255\_345\_DH1

Fri 04/26/2024 to Tue 05/07/2024  
0500 Continuous 1900  
Work scheduled by: NYPA

DYSINGER EAST  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 2850 MW  
REV (Export) 350 MW  
3200 MW

### MARCY\_-FRASANNX\_345\_UCC2-41

Mon 04/29/2024 to Tue 07/16/2024  
0700 Continuous 1530  
Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 3225 MW  
REV (Export) 500 MW  
3725 MW

### PANNELL\_-CLAY\_\_\_345\_2

Mon 04/29/2024 to Fri 05/03/2024  
0700 Continuous 1530  
Work scheduled by: NYPA

WEST CENTRAL  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 1300 MW  
REV (Export) 950 MW  
2250 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Friday, January 12, 2024 to Friday, July 11, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### W49TH\_ST\_345KV\_5

Wed 05/01/2024 to Fri 05/03/2024  
0001 Continuous 0200  
Work scheduled by: ConEd

SCH - PJM\_HTP FWD (Import) REV (Export)  
**300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

### W49TH\_ST\_345KV\_7

Wed 05/01/2024 to Fri 05/03/2024  
0001 Continuous 0200  
Work scheduled by: ConEd

SCH - PJM\_HTP FWD (Import) REV (Export)  
**300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

### SHOR\_NPX-SHOREHAM\_138\_CSC

Mon 05/06/2024 to Fri 05/10/2024  
0600 Continuous 1800  
Work scheduled by: LI

SCH - NPX\_CSC FWD (Import) REV (Export)  
**0 MW** **0 MW**  
Impacts Total Transfer Capability 330 MW 330 MW  
TTC with All Lines In Service 330 MW 330 MW

### NIAGARA\_ROBNSNRD\_230\_64

Mon 05/13/2024 to Fri 05/17/2024  
0500 Continuous 1900  
Work scheduled by: NYPA

SCH - OH - NY FWD (Import) REV (Export)  
**1500 MW**  
Impacts Total Transfer Capability 150 MW  
TTC with All Lines In Service 1650 MW

### BUCHAN\_S-MILLWOOD\_345\_W97

Fri 05/17/2024 to Sat 05/18/2024  
0001 Continuous 0200  
Work scheduled by: ConEd

UPNY CONED FWD (Import) REV (Export)  
**8015 MW**  
Impacts Total Transfer Capability 35 MW  
TTC with All Lines In Service 8050 MW

### FITZPTRK-EDIC\_\_\_345\_FE-1

Mon 05/20/2024 to Fri 05/24/2024  
0700 Continuous 1530  
Work scheduled by: NYPA

OSWEGO EXPORT FWD (Import) REV (Export)  
**4800 MW**  
Impacts Total Transfer Capability 450 MW  
TTC with All Lines In Service 5250 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Friday, January 12, 2024 to Friday, July 11, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>FITZPTRK-EDIC__345_FE-1</b>				FWD (Import)	REV (Export)
Mon 05/20/2024	to	Fri 05/24/2024	CENTRAL EAST - VC	<b>3520 MW</b>	
0700	Continuous	1530	Impacts Total Transfer Capability	205 MW	
Work scheduled by: NYPA			TTC with All Lines In Service	3725 MW	
<b>FITZPTRK-EDIC__345_FE-1</b>				FWD (Import)	REV (Export)
Tue 05/28/2024	to	Fri 05/31/2024	OSWEGO EXPORT	<b>4800 MW</b>	
0700	Continuous	1530	Impacts Total Transfer Capability	450 MW	
Work scheduled by: NYPA			TTC with All Lines In Service	5250 MW	
<b>FITZPTRK-EDIC__345_FE-1</b>				FWD (Import)	REV (Export)
Tue 05/28/2024	to	Fri 05/31/2024	CENTRAL EAST - VC	<b>3520 MW</b>	
0700	Continuous	1530	Impacts Total Transfer Capability	205 MW	
Work scheduled by: NYPA			TTC with All Lines In Service	3725 MW	
<b>BECK__-PACKARD_230_BP76</b>				FWD (Import)	REV (Export)
Fri 05/31/2024	to	Fri 05/31/2024	SCH - OH - NY	<b>1600 MW</b>	<b>1050 MW</b>
0730	Continuous	1630	Impacts Total Transfer Capability	450 MW	600 MW
Work scheduled by: NGrid			TTC with All Lines In Service	2050 MW	1650 MW
<b>CHASLAKE-PORTER__230_11</b>				FWD (Import)	REV (Export)
Sat 06/01/2024	to	Wed 07/03/2024	MOSES SOUTH	<b>2100 MW</b>	
0530	Continuous	1600	Impacts Total Transfer Capability	1050 MW	
Work scheduled by: NGrid			TTC with All Lines In Service	3150 MW	
<b>NIAGARA_345_230_AT4</b>				FWD (Import)	REV (Export)
Tue 06/11/2024	to	Wed 06/12/2024	SCH - OH - NY		<b>1200 MW</b>
0500	Continuous	1900	Impacts Total Transfer Capability	450 MW	
Work scheduled by: NYPA			TTC with All Lines In Service		1650 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Friday, January 12, 2024 to Friday, July 11, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### CHASLAKE-PORTER\_\_230\_11

Mon 07/08/2024 to Fri 08/30/2024

0700 Continuous 1900

Work scheduled by: NGrid

MOSES SOUTH

FWD (Import)

REV (Export)

**2100 MW**

Impacts Total Transfer Capability

1050 MW

TTC with All Lines In Service

3150 MW

### DYSINGER-STA\_255\_345\_DH2

Mon 07/15/2024 to Sun 08/04/2024

0500 Continuous 1900

Work scheduled by: NYPA

DYSINGER EAST

FWD (Import)

REV (Export)

**2850 MW**

Impacts Total Transfer Capability

350 MW

TTC with All Lines In Service

3200 MW

### MOSES\_\_-ADIRNDCK\_230\_MA2

Mon 09/02/2024 to Mon 09/02/2024

0700 Continuous 1730

Work scheduled by: NYPA

CANCELLED by TO 01/09/2024 14:19

MOSES SOUTH

FWD (Import)

REV (Export)

**2100 MW**

Impacts Total Transfer Capability

1050 MW

TTC with All Lines In Service

3150 MW

### CHASLAKE-PORTER\_\_230\_11

Tue 09/03/2024 to Fri 11/15/2024

0530 Continuous 2000

Work scheduled by: NGrid

MOSES SOUTH

FWD (Import)

REV (Export)

**2100 MW**

Impacts Total Transfer Capability

1050 MW

TTC with All Lines In Service

3150 MW

### MOSES\_\_-ADIRNDCK\_230\_MA2

Tue 09/03/2024 to Fri 11/15/2024

0700 Continuous 1730

Work scheduled by: NYPA

CANCELLED by TO 01/09/2024 14:18

MOSES SOUTH

FWD (Import)

REV (Export)

**2100 MW**

Impacts Total Transfer Capability

1050 MW

TTC with All Lines In Service

3150 MW

### FITZPTRK-EDIC\_\_345\_FE-1

Mon 09/09/2024 to Mon 09/09/2024

0001 Continuous 0100

Work scheduled by: NYPA

OSWEGO EXPORT

FWD (Import)

REV (Export)

**4800 MW**

Impacts Total Transfer Capability

450 MW

TTC with All Lines In Service

5250 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Friday, January 12, 2024 to Friday, July 11, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>FITZPTRK-EDIC__345_FE-1</b>				FWD (Import)	REV (Export)
Mon 09/09/2024	to	Mon 09/09/2024	CENTRAL EAST - VC	<b>3520 MW</b>	
0001	Continuous	0100	Impacts Total Transfer Capability	205 MW	
Work scheduled by: NYPA			TTC with All Lines In Service	3725 MW	
<b>ROCHESTR-PANNELL__345_RP1</b>				FWD (Import)	REV (Export)
Mon 09/09/2024	to	Fri 09/13/2024	DYSINGER EAST	<b>2300 MW</b>	
0700	Continuous	1530	Impacts Total Transfer Capability	900 MW	
Work scheduled by: NYPA			TTC with All Lines In Service	3200 MW	
<b>MOTTHAVN-RAINEY__345_Q11</b>				FWD (Import)	REV (Export)
Sun 09/15/2024	to	Sat 10/26/2024	SPR/DUN-SOUTH	<b>3800 MW</b>	
0001	Continuous	0300	Impacts Total Transfer Capability	800 MW	
Work scheduled by: ConEd			TTC with All Lines In Service	4600 MW	
<b>DYSINGER-STA_255__345_DH2</b>				FWD (Import)	REV (Export)
Mon 09/16/2024	to	Mon 10/28/2024	DYSINGER EAST	<b>2850 MW</b>	
0500	Continuous	1900	Impacts Total Transfer Capability	350 MW	
Work scheduled by: NYPA			TTC with All Lines In Service	3200 MW	
<b>ROCHESTR-PANNELL__345_RP2</b>				FWD (Import)	REV (Export)
Mon 09/16/2024	to	Fri 09/20/2024	DYSINGER EAST	<b>2300 MW</b>	
0700	Continuous	1530	Impacts Total Transfer Capability	900 MW	
Work scheduled by: NYPA			TTC with All Lines In Service	3200 MW	
<b>STLAWRNC-MOSES__230_L34P</b>				FWD (Import)	REV (Export)
Mon 09/16/2024	to	Fri 09/20/2024	SCH - OH - NY		
0700	Continuous	1530	Impacts Total Transfer Capability		
Work scheduled by: NYPA			TTC with All Lines In Service		

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Friday, January 12, 2024 to Friday, July 11, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>PANNELL-CLAY___345_1</b>				FWD (Import)	REV (Export)
Mon 09/23/2024	to	Fri 09/27/2024	WEST CENTRAL	<b>1300 MW</b>	
0700	Continuous	1530	Impacts Total Transfer Capability	950 MW	
Work scheduled by: NYPA			TTC with All Lines In Service	2250 MW	
<b>STLAWRNC-MOSES___230_L34P</b>				FWD (Import)	REV (Export)
Mon 09/23/2024	to	Fri 09/27/2024	SCH - OH - NY		
0700	Continuous	1530	Impacts Total Transfer Capability		
Work scheduled by: NYPA			TTC with All Lines In Service		
<b>FITZPTRK-EDIC___345_FE-1</b>				FWD (Import)	REV (Export)
Thu 09/26/2024	to	Thu 09/26/2024	OSWEGO EXPORT	<b>4800 MW</b>	
0900	Continuous	1000	Impacts Total Transfer Capability	450 MW	
Work scheduled by: NYPA			TTC with All Lines In Service	5250 MW	
<b>FITZPTRK-EDIC___345_FE-1</b>				FWD (Import)	REV (Export)
Thu 09/26/2024	to	Thu 09/26/2024	CENTRAL EAST - VC	<b>3520 MW</b>	
0900	Continuous	1000	Impacts Total Transfer Capability	205 MW	
Work scheduled by: NYPA			TTC with All Lines In Service	3725 MW	
<b>STLAWRNC-MOSES___230_L34P</b>				FWD (Import)	REV (Export)
Mon 09/30/2024	to	Fri 10/04/2024	SCH - OH - NY		
0700	Continuous	1530	Impacts Total Transfer Capability		
Work scheduled by: NYPA			TTC with All Lines In Service		
<b>FITZPTRK-EDIC___345_FE-1</b>				FWD (Import)	REV (Export)
Mon 09/30/2024	to	Fri 10/04/2024	OSWEGO EXPORT	<b>4800 MW</b>	
1700	Continuous	1530	Impacts Total Transfer Capability	450 MW	
Work scheduled by: NYPA			TTC with All Lines In Service	5250 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Friday, January 12, 2024 to Friday, July 11, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### FITZPTRK-EDIC\_345\_FE-1

Mon 09/30/2024 to Fri 10/04/2024  
1700 Continuous 1530  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
CENTRAL EAST - VC	<b>3520 MW</b>	
Impacts Total Transfer Capability	205 MW	
TTC with All Lines In Service	3725 MW	

### BECK\_-NIAGARA\_345\_PA302

Mon 10/07/2024 to Fri 10/11/2024  
0500 Continuous 1900  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - OH - NY	<b>1000 MW</b>	<b>850 MW</b>
Impacts Total Transfer Capability	1050 MW	800 MW
TTC with All Lines In Service	2050 MW	1650 MW

### NEPTUNE\_DUFFYAVE\_345\_NEPTUNE

Mon 10/07/2024 to Fri 10/11/2024  
0600 Continuous 1600  
Work scheduled by: LI

	FWD (Import)	REV (Export)
SCH - PJM_NEPTUNE	<b>0 MW</b>	
Impacts Total Transfer Capability	660 MW	
TTC with All Lines In Service	660 MW	

### NEWBRDGE\_345\_138\_BK\_1

Mon 10/07/2024 to Fri 10/11/2024  
0600 Continuous 1600  
Work scheduled by: LI

	FWD (Import)	REV (Export)
SCH - PJM_NEPTUNE	<b>375 MW</b>	
Impacts Total Transfer Capability	285 MW	
TTC with All Lines In Service	660 MW	

### NEWBRDGE\_345\_138\_BK\_2

Mon 10/07/2024 to Fri 10/11/2024  
0600 Continuous 1600  
Work scheduled by: LI

	FWD (Import)	REV (Export)
SCH - PJM_NEPTUNE	<b>375 MW</b>	
Impacts Total Transfer Capability	285 MW	
TTC with All Lines In Service	660 MW	

### NEWBRDGE-DUFFYAVE\_345\_501

Mon 10/07/2024 to Fri 10/11/2024  
0600 Continuous 1600  
Work scheduled by: LI

	FWD (Import)	REV (Export)
SCH - PJM_NEPTUNE	<b>0 MW</b>	
Impacts Total Transfer Capability	660 MW	
TTC with All Lines In Service	660 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Friday, January 12, 2024 to Friday, July 11, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SHOR\_NPX-SHOREHAM\_138\_CSC

Mon 10/07/2024 to Fri 10/11/2024  
0600 Continuous 1800

Work scheduled by: LI

SCH - NPX\_CSC

FWD (Import)

REV (Export)

0 MW

0 MW

Impacts Total Transfer Capability

330 MW

330 MW

TTC with All Lines In Service

330 MW

330 MW

### MARCY\_\_-FRASANNX\_345\_UCC2-41

Wed 10/09/2024 to Thu 10/10/2024  
0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC

FWD (Import)

REV (Export)

3225 MW

Impacts Total Transfer Capability

500 MW

TTC with All Lines In Service

3725 MW

### MARCY\_\_-N.SCTLND\_345\_18

Tue 10/15/2024 to Thu 10/17/2024  
0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC

FWD (Import)

REV (Export)

2665 MW

Impacts Total Transfer Capability

1060 MW

TTC with All Lines In Service

3725 MW

### MARCY\_\_-N.SCTLND\_345\_18

Mon 10/21/2024 to Fri 10/25/2024  
0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC

FWD (Import)

REV (Export)

2665 MW

Impacts Total Transfer Capability

1060 MW

TTC with All Lines In Service

3725 MW

### MARCY\_\_345KV\_CSC

Mon 10/28/2024 to Sun 11/10/2024  
0700 Continuous 1530

Work scheduled by: NYPA

CENTRAL EAST - VC

FWD (Import)

REV (Export)

3650 MW

Impacts Total Transfer Capability

75 MW

TTC with All Lines In Service

3725 MW

### DYSINGER-STA\_255\_345\_DH2

Tue 10/29/2024 to Thu 10/31/2024  
0500 Continuous 2100

Work scheduled by: NYPA

DYSINGER EAST

FWD (Import)

REV (Export)

2850 MW

Impacts Total Transfer Capability

350 MW

TTC with All Lines In Service

3200 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Friday, January 12, 2024 to Friday, July 11, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### DYSINGER-STA\_255\_345\_DH1

Mon 11/04/2024 to Sat 11/16/2024  
0500 Continuous 1900  
Work scheduled by: NYPA

DYSINGER EAST  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **2850 MW**  
350 MW  
3200 MW

### BECK\_\_-NIAGARA\_230\_PA27

Fri 11/15/2024 to Fri 11/15/2024  
0500 Continuous 1900  
Work scheduled by: NYPA

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **2100 MW**  
350 MW  
2450 MW

### CHATGUAY-MASSENA\_765\_7040

Sat 11/16/2024 to Fri 11/29/2024  
0001 Continuous 2359  
Work scheduled by: NYPA

SCH - HQ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **0 MW**  
1500 MW  
1500 MW  
REV (Export) **0 MW**  
1000 MW  
1000 MW

### CHATGUAY-MASSENA\_765\_7040

Sat 11/16/2024 to Fri 11/29/2024  
0001 Continuous 2359  
Work scheduled by: NYPA

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **1550 MW**  
1600 MW  
3150 MW  
REV (Export)

### CHATGUAY-MASSENA\_765\_7040 , MASSENA\_-MARCY\_\_765\_MSU1

Sat 11/16/2024 to Fri 11/29/2024  
0001 2359  
Work scheduled by:

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **500 MW**  
2650 MW  
3150 MW  
REV (Export)

### MARCY\_\_765\_345\_AT1

Sat 11/16/2024 to Fri 11/29/2024  
0001 Continuous 2359  
Work scheduled by: NYPA

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **1750 MW**  
1400 MW  
3150 MW  
REV (Export)

ARR: 19

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Friday, January 12, 2024 to Friday, July 11, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MARCY\_\_765\_345\_AT2

Sat 11/16/2024 to Fri 11/29/2024  
0001 Continuous 2359

ARR: 19

FWD (Import) REV (Export)

MOSES SOUTH 1700 MW  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

### MASSENA\_-MARCY\_\_765\_MSU1

Sat 11/16/2024 to Fri 11/29/2024  
0001 Continuous 2359

FWD (Import) REV (Export)

SCH - HQ\_CEDARS 90 MW  
Impacts Total Transfer Capability 189 MW  
TTC with All Lines In Service 279 MW

### MASSENA\_-MARCY\_\_765\_MSU1

Sat 11/16/2024 to Fri 11/29/2024  
0001 Continuous 2359

FWD (Import) REV (Export)

SCH - HQ - NY 475 MW 1000 MW  
Impacts Total Transfer Capability 1025 MW 0 MW  
TTC with All Lines In Service 1500 MW 1000 MW

### MASSENA\_-MARCY\_\_765\_MSU1

Sat 11/16/2024 to Fri 11/29/2024  
0001 Continuous 2359

FWD (Import) REV (Export)

MOSES SOUTH 500 MW  
Impacts Total Transfer Capability 2650 MW  
TTC with All Lines In Service 3150 MW

### MASSENA\_-MARCY\_\_765\_MSU1

Sat 11/16/2024 to Fri 11/29/2024  
0001 Continuous 2359

FWD (Import) REV (Export)

CENTRAL EAST - VC 2595 MW  
Impacts Total Transfer Capability 1130 MW  
TTC with All Lines In Service 3725 MW

### MOSES\_-MASSENA\_230\_MMS2 , MOSES\_-MASSENA\_230\_MMS1

Sat 11/16/2024 to Fri 11/29/2024  
0001 Continuous 2359

FWD (Import) REV (Export)

SCH - HQ\_CEDARS 90 MW  
Impacts Total Transfer Capability 189 MW  
TTC with All Lines In Service 279 MW

Work scheduled by:



NYISO TRANSFER LIMITATIONS

Seasonal Limits Friday, January 12, 2024 to Friday, July 11, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES__-MASSENA__230_MMS2 , MOSES__-MASSENA__230_MMS1				FWD (Import)	REV (Export)
Sat 11/16/2024	to	Fri 11/29/2024	SCH - HQ - NY	850 MW	0 MW
0001		2359	Impacts Total Transfer Capability	650 MW	1000 MW
Work scheduled by:			TTC with All Lines In Service	1500 MW	1000 MW
ADIRNDCK-PORTER__230_12				FWD (Import)	REV (Export)
Sun 12/01/2024	to	Sat 05/31/2025	MOSES SOUTH	2300 MW	
0530	Continuous	1700	Impacts Total Transfer Capability	850 MW	
Work scheduled by: NGrid			TTC with All Lines In Service	3150 MW	