

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, January 18, 2024 to Thursday, July 17, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONP_-FARRAGUT_345_B3402						FWD (Import)	REV (Export)
Mon 01/15/2018	to	Sun 03/31/2024			SCH - PJ - NY		
0001	Continuous	2359	<u>EXT FORCED by ConEd 12/20/2023 15:20</u>		Impacts Total Transfer Capability		
Work scheduled by: ConEd						TTC with All Lines In Service	
MARION_-FARRAGUT_345_C3403						FWD (Import)	REV (Export)
Mon 01/15/2018	to	Sun 03/31/2024			SCH - PJ - NY		
0001	Continuous	2359	<u>EXT FORCED by ConEd 12/20/2023 15:20</u>		Impacts Total Transfer Capability		
Work scheduled by: ConEd						TTC with All Lines In Service	
MARION_-FARRAGUT_345_C3403 , HUDSONP_-FARRAGUT_345_B3402						FWD (Import)	REV (Export)
Mon 01/15/2018	to	Sun 03/31/2024			SCH - PJ - NY	2400 MW	2400 MW
0001		2359			Impacts Total Transfer Capability	150 MW	250 MW
Work scheduled by:						TTC with All Lines In Service	2550 MW 2650 MW
HOMRC_NY-MAINS_NY_345_47						FWD (Import)	REV (Export)
Fri 09/08/2023	to	Wed 01/31/2024			SCH - PJ - NY		
1612	Continuous	2359	<u>EXT FORCED by PJM 12/14/2023 17:00</u>		Impacts Total Transfer Capability		
Work scheduled by: PJM						TTC with All Lines In Service	
SCH-IMO-NYISO_LIMIT_1900						FWD (Import)	REV (Export)
Wed 11/01/2023	to	Tue 04/30/2024			SCH - OH - NY	2200 MW	
0001	Continuous	2359			Impacts Total Transfer Capability	250 MW	
Work scheduled by: IESO						TTC with All Lines In Service	2450 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, January 18, 2024 to Thursday, July 17, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_6

Fri 12/15/2023 to Fri 02/16/2024
0000 Continuous 2359

EXT FORCED by ConEd 12/20/2023 15:29

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

3800 MW

Impacts Total Transfer Capability

800 MW

TTC with All Lines In Service

4600 MW

Work scheduled by: ConEd

DUNWODIE-SHORE_RD_345_Y50

Fri 12/15/2023 to Fri 02/16/2024
0000 Continuous 2359

EXT FORCED by ConEd 12/20/2023 15:29

CONED - LIPA

FWD (Import)

REV (Export)

800 MW

Impacts Total Transfer Capability

700 MW

TTC with All Lines In Service

1500 MW

Work scheduled by: ConEd

SHORE_RD_345_138_BK 1

Fri 12/15/2023 to Fri 02/16/2024
0000 Continuous 2359

EXT FORCED by ConEd 12/20/2023 15:29

CONED - LIPA

FWD (Import)

REV (Export)

1350 MW

Impacts Total Transfer Capability

150 MW

TTC with All Lines In Service

1500 MW

Work scheduled by: ConEd

SHORE_RD_345_138_BK 2

Fri 12/15/2023 to Fri 02/16/2024
0000 Continuous 2359

EXT FORCED by ConEd 12/20/2023 15:29

CONED - LIPA

FWD (Import)

REV (Export)

1350 MW

Impacts Total Transfer Capability

150 MW

TTC with All Lines In Service

1500 MW

Work scheduled by: ConEd

DUNWODIE-MOTTHAVN_345_71

Sun 12/24/2023 to Fri 03/01/2024
1827 Continuous 2300

EXT FORCED by ConEd 01/02/2024 14:46

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

3800 MW

Impacts Total Transfer Capability

800 MW

TTC with All Lines In Service

4600 MW

Work scheduled by: ConEd

ADIRNDCK-PORTER__230_12

Tue 01/02/2024 to Fri 05/31/2024
0630 Continuous 1730

UPDATED by NGrid 07/11/2023 11:44

MOSES SOUTH

FWD (Import)

REV (Export)

2300 MW

Impacts Total Transfer Capability

850 MW

TTC with All Lines In Service

3150 MW

Work scheduled by: NGrid

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, January 18, 2024 to Thursday, July 17, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-IMO-NYISO_LIMIT_1750

Tue 01/02/2024 to Fri 05/31/2024
0630 Continuous 1730

UPDATED by NGrid 07/11/2023 11:44

SCH - OH - NY

FWD (Import)

REV (Export)

2050 MW

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

2450 MW

Work scheduled by: NGrid

FRASER__345_FRASER SVC

Tue 01/02/2024 to Fri 03/01/2024
0700 Continuous 1530

CENTRAL EAST - VC

FWD (Import)

REV (Export)

3655 MW

Impacts Total Transfer Capability

70 MW

TTC with All Lines In Service

3725 MW

Work scheduled by: NYPA

SCH-NE-NYISO_LIMIT_1100

Fri 01/12/2024 to Mon 01/22/2024
0001 Continuous 2200

UPDATED by ConEd 01/14/2024 11:06

SCH - NE - NY

FWD (Import)

REV (Export)

1300 MW

Impacts Total Transfer Capability

100 MW

TTC with All Lines In Service

1400 MW

Work scheduled by: ConEd

BECK__-PACKARD_230_BP76

Mon 01/15/2024 to Sun 01/21/2024
0400 Continuous 1700

SCH - OH - NY

FWD (Import)

REV (Export)

1800 MW

1350 MW

Impacts Total Transfer Capability

650 MW

550 MW

TTC with All Lines In Service

2450 MW

1900 MW

Work scheduled by: NGrid

SCH-IMO-NYISO_LIMIT_1300

Mon 01/15/2024 to Sun 01/21/2024
0400 Continuous 1700

SCH - OH - NY

FWD (Import)

REV (Export)

1600 MW

Impacts Total Transfer Capability

850 MW

TTC with All Lines In Service

2450 MW

Work scheduled by: NGrid

SCH-NE-NYISO_LIMIT_400

Wed 01/17/2024 to Thu 01/18/2024
2300 Continuous 0659

UPDATED by ConEd 01/14/2024 11:06

SCH - NE - NY

FWD (Import)

REV (Export)

600 MW

Impacts Total Transfer Capability

800 MW

TTC with All Lines In Service

1400 MW

Work scheduled by: ConEd

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, January 18, 2024 to Thursday, July 17, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NE-NYISO_LIMIT_400

Thu 01/18/2024 to Fri 01/19/2024
2300 Continuous 0659
Work scheduled by: ConEd

UPDATED by ConEd 01/14/2024 11:06

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
600 MW
800 MW
1400 MW

SCH-NE-NYISO_LIMIT_400

Fri 01/19/2024 to Sat 01/20/2024
2300 Continuous 0659
Work scheduled by: ConEd

UPDATED by ConEd 01/14/2024 11:06

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
600 MW
800 MW
1400 MW

SCH-NE-NYISO_LIMIT_400

Sat 01/20/2024 to Sun 01/21/2024
2300 Continuous 0659
Work scheduled by: ConEd

UPDATED by ConEd 01/14/2024 11:06

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
600 MW
800 MW
1400 MW

SCH-NE-NYISO_LIMIT_400

Sun 01/21/2024 to Mon 01/22/2024
2300 Continuous 0659
Work scheduled by: ConEd

UPDATED by ConEd 01/14/2024 11:06

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
600 MW
800 MW
1400 MW

SCH-IMO_NY_NIAG_NRTH_BUS_W/BB

Fri 01/26/2024 to Fri 01/26/2024
0500 Continuous 1900
Work scheduled by: NYPA

SCH - OH - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
1550 MW **1450 MW**
900 MW 450 MW
2450 MW 1900 MW

EDIC__-PRINCTWN_345_351

Thu 02/01/2024 to Thu 02/01/2024
0700 Daily 1700
Work scheduled by: NGrid

UPDATED by LS 01/18/2024 14:00

CENTRAL EAST - VC
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
3335 MW
390 MW
3725 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, January 18, 2024 to Thursday, July 17, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CLAY___-EDIC___345_2-15					FWD (Import)	REV (Export)
Mon 02/05/2024	to	Mon 03/11/2024		OSWEGO EXPORT	4850 MW	
0700	Continuous	1600		Impacts Total Transfer Capability	400 MW	
Work scheduled by: NGrid				TTC with All Lines In Service	5250 MW	
MILLWOOD-EASTVIEW_345_W82					FWD (Import)	REV (Export)
Wed 02/07/2024	to	Sun 02/11/2024	<u>UPDATED by ConEd 01/12/2024 08:51</u>	UPNY CONED	7810 MW	
0001	Continuous	2200		Impacts Total Transfer Capability	240 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	8050 MW	
EDIC___-PRINCTWN_345_352					FWD (Import)	REV (Export)
Thu 02/08/2024	to	Thu 02/08/2024		CENTRAL EAST - VC	3335 MW	
0700	Continuous	1700		Impacts Total Transfer Capability	390 MW	
Work scheduled by: NGrid				TTC with All Lines In Service	3725 MW	
SCH-IMO_NY_NIAG_SOUTH_BUS_W/BB					FWD (Import)	REV (Export)
Fri 02/09/2024	to	Fri 02/09/2024		SCH - OH - NY	1550 MW	1450 MW
0500	Continuous	1900		Impacts Total Transfer Capability	900 MW	450 MW
Work scheduled by: NYPA				TTC with All Lines In Service	2450 MW	1900 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, January 18, 2024 to Thursday, July 17, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST-E13THSTA_345_M54

Mon 02/12/2024 to Mon 02/12/2024
0001 Continuous 0030
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	3800 MW	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

W49TH_ST-E13THSTA_345_M54

Mon 02/12/2024 to Mon 02/12/2024
0330 Continuous 0400
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	3800 MW	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

ROTTDAM-EASTOVER_230_38

Wed 02/14/2024 to Fri 02/16/2024
0700 Continuous 1700
Work scheduled by: NGrid
ARR: 77

	FWD (Import)	REV (Export)
SCH - NE - NY	1400 MW	
Impacts Total Transfer Capability	0 MW	
TTC with All Lines In Service	1400 MW	

NIAGARA_PACKARD_230_62

Fri 02/16/2024 to Fri 02/16/2024
0500 Continuous 1900
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - OH - NY	1750 MW	1850 MW
Impacts Total Transfer Capability	700 MW	50 MW
TTC with All Lines In Service	2450 MW	1900 MW

MILLWOOD-EASTVIEW_345_W85

Sat 02/17/2024 to Mon 02/19/2024
0001 Continuous 0200
Work scheduled by: ConEd
UPDATED by ConEd 01/12/2024 08:46

	FWD (Import)	REV (Export)
UPNY CONED	7810 MW	
Impacts Total Transfer Capability	240 MW	
TTC with All Lines In Service	8050 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, January 18, 2024 to Thursday, July 17, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBKR_345KV_RNS4						FWD (Import)	REV (Export)
Mon 02/19/2024	to	Mon 02/19/2024	<u>CANCELLED by TO 01/17/2024 07:22</u>	SPR/DUN-SOUTH	3200 MW		
0001	Continuous	0030		Impacts Total Transfer Capability	1400 MW		
Work scheduled by: ConEd				TTC with All Lines In Service	4600 MW		
SPRNBKR_W49TH_ST_345_M52						FWD (Import)	REV (Export)
Mon 02/19/2024	to	Mon 02/19/2024	<u>CANCELLED by TO 01/17/2024 07:22</u>	SPR/DUN-SOUTH	3200 MW		
0001	Continuous	1930		Impacts Total Transfer Capability	1400 MW		
Work scheduled by: ConEd				TTC with All Lines In Service	4600 MW		
W49TH_ST_345KV_5						FWD (Import)	REV (Export)
Mon 02/19/2024	to	Mon 02/19/2024	<u>CANCELLED by TO 01/17/2024 07:22</u>	SCH - PJM_HTP	300 MW		
0001	Continuous	1930		Impacts Total Transfer Capability	360 MW		
Work scheduled by: ConEd				TTC with All Lines In Service	660 MW		
SPRNBKR_345KV_RNS4						FWD (Import)	REV (Export)
Mon 02/19/2024	to	Mon 02/19/2024	<u>CANCELLED by TO 01/17/2024 07:22</u>	SPR/DUN-SOUTH	3200 MW		
1900	Continuous	1930		Impacts Total Transfer Capability	1400 MW		
Work scheduled by: ConEd				TTC with All Lines In Service	4600 MW		
BERKSHIR-ALPS_345_393						FWD (Import)	REV (Export)
Wed 02/21/2024	to	Thu 02/22/2024	<u>UPDATED by ISONE 01/18/2024 13:55</u>	SCH - NPX_1385	100 MW	100 MW	
1201	Continuous	1500	ARR: 78	Impacts Total Transfer Capability	100 MW	100 MW	
Work scheduled by: NGrid				TTC with All Lines In Service	200 MW	200 MW	
BERKSHIR-ALPS_345_393						FWD (Import)	REV (Export)
Wed 02/21/2024	to	Thu 02/22/2024	<u>UPDATED by ISONE 01/18/2024 13:55</u>	SCH - NE - NY	1100 MW	1700 MW	
1201	Continuous	1500	ARR: 78	Impacts Total Transfer Capability	300 MW	100 MW	
Work scheduled by: NGrid				TTC with All Lines In Service	1400 MW	1800 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, January 18, 2024 to Thursday, July 17, 2025

CENTRAL EAST 7550 MW
 CENTRAL EAST - VC 3725 MW
 TOTAL EAST 6150 MW
 UPNY CONED 8050 MW
 SPR/DUN-SOUTH 4600 MW
 DYSINGER EAST 3200 MW
 MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BERKSHIR-ALPS___345_393 , BERKSHIR-NORTHFLD_345_312					FWD (Import)	REV (Export)
Wed 02/21/2024	to	Thu 02/22/2024		SCH - NE - NY	1100 MW	1100 MW
1201		1500		Impacts Total Transfer Capability	300 MW	700 MW
Work scheduled by: ARR: 78				TTC with All Lines In Service	1400 MW	1800 MW
BERKSHIR-NORTHFLD_345_312					FWD (Import)	REV (Export)
Wed 02/21/2024	to	Thu 02/22/2024	<u>UPDATED by ISONE 01/18/2024 13:55</u>	SCH - NPX_1385	100 MW	100 MW
1201	Continuous	1500		Impacts Total Transfer Capability	100 MW	100 MW
Work scheduled by: NGrid				TTC with All Lines In Service	200 MW	200 MW
BERKSHIR-NORTHFLD_345_312					FWD (Import)	REV (Export)
Wed 02/21/2024	to	Thu 02/22/2024	<u>UPDATED by ISONE 01/18/2024 13:55</u>	SCH - NE - NY	1300 MW	
1201	Continuous	1500		Impacts Total Transfer Capability	100 MW	
Work scheduled by: NGrid				TTC with All Lines In Service	1400 MW	
SCH-NE-NYISO_LIMIT_1100					FWD (Import)	REV (Export)
Wed 02/21/2024	to	Thu 02/22/2024	<u>UPDATED by ISONE 01/18/2024 13:55</u>	SCH - NE - NY	1300 MW	
1201	Continuous	1500		Impacts Total Transfer Capability	100 MW	
Work scheduled by: NGrid				TTC with All Lines In Service	1400 MW	
SCH-NE-NYISO_LIMIT_900					FWD (Import)	REV (Export)
Wed 02/21/2024	to	Thu 02/22/2024	<u>UPDATED by ISONE 01/18/2024 13:55</u>	SCH - NE - NY	1100 MW	
1201	Continuous	1500		Impacts Total Transfer Capability	300 MW	
Work scheduled by: NGrid				TTC with All Lines In Service	1400 MW	
SCH-NYISO-NE_LIMIT_900					FWD (Import)	REV (Export)
Wed 02/21/2024	to	Thu 02/22/2024	<u>UPDATED by ISONE 01/18/2024 13:55</u>	SCH - NE - NY		1100 MW
1201	Continuous	1500		Impacts Total Transfer Capability		700 MW
Work scheduled by: NGrid				TTC with All Lines In Service		1800 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, January 18, 2024 to Thursday, July 17, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_6

Sat 02/24/2024 to Sun 03/03/2024

0001 Continuous 2359

Work scheduled by: ConEd

CANCELLED by TO 01/14/2024 16:49

SCH - PJM_HTP

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

310 MW

350 MW

660 MW

W49TH_ST_345KV_8

Sat 02/24/2024 to Mon 03/04/2024

0001 Continuous 0200

Work scheduled by: ConEd

CANCELLED by TO 01/14/2024 16:49

SCH - PJM_HTP

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

310 MW

350 MW

660 MW

MOTTHAVN-RAINEY__345_Q12

Sat 03/02/2024 to Thu 04/11/2024

0001 Continuous 0200

Work scheduled by: ConEd

SPR/DUN-SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

3800 MW

800 MW

4600 MW

SHORE_RD_345_138_BK 2

Mon 03/04/2024 to Fri 05/03/2024

0001 Continuous 2359

Work scheduled by: LI

CONED - LIPA

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

1350 MW

150 MW

1500 MW

W49TH_ST_345KV_6

Mon 03/04/2024 to Tue 04/30/2024

0001 Continuous 0200

Work scheduled by: ConEd

CANCELLED by TO 01/14/2024 15:43

SCH - PJM_HTP

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

310 MW

350 MW

660 MW

W49TH_ST-E13THSTA_345_M55

Mon 03/04/2024 to Tue 04/30/2024

0001 Continuous 0200

Work scheduled by: ConEd

CANCELLED by TO 01/14/2024 15:43

SPR/DUN-SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

3800 MW

800 MW

4600 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, January 18, 2024 to Thursday, July 17, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

STLAWRNC-MOSES__230_L33P					FWD (Import)	REV (Export)
Mon 03/04/2024	to	Mon 03/04/2024		SCH - OH - NY		
0700	Continuous	1930		Impacts Total Transfer Capability		
Work scheduled by: NYPA				TTC with All Lines In Service		
BECK__-PACKARD__230_BP76					FWD (Import)	REV (Export)
Mon 03/04/2024	to	Fri 05/24/2024		SCH - OH - NY	1800 MW	1350 MW
0800	Continuous	1600		Impacts Total Transfer Capability	650 MW	550 MW
Work scheduled by: NGrid				TTC with All Lines In Service	2450 MW	1900 MW
STLAWRNC-MOSES__230_L34P					FWD (Import)	REV (Export)
Tue 03/05/2024	to	Tue 03/05/2024		SCH - OH - NY		
0700	Continuous	1930		Impacts Total Transfer Capability		
Work scheduled by: NYPA				TTC with All Lines In Service		
SCRIBA__-VOLNEY__345_21					FWD (Import)	REV (Export)
Thu 03/07/2024	to	Thu 03/14/2024	<u>UPDATED by NGrid 12/29/2023 11:38</u>	OSWEGO EXPORT	5250 MW	
0800	Continuous	1630		Impacts Total Transfer Capability	0 MW	
Work scheduled by: NGrid				TTC with All Lines In Service	5250 MW	
SPRNBK__345KV_RS3 , SPRNBK__345KV_RS4					FWD (Import)	REV (Export)
Mon 03/11/2024	to	Mon 03/11/2024		SPR/DUN-SOUTH	3800 MW	
0001		0030		Impacts Total Transfer Capability	800 MW	
Work scheduled by:				TTC with All Lines In Service	4600 MW	
CLAY__-EDIC__345_1-16					FWD (Import)	REV (Export)
Mon 03/18/2024	to	Mon 04/22/2024		OSWEGO EXPORT	4850 MW	
0700	Continuous	1600		Impacts Total Transfer Capability	400 MW	
Work scheduled by: NGrid				TTC with All Lines In Service	5250 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, January 18, 2024 to Thursday, July 17, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES__-ADIRNDCK_230_MA1

Mon 03/18/2024 to Mon 03/18/2024
0700 Continuous 1730
Work scheduled by: NYPA

MOSES SOUTH FWD (Import) REV (Export)
2300 MW
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

S.RIPLEY-DUNKIRK_230_68

Mon 03/18/2024 to Fri 03/22/2024
0800 Continuous 1600
Work scheduled by: PJM

SCH - PJ - NY FWD (Import) REV (Export)
Impacts Total Transfer Capability
TTC with All Lines In Service

MAINESBG-WATRCURE_345_30

Wed 03/20/2024 to Wed 03/20/2024
0800 Continuous 1300
Work scheduled by: NYSEG

SCH - PJ - NY FWD (Import) REV (Export)
2400 MW
Impacts Total Transfer Capability 150 MW
TTC with All Lines In Service 2550 MW

MILLWOOD-EASTVIEW_345_W85

Sun 03/24/2024 to Sat 03/30/2024
0201 Continuous 0200
Work scheduled by: ConEd
UPDATED by ConEd 01/12/2024 07:57

UPNY CONED FWD (Import) REV (Export)
7810 MW
Impacts Total Transfer Capability 240 MW
TTC with All Lines In Service 8050 MW

SPRNBK_345KV_RNS3

Sun 03/24/2024 to Sun 03/24/2024
0201 Continuous 0230
Work scheduled by: ConEd
UPDATED by ConEd 01/12/2024 07:57

SPR/DUN-SOUTH FWD (Import) REV (Export)
3800 MW
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

BERKSHIR-ALPS___345_393

Wed 03/27/2024 to Thu 03/28/2024
1201 Continuous 1500
Work scheduled by: NGrid
UPDATED by ISONE 01/09/2024 16:12
ARR: 78

SCH - NPX_1385 FWD (Import) REV (Export)
100 MW 100 MW
Impacts Total Transfer Capability 100 MW 100 MW
TTC with All Lines In Service 200 MW 200 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, January 18, 2024 to Thursday, July 17, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BERKSHIR-ALPS___345_393						FWD (Import)	REV (Export)
Wed 03/27/2024	to	Thu 03/28/2024	<u>UPDATED by ISONE 01/09/2024 16:12</u>	SCH - NE - NY		1100 MW	1700 MW
1201	Continuous	1500	ARR: 78	Impacts Total Transfer Capability		300 MW	100 MW
Work scheduled by: NGrid						TTC with All Lines In Service	1400 MW 1800 MW
BERKSHIR-ALPS___345_393 , BERKSHIR-NORTHFLD_345_312						FWD (Import)	REV (Export)
Wed 03/27/2024	to	Thu 03/28/2024		SCH - NE - NY		1100 MW	1100 MW
1201		1500	ARR: 78	Impacts Total Transfer Capability		300 MW	700 MW
Work scheduled by:						TTC with All Lines In Service	1400 MW 1800 MW
BERKSHIR-NORTHFLD_345_312						FWD (Import)	REV (Export)
Wed 03/27/2024	to	Thu 03/28/2024	<u>UPDATED by ISONE 01/09/2024 16:12</u>	SCH - NPX_1385		100 MW	100 MW
1201	Continuous	1500		Impacts Total Transfer Capability		100 MW	100 MW
Work scheduled by: NGrid						TTC with All Lines In Service	200 MW 200 MW
BERKSHIR-NORTHFLD_345_312						FWD (Import)	REV (Export)
Wed 03/27/2024	to	Thu 03/28/2024	<u>UPDATED by ISONE 01/09/2024 16:12</u>	SCH - NE - NY		1300 MW	
1201	Continuous	1500		Impacts Total Transfer Capability		100 MW	
Work scheduled by: NGrid						TTC with All Lines In Service	1400 MW
SCH-NE-NYISO_LIMIT_1100						FWD (Import)	REV (Export)
Wed 03/27/2024	to	Thu 03/28/2024	<u>UPDATED by ISONE 01/09/2024 16:12</u>	SCH - NE - NY		1300 MW	
1201	Continuous	1500		Impacts Total Transfer Capability		100 MW	
Work scheduled by: NGrid						TTC with All Lines In Service	1400 MW
SCH-NE-NYISO_LIMIT_900						FWD (Import)	REV (Export)
Wed 03/27/2024	to	Thu 03/28/2024	<u>UPDATED by ISONE 01/09/2024 16:12</u>	SCH - NE - NY		1100 MW	
1201	Continuous	1500		Impacts Total Transfer Capability		300 MW	
Work scheduled by: NGrid						TTC with All Lines In Service	1400 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, January 18, 2024 to Thursday, July 17, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-NE_LIMIT_900

Wed 03/27/2024 to Thu 03/28/2024
1201 Continuous 1500
Work scheduled by: NGrid

UPDATED by ISONE 01/09/2024 16:12

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
1100 MW
700 MW
1800 MW

SPRNBK_345KV_RNS3

Sat 03/30/2024 to Sat 03/30/2024
0130 Continuous 0200
Work scheduled by: ConEd

UPDATED by ConEd 01/12/2024 07:57

SPR/DUN-SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
3800 MW
800 MW
4600 MW

LADENTWN-BUCHAN_S_345_Y88

Mon 04/01/2024 to Fri 05/17/2024
0001 Continuous 2359
Work scheduled by: ConEd

UPNY CONED
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
7695 MW
355 MW
8050 MW

SPRNBK_345KV_RS3 , SPRNBK_345KV_RS4

Mon 04/01/2024 to Mon 04/01/2024
2130 2200
Work scheduled by:

SPR/DUN-SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
3800 MW
800 MW
4600 MW

NIAGARA-DYSINGER_345_ND1

Mon 04/08/2024 to Fri 04/12/2024
0500 Continuous 1900
Work scheduled by: NYPA

DYSINGER EAST
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
2700 MW
500 MW
3200 MW

LINDN_CG-LNDVFT__345_V-3022

Mon 04/08/2024 to Sat 04/13/2024
0800 Continuous 1500
Work scheduled by: PJM

SCH - PJM_VFT
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
0 MW **0 MW**
315 MW 315 MW
315 MW 315 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, January 18, 2024 to Thursday, July 17, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_DYSINGER_345_ND2

Mon 04/15/2024 to Fri 04/19/2024
0500 Continuous 1900
Work scheduled by: NYPA

DYSINGER EAST
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
2700 MW	
500 MW	
3200 MW	

SCH-NPX_1385-NYISO_LIMIT_100

Mon 04/15/2024 to Fri 04/26/2024
0600 Continuous 2200
Work scheduled by: ISONE

SCH - NPX_1385
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
100 MW	
100 MW	
200 MW	

GOETHALS_345KV_5

Thu 04/18/2024 to Thu 04/18/2024
0001 Continuous 0030
Work scheduled by: ConEd

STATEN ISLAND
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)

LINDEN_GOETHALS_230_A2253

Thu 04/18/2024 to Thu 04/25/2024
0001 Continuous 0200
Work scheduled by: ConEd

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)

LINDN_CG-LNDVFT_345_V-3022

Thu 04/18/2024 to Thu 04/18/2024
1500 Continuous 1800
Work scheduled by: PJM

SCH - PJM_VFT
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
0 MW	0 MW
315 MW	315 MW
315 MW	315 MW

W49TH_ST_345KV_8

Sat 04/20/2024 to Thu 04/25/2024
0001 Continuous 0200
Work scheduled by: ConEd

CANCELLED by TO 01/14/2024 15:47

SCH - PJM_HTTP
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
310 MW	
350 MW	
660 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, January 18, 2024 to Thursday, July 17, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PANNELL_-CLAY___345_1

Mon 04/22/2024 to Fri 04/26/2024
0700 Continuous 1530

Work scheduled by: NYPA

WEST CENTRAL
Impacts Total Transfer Capability 1300 MW
TTC with All Lines In Service 950 MW
2250 MW

FWD (Import) REV (Export)

GOETHALS_345KV_5

Thu 04/25/2024 to Thu 04/25/2024
0130 Continuous 0200

Work scheduled by: ConEd

STATEN ISLAND
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

DYSINGER-STA_255_345_DH1

Fri 04/26/2024 to Tue 05/07/2024
0500 Continuous 1900

Work scheduled by: NYPA

DYSINGER EAST
Impacts Total Transfer Capability 2850 MW
TTC with All Lines In Service 350 MW
3200 MW

FWD (Import) REV (Export)

MARCY_-FRASANNX_345_UCC2-41

Mon 04/29/2024 to Tue 07/16/2024
0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC
Impacts Total Transfer Capability 3225 MW
TTC with All Lines In Service 500 MW
3725 MW

FWD (Import) REV (Export)

PANNELL_-CLAY___345_2

Mon 04/29/2024 to Fri 05/03/2024
0700 Continuous 1530

Work scheduled by: NYPA

WEST CENTRAL
Impacts Total Transfer Capability 1300 MW
TTC with All Lines In Service 950 MW
2250 MW

FWD (Import) REV (Export)

W49TH_ST_345KV_5

Wed 05/01/2024 to Fri 05/03/2024
0001 Continuous 0200

Work scheduled by: ConEd

SCH - PJM_HTP
Impacts Total Transfer Capability 300 MW
TTC with All Lines In Service 360 MW
660 MW

FWD (Import) REV (Export)

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, January 18, 2024 to Thursday, July 17, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_7

Wed 05/01/2024 to Fri 05/03/2024
0001 Continuous 0200
Work scheduled by: ConEd

SCH - PJM_HTP
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
300 MW	
360 MW	
660 MW	

SHOR_NPX-SHOREHAM_138_CSC

Mon 05/06/2024 to Fri 05/10/2024
0600 Continuous 1800
Work scheduled by: LI

SCH - NPX_CSC
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
0 MW	0 MW
330 MW	330 MW
330 MW	330 MW

NIAGARA_ROBNSNRD_230_64

Mon 05/13/2024 to Fri 05/17/2024
0500 Continuous 1900
Work scheduled by: NYPA

SCH - OH - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
	1500 MW
	150 MW
	1650 MW

BUCHAN_S-MILLWOOD_345_W97

Fri 05/17/2024 to Sat 05/18/2024
0001 Continuous 0200
Work scheduled by: ConEd

UPNY CONED
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
8015 MW	
35 MW	
8050 MW	

FITZPTRK-EDIC___345_FE-1

Mon 05/20/2024 to Fri 05/24/2024
0700 Continuous 1530
Work scheduled by: NYPA

OSWEGO EXPORT
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
4800 MW	
450 MW	
5250 MW	

FITZPTRK-EDIC___345_FE-1

Mon 05/20/2024 to Fri 05/24/2024
0700 Continuous 1530
Work scheduled by: NYPA

CENTRAL EAST - VC
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
3520 MW	
205 MW	
3725 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, January 18, 2024 to Thursday, July 17, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FITZPTRK-EDIC__345_FE-1

Tue 05/28/2024 to Fri 05/31/2024
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
OSWEGO EXPORT	4800 MW	
Impacts Total Transfer Capability	450 MW	
TTC with All Lines In Service	5250 MW	

FITZPTRK-EDIC__345_FE-1

Tue 05/28/2024 to Fri 05/31/2024
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
CENTRAL EAST - VC	3520 MW	
Impacts Total Transfer Capability	205 MW	
TTC with All Lines In Service	3725 MW	

BECK__PACKARD_230_BP76

Fri 05/31/2024 to Fri 05/31/2024
0730 Continuous 1630
Work scheduled by: NGrid

	FWD (Import)	REV (Export)
SCH - OH - NY	1600 MW	1050 MW
Impacts Total Transfer Capability	450 MW	600 MW
TTC with All Lines In Service	2050 MW	1650 MW

CHASLAKE-PORTER__230_11

Sat 06/01/2024 to Wed 07/03/2024
0530 Continuous 1600
Work scheduled by: NGrid

	FWD (Import)	REV (Export)
MOSES SOUTH	2100 MW	
Impacts Total Transfer Capability	1050 MW	
TTC with All Lines In Service	3150 MW	

NIAGARA_345_230_AT4

Tue 06/11/2024 to Wed 06/12/2024
0500 Continuous 1900
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - OH - NY		1200 MW
Impacts Total Transfer Capability		450 MW
TTC with All Lines In Service		1650 MW

CHASLAKE-PORTER__230_11

Mon 07/08/2024 to Fri 08/30/2024
0700 Continuous 1900
Work scheduled by: NGrid

	FWD (Import)	REV (Export)
MOSES SOUTH	2100 MW	
Impacts Total Transfer Capability	1050 MW	
TTC with All Lines In Service	3150 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, January 18, 2024 to Thursday, July 17, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DYSINGER-STA_255_345_DH2

Mon 07/15/2024 to Sun 08/04/2024
0500 Continuous 1900
Work scheduled by: NYPA

DYSINGER EAST
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) **2850 MW**
350 MW
3200 MW

LEEDS_345_LEEDS SVC

Mon 07/22/2024 to Thu 07/25/2024
0730 Continuous 1600
Work scheduled by: NGrid

CENTRAL EAST - VC
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) **3675 MW**
50 MW
3725 MW

CHASLAKE-PORTER_230_11

Tue 09/03/2024 to Fri 11/15/2024
0530 Continuous 2000
Work scheduled by: NGrid

MOSES SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) **2100 MW**
1050 MW
3150 MW

FITZPTRK-EDIC_345_FE-1

Mon 09/09/2024 to Mon 09/09/2024
0001 Continuous 0100
Work scheduled by: NYPA

OSWEGO EXPORT
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) **4800 MW**
450 MW
5250 MW

FITZPTRK-EDIC_345_FE-1

Mon 09/09/2024 to Mon 09/09/2024
0001 Continuous 0100
Work scheduled by: NYPA

CENTRAL EAST - VC
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) **3520 MW**
205 MW
3725 MW

ROCHESTR-PANNELL_345_RP1

Mon 09/09/2024 to Fri 09/13/2024
0700 Continuous 1530
Work scheduled by: NYPA

DYSINGER EAST
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) **2300 MW**
900 MW
3200 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, January 18, 2024 to Thursday, July 17, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOTTHAVN-RAINEY__345_Q11

Sun 09/15/2024 to Sat 10/26/2024
0001 Continuous 0300

Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

DYSINGER-STA_255_345_DH2

Mon 09/16/2024 to Mon 10/28/2024
0500 Continuous 1900

Work scheduled by: NYPA

DYSINGER EAST **2850 MW**
Impacts Total Transfer Capability 350 MW
TTC with All Lines In Service 3200 MW

FWD (Import) REV (Export)

ROCHESTR-PANNELL__345_RP2

Mon 09/16/2024 to Fri 09/20/2024
0700 Continuous 1530

Work scheduled by: NYPA

DYSINGER EAST **2300 MW**
Impacts Total Transfer Capability 900 MW
TTC with All Lines In Service 3200 MW

FWD (Import) REV (Export)

STLAWRNC-MOSES__230_L34P

Mon 09/16/2024 to Fri 09/20/2024
0700 Continuous 1530

Work scheduled by: NYPA

SCH - OH - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

PANNELL_-CLAY__345_1

Mon 09/23/2024 to Fri 09/27/2024
0700 Continuous 1530

Work scheduled by: NYPA

WEST CENTRAL **1300 MW**
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

FWD (Import) REV (Export)

STLAWRNC-MOSES__230_L34P

Mon 09/23/2024 to Fri 09/27/2024
0700 Continuous 1530

Work scheduled by: NYPA

SCH - OH - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, January 18, 2024 to Thursday, July 17, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FITZPTRK-EDIC___345_FE-1					FWD (Import)	REV (Export)
Thu 09/26/2024	to	Thu 09/26/2024		OSWEGO EXPORT	4800 MW	
0900	Continuous	1000		Impacts Total Transfer Capability	450 MW	
Work scheduled by: NYPA				TTC with All Lines In Service	5250 MW	
FITZPTRK-EDIC___345_FE-1					FWD (Import)	REV (Export)
Thu 09/26/2024	to	Thu 09/26/2024		CENTRAL EAST - VC	3520 MW	
0900	Continuous	1000		Impacts Total Transfer Capability	205 MW	
Work scheduled by: NYPA				TTC with All Lines In Service	3725 MW	
STLAWRNC-MOSES___230_L34P					FWD (Import)	REV (Export)
Mon 09/30/2024	to	Fri 10/04/2024		SCH - OH - NY		
0700	Continuous	1530		Impacts Total Transfer Capability		
Work scheduled by: NYPA				TTC with All Lines In Service		
FITZPTRK-EDIC___345_FE-1					FWD (Import)	REV (Export)
Mon 09/30/2024	to	Fri 10/04/2024		OSWEGO EXPORT	4800 MW	
1700	Continuous	1530		Impacts Total Transfer Capability	450 MW	
Work scheduled by: NYPA				TTC with All Lines In Service	5250 MW	
FITZPTRK-EDIC___345_FE-1					FWD (Import)	REV (Export)
Mon 09/30/2024	to	Fri 10/04/2024		CENTRAL EAST - VC	3520 MW	
1700	Continuous	1530		Impacts Total Transfer Capability	205 MW	
Work scheduled by: NYPA				TTC with All Lines In Service	3725 MW	
BECK___-NIAGARA_345_PA302					FWD (Import)	REV (Export)
Mon 10/07/2024	to	Fri 10/11/2024		SCH - OH - NY	1000 MW	850 MW
0500	Continuous	1900		Impacts Total Transfer Capability	1050 MW	800 MW
Work scheduled by: NYPA				TTC with All Lines In Service	2050 MW	1650 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, January 18, 2024 to Thursday, July 17, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEPTUNE_DUFFYAVE_345_NEPTUNE					FWD (Import)	REV (Export)
Mon 10/07/2024	to	Fri 10/11/2024		SCH - PJM_NEPTUNE	0 MW	
0600	Continuous	1600		Impacts Total Transfer Capability	660 MW	
Work scheduled by: LI				TTC with All Lines In Service	660 MW	
NEWBRDGE_345_138_BK_1					FWD (Import)	REV (Export)
Mon 10/07/2024	to	Fri 10/11/2024		SCH - PJM_NEPTUNE	375 MW	
0600	Continuous	1600		Impacts Total Transfer Capability	285 MW	
Work scheduled by: LI				TTC with All Lines In Service	660 MW	
NEWBRDGE_345_138_BK_2					FWD (Import)	REV (Export)
Mon 10/07/2024	to	Fri 10/11/2024		SCH - PJM_NEPTUNE	375 MW	
0600	Continuous	1600		Impacts Total Transfer Capability	285 MW	
Work scheduled by: LI				TTC with All Lines In Service	660 MW	
NEWBRDGE-DUFFYAVE_345_501					FWD (Import)	REV (Export)
Mon 10/07/2024	to	Fri 10/11/2024		SCH - PJM_NEPTUNE	0 MW	
0600	Continuous	1600		Impacts Total Transfer Capability	660 MW	
Work scheduled by: LI				TTC with All Lines In Service	660 MW	
SHOR_NPX-SHOREHAM_138_CSC					FWD (Import)	REV (Export)
Mon 10/07/2024	to	Fri 10/11/2024		SCH - NPX_CSC	0 MW	0 MW
0600	Continuous	1800		Impacts Total Transfer Capability	330 MW	330 MW
Work scheduled by: LI				TTC with All Lines In Service	330 MW	330 MW
MARCY__FRASANNX_345_UCC2-41					FWD (Import)	REV (Export)
Wed 10/09/2024	to	Thu 10/10/2024		CENTRAL EAST - VC	3225 MW	
0700	Continuous	1530		Impacts Total Transfer Capability	500 MW	
Work scheduled by: NYPA				TTC with All Lines In Service	3725 MW	

ARR: 19

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, January 18, 2024 to Thursday, July 17, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY__N.SCTLND_345_18						FWD (Import)	REV (Export)
Tue 10/15/2024	to	Thu 10/17/2024			CENTRAL EAST - VC	2665 MW	
0700	Continuous	1530			Impacts Total Transfer Capability	1060 MW	
Work scheduled by: NYPA				ARR: 19	TTC with All Lines In Service	3725 MW	
MARCY__N.SCTLND_345_18						FWD (Import)	REV (Export)
Mon 10/21/2024	to	Fri 10/25/2024			CENTRAL EAST - VC	2665 MW	
0700	Continuous	1530			Impacts Total Transfer Capability	1060 MW	
Work scheduled by: NYPA				ARR: 19	TTC with All Lines In Service	3725 MW	
MARCY__345KV_CSC						FWD (Import)	REV (Export)
Mon 10/28/2024	to	Sun 11/10/2024			CENTRAL EAST - VC	3650 MW	
0700	Continuous	1530			Impacts Total Transfer Capability	75 MW	
Work scheduled by: NYPA					TTC with All Lines In Service	3725 MW	
DYSINGER-STA_255_345_DH2						FWD (Import)	REV (Export)
Tue 10/29/2024	to	Thu 10/31/2024			DYSINGER EAST	2850 MW	
0500	Continuous	2100			Impacts Total Transfer Capability	350 MW	
Work scheduled by: NYPA					TTC with All Lines In Service	3200 MW	
DYSINGER-STA_255_345_DH1						FWD (Import)	REV (Export)
Mon 11/04/2024	to	Sat 11/16/2024			DYSINGER EAST	2850 MW	
0500	Continuous	1900			Impacts Total Transfer Capability	350 MW	
Work scheduled by: NYPA					TTC with All Lines In Service	3200 MW	
BECK__-NIAGARA_230_PA27						FWD (Import)	REV (Export)
Fri 11/15/2024	to	Fri 11/15/2024			SCH - OH - NY	2100 MW	
0500	Continuous	1900			Impacts Total Transfer Capability	350 MW	
Work scheduled by: NYPA					TTC with All Lines In Service	2450 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, January 18, 2024 to Thursday, July 17, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHATGUAY-MASSENA__765_7040

Sat 11/16/2024 to Fri 11/29/2024
0001 Continuous 2359
Work scheduled by: NYPA

SCH - HQ - NY
0 MW
0 MW
Impacts Total Transfer Capability 1500 MW 1000 MW
TTC with All Lines In Service 1500 MW 1000 MW

CHATGUAY-MASSENA__765_7040

Sat 11/16/2024 to Fri 11/29/2024
0001 Continuous 2359
Work scheduled by: NYPA

MOSES SOUTH
1550 MW
Impacts Total Transfer Capability 1600 MW
TTC with All Lines In Service 3150 MW

CHATGUAY-MASSENA__765_7040 , MASSENA-MARCY__765_MSU1

Sat 11/16/2024 to Fri 11/29/2024
0001 2359
Work scheduled by:

MOSES SOUTH
500 MW
Impacts Total Transfer Capability 2650 MW
TTC with All Lines In Service 3150 MW

MARCY__765_345_AT1

Sat 11/16/2024 to Fri 11/29/2024
0001 Continuous 2359
Work scheduled by: NYPA

ARR: 19

MOSES SOUTH
1750 MW
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 3150 MW

MARCY__765_345_AT2

Sat 11/16/2024 to Fri 11/29/2024
0001 Continuous 2359
Work scheduled by: NYPA

ARR: 19

MOSES SOUTH
1700 MW
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

MASSENA-MARCY__765_MSU1

Sat 11/16/2024 to Fri 11/29/2024
0001 Continuous 2359
Work scheduled by: NYPA

SCH - HQ_CEDARS
90 MW
Impacts Total Transfer Capability 189 MW
TTC with All Lines In Service 279 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Thursday, January 18, 2024 to Thursday, July 17, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA_MARCY__765_MSU1					FWD (Import)	REV (Export)
Sat 11/16/2024	to	Fri 11/29/2024		SCH - HQ - NY	475 MW	1000 MW
0001	Continuous	2359		Impacts Total Transfer Capability	1025 MW	0 MW
Work scheduled by: NYPA				TTC with All Lines In Service	1500 MW	1000 MW
MASSENA_MARCY__765_MSU1					FWD (Import)	REV (Export)
Sat 11/16/2024	to	Fri 11/29/2024		MOSES SOUTH	500 MW	
0001	Continuous	2359		Impacts Total Transfer Capability	2650 MW	
Work scheduled by: NYPA				TTC with All Lines In Service	3150 MW	
MASSENA_MARCY__765_MSU1					FWD (Import)	REV (Export)
Sat 11/16/2024	to	Fri 11/29/2024		CENTRAL EAST - VC	2595 MW	
0001	Continuous	2359		Impacts Total Transfer Capability	1130 MW	
Work scheduled by: NYPA				TTC with All Lines In Service	3725 MW	
MOSES__-MASSENA_230_MMS2 , MOSES__-MASSENA_230_MMS1					FWD (Import)	REV (Export)
Sat 11/16/2024	to	Fri 11/29/2024		SCH - HQ_CEDARS	90 MW	
0001		2359		Impacts Total Transfer Capability	189 MW	
Work scheduled by:				TTC with All Lines In Service	279 MW	
MOSES__-MASSENA_230_MMS2 , MOSES__-MASSENA_230_MMS1					FWD (Import)	REV (Export)
Sat 11/16/2024	to	Fri 11/29/2024		SCH - HQ - NY	850 MW	0 MW
0001		2359		Impacts Total Transfer Capability	650 MW	1000 MW
Work scheduled by:				TTC with All Lines In Service	1500 MW	1000 MW
ADIRNDCK-PORTER__230_12					FWD (Import)	REV (Export)
Sun 12/01/2024	to	Sat 05/31/2025		MOSES SOUTH	2300 MW	
0530	Continuous	1700		Impacts Total Transfer Capability	850 MW	
Work scheduled by: NGrid				TTC with All Lines In Service	3150 MW	

NYISO TRANSFER LIMITATIONS