

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 10, 2024 to Tuesday, September 9, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONP_-FARRAGUT_345_B3402

Mon 01/15/2018 to Sun 03/31/2024
0001 Continuous 2359
Work scheduled by: ConEd

EXT FORCED by ConEd 12/20/2023 15:20

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Sun 03/31/2024
0001 Continuous 2359
Work scheduled by: ConEd

EXT FORCED by ConEd 12/20/2023 15:20

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

MARION_-FARRAGUT_345_C3403 , HUDSONP_-FARRAGUT_345_B3402

Mon 01/15/2018 to Sun 03/31/2024
0001 2359
Work scheduled by:

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
2400 MW 2400 MW
150 MW 250 MW
2550 MW 2650 MW

HOMRC_NY-MAINS_NY_345_47

Fri 09/08/2023 to Wed 03/13/2024
1612 Continuous 1600
Work scheduled by: PJM

UPDATED by NYSEG 03/08/2024 16:06

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

SCH-IMO-NYISO_LIMIT_1900

Wed 11/01/2023 to Tue 04/30/2024
0001 Continuous 2359
Work scheduled by: IESO

SCH - OH - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
2200 MW
250 MW
2450 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 10, 2024 to Tuesday, September 9, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_6

Fri 12/15/2023 to Thu 03/14/2024
0000 Continuous 0100

EXT FORCED by ConEd 02/01/2024 13:54

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

3800 MW

Impacts Total Transfer Capability

800 MW

TTC with All Lines In Service

4600 MW

Work scheduled by: ConEd

DUNWODIE-SHORE_RD_345_Y50

Fri 12/15/2023 to Thu 03/14/2024
0000 Continuous 0100

EXT FORCED by ConEd 02/01/2024 13:54

CONED - LIPA

FWD (Import)

REV (Export)

800 MW

Impacts Total Transfer Capability

700 MW

TTC with All Lines In Service

1500 MW

Work scheduled by: ConEd

SHORE_RD_345_138_BK 2

Fri 12/15/2023 to Thu 03/14/2024
0000 Continuous 0100

EXT FORCED by ConEd 02/01/2024 13:54

CONED - LIPA

FWD (Import)

REV (Export)

1350 MW

Impacts Total Transfer Capability

150 MW

TTC with All Lines In Service

1500 MW

Work scheduled by: ConEd

ADIRNDCK-PORTER__230_12

Tue 01/02/2024 to Wed 05/29/2024
0630 Continuous 1730

UPDATED by NGrid 07/11/2023 11:44

MOSES SOUTH

FWD (Import)

REV (Export)

2300 MW

Impacts Total Transfer Capability

850 MW

TTC with All Lines In Service

3150 MW

Work scheduled by: NGrid

SCH-IMO-NYISO_LIMIT_1750

Tue 01/02/2024 to Wed 05/29/2024
0630 Continuous 1730

UPDATED by NGrid 07/11/2023 11:44

SCH - OH - NY

FWD (Import)

REV (Export)

2050 MW

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

2450 MW

Work scheduled by: NGrid

FRASER__345_FRASER SVC

Tue 01/02/2024 to Fri 03/22/2024
0700 Continuous 1530

EXTENDED by NYPA 02/22/2024 14:18

CENTRAL EAST - VC

FWD (Import)

REV (Export)

3655 MW

Impacts Total Transfer Capability

70 MW

TTC with All Lines In Service

3725 MW

Work scheduled by: NYPA

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 10, 2024 to Tuesday, September 9, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK_W49TH_ST_345_M51

Tue 01/30/2024 to Sun 03/31/2024
0202 Continuous 2359

UPDATED by ConEd 02/21/2024 13:28

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

3200 MW

Impacts Total Transfer Capability

1400 MW

TTC with All Lines In Service

4600 MW

CLAY__-EDIC__345_2-15

Mon 02/05/2024 to Fri 03/15/2024
0700 Continuous 1600

UPDATED by NYPA 02/02/2024 14:53

OSWEGO EXPORT

FWD (Import)

REV (Export)

4850 MW

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

5250 MW

SHORE_RD_345_138_BK 1

Mon 02/12/2024 to Fri 05/03/2024
0001 Continuous 2359

UPDATED by LI 02/07/2024 12:08

CONED - LIPA

FWD (Import)

REV (Export)

1350 MW

Impacts Total Transfer Capability

150 MW

TTC with All Lines In Service

1500 MW

BECK__-PACKARD_230_BP76

Mon 03/04/2024 to Fri 05/24/2024
0500 Continuous 1600

SCH - OH - NY

FWD (Import)

REV (Export)

1800 MW

1350 MW

Impacts Total Transfer Capability

650 MW

550 MW

TTC with All Lines In Service

2450 MW

1900 MW

SCH-IMO-NYISO_LIMIT_1300

Mon 03/04/2024 to Mon 05/20/2024
0500 Continuous 0800

SCH - OH - NY

FWD (Import)

REV (Export)

1600 MW

Impacts Total Transfer Capability

850 MW

TTC with All Lines In Service

2450 MW

CHAT_DC_GC1

Mon 03/11/2024 to Mon 03/11/2024
0001 Continuous 0200

MOSES SOUTH

FWD (Import)

REV (Export)

2850 MW

Impacts Total Transfer Capability

300 MW

TTC with All Lines In Service

3150 MW

Work scheduled by: HQ

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 10, 2024 to Tuesday, September 9, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHAT_DC_GC1

Mon 03/11/2024 to Mon 03/11/2024
0001 Continuous 0200
Work scheduled by: HQ

	FWD (Import)	REV (Export)
SCH - HQ - NY		500 MW
Impacts Total Transfer Capability		500 MW
TTC with All Lines In Service		1000 MW

CHAT_DC_GC1 , CHAT_DC_GC2

Mon 03/11/2024 to Mon 03/11/2024
0001 0200
Work scheduled by:

	FWD (Import)	REV (Export)
MOSES SOUTH	2550 MW	
Impacts Total Transfer Capability	600 MW	
TTC with All Lines In Service	3150 MW	

CHAT_DC_GC1 , CHAT_DC_GC2

Mon 03/11/2024 to Mon 03/11/2024
0001 0200
Work scheduled by:

	FWD (Import)	REV (Export)
SCH - HQ - NY	1370 MW	0 MW
Impacts Total Transfer Capability	130 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

CHAT_DC_GC2

Mon 03/11/2024 to Mon 03/11/2024
0001 Continuous 0200
Work scheduled by: HQ

	FWD (Import)	REV (Export)
MOSES SOUTH	2850 MW	
Impacts Total Transfer Capability	300 MW	
TTC with All Lines In Service	3150 MW	

CHAT_DC_GC2

Mon 03/11/2024 to Mon 03/11/2024
0001 Continuous 0200
Work scheduled by: HQ

	FWD (Import)	REV (Export)
SCH - HQ - NY		500 MW
Impacts Total Transfer Capability		500 MW
TTC with All Lines In Service		1000 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 10, 2024 to Tuesday, September 9, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-HQ-NYISO_LIMIT_1150

Mon 03/11/2024 to Mon 03/11/2024
0001 Continuous 0200
Work scheduled by: HQ

SCH - HQ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
1150 MW	
350 MW	
1500 MW	

SCH-HQ_CEDARS-NYISO_LIMIT_240

Mon 03/11/2024 to Thu 04/11/2024
0800 Continuous 1800
Work scheduled by: HQ

SCH - HQ_CEDARS
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
240 MW	
39 MW	
279 MW	

SCH-NYISO-HQ_CEDARS_LIMIT_0

Mon 03/11/2024 to Thu 04/11/2024
0800 Continuous 1800
Work scheduled by: HQ

SCH - HQ_CEDARS
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
	0 MW
	100 MW
	100 MW

DUNWODIE_345KV_3

Tue 03/12/2024 to Wed 03/13/2024
0001 Continuous 0200
Work scheduled by: ConEd

SPR/DUN-SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
3800 MW	
800 MW	
4600 MW	

DUNWODIE_345KV_4

Tue 03/12/2024 to Wed 03/13/2024
0001 Continuous 0200
Work scheduled by: ConEd

SPR/DUN-SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
3800 MW	
800 MW	
4600 MW	

DUNWODIE_345KV_8

Tue 03/12/2024 to Wed 03/13/2024
0201 Continuous 0100
Work scheduled by: ConEd

SPR/DUN-SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
3800 MW	
800 MW	
4600 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 10, 2024 to Tuesday, September 9, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCRIBA_-VOLNEY_345_21

Tue 03/12/2024 to Tue 03/19/2024
0800 Continuous 1630

UPDATED by NGrid 12/29/2023 11:38

OSWEGO EXPORT
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
5250 MW
0 MW
5250 MW

Work scheduled by: NGrid

ELBRIDGE-LAFAYTTE_345_17-LE

Wed 03/13/2024 to Wed 03/13/2024
0700 Continuous 0900

UPDATED by NGrid 02/26/2024 13:51

ARR: 75

OSWEGO EXPORT
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
5250 MW
0 MW
5250 MW

Work scheduled by: NGrid

OSWEGO_-ELBRIDGE_345_17

Wed 03/13/2024 to Fri 03/15/2024
0700 Continuous 1700

UPDATED by NGrid 02/26/2024 13:51

ARR: 75

OSWEGO EXPORT
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
5250 MW
0 MW
5250 MW

Work scheduled by: NGrid

NRTH1385-NOR HBR_138_601

Thu 03/14/2024 to Thu 03/14/2024
0800 Continuous 1900

UPDATED by ISONE 03/08/2024 09:15

SCH - NPX_1385
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
100 MW **100 MW**
100 MW 100 MW
200 MW 200 MW

Work scheduled by: ISONE

NRTH1385-NOR HBR_138_602

Thu 03/14/2024 to Thu 03/14/2024
0800 Continuous 1900

UPDATED by ISONE 03/08/2024 09:15

SCH - NPX_1385
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
100 MW **100 MW**
100 MW 100 MW
200 MW 200 MW

Work scheduled by: ISONE

NRTH1385-NOR HBR_138_603

Thu 03/14/2024 to Thu 03/14/2024
0800 Continuous 1900

UPDATED by ISONE 03/08/2024 09:15

SCH - NPX_1385
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
100 MW **100 MW**
100 MW 100 MW
200 MW 200 MW

Work scheduled by: ISONE

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 10, 2024 to Tuesday, September 9, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NRTH1385-NORHBR_138_601 , NRTH1385-NORHBR_138_602

Thu 03/14/2024 to Thu 03/14/2024
0800 1900

Work scheduled by:

SCH - NPX_1385

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

0 MW

200 MW

200 MW

REV (Export)

0 MW

200 MW

200 MW

NRTH1385-NORHBR_138_601 , NRTH1385-NORHBR_138_603

Thu 03/14/2024 to Thu 03/14/2024
0800 1900

Work scheduled by:

SCH - NPX_1385

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

0 MW

200 MW

200 MW

REV (Export)

0 MW

200 MW

200 MW

NRTH1385-NORHBR_138_603 , NRTH1385-NORHBR_138_602

Thu 03/14/2024 to Thu 03/14/2024
0800 1900

Work scheduled by:

SCH - NPX_1385

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

0 MW

200 MW

200 MW

REV (Export)

0 MW

200 MW

200 MW

NRTH1385-NRTHPORT_138_NNC

Thu 03/14/2024 to Thu 03/14/2024
0800 Continuous 1900

Work scheduled by: ISONE

UPDATED by ISONE 03/08/2024 09:15

SCH - NPX_1385

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

0 MW

200 MW

200 MW

REV (Export)

0 MW

200 MW

200 MW

ELBRIDGE-LAFAYTTE_345_17-LE

Fri 03/15/2024 to Fri 03/15/2024
1500 Continuous 1700

Work scheduled by: NGrid

UPDATED by NGrid 02/26/2024 13:51

ARR: 75

OSWEGO EXPORT

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

5250 MW

0 MW

5250 MW

REV (Export)

SCH-IMO-NYISO_LIMIT_950

Sun 03/17/2024 to Thu 03/21/2024
0830 Continuous 1600

Work scheduled by: IESO

UPDATED by IESO 03/07/2024 15:57

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

1250 MW

1200 MW

2450 MW

REV (Export)

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 10, 2024 to Tuesday, September 9, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-IMO_LIMIT_500

Sun 03/17/2024 to Thu 03/21/2024
0830 Continuous 1600

UPDATED by IESO 03/07/2024 15:57

SCH - OH - NY

FWD (Import)

REV (Export)

800 MW

Impacts Total Transfer Capability

1100 MW

TTC with All Lines In Service

1900 MW

Work scheduled by: IESO

CLAY__-EDIC__345_1-16

Mon 03/18/2024 to Mon 04/22/2024
0700 Continuous 1600

OSWEGO EXPORT

FWD (Import)

REV (Export)

4850 MW

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

5250 MW

Work scheduled by: NGrid

MOSES__-ADIRNDCK_230_MA1

Mon 03/18/2024 to Mon 03/18/2024
0700 Continuous 2130

MOSES SOUTH

FWD (Import)

REV (Export)

2300 MW

Impacts Total Transfer Capability

850 MW

TTC with All Lines In Service

3150 MW

Work scheduled by: NYPA

S.RIPLEY-DUNKIRK_230_68

Mon 03/18/2024 to Fri 03/22/2024
0800 Continuous 1600

SCH - PJ - NY

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: PJM

SPRNBK_345KV_RNS5

Tue 03/19/2024 to Tue 03/19/2024
0001 Continuous 0030

UPDATED by ConEd 02/21/2024 13:28

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

3200 MW

Impacts Total Transfer Capability

1400 MW

TTC with All Lines In Service

4600 MW

Work scheduled by: ConEd

SPRNBK_345KV_RNS5

Wed 03/20/2024 to Sun 03/24/2024
0001 Continuous 0200

UPDATED by ConEd 02/21/2024 13:28

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

3200 MW

Impacts Total Transfer Capability

1400 MW

TTC with All Lines In Service

4600 MW

Work scheduled by: ConEd

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 10, 2024 to Tuesday, September 9, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MAINESBG-WATRCURE_345_30

Thu 03/21/2024 to Thu 03/21/2024
0800 Continuous 1300
Work scheduled by: NYSEG

SCH - PJ - NY
Impacts Total Transfer Capability 150 MW
TTC with All Lines In Service 2550 MW

FWD (Import) REV (Export)

2400 MW

MILLWOOD-EASTVIEW_345_W85

Mon 03/25/2024 to Sat 03/30/2024
0201 Continuous 0200
Work scheduled by: ConEd

UPDATED by ConEd 01/12/2024 07:57

UPNY CONED
Impacts Total Transfer Capability 240 MW
TTC with All Lines In Service 8050 MW

FWD (Import) REV (Export)

7810 MW

SPRNBK_345KV_RNS3

Mon 03/25/2024 to Mon 03/25/2024
0201 Continuous 0230
Work scheduled by: ConEd

UPDATED by ConEd 01/12/2024 07:57

SPR/DUN-SOUTH
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

3800 MW

BERKSHIR-ALPS_345_393

Wed 03/27/2024 to Thu 03/28/2024
1201 Continuous 1500
Work scheduled by: NGrid

UPDATED by ISONE 01/09/2024 16:12

ARR: 78

SCH - NPX_1385
Impacts Total Transfer Capability 100 MW 100 MW
TTC with All Lines In Service 200 MW 200 MW

FWD (Import) REV (Export)

100 MW

100 MW

BERKSHIR-ALPS_345_393

Wed 03/27/2024 to Thu 03/28/2024
1201 Continuous 1500
Work scheduled by: NGrid

UPDATED by ISONE 01/09/2024 16:12

ARR: 78

SCH - NE - NY
Impacts Total Transfer Capability 300 MW 100 MW
TTC with All Lines In Service 1400 MW 1800 MW

FWD (Import) REV (Export)

1100 MW

1700 MW

BERKSHIR-ALPS_345_393 , BERKSHIR-NORTHFLD_345_312

Wed 03/27/2024 to Thu 03/28/2024
1201 Continuous 1500
Work scheduled by:

ARR: 78

SCH - NE - NY
Impacts Total Transfer Capability 300 MW 700 MW
TTC with All Lines In Service 1400 MW 1800 MW

FWD (Import) REV (Export)

1100 MW

1100 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 10, 2024 to Tuesday, September 9, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BERKSHIR-NORTHFLD_345_312						FWD (Import)	REV (Export)
Wed 03/27/2024	to	Thu 03/28/2024	<u>UPDATED by ISONE 01/09/2024 16:12</u>	SCH - NPX_1385		100 MW	100 MW
1201	Continuous	1500		Impacts Total Transfer Capability		100 MW	100 MW
Work scheduled by: NGrid					TTC with All Lines In Service	200 MW	200 MW
BERKSHIR-NORTHFLD_345_312						FWD (Import)	REV (Export)
Wed 03/27/2024	to	Thu 03/28/2024	<u>UPDATED by ISONE 01/09/2024 16:12</u>	SCH - NE - NY		1300 MW	
1201	Continuous	1500		Impacts Total Transfer Capability		100 MW	
Work scheduled by: NGrid					TTC with All Lines In Service	1400 MW	
SCH-NE-NYISO_LIMIT_1100						FWD (Import)	REV (Export)
Wed 03/27/2024	to	Thu 03/28/2024	<u>UPDATED by ISONE 01/09/2024 16:12</u>	SCH - NE - NY		1300 MW	
1201	Continuous	1500		Impacts Total Transfer Capability		100 MW	
Work scheduled by: NGrid					TTC with All Lines In Service	1400 MW	
SCH-NE-NYISO_LIMIT_900						FWD (Import)	REV (Export)
Wed 03/27/2024	to	Thu 03/28/2024	<u>UPDATED by ISONE 01/09/2024 16:12</u>	SCH - NE - NY		1100 MW	
1201	Continuous	1500		Impacts Total Transfer Capability		300 MW	
Work scheduled by: NGrid					TTC with All Lines In Service	1400 MW	
SCH-NYISO-NE_LIMIT_900						FWD (Import)	REV (Export)
Wed 03/27/2024	to	Thu 03/28/2024	<u>UPDATED by ISONE 01/09/2024 16:12</u>	SCH - NE - NY			1100 MW
1201	Continuous	1500		Impacts Total Transfer Capability			700 MW
Work scheduled by: NGrid					TTC with All Lines In Service		1800 MW
SPRNBK_345KV_RNS3						FWD (Import)	REV (Export)
Sat 03/30/2024	to	Sat 03/30/2024	<u>UPDATED by ConEd 01/12/2024 07:57</u>	SPR/DUN-SOUTH		3800 MW	
0130	Continuous	0200		Impacts Total Transfer Capability		800 MW	
Work scheduled by: ConEd					TTC with All Lines In Service	4600 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 10, 2024 to Tuesday, September 9, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK_345KV_RNS5

Sat 03/30/2024 to Sat 03/30/2024
0130 Continuous 0200

UPDATED by ConEd 02/21/2024 13:28

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

3200 MW

Impacts Total Transfer Capability

1400 MW

TTC with All Lines In Service

4600 MW

CHAT_DC_GC1

Sun 03/31/2024 to Sun 03/31/2024
0001 Continuous 0200

MOSES SOUTH

FWD (Import)

REV (Export)

2850 MW

Impacts Total Transfer Capability

300 MW

TTC with All Lines In Service

3150 MW

CHAT_DC_GC1

Sun 03/31/2024 to Sun 03/31/2024
0001 Continuous 0200

SCH - HQ - NY

FWD (Import)

REV (Export)

500 MW

Impacts Total Transfer Capability

500 MW

TTC with All Lines In Service

1000 MW

CHAT_DC_GC1 , CHAT_DC_GC2

Sun 03/31/2024 to Sun 03/31/2024
0001 0200

MOSES SOUTH

FWD (Import)

REV (Export)

2550 MW

Impacts Total Transfer Capability

600 MW

TTC with All Lines In Service

3150 MW

CHAT_DC_GC1 , CHAT_DC_GC2

Sun 03/31/2024 to Sun 03/31/2024
0001 0200

SCH - HQ - NY

FWD (Import)

REV (Export)

1370 MW

0 MW

Impacts Total Transfer Capability

130 MW

1000 MW

TTC with All Lines In Service

1500 MW

1000 MW

CHAT_DC_GC2

Sun 03/31/2024 to Sun 03/31/2024
0001 Continuous 0200

MOSES SOUTH

FWD (Import)

REV (Export)

2850 MW

Impacts Total Transfer Capability

300 MW

TTC with All Lines In Service

3150 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 10, 2024 to Tuesday, September 9, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHAT_DC_GC2

Sun 03/31/2024 to Sun 03/31/2024
0001 Continuous 0200
Work scheduled by: HQ

SCH - HQ - NY
Impacts Total Transfer Capability 500 MW
TTC with All Lines In Service 1000 MW

SCH-HQ-NYISO_LIMIT_1150

Sun 03/31/2024 to Sun 03/31/2024
0001 Continuous 0200
Work scheduled by: HQ

SCH - HQ - NY
Impacts Total Transfer Capability 350 MW
TTC with All Lines In Service 1500 MW

MOTTHAVN-RAINEY__345_Q12

Mon 04/01/2024 to Mon 04/15/2024
0001 Continuous 0200
Work scheduled by: ConEd

SPR/DUN-SOUTH
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

RAMAPO__BUCHAN_N_345_Y94

Tue 04/02/2024 to Tue 04/30/2024
0201 Continuous 0200
Work scheduled by: ConEd

UPNY CONED
Impacts Total Transfer Capability 295 MW
TTC with All Lines In Service 8050 MW

W49TH_ST_345KV_5

Wed 04/03/2024 to Wed 04/03/2024
0001 Continuous 0030
Work scheduled by: ConEd

SCH - PJM_HTP
Impacts Total Transfer Capability 360 MW
TTC with All Lines In Service 660 MW

W49TH_ST_345KV_7

Wed 04/03/2024 to Wed 04/03/2024
0001 Continuous 0030
Work scheduled by: ConEd

SCH - PJM_HTP
Impacts Total Transfer Capability 360 MW
TTC with All Lines In Service 660 MW

Sunday, March 10, 2024 to Tuesday, September 9, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BERKSHIR-ALPS____345_393					FWD (Import)	REV (Export)
Wed 04/03/2024	to	Sun 04/07/2024	UPDATED by ISONE 02/08/2024 16:42	SCH - NPX_1385	100 MW	100 MW
1200	Continuous	1000	ARR: 78	Impacts Total Transfer Capability	100 MW	100 MW
Work scheduled by: NGrid				TTC with All Lines In Service	200 MW	200 MW
BERKSHIR-ALPS____345_393					FWD (Import)	REV (Export)
Wed 04/03/2024	to	Sun 04/07/2024	UPDATED by ISONE 02/08/2024 16:42	SCH - NE - NY	1100 MW	1700 MW
1200	Continuous	1000	ARR: 78	Impacts Total Transfer Capability	300 MW	100 MW
Work scheduled by: NGrid				TTC with All Lines In Service	1400 MW	1800 MW
BERKSHIR-ALPS____345_393 , BERKSHIR-NORTHFLD_345_312					FWD (Import)	REV (Export)
Wed 04/03/2024	to	Sun 04/07/2024		SCH - NE - NY	1100 MW	1100 MW
1200		1000	ARR: 78	Impacts Total Transfer Capability	300 MW	700 MW
Work scheduled by:				TTC with All Lines In Service	1400 MW	1800 MW
BERKSHIR-NORTHFLD_345_312					FWD (Import)	REV (Export)
Wed 04/03/2024	to	Sun 04/07/2024	UPDATED by ISONE 02/08/2024 16:42	SCH - NPX_1385	100 MW	100 MW
1200	Continuous	1000		Impacts Total Transfer Capability	100 MW	100 MW
Work scheduled by: NGrid				TTC with All Lines In Service	200 MW	200 MW
BERKSHIR-NORTHFLD_345_312					FWD (Import)	REV (Export)
Wed 04/03/2024	to	Sun 04/07/2024	UPDATED by ISONE 02/08/2024 16:42	SCH - NE - NY	1300 MW	
1200	Continuous	1000		Impacts Total Transfer Capability	100 MW	
Work scheduled by: NGrid				TTC with All Lines In Service	1400 MW	
SCH-NE-NYISO_LIMIT_900					FWD (Import)	REV (Export)
Wed 04/03/2024	to	Sun 04/07/2024	UPDATED by ISONE 02/08/2024 16:42	SCH - NE - NY	1100 MW	
1200	Continuous	1000		Impacts Total Transfer Capability	300 MW	
Work scheduled by: NGrid				TTC with All Lines In Service	1400 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 10, 2024 to Tuesday, September 9, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-NE_LIMIT_900

Wed 04/03/2024 to Sun 04/07/2024
1200 Continuous 1000

UPDATED by ISONE 02/08/2024 16:42

FWD (Import) REV (Export)

1100 MW

Work scheduled by: NGrid

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

700 MW

1800 MW

W49TH_ST_345KV_5

Fri 04/05/2024 to Fri 04/05/2024
0130 Continuous 0200

FWD (Import) REV (Export)

300 MW

Work scheduled by: ConEd

SCH - PJM_HTP
Impacts Total Transfer Capability
TTC with All Lines In Service

360 MW

660 MW

W49TH_ST_345KV_7

Fri 04/05/2024 to Fri 04/05/2024
0130 Continuous 0200

FWD (Import) REV (Export)

300 MW

Work scheduled by: ConEd

SCH - PJM_HTP
Impacts Total Transfer Capability
TTC with All Lines In Service

360 MW

660 MW

SPRNBK_345KV_RS3 , SPRNBK_345KV_RS4

Fri 04/05/2024 to Fri 04/05/2024
0201 Continuous 0230

FWD (Import) REV (Export)

3800 MW

Work scheduled by:

SPR/DUN-SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

800 MW

4600 MW

MARCY_765_345_AT1

Fri 04/05/2024 to Fri 04/05/2024
0500 Continuous 1930

FWD (Import) REV (Export)

1750 MW

Work scheduled by: NYPA

ARR: 19

MOSES SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

1400 MW

3150 MW

WATRCURE-OAKDALE_345_31

Fri 04/05/2024 to Fri 04/05/2024
0800 Continuous 1500

FWD (Import) REV (Export)

2400 MW

Work scheduled by: NYSEG

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

150 MW

2550 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 10, 2024 to Tuesday, September 9, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_5

Sat 04/06/2024 to Sat 04/06/2024

0130 Continuous 0200

Work scheduled by: ConEd

SCH - PJM_HTP

FWD (Import)

REV (Export)

300 MW

Impacts Total Transfer Capability

360 MW

TTC with All Lines In Service

660 MW

W49TH_ST_345KV_7

Sat 04/06/2024 to Sat 04/06/2024

0130 Continuous 0200

Work scheduled by: ConEd

SCH - PJM_HTP

FWD (Import)

REV (Export)

300 MW

Impacts Total Transfer Capability

360 MW

TTC with All Lines In Service

660 MW

MARCY___765_345_AT2

Sat 04/06/2024 to Sat 04/06/2024

0500 Continuous 1930

Work scheduled by: NYPA

ARR: 19

MOSES SOUTH

FWD (Import)

REV (Export)

1700 MW

Impacts Total Transfer Capability

1450 MW

TTC with All Lines In Service

3150 MW

W49TH_ST_345KV_5

Sun 04/07/2024 to Sun 04/07/2024

0130 Continuous 0200

Work scheduled by: ConEd

SCH - PJM_HTP

FWD (Import)

REV (Export)

300 MW

Impacts Total Transfer Capability

360 MW

TTC with All Lines In Service

660 MW

W49TH_ST_345KV_7

Sun 04/07/2024 to Sun 04/07/2024

0130 Continuous 0200

Work scheduled by: ConEd

SCH - PJM_HTP

FWD (Import)

REV (Export)

300 MW

Impacts Total Transfer Capability

360 MW

TTC with All Lines In Service

660 MW

GOETHALS_345KV_5

Mon 04/08/2024 to Mon 04/08/2024

0001 Continuous 0030

Work scheduled by: ConEd

CANCELLED by TO 03/06/2024 14:05

STATEN ISLAND

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

TTC with All Lines In Service

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 10, 2024 to Tuesday, September 9, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LINDEN_-GOETHALS_230_A2253

Mon 04/08/2024 to Tue 04/09/2024

0001 Continuous 0200

Work scheduled by: ConEd

CANCELLED by TO 03/06/2024 14:05

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

LINDN_CG-LNDVFT__345_V-3022

Mon 04/08/2024 to Sat 04/13/2024

0800 Continuous 1500

Work scheduled by: PJM

SCH - PJM_VFT

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

0 MW

0 MW

315 MW

315 MW

315 MW

315 MW

SPRNBK_345KV_RS3 , SPRNBK_345KV_RS4

Mon 04/08/2024 to Mon 04/08/2024

2130 2200

Work scheduled by:

SPR/DUN-SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

3800 MW

800 MW

4600 MW

GOETHALS_345KV_5

Tue 04/09/2024 to Tue 04/09/2024

0130 Continuous 0200

Work scheduled by: ConEd

CANCELLED by TO 03/06/2024 14:05

STATEN ISLAND

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

BERKSHIR-ALPS__345_393

Tue 04/09/2024 to Fri 05/10/2024

0600 Continuous 1500

Work scheduled by: NGrid

UPDATED by ISONE 02/08/2024 16:42

ARR: 78

SCH - NPX_1385

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

100 MW

100 MW

100 MW

100 MW

200 MW

200 MW

BERKSHIR-ALPS__345_393

Tue 04/09/2024 to Fri 05/10/2024

0600 Continuous 1500

Work scheduled by: NGrid

UPDATED by ISONE 02/08/2024 16:42

ARR: 78

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

1100 MW

1700 MW

300 MW

100 MW

1400 MW

1800 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 10, 2024 to Tuesday, September 9, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BERKSHIR-ALPS___345_393 , BERKSHIR-NORTHFLD_345_312					FWD (Import)	REV (Export)
Tue 04/09/2024	to	Fri 05/10/2024		SCH - NE - NY	1100 MW	1100 MW
0600		1500		Impacts Total Transfer Capability	300 MW	700 MW
Work scheduled by: ARR: 78				TTC with All Lines In Service	1400 MW	1800 MW
BERKSHIR-NORTHFLD_345_312					FWD (Import)	REV (Export)
Tue 04/09/2024	to	Fri 05/10/2024	<u>UPDATED by ISONE 02/08/2024 16:42</u>	SCH - NPX_1385	100 MW	100 MW
0600	Continuous	1500		Impacts Total Transfer Capability	100 MW	100 MW
Work scheduled by: NGrid				TTC with All Lines In Service	200 MW	200 MW
BERKSHIR-NORTHFLD_345_312					FWD (Import)	REV (Export)
Tue 04/09/2024	to	Fri 05/10/2024	<u>UPDATED by ISONE 02/08/2024 16:42</u>	SCH - NE - NY	1300 MW	
0600	Continuous	1500		Impacts Total Transfer Capability	100 MW	
Work scheduled by: NGrid				TTC with All Lines In Service	1400 MW	
SCH-NE-NYISO_LIMIT_900					FWD (Import)	REV (Export)
Tue 04/09/2024	to	Tue 04/30/2024	<u>UPDATED by ISONE 02/08/2024 16:42</u>	SCH - NE - NY	1100 MW	
0600	Continuous	2359		Impacts Total Transfer Capability	300 MW	
Work scheduled by: NGrid				TTC with All Lines In Service	1400 MW	
SCH-NYISO-NE_LIMIT_900					FWD (Import)	REV (Export)
Tue 04/09/2024	to	Fri 05/10/2024	<u>UPDATED by ISONE 02/08/2024 16:42</u>	SCH - NE - NY		1100 MW
0600	Continuous	2359		Impacts Total Transfer Capability		700 MW
Work scheduled by: NGrid				TTC with All Lines In Service		1800 MW
CHAT_DC_GC1					FWD (Import)	REV (Export)
Sun 04/14/2024	to	Sun 04/14/2024		MOSES SOUTH	2850 MW	
0001	Continuous	0200		Impacts Total Transfer Capability	300 MW	
Work scheduled by: HQ				TTC with All Lines In Service	3150 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 10, 2024 to Tuesday, September 9, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHAT_DC_GC1				FWD (Import)	REV (Export)
Sun 04/14/2024	to	Sun 04/14/2024	SCH - HQ - NY		500 MW
0001	Continuous	0200	Impacts Total Transfer Capability	500 MW	
Work scheduled by: HQ			TTC with All Lines In Service	1000 MW	
CHAT_DC_GC1 , CHAT_DC_GC2				FWD (Import)	REV (Export)
Sun 04/14/2024	to	Sun 04/14/2024	MOSES SOUTH	2550 MW	
0001		0200	Impacts Total Transfer Capability	600 MW	
Work scheduled by:			TTC with All Lines In Service	3150 MW	
CHAT_DC_GC1 , CHAT_DC_GC2				FWD (Import)	REV (Export)
Sun 04/14/2024	to	Sun 04/14/2024	SCH - HQ - NY	1370 MW	0 MW
0001		0200	Impacts Total Transfer Capability	130 MW	1000 MW
Work scheduled by:			TTC with All Lines In Service	1500 MW	1000 MW
CHAT_DC_GC2				FWD (Import)	REV (Export)
Sun 04/14/2024	to	Sun 04/14/2024	MOSES SOUTH	2850 MW	
0001	Continuous	0200	Impacts Total Transfer Capability	300 MW	
Work scheduled by: HQ			TTC with All Lines In Service	3150 MW	
CHAT_DC_GC2				FWD (Import)	REV (Export)
Sun 04/14/2024	to	Sun 04/14/2024	SCH - HQ - NY		500 MW
0001	Continuous	0200	Impacts Total Transfer Capability	500 MW	
Work scheduled by: HQ			TTC with All Lines In Service	1000 MW	
SCH-HQ-NYISO_LIMIT_1150				FWD (Import)	REV (Export)
Sun 04/14/2024	to	Sun 04/14/2024	SCH - HQ - NY	1150 MW	
0001	Continuous	0200	Impacts Total Transfer Capability	350 MW	
Work scheduled by: HQ			TTC with All Lines In Service	1500 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 10, 2024 to Tuesday, September 9, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NPX_1385-NYISO_LIMIT_100

Mon 04/15/2024 to Fri 04/26/2024
0600 Continuous 2200
Work scheduled by: ISONE

SCH - NPX_1385
Impacts Total Transfer Capability 100 MW
TTC with All Lines In Service 200 MW

ELBRIDGE-LAFAYTTE_345_17-LE

Tue 04/16/2024 to Fri 05/03/2024
0700 Continuous 1630
Work scheduled by: NGrid

ARR: 75

OSWEGO EXPORT
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 5250 MW

LINDN_CG-LNDVFT__345_V-3022

Thu 04/18/2024 to Thu 04/18/2024
1500 Continuous 1800
Work scheduled by: PJM

SCH - PJM_VFT
Impacts Total Transfer Capability 315 MW
TTC with All Lines In Service 315 MW

HUDSONTP-W49TH_ST_345_Y56

Mon 04/22/2024 to Fri 04/26/2024
0600 Continuous 1600
Work scheduled by: ConEd

SCH - PJM_HTP
Impacts Total Transfer Capability 660 MW
TTC with All Lines In Service 660 MW

W49TH_ST_345KV_7

Mon 04/22/2024 to Mon 04/22/2024
0600 Continuous 0630
Work scheduled by: ConEd

SCH - PJM_HTP
Impacts Total Transfer Capability 360 MW
TTC with All Lines In Service 660 MW

W49TH_ST_345KV_8

Mon 04/22/2024 to Mon 04/22/2024
0600 Continuous 0630
Work scheduled by: ConEd

SCH - PJM_HTP
Impacts Total Transfer Capability 350 MW
TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 10, 2024 to Tuesday, September 9, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PANNELL_-CLAY___345_1					FWD (Import)	REV (Export)
Mon 04/22/2024	to	Fri 04/26/2024		WEST CENTRAL	1300 MW	
0700	Continuous	1530		Impacts Total Transfer Capability	950 MW	
Work scheduled by: NYPA				TTC with All Lines In Service	2250 MW	
DUNWODIE_345KV_6					FWD (Import)	REV (Export)
Tue 04/23/2024	to	Tue 04/23/2024		SPR/DUN-SOUTH	3800 MW	
0001	Continuous	0030		Impacts Total Transfer Capability	800 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	4600 MW	
DUNWODIE_345KV_8					FWD (Import)	REV (Export)
Tue 04/23/2024	to	Tue 04/23/2024		SPR/DUN-SOUTH	3800 MW	
0001	Continuous	0030		Impacts Total Transfer Capability	800 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	4600 MW	
OSWEGO_-ELBRIDGE_345_17					FWD (Import)	REV (Export)
Tue 04/23/2024	to	Sat 04/27/2024		OSWEGO EXPORT	5250 MW	
0730	Continuous	1630	ARR: 75	Impacts Total Transfer Capability	0 MW	
Work scheduled by: NGrid				TTC with All Lines In Service	5250 MW	
DUNWODIE_345KV_6					FWD (Import)	REV (Export)
Wed 04/24/2024	to	Wed 04/24/2024		SPR/DUN-SOUTH	3800 MW	
2130	Continuous	2200		Impacts Total Transfer Capability	800 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	4600 MW	
DUNWODIE_345KV_8					FWD (Import)	REV (Export)
Wed 04/24/2024	to	Wed 04/24/2024		SPR/DUN-SOUTH	3800 MW	
2130	Continuous	2200		Impacts Total Transfer Capability	800 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	4600 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 10, 2024 to Tuesday, September 9, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DYSINGER-STA_255_345_DH1

Fri 04/26/2024 to Tue 05/07/2024
0500 Continuous 1900
Work scheduled by: NYPA

DYSINGER EAST
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
2850 MW	
350 MW	
3200 MW	

W49TH_ST_345KV_7

Fri 04/26/2024 to Fri 04/26/2024
1530 Continuous 1600
Work scheduled by: ConEd

SCH - PJM_HTP
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
300 MW	
360 MW	
660 MW	

W49TH_ST_345KV_8

Fri 04/26/2024 to Fri 04/26/2024
1530 Continuous 1600
Work scheduled by: ConEd

SCH - PJM_HTP
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
310 MW	
350 MW	
660 MW	

SHOR_NPX-SHOREHAM_138_CSC

Mon 04/29/2024 to Sat 05/04/2024
0600 Continuous 1800
Work scheduled by: LI

SCH - NPX_CSC
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
0 MW	0 MW
330 MW	330 MW
330 MW	330 MW

MARCY__FRASANNX_345_UCC2-41

Mon 04/29/2024 to Fri 05/24/2024
0700 Continuous 1730
Work scheduled by: NYPA

UPDATED by NYPA 02/13/2024 10:53
ARR: 19

CENTRAL EAST - VC
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
3225 MW	
500 MW	
3725 MW	

PANNELL-CLAY__345_2

Mon 04/29/2024 to Fri 05/03/2024
0700 Continuous 1530
Work scheduled by: NYPA

WEST CENTRAL
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
1300 MW	
950 MW	
2250 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 10, 2024 to Tuesday, September 9, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LADENTWN-BUCHAN_S_345_Y88

Tue 04/30/2024 to Sun 05/19/2024
0201 Continuous 2359
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
UPNY CONED	7695 MW	
Impacts Total Transfer Capability	355 MW	
TTC with All Lines In Service	8050 MW	

SCH-NE-NYISO_LIMIT_700

Wed 05/01/2024 to Fri 05/10/2024
0001 Continuous 1500
Work scheduled by: NGrid
UPDATED by ISONE 02/08/2024 16:42

	FWD (Import)	REV (Export)
SCH - NE - NY	900 MW	
Impacts Total Transfer Capability	500 MW	
TTC with All Lines In Service	1400 MW	

W49TH_ST_345KV_5

Wed 05/01/2024 to Fri 05/03/2024
0001 Continuous 0200
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - PJM_HTP	300 MW	
Impacts Total Transfer Capability	360 MW	
TTC with All Lines In Service	660 MW	

W49TH_ST_345KV_7

Wed 05/01/2024 to Fri 05/03/2024
0001 Continuous 0200
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - PJM_HTP	300 MW	
Impacts Total Transfer Capability	360 MW	
TTC with All Lines In Service	660 MW	

SPRNBK_345KV_RNS4

Sun 05/05/2024 to Sun 05/05/2024
0001 Continuous 1930
Work scheduled by: ConEd
UPDATED by ConEd 02/07/2024 10:31

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	3200 MW	
Impacts Total Transfer Capability	1400 MW	
TTC with All Lines In Service	4600 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 10, 2024 to Tuesday, September 9, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK -W49TH_ST_345_M52

Sun 05/05/2024 to Sun 05/05/2024
0001 Continuous 1930
Work scheduled by: ConEd

UPDATED by ConEd 02/07/2024 10:31

SPR/DUN-SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
3200 MW
1400 MW
4600 MW

W49TH_ST_345KV_5

Sun 05/05/2024 to Sun 05/05/2024
0001 Continuous 1730
Work scheduled by: ConEd

UPDATED by ConEd 02/07/2024 10:31

SCH - PJM_HTP
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
300 MW
360 MW
660 MW

W49TH_ST_345KV_5

Sun 05/05/2024 to Sun 05/05/2024
1900 Continuous 1930
Work scheduled by: ConEd

UPDATED by ConEd 02/07/2024 10:31

SCH - PJM_HTP
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
300 MW
360 MW
660 MW

EGRDNCTY_345_138_AT1

Mon 05/06/2024 to Mon 05/06/2024
0001 Continuous 0030
Work scheduled by: ConEd

CONED - LIPA
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
1250 MW
250 MW
1500 MW

EGRDNCTY_345_138_AT2

Mon 05/06/2024 to Mon 05/06/2024
0001 Continuous 0030
Work scheduled by: ConEd

CONED - LIPA
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
1250 MW
250 MW
1500 MW

SPRNBK -EGRDNCTR_345_Y49

Mon 05/06/2024 to Wed 05/08/2024
0001 Continuous 2200
Work scheduled by: ConEd

CONED - LIPA
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
775 MW
725 MW
1500 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 10, 2024 to Tuesday, September 9, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PANNELL_-CLAY___345_2

Tue 05/07/2024 to Tue 05/07/2024
0730 Continuous 1430
Work scheduled by: NGrid

WEST CENTRAL FWD (Import) REV (Export)
1300 MW
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

EGRDNCTY_345_138_AT1

Tue 05/07/2024 to Tue 05/07/2024
2130 Continuous 2200
Work scheduled by: ConEd

CONED - LIPA FWD (Import) REV (Export)
1250 MW
Impacts Total Transfer Capability 250 MW
TTC with All Lines In Service 1500 MW

EGRDNCTY_345_138_AT2

Tue 05/07/2024 to Tue 05/07/2024
2130 Continuous 2200
Work scheduled by: ConEd

CONED - LIPA FWD (Import) REV (Export)
1250 MW
Impacts Total Transfer Capability 250 MW
TTC with All Lines In Service 1500 MW

E13THSTA-FARRAGUT_345_46

Wed 05/08/2024 to Sun 05/12/2024
0201 Continuous 0301
Work scheduled by: ConEd
UPDATED by ConEd 02/27/2024 15:33

SPR/DUN-SOUTH FWD (Import) REV (Export)
3800 MW
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

CLAY___-INDPDNCE_345_26

Wed 05/08/2024 to Wed 05/08/2024
0730 Continuous 1430
Work scheduled by: NGrid

OSWEGO EXPORT FWD (Import) REV (Export)
5000 MW
Impacts Total Transfer Capability 250 MW
TTC with All Lines In Service 5250 MW

PANNELL_-CLAY___345_1

Thu 05/09/2024 to Thu 05/09/2024
0730 Continuous 1430
Work scheduled by: NGrid

WEST CENTRAL FWD (Import) REV (Export)
1300 MW
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 10, 2024 to Tuesday, September 9, 2025

CENTRAL EAST 7550 MW
 CENTRAL EAST - VC 3725 MW
 TOTAL EAST 6150 MW
 UPNY CONED 8050 MW
 SPR/DUN-SOUTH 4600 MW
 DYSINGER EAST 3200 MW
 MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_ROBNSNRD_230_64

Mon 05/13/2024 to Fri 05/17/2024
 0500 Continuous 1900
 Work scheduled by: NYPA

SCH - OH - NY
 Impacts Total Transfer Capability 1500 MW
 TTC with All Lines In Service 150 MW
 TTC with All Lines In Service 1650 MW

NEPTUNE_DUFFYAVE_345_NEPTUNE

Mon 05/13/2024 to Fri 05/17/2024
 0600 Continuous 1600
 Work scheduled by: LI

SCH - PJM_NEPTUNE
 Impacts Total Transfer Capability 0 MW
 TTC with All Lines In Service 660 MW
 TTC with All Lines In Service 660 MW

NEWBRDGE_345_138_BK_1

Mon 05/13/2024 to Fri 05/17/2024
 0600 Continuous 1600
 Work scheduled by: LI

SCH - PJM_NEPTUNE
 Impacts Total Transfer Capability 375 MW
 TTC with All Lines In Service 285 MW
 TTC with All Lines In Service 660 MW

NEWBRDGE_345_138_BK_2

Mon 05/13/2024 to Fri 05/17/2024
 0600 Continuous 1600
 Work scheduled by: LI

SCH - PJM_NEPTUNE
 Impacts Total Transfer Capability 375 MW
 TTC with All Lines In Service 285 MW
 TTC with All Lines In Service 660 MW

NEWBRDGE-DUFFYAVE_345_501

Mon 05/13/2024 to Fri 05/17/2024
 0600 Continuous 1600
 Work scheduled by: LI

SCH - PJM_NEPTUNE
 Impacts Total Transfer Capability 0 MW
 TTC with All Lines In Service 660 MW
 TTC with All Lines In Service 660 MW

VOLNEY__CLAY___345_6

Tue 05/14/2024 to Tue 05/14/2024
 0730 Continuous 1430
 Work scheduled by: NGrid

OSWEGO EXPORT
 Impacts Total Transfer Capability 5250 MW
 TTC with All Lines In Service 0 MW
 TTC with All Lines In Service 5250 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 10, 2024 to Tuesday, September 9, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CLAY__-EDIC__345_2-15

Wed 05/15/2024 to Wed 05/15/2024
0730 Continuous 1430
Work scheduled by: NGrid

OSWEGO EXPORT FWD (Import) REV (Export)
4850 MW
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 5250 MW

NINEMILE-CLAY__345_8

Thu 05/16/2024 to Thu 05/16/2024
0730 Continuous 1430
Work scheduled by: NGrid

OSWEGO EXPORT FWD (Import) REV (Export)
5150 MW
Impacts Total Transfer Capability 100 MW
TTC with All Lines In Service 5250 MW

BUCHAN_S-MILLWOOD_345_W97

Fri 05/17/2024 to Sat 05/18/2024
0001 Continuous 0200
Work scheduled by: ConEd

UPNY CONED FWD (Import) REV (Export)
8015 MW
Impacts Total Transfer Capability 35 MW
TTC with All Lines In Service 8050 MW

KNICRBKR-PLSNTVLY_345_Y57

Sat 05/18/2024 to Sun 05/26/2024
2300 Continuous 0100
Work scheduled by: NGrid ARR: 78

UPNY CONED FWD (Import) REV (Export)
7885 MW
Impacts Total Transfer Capability 165 MW
TTC with All Lines In Service 8050 MW

FITZPTRK-EDIC__345_FE-1

Mon 05/20/2024 to Fri 05/24/2024
0700 Continuous 1530
Work scheduled by: NYPA

OSWEGO EXPORT FWD (Import) REV (Export)
4800 MW
Impacts Total Transfer Capability 450 MW
TTC with All Lines In Service 5250 MW

FITZPTRK-EDIC__345_FE-1

Mon 05/20/2024 to Fri 05/24/2024
0700 Continuous 1530
Work scheduled by: NYPA

CENTRAL EAST - VC FWD (Import) REV (Export)
3520 MW
Impacts Total Transfer Capability 205 MW
TTC with All Lines In Service 3725 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 10, 2024 to Tuesday, September 9, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FITZPTRK-EDIC___345_FE-1

Tue 05/28/2024 to Fri 05/31/2024
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
OSWEGO EXPORT	4800 MW	
Impacts Total Transfer Capability	450 MW	
TTC with All Lines In Service	5250 MW	

FITZPTRK-EDIC___345_FE-1

Tue 05/28/2024 to Fri 05/31/2024
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
CENTRAL EAST - VC	3520 MW	
Impacts Total Transfer Capability	205 MW	
TTC with All Lines In Service	3725 MW	

CHATGUAY-MASSENA_765_7040

Wed 05/29/2024 to Sat 06/01/2024
1800 Continuous 0500
Work scheduled by: NYPA

UPDATED by NYPA 02/02/2024 10:05

	FWD (Import)	REV (Export)
SCH - HQ - NY	0 MW	0 MW
Impacts Total Transfer Capability	1500 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

CHATGUAY-MASSENA_765_7040

Wed 05/29/2024 to Sat 06/01/2024
1800 Continuous 0500
Work scheduled by: NYPA

UPDATED by NYPA 02/02/2024 10:05

	FWD (Import)	REV (Export)
MOSES SOUTH	1550 MW	
Impacts Total Transfer Capability	1600 MW	
TTC with All Lines In Service	3150 MW	

MARCY___765_345_AT1

Wed 05/29/2024 to Sat 06/01/2024
1800 Continuous 0500
Work scheduled by: NYPA

UPDATED by NYPA 02/02/2024 10:05

ARR: 19

	FWD (Import)	REV (Export)
MOSES SOUTH	1750 MW	
Impacts Total Transfer Capability	1400 MW	
TTC with All Lines In Service	3150 MW	

MARCY___765_345_AT2

Wed 05/29/2024 to Sat 06/01/2024
1800 Continuous 0500
Work scheduled by: NYPA

UPDATED by NYPA 02/02/2024 10:05

ARR: 19

	FWD (Import)	REV (Export)
MOSES SOUTH	1700 MW	
Impacts Total Transfer Capability	1450 MW	
TTC with All Lines In Service	3150 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 10, 2024 to Tuesday, September 9, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA_-MARCY___765_MSU1						FWD (Import)	REV (Export)
Wed 05/29/2024	to	Sat 06/01/2024	<u>UPDATED by NYPA 02/02/2024 10:05</u>	SCH - HQ_CEDARS		90 MW	
1800	Continuous	0500		Impacts Total Transfer Capability		180 MW	
Work scheduled by: NYPA					TTC with All Lines In Service	270 MW	
MASSENA_-MARCY___765_MSU1						FWD (Import)	REV (Export)
Wed 05/29/2024	to	Sat 06/01/2024	<u>UPDATED by NYPA 02/02/2024 10:05</u>	SCH - HQ - NY		475 MW	1000 MW
1800	Continuous	0500		Impacts Total Transfer Capability		1025 MW	0 MW
Work scheduled by: NYPA					TTC with All Lines In Service	1500 MW	1000 MW
MASSENA_-MARCY___765_MSU1						FWD (Import)	REV (Export)
Wed 05/29/2024	to	Sat 06/01/2024	<u>UPDATED by NYPA 02/02/2024 10:05</u>	MOSES SOUTH		500 MW	
1800	Continuous	0500		Impacts Total Transfer Capability		2650 MW	
Work scheduled by: NYPA					TTC with All Lines In Service	3150 MW	
MASSENA_-MARCY___765_MSU1						FWD (Import)	REV (Export)
Wed 05/29/2024	to	Sat 06/01/2024	<u>UPDATED by NYPA 02/02/2024 10:05</u>	CENTRAL EAST - VC		2595 MW	
1800	Continuous	0500		Impacts Total Transfer Capability		1130 MW	
Work scheduled by: NYPA					TTC with All Lines In Service	3725 MW	
MASSENA_-MARCY___765_MSU1 , CHATGUAY-MASSENA_765_7040						FWD (Import)	REV (Export)
Wed 05/29/2024	to	Sat 06/01/2024		MOSES SOUTH		500 MW	
1800		0500		Impacts Total Transfer Capability		2650 MW	
Work scheduled by:					TTC with All Lines In Service	3150 MW	
MOSES__-MASSENA_230_MMS2 , MOSES__-MASSENA_230_MMS1						FWD (Import)	REV (Export)
Wed 05/29/2024	to	Sat 06/01/2024		SCH - HQ_CEDARS		90 MW	
1800		0500		Impacts Total Transfer Capability		180 MW	
Work scheduled by:					TTC with All Lines In Service	270 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 10, 2024 to Tuesday, September 9, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES__-MASSENA_230_MMS2 , MOSES__-MASSENA_230_MMS1				FWD (Import)	REV (Export)
Wed 05/29/2024	to	Sat 06/01/2024	SCH - HQ - NY	850 MW	0 MW
1800		0500	Impacts Total Transfer Capability	650 MW	1000 MW
Work scheduled by:			TTC with All Lines In Service	1500 MW	1000 MW
BECK__-PACKARD_230_BP76				FWD (Import)	REV (Export)
Fri 05/31/2024	to	Fri 05/31/2024	SCH - OH - NY	1600 MW	1050 MW
0730	Continuous	1630	Impacts Total Transfer Capability	450 MW	600 MW
Work scheduled by: NGrid			TTC with All Lines In Service	2050 MW	1650 MW
CHASLAKE-PORTER__230_11				FWD (Import)	REV (Export)
Sat 06/01/2024	to	Wed 07/03/2024	MOSES SOUTH	2100 MW	
0530	Continuous	1600	Impacts Total Transfer Capability	1050 MW	
Work scheduled by: NGrid			TTC with All Lines In Service	3150 MW	
WATRCURE-OAKDALE_345_31				FWD (Import)	REV (Export)
Mon 06/03/2024	to	Fri 06/07/2024	SCH - PJ - NY	2050 MW	
0700	Continuous	1430	Impacts Total Transfer Capability	200 MW	
Work scheduled by: NYSEG			TTC with All Lines In Service	2250 MW	
NIAGARA_345_230_AT4				FWD (Import)	REV (Export)
Tue 06/11/2024	to	Wed 06/12/2024	SCH - OH - NY		1200 MW
0500	Continuous	1900	Impacts Total Transfer Capability		450 MW
Work scheduled by: NYPA			TTC with All Lines In Service		1650 MW
CHASLAKE-PORTER__230_11				FWD (Import)	REV (Export)
Mon 07/08/2024	to	Fri 08/30/2024	MOSES SOUTH	2100 MW	
0700	Continuous	1900	Impacts Total Transfer Capability	1050 MW	
Work scheduled by: NGrid			TTC with All Lines In Service	3150 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 10, 2024 to Tuesday, September 9, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

OSWEGO__VOLNEY__345_11

Mon 07/08/2024 to Fri 07/26/2024
 0700 Continuous 1700
 Work scheduled by: NGrid

OSWEGO EXPORT	FWD (Import)	REV (Export)
	5250 MW	
Impacts Total Transfer Capability	0 MW	
TTC with All Lines In Service	5250 MW	

DYSINGER-STA_255_345_DH2

Mon 07/15/2024 to Sun 08/04/2024
 0500 Continuous 1900
 Work scheduled by: NYPA

DYSINGER EAST	FWD (Import)	REV (Export)
	2850 MW	
Impacts Total Transfer Capability	350 MW	
TTC with All Lines In Service	3200 MW	

ROSETON_-EFISHKIL_345_RFK305

Sat 07/20/2024 to Sun 07/21/2024
 0700 Continuous 1600
 Work scheduled by: CHGE

UPNY CONED	FWD (Import)	REV (Export)
	7215 MW	
Impacts Total Transfer Capability	835 MW	
TTC with All Lines In Service	8050 MW	

LEEDS__345_LEEDS SVC

Mon 07/22/2024 to Thu 07/25/2024
 0730 Continuous 1600
 Work scheduled by: NGrid

CENTRAL EAST - VC	FWD (Import)	REV (Export)
	3675 MW	
Impacts Total Transfer Capability	50 MW	
TTC with All Lines In Service	3725 MW	

FRASER__345_FRASER SVC

Mon 07/29/2024 to Fri 08/02/2024
 0800 Continuous 1400
 Work scheduled by: NYSEG

CENTRAL EAST - VC	FWD (Import)	REV (Export)
	3655 MW	
Impacts Total Transfer Capability	70 MW	
TTC with All Lines In Service	3725 MW	

EDIC__-GORDONRD_345_14

Mon 08/19/2024 to Fri 08/30/2024
 0630 Continuous 1800
 Work scheduled by: NGrid

CENTRAL EAST - VC	FWD (Import)	REV (Export)
	2770 MW	
Impacts Total Transfer Capability	955 MW	
TTC with All Lines In Service	3725 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 10, 2024 to Tuesday, September 9, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EDIC__-PRINCTWN_345_351

Mon 08/19/2024 to Sat 08/24/2024

0700 Continuous 1700

Work scheduled by: NGrid

UPDATED by NGrid 02/02/2024 14:41

CENTRAL EAST - VC

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

3335 MW

390 MW

3725 MW

MARCY__-EDIC__345_UE1-7

Sun 08/25/2024 to Fri 08/30/2024

0800 Continuous 1600

Work scheduled by: NGrid

ARR: 16 & 19

OSWEGO EXPORT

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

5250 MW

0 MW

5250 MW

CHASLAKE-PORTER__230_11

Tue 09/03/2024 to Fri 11/15/2024

0530 Continuous 2000

Work scheduled by: NGrid

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

2100 MW

1050 MW

3150 MW

FITZPTRK-EDIC__345_FE-1

Mon 09/09/2024 to Mon 09/09/2024

0001 Continuous 0100

Work scheduled by: NYPA

OSWEGO EXPORT

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

4800 MW

450 MW

5250 MW

FITZPTRK-EDIC__345_FE-1

Mon 09/09/2024 to Mon 09/09/2024

0001 Continuous 0100

Work scheduled by: NYPA

CENTRAL EAST - VC

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

3520 MW

205 MW

3725 MW

EDIC__-PRINCTWN_345_351

Mon 09/09/2024 to Wed 09/11/2024

0700 Continuous 1700

Work scheduled by: NGrid

CENTRAL EAST - VC

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

3335 MW

390 MW

3725 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 10, 2024 to Tuesday, September 9, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ROCHESTR-PANNELL__345_RP1

Mon 09/09/2024 to Fri 09/13/2024
0700 Continuous 1530
Work scheduled by: NYPA

DYSINGER EAST FWD (Import) REV (Export)
2300 MW
Impacts Total Transfer Capability 900 MW
TTC with All Lines In Service 3200 MW

MARCY__-EDIC__345_UE1-7

Thu 09/12/2024 to Sat 09/14/2024
0700 Continuous 1700
Work scheduled by: NGrid ARR: 16 & 19

OSWEGO EXPORT FWD (Import) REV (Export)
5250 MW
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 5250 MW

MOTTHAVN-RAINEY__345_Q11

Sun 09/15/2024 to Sat 10/26/2024
0001 Continuous 0300
Work scheduled by: ConEd

SPR/DUN-SOUTH FWD (Import) REV (Export)
3800 MW
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

DYSINGER-STA_255_345_DH2

Mon 09/16/2024 to Mon 10/28/2024
0500 Continuous 1900
Work scheduled by: NYPA

DYSINGER EAST FWD (Import) REV (Export)
2850 MW
Impacts Total Transfer Capability 350 MW
TTC with All Lines In Service 3200 MW

ROCHESTR-PANNELL__345_RP2

Mon 09/16/2024 to Fri 09/20/2024
0700 Continuous 1530
Work scheduled by: NYPA

DYSINGER EAST FWD (Import) REV (Export)
2300 MW
Impacts Total Transfer Capability 900 MW
TTC with All Lines In Service 3200 MW

STLAWRNC-MOSES__230_L34P

Mon 09/16/2024 to Fri 09/20/2024
0700 Continuous 1530
Work scheduled by: NYPA

SCH - OH - NY FWD (Import) REV (Export)
Impacts Total Transfer Capability
TTC with All Lines In Service

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 10, 2024 to Tuesday, September 9, 2025

CENTRAL EAST 7550 MW
 CENTRAL EAST - VC 3725 MW
 TOTAL EAST 6150 MW
 UPNY CONED 8050 MW
 SPR/DUN-SOUTH 4600 MW
 DYSINGER EAST 3200 MW
 MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PANNELL-CLAY___345_1

Mon 09/23/2024 to Fri 09/27/2024

0700 Continuous 1530

Work scheduled by: NYPA

WEST CENTRAL

FWD (Import)

REV (Export)

1300 MW

Impacts Total Transfer Capability

950 MW

TTC with All Lines In Service

2250 MW

STLAWRNC-MOSES___230_L34P

Mon 09/23/2024 to Fri 09/27/2024

0700 Continuous 1530

Work scheduled by: NYPA

SCH - OH - NY

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

TTC with All Lines In Service

FITZPTRK-EDIC___345_FE-1

Thu 09/26/2024 to Thu 09/26/2024

0900 Continuous 1000

Work scheduled by: NYPA

OSWEGO EXPORT

FWD (Import)

REV (Export)

4800 MW

Impacts Total Transfer Capability

TTC with All Lines In Service

450 MW

5250 MW

FITZPTRK-EDIC___345_FE-1

Thu 09/26/2024 to Thu 09/26/2024

0900 Continuous 1000

Work scheduled by: NYPA

CENTRAL EAST - VC

FWD (Import)

REV (Export)

3520 MW

Impacts Total Transfer Capability

TTC with All Lines In Service

205 MW

3725 MW

STLAWRNC-MOSES___230_L34P

Mon 09/30/2024 to Fri 10/04/2024

0700 Continuous 1530

Work scheduled by: NYPA

SCH - OH - NY

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

TTC with All Lines In Service

FITZPTRK-EDIC___345_FE-1

Mon 09/30/2024 to Fri 10/04/2024

1700 Continuous 1530

Work scheduled by: NYPA

OSWEGO EXPORT

FWD (Import)

REV (Export)

4800 MW

Impacts Total Transfer Capability

TTC with All Lines In Service

450 MW

5250 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 10, 2024 to Tuesday, September 9, 2025

CENTRAL EAST 7550 MW
 CENTRAL EAST - VC 3725 MW
 TOTAL EAST 6150 MW
 UPNY CONED 8050 MW
 SPR/DUN-SOUTH 4600 MW
 DYSINGER EAST 3200 MW
 MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FITZPTRK-EDIC_345_FE-1

Mon 09/30/2024 to Fri 10/04/2024
 1700 Continuous 1530
 Work scheduled by: NYPA

	FWD (Import)	REV (Export)
CENTRAL EAST - VC	3520 MW	
Impacts Total Transfer Capability	205 MW	
TTC with All Lines In Service	3725 MW	

BECK_-NIAGARA_345_PA302

Mon 10/07/2024 to Fri 10/11/2024
 0500 Continuous 1900
 Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - OH - NY	1000 MW	850 MW
Impacts Total Transfer Capability	1050 MW	800 MW
TTC with All Lines In Service	2050 MW	1650 MW

NEPTUNE_-DUFFYAVE_345_NEPTUNE

Mon 10/07/2024 to Fri 10/11/2024
 0600 Continuous 1600
 Work scheduled by: LI

	FWD (Import)	REV (Export)
SCH - PJM_NEPTUNE	0 MW	
Impacts Total Transfer Capability	660 MW	
TTC with All Lines In Service	660 MW	

NEWBRDGE_345_138_BK_1

Mon 10/07/2024 to Fri 10/11/2024
 0600 Continuous 1600
 Work scheduled by: LI

	FWD (Import)	REV (Export)
SCH - PJM_NEPTUNE	375 MW	
Impacts Total Transfer Capability	285 MW	
TTC with All Lines In Service	660 MW	

NEWBRDGE_345_138_BK_2

Mon 10/07/2024 to Fri 10/11/2024
 0600 Continuous 1600
 Work scheduled by: LI

	FWD (Import)	REV (Export)
SCH - PJM_NEPTUNE	375 MW	
Impacts Total Transfer Capability	285 MW	
TTC with All Lines In Service	660 MW	

NEWBRDGE-DUFFYAVE_345_501

Mon 10/07/2024 to Fri 10/11/2024
 0600 Continuous 1600
 Work scheduled by: LI

	FWD (Import)	REV (Export)
SCH - PJM_NEPTUNE	0 MW	
Impacts Total Transfer Capability	660 MW	
TTC with All Lines In Service	660 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 10, 2024 to Tuesday, September 9, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SHOR_NPX-SHOREHAM_138_CSC						FWD (Import)	REV (Export)
Mon 10/07/2024	to	Fri 10/11/2024			SCH - NPX_CSC	0 MW	0 MW
0600	Continuous	1800			Impacts Total Transfer Capability	330 MW	330 MW
Work scheduled by: LI					TTC with All Lines In Service	330 MW	330 MW
MARCY__-FRASANNX_345_UCC2-41						FWD (Import)	REV (Export)
Wed 10/09/2024	to	Thu 10/10/2024			CENTRAL EAST - VC	3225 MW	
0700	Continuous	1530	ARR: 19		Impacts Total Transfer Capability	500 MW	
Work scheduled by: NYPA					TTC with All Lines In Service	3725 MW	
MARCY__-N.SCTLND_345_18						FWD (Import)	REV (Export)
Tue 10/15/2024	to	Thu 10/17/2024			CENTRAL EAST - VC	2665 MW	
0700	Continuous	1530	ARR: 19		Impacts Total Transfer Capability	1060 MW	
Work scheduled by: NYPA					TTC with All Lines In Service	3725 MW	
MARCY__-N.SCTLND_345_18						FWD (Import)	REV (Export)
Mon 10/21/2024	to	Fri 10/25/2024			CENTRAL EAST - VC	2665 MW	
0700	Continuous	1530	ARR: 19		Impacts Total Transfer Capability	1060 MW	
Work scheduled by: NYPA					TTC with All Lines In Service	3725 MW	
MARCY__345KV_CSC						FWD (Import)	REV (Export)
Mon 10/28/2024	to	Sun 11/10/2024			CENTRAL EAST - VC	3650 MW	
0700	Continuous	1530			Impacts Total Transfer Capability	75 MW	
Work scheduled by: NYPA					TTC with All Lines In Service	3725 MW	
DYSINGER-STA_255_345_DH2						FWD (Import)	REV (Export)
Tue 10/29/2024	to	Thu 10/31/2024			DYSINGER EAST	2850 MW	
0500	Continuous	2100			Impacts Total Transfer Capability	350 MW	
Work scheduled by: NYPA					TTC with All Lines In Service	3200 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 10, 2024 to Tuesday, September 9, 2025

CENTRAL EAST 7550 MW
 CENTRAL EAST - VC 3725 MW
 TOTAL EAST 6150 MW
 UPNY CONED 8050 MW
 SPR/DUN-SOUTH 4600 MW
 DYSINGER EAST 3200 MW
 MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DYSINGER-STA_255_345_DH1

Mon 11/04/2024 to Sat 11/16/2024
 0500 Continuous 1900
 Work scheduled by: NYPA

	FWD (Import)	REV (Export)
DYSINGER EAST	2850 MW	
Impacts Total Transfer Capability	350 MW	
TTC with All Lines In Service	3200 MW	

BECK__-NIAGARA_230_PA27

Fri 11/15/2024 to Fri 11/15/2024
 0500 Continuous 1900
 Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - OH - NY	2100 MW	
Impacts Total Transfer Capability	350 MW	
TTC with All Lines In Service	2450 MW	

CHATGUAY-MASSENA_765_7040

Sat 11/16/2024 to Fri 11/29/2024
 0001 Continuous 2359
 Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - HQ - NY	0 MW	0 MW
Impacts Total Transfer Capability	1500 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

CHATGUAY-MASSENA_765_7040

Sat 11/16/2024 to Fri 11/29/2024
 0001 Continuous 2359
 Work scheduled by: NYPA

	FWD (Import)	REV (Export)
MOSES SOUTH	1550 MW	
Impacts Total Transfer Capability	1600 MW	
TTC with All Lines In Service	3150 MW	

MARCY__765_345_AT1

Sat 11/16/2024 to Fri 11/29/2024
 0001 Continuous 2359
 Work scheduled by: NYPA

ARR: 19

	FWD (Import)	REV (Export)
MOSES SOUTH	1750 MW	
Impacts Total Transfer Capability	1400 MW	
TTC with All Lines In Service	3150 MW	

MARCY__765_345_AT2

Sat 11/16/2024 to Fri 11/29/2024
 0001 Continuous 2359
 Work scheduled by: NYPA

ARR: 19

	FWD (Import)	REV (Export)
MOSES SOUTH	1700 MW	
Impacts Total Transfer Capability	1450 MW	
TTC with All Lines In Service	3150 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 10, 2024 to Tuesday, September 9, 2025

CENTRAL EAST 7550 MW
 CENTRAL EAST - VC 3725 MW
 TOTAL EAST 6150 MW
 UPNY CONED 8050 MW
 SPR/DUN-SOUTH 4600 MW
 DYSINGER EAST 3200 MW
 MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA_-MARCY___765_MSU1					FWD (Import)	REV (Export)
Sat 11/16/2024	to	Fri 11/29/2024		SCH - HQ_CEDARS	90 MW	
0001	Continuous	2359		Impacts Total Transfer Capability	189 MW	
Work scheduled by: NYPA				TTC with All Lines In Service	279 MW	
MASSENA_-MARCY___765_MSU1					FWD (Import)	REV (Export)
Sat 11/16/2024	to	Fri 11/29/2024		SCH - HQ - NY	475 MW	1000 MW
0001	Continuous	2359		Impacts Total Transfer Capability	1025 MW	0 MW
Work scheduled by: NYPA				TTC with All Lines In Service	1500 MW	1000 MW
MASSENA_-MARCY___765_MSU1					FWD (Import)	REV (Export)
Sat 11/16/2024	to	Fri 11/29/2024		MOSES SOUTH	500 MW	
0001	Continuous	2359		Impacts Total Transfer Capability	2650 MW	
Work scheduled by: NYPA				TTC with All Lines In Service	3150 MW	
MASSENA_-MARCY___765_MSU1					FWD (Import)	REV (Export)
Sat 11/16/2024	to	Fri 11/29/2024		CENTRAL EAST - VC	2595 MW	
0001	Continuous	2359		Impacts Total Transfer Capability	1130 MW	
Work scheduled by: NYPA				TTC with All Lines In Service	3725 MW	
MASSENA_-MARCY___765_MSU1 , CHATGUAY-MASSENA_765_7040					FWD (Import)	REV (Export)
Sat 11/16/2024	to	Fri 11/29/2024		MOSES SOUTH	500 MW	
0001		2359		Impacts Total Transfer Capability	2650 MW	
Work scheduled by:				TTC with All Lines In Service	3150 MW	
MOSES___-MASSENA_230_MMS2 , MOSES___-MASSENA_230_MMS1					FWD (Import)	REV (Export)
Sat 11/16/2024	to	Fri 11/29/2024		SCH - HQ_CEDARS	90 MW	
0001		2359		Impacts Total Transfer Capability	189 MW	
Work scheduled by:				TTC with All Lines In Service	279 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, March 10, 2024 to Tuesday, September 9, 2025

CENTRAL EAST 7550 MW
 CENTRAL EAST - VC 3725 MW
 TOTAL EAST 6150 MW
 UPNY CONED 8050 MW
 SPR/DUN-SOUTH 4600 MW
 DYSINGER EAST 3200 MW
 MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES__-MASSENA_230_MMS2 , MOSES__-MASSENA_230_MMS1

Sat 11/16/2024 to Fri 11/29/2024
 0001 2359

Work scheduled by:

SCH - HQ - NY

FWD (Import)

REV (Export)

850 MW

0 MW

Impacts Total Transfer Capability

650 MW

1000 MW

TTC with All Lines In Service

1500 MW

1000 MW

ADIRNDCK-PORTER__230_12

Sun 12/01/2024 to Tue 12/24/2024
 0530 Continuous 1700

Work scheduled by: NGrid

MOSES SOUTH

FWD (Import)

REV (Export)

2300 MW

Impacts Total Transfer Capability

850 MW

TTC with All Lines In Service

3150 MW

ADIRNDCK-PORTER__230_12

Thu 01/02/2025 to Sat 05/31/2025
 0530 Continuous 1700

Work scheduled by: NGrid

MOSES SOUTH

FWD (Import)

REV (Export)

2300 MW

Impacts Total Transfer Capability

850 MW

TTC with All Lines In Service

3150 MW