

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 9, 2024 to Wednesday, October 8, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONP_-FARRAGUT_345_B3402

Mon 01/15/2018 to Tue 12/31/2024
0001 Continuous 2359
Work scheduled by: ConEd

EXT FORCED by ConEd 03/11/2024 11:26

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Tue 12/31/2024
0001 Continuous 2359
Work scheduled by: ConEd

EXT FORCED by ConEd 03/11/2024 11:26

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

MARION_-FARRAGUT_345_C3403 , HUDSONP_-FARRAGUT_345_B3402

Mon 01/15/2018 to Tue 12/31/2024
0001 2359
Work scheduled by:

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
2400 MW **2400 MW**
150 MW 250 MW
2550 MW 2650 MW

SCH-IMO-NYISO_LIMIT_1900

Wed 11/01/2023 to Tue 04/30/2024
0001 Continuous 2359
Work scheduled by: IESO

SCH - OH - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
2200 MW
250 MW
2450 MW

ADIRNDCK-PORTER__230_12

Tue 01/02/2024 to Wed 05/29/2024
0630 Continuous 1730
Work scheduled by: NGrid

UPDATED by NGrid 07/11/2023 11:44

MOSES SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
2300 MW
850 MW
3150 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 9, 2024 to Wednesday, October 8, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-IMO-NYISO_LIMIT_1750

Tue 01/02/2024 to Wed 05/29/2024
0630 Continuous 1730
Work scheduled by: NGrid

UPDATED by NGrid 07/11/2023 11:44

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

2050 MW

400 MW

2450 MW

SPRNBK_-W49TH_ST_345_M51

Tue 01/30/2024 to Thu 04/25/2024
0202 Continuous 2359
Work scheduled by: ConEd

EXT FORCED by ConEd 04/08/2024 15:10

SPR/DUN-SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

3200 MW

1400 MW

4600 MW

SHORE_RD_345_138_BK 1

Mon 02/12/2024 to Fri 05/03/2024
0001 Continuous 2359
Work scheduled by: LI

UPDATED by LI 02/07/2024 12:08

CONED - LIPA

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

1350 MW

150 MW

1500 MW

BECK_-PACKARD_230_BP76

Mon 03/04/2024 to Fri 05/24/2024
0500 Continuous 1600
Work scheduled by: NGrid

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

1800 MW

650 MW

2450 MW

1350 MW

550 MW

1900 MW

SCH-IMO-NYISO_LIMIT_1300

Mon 03/04/2024 to Mon 05/20/2024
0500 Continuous 0800
Work scheduled by: NGrid

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

1600 MW

850 MW

2450 MW

SCH-HQ_CEDARS-NYISO_LIMIT_240

Mon 03/11/2024 to Thu 04/11/2024
0800 Continuous 1800
Work scheduled by: HQ

SCH - HQ_CEDARS

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

240 MW

39 MW

279 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 9, 2024 to Wednesday, October 8, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-HQ_CEDARS_LIMIT_0

Mon 03/11/2024 to Thu 04/11/2024
0800 Continuous 1800
Work scheduled by: HQ

FWD (Import) REV (Export)
SCH - HQ_CEDARS 0 MW
Impacts Total Transfer Capability 100 MW
TTC with All Lines In Service 100 MW

CLAY__-EDIC__345_1-16

Mon 03/18/2024 to Fri 04/19/2024
0700 Continuous 0900
Work scheduled by: NGrid
UPDATED by NGrid 04/03/2024 09:02

FWD (Import) REV (Export)
OSWEGO EXPORT 4850 MW
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 5250 MW

RAMAPO__BUCHAN_N_345_Y94

Tue 04/02/2024 to Tue 04/30/2024
0201 Continuous 0200
Work scheduled by: ConEd

FWD (Import) REV (Export)
UPNY CONED 7755 MW
Impacts Total Transfer Capability 295 MW
TTC with All Lines In Service 8050 MW

MOTHAVN-RAINEY__345_Q12

Thu 04/04/2024 to Thu 04/25/2024
0001 Continuous 0200
Work scheduled by: ConEd
EXTENDED by ConEd 04/03/2024 10:26

FWD (Import) REV (Export)
SPR/DUN-SOUTH 3800 MW
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

STLAWRNC-MOSES__230_L34P

Thu 04/04/2024 to Tue 04/09/2024
1331 Continuous 2359
Work scheduled by: IESO
EXT FORCED by IESO 04/08/2024 16:28

FWD (Import) REV (Export)
SCH - OH - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FRASER__345_FRASER SVC

Sat 04/06/2024 to Fri 04/12/2024
1758 Continuous 1600
Work scheduled by: NYSEG

FWD (Import) REV (Export)
CENTRAL EAST - VC 3655 MW
Impacts Total Transfer Capability 70 MW
TTC with All Lines In Service 3725 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 9, 2024 to Wednesday, October 8, 2025

CENTRAL EAST 7550 MW
 CENTRAL EAST - VC 3725 MW
 TOTAL EAST 6150 MW
 UPNY CONED 8050 MW
 SPR/DUN-SOUTH 4600 MW
 DYSINGER EAST 3200 MW
 MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MILLWOOD-EASTVIEW_345_W99

Sun 04/07/2024 to Wed 04/10/2024
 1737 Continuous 2359

FORCED by ConEd 04/08/2024 15:04

UPNY CONED

FWD (Import)

REV (Export)

7810 MW

Impacts Total Transfer Capability

240 MW

TTC with All Lines In Service

8050 MW

Work scheduled by: ConEd

LINDN_CG-LNDVFT_345_V-3022

Mon 04/08/2024 to Sat 04/13/2024
 0800 Continuous 1500

UPDATED by PJM 03/13/2024 15:45

SCH - PJM_VFT

FWD (Import)

REV (Export)

0 MW

0 MW

Impacts Total Transfer Capability

315 MW

315 MW

TTC with All Lines In Service

315 MW

315 MW

Work scheduled by: PJM

SCH-NE-NYISO_LIMIT_600

Mon 04/08/2024 to Tue 04/09/2024
 2300 Continuous 0659

SCH - NE - NY

FWD (Import)

REV (Export)

800 MW

Impacts Total Transfer Capability

600 MW

TTC with All Lines In Service

1400 MW

Work scheduled by: ConEd

BERKSHIR-ALPS_345_393

Tue 04/09/2024 to Tue 04/09/2024
 0600 Continuous 0630

UPDATED by ISONE 04/02/2024 13:47

SCH - NPX_1385

FWD (Import)

REV (Export)

100 MW

100 MW

Impacts Total Transfer Capability

100 MW

100 MW

TTC with All Lines In Service

200 MW

200 MW

Work scheduled by: NGrid

ARR: 78

BERKSHIR-ALPS_345_393

Tue 04/09/2024 to Tue 04/09/2024
 0600 Continuous 0630

UPDATED by ISONE 04/02/2024 13:47

SCH - NE - NY

FWD (Import)

REV (Export)

1100 MW

1700 MW

Impacts Total Transfer Capability

300 MW

100 MW

TTC with All Lines In Service

1400 MW

1800 MW

Work scheduled by: NGrid

ARR: 78

BERKSHIR-ALPS_345_393 , BERKSHIR-NORTHFLD_345_312

Tue 04/09/2024 to Tue 04/09/2024
 0600 Continuous 0630

SCH - NE - NY

FWD (Import)

REV (Export)

1100 MW

1100 MW

Impacts Total Transfer Capability

300 MW

700 MW

TTC with All Lines In Service

1400 MW

1800 MW

Work scheduled by:

ARR: 78

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 9, 2024 to Wednesday, October 8, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BERKSHIR-NORTHFLD_345_312

Tue 04/09/2024 to Fri 05/10/2024
0600 Continuous 1500
Work scheduled by: NGrid

UPDATED by ISONE 04/02/2024 13:47

SCH - NPX_1385
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
100 MW 100 MW
100 MW 100 MW
200 MW 200 MW

BERKSHIR-NORTHFLD_345_312

Tue 04/09/2024 to Fri 05/10/2024
0600 Continuous 1500
Work scheduled by: NGrid

UPDATED by ISONE 04/02/2024 13:47

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
1300 MW
100 MW
1400 MW

SCH-NE-NYISO_LIMIT_700

Tue 04/09/2024 to Fri 05/10/2024
0600 Continuous 1500
Work scheduled by: NGrid

UPDATED by ISONE 04/02/2024 13:47

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
900 MW
500 MW
1400 MW

SCH-NYISO-NE_LIMIT_900

Tue 04/09/2024 to Fri 05/10/2024
0600 Continuous 2359
Work scheduled by: NGrid

UPDATED by ISONE 04/02/2024 13:47

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
1100 MW
700 MW
1800 MW

SCH-NE-NYISO_LIMIT_800

Tue 04/09/2024 to Tue 04/09/2024
0700 Continuous 2259
Work scheduled by: ConEd

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
1000 MW
400 MW
1400 MW

SCH-NE-NYISO_LIMIT_600

Tue 04/09/2024 to Wed 04/10/2024
2300 Continuous 0659
Work scheduled by: ConEd

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
800 MW
600 MW
1400 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 9, 2024 to Wednesday, October 8, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EGRDNCTY_345_138_AT1

Wed 04/10/2024 to Wed 04/10/2024
0700 Continuous 1500

FORCED by LI 04/08/2024 17:12

CONED - LIPA

FWD (Import)

REV (Export)

1250 MW

Impacts Total Transfer Capability

250 MW

TTC with All Lines In Service

1500 MW

Work scheduled by: LI

SCH-NE-NYISO_LIMIT_800

Wed 04/10/2024 to Wed 04/10/2024
0700 Continuous 2259

SCH - NE - NY

FWD (Import)

REV (Export)

1000 MW

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

1400 MW

Work scheduled by: ConEd

SCH-NE-NYISO_LIMIT_600

Wed 04/10/2024 to Thu 04/11/2024
2300 Continuous 0659

SCH - NE - NY

FWD (Import)

REV (Export)

800 MW

Impacts Total Transfer Capability

600 MW

TTC with All Lines In Service

1400 MW

Work scheduled by: ConEd

NIAGARA_PACKARD_230_62

Thu 04/11/2024 to Thu 04/11/2024
0700 Continuous 1630

SCH - OH - NY

FWD (Import)

REV (Export)

1750 MW

1850 MW

Impacts Total Transfer Capability

700 MW

50 MW

TTC with All Lines In Service

2450 MW

1900 MW

Work scheduled by: NGrid

SCH-NE-NYISO_LIMIT_800

Thu 04/11/2024 to Thu 04/11/2024
0700 Continuous 2259

SCH - NE - NY

FWD (Import)

REV (Export)

1000 MW

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

1400 MW

Work scheduled by: ConEd

SCH-IMO-NYISO_LIMIT_1000

Thu 04/11/2024 to Thu 04/11/2024
0730 Continuous 1700

SCH - OH - NY

FWD (Import)

REV (Export)

1300 MW

Impacts Total Transfer Capability

1150 MW

TTC with All Lines In Service

2450 MW

Work scheduled by: IESO

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 9, 2024 to Wednesday, October 8, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-IMO_LIMIT_700

Thu 04/11/2024 to Thu 04/11/2024
0730 Continuous 1700
Work scheduled by: IESO

	FWD (Import)	REV (Export)
SCH - OH - NY		1000 MW
Impacts Total Transfer Capability		900 MW
TTC with All Lines In Service		1900 MW

SCH-NE-NYISO_LIMIT_600

Thu 04/11/2024 to Fri 04/12/2024
2300 Continuous 0659
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - NE - NY	800 MW	
Impacts Total Transfer Capability	600 MW	
TTC with All Lines In Service	1400 MW	

SCH-NE-NYISO_LIMIT_800

Fri 04/12/2024 to Fri 04/12/2024
0700 Continuous 2259
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - NE - NY	1000 MW	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

SCH-NE-NYISO_LIMIT_600

Fri 04/12/2024 to Sat 04/13/2024
2300 Continuous 0659
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - NE - NY	800 MW	
Impacts Total Transfer Capability	600 MW	
TTC with All Lines In Service	1400 MW	

SCH-NE-NYISO_LIMIT_800

Sat 04/13/2024 to Sat 04/13/2024
0700 Continuous 2259
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - NE - NY	1000 MW	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

CHAT_DC_GC1

Sat 04/13/2024 to Sat 04/13/2024
2100 Continuous 2300
Work scheduled by: HQ

	FWD (Import)	REV (Export)
MOSES SOUTH	2850 MW	
Impacts Total Transfer Capability	300 MW	
TTC with All Lines In Service	3150 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 9, 2024 to Wednesday, October 8, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHAT_DC_GC1

Sat 04/13/2024 to Sat 04/13/2024
2100 Continuous 2300
Work scheduled by: HQ

	FWD (Import)	REV (Export)
SCH - HQ - NY		500 MW
Impacts Total Transfer Capability		500 MW
TTC with All Lines In Service		1000 MW

CHAT_DC_GC1 , CHAT_DC_GC2

Sat 04/13/2024 to Sat 04/13/2024
2100 2300
Work scheduled by:

	FWD (Import)	REV (Export)
MOSES SOUTH	2550 MW	
Impacts Total Transfer Capability	600 MW	
TTC with All Lines In Service	3150 MW	

CHAT_DC_GC1 , CHAT_DC_GC2

Sat 04/13/2024 to Sat 04/13/2024
2100 2300
Work scheduled by:

	FWD (Import)	REV (Export)
SCH - HQ - NY	1370 MW	0 MW
Impacts Total Transfer Capability	130 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

CHAT_DC_GC2

Sat 04/13/2024 to Sat 04/13/2024
2100 Continuous 2300
Work scheduled by: HQ

	FWD (Import)	REV (Export)
MOSES SOUTH	2850 MW	
Impacts Total Transfer Capability	300 MW	
TTC with All Lines In Service	3150 MW	

CHAT_DC_GC2

Sat 04/13/2024 to Sat 04/13/2024
2100 Continuous 2300
Work scheduled by: HQ

	FWD (Import)	REV (Export)
SCH - HQ - NY		500 MW
Impacts Total Transfer Capability		500 MW
TTC with All Lines In Service		1000 MW

SCH-HQ-NYISO_LIMIT_1150

Sat 04/13/2024 to Sat 04/13/2024
2100 Continuous 2300
Work scheduled by: HQ

	FWD (Import)	REV (Export)
SCH - HQ - NY	1150 MW	
Impacts Total Transfer Capability	350 MW	
TTC with All Lines In Service	1500 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 9, 2024 to Wednesday, October 8, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NE-NYISO_LIMIT_600

Sat 04/13/2024 to Sun 04/14/2024
2300 Continuous 0659
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	800 MW	
Impacts Total Transfer Capability	600 MW	
TTC with All Lines In Service	1400 MW	

SCH-NE-NYISO_LIMIT_800

Sun 04/14/2024 to Sun 04/14/2024
0700 Continuous 2259
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	1000 MW	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

SCH-NE-NYISO_LIMIT_600

Sun 04/14/2024 to Mon 04/15/2024
2300 Continuous 0659
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	800 MW	
Impacts Total Transfer Capability	600 MW	
TTC with All Lines In Service	1400 MW	

SCH-NPX_1385-NYISO_LIMIT_100

Mon 04/15/2024 to Fri 04/26/2024
0600 Continuous 2200
Work scheduled by: ISONE

UPDATED by ISONE 04/09/2024 13:34

SCH - NPX_1385	FWD (Import)	REV (Export)
	100 MW	
Impacts Total Transfer Capability	100 MW	
TTC with All Lines In Service	200 MW	

SCH-NE-NYISO_LIMIT_800

Mon 04/15/2024 to Mon 04/15/2024
0700 Continuous 2259
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	1000 MW	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

SCH-NE-NYISO_LIMIT_600

Mon 04/15/2024 to Tue 04/16/2024
2300 Continuous 0659
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	800 MW	
Impacts Total Transfer Capability	600 MW	
TTC with All Lines In Service	1400 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 9, 2024 to Wednesday, October 8, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ELBRIDGE-LAFAYTTE_345_17-LE

Tue 04/16/2024 to Fri 05/03/2024
0700 Continuous 1630

ARR: 75

OSWEGO EXPORT

FWD (Import)

REV (Export)

5250 MW

Impacts Total Transfer Capability

0 MW

TTC with All Lines In Service

5250 MW

SCH-NE-NYISO_LIMIT_800

Tue 04/16/2024 to Tue 04/16/2024
0700 Continuous 2259

SCH - NE - NY

FWD (Import)

REV (Export)

1000 MW

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

1400 MW

SCH-NE-NYISO_LIMIT_600

Tue 04/16/2024 to Wed 04/17/2024
2300 Continuous 0659

SCH - NE - NY

FWD (Import)

REV (Export)

800 MW

Impacts Total Transfer Capability

600 MW

TTC with All Lines In Service

1400 MW

SCH-NE-NYISO_LIMIT_800

Wed 04/17/2024 to Wed 04/17/2024
0700 Continuous 2259

SCH - NE - NY

FWD (Import)

REV (Export)

1000 MW

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

1400 MW

SCH-NE-NYISO_LIMIT_600

Wed 04/17/2024 to Thu 04/18/2024
2300 Continuous 0659

SCH - NE - NY

FWD (Import)

REV (Export)

800 MW

Impacts Total Transfer Capability

600 MW

TTC with All Lines In Service

1400 MW

SCH-NE-NYISO_LIMIT_800

Thu 04/18/2024 to Thu 04/18/2024
0700 Continuous 2259

SCH - NE - NY

FWD (Import)

REV (Export)

1000 MW

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

1400 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 9, 2024 to Wednesday, October 8, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LINDN_CG-LNDVFT__345_V-3022

Thu 04/18/2024 to Thu 04/18/2024
1500 Continuous 2200

UPDATED by PJM 03/13/2024 15:45

SCH - PJM_VFT

FWD (Import)

REV (Export)

0 MW

0 MW

Impacts Total Transfer Capability

315 MW

315 MW

TTC with All Lines In Service

315 MW

315 MW

Work scheduled by: PJM

SCH-NE-NYISO_LIMIT_600

Thu 04/18/2024 to Fri 04/19/2024
2300 Continuous 0659

SCH - NE - NY

FWD (Import)

REV (Export)

800 MW

Impacts Total Transfer Capability

600 MW

TTC with All Lines In Service

1400 MW

Work scheduled by: ConEd

SCH-NE-NYISO_LIMIT_800

Fri 04/19/2024 to Fri 04/19/2024
0700 Continuous 2259

SCH - NE - NY

FWD (Import)

REV (Export)

1000 MW

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

1400 MW

Work scheduled by: ConEd

SCH-NE-NYISO_LIMIT_600

Fri 04/19/2024 to Sat 04/20/2024
2300 Continuous 0659

SCH - NE - NY

FWD (Import)

REV (Export)

800 MW

Impacts Total Transfer Capability

600 MW

TTC with All Lines In Service

1400 MW

Work scheduled by: ConEd

SCH-NE-NYISO_LIMIT_800

Sat 04/20/2024 to Sat 04/20/2024
0700 Continuous 2259

SCH - NE - NY

FWD (Import)

REV (Export)

1000 MW

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

1400 MW

Work scheduled by: ConEd

SCH-NE-NYISO_LIMIT_600

Sat 04/20/2024 to Sun 04/21/2024
2300 Continuous 0659

SCH - NE - NY

FWD (Import)

REV (Export)

800 MW

Impacts Total Transfer Capability

600 MW

TTC with All Lines In Service

1400 MW

Work scheduled by: ConEd

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 9, 2024 to Wednesday, October 8, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK_345KV_RS4 , SPRNBK_345KV_RS3

Sun 04/21/2024 to Sun 04/21/2024
0001 0030

Work scheduled by:

SPR/DUN-SOUTH FWD (Import) REV (Export)
3800 MW
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

SCH-NE-NYISO_LIMIT_800

Sun 04/21/2024 to Sun 04/21/2024
0700 Continuous 2259

Work scheduled by: ConEd

SCH - NE - NY FWD (Import) REV (Export)
1000 MW
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 1400 MW

SCH-NE-NYISO_LIMIT_600

Sun 04/21/2024 to Mon 04/22/2024
2300 Continuous 0659

Work scheduled by: ConEd

SCH - NE - NY FWD (Import) REV (Export)
800 MW
Impacts Total Transfer Capability 600 MW
TTC with All Lines In Service 1400 MW

HUDSONTP-W49TH_ST_345_Y56

Mon 04/22/2024 to Fri 04/26/2024
0600 Continuous 1600

Work scheduled by: ConEd

SCH - PJM_HTP FWD (Import) REV (Export)
0 MW
Impacts Total Transfer Capability 660 MW
TTC with All Lines In Service 660 MW

W49TH_ST_345KV_7

Mon 04/22/2024 to Mon 04/22/2024
0600 Continuous 0630

Work scheduled by: ConEd

SCH - PJM_HTP FWD (Import) REV (Export)
300 MW
Impacts Total Transfer Capability 360 MW
TTC with All Lines In Service 660 MW

W49TH_ST_345KV_8

Mon 04/22/2024 to Mon 04/22/2024
0600 Continuous 0630

Work scheduled by: ConEd

SCH - PJM_HTP FWD (Import) REV (Export)
310 MW
Impacts Total Transfer Capability 350 MW
TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 9, 2024 to Wednesday, October 8, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PANNELL_-CLAY___345_1

Mon 04/22/2024 to Fri 04/26/2024
0700 Continuous 1530

Work scheduled by: NYPA

WEST CENTRAL FWD (Import) REV (Export)
1300 MW
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

SCH-NE-NYISO_LIMIT_800

Mon 04/22/2024 to Mon 04/22/2024
0700 Continuous 2259

Work scheduled by: ConEd

SCH - NE - NY FWD (Import) REV (Export)
1000 MW
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 1400 MW

SCH-NE-NYISO_LIMIT_600

Mon 04/22/2024 to Tue 04/23/2024
2300 Continuous 0659

Work scheduled by: ConEd

SCH - NE - NY FWD (Import) REV (Export)
800 MW
Impacts Total Transfer Capability 600 MW
TTC with All Lines In Service 1400 MW

SCH-NE-NYISO_LIMIT_800

Tue 04/23/2024 to Tue 04/23/2024
0700 Continuous 2259

Work scheduled by: ConEd

SCH - NE - NY FWD (Import) REV (Export)
1000 MW
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 1400 MW

OSWEGO_-ELBRIDGE_345_17

Tue 04/23/2024 to Sat 04/27/2024
0730 Continuous 1630

Work scheduled by: NGrid

ARR: 75

OSWEGO EXPORT FWD (Import) REV (Export)
5250 MW
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 5250 MW

SCH-NE-NYISO_LIMIT_600

Tue 04/23/2024 to Wed 04/24/2024
2300 Continuous 0659

Work scheduled by: ConEd

SCH - NE - NY FWD (Import) REV (Export)
800 MW
Impacts Total Transfer Capability 600 MW
TTC with All Lines In Service 1400 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 9, 2024 to Wednesday, October 8, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NE-NYISO_LIMIT_800

Wed 04/24/2024 to Wed 04/24/2024
0700 Continuous 2259
Work scheduled by: ConEd

SCH - NE - NY FWD (Import) REV (Export)
1000 MW
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 1400 MW

SPRNBK_345KV_RS4 , SPRNBK_345KV_RS3

Wed 04/24/2024 to Wed 04/24/2024
2130 2200
Work scheduled by:

SPR/DUN-SOUTH FWD (Import) REV (Export)
3800 MW
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

SCH-NE-NYISO_LIMIT_600

Wed 04/24/2024 to Thu 04/25/2024
2300 Continuous 0659
Work scheduled by: ConEd

SCH - NE - NY FWD (Import) REV (Export)
800 MW
Impacts Total Transfer Capability 600 MW
TTC with All Lines In Service 1400 MW

SCH-NE-NYISO_LIMIT_800

Thu 04/25/2024 to Thu 04/25/2024
0700 Continuous 2259
Work scheduled by: ConEd

SCH - NE - NY FWD (Import) REV (Export)
1000 MW
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 1400 MW

SCH-NE-NYISO_LIMIT_600

Thu 04/25/2024 to Fri 04/26/2024
2300 Continuous 0659
Work scheduled by: ConEd

SCH - NE - NY FWD (Import) REV (Export)
800 MW
Impacts Total Transfer Capability 600 MW
TTC with All Lines In Service 1400 MW

SPRNBK_345KV_RN55

Thu 04/25/2024 to Thu 04/25/2024
2330 Continuous 2359
Work scheduled by: ConEd
EXT FORCED by ConEd 04/08/2024 15:10

SPR/DUN-SOUTH FWD (Import) REV (Export)
3200 MW
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 9, 2024 to Wednesday, October 8, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NE-NYISO_LIMIT_800

Fri 04/26/2024 to Fri 04/26/2024
0700 Continuous 2259
Work scheduled by: ConEd

SCH - NE - NY **1000 MW**
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 1400 MW

FWD (Import) REV (Export)

W49TH_ST_345KV_7

Fri 04/26/2024 to Fri 04/26/2024
1530 Continuous 1600
Work scheduled by: ConEd

SCH - PJM_HTP **300 MW**
Impacts Total Transfer Capability 360 MW
TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

W49TH_ST_345KV_8

Fri 04/26/2024 to Fri 04/26/2024
1530 Continuous 1600
Work scheduled by: ConEd

SCH - PJM_HTP **310 MW**
Impacts Total Transfer Capability 350 MW
TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

SCH-NE-NYISO_LIMIT_600

Fri 04/26/2024 to Sat 04/27/2024
2300 Continuous 0659
Work scheduled by: ConEd

SCH - NE - NY **800 MW**
Impacts Total Transfer Capability 600 MW
TTC with All Lines In Service 1400 MW

FWD (Import) REV (Export)

SCH-NE-NYISO_LIMIT_800

Sat 04/27/2024 to Sat 04/27/2024
0700 Continuous 2259
Work scheduled by: ConEd

SCH - NE - NY **1000 MW**
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 1400 MW

FWD (Import) REV (Export)

SCH-NE-NYISO_LIMIT_600

Sat 04/27/2024 to Sun 04/28/2024
2300 Continuous 0659
Work scheduled by: ConEd

SCH - NE - NY **800 MW**
Impacts Total Transfer Capability 600 MW
TTC with All Lines In Service 1400 MW

FWD (Import) REV (Export)

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 9, 2024 to Wednesday, October 8, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NE-NYISO_LIMIT_800

Sun 04/28/2024 to Sun 04/28/2024
0700 Continuous 2259
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	1000 MW	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

SCH-NE-NYISO_LIMIT_600

Sun 04/28/2024 to Mon 04/29/2024
2300 Continuous 0659
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	800 MW	
Impacts Total Transfer Capability	600 MW	
TTC with All Lines In Service	1400 MW	

SHOR_NPX-SHOREHAM_138_CSC

Mon 04/29/2024 to Sat 05/04/2024
0600 Continuous 1800
Work scheduled by: LI

SCH - NPX_CSC	FWD (Import)	REV (Export)
	0 MW	0 MW
Impacts Total Transfer Capability	330 MW	330 MW
TTC with All Lines In Service	330 MW	330 MW

MARCY__FRASANNX_345_UCC2-41

Mon 04/29/2024 to Fri 05/24/2024 UPDATED by NYPA 02/13/2024 10:53
0700 Continuous 1730
Work scheduled by: NYPA
ARR: 19

CENTRAL EAST - VC	FWD (Import)	REV (Export)
	3225 MW	
Impacts Total Transfer Capability	500 MW	
TTC with All Lines In Service	3725 MW	

PANNELL_-CLAY___345_2

Mon 04/29/2024 to Fri 05/03/2024
0700 Continuous 1530
Work scheduled by: NYPA

WEST CENTRAL	FWD (Import)	REV (Export)
	1300 MW	
Impacts Total Transfer Capability	950 MW	
TTC with All Lines In Service	2250 MW	

SCH-NE-NYISO_LIMIT_800

Mon 04/29/2024 to Mon 04/29/2024
0700 Continuous 2259
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	1000 MW	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 9, 2024 to Wednesday, October 8, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NE-NYISO_LIMIT_600

Mon 04/29/2024 to Tue 04/30/2024
2300 Continuous 0659
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - NE - NY	800 MW	
Impacts Total Transfer Capability	600 MW	
TTC with All Lines In Service	1400 MW	

LADENTWN-BUCHAN_S_345_Y88

Tue 04/30/2024 to Sun 05/19/2024
0201 Continuous 2359
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
UPNY CONED	7695 MW	
Impacts Total Transfer Capability	355 MW	
TTC with All Lines In Service	8050 MW	

SCH-NE-NYISO_LIMIT_800

Tue 04/30/2024 to Tue 04/30/2024
0700 Continuous 2259
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - NE - NY	1000 MW	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

SCH-NE-NYISO_LIMIT_600

Tue 04/30/2024 to Wed 05/01/2024
2300 Continuous 0659
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - NE - NY	800 MW	
Impacts Total Transfer Capability	600 MW	
TTC with All Lines In Service	1400 MW	

W49TH_ST_345KV_5

Wed 05/01/2024 to Fri 05/03/2024
0001 Continuous 0200
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - PJM_HTP	300 MW	
Impacts Total Transfer Capability	360 MW	
TTC with All Lines In Service	660 MW	

W49TH_ST_345KV_7

Wed 05/01/2024 to Fri 05/03/2024
0001 Continuous 0200
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - PJM_HTP	300 MW	
Impacts Total Transfer Capability	360 MW	
TTC with All Lines In Service	660 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 9, 2024 to Wednesday, October 8, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NE-NYISO_LIMIT_800					FWD (Import)	REV (Export)
Wed 05/01/2024	to	Wed 05/01/2024		SCH - NE - NY	1000 MW	
0700	Continuous	2259		Impacts Total Transfer Capability	400 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	1400 MW	
SCH-NE-NYISO_LIMIT_600					FWD (Import)	REV (Export)
Wed 05/01/2024	to	Thu 05/02/2024		SCH - NE - NY	800 MW	
2300	Continuous	0659		Impacts Total Transfer Capability	600 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	1400 MW	
SCH-NE-NYISO_LIMIT_800					FWD (Import)	REV (Export)
Thu 05/02/2024	to	Thu 05/02/2024		SCH - NE - NY	1000 MW	
0700	Continuous	2259		Impacts Total Transfer Capability	400 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	1400 MW	
SCH-NE-NYISO_LIMIT_600					FWD (Import)	REV (Export)
Thu 05/02/2024	to	Fri 05/03/2024		SCH - NE - NY	800 MW	
2300	Continuous	0659		Impacts Total Transfer Capability	600 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	1400 MW	
SCH-NE-NYISO_LIMIT_800					FWD (Import)	REV (Export)
Fri 05/03/2024	to	Fri 05/03/2024		SCH - NE - NY	1000 MW	
0700	Continuous	2259		Impacts Total Transfer Capability	400 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	1400 MW	
SCH-NE-NYISO_LIMIT_600					FWD (Import)	REV (Export)
Fri 05/03/2024	to	Sat 05/04/2024		SCH - NE - NY	800 MW	
2300	Continuous	0659		Impacts Total Transfer Capability	600 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	1400 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 9, 2024 to Wednesday, October 8, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NE-NYISO_LIMIT_800

Sat 05/04/2024 to Sat 05/04/2024

0700 Continuous 2259

Work scheduled by: ConEd

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

1000 MW

400 MW

1400 MW

SCH-NE-NYISO_LIMIT_600

Sat 05/04/2024 to Sun 05/05/2024

2300 Continuous 0659

Work scheduled by: ConEd

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

800 MW

600 MW

1400 MW

SPRNBK_345KV_RNS4

Sun 05/05/2024 to Sun 05/05/2024

0001 Continuous 1930

Work scheduled by: ConEd

UPDATED by ConEd 02/07/2024 10:31

SPR/DUN-SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

3200 MW

1400 MW

4600 MW

SPRNBK-W49TH_ST_345_M52

Sun 05/05/2024 to Sun 05/05/2024

0001 Continuous 1930

Work scheduled by: ConEd

UPDATED by ConEd 02/07/2024 10:31

SPR/DUN-SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

3200 MW

1400 MW

4600 MW

W49TH_ST_345KV_5

Sun 05/05/2024 to Sun 05/05/2024

0001 Continuous 1730

Work scheduled by: ConEd

UPDATED by ConEd 02/07/2024 10:31

SCH - PJM_HTP

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

300 MW

360 MW

660 MW

SCH-NE-NYISO_LIMIT_800

Sun 05/05/2024 to Sun 05/05/2024

0700 Continuous 2259

Work scheduled by: ConEd

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

1000 MW

400 MW

1400 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 9, 2024 to Wednesday, October 8, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_5						FWD (Import)	REV (Export)
Sun 05/05/2024	to	Sun 05/05/2024		SCH - PJM_HTP		300 MW	
1900	Continuous	1930	<u>UPDATED by ConEd 02/07/2024 10:31</u>	Impacts Total Transfer Capability		360 MW	
Work scheduled by: ConEd				TTC with All Lines In Service		660 MW	
SCH-NE-NYISO_LIMIT_600						FWD (Import)	REV (Export)
Sun 05/05/2024	to	Mon 05/06/2024		SCH - NE - NY		800 MW	
2300	Continuous	0659		Impacts Total Transfer Capability		600 MW	
Work scheduled by: ConEd				TTC with All Lines In Service		1400 MW	
EGRDNCTY_345_138_AT1						FWD (Import)	REV (Export)
Mon 05/06/2024	to	Mon 05/06/2024		CONED - LIPA		1250 MW	
0001	Continuous	0030		Impacts Total Transfer Capability		250 MW	
Work scheduled by: ConEd				TTC with All Lines In Service		1500 MW	
EGRDNCTY_345_138_AT2						FWD (Import)	REV (Export)
Mon 05/06/2024	to	Mon 05/06/2024		CONED - LIPA		1250 MW	
0001	Continuous	0030		Impacts Total Transfer Capability		250 MW	
Work scheduled by: ConEd				TTC with All Lines In Service		1500 MW	
SPRNBK_-EGRDNCTR_345_Y49						FWD (Import)	REV (Export)
Mon 05/06/2024	to	Wed 05/08/2024		CONED - LIPA		775 MW	
0001	Continuous	2200		Impacts Total Transfer Capability		725 MW	
Work scheduled by: ConEd				TTC with All Lines In Service		1500 MW	
SCH-NE-NYISO_LIMIT_800						FWD (Import)	REV (Export)
Mon 05/06/2024	to	Mon 05/06/2024		SCH - NE - NY		1000 MW	
0700	Continuous	2259		Impacts Total Transfer Capability		400 MW	
Work scheduled by: ConEd				TTC with All Lines In Service		1400 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 9, 2024 to Wednesday, October 8, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NE-NYISO_LIMIT_600					FWD (Import)	REV (Export)
Mon 05/06/2024	to	Tue 05/07/2024		SCH - NE - NY	800 MW	
2300	Continuous	0659		Impacts Total Transfer Capability	600 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	1400 MW	
SCH-NE-NYISO_LIMIT_800					FWD (Import)	REV (Export)
Tue 05/07/2024	to	Tue 05/07/2024		SCH - NE - NY	1000 MW	
0700	Continuous	2259		Impacts Total Transfer Capability	400 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	1400 MW	
PANNELL_CLAY___345_2					FWD (Import)	REV (Export)
Tue 05/07/2024	to	Tue 05/07/2024		WEST CENTRAL	1300 MW	
0730	Continuous	1430		Impacts Total Transfer Capability	950 MW	
Work scheduled by: NGrid				TTC with All Lines In Service	2250 MW	
EGRDNCTY_345_138_AT1					FWD (Import)	REV (Export)
Tue 05/07/2024	to	Tue 05/07/2024		CONED - LIPA	1250 MW	
2130	Continuous	2200		Impacts Total Transfer Capability	250 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	1500 MW	
EGRDNCTY_345_138_AT2					FWD (Import)	REV (Export)
Tue 05/07/2024	to	Tue 05/07/2024		CONED - LIPA	1250 MW	
2130	Continuous	2200		Impacts Total Transfer Capability	250 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	1500 MW	
SCH-NE-NYISO_LIMIT_600					FWD (Import)	REV (Export)
Tue 05/07/2024	to	Wed 05/08/2024		SCH - NE - NY	800 MW	
2300	Continuous	0659		Impacts Total Transfer Capability	600 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	1400 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 9, 2024 to Wednesday, October 8, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NE-NYISO_LIMIT_800

Wed 05/08/2024 to Wed 05/08/2024
0700 Continuous 2259
Work scheduled by: ConEd

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) 1000 MW
REV (Export) 400 MW
1400 MW

CLAY__-INDPDNCE_345_26

Wed 05/08/2024 to Wed 05/08/2024
0730 Continuous 1430
Work scheduled by: NGrid

OSWEGO EXPORT
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) 5000 MW
REV (Export) 250 MW
5250 MW

SCH-NE-NYISO_LIMIT_600

Wed 05/08/2024 to Thu 05/09/2024
2300 Continuous 0659
Work scheduled by: ConEd

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) 800 MW
REV (Export) 600 MW
1400 MW

SCH-NE-NYISO_LIMIT_800

Thu 05/09/2024 to Thu 05/09/2024
0700 Continuous 2259
Work scheduled by: ConEd

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) 1000 MW
REV (Export) 400 MW
1400 MW

PANNELL_-CLAY__345_1

Thu 05/09/2024 to Thu 05/09/2024
0730 Continuous 1430
Work scheduled by: NGrid

WEST CENTRAL
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) 1300 MW
REV (Export) 950 MW
2250 MW

SCH-NE-NYISO_LIMIT_600

Thu 05/09/2024 to Fri 05/10/2024
2300 Continuous 0659
Work scheduled by: ConEd

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) 800 MW
REV (Export) 600 MW
1400 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 9, 2024 to Wednesday, October 8, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NE-NYISO_LIMIT_800					FWD (Import)	REV (Export)
Fri 05/10/2024	to	Fri 05/10/2024		SCH - NE - NY	1000 MW	
0700	Continuous	2259		Impacts Total Transfer Capability	400 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	1400 MW	
BERKSHIR-ALPS___345_393					FWD (Import)	REV (Export)
Fri 05/10/2024	to	Fri 05/10/2024	<u>UPDATED by ISONE 04/02/2024 13:47</u>	SCH - NPX_1385	100 MW	100 MW
1430	Continuous	1500	ARR: 78	Impacts Total Transfer Capability	100 MW	100 MW
Work scheduled by: NGrid				TTC with All Lines In Service	200 MW	200 MW
BERKSHIR-ALPS___345_393					FWD (Import)	REV (Export)
Fri 05/10/2024	to	Fri 05/10/2024	<u>UPDATED by ISONE 04/02/2024 13:47</u>	SCH - NE - NY	900 MW	
1430	Continuous	1500	ARR: 78	Impacts Total Transfer Capability	500 MW	
Work scheduled by: NGrid				TTC with All Lines In Service	1400 MW	
BERKSHIR-ALPS___345_393 , BERKSHIR-NORTHFLD_345_312					FWD (Import)	REV (Export)
Fri 05/10/2024	to	Fri 05/10/2024		SCH - NE - NY	900 MW	
1430		1500	ARR: 78	Impacts Total Transfer Capability	500 MW	
Work scheduled by:				TTC with All Lines In Service	1400 MW	
SCH-NE-NYISO_LIMIT_600					FWD (Import)	REV (Export)
Fri 05/10/2024	to	Sat 05/11/2024		SCH - NE - NY	800 MW	
2300	Continuous	0659		Impacts Total Transfer Capability	600 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	1400 MW	
SCH-NE-NYISO_LIMIT_800					FWD (Import)	REV (Export)
Sat 05/11/2024	to	Sat 05/11/2024		SCH - NE - NY	1000 MW	
0700	Continuous	2259		Impacts Total Transfer Capability	400 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	1400 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 9, 2024 to Wednesday, October 8, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NE-NYISO_LIMIT_600

Sat 05/11/2024 to Sun 05/12/2024
2300 Continuous 0659
Work scheduled by: ConEd

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) 800 MW
REV (Export) 600 MW
1400 MW

SPRNBK-TREMONT_345_X28

Sun 05/12/2024 to Sun 05/12/2024
0001 Continuous 0500
Work scheduled by: ConEd

SPR/DUN-SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) 4200 MW
REV (Export) 400 MW
4600 MW

SCH-NE-NYISO_LIMIT_800

Sun 05/12/2024 to Sun 05/12/2024
0700 Continuous 2259
Work scheduled by: ConEd

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) 1000 MW
REV (Export) 400 MW
1400 MW

SCH-NE-NYISO_LIMIT_600

Sun 05/12/2024 to Mon 05/13/2024
2300 Continuous 0659
Work scheduled by: ConEd

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) 800 MW
REV (Export) 600 MW
1400 MW

GOETHALS_345KV_5

Mon 05/13/2024 to Mon 05/13/2024
0001 Continuous 0030
Work scheduled by: ConEd

STATEN ISLAND
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import)
REV (Export)

HUDSONP_-FARRAGUT_345_B3402 , LINDEN_- GOETHALS_230_A2253

Mon 05/13/2024 to Tue 05/14/2024
0001 1000
Work scheduled by:

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) 2200 MW
REV (Export) 50 MW
2250 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 9, 2024 to Wednesday, October 8, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LINDEN_-GOETHALS_230_A2253

Mon 05/13/2024 to Tue 05/14/2024

0001 Continuous 1000

Work scheduled by: ConEd

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

MARION_-FARRAGUT_345_C3403 , HUDSONP_- FARRAGUT_345_B3402 , LINDEN_-GOETHALS_230_A2253

Mon 05/13/2024 to Tue 05/14/2024

0001 1000

Work scheduled by:

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

2200 MW

50 MW

2250 MW

MARION_-FARRAGUT_345_C3403 , LINDEN_-GOETHALS_230_A2253

Mon 05/13/2024 to Tue 05/14/2024

0001 1000

Work scheduled by:

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

2200 MW

50 MW

2250 MW

NIAGARA_-ROBNSNRD_230_64

Mon 05/13/2024 to Fri 05/17/2024

0500 Continuous 1900

Work scheduled by: NYPA

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

1500 MW

150 MW

1650 MW

NEPTUNE_-DUFFYAVE_345_NEPTUNE

Mon 05/13/2024 to Fri 05/17/2024

0600 Continuous 1600

Work scheduled by: LI

SCH - PJM_NEPTUNE

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

0 MW

660 MW

660 MW

NEWBRDGE_345_138_BK_1

Mon 05/13/2024 to Fri 05/17/2024

0600 Continuous 1600

Work scheduled by: LI

SCH - PJM_NEPTUNE

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

375 MW

285 MW

660 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 9, 2024 to Wednesday, October 8, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEWBRDGE_345_138_BK_2

Mon 05/13/2024 to Fri 05/17/2024
0600 Continuous 1600
Work scheduled by: LI

	FWD (Import)	REV (Export)
SCH - PJM_NEPTUNE	375 MW	
Impacts Total Transfer Capability	285 MW	
TTC with All Lines In Service	660 MW	

NEWBRDGE-DUFFYAVE_345_501

Mon 05/13/2024 to Fri 05/17/2024
0600 Continuous 1600
Work scheduled by: LI

	FWD (Import)	REV (Export)
SCH - PJM_NEPTUNE	0 MW	
Impacts Total Transfer Capability	660 MW	
TTC with All Lines In Service	660 MW	

SCH-NE-NYISO_LIMIT_800

Mon 05/13/2024 to Mon 05/13/2024
0700 Continuous 2259
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - NE - NY	1000 MW	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

SCH-NE-NYISO_LIMIT_600

Mon 05/13/2024 to Tue 05/14/2024
2300 Continuous 0659
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - NE - NY	800 MW	
Impacts Total Transfer Capability	600 MW	
TTC with All Lines In Service	1400 MW	

SCH-NE-NYISO_LIMIT_800

Tue 05/14/2024 to Tue 05/14/2024
0700 Continuous 2259
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - NE - NY	1000 MW	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

VOLNEY_-CLAY_345_6

Tue 05/14/2024 to Tue 05/14/2024
0730 Continuous 1430
Work scheduled by: NGrid

	FWD (Import)	REV (Export)
OSWEGO EXPORT	5250 MW	
Impacts Total Transfer Capability	0 MW	
TTC with All Lines In Service	5250 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 9, 2024 to Wednesday, October 8, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

GOETHALS_345KV_5

Tue 05/14/2024 to Tue 05/14/2024
0930 Continuous 1000
Work scheduled by: ConEd

STATEN ISLAND
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

SCH-NE-NYISO_LIMIT_600

Tue 05/14/2024 to Wed 05/15/2024
2300 Continuous 0659
Work scheduled by: ConEd

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

800 MW
600 MW
1400 MW

SCH-NE-NYISO_LIMIT_800

Wed 05/15/2024 to Wed 05/15/2024
0700 Continuous 2259
Work scheduled by: ConEd

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

1000 MW
400 MW
1400 MW

CLAY__-EDIC__345_2-15

Wed 05/15/2024 to Wed 05/15/2024
0730 Continuous 1430
Work scheduled by: NGrid

OSWEGO EXPORT
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

4850 MW
400 MW
5250 MW

SCH-NE-NYISO_LIMIT_600

Wed 05/15/2024 to Thu 05/16/2024
2300 Continuous 0659
Work scheduled by: ConEd

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

800 MW
600 MW
1400 MW

GOETHALS_345KV_5

Thu 05/16/2024 to Thu 05/16/2024
0001 Continuous 0030
Work scheduled by: ConEd

STATEN ISLAND
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 9, 2024 to Wednesday, October 8, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONP_-FARRAGUT_345_B3402 , LINDEN_-GOETHALS_230_A2253

Thu 05/16/2024 to Thu 05/16/2024
0001 0300

Work scheduled by:

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

2200 MW

50 MW

2250 MW

LINDEN_-GOETHALS_230_A2253

Thu 05/16/2024 to Thu 05/16/2024
0001 Continuous 0300

Work scheduled by: ConEd

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

2200 MW

50 MW

2250 MW

MARION_-FARRAGUT_345_C3403 , HUDSONP_-FARRAGUT_345_B3402 , LINDEN_-GOETHALS_230_A2253

Thu 05/16/2024 to Thu 05/16/2024
0001 0300

Work scheduled by:

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

2200 MW

50 MW

2250 MW

MARION_-FARRAGUT_345_C3403 , LINDEN_-GOETHALS_230_A2253

Thu 05/16/2024 to Thu 05/16/2024
0001 0300

Work scheduled by:

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

2200 MW

50 MW

2250 MW

GOETHALS_345KV_5

Thu 05/16/2024 to Thu 05/16/2024
0230 Continuous 0300

Work scheduled by: ConEd

STATEN ISLAND

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 9, 2024 to Wednesday, October 8, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NE-NYISO_LIMIT_800

Thu 05/16/2024 to Thu 05/16/2024
0700 Continuous 2259
Work scheduled by: ConEd

SCH - NE - NY FWD (Import) REV (Export)
1000 MW
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 1400 MW

NINEMILE-CLAY___345_8

Thu 05/16/2024 to Thu 05/16/2024
0730 Continuous 1430
Work scheduled by: NGrid

OSWEGO EXPORT FWD (Import) REV (Export)
5150 MW
Impacts Total Transfer Capability 100 MW
TTC with All Lines In Service 5250 MW

SCH-NE-NYISO_LIMIT_600

Thu 05/16/2024 to Fri 05/17/2024
2300 Continuous 0659
Work scheduled by: ConEd

SCH - NE - NY FWD (Import) REV (Export)
800 MW
Impacts Total Transfer Capability 600 MW
TTC with All Lines In Service 1400 MW

BUCHAN_S-MILLWOOD_345_W97

Fri 05/17/2024 to Sat 05/18/2024
0001 Continuous 0200
Work scheduled by: ConEd

UPNY CONED FWD (Import) REV (Export)
8015 MW
Impacts Total Transfer Capability 35 MW
TTC with All Lines In Service 8050 MW

SCH-NE-NYISO_LIMIT_800

Fri 05/17/2024 to Fri 05/17/2024
0700 Continuous 2200
Work scheduled by: ConEd

SCH - NE - NY FWD (Import) REV (Export)
1000 MW
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 1400 MW

KNICRBKR-PLSNTVLY_345_Y57

Sat 05/18/2024 to Sun 05/26/2024
2300 Continuous 0100
Work scheduled by: NGrid

ARR: 78

UPNY CONED FWD (Import) REV (Export)
7885 MW
Impacts Total Transfer Capability 165 MW
TTC with All Lines In Service 8050 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 9, 2024 to Wednesday, October 8, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FITZPTRK-EDIC___345_FE-1

Mon 05/20/2024 to Thu 05/23/2024
0700 Continuous 1730

Work scheduled by: NYPA

OSWEGO EXPORT	FWD (Import)	REV (Export)
	4800 MW	
Impacts Total Transfer Capability	450 MW	
TTC with All Lines In Service	5250 MW	

FITZPTRK-EDIC___345_FE-1

Mon 05/20/2024 to Thu 05/23/2024
0700 Continuous 1730

Work scheduled by: NYPA

CENTRAL EAST - VC	FWD (Import)	REV (Export)
	3520 MW	
Impacts Total Transfer Capability	205 MW	
TTC with All Lines In Service	3725 MW	

FITZPTRK-EDIC___345_FE-1

Tue 05/28/2024 to Fri 05/31/2024
0700 Continuous 1530

Work scheduled by: NYPA

OSWEGO EXPORT	FWD (Import)	REV (Export)
	4800 MW	
Impacts Total Transfer Capability	450 MW	
TTC with All Lines In Service	5250 MW	

FITZPTRK-EDIC___345_FE-1

Tue 05/28/2024 to Fri 05/31/2024
0700 Continuous 1530

Work scheduled by: NYPA

CENTRAL EAST - VC	FWD (Import)	REV (Export)
	3520 MW	
Impacts Total Transfer Capability	205 MW	
TTC with All Lines In Service	3725 MW	

CHATGUAY-MASSENA_765_7040

Wed 05/29/2024 to Sat 06/01/2024
1800 Continuous 0500

Work scheduled by: NYPA

UPDATED by NYPA 02/02/2024 10:05

SCH - HQ - NY	FWD (Import)	REV (Export)
	0 MW	0 MW
Impacts Total Transfer Capability	1500 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

CHATGUAY-MASSENA_765_7040

Wed 05/29/2024 to Sat 06/01/2024
1800 Continuous 0500

Work scheduled by: NYPA

UPDATED by NYPA 02/02/2024 10:05

MOSES SOUTH	FWD (Import)	REV (Export)
	1550 MW	
Impacts Total Transfer Capability	1600 MW	
TTC with All Lines In Service	3150 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 9, 2024 to Wednesday, October 8, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___765_345_AT1

Wed 05/29/2024 to Sat 06/01/2024
1800 Continuous 0500
Work scheduled by: NYPA

UPDATED by NYPA 02/02/2024 10:05

ARR: 19

MOSES SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
1750 MW
1400 MW
3150 MW

MARCY___765_345_AT2

Wed 05/29/2024 to Sat 06/01/2024
1800 Continuous 0500
Work scheduled by: NYPA

UPDATED by NYPA 02/02/2024 10:05

ARR: 19

MOSES SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
1700 MW
1450 MW
3150 MW

MASSENA_-MARCY___765_MSU1

Wed 05/29/2024 to Sat 06/01/2024
1800 Continuous 0500
Work scheduled by: NYPA

UPDATED by NYPA 02/02/2024 10:05

SCH - HQ_CEDARS
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
90 MW
180 MW
270 MW

MASSENA_-MARCY___765_MSU1

Wed 05/29/2024 to Sat 06/01/2024
1800 Continuous 0500
Work scheduled by: NYPA

UPDATED by NYPA 02/02/2024 10:05

SCH - HQ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
475 MW **1000 MW**
1025 MW 0 MW
1500 MW 1000 MW

MASSENA_-MARCY___765_MSU1

Wed 05/29/2024 to Sat 06/01/2024
1800 Continuous 0500
Work scheduled by: NYPA

UPDATED by NYPA 02/02/2024 10:05

MOSES SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
500 MW
2650 MW
3150 MW

MASSENA_-MARCY___765_MSU1

Wed 05/29/2024 to Sat 06/01/2024
1800 Continuous 0500
Work scheduled by: NYPA

UPDATED by NYPA 02/02/2024 10:05

CENTRAL EAST - VC
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
2595 MW
1130 MW
3725 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 9, 2024 to Wednesday, October 8, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA__MARCY__765_MSU1 , CHATGUAY-MASSENA_765_7040

Wed 05/29/2024 to Sat 06/01/2024
1800 0500

Work scheduled by:

MOSES SOUTH **500 MW**
Impacts Total Transfer Capability 2650 MW
TTC with All Lines In Service 3150 MW

MOSES__-MASSENA_230_MMS2 , MOSES__-MASSENA_230_MMS1

Wed 05/29/2024 to Sat 06/01/2024
1800 0500

Work scheduled by:

SCH - HQ_CEDARS **90 MW**
Impacts Total Transfer Capability 180 MW
TTC with All Lines In Service 270 MW

MOSES__-MASSENA_230_MMS2 , MOSES__-MASSENA_230_MMS1

Wed 05/29/2024 to Sat 06/01/2024
1800 0500

Work scheduled by:

SCH - HQ - NY **850 MW** **0 MW**
Impacts Total Transfer Capability 650 MW 1000 MW
TTC with All Lines In Service 1500 MW 1000 MW

BECK__-PACKARD_230_BP76

Fri 05/31/2024 to Fri 05/31/2024
0730 Continuous 1630

Work scheduled by: NGrid

SCH - OH - NY **1600 MW** **1050 MW**
Impacts Total Transfer Capability 450 MW 600 MW
TTC with All Lines In Service 2050 MW 1650 MW

CHASLAKE-PORTER__230_11

Sat 06/01/2024 to Wed 07/03/2024
0530 Continuous 1600

Work scheduled by: NGrid

MOSES SOUTH **2100 MW**
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

CRICKVLY-PLSNTVLY_345_F84

Mon 06/03/2024 to Tue 06/04/2024
0001 Continuous 2200

Work scheduled by: ConEd

SCH - NE - NY **600 MW**
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 1400 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 9, 2024 to Wednesday, October 8, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CRICKVLY-PLSNTVLY_345_F84					FWD (Import)	REV (Export)
Mon 06/03/2024	to	Tue 06/04/2024		SCH - NPX_1385	100 MW	100 MW
0001	Continuous	2200		Impacts Total Transfer Capability	100 MW	100 MW
Work scheduled by: ConEd				TTC with All Lines In Service	200 MW	200 MW
WATRCURE-OAKDALE_345_31					FWD (Import)	REV (Export)
Mon 06/03/2024	to	Fri 06/07/2024		SCH - PJ - NY	2050 MW	
0700	Continuous	1430		Impacts Total Transfer Capability	200 MW	
Work scheduled by: NYSEG				TTC with All Lines In Service	2250 MW	
DUNWODIE_345KV_3					FWD (Import)	REV (Export)
Sat 06/08/2024	to	Mon 06/10/2024		SPR/DUN-SOUTH	3800 MW	
0001	Continuous	0200		Impacts Total Transfer Capability	800 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	4600 MW	
DUNWODIE_345KV_4					FWD (Import)	REV (Export)
Sat 06/08/2024	to	Mon 06/10/2024		SPR/DUN-SOUTH	3800 MW	
0001	Continuous	0200		Impacts Total Transfer Capability	800 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	4600 MW	
NIAGARA_345_230_AT4					FWD (Import)	REV (Export)
Tue 06/11/2024	to	Wed 06/12/2024		SCH - OH - NY		1200 MW
0500	Continuous	1900		Impacts Total Transfer Capability		450 MW
Work scheduled by: NYPA				TTC with All Lines In Service		1650 MW
CHASLAKE-PORTER_230_11					FWD (Import)	REV (Export)
Mon 07/08/2024	to	Fri 08/30/2024		MOSES SOUTH	2100 MW	
0700	Continuous	1900		Impacts Total Transfer Capability	1050 MW	
Work scheduled by: NGrid				TTC with All Lines In Service	3150 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 9, 2024 to Wednesday, October 8, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ROSETON_EFISHKIL_345_RFK305

Sat 07/20/2024 to Sun 07/21/2024

0700 Continuous 1600

Work scheduled by: CHGE

UPNY CONED

FWD (Import)

REV (Export)

7215 MW

Impacts Total Transfer Capability

835 MW

TTC with All Lines In Service

8050 MW

LEEDS_345_LEEDS SVC

Mon 07/22/2024 to Thu 07/25/2024

0730 Continuous 1600

Work scheduled by: NGrid

CENTRAL EAST - VC

FWD (Import)

REV (Export)

3675 MW

Impacts Total Transfer Capability

50 MW

TTC with All Lines In Service

3725 MW

FRASER_345_FRASER SVC

Mon 07/29/2024 to Fri 08/02/2024

0800 Continuous 1400

Work scheduled by: NYSEG

CENTRAL EAST - VC

FWD (Import)

REV (Export)

3655 MW

Impacts Total Transfer Capability

70 MW

TTC with All Lines In Service

3725 MW

EDIC_GORDONRD_345_14

Mon 08/19/2024 to Fri 08/30/2024

0630 Continuous 1800

Work scheduled by: NGrid

CENTRAL EAST - VC

FWD (Import)

REV (Export)

2770 MW

Impacts Total Transfer Capability

955 MW

TTC with All Lines In Service

3725 MW

EDIC_PRINCTWN_345_351

Mon 08/19/2024 to Sat 08/24/2024

0700 Continuous 1700

Work scheduled by: NGrid

UPDATED by NGrid 02/02/2024 14:41

CENTRAL EAST - VC

FWD (Import)

REV (Export)

3335 MW

Impacts Total Transfer Capability

390 MW

TTC with All Lines In Service

3725 MW

MARCY_EDIC_345_UE1-7

Sun 08/25/2024 to Fri 08/30/2024

0800 Continuous 1600

Work scheduled by: NGrid

ARR: 16 & 19

OSWEGO EXPORT

FWD (Import)

REV (Export)

5250 MW

Impacts Total Transfer Capability

0 MW

TTC with All Lines In Service

5250 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 9, 2024 to Wednesday, October 8, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHASLAKE-PORTER__230_11

Tue 09/03/2024 to Fri 11/15/2024
0530 Continuous 2000
Work scheduled by: NGrid

	FWD (Import)	REV (Export)
MOSES SOUTH	2100 MW	
Impacts Total Transfer Capability	1050 MW	
TTC with All Lines In Service	3150 MW	

EDIC__GORDONRD_345_14

Tue 09/03/2024 to Mon 10/14/2024
0600 Continuous 1800
Work scheduled by: NGrid

	FWD (Import)	REV (Export)
CENTRAL EAST - VC	2770 MW	
Impacts Total Transfer Capability	955 MW	
TTC with All Lines In Service	3725 MW	

FITZPTRK-EDIC__345_FE-1

Mon 09/09/2024 to Mon 09/09/2024
0001 Continuous 0100
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
OSWEGO EXPORT	4800 MW	
Impacts Total Transfer Capability	450 MW	
TTC with All Lines In Service	5250 MW	

FITZPTRK-EDIC__345_FE-1

Mon 09/09/2024 to Mon 09/09/2024
0001 Continuous 0100
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
CENTRAL EAST - VC	3520 MW	
Impacts Total Transfer Capability	205 MW	
TTC with All Lines In Service	3725 MW	

EDIC__PRINCTWN_345_351

Mon 09/09/2024 to Wed 09/11/2024
0700 Continuous 1700
Work scheduled by: NGrid

	FWD (Import)	REV (Export)
CENTRAL EAST - VC	3335 MW	
Impacts Total Transfer Capability	390 MW	
TTC with All Lines In Service	3725 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 9, 2024 to Wednesday, October 8, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ROCHESTR-PANNELL__345_RP1					FWD (Import)	REV (Export)
Mon 09/09/2024	to	Fri 09/13/2024		DYSINGER EAST	2300 MW	
0700	Continuous	1530		Impacts Total Transfer Capability	900 MW	
Work scheduled by: NYPA				TTC with All Lines In Service	3200 MW	
MARCY__-EDIC__345_UE1-7					FWD (Import)	REV (Export)
Thu 09/12/2024	to	Sat 09/14/2024		OSWEGO EXPORT	5250 MW	
0700	Continuous	1700	ARR: 16 & 19	Impacts Total Transfer Capability	0 MW	
Work scheduled by: NGrid				TTC with All Lines In Service	5250 MW	
MOTTHAVN-RAINEY__345_Q11					FWD (Import)	REV (Export)
Sun 09/15/2024	to	Sat 10/26/2024		SPR/DUN-SOUTH	3800 MW	
0001	Continuous	0300		Impacts Total Transfer Capability	800 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	4600 MW	
W49TH_ST_345KV_6					FWD (Import)	REV (Export)
Sun 09/15/2024	to	Fri 09/27/2024		SCH - PJM_HTP	300 MW	
0001	Continuous	0100		Impacts Total Transfer Capability	360 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	660 MW	
W49TH_ST_345KV_8					FWD (Import)	REV (Export)
Sun 09/15/2024	to	Fri 09/27/2024		SCH - PJM_HTP	450 MW	
0001	Continuous	0100		Impacts Total Transfer Capability	210 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	660 MW	
DYSINGER-STA_255_345_DH2					FWD (Import)	REV (Export)
Mon 09/16/2024	to	Mon 10/28/2024		DYSINGER EAST	2850 MW	
0500	Continuous	1900		Impacts Total Transfer Capability	350 MW	
Work scheduled by: NYPA				TTC with All Lines In Service	3200 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 9, 2024 to Wednesday, October 8, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ROCHESTR-PANNELL__345_RP2

Mon 09/16/2024 to Fri 09/20/2024
0700 Continuous 1530
Work scheduled by: NYPA

DYSINGER EAST
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) 2300 MW
REV (Export) 900 MW
3200 MW

STLAWRNC-MOSES__230_L34P

Mon 09/16/2024 to Fri 09/20/2024
0700 Continuous 1530
Work scheduled by: NYPA

SCH - OH - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

PANNELL_-CLAY__345_1

Mon 09/23/2024 to Fri 09/27/2024
0700 Continuous 1530
Work scheduled by: NYPA

WEST CENTRAL
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) 1300 MW
REV (Export) 950 MW
2250 MW

STLAWRNC-MOSES__230_L34P

Mon 09/23/2024 to Fri 09/27/2024
0700 Continuous 1530
Work scheduled by: NYPA

SCH - OH - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

FITZPTRK-EDIC__345_FE-1

Thu 09/26/2024 to Thu 09/26/2024
0900 Continuous 1000
Work scheduled by: NYPA

OSWEGO EXPORT
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) 4800 MW
REV (Export) 450 MW
5250 MW

FITZPTRK-EDIC__345_FE-1

Thu 09/26/2024 to Thu 09/26/2024
0900 Continuous 1000
Work scheduled by: NYPA

CENTRAL EAST - VC
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) 3520 MW
REV (Export) 205 MW
3725 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 9, 2024 to Wednesday, October 8, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST-E13THSTA_345_M55

Fri 09/27/2024 to Tue 11/19/2024
0001 Continuous 0200
Work scheduled by: ConEd

SPR/DUN-SOUTH FWD (Import) REV (Export)
3800 MW
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

W49TH_ST_345KV_6

Fri 09/27/2024 to Tue 11/19/2024
0101 Continuous 0200
Work scheduled by: ConEd

SCH - PJM_HTP FWD (Import) REV (Export)
300 MW
Impacts Total Transfer Capability 360 MW
TTC with All Lines In Service 660 MW

STLAWRNC-MOSES__230_L34P

Mon 09/30/2024 to Fri 10/04/2024
0700 Continuous 1530
Work scheduled by: NYPA

SCH - OH - NY FWD (Import) REV (Export)
Impacts Total Transfer Capability
TTC with All Lines In Service

FITZPTRK-EDIC__345_FE-1

Mon 09/30/2024 to Fri 10/04/2024
1700 Continuous 1530
Work scheduled by: NYPA

OSWEGO EXPORT FWD (Import) REV (Export)
4800 MW
Impacts Total Transfer Capability 450 MW
TTC with All Lines In Service 5250 MW

FITZPTRK-EDIC__345_FE-1

Mon 09/30/2024 to Fri 10/04/2024
1700 Continuous 1530
Work scheduled by: NYPA

CENTRAL EAST - VC FWD (Import) REV (Export)
3520 MW
Impacts Total Transfer Capability 205 MW
TTC with All Lines In Service 3725 MW

BECK__-NIAGARA_345_PA302

Mon 10/07/2024 to Fri 10/11/2024
0500 Continuous 1900
Work scheduled by: NYPA

SCH - OH - NY FWD (Import) REV (Export)
1000 MW 850 MW
Impacts Total Transfer Capability 1050 MW 800 MW
TTC with All Lines In Service 2050 MW 1650 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 9, 2024 to Wednesday, October 8, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEPTUNE_DUFFYAVE_345_NEPTUNE

Mon 10/07/2024 to Fri 10/11/2024
0600 Continuous 1600
Work scheduled by: LI

SCH - PJM_NEPTUNE **0 MW**
Impacts Total Transfer Capability 660 MW
TTC with All Lines In Service 660 MW

NEWBRDGE_345_138_BK_1

Mon 10/07/2024 to Fri 10/11/2024
0600 Continuous 1600
Work scheduled by: LI

SCH - PJM_NEPTUNE **375 MW**
Impacts Total Transfer Capability 285 MW
TTC with All Lines In Service 660 MW

NEWBRDGE_345_138_BK_2

Mon 10/07/2024 to Fri 10/11/2024
0600 Continuous 1600
Work scheduled by: LI

SCH - PJM_NEPTUNE **375 MW**
Impacts Total Transfer Capability 285 MW
TTC with All Lines In Service 660 MW

NEWBRDGE-DUFFYAVE_345_501

Mon 10/07/2024 to Fri 10/11/2024
0600 Continuous 1600
Work scheduled by: LI

SCH - PJM_NEPTUNE **0 MW**
Impacts Total Transfer Capability 660 MW
TTC with All Lines In Service 660 MW

SHOR_NPX-SHOREHAM_138_CSC

Mon 10/07/2024 to Fri 10/11/2024
0600 Continuous 1800
Work scheduled by: LI

SCH - NPX_CSC **0 MW** **0 MW**
Impacts Total Transfer Capability 330 MW 330 MW
TTC with All Lines In Service 330 MW 330 MW

MARCY__FRASANNX_345_UCC2-41

Wed 10/09/2024 to Thu 10/10/2024
0700 Continuous 1530
Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC **3225 MW**
Impacts Total Transfer Capability 500 MW
TTC with All Lines In Service 3725 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 9, 2024 to Wednesday, October 8, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY__N.SCTLND_345_18					FWD (Import)	REV (Export)
Tue 10/15/2024	to	Thu 10/17/2024		CENTRAL EAST - VC	2665 MW	
0700	Continuous	1530	ARR: 19	Impacts Total Transfer Capability	1060 MW	
Work scheduled by: NYPA				TTC with All Lines In Service	3725 MW	
MARCY__N.SCTLND_345_18					FWD (Import)	REV (Export)
Mon 10/21/2024	to	Fri 10/25/2024		CENTRAL EAST - VC	2665 MW	
0700	Continuous	1530	ARR: 19	Impacts Total Transfer Capability	1060 MW	
Work scheduled by: NYPA				TTC with All Lines In Service	3725 MW	
MARCY__345KV_CSC					FWD (Import)	REV (Export)
Mon 10/28/2024	to	Sun 11/10/2024		CENTRAL EAST - VC	3650 MW	
0700	Continuous	1530		Impacts Total Transfer Capability	75 MW	
Work scheduled by: NYPA				TTC with All Lines In Service	3725 MW	
DYSINGER-STA_255_345_DH2					FWD (Import)	REV (Export)
Tue 10/29/2024	to	Thu 10/31/2024		DYSINGER EAST	2850 MW	
0500	Continuous	2100		Impacts Total Transfer Capability	350 MW	
Work scheduled by: NYPA				TTC with All Lines In Service	3200 MW	
DYSINGER-STA_255_345_DH1					FWD (Import)	REV (Export)
Mon 11/04/2024	to	Sat 11/16/2024		DYSINGER EAST	2850 MW	
0500	Continuous	1900		Impacts Total Transfer Capability	350 MW	
Work scheduled by: NYPA				TTC with All Lines In Service	3200 MW	
LINDN_CG-LNDVFT__345_V-3022					FWD (Import)	REV (Export)
Tue 11/12/2024	to	Tue 11/12/2024		SCH - PJM_VFT	0 MW	0 MW
0800	Continuous	2359		Impacts Total Transfer Capability	315 MW	315 MW
Work scheduled by: PJM				TTC with All Lines In Service	315 MW	315 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 9, 2024 to Wednesday, October 8, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BECK__-NIAGARA_230_PA27

Fri 11/15/2024 to Fri 11/15/2024
0500 Continuous 1900
Work scheduled by: NYPA

SCH - OH - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) 2100 MW
350 MW
2450 MW

OSWEGO_-VOLNEY_345_12

Fri 11/15/2024 to Fri 12/13/2024
0730 Continuous 1600
Work scheduled by: NGrid

OSWEGO EXPORT
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) 5250 MW
0 MW
5250 MW

CHATGUAY-MASSENA_765_7040

Sat 11/16/2024 to Fri 11/29/2024
0001 Continuous 2359
Work scheduled by: NYPA

SCH - HQ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) 0 MW
1500 MW
1500 MW

REV (Export) 0 MW
1000 MW
1000 MW

CHATGUAY-MASSENA_765_7040

Sat 11/16/2024 to Fri 11/29/2024
0001 Continuous 2359
Work scheduled by: NYPA

MOSES SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) 1550 MW
1600 MW
3150 MW

MARCY__765_345_AT1

Sat 11/16/2024 to Fri 11/29/2024
0001 Continuous 2359
Work scheduled by: NYPA

ARR: 19

MOSES SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) 1750 MW
1400 MW
3150 MW

MARCY__765_345_AT2

Sat 11/16/2024 to Fri 11/29/2024
0001 Continuous 2359
Work scheduled by: NYPA

ARR: 19

MOSES SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) 1700 MW
1450 MW
3150 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 9, 2024 to Wednesday, October 8, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA_-MARCY___765_MSU1

Sat 11/16/2024 to Fri 11/29/2024
0001 Continuous 2359
Work scheduled by: NYPA

SCH - HQ_CEDARS
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
90 MW	
189 MW	
279 MW	

MASSENA_-MARCY___765_MSU1

Sat 11/16/2024 to Fri 11/29/2024
0001 Continuous 2359
Work scheduled by: NYPA

SCH - HQ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
475 MW	1000 MW
1025 MW	0 MW
1500 MW	1000 MW

MASSENA_-MARCY___765_MSU1

Sat 11/16/2024 to Fri 11/29/2024
0001 Continuous 2359
Work scheduled by: NYPA

MOSES SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
500 MW	
2650 MW	
3150 MW	

MASSENA_-MARCY___765_MSU1

Sat 11/16/2024 to Fri 11/29/2024
0001 Continuous 2359
Work scheduled by: NYPA

CENTRAL EAST - VC
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
2595 MW	
1130 MW	
3725 MW	

MASSENA_-MARCY___765_MSU1 , CHATGUAY-MASSENA_765_7040

Sat 11/16/2024 to Fri 11/29/2024
0001 2359
Work scheduled by:

MOSES SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
500 MW	
2650 MW	
3150 MW	

MOSES__-MASSENA_230_MMS2 , MOSES__-MASSENA_230_MMS1

Sat 11/16/2024 to Fri 11/29/2024
0001 2359
Work scheduled by:

SCH - HQ_CEDARS
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
90 MW	
189 MW	
279 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 9, 2024 to Wednesday, October 8, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES__-MASSENA_230_MMS2 , MOSES__-MASSENA_230_MMS1

Sat 11/16/2024 to Fri 11/29/2024
0001 2359

Work scheduled by:

SCH - HQ - NY

FWD (Import)

REV (Export)

850 MW

0 MW

Impacts Total Transfer Capability

650 MW

1000 MW

TTC with All Lines In Service

1500 MW

1000 MW

LINDN_CG-LNDVFT__345_V-3022

Fri 11/22/2024 to Fri 11/22/2024
1500 Continuous 1800

Work scheduled by: PJM

SCH - PJM_VFT

FWD (Import)

REV (Export)

0 MW

0 MW

Impacts Total Transfer Capability

315 MW

315 MW

TTC with All Lines In Service

315 MW

315 MW

ADIRNDCK-PORTER__230_12

Sun 12/01/2024 to Tue 12/24/2024
0530 Continuous 1700

Work scheduled by: NGrid

MOSES SOUTH

FWD (Import)

REV (Export)

2300 MW

Impacts Total Transfer Capability

850 MW

TTC with All Lines In Service

3150 MW

E13THSTA-FARRAGUT_345_46

Wed 12/18/2024 to Fri 12/20/2024
0201 Continuous 0300

Work scheduled by: ConEd

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

3800 MW

Impacts Total Transfer Capability

800 MW

TTC with All Lines In Service

4600 MW

ADIRNDCK-PORTER__230_12

Thu 01/02/2025 to Sat 05/31/2025
0530 Continuous 1700

Work scheduled by: NGrid

MOSES SOUTH

FWD (Import)

REV (Export)

2300 MW

Impacts Total Transfer Capability

850 MW

TTC with All Lines In Service

3150 MW

OSWEGO_-VOLNEY__345_11

Mon 01/06/2025 to Fri 01/24/2025
0700 Continuous 1700

Work scheduled by: NGrid

OSWEGO EXPORT

FWD (Import)

REV (Export)

5250 MW

Impacts Total Transfer Capability

0 MW

TTC with All Lines In Service

5250 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 9, 2024 to Wednesday, October 8, 2025

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

E13THSTA-FARRAGUT_345_46

Fri 01/10/2025 to Wed 01/15/2025

0001 Continuous 0300

Work scheduled by: ConEd

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

3800 MW

Impacts Total Transfer Capability

800 MW

TTC with All Lines In Service

4600 MW

OSWEGO_-ELBRIDGE_345_17

Mon 01/27/2025 to Fri 02/14/2025

0630 Continuous 1730

Work scheduled by: NGrid

ARR: 75

OSWEGO EXPORT

FWD (Import)

REV (Export)

5250 MW

Impacts Total Transfer Capability

0 MW

TTC with All Lines In Service

5250 MW

ELBRIDGE-LAFAYTTE_345_17-LE

Wed 02/12/2025 to Fri 02/14/2025

0700 Continuous 1730

Work scheduled by: NGrid

ARR: 75

OSWEGO EXPORT

FWD (Import)

REV (Export)

5250 MW

Impacts Total Transfer Capability

0 MW

TTC with All Lines In Service

5250 MW

GOETHALS_345KV_5

Mon 09/08/2025 to Mon 09/08/2025

0301 Continuous 0330

Work scheduled by: ConEd

STATEN ISLAND

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

TTC with All Lines In Service

GOETHALS_345KV_5

Tue 09/09/2025 to Tue 09/09/2025

2330 Continuous 2359

Work scheduled by: ConEd

STATEN ISLAND

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

TTC with All Lines In Service

GOETHALS_345KV_5

Mon 09/15/2025 to Mon 09/15/2025

0230 Continuous 0300

Work scheduled by: ConEd

STATEN ISLAND

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

TTC with All Lines In Service

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, April 9, 2024 to Wednesday, October 8, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

GOETHALS_345KV_5

Mon 09/15/2025 to Mon 09/15/2025
0301 Continuous 0330
Work scheduled by: ConEd

STATEN ISLAND
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

ADIRNDCK-PORTER__230_12

Mon 09/15/2025 to Sun 10/12/2025
0600 Continuous 1700
Work scheduled by: NGrid

MOSES SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
2100 MW
1050 MW
3150 MW

GOETHALS_345KV_5

Tue 09/16/2025 to Tue 09/16/2025
2330 Continuous 2359
Work scheduled by: ConEd

STATEN ISLAND
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

GOETHALS_345KV_5

Fri 09/26/2025 to Fri 09/26/2025
0230 Continuous 0300
Work scheduled by: ConEd

STATEN ISLAND
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

BECK__-NIAGARA_230_PA27

Mon 09/29/2025 to Wed 11/26/2025
0500 Continuous 1900
Work scheduled by: NYPA

SCH - OH - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
1900 MW **1650 MW**
150 MW 0 MW
2050 MW 1650 MW