

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, April 11, 2024 to Friday, October 10, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### HUDSONP\_-FARRAGUT\_345\_B3402

FWD (Import) REV (Export)

Mon 01/15/2018 to Tue 12/31/2024

0001 Continuous 2359

Work scheduled by: ConEd

EXT FORCED by ConEd 03/11/2024 11:26

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

### MARION\_-FARRAGUT\_345\_C3403

FWD (Import) REV (Export)

Mon 01/15/2018 to Tue 12/31/2024

0001 Continuous 2359

Work scheduled by: ConEd

EXT FORCED by ConEd 03/11/2024 11:26

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

### MARION\_-FARRAGUT\_345\_C3403 , HUDSONP\_-FARRAGUT\_345\_B3402

FWD (Import) REV (Export)

Mon 01/15/2018 to Tue 12/31/2024

0001 2359

Work scheduled by:

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

**2400 MW** **2400 MW**

150 MW 250 MW

2550 MW 2650 MW

### SCH-IMO-NYISO\_LIMIT\_1900

FWD (Import) REV (Export)

Wed 11/01/2023 to Tue 04/30/2024

0001 Continuous 2359

Work scheduled by: IESO

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

**2200 MW**

250 MW

2450 MW

### ADIRNDCK-PORTER\_\_230\_12

FWD (Import) REV (Export)

Tue 01/02/2024 to Wed 05/29/2024

0630 Continuous 1730

Work scheduled by: NGrid

UPDATED by NGrid 07/11/2023 11:44

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

**2300 MW**

850 MW

3150 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, April 11, 2024 to Friday, October 10, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-IMO-NYISO\_LIMIT\_1750

Tue 01/02/2024 to Wed 05/29/2024  
0630 Continuous 1730  
Work scheduled by: NGrid

UPDATED by NGrid 07/11/2023 11:44

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**2050 MW**

400 MW

2450 MW

### SPRNBK\_-W49TH\_ST\_345\_M51

Tue 01/30/2024 to Thu 04/25/2024  
0202 Continuous 2359  
Work scheduled by: ConEd

EXT FORCED by ConEd 04/08/2024 15:10

SPR/DUN-SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**3200 MW**

1400 MW

4600 MW

### SHORE\_RD\_345\_138\_BK 1

Mon 02/12/2024 to Fri 05/03/2024  
0001 Continuous 2359  
Work scheduled by: LI

UPDATED by LI 02/07/2024 12:08

CONED - LIPA

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**1350 MW**

150 MW

1500 MW

### BECK\_-PACKARD\_230\_BP76

Mon 03/04/2024 to Fri 05/24/2024  
0500 Continuous 1600  
Work scheduled by: NGrid

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**1800 MW**

650 MW

2450 MW

**1350 MW**

550 MW

1900 MW

### SCH-IMO-NYISO\_LIMIT\_1300

Mon 03/04/2024 to Mon 05/20/2024  
0500 Continuous 0800  
Work scheduled by: NGrid

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**1600 MW**

850 MW

2450 MW

### SCH-HQ\_CEDARS-NYISO\_LIMIT\_240

Mon 03/11/2024 to Thu 04/25/2024  
0800 Continuous 1500  
Work scheduled by: HQ

EXTENDED by HQ 04/11/2024 16:37

SCH - HQ\_CEDARS

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**240 MW**

39 MW

279 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, April 11, 2024 to Friday, October 10, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NYISO-HQ\_CEDARS\_LIMIT\_0

Mon 03/11/2024 to Thu 04/25/2024  
0800 Continuous 1500

EXTENDED by HQ 04/11/2024 16:37

SCH - HQ\_CEDARS

FWD (Import)

REV (Export)

**0 MW**

Impacts Total Transfer Capability

100 MW

TTC with All Lines In Service

100 MW

### CLAY\_\_-EDIC\_\_345\_1-16

Mon 03/18/2024 to Fri 04/19/2024  
0700 Continuous 0900

UPDATED by NGrid 04/03/2024 09:02

OSWEGO EXPORT

FWD (Import)

REV (Export)

**4850 MW**

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

5250 MW

### RAMAPO\_\_BUCHAN\_N\_345\_Y94

Tue 04/02/2024 to Tue 04/30/2024  
0201 Continuous 0200

UPNY CONED

FWD (Import)

REV (Export)

**7755 MW**

Impacts Total Transfer Capability

295 MW

TTC with All Lines In Service

8050 MW

### MOTHAVN-RAINEY\_\_345\_Q12

Thu 04/04/2024 to Thu 04/25/2024  
0001 Continuous 0200

EXTENDED by ConEd 04/03/2024 10:26

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

**3800 MW**

Impacts Total Transfer Capability

800 MW

TTC with All Lines In Service

4600 MW

### FRASER\_\_345\_FRASER SVC

Sat 04/06/2024 to Fri 04/19/2024  
1758 Continuous 1600

EXT FORCED by NYSEG 04/11/2024 14:44

CENTRAL EAST - VC

FWD (Import)

REV (Export)

**3655 MW**

Impacts Total Transfer Capability

70 MW

TTC with All Lines In Service

3725 MW

### LINDN\_CG-LNDVFT\_\_345\_V-3022

Mon 04/08/2024 to Sat 04/13/2024  
0800 Continuous 1500

UPDATED by PJM 03/13/2024 15:45

SCH - PJM\_VFT

FWD (Import)

REV (Export)

**0 MW**

**0 MW**

Impacts Total Transfer Capability

315 MW

315 MW

TTC with All Lines In Service

315 MW

315 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, April 11, 2024 to Friday, October 10, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### BERKSHIR-NORTHFLD\_345\_312

Tue 04/09/2024 to Fri 05/10/2024  
0600 Continuous 1500  
Work scheduled by: NGrid

UPDATED by ISONE 04/02/2024 13:47

SCH - NPX\_1385

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

**100 MW**

100 MW

200 MW

REV (Export)

**100 MW**

100 MW

200 MW

### BERKSHIR-NORTHFLD\_345\_312

Tue 04/09/2024 to Fri 05/10/2024  
0600 Continuous 1500  
Work scheduled by: NGrid

UPDATED by ISONE 04/02/2024 13:47

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

**1300 MW**

100 MW

1400 MW

REV (Export)

### SCH-NE-NYISO\_LIMIT\_700

Tue 04/09/2024 to Fri 05/10/2024  
0600 Continuous 1500  
Work scheduled by: NGrid

UPDATED by ISONE 04/02/2024 13:47

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

**900 MW**

500 MW

1400 MW

REV (Export)

### SCH-NYISO-NE\_LIMIT\_900

Tue 04/09/2024 to Fri 05/10/2024  
0600 Continuous 2359  
Work scheduled by: NGrid

UPDATED by ISONE 04/02/2024 13:47

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

**1100 MW**

700 MW

1800 MW

REV (Export)

### SCH-NE-NYISO\_LIMIT\_600

Wed 04/10/2024 to Thu 04/11/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

**800 MW**

600 MW

1400 MW

REV (Export)

### NIAGARA\_PACKARD\_230\_62

Thu 04/11/2024 to Thu 04/11/2024  
0700 Continuous 1630  
Work scheduled by: NGrid

CANCELLED by TO 04/11/2024 13:17

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

**1750 MW**

700 MW

2450 MW

REV (Export)

**1850 MW**

50 MW

1900 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, April 11, 2024 to Friday, October 10, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_800

Thu 04/11/2024 to Thu 04/11/2024  
0700 Continuous 2259  
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>1000 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

### SCH-IMO-NYISO\_LIMIT\_1000

Thu 04/11/2024 to Thu 04/11/2024  
0730 Continuous 1700  
Work scheduled by: IESO

SCH - OH - NY	FWD (Import)	REV (Export)
	<b>1300 MW</b>	
Impacts Total Transfer Capability	1150 MW	
TTC with All Lines In Service	2450 MW	

### SCH-NYISO-IMO\_LIMIT\_700

Thu 04/11/2024 to Thu 04/11/2024  
0730 Continuous 1700  
Work scheduled by: IESO

SCH - OH - NY	FWD (Import)	REV (Export)
		<b>1000 MW</b>
Impacts Total Transfer Capability		900 MW
TTC with All Lines In Service		1900 MW

### SCH-NE-NYISO\_LIMIT\_600

Thu 04/11/2024 to Fri 04/12/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>800 MW</b>	
Impacts Total Transfer Capability	600 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NE-NYISO\_LIMIT\_800

Fri 04/12/2024 to Fri 04/12/2024  
0700 Continuous 2259  
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>1000 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NE-NYISO\_LIMIT\_600

Fri 04/12/2024 to Sat 04/13/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>800 MW</b>	
Impacts Total Transfer Capability	600 MW	
TTC with All Lines In Service	1400 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, April 11, 2024 to Friday, October 10, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_800

Sat 04/13/2024 to Sat 04/13/2024  
0700 Continuous 2259  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - NE - NY	<b>1000 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

### CHAT\_DC\_GC1

Sat 04/13/2024 to Sat 04/13/2024  
2100 Continuous 2300  
Work scheduled by: HQ

	FWD (Import)	REV (Export)
MOSES SOUTH	<b>2850 MW</b>	
Impacts Total Transfer Capability	300 MW	
TTC with All Lines In Service	3150 MW	

### CHAT\_DC\_GC1

Sat 04/13/2024 to Sat 04/13/2024  
2100 Continuous 2300  
Work scheduled by: HQ

	FWD (Import)	REV (Export)
SCH - HQ - NY		<b>500 MW</b>
Impacts Total Transfer Capability		500 MW
TTC with All Lines In Service		1000 MW

### CHAT\_DC\_GC1 , CHAT\_DC\_GC2

Sat 04/13/2024 to Sat 04/13/2024  
2100 2300  
Work scheduled by:

	FWD (Import)	REV (Export)
MOSES SOUTH	<b>2550 MW</b>	
Impacts Total Transfer Capability	600 MW	
TTC with All Lines In Service	3150 MW	

### CHAT\_DC\_GC1 , CHAT\_DC\_GC2

Sat 04/13/2024 to Sat 04/13/2024  
2100 2300  
Work scheduled by:

	FWD (Import)	REV (Export)
SCH - HQ - NY	<b>1370 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	130 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

### CHAT\_DC\_GC2

Sat 04/13/2024 to Sat 04/13/2024  
2100 Continuous 2300  
Work scheduled by: HQ

	FWD (Import)	REV (Export)
MOSES SOUTH	<b>2850 MW</b>	
Impacts Total Transfer Capability	300 MW	
TTC with All Lines In Service	3150 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, April 11, 2024 to Friday, October 10, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### CHAT\_DC\_GC2

Sat 04/13/2024 to Sat 04/13/2024  
2100 Continuous 2300  
Work scheduled by: HQ

SCH - HQ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) REV (Export)  
**500 MW**  
500 MW  
1000 MW

### SCH-HQ-NYISO\_LIMIT\_1150

Sat 04/13/2024 to Sat 04/13/2024  
2100 Continuous 2300  
Work scheduled by: HQ

SCH - HQ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) REV (Export)  
**1150 MW**  
350 MW  
1500 MW

### SCH-NE-NYISO\_LIMIT\_600

Sat 04/13/2024 to Sun 04/14/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) REV (Export)  
**800 MW**  
600 MW  
1400 MW

### SCH-NE-NYISO\_LIMIT\_800

Sun 04/14/2024 to Sun 04/14/2024  
0700 Continuous 2259  
Work scheduled by: ConEd

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) REV (Export)  
**1000 MW**  
400 MW  
1400 MW

### SCH-NE-NYISO\_LIMIT\_600

Sun 04/14/2024 to Mon 04/15/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) REV (Export)  
**800 MW**  
600 MW  
1400 MW

### SCH-NPX\_1385-NYISO\_LIMIT\_100

Mon 04/15/2024 to Fri 04/26/2024  
0600 Continuous 2200  
Work scheduled by: ISONE

UPDATED by ISONE 04/09/2024 13:34

SCH - NPX\_1385  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) REV (Export)  
**100 MW**  
100 MW  
200 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, April 11, 2024 to Friday, October 10, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_800

Mon 04/15/2024 to Mon 04/15/2024  
0700 Continuous 2259  
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>1000 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

### NIAGARA\_PACKARD\_230\_62

Mon 04/15/2024 to Mon 04/15/2024  
0800 Continuous 1600  
Work scheduled by: NGrid

SCH - OH - NY	FWD (Import)	REV (Export)
	<b>1750 MW</b>	<b>1850 MW</b>
Impacts Total Transfer Capability	700 MW	50 MW
TTC with All Lines In Service	2450 MW	1900 MW

### SCH-NE-NYISO\_LIMIT\_600

Mon 04/15/2024 to Tue 04/16/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>800 MW</b>	
Impacts Total Transfer Capability	600 MW	
TTC with All Lines In Service	1400 MW	

### ELBRIDGE-LAFAYTTE\_345\_17-LE

Tue 04/16/2024 to Fri 05/03/2024  
0700 Continuous 1630  
Work scheduled by: NGrid

UPDATED by NGrid 04/11/2024 14:02  
ARR: 75

OSWEGO EXPORT	FWD (Import)	REV (Export)
	<b>5250 MW</b>	
Impacts Total Transfer Capability	0 MW	
TTC with All Lines In Service	5250 MW	

### OSWEGO\_ELBRIDGE\_345\_17

Tue 04/16/2024 to Tue 04/16/2024  
0700 Continuous 0900  
Work scheduled by: NGrid

UPDATED by NGrid 04/11/2024 14:02  
ARR: 75

OSWEGO EXPORT	FWD (Import)	REV (Export)
	<b>5250 MW</b>	
Impacts Total Transfer Capability	0 MW	
TTC with All Lines In Service	5250 MW	

### SCH-NE-NYISO\_LIMIT\_800

Tue 04/16/2024 to Tue 04/16/2024  
0700 Continuous 2259  
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>1000 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, April 11, 2024 to Friday, October 10, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_600

Tue 04/16/2024 to Wed 04/17/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>800 MW</b>	
Impacts Total Transfer Capability	600 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NE-NYISO\_LIMIT\_800

Wed 04/17/2024 to Wed 04/17/2024  
0700 Continuous 2259  
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>1000 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NE-NYISO\_LIMIT\_600

Wed 04/17/2024 to Thu 04/18/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>800 MW</b>	
Impacts Total Transfer Capability	600 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NE-NYISO\_LIMIT\_800

Thu 04/18/2024 to Thu 04/18/2024  
0700 Continuous 2259  
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>1000 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

### LINDN\_CG-LNDVFT\_\_345\_V-3022

Thu 04/18/2024 to Thu 04/18/2024  
1500 Continuous 2200  
Work scheduled by: PJM

UPDATED by PJM 03/13/2024 15:45

SCH - PJM_VFT	FWD (Import)	REV (Export)
	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	315 MW	315 MW
TTC with All Lines In Service	315 MW	315 MW

### SCH-NE-NYISO\_LIMIT\_600

Thu 04/18/2024 to Fri 04/19/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>800 MW</b>	
Impacts Total Transfer Capability	600 MW	
TTC with All Lines In Service	1400 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, April 11, 2024 to Friday, October 10, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_800

Fri 04/19/2024 to Fri 04/19/2024  
0700 Continuous 2259  
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>1000 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NE-NYISO\_LIMIT\_600

Fri 04/19/2024 to Sat 04/20/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>800 MW</b>	
Impacts Total Transfer Capability	600 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NE-NYISO\_LIMIT\_800

Sat 04/20/2024 to Sat 04/20/2024  
0700 Continuous 2259  
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>1000 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NE-NYISO\_LIMIT\_600

Sat 04/20/2024 to Sun 04/21/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>800 MW</b>	
Impacts Total Transfer Capability	600 MW	
TTC with All Lines In Service	1400 MW	

### SPRNBK\_345KV\_RS4 , SPRNBK\_345KV\_RS3

Sun 04/21/2024 to Sun 04/21/2024  
0001 0030  
Work scheduled by:

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

### SCH-NE-NYISO\_LIMIT\_800

Sun 04/21/2024 to Sun 04/21/2024  
0700 Continuous 2259  
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>1000 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, April 11, 2024 to Friday, October 10, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_600

Sun 04/21/2024 to Mon 04/22/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>800 MW</b>	
Impacts Total Transfer Capability	600 MW	
TTC with All Lines In Service	1400 MW	

### HUDSONTP-W49TH\_ST\_345\_Y56

Mon 04/22/2024 to Fri 04/26/2024  
0600 Continuous 1600  
Work scheduled by: ConEd

SCH - PJM_HTP	FWD (Import)	REV (Export)
	<b>0 MW</b>	
Impacts Total Transfer Capability	660 MW	
TTC with All Lines In Service	660 MW	

### W49TH\_ST\_345KV\_7

Mon 04/22/2024 to Mon 04/22/2024  
0600 Continuous 0630  
Work scheduled by: ConEd

SCH - PJM_HTP	FWD (Import)	REV (Export)
	<b>300 MW</b>	
Impacts Total Transfer Capability	360 MW	
TTC with All Lines In Service	660 MW	

### W49TH\_ST\_345KV\_8

Mon 04/22/2024 to Mon 04/22/2024  
0600 Continuous 0630  
Work scheduled by: ConEd

SCH - PJM_HTP	FWD (Import)	REV (Export)
	<b>310 MW</b>	
Impacts Total Transfer Capability	350 MW	
TTC with All Lines In Service	660 MW	

### PANNELL-CLAY\_345\_1

Mon 04/22/2024 to Fri 04/26/2024  
0700 Continuous 1530  
Work scheduled by: NYPA

WEST CENTRAL	FWD (Import)	REV (Export)
	<b>1300 MW</b>	
Impacts Total Transfer Capability	950 MW	
TTC with All Lines In Service	2250 MW	

### SCH-NE-NYISO\_LIMIT\_800

Mon 04/22/2024 to Mon 04/22/2024  
0700 Continuous 2259  
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>1000 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, April 11, 2024 to Friday, October 10, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_600

Mon 04/22/2024 to Tue 04/23/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>800 MW</b>	
Impacts Total Transfer Capability	600 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NE-NYISO\_LIMIT\_800

Tue 04/23/2024 to Tue 04/23/2024  
0700 Continuous 2259  
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>1000 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

### OSWEGO\_-ELBRIDGE\_345\_17

Tue 04/23/2024 to Sat 04/27/2024  
0730 Continuous 1630  
Work scheduled by: NGrid

ARR: 75

OSWEGO EXPORT	FWD (Import)	REV (Export)
	<b>5250 MW</b>	
Impacts Total Transfer Capability	0 MW	
TTC with All Lines In Service	5250 MW	

### SCH-NE-NYISO\_LIMIT\_600

Tue 04/23/2024 to Wed 04/24/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>800 MW</b>	
Impacts Total Transfer Capability	600 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NE-NYISO\_LIMIT\_800

Wed 04/24/2024 to Wed 04/24/2024  
0700 Continuous 2259  
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>1000 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

### SPRNBK\_345KV\_RS4 , SPRNBK\_345KV\_RS3

Wed 04/24/2024 to Wed 04/24/2024  
2130 2200  
Work scheduled by:

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, April 11, 2024 to Friday, October 10, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SCH-NE-NYISO_LIMIT_600</b>					FWD (Import)	REV (Export)
Wed 04/24/2024	to	Thu 04/25/2024		SCH - NE - NY	<b>800 MW</b>	
2300	Continuous	0659		Impacts Total Transfer Capability	600 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	1400 MW	
<b>SCH-NE-NYISO_LIMIT_800</b>					FWD (Import)	REV (Export)
Thu 04/25/2024	to	Thu 04/25/2024		SCH - NE - NY	<b>1000 MW</b>	
0700	Continuous	2259		Impacts Total Transfer Capability	400 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	1400 MW	
<b>SCH-NE-NYISO_LIMIT_600</b>					FWD (Import)	REV (Export)
Thu 04/25/2024	to	Fri 04/26/2024		SCH - NE - NY	<b>800 MW</b>	
2300	Continuous	0659		Impacts Total Transfer Capability	600 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	1400 MW	
<b>SPRNBK_345KV_RNS5</b>					FWD (Import)	REV (Export)
Thu 04/25/2024	to	Thu 04/25/2024	<u>EXT FORCED by ConEd 04/08/2024 15:10</u>	SPR/DUN-SOUTH	<b>3200 MW</b>	
2330	Continuous	2359		Impacts Total Transfer Capability	1400 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	4600 MW	
<b>SCH-NE-NYISO_LIMIT_800</b>					FWD (Import)	REV (Export)
Fri 04/26/2024	to	Fri 04/26/2024		SCH - NE - NY	<b>1000 MW</b>	
0700	Continuous	2259		Impacts Total Transfer Capability	400 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	1400 MW	
<b>W49TH_ST_345KV_7</b>					FWD (Import)	REV (Export)
Fri 04/26/2024	to	Fri 04/26/2024		SCH - PJM_HTP	<b>300 MW</b>	
1530	Continuous	1600		Impacts Total Transfer Capability	360 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	660 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, April 11, 2024 to Friday, October 10, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### W49TH\_ST\_345KV\_8

Fri 04/26/2024 to Fri 04/26/2024  
1530 Continuous 1600  
Work scheduled by: ConEd

SCH - PJM_HTP	FWD (Import)	REV (Export)
	<b>310 MW</b>	
Impacts Total Transfer Capability	350 MW	
TTC with All Lines In Service	660 MW	

### SCH-NE-NYISO\_LIMIT\_600

Fri 04/26/2024 to Sat 04/27/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>800 MW</b>	
Impacts Total Transfer Capability	600 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NE-NYISO\_LIMIT\_800

Sat 04/27/2024 to Sat 04/27/2024  
0700 Continuous 2259  
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>1000 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NE-NYISO\_LIMIT\_600

Sat 04/27/2024 to Sun 04/28/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>800 MW</b>	
Impacts Total Transfer Capability	600 MW	
TTC with All Lines In Service	1400 MW	

### CHAT\_DC\_GC2

Sun 04/28/2024 to Fri 05/17/2024  
0600 Continuous 2000  
Work scheduled by: HQ

MOSES SOUTH	FWD (Import)	REV (Export)
	<b>2850 MW</b>	
Impacts Total Transfer Capability	300 MW	
TTC with All Lines In Service	3150 MW	

### CHAT\_DC\_GC2

Sun 04/28/2024 to Fri 05/17/2024  
0600 Continuous 2000  
Work scheduled by: HQ

SCH - HQ - NY	FWD (Import)	REV (Export)
	<b>500 MW</b>	
Impacts Total Transfer Capability	500 MW	
TTC with All Lines In Service	1000 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, April 11, 2024 to Friday, October 10, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-HQ-NYISO\_LIMIT\_1400

Sun 04/28/2024 to Fri 05/17/2024  
0600 Continuous 2000

Work scheduled by: HQ

SCH - HQ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**1400 MW**

100 MW

1500 MW

### SCH-NE-NYISO\_LIMIT\_800

Sun 04/28/2024 to Sun 04/28/2024  
0700 Continuous 2259

Work scheduled by: ConEd

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**1000 MW**

400 MW

1400 MW

### SCH-NE-NYISO\_LIMIT\_600

Sun 04/28/2024 to Mon 04/29/2024  
2300 Continuous 0659

Work scheduled by: ConEd

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**800 MW**

600 MW

1400 MW

### SHOR\_NPX-SHOREHAM\_138\_CSC

Mon 04/29/2024 to Sat 05/04/2024  
0600 Continuous 1800

Work scheduled by: LI

SCH - NPX\_CSC

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**0 MW**

330 MW

330 MW

**0 MW**

330 MW

330 MW

### MARCY\_-FRASANNX\_345\_UCC2-41

Mon 04/29/2024 to Fri 05/24/2024  
0700 Continuous 1730

Work scheduled by: NYPA

UPDATED by NYPA 02/13/2024 10:53

ARR: 19

CENTRAL EAST - VC

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**3225 MW**

500 MW

3725 MW

### PANNELL\_-CLAY\_345\_2

Mon 04/29/2024 to Fri 05/03/2024  
0700 Continuous 1530

Work scheduled by: NYPA

WEST CENTRAL

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**1300 MW**

950 MW

2250 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, April 11, 2024 to Friday, October 10, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_800

Mon 04/29/2024 to Mon 04/29/2024  
0700 Continuous 2259  
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>1000 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NE-NYISO\_LIMIT\_600

Mon 04/29/2024 to Tue 04/30/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>800 MW</b>	
Impacts Total Transfer Capability	600 MW	
TTC with All Lines In Service	1400 MW	

### LADENTWN-BUCHAN\_S\_345\_Y88

Tue 04/30/2024 to Sun 05/19/2024  
0201 Continuous 2359  
Work scheduled by: ConEd

UPNY CONED	FWD (Import)	REV (Export)
	<b>7695 MW</b>	
Impacts Total Transfer Capability	355 MW	
TTC with All Lines In Service	8050 MW	

### SCH-NE-NYISO\_LIMIT\_800

Tue 04/30/2024 to Tue 04/30/2024  
0700 Continuous 2259  
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>1000 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NE-NYISO\_LIMIT\_600

Tue 04/30/2024 to Wed 05/01/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>800 MW</b>	
Impacts Total Transfer Capability	600 MW	
TTC with All Lines In Service	1400 MW	

### W49TH\_ST\_345KV\_5

Wed 05/01/2024 to Fri 05/03/2024  
0001 Continuous 0200  
Work scheduled by: ConEd

SCH - PJM_HTP	FWD (Import)	REV (Export)
	<b>300 MW</b>	
Impacts Total Transfer Capability	360 MW	
TTC with All Lines In Service	660 MW	



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, April 11, 2024 to Friday, October 10, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### W49TH\_ST\_345KV\_7

Wed 05/01/2024 to Fri 05/03/2024  
0001 Continuous 0200  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - PJM_HTP	<b>300 MW</b>	
Impacts Total Transfer Capability	360 MW	
TTC with All Lines In Service	660 MW	

### MOSES\_\_-ADIRNDCK\_230\_MA1

Wed 05/01/2024 to Mon 05/06/2024  
0600 Continuous 0700  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
MOSES SOUTH	<b>2100 MW</b>	
Impacts Total Transfer Capability	1050 MW	
TTC with All Lines In Service	3150 MW	

### SCH-NE-NYISO\_LIMIT\_800

Wed 05/01/2024 to Wed 05/01/2024  
0700 Continuous 2259  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - NE - NY	<b>1000 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NE-NYISO\_LIMIT\_600

Wed 05/01/2024 to Thu 05/02/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - NE - NY	<b>800 MW</b>	
Impacts Total Transfer Capability	600 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NE-NYISO\_LIMIT\_800

Thu 05/02/2024 to Thu 05/02/2024  
0700 Continuous 2259  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - NE - NY	<b>1000 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NE-NYISO\_LIMIT\_600

Thu 05/02/2024 to Fri 05/03/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - NE - NY	<b>800 MW</b>	
Impacts Total Transfer Capability	600 MW	
TTC with All Lines In Service	1400 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, April 11, 2024 to Friday, October 10, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_800

Fri 05/03/2024 to Fri 05/03/2024  
0700 Continuous 2259  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - NE - NY	<b>1000 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

### OSWEGO\_-ELBRIDGE\_345\_17

Fri 05/03/2024 to Fri 05/03/2024 UPDATED by NGrid 04/11/2024 14:02  
1430 Continuous 1630  
Work scheduled by: NGrid ARR: 75

	FWD (Import)	REV (Export)
OSWEGO EXPORT	<b>5250 MW</b>	
Impacts Total Transfer Capability	0 MW	
TTC with All Lines In Service	5250 MW	

### SCH-NE-NYISO\_LIMIT\_600

Fri 05/03/2024 to Sat 05/04/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - NE - NY	<b>800 MW</b>	
Impacts Total Transfer Capability	600 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NE-NYISO\_LIMIT\_800

Sat 05/04/2024 to Sat 05/04/2024  
0700 Continuous 2259  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - NE - NY	<b>1000 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NE-NYISO\_LIMIT\_600

Sat 05/04/2024 to Sun 05/05/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - NE - NY	<b>800 MW</b>	
Impacts Total Transfer Capability	600 MW	
TTC with All Lines In Service	1400 MW	

### SPRNBK\_345KV\_RNS4

Sun 05/05/2024 to Sun 05/05/2024 UPDATED by ConEd 02/07/2024 10:31  
0001 Continuous 1930  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	<b>3200 MW</b>	
Impacts Total Transfer Capability	1400 MW	
TTC with All Lines In Service	4600 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, April 11, 2024 to Friday, October 10, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SPRNBK\_W49TH\_ST\_345\_M52

Sun 05/05/2024 to Sun 05/05/2024  
0001 Continuous 1930

UPDATED by ConEd 02/07/2024 10:31

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

**3200 MW**

Impacts Total Transfer Capability

1400 MW

TTC with All Lines In Service

4600 MW

Work scheduled by: ConEd

### W49TH\_ST\_345KV\_5

Sun 05/05/2024 to Sun 05/05/2024  
0001 Continuous 1730

UPDATED by ConEd 02/07/2024 10:31

SCH - PJM\_HTP

FWD (Import)

REV (Export)

**300 MW**

Impacts Total Transfer Capability

360 MW

TTC with All Lines In Service

660 MW

Work scheduled by: ConEd

### SCH-NE-NYISO\_LIMIT\_800

Sun 05/05/2024 to Sun 05/05/2024  
0700 Continuous 2259

SCH - NE - NY

FWD (Import)

REV (Export)

**1000 MW**

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

1400 MW

Work scheduled by: ConEd

### W49TH\_ST\_345KV\_5

Sun 05/05/2024 to Sun 05/05/2024  
1900 Continuous 1930

UPDATED by ConEd 02/07/2024 10:31

SCH - PJM\_HTP

FWD (Import)

REV (Export)

**300 MW**

Impacts Total Transfer Capability

360 MW

TTC with All Lines In Service

660 MW

Work scheduled by: ConEd

### SCH-NE-NYISO\_LIMIT\_600

Sun 05/05/2024 to Mon 05/06/2024  
2300 Continuous 0659

SCH - NE - NY

FWD (Import)

REV (Export)

**800 MW**

Impacts Total Transfer Capability

600 MW

TTC with All Lines In Service

1400 MW

Work scheduled by: ConEd

### EGRDNCTY\_345\_138\_AT1

Mon 05/06/2024 to Mon 05/06/2024  
0001 Continuous 0030

CONED - LIPA

FWD (Import)

REV (Export)

**1250 MW**

Impacts Total Transfer Capability

250 MW

TTC with All Lines In Service

1500 MW

Work scheduled by: ConEd

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, April 11, 2024 to Friday, October 10, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### EGRDNCTY\_345\_138\_AT2

Mon 05/06/2024 to Mon 05/06/2024  
0001 Continuous 0030  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
CONED - LIPA	<b>1250 MW</b>	
Impacts Total Transfer Capability	250 MW	
TTC with All Lines In Service	1500 MW	

### SPRNBK -EGRDNCTR\_345\_Y49

Mon 05/06/2024 to Wed 05/08/2024  
0001 Continuous 2200  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
CONED - LIPA	<b>775 MW</b>	
Impacts Total Transfer Capability	725 MW	
TTC with All Lines In Service	1500 MW	

### SCH-NE-NYISO\_LIMIT\_800

Mon 05/06/2024 to Mon 05/06/2024  
0700 Continuous 2259  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - NE - NY	<b>1000 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NE-NYISO\_LIMIT\_600

Mon 05/06/2024 to Tue 05/07/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - NE - NY	<b>800 MW</b>	
Impacts Total Transfer Capability	600 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NE-NYISO\_LIMIT\_800

Tue 05/07/2024 to Tue 05/07/2024  
0700 Continuous 2259  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - NE - NY	<b>1000 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

### PANNELL -CLAY\_\_\_345\_2

Tue 05/07/2024 to Tue 05/07/2024  
0730 Continuous 1430  
Work scheduled by: NGrid

	FWD (Import)	REV (Export)
WEST CENTRAL	<b>1300 MW</b>	
Impacts Total Transfer Capability	950 MW	
TTC with All Lines In Service	2250 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, April 11, 2024 to Friday, October 10, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### EGRDNCTY\_345\_138\_AT1

Tue 05/07/2024 to Tue 05/07/2024  
2130 Continuous 2200  
Work scheduled by: ConEd

FWD (Import) REV (Export)  
CONED - LIPA **1250 MW**  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 1500 MW

### EGRDNCTY\_345\_138\_AT2

Tue 05/07/2024 to Tue 05/07/2024  
2130 Continuous 2200  
Work scheduled by: ConEd

FWD (Import) REV (Export)  
CONED - LIPA **1250 MW**  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 1500 MW

### SCH-NE-NYISO\_LIMIT\_600

Tue 05/07/2024 to Wed 05/08/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

FWD (Import) REV (Export)  
SCH - NE - NY **800 MW**  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 1400 MW

### SCH-NE-NYISO\_LIMIT\_800

Wed 05/08/2024 to Wed 05/08/2024  
0700 Continuous 2259  
Work scheduled by: ConEd

FWD (Import) REV (Export)  
SCH - NE - NY **1000 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 1400 MW

### CLAY\_\_\_-INDPDNCE\_345\_26

Wed 05/08/2024 to Wed 05/08/2024  
0730 Continuous 1430  
Work scheduled by: NGrid

FWD (Import) REV (Export)  
OSWEGO EXPORT **5000 MW**  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 5250 MW

### SCH-NE-NYISO\_LIMIT\_600

Wed 05/08/2024 to Thu 05/09/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

FWD (Import) REV (Export)  
SCH - NE - NY **800 MW**  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 1400 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, April 11, 2024 to Friday, October 10, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_800

Thu 05/09/2024 to Thu 05/09/2024  
0700 Continuous 2259  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - NE - NY	<b>1000 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

### PANNELL\_CLAY\_\_\_345\_1

Thu 05/09/2024 to Thu 05/09/2024  
0730 Continuous 1430  
Work scheduled by: NGrid

	FWD (Import)	REV (Export)
WEST CENTRAL	<b>1300 MW</b>	
Impacts Total Transfer Capability	950 MW	
TTC with All Lines In Service	2250 MW	

### SCH-NE-NYISO\_LIMIT\_600

Thu 05/09/2024 to Fri 05/10/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - NE - NY	<b>800 MW</b>	
Impacts Total Transfer Capability	600 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NE-NYISO\_LIMIT\_800

Fri 05/10/2024 to Fri 05/10/2024  
0700 Continuous 2259  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - NE - NY	<b>1000 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

### BERKSHIR-ALPS\_\_\_345\_393

Fri 05/10/2024 to Fri 05/10/2024  
1430 Continuous 1500  
Work scheduled by: NGrid

UPDATED by ISONE 04/02/2024 13:47  
ARR: 78

	FWD (Import)	REV (Export)
SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

### BERKSHIR-ALPS\_\_\_345\_393

Fri 05/10/2024 to Fri 05/10/2024  
1430 Continuous 1500  
Work scheduled by: NGrid

UPDATED by ISONE 04/02/2024 13:47  
ARR: 78

	FWD (Import)	REV (Export)
SCH - NE - NY	<b>900 MW</b>	
Impacts Total Transfer Capability	500 MW	
TTC with All Lines In Service	1400 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, April 11, 2024 to Friday, October 10, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### BERKSHIR-ALPS\_\_\_345\_393 , BERKSHIR-NORTHFLD\_345\_312

Fri 05/10/2024 to Fri 05/10/2024

1430 1500

ARR: 78

FWD (Import) REV (Export)

SCH - NE - NY **900 MW**

Impacts Total Transfer Capability 500 MW

TTC with All Lines In Service 1400 MW

Work scheduled by:

### SCH-NE-NYISO\_LIMIT\_600

Fri 05/10/2024 to Sat 05/11/2024

2300 Continuous 0659

FWD (Import) REV (Export)

SCH - NE - NY **800 MW**

Impacts Total Transfer Capability 600 MW

TTC with All Lines In Service 1400 MW

Work scheduled by: ConEd

### SCH-NE-NYISO\_LIMIT\_800

Sat 05/11/2024 to Sat 05/11/2024

0700 Continuous 2259

FWD (Import) REV (Export)

SCH - NE - NY **1000 MW**

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 1400 MW

Work scheduled by: ConEd

### SCH-NE-NYISO\_LIMIT\_600

Sat 05/11/2024 to Sun 05/12/2024

2300 Continuous 0659

FWD (Import) REV (Export)

SCH - NE - NY **800 MW**

Impacts Total Transfer Capability 600 MW

TTC with All Lines In Service 1400 MW

Work scheduled by: ConEd

### SPRNBK\_-TREMONT\_345\_X28

Sun 05/12/2024 to Sun 05/12/2024

0001 Continuous 0500

FWD (Import) REV (Export)

SPR/DUN-SOUTH **4200 MW**

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

### SPRNBK\_-TREMONT\_345\_X28

Sun 05/12/2024 to Sun 05/12/2024

0001 Continuous 0500

FWD (Import) REV (Export)

SPR/DUN-SOUTH **4200 MW**

Impacts Total Transfer Capability 400 MW

TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

CANCELLED by TO 04/10/2024 13:52

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, April 11, 2024 to Friday, October 10, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_800

Sun 05/12/2024 to Sun 05/12/2024  
0700 Continuous 2259  
Work scheduled by: ConEd

SCH - NE - NY FWD (Import) REV (Export)  
1000 MW  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 1400 MW

### SCH-NE-NYISO\_LIMIT\_600

Sun 05/12/2024 to Mon 05/13/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

SCH - NE - NY FWD (Import) REV (Export)  
800 MW  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 1400 MW

### GOETHALS\_345KV\_5

Mon 05/13/2024 to Mon 05/13/2024  
0001 Continuous 0030  
Work scheduled by: ConEd

STATEN ISLAND FWD (Import) REV (Export)  
Impacts Total Transfer Capability  
TTC with All Lines In Service

### HUDSONP\_FARRAGUT\_345\_B3402, LINDEN\_-GOETHALS\_230\_A2253

Mon 05/13/2024 to Tue 05/14/2024  
0001 1000  
Work scheduled by:

SCH - PJ - NY FWD (Import) REV (Export)  
2200 MW  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 2250 MW

### LINDEN\_-GOETHALS\_230\_A2253

Mon 05/13/2024 to Tue 05/14/2024  
0001 Continuous 1000  
Work scheduled by: ConEd

SCH - PJ - NY FWD (Import) REV (Export)  
Impacts Total Transfer Capability  
TTC with All Lines In Service



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, April 11, 2024 to Friday, October 10, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MARION\_-FARRAGUT\_345\_C3403 , HUDSONP\_-FARRAGUT\_345\_B3402 , LINDEN\_-GOETHALS\_230\_A2253

Mon 05/13/2024 to Tue 05/14/2024  
0001 1000

Work scheduled by:

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**2200 MW**

50 MW

2250 MW

### MARION\_-FARRAGUT\_345\_C3403 , LINDEN\_-GOETHALS\_230\_A2253

Mon 05/13/2024 to Tue 05/14/2024  
0001 1000

Work scheduled by:

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**2200 MW**

50 MW

2250 MW

### NIAGARA\_-ROBNSNRD\_230\_64

Mon 05/13/2024 to Fri 05/17/2024  
0500 Continuous 1900

Work scheduled by: NYPA

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**1500 MW**

150 MW

1650 MW

### NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE

Mon 05/13/2024 to Fri 05/17/2024  
0600 Continuous 1600

Work scheduled by: LI

SCH - PJM\_NEPTUNE

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**0 MW**

660 MW

660 MW

### NEWBRDGE\_345\_138\_BK\_1

Mon 05/13/2024 to Fri 05/17/2024  
0600 Continuous 1600

Work scheduled by: LI

SCH - PJM\_NEPTUNE

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**375 MW**

285 MW

660 MW

### NEWBRDGE\_345\_138\_BK\_2

Mon 05/13/2024 to Fri 05/17/2024  
0600 Continuous 1600

Work scheduled by: LI

SCH - PJM\_NEPTUNE

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**375 MW**

285 MW

660 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, April 11, 2024 to Friday, October 10, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>NEWBRDGE-DUFFYAVE_345_501</b>					FWD (Import)	REV (Export)
Mon 05/13/2024	to	Fri 05/17/2024		SCH - PJM_NEPTUNE	<b>0 MW</b>	
0600	Continuous	1600		Impacts Total Transfer Capability	660 MW	
Work scheduled by: LI				TTC with All Lines In Service	660 MW	
<b>SCH-NE-NYISO_LIMIT_800</b>					FWD (Import)	REV (Export)
Mon 05/13/2024	to	Mon 05/13/2024		SCH - NE - NY	<b>1000 MW</b>	
0700	Continuous	2259		Impacts Total Transfer Capability	400 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	1400 MW	
<b>SCH-NE-NYISO_LIMIT_600</b>					FWD (Import)	REV (Export)
Mon 05/13/2024	to	Tue 05/14/2024		SCH - NE - NY	<b>800 MW</b>	
2300	Continuous	0659		Impacts Total Transfer Capability	600 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	1400 MW	
<b>SCH-NE-NYISO_LIMIT_800</b>					FWD (Import)	REV (Export)
Tue 05/14/2024	to	Tue 05/14/2024		SCH - NE - NY	<b>1000 MW</b>	
0700	Continuous	2259		Impacts Total Transfer Capability	400 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	1400 MW	
<b>VOLNEY_-CLAY_345_6</b>					FWD (Import)	REV (Export)
Tue 05/14/2024	to	Tue 05/14/2024		OSWEGO EXPORT	<b>5250 MW</b>	
0730	Continuous	1430		Impacts Total Transfer Capability	0 MW	
Work scheduled by: NGrid				TTC with All Lines In Service	5250 MW	
<b>GOETHALS_345KV_5</b>					FWD (Import)	REV (Export)
Tue 05/14/2024	to	Tue 05/14/2024		STATEN ISLAND		
0930	Continuous	1000		Impacts Total Transfer Capability		
Work scheduled by: ConEd				TTC with All Lines In Service		

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, April 11, 2024 to Friday, October 10, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_600

Tue 05/14/2024 to Wed 05/15/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>800 MW</b>	
Impacts Total Transfer Capability	600 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NE-NYISO\_LIMIT\_800

Wed 05/15/2024 to Wed 05/15/2024  
0700 Continuous 2259  
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>1000 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

### CLAY\_\_-EDIC\_\_345\_2-15

Wed 05/15/2024 to Wed 05/15/2024  
0730 Continuous 1430  
Work scheduled by: NGrid

OSWEGO EXPORT	FWD (Import)	REV (Export)
	<b>4850 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	5250 MW	

### SCH-NE-NYISO\_LIMIT\_600

Wed 05/15/2024 to Thu 05/16/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>800 MW</b>	
Impacts Total Transfer Capability	600 MW	
TTC with All Lines In Service	1400 MW	

### GOETHALS\_345KV\_5

Thu 05/16/2024 to Thu 05/16/2024  
0001 Continuous 0030  
Work scheduled by: ConEd

STATEN ISLAND	FWD (Import)	REV (Export)
Impacts Total Transfer Capability		
TTC with All Lines In Service		

### HUDSONP\_-FARRAGUT\_345\_B3402 , LINDEN\_- GOETHALS\_230\_A2253

Thu 05/16/2024 to Thu 05/16/2024  
0001 0300  
Work scheduled by:

SCH - PJ - NY	FWD (Import)	REV (Export)
	<b>2200 MW</b>	
Impacts Total Transfer Capability	50 MW	
TTC with All Lines In Service	2250 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, April 11, 2024 to Friday, October 10, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### LINDEN\_-GOETHALS\_230\_A2253

FWD (Import) REV (Export)

Thu 05/16/2024 to Thu 05/16/2024

0001 Continuous 0300

Work scheduled by: ConEd

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

### MARION\_-FARRAGUT\_345\_C3403 , HUDSONP\_- FARRAGUT\_345\_B3402 , LINDEN\_-GOETHALS\_230\_A2253

FWD (Import) REV (Export)

Thu 05/16/2024 to Thu 05/16/2024

0001 0300

Work scheduled by:

SCH - PJ - NY

**2200 MW**

Impacts Total Transfer Capability

50 MW

TTC with All Lines In Service

2250 MW

### MARION\_-FARRAGUT\_345\_C3403 , LINDEN\_-GOETHALS\_230\_A2253

FWD (Import) REV (Export)

Thu 05/16/2024 to Thu 05/16/2024

0001 0300

Work scheduled by:

SCH - PJ - NY

**2200 MW**

Impacts Total Transfer Capability

50 MW

TTC with All Lines In Service

2250 MW

### GOETHALS\_345KV\_5

FWD (Import) REV (Export)

Thu 05/16/2024 to Thu 05/16/2024

0230 Continuous 0300

Work scheduled by: ConEd

STATEN ISLAND

Impacts Total Transfer Capability

TTC with All Lines In Service

### SCH-NE-NYISO\_LIMIT\_800

FWD (Import) REV (Export)

Thu 05/16/2024 to Thu 05/16/2024

0700 Continuous 2259

Work scheduled by: ConEd

SCH - NE - NY

**1000 MW**

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

1400 MW

### NINEMILE-CLAY\_\_\_345\_8

FWD (Import) REV (Export)

Thu 05/16/2024 to Thu 05/16/2024

0730 Continuous 1430

Work scheduled by: NGrid

OSWEGO EXPORT

**5150 MW**

Impacts Total Transfer Capability

100 MW

TTC with All Lines In Service

5250 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, April 11, 2024 to Friday, October 10, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_600

Thu 05/16/2024 to Fri 05/17/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - NE - NY	<b>800 MW</b>	
Impacts Total Transfer Capability	600 MW	
TTC with All Lines In Service	1400 MW	

### BUCHAN\_S-MILLWOOD\_345\_W97

Fri 05/17/2024 to Sat 05/18/2024  
0001 Continuous 0200  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
UPNY CONED	<b>8015 MW</b>	
Impacts Total Transfer Capability	35 MW	
TTC with All Lines In Service	8050 MW	

### SCH-NE-NYISO\_LIMIT\_800

Fri 05/17/2024 to Fri 05/17/2024  
0700 Continuous 2200  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - NE - NY	<b>1000 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

### KNICRBKR-PLSNTVLY\_345\_Y57

Sat 05/18/2024 to Sun 05/26/2024  
2300 Continuous 0100  
Work scheduled by: NGrid

ARR: 78

	FWD (Import)	REV (Export)
UPNY CONED	<b>7885 MW</b>	
Impacts Total Transfer Capability	165 MW	
TTC with All Lines In Service	8050 MW	

### FITZPTRK-EDIC\_\_\_345\_FE-1

Mon 05/20/2024 to Thu 05/23/2024  
0700 Continuous 1730  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
OSWEGO EXPORT	<b>4800 MW</b>	
Impacts Total Transfer Capability	450 MW	
TTC with All Lines In Service	5250 MW	

### FITZPTRK-EDIC\_\_\_345\_FE-1

Mon 05/20/2024 to Thu 05/23/2024  
0700 Continuous 1730  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
CENTRAL EAST - VC	<b>3520 MW</b>	
Impacts Total Transfer Capability	205 MW	
TTC with All Lines In Service	3725 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, April 11, 2024 to Friday, October 10, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### FITZPTRK-EDIC\_\_345\_FE-1

Tue 05/28/2024 to Fri 05/31/2024  
0700 Continuous 1530

Work scheduled by: NYPA

OSWEGO EXPORT **4800 MW**  
Impacts Total Transfer Capability 450 MW  
TTC with All Lines In Service 5250 MW

FWD (Import) REV (Export)

### FITZPTRK-EDIC\_\_345\_FE-1

Tue 05/28/2024 to Fri 05/31/2024  
0700 Continuous 1530

Work scheduled by: NYPA

CENTRAL EAST - VC **3520 MW**  
Impacts Total Transfer Capability 205 MW  
TTC with All Lines In Service 3725 MW

FWD (Import) REV (Export)

### LEEDS\_\_345\_LEEDS SVC

Tue 05/28/2024 to Tue 05/28/2024  
0830 Continuous 1630

Work scheduled by: NGrid

CENTRAL EAST - VC **3675 MW**  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 3725 MW

FWD (Import) REV (Export)

### CHATGUAY-MASSENA\_765\_7040

Wed 05/29/2024 to Sat 06/01/2024  
1800 Continuous 0500

Work scheduled by: NYPA

UPDATED by NYPA 02/02/2024 10:05

SCH - HQ - NY **0 MW** **0 MW**  
Impacts Total Transfer Capability 1500 MW 1000 MW  
TTC with All Lines In Service 1500 MW 1000 MW

FWD (Import) REV (Export)

### CHATGUAY-MASSENA\_765\_7040

Wed 05/29/2024 to Sat 06/01/2024  
1800 Continuous 0500

Work scheduled by: NYPA

UPDATED by NYPA 02/02/2024 10:05

MOSES SOUTH **1550 MW**  
Impacts Total Transfer Capability 1600 MW  
TTC with All Lines In Service 3150 MW

FWD (Import) REV (Export)

### MARCY\_\_765\_345\_AT1

Wed 05/29/2024 to Sat 06/01/2024  
1800 Continuous 0500

Work scheduled by: NYPA

UPDATED by NYPA 02/02/2024 10:05

ARR: 19

MOSES SOUTH **1750 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 3150 MW

FWD (Import) REV (Export)

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, April 11, 2024 to Friday, October 10, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MARCY\_\_\_765\_345\_AT2

Wed 05/29/2024 to Sat 06/01/2024  
1800 Continuous 0500

UPDATED by NYPA 02/02/2024 10:05

ARR: 19

MOSES SOUTH

FWD (Import)

REV (Export)

**1700 MW**

Impacts Total Transfer Capability

1450 MW

TTC with All Lines In Service

3150 MW

### MASSENA\_-MARCY\_\_\_765\_MSU1

Wed 05/29/2024 to Sat 06/01/2024  
1800 Continuous 0500

UPDATED by NYPA 02/02/2024 10:05

SCH - HQ\_CEDARS

FWD (Import)

REV (Export)

**90 MW**

Impacts Total Transfer Capability

180 MW

TTC with All Lines In Service

270 MW

### MASSENA\_-MARCY\_\_\_765\_MSU1

Wed 05/29/2024 to Sat 06/01/2024  
1800 Continuous 0500

UPDATED by NYPA 02/02/2024 10:05

SCH - HQ - NY

FWD (Import)

REV (Export)

**475 MW**

**1000 MW**

Impacts Total Transfer Capability

1025 MW

0 MW

TTC with All Lines In Service

1500 MW

1000 MW

### MASSENA\_-MARCY\_\_\_765\_MSU1

Wed 05/29/2024 to Sat 06/01/2024  
1800 Continuous 0500

UPDATED by NYPA 02/02/2024 10:05

MOSES SOUTH

FWD (Import)

REV (Export)

**500 MW**

Impacts Total Transfer Capability

2650 MW

TTC with All Lines In Service

3150 MW

### MASSENA\_-MARCY\_\_\_765\_MSU1

Wed 05/29/2024 to Sat 06/01/2024  
1800 Continuous 0500

UPDATED by NYPA 02/02/2024 10:05

CENTRAL EAST - VC

FWD (Import)

REV (Export)

**2595 MW**

Impacts Total Transfer Capability

1130 MW

TTC with All Lines In Service

3725 MW

### MASSENA\_-MARCY\_\_\_765\_MSU1 , CHATGUAY-MASSENA\_765\_7040

Wed 05/29/2024 to Sat 06/01/2024  
1800 Continuous 0500

MOSES SOUTH

FWD (Import)

REV (Export)

**500 MW**

Impacts Total Transfer Capability

2650 MW

TTC with All Lines In Service

3150 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, April 11, 2024 to Friday, October 10, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MOSES__-MASSENA_230_MMS2 , MOSES__-MASSENA_230_MMS1</b>					FWD (Import)	REV (Export)
Wed 05/29/2024	to	Sat 06/01/2024		SCH - HQ_CEDARS	<b>90 MW</b>	
1800		0500		Impacts Total Transfer Capability	180 MW	
Work scheduled by:				TTC with All Lines In Service	270 MW	
<b>MOSES__-MASSENA_230_MMS2 , MOSES__-MASSENA_230_MMS1</b>					FWD (Import)	REV (Export)
Wed 05/29/2024	to	Sat 06/01/2024		SCH - HQ - NY	<b>850 MW</b>	<b>0 MW</b>
1800		0500		Impacts Total Transfer Capability	650 MW	1000 MW
Work scheduled by:				TTC with All Lines In Service	1500 MW	1000 MW
<b>BECK__-PACKARD_230_BP76</b>					FWD (Import)	REV (Export)
Fri 05/31/2024	to	Fri 05/31/2024		SCH - OH - NY	<b>1600 MW</b>	<b>1050 MW</b>
0730	Continuous	1630		Impacts Total Transfer Capability	450 MW	600 MW
Work scheduled by: NGrid				TTC with All Lines In Service	2050 MW	1650 MW
<b>CHASLAKE-PORTER__230_11</b>					FWD (Import)	REV (Export)
Sat 06/01/2024	to	Wed 07/03/2024		MOSES SOUTH	<b>2100 MW</b>	
0530	Continuous	1600		Impacts Total Transfer Capability	1050 MW	
Work scheduled by: NGrid				TTC with All Lines In Service	3150 MW	
<b>CRICKVLY-PLSNTVLY_345_F84</b>					FWD (Import)	REV (Export)
Mon 06/03/2024	to	Tue 06/04/2024		SCH - NE - NY	<b>600 MW</b>	
0001	Continuous	2200		Impacts Total Transfer Capability	800 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	1400 MW	
<b>CRICKVLY-PLSNTVLY_345_F84</b>					FWD (Import)	REV (Export)
Mon 06/03/2024	to	Tue 06/04/2024		SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
0001	Continuous	2200		Impacts Total Transfer Capability	100 MW	100 MW
Work scheduled by: ConEd				TTC with All Lines In Service	200 MW	200 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, April 11, 2024 to Friday, October 10, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### WATRCURE-OAKDALE\_345\_31

Mon 06/03/2024 to Fri 06/07/2024  
0700 Continuous 1430

Work scheduled by: NYSEG

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**2050 MW**

200 MW

2250 MW

### DUNWODIE\_345KV\_3

Sat 06/08/2024 to Mon 06/10/2024  
0001 Continuous 0200

Work scheduled by: ConEd

SPR/DUN-SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**3800 MW**

800 MW

4600 MW

### DUNWODIE\_345KV\_4

Sat 06/08/2024 to Mon 06/10/2024  
0001 Continuous 0200

Work scheduled by: ConEd

SPR/DUN-SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**3800 MW**

800 MW

4600 MW

### NIAGARA\_345\_230\_AT4

Tue 06/11/2024 to Wed 06/12/2024  
0500 Continuous 1900

Work scheduled by: NYPA

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**1200 MW**

450 MW

1650 MW

### CHASLAKE-PORTER\_230\_11

Mon 07/08/2024 to Fri 08/30/2024  
0700 Continuous 1900

Work scheduled by: NGrid

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**2100 MW**

1050 MW

3150 MW

### ROSETON\_EFISHKIL\_345\_RFK305

Sat 07/20/2024 to Sun 07/21/2024  
0700 Continuous 1600

Work scheduled by: CHGE

UPNY CONED

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**7215 MW**

835 MW

8050 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, April 11, 2024 to Friday, October 10, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### LEEDS\_\_345\_LEEDS SVC

Mon 07/22/2024 to Thu 07/25/2024  
0730 Continuous 1600  
Work scheduled by: NGrid

FWD (Import) REV (Export)  
CENTRAL EAST - VC **3675 MW**  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 3725 MW

### FRASER\_\_345\_FRASER SVC

Mon 07/29/2024 to Fri 08/02/2024  
0800 Continuous 1400  
Work scheduled by: NYSEG

FWD (Import) REV (Export)  
CENTRAL EAST - VC **3655 MW**  
Impacts Total Transfer Capability 70 MW  
TTC with All Lines In Service 3725 MW

### EDIC\_\_GORDONRD\_345\_14

Mon 08/19/2024 to Fri 08/30/2024  
0630 Continuous 1800  
Work scheduled by: NGrid

FWD (Import) REV (Export)  
CENTRAL EAST - VC **2770 MW**  
Impacts Total Transfer Capability 955 MW  
TTC with All Lines In Service 3725 MW

### EDIC\_\_PRINCTWN\_345\_351

Mon 08/19/2024 to Sat 08/24/2024  
0700 Continuous 1700  
Work scheduled by: NGrid

UPDATED by NGrid 02/02/2024 14:41

FWD (Import) REV (Export)  
CENTRAL EAST - VC **3335 MW**  
Impacts Total Transfer Capability 390 MW  
TTC with All Lines In Service 3725 MW

### MARCY\_\_EDIC\_\_345\_UE1-7

Sun 08/25/2024 to Fri 08/30/2024  
0800 Continuous 1600  
Work scheduled by: NGrid

ARR: 16 & 19

FWD (Import) REV (Export)  
OSWEGO EXPORT **5250 MW**  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

### CHASLAKE-PORTER\_\_230\_11

Tue 09/03/2024 to Fri 11/15/2024  
0530 Continuous 2000  
Work scheduled by: NGrid

FWD (Import) REV (Export)  
MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, April 11, 2024 to Friday, October 10, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### EDIC\_\_\_-GORDONRD\_345\_14

Tue 09/03/2024 to Mon 10/14/2024  
0600 Continuous 1800  
Work scheduled by: NGrid

FWD (Import) REV (Export)  
CENTRAL EAST - VC **2770 MW**  
Impacts Total Transfer Capability 955 MW  
TTC with All Lines In Service 3725 MW

### FITZPTRK-EDIC\_\_\_345\_FE-1

Mon 09/09/2024 to Mon 09/09/2024  
0001 Continuous 0100  
Work scheduled by: NYPA

FWD (Import) REV (Export)  
OSWEGO EXPORT **4800 MW**  
Impacts Total Transfer Capability 450 MW  
TTC with All Lines In Service 5250 MW

### FITZPTRK-EDIC\_\_\_345\_FE-1

Mon 09/09/2024 to Mon 09/09/2024  
0001 Continuous 0100  
Work scheduled by: NYPA

FWD (Import) REV (Export)  
CENTRAL EAST - VC **3520 MW**  
Impacts Total Transfer Capability 205 MW  
TTC with All Lines In Service 3725 MW

### EDIC\_\_\_-PRINCTWN\_345\_351

Mon 09/09/2024 to Wed 09/11/2024  
0700 Continuous 1700  
Work scheduled by: NGrid

FWD (Import) REV (Export)  
CENTRAL EAST - VC **3335 MW**  
Impacts Total Transfer Capability 390 MW  
TTC with All Lines In Service 3725 MW

### ROCHESTR-PANNELL\_345\_RP1

Mon 09/09/2024 to Fri 09/13/2024  
0700 Continuous 1530  
Work scheduled by: NYPA

FWD (Import) REV (Export)  
DYSINGER EAST **2300 MW**  
Impacts Total Transfer Capability 900 MW  
TTC with All Lines In Service 3200 MW

### MARCY\_\_\_-EDIC\_\_\_345\_UE1-7

Thu 09/12/2024 to Sat 09/14/2024  
0700 Continuous 1700  
Work scheduled by: NGrid

ARR: 16 & 19

FWD (Import) REV (Export)  
OSWEGO EXPORT **5250 MW**  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, April 11, 2024 to Friday, October 10, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MOTTHAVN-RAINEY\_\_345\_Q11

Sun 09/15/2024 to Sat 10/26/2024  
0001 Continuous 0300  
Work scheduled by: ConEd

SPR/DUN-SOUTH FWD (Import) REV (Export)  
**3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

### W49TH\_ST\_345KV\_6

Sun 09/15/2024 to Fri 09/27/2024  
0001 Continuous 0100  
Work scheduled by: ConEd

SCH - PJM\_HTP FWD (Import) REV (Export)  
**300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

### W49TH\_ST\_345KV\_8

Sun 09/15/2024 to Fri 09/27/2024  
0001 Continuous 0100  
Work scheduled by: ConEd

SCH - PJM\_HTP FWD (Import) REV (Export)  
**450 MW**  
Impacts Total Transfer Capability 210 MW  
TTC with All Lines In Service 660 MW

### DYSINGER-STA\_255\_345\_DH2

Mon 09/16/2024 to Mon 10/28/2024  
0500 Continuous 1900  
Work scheduled by: NYPA

DYSINGER EAST FWD (Import) REV (Export)  
**2850 MW**  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 3200 MW

### ROCHESTR-PANNELL\_345\_RP2

Mon 09/16/2024 to Fri 09/20/2024  
0700 Continuous 1530  
Work scheduled by: NYPA

DYSINGER EAST FWD (Import) REV (Export)  
**2300 MW**  
Impacts Total Transfer Capability 900 MW  
TTC with All Lines In Service 3200 MW

### STLAWRNC-MOSES\_\_230\_L34P

Mon 09/16/2024 to Fri 09/20/2024  
0700 Continuous 1530  
Work scheduled by: NYPA

SCH - OH - NY FWD (Import) REV (Export)  
Impacts Total Transfer Capability  
TTC with All Lines In Service

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, April 11, 2024 to Friday, October 10, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### PANNELL-CLAY\_\_\_345\_1

Mon 09/23/2024 to Fri 09/27/2024

0700 Continuous 1530

Work scheduled by: NYPA

WEST CENTRAL

FWD (Import)

REV (Export)

**1300 MW**

Impacts Total Transfer Capability

950 MW

TTC with All Lines In Service

2250 MW

### STLAWRNC-MOSES\_\_\_230\_L34P

Mon 09/23/2024 to Fri 09/27/2024

0700 Continuous 1530

Work scheduled by: NYPA

SCH - OH - NY

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

TTC with All Lines In Service

### FITZPTRK-EDIC\_\_\_345\_FE-1

Thu 09/26/2024 to Thu 09/26/2024

0900 Continuous 1000

Work scheduled by: NYPA

OSWEGO EXPORT

FWD (Import)

REV (Export)

**4800 MW**

Impacts Total Transfer Capability

450 MW

TTC with All Lines In Service

5250 MW

### FITZPTRK-EDIC\_\_\_345\_FE-1

Thu 09/26/2024 to Thu 09/26/2024

0900 Continuous 1000

Work scheduled by: NYPA

CENTRAL EAST - VC

FWD (Import)

REV (Export)

**3520 MW**

Impacts Total Transfer Capability

205 MW

TTC with All Lines In Service

3725 MW

### W49TH\_ST-E13THSTA\_345\_M55

Fri 09/27/2024 to Tue 11/19/2024

0001 Continuous 0200

Work scheduled by: ConEd

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

**3800 MW**

Impacts Total Transfer Capability

800 MW

TTC with All Lines In Service

4600 MW

### W49TH\_ST\_345KV\_6

Fri 09/27/2024 to Tue 11/19/2024

0101 Continuous 0200

Work scheduled by: ConEd

SCH - PJM\_HTP

FWD (Import)

REV (Export)

**300 MW**

Impacts Total Transfer Capability

360 MW

TTC with All Lines In Service

660 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, April 11, 2024 to Friday, October 10, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### STLAWRNC-MOSES\_\_230\_L34P

Mon 09/30/2024 to Fri 10/04/2024  
0700 Continuous 1530  
Work scheduled by: NYPA

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### FITZPTRK-EDIC\_\_345\_FE-1

Mon 09/30/2024 to Fri 10/04/2024  
1700 Continuous 1530  
Work scheduled by: NYPA

OSWEGO EXPORT  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**4800 MW**  
450 MW  
5250 MW

### FITZPTRK-EDIC\_\_345\_FE-1

Mon 09/30/2024 to Fri 10/04/2024  
1700 Continuous 1530  
Work scheduled by: NYPA

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3520 MW**  
205 MW  
3725 MW

### BECK\_\_-NIAGARA\_345\_PA302

Mon 10/07/2024 to Fri 10/11/2024  
0500 Continuous 1900  
Work scheduled by: NYPA

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1000 MW** **850 MW**  
1050 MW 800 MW  
2050 MW 1650 MW

### NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE

Mon 10/07/2024 to Fri 10/11/2024  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**0 MW**  
660 MW  
660 MW

### NEWBRDGE\_345\_138\_BK\_1

Mon 10/07/2024 to Fri 10/11/2024  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**375 MW**  
285 MW  
660 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, April 11, 2024 to Friday, October 10, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### NEWBRDGE\_345\_138\_BK\_2

Mon 10/07/2024 to Fri 10/11/2024  
0600 Continuous 1600

Work scheduled by: LI

SCH - PJM\_NEPTUNE  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) 375 MW  
REV (Export) 285 MW  
660 MW

### NEWBRDGE-DUFFYAVE\_345\_501

Mon 10/07/2024 to Fri 10/11/2024  
0600 Continuous 1600

Work scheduled by: LI

SCH - PJM\_NEPTUNE  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) 0 MW  
REV (Export) 660 MW  
660 MW

### SHOR\_NPX-SHOREHAM\_138\_CSC

Mon 10/07/2024 to Fri 10/11/2024  
0600 Continuous 1800

Work scheduled by: LI

SCH - NPX\_CSC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) 0 MW  
REV (Export) 0 MW  
330 MW  
330 MW

### MARCY\_\_FRASANNX\_345\_UCC2-41

Wed 10/09/2024 to Thu 10/10/2024  
0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) 3225 MW  
REV (Export) 500 MW  
3725 MW

### MARCY\_\_N.SCTLND\_345\_18

Tue 10/15/2024 to Thu 10/17/2024  
0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) 2665 MW  
REV (Export) 1060 MW  
3725 MW

### MARCY\_\_N.SCTLND\_345\_18

Mon 10/21/2024 to Fri 10/25/2024  
0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) 2665 MW  
REV (Export) 1060 MW  
3725 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, April 11, 2024 to Friday, October 10, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MARCY\_\_345KV\_CSC

Mon 10/28/2024 to Sun 11/10/2024  
0700 Continuous 1530  
Work scheduled by: NYPA

FWD (Import) REV (Export)  
CENTRAL EAST - VC **3650 MW**  
Impacts Total Transfer Capability 75 MW  
TTC with All Lines In Service 3725 MW

### DYSINGER-STA\_255\_345\_DH2

Tue 10/29/2024 to Thu 10/31/2024  
0500 Continuous 2100  
Work scheduled by: NYPA

FWD (Import) REV (Export)  
DYSINGER EAST **2850 MW**  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 3200 MW

### DYSINGER-STA\_255\_345\_DH1

Mon 11/04/2024 to Sat 11/16/2024  
0500 Continuous 1900  
Work scheduled by: NYPA

FWD (Import) REV (Export)  
DYSINGER EAST **2850 MW**  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 3200 MW

### LINDN\_CG-LNDVFT\_\_345\_V-3022

Tue 11/12/2024 to Tue 11/12/2024  
0800 Continuous 2359  
Work scheduled by: PJM

FWD (Import) REV (Export)  
SCH - PJM\_VFT **0 MW** **0 MW**  
Impacts Total Transfer Capability 315 MW 315 MW  
TTC with All Lines In Service 315 MW 315 MW

### BECK\_\_-NIAGARA\_230\_PA27

Fri 11/15/2024 to Fri 11/15/2024  
0500 Continuous 1900  
Work scheduled by: NYPA

FWD (Import) REV (Export)  
SCH - OH - NY **2100 MW**  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 2450 MW

### OSWEGO\_-VOLNEY\_\_345\_12

Fri 11/15/2024 to Fri 12/13/2024  
0730 Continuous 1600  
Work scheduled by: NGrid

FWD (Import) REV (Export)  
OSWEGO EXPORT **5250 MW**  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, April 11, 2024 to Friday, October 10, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### CHATGUAY-MASSENA\_765\_7040

Sat 11/16/2024 to Fri 11/29/2024

0001 Continuous 2359

Work scheduled by: NYPA

SCH - HQ - NY

FWD (Import)

REV (Export)

0 MW

0 MW

Impacts Total Transfer Capability

1500 MW

1000 MW

TTC with All Lines In Service

1500 MW

1000 MW

### CHATGUAY-MASSENA\_765\_7040

Sat 11/16/2024 to Fri 11/29/2024

0001 Continuous 2359

Work scheduled by: NYPA

MOSES SOUTH

FWD (Import)

REV (Export)

1550 MW

Impacts Total Transfer Capability

1600 MW

TTC with All Lines In Service

3150 MW

### MARCY\_765\_345\_AT1

Sat 11/16/2024 to Fri 11/29/2024

0001 Continuous 2359

Work scheduled by: NYPA

ARR: 19

MOSES SOUTH

FWD (Import)

REV (Export)

1750 MW

Impacts Total Transfer Capability

1400 MW

TTC with All Lines In Service

3150 MW

### MARCY\_765\_345\_AT2

Sat 11/16/2024 to Fri 11/29/2024

0001 Continuous 2359

Work scheduled by: NYPA

ARR: 19

MOSES SOUTH

FWD (Import)

REV (Export)

1700 MW

Impacts Total Transfer Capability

1450 MW

TTC with All Lines In Service

3150 MW

### MASSENA\_-MARCY\_765\_MSU1

Sat 11/16/2024 to Fri 11/29/2024

0001 Continuous 2359

Work scheduled by: NYPA

SCH - HQ\_CEDARS

FWD (Import)

REV (Export)

90 MW

Impacts Total Transfer Capability

189 MW

TTC with All Lines In Service

279 MW

### MASSENA\_-MARCY\_765\_MSU1

Sat 11/16/2024 to Fri 11/29/2024

0001 Continuous 2359

Work scheduled by: NYPA

SCH - HQ - NY

FWD (Import)

REV (Export)

475 MW

1000 MW

Impacts Total Transfer Capability

1025 MW

0 MW

TTC with All Lines In Service

1500 MW

1000 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, April 11, 2024 to Friday, October 10, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MASSENA_MARCY__765_MSU1</b>				FWD (Import)	REV (Export)
Sat 11/16/2024	to	Fri 11/29/2024	MOSES SOUTH	<b>500 MW</b>	
0001	Continuous	2359	Impacts Total Transfer Capability	2650 MW	
Work scheduled by: NYPA			TTC with All Lines In Service	3150 MW	
<b>MASSENA_MARCY__765_MSU1</b>				FWD (Import)	REV (Export)
Sat 11/16/2024	to	Fri 11/29/2024	CENTRAL EAST - VC	<b>2595 MW</b>	
0001	Continuous	2359	Impacts Total Transfer Capability	1130 MW	
Work scheduled by: NYPA			TTC with All Lines In Service	3725 MW	
<b>MASSENA_MARCY__765_MSU1 , CHATGUAY-MASSENA_765_7040</b>				FWD (Import)	REV (Export)
Sat 11/16/2024	to	Fri 11/29/2024	MOSES SOUTH	<b>500 MW</b>	
0001		2359	Impacts Total Transfer Capability	2650 MW	
Work scheduled by:			TTC with All Lines In Service	3150 MW	
<b>MOSES__-MASSENA_230_MMS2 , MOSES__-MASSENA_230_MMS1</b>				FWD (Import)	REV (Export)
Sat 11/16/2024	to	Fri 11/29/2024	SCH - HQ_CEDARS	<b>90 MW</b>	
0001		2359	Impacts Total Transfer Capability	189 MW	
Work scheduled by:			TTC with All Lines In Service	279 MW	
<b>MOSES__-MASSENA_230_MMS2 , MOSES__-MASSENA_230_MMS1</b>				FWD (Import)	REV (Export)
Sat 11/16/2024	to	Fri 11/29/2024	SCH - HQ - NY	<b>850 MW</b>	<b>0 MW</b>
0001		2359	Impacts Total Transfer Capability	650 MW	1000 MW
Work scheduled by:			TTC with All Lines In Service	1500 MW	1000 MW
<b>LINDN_CG-LNDVFT__345_V-3022</b>				FWD (Import)	REV (Export)
Fri 11/22/2024	to	Fri 11/22/2024	SCH - PJM_VFT	<b>0 MW</b>	<b>0 MW</b>
1500	Continuous	1800	Impacts Total Transfer Capability	315 MW	315 MW
Work scheduled by: PJM			TTC with All Lines In Service	315 MW	315 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, April 11, 2024 to Friday, October 10, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### ADIRNDCK-PORTER\_\_230\_12

Sun 12/01/2024 to Tue 12/24/2024  
0530 Continuous 1700  
Work scheduled by: NGrid

FWD (Import) REV (Export)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

### E13THSTA-FARRAGUT\_345\_46

Wed 12/18/2024 to Fri 12/20/2024  
0201 Continuous 0300  
Work scheduled by: ConEd

FWD (Import) REV (Export)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

### ADIRNDCK-PORTER\_\_230\_12

Thu 01/02/2025 to Sat 05/31/2025  
0530 Continuous 1700  
Work scheduled by: NGrid

FWD (Import) REV (Export)  
MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

### OSWEGO\_-VOLNEY\_\_345\_11

Mon 01/06/2025 to Fri 01/24/2025  
0700 Continuous 1700  
Work scheduled by: NGrid

FWD (Import) REV (Export)  
OSWEGO EXPORT **5250 MW**  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

### E13THSTA-FARRAGUT\_345\_46

Fri 01/10/2025 to Wed 01/15/2025  
0001 Continuous 0300  
Work scheduled by: ConEd

FWD (Import) REV (Export)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

### OSWEGO\_-ELBRIDGE\_345\_17

Mon 01/27/2025 to Fri 02/14/2025  
0630 Continuous 1730  
Work scheduled by: NGrid

ARR: 75

FWD (Import) REV (Export)  
OSWEGO EXPORT **5250 MW**  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, April 11, 2024 to Friday, October 10, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### ELBRIDGE-LAFAYTTE\_345\_17-LE

Wed 02/12/2025 to Fri 02/14/2025  
0700 Continuous 1730

ARR: 75

OSWEGO EXPORT

FWD (Import)

REV (Export)

**5250 MW**

Impacts Total Transfer Capability

0 MW

TTC with All Lines In Service

5250 MW

Work scheduled by: NGrid

### GOETHALS\_345KV\_5

Mon 09/08/2025 to Mon 09/08/2025  
0301 Continuous 0330

Work scheduled by: ConEd

STATEN ISLAND

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

TTC with All Lines In Service

### GOETHALS\_345KV\_5

Tue 09/09/2025 to Tue 09/09/2025  
2330 Continuous 2359

Work scheduled by: ConEd

STATEN ISLAND

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

TTC with All Lines In Service

### GOETHALS\_345KV\_5

Mon 09/15/2025 to Mon 09/15/2025  
0230 Continuous 0300

Work scheduled by: ConEd

STATEN ISLAND

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

TTC with All Lines In Service

### GOETHALS\_345KV\_5

Mon 09/15/2025 to Mon 09/15/2025  
0301 Continuous 0330

Work scheduled by: ConEd

STATEN ISLAND

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

TTC with All Lines In Service

### ADIRNDCK-PORTER\_\_230\_12

Mon 09/15/2025 to Sun 10/12/2025  
0600 Continuous 1700

Work scheduled by: NGrid

MOSES SOUTH

FWD (Import)

REV (Export)

**2100 MW**

Impacts Total Transfer Capability

1050 MW

TTC with All Lines In Service

3150 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits		Thursday, April 11, 2024 to Friday, October 10, 2025			
CENTRAL EAST	7550 MW	<b>The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.</b>			
CENTRAL EAST - VC	3725 MW				
TOTAL EAST	6150 MW				
UPNY CONED	8050 MW				
SPR/DUN-SOUTH	4600 MW				
DYSINGER EAST	3200 MW				
MOSES SOUTH	3150 MW				
<hr/>					
GOETHALS_345KV_5				FWD (Import)	REV (Export)
Tue 09/16/2025	to	Tue 09/16/2025	STATEN ISLAND		
2330	Continuous	2359	Impacts Total Transfer Capability		
Work scheduled by: ConEd			TTC with All Lines In Service		
<hr/>					
GOETHALS_345KV_5				FWD (Import)	REV (Export)
Fri 09/26/2025	to	Fri 09/26/2025	STATEN ISLAND		
0230	Continuous	0300	Impacts Total Transfer Capability		
Work scheduled by: ConEd			TTC with All Lines In Service		
<hr/>					
BECK__-NIAGARA_230_PA27				FWD (Import)	REV (Export)
Mon 09/29/2025	to	Wed 11/26/2025	SCH - OH - NY	<b>1900 MW</b>	<b>1650 MW</b>
0500	Continuous	1900	Impacts Total Transfer Capability	150 MW	0 MW
Work scheduled by: NYPA			TTC with All Lines In Service	2050 MW	1650 MW