

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, April 22, 2024 to Tuesday, October 21, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>HUDSONP_-FARRAGUT_345_B3402</b>						FWD (Import)	REV (Export)
Mon 01/15/2018	to	Tue 12/31/2024			SCH - PJ - NY		
0001	Continuous	2359	<u>EXT FORCED by ConEd 03/11/2024 11:26</u>		Impacts Total Transfer Capability		
Work scheduled by: ConEd						TTC with All Lines In Service	
<b>MARION_-FARRAGUT_345_C3403</b>						FWD (Import)	REV (Export)
Mon 01/15/2018	to	Tue 12/31/2024			SCH - PJ - NY		
0001	Continuous	2359	<u>EXT FORCED by ConEd 03/11/2024 11:26</u>		Impacts Total Transfer Capability		
Work scheduled by: ConEd						TTC with All Lines In Service	
<b>MARION_-FARRAGUT_345_C3403 , HUDSONP_-FARRAGUT_345_B3402</b>						FWD (Import)	REV (Export)
Mon 01/15/2018	to	Tue 12/31/2024			SCH - PJ - NY	<b>2400 MW</b>	<b>2400 MW</b>
0001		2359			Impacts Total Transfer Capability	150 MW	250 MW
Work scheduled by:						TTC with All Lines In Service	2550 MW 2650 MW
<b>SCH-IMO-NYISO_LIMIT_1900</b>						FWD (Import)	REV (Export)
Wed 11/01/2023	to	Tue 04/30/2024			SCH - OH - NY	<b>2200 MW</b>	
0001	Continuous	2359			Impacts Total Transfer Capability	250 MW	
Work scheduled by: IESO						TTC with All Lines In Service	2450 MW
<b>ADIRNDCK-PORTER__230_12</b>						FWD (Import)	REV (Export)
Tue 01/02/2024	to	Wed 05/29/2024			MOSES SOUTH	<b>2300 MW</b>	
0630	Continuous	1730	<u>UPDATED by NGrid 07/11/2023 11:44</u>		Impacts Total Transfer Capability	850 MW	
Work scheduled by: NGrid						TTC with All Lines In Service	3150 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, April 22, 2024 to Tuesday, October 21, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-IMO-NYISO\_LIMIT\_1750

Tue 01/02/2024 to Wed 05/29/2024  
0630 Continuous 1730  
Work scheduled by: NGrid

UPDATED by NGrid 07/11/2023 11:44

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**2050 MW**

400 MW

2450 MW

### SPRNBK\_-W49TH\_ST\_345\_M51

Tue 01/30/2024 to Thu 04/25/2024  
0202 Continuous 2359  
Work scheduled by: ConEd

EXT FORCED by ConEd 04/08/2024 15:10

SPR/DUN-SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**3200 MW**

1400 MW

4600 MW

### SHORE\_RD\_345\_138\_BK 1

Mon 02/12/2024 to Fri 05/03/2024  
0001 Continuous 2359  
Work scheduled by: LI

UPDATED by LI 02/07/2024 12:08

CONED - LIPA

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**1350 MW**

150 MW

1500 MW

### BECK\_-PACKARD\_230\_BP76

Mon 03/04/2024 to Fri 05/24/2024  
0500 Continuous 1600  
Work scheduled by: NGrid

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**1800 MW**

650 MW

2450 MW

**1350 MW**

550 MW

1900 MW

### SCH-IMO-NYISO\_LIMIT\_1300

Mon 03/04/2024 to Mon 05/20/2024  
0500 Continuous 0800  
Work scheduled by: NGrid

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**1600 MW**

850 MW

2450 MW

### SCH-HQ\_CEDARS-NYISO\_LIMIT\_240

Mon 03/11/2024 to Thu 04/25/2024  
0800 Continuous 1500  
Work scheduled by: HQ

EXTENDED by HQ 04/11/2024 16:37

SCH - HQ\_CEDARS

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**240 MW**

39 MW

279 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, April 22, 2024 to Tuesday, October 21, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NYISO-HQ\_CEDARS\_LIMIT\_0

Mon 03/11/2024 to Thu 04/25/2024  
0800 Continuous 1500

EXTENDED by HQ 04/11/2024 16:37

SCH - HQ\_CEDARS

FWD (Import)

REV (Export)

**0 MW**

Impacts Total Transfer Capability

100 MW

TTC with All Lines In Service

100 MW

Work scheduled by: HQ

### RAMAPO\_\_BUCHAN\_N\_345\_Y94

Tue 04/02/2024 to Tue 04/30/2024  
0201 Continuous 0200

UPNY CONED

FWD (Import)

REV (Export)

**7755 MW**

Impacts Total Transfer Capability

295 MW

TTC with All Lines In Service

8050 MW

Work scheduled by: ConEd

### MOTTHAVN-RAINEY\_\_345\_Q12

Thu 04/04/2024 to Thu 04/25/2024  
0001 Continuous 0200

EXTENDED by ConEd 04/03/2024 10:26

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

**3800 MW**

Impacts Total Transfer Capability

800 MW

TTC with All Lines In Service

4600 MW

Work scheduled by: ConEd

### FRASER\_\_345\_FRASER SVC

Sat 04/06/2024 to Tue 04/23/2024  
1758 Continuous 2359

EXT FORCED by NYSEG 04/11/2024 14:44

CENTRAL EAST - VC

FWD (Import)

REV (Export)

**3655 MW**

Impacts Total Transfer Capability

70 MW

TTC with All Lines In Service

3725 MW

Work scheduled by: NYSEG

### BERKSHIR-NORTHFLD\_345\_312

Tue 04/09/2024 to Fri 05/10/2024  
0600 Continuous 1500

UPDATED by ISONE 04/02/2024 13:47

SCH - NPX\_1385

FWD (Import)

REV (Export)

**100 MW**

**100 MW**

Impacts Total Transfer Capability

100 MW

100 MW

TTC with All Lines In Service

200 MW

200 MW

Work scheduled by: NGrid

### BERKSHIR-NORTHFLD\_345\_312

Tue 04/09/2024 to Fri 05/10/2024  
0600 Continuous 1500

UPDATED by ISONE 04/02/2024 13:47

SCH - NE - NY

FWD (Import)

REV (Export)

**1300 MW**

Impacts Total Transfer Capability

100 MW

TTC with All Lines In Service

1400 MW

Work scheduled by: NGrid

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, April 22, 2024 to Tuesday, October 21, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_700

Tue 04/09/2024 to Fri 05/10/2024  
0600 Continuous 1500  
Work scheduled by: NGrid

UPDATED by ISONE 04/02/2024 13:47

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**900 MW**  
500 MW  
1400 MW

### SCH-NYISO-NE\_LIMIT\_900

Tue 04/09/2024 to Fri 05/10/2024  
0600 Continuous 2359  
Work scheduled by: NGrid

UPDATED by ISONE 04/02/2024 13:47

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1100 MW**  
700 MW  
1800 MW

### SCH-NPX\_1385-NYISO\_LIMIT\_100

Mon 04/15/2024 to Fri 04/26/2024  
0600 Continuous 2200  
Work scheduled by: ISONE

UPDATED by ISONE 04/09/2024 13:34

SCH - NPX\_1385  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**100 MW**  
100 MW  
200 MW

### DUNWODIE\_345KV\_4

Tue 04/16/2024 to Mon 04/29/2024  
1045 Continuous 2359  
Work scheduled by: ConEd

FORCED by ConEd 04/16/2024 14:42

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3800 MW**  
800 MW  
4600 MW

### SCH-NE-NYISO\_LIMIT\_600

Sun 04/21/2024 to Mon 04/22/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**800 MW**  
600 MW  
1400 MW

### PANNELL-CLAY\_345\_1

Mon 04/22/2024 to Fri 04/26/2024  
0700 Continuous 1530  
Work scheduled by: NYPA

WEST CENTRAL  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1300 MW**  
950 MW  
2250 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, April 22, 2024 to Tuesday, October 21, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_800

Mon 04/22/2024 to Mon 04/22/2024  
0700 Continuous 2259

SCH - NE - NY

FWD (Import)

REV (Export)

**1000 MW**

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

1400 MW

Work scheduled by: ConEd

### ELBRIDGE-LAFAYTTE\_345\_17-LE

Mon 04/22/2024 to Fri 04/26/2024  
0800 Continuous 1630

UPDATED by NGrid 04/16/2024 13:38

OSWEGO EXPORT

FWD (Import)

REV (Export)

**5250 MW**

Impacts Total Transfer Capability

0 MW

TTC with All Lines In Service

5250 MW

Work scheduled by: NGrid

ARR: 75

### OSWEGO\_-ELBRIDGE\_345\_17

Mon 04/22/2024 to Mon 04/22/2024  
0800 Continuous 0830

UPDATED by NGrid 04/16/2024 13:38

OSWEGO EXPORT

FWD (Import)

REV (Export)

**5250 MW**

Impacts Total Transfer Capability

0 MW

TTC with All Lines In Service

5250 MW

Work scheduled by: NGrid

ARR: 75

### SCH-NE-NYISO\_LIMIT\_600

Mon 04/22/2024 to Tue 04/23/2024  
2300 Continuous 0659

SCH - NE - NY

FWD (Import)

REV (Export)

**800 MW**

Impacts Total Transfer Capability

600 MW

TTC with All Lines In Service

1400 MW

Work scheduled by: ConEd

### SCH-NE-NYISO\_LIMIT\_800

Tue 04/23/2024 to Tue 04/23/2024  
0700 Continuous 2259

SCH - NE - NY

FWD (Import)

REV (Export)

**1000 MW**

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

1400 MW

Work scheduled by: ConEd

### OSWEGO\_-ELBRIDGE\_345\_17

Tue 04/23/2024 to Sat 04/27/2024  
0730 Continuous 1630

OSWEGO EXPORT

FWD (Import)

REV (Export)

**5250 MW**

Impacts Total Transfer Capability

0 MW

TTC with All Lines In Service

5250 MW

Work scheduled by: NGrid

ARR: 75

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, April 22, 2024 to Tuesday, October 21, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_600

Tue 04/23/2024 to Wed 04/24/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

SCH - NE - NY FWD (Import) REV (Export)  
**800 MW**  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 1400 MW

### SCH-NE-NYISO\_LIMIT\_800

Wed 04/24/2024 to Wed 04/24/2024  
0700 Continuous 2259  
Work scheduled by: ConEd

SCH - NE - NY FWD (Import) REV (Export)  
**1000 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 1400 MW

### SPRNBK\_345KV\_RS3 , SPRNBK\_345KV\_RS4

Wed 04/24/2024 to Wed 04/24/2024  
2130 2200  
Work scheduled by:

SPR/DUN-SOUTH FWD (Import) REV (Export)  
**3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

### SCH-NE-NYISO\_LIMIT\_600

Wed 04/24/2024 to Thu 04/25/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

SCH - NE - NY FWD (Import) REV (Export)  
**800 MW**  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 1400 MW

### SCH-NE-NYISO\_LIMIT\_800

Thu 04/25/2024 to Thu 04/25/2024  
0700 Continuous 2259  
Work scheduled by: ConEd

SCH - NE - NY FWD (Import) REV (Export)  
**1000 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 1400 MW

### SCH-NE-NYISO\_LIMIT\_600

Thu 04/25/2024 to Fri 04/26/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

SCH - NE - NY FWD (Import) REV (Export)  
**800 MW**  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 1400 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, April 22, 2024 to Tuesday, October 21, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SPRNBK\_345KV\_RNS5

Thu 04/25/2024 to Thu 04/25/2024  
2330 Continuous 2359

EXT FORCED by ConEd 04/08/2024 15:10

FWD (Import) REV (Export)

SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

Work scheduled by: ConEd

### SCH-NE-NYISO\_LIMIT\_800

Fri 04/26/2024 to Fri 04/26/2024  
0700 Continuous 2259

FWD (Import) REV (Export)

SCH - NE - NY **1000 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 1400 MW

Work scheduled by: ConEd

### SCH-NE-NYISO\_LIMIT\_600

Fri 04/26/2024 to Sat 04/27/2024  
2300 Continuous 0659

FWD (Import) REV (Export)

SCH - NE - NY **800 MW**  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 1400 MW

Work scheduled by: ConEd

### SCH-NE-NYISO\_LIMIT\_800

Sat 04/27/2024 to Sat 04/27/2024  
0700 Continuous 2259

FWD (Import) REV (Export)

SCH - NE - NY **1000 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 1400 MW

Work scheduled by: ConEd

### SCH-NE-NYISO\_LIMIT\_600

Sat 04/27/2024 to Sun 04/28/2024  
2300 Continuous 0659

FWD (Import) REV (Export)

SCH - NE - NY **800 MW**  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 1400 MW

Work scheduled by: ConEd

### CHAT\_DC\_GC2

Sun 04/28/2024 to Fri 05/17/2024  
0600 Continuous 2000

FWD (Import) REV (Export)

MOSES SOUTH **2850 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

Work scheduled by: HQ

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, April 22, 2024 to Tuesday, October 21, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### CHAT\_DC\_GC2

Sun 04/28/2024 to Fri 05/17/2024  
0600 Continuous 2000  
Work scheduled by: HQ

SCH - HQ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 500 MW  
REV (Export) 500 MW  
1000 MW

### SCH-HQ-NYISO\_LIMIT\_1400

Sun 04/28/2024 to Fri 05/17/2024  
0600 Continuous 2000  
Work scheduled by: HQ

SCH - HQ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 1400 MW  
REV (Export) 100 MW  
1500 MW

### SCH-NE-NYISO\_LIMIT\_800

Sun 04/28/2024 to Sun 04/28/2024  
0700 Continuous 2259  
Work scheduled by: ConEd

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 1000 MW  
REV (Export) 400 MW  
1400 MW

### SCH-NE-NYISO\_LIMIT\_600

Sun 04/28/2024 to Mon 04/29/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 800 MW  
REV (Export) 600 MW  
1400 MW

### SHOR\_NPX-SHOREHAM\_138\_CSC

Mon 04/29/2024 to Sat 05/04/2024  
0600 Continuous 1800  
Work scheduled by: LI

SCH - NPX\_CSC  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 0 MW  
REV (Export) 0 MW  
330 MW  
330 MW

### MARCY\_\_FRASANNX\_345\_UCC2-41

Mon 04/29/2024 to Fri 05/24/2024  
0700 Continuous 1730  
Work scheduled by: NYPA

UPDATED by NYPA 04/16/2024 10:08

ARR: 19

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 3225 MW  
REV (Export) 500 MW  
3725 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, April 22, 2024 to Tuesday, October 21, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### PANNELL\_-CLAY\_\_\_345\_2

Mon 04/29/2024 to Fri 05/03/2024  
0700 Continuous 1530  
Work scheduled by: NYPA

WEST CENTRAL  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 1300 MW  
REV (Export) 950 MW  
2250 MW

### SCH-NE-NYISO\_LIMIT\_800

Mon 04/29/2024 to Mon 04/29/2024  
0700 Continuous 2259  
Work scheduled by: ConEd

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 1000 MW  
REV (Export) 400 MW  
1400 MW

### SCH-NE-NYISO\_LIMIT\_600

Mon 04/29/2024 to Tue 04/30/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 800 MW  
REV (Export) 600 MW  
1400 MW

### DUNWODIE\_345KV\_8

Tue 04/30/2024 to Tue 04/30/2024  
0001 Continuous 2200  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 3800 MW  
REV (Export) 800 MW  
4600 MW

### LADENTWN-LOVETT\_\_\_345\_Y66

Tue 04/30/2024 to Sun 05/19/2024  
0201 Continuous 2359  
Work scheduled by: ConEd

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 7695 MW  
REV (Export) 355 MW  
8050 MW

### LOVETT\_-BUCHAN\_S\_345\_Y88

Tue 04/30/2024 to Sun 05/19/2024  
0201 Continuous 2359  
Work scheduled by: ConEd

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 7695 MW  
REV (Export) 355 MW  
8050 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, April 22, 2024 to Tuesday, October 21, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_800

Tue 04/30/2024 to Tue 04/30/2024  
0700 Continuous 2259  
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>1000 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NE-NYISO\_LIMIT\_600

Tue 04/30/2024 to Wed 05/01/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>800 MW</b>	
Impacts Total Transfer Capability	600 MW	
TTC with All Lines In Service	1400 MW	

### W49TH\_ST\_345KV\_5

Wed 05/01/2024 to Fri 05/03/2024  
0001 Continuous 0200  
Work scheduled by: ConEd

SCH - PJM_HTP	FWD (Import)	REV (Export)
	<b>300 MW</b>	
Impacts Total Transfer Capability	360 MW	
TTC with All Lines In Service	660 MW	

### W49TH\_ST\_345KV\_7

Wed 05/01/2024 to Fri 05/03/2024  
0001 Continuous 0200  
Work scheduled by: ConEd

SCH - PJM_HTP	FWD (Import)	REV (Export)
	<b>300 MW</b>	
Impacts Total Transfer Capability	360 MW	
TTC with All Lines In Service	660 MW	

### MOSES\_\_-ADIRNDCK\_230\_MA1

Wed 05/01/2024 to Mon 05/06/2024  
0600 Continuous 0700  
Work scheduled by: NYPA

MOSES SOUTH	FWD (Import)	REV (Export)
	<b>2100 MW</b>	
Impacts Total Transfer Capability	1050 MW	
TTC with All Lines In Service	3150 MW	

### SCH-NE-NYISO\_LIMIT\_800

Wed 05/01/2024 to Wed 05/01/2024  
0700 Continuous 2259  
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>1000 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, April 22, 2024 to Tuesday, October 21, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_600

Wed 05/01/2024 to Thu 05/02/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>800 MW</b>	
Impacts Total Transfer Capability	600 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NE-NYISO\_LIMIT\_800

Thu 05/02/2024 to Thu 05/02/2024  
0700 Continuous 2259  
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>1000 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NE-NYISO\_LIMIT\_600

Thu 05/02/2024 to Fri 05/03/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>800 MW</b>	
Impacts Total Transfer Capability	600 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NE-NYISO\_LIMIT\_800

Fri 05/03/2024 to Fri 05/03/2024  
0700 Continuous 2259  
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>1000 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NE-NYISO\_LIMIT\_600

Fri 05/03/2024 to Sat 05/04/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>800 MW</b>	
Impacts Total Transfer Capability	600 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NE-NYISO\_LIMIT\_800

Sat 05/04/2024 to Sat 05/04/2024  
0700 Continuous 2259  
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>1000 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, April 22, 2024 to Tuesday, October 21, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_600

Sat 05/04/2024 to Sun 05/05/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

SCH - NE - NY FWD (Import) REV (Export)  
**800 MW**  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 1400 MW

### SCH-NE-NYISO\_LIMIT\_800

Sun 05/05/2024 to Sun 05/05/2024  
0700 Continuous 2259  
Work scheduled by: ConEd

SCH - NE - NY FWD (Import) REV (Export)  
**1000 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 1400 MW

### SCH-NE-NYISO\_LIMIT\_600

Sun 05/05/2024 to Mon 05/06/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

SCH - NE - NY FWD (Import) REV (Export)  
**800 MW**  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 1400 MW

### EGRDNCTY\_345\_138\_AT1

Mon 05/06/2024 to Mon 05/06/2024  
0001 Continuous 0030  
Work scheduled by: ConEd

CONED - LIPA FWD (Import) REV (Export)  
**1250 MW**  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 1500 MW

### EGRDNCTY\_345\_138\_AT2

Mon 05/06/2024 to Mon 05/06/2024  
0001 Continuous 0030  
Work scheduled by: ConEd

CONED - LIPA FWD (Import) REV (Export)  
**1250 MW**  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 1500 MW

### SPRNBK -EGRDNCTR\_345\_Y49

Mon 05/06/2024 to Wed 05/08/2024  
0001 Continuous 2200  
Work scheduled by: ConEd

CANCELLED by TO 04/19/2024 11:32

CONED - LIPA FWD (Import) REV (Export)  
**775 MW**  
Impacts Total Transfer Capability 725 MW  
TTC with All Lines In Service 1500 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, April 22, 2024 to Tuesday, October 21, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_800

Mon 05/06/2024 to Mon 05/06/2024  
 0700 Continuous 2259  
 Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>1000 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NE-NYISO\_LIMIT\_600

Mon 05/06/2024 to Tue 05/07/2024  
 2300 Continuous 0659  
 Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>800 MW</b>	
Impacts Total Transfer Capability	600 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NE-NYISO\_LIMIT\_800

Tue 05/07/2024 to Tue 05/07/2024  
 0700 Continuous 2259  
 Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>1000 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

### PANNELL-CLAY\_345\_2

Tue 05/07/2024 to Tue 05/07/2024  
 0730 Continuous 1430  
 Work scheduled by: NGrid

WEST CENTRAL	FWD (Import)	REV (Export)
	<b>1300 MW</b>	
Impacts Total Transfer Capability	950 MW	
TTC with All Lines In Service	2250 MW	

### EGRDNCTY\_345\_138\_AT1

Tue 05/07/2024 to Tue 05/07/2024  
 2130 Continuous 2200  
 Work scheduled by: ConEd

CONED - LIPA	FWD (Import)	REV (Export)
	<b>1250 MW</b>	
Impacts Total Transfer Capability	250 MW	
TTC with All Lines In Service	1500 MW	

### EGRDNCTY\_345\_138\_AT2

Tue 05/07/2024 to Tue 05/07/2024  
 2130 Continuous 2200  
 Work scheduled by: ConEd

CONED - LIPA	FWD (Import)	REV (Export)
	<b>1250 MW</b>	
Impacts Total Transfer Capability	250 MW	
TTC with All Lines In Service	1500 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, April 22, 2024 to Tuesday, October 21, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_600

Tue 05/07/2024 to Wed 05/08/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>800 MW</b>	
Impacts Total Transfer Capability	600 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NE-NYISO\_LIMIT\_800

Wed 05/08/2024 to Wed 05/08/2024  
0700 Continuous 2259  
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>1000 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

### CLAY\_\_-INDPDNCE\_345\_26

Wed 05/08/2024 to Wed 05/08/2024  
0730 Continuous 1430  
Work scheduled by: NGrid

OSWEGO EXPORT	FWD (Import)	REV (Export)
	<b>5000 MW</b>	
Impacts Total Transfer Capability	250 MW	
TTC with All Lines In Service	5250 MW	

### SCH-NE-NYISO\_LIMIT\_600

Wed 05/08/2024 to Thu 05/09/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>800 MW</b>	
Impacts Total Transfer Capability	600 MW	
TTC with All Lines In Service	1400 MW	

### E13THSTA-FARRAGUT\_345\_45

Thu 05/09/2024 to Thu 05/09/2024  
0301 Continuous 0331  
Work scheduled by: ConEd

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

### SCH-NE-NYISO\_LIMIT\_800

Thu 05/09/2024 to Thu 05/09/2024  
0700 Continuous 2259  
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>1000 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, April 22, 2024 to Tuesday, October 21, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### PANNELL-CLAY\_\_\_345\_1

Thu 05/09/2024 to Thu 05/09/2024  
0730 Continuous 1430

Work scheduled by: NGrid

WEST CENTRAL  
Impacts Total Transfer Capability 1300 MW  
TTC with All Lines In Service 950 MW  
2250 MW

FWD (Import) REV (Export)

### SCH-NE-NYISO\_LIMIT\_600

Thu 05/09/2024 to Fri 05/10/2024  
2300 Continuous 0659

Work scheduled by: ConEd

SCH - NE - NY  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 600 MW  
1400 MW

FWD (Import) REV (Export)

### SCH-NE-NYISO\_LIMIT\_800

Fri 05/10/2024 to Fri 05/10/2024  
0700 Continuous 2259

Work scheduled by: ConEd

SCH - NE - NY  
Impacts Total Transfer Capability 1000 MW  
TTC with All Lines In Service 400 MW  
1400 MW

FWD (Import) REV (Export)

### BERKSHIR-ALPS\_\_\_345\_393

Fri 05/10/2024 to Fri 05/10/2024  
1430 Continuous 1500

Work scheduled by: NGrid

UPDATED by ISONE 04/02/2024 13:47

ARR: 78

SCH - NPX\_1385  
Impacts Total Transfer Capability 100 MW  
TTC with All Lines In Service 100 MW  
200 MW  
100 MW  
200 MW

FWD (Import) REV (Export)

### BERKSHIR-ALPS\_\_\_345\_393

Fri 05/10/2024 to Fri 05/10/2024  
1430 Continuous 1500

Work scheduled by: NGrid

UPDATED by ISONE 04/02/2024 13:47

ARR: 78

SCH - NE - NY  
Impacts Total Transfer Capability 900 MW  
TTC with All Lines In Service 500 MW  
1400 MW

FWD (Import) REV (Export)

### BERKSHIR-ALPS\_\_\_345\_393 , BERKSHIR-NORTHFLD\_345\_312

Fri 05/10/2024 to Fri 05/10/2024  
1430 1500

Work scheduled by:

ARR: 78

SCH - NE - NY  
Impacts Total Transfer Capability 900 MW  
TTC with All Lines In Service 500 MW  
1400 MW

FWD (Import) REV (Export)

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, April 22, 2024 to Tuesday, October 21, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_600

Fri 05/10/2024 to Sat 05/11/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) **800 MW**  
600 MW  
1400 MW

### SCH-NE-NYISO\_LIMIT\_800

Sat 05/11/2024 to Sat 05/11/2024  
0700 Continuous 2259  
Work scheduled by: ConEd

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) **1000 MW**  
400 MW  
1400 MW

### SCH-NE-NYISO\_LIMIT\_600

Sat 05/11/2024 to Sun 05/12/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) **800 MW**  
600 MW  
1400 MW

### SPRNBK\_-TREMONT\_345\_X28

Sun 05/12/2024 to Sun 05/12/2024  
0001 Continuous 0500  
Work scheduled by: ConEd

CANCELLED by TO 04/19/2024 11:34

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) **4200 MW**  
400 MW  
4600 MW

### SCH-NE-NYISO\_LIMIT\_800

Sun 05/12/2024 to Sun 05/12/2024  
0700 Continuous 2259  
Work scheduled by: ConEd

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) **1000 MW**  
400 MW  
1400 MW

### SCH-NE-NYISO\_LIMIT\_600

Sun 05/12/2024 to Mon 05/13/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) **800 MW**  
600 MW  
1400 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, April 22, 2024 to Tuesday, October 21, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### NIAGARA\_ROBNSNRD\_230\_64

Mon 05/13/2024 to Fri 05/17/2024  
0500 Continuous 1900  
Work scheduled by: NYPA

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 1500 MW  
REV (Export) 150 MW  
1650 MW

### NEPTUNE\_DUFFYAVE\_345\_NEPTUNE

Mon 05/13/2024 to Fri 05/17/2024  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 0 MW  
REV (Export) 660 MW  
660 MW

### NEWBRDGE\_345\_138\_BK\_1

Mon 05/13/2024 to Fri 05/17/2024  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 375 MW  
REV (Export) 285 MW  
660 MW

### NEWBRDGE\_345\_138\_BK\_2

Mon 05/13/2024 to Fri 05/17/2024  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 375 MW  
REV (Export) 285 MW  
660 MW

### NEWBRDGE-DUFFYAVE\_345\_501

Mon 05/13/2024 to Fri 05/17/2024  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 0 MW  
REV (Export) 660 MW  
660 MW

### SCH-NE-NYISO\_LIMIT\_800

Mon 05/13/2024 to Mon 05/13/2024  
0700 Continuous 2259  
Work scheduled by: ConEd

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 1000 MW  
REV (Export) 400 MW  
1400 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, April 22, 2024 to Tuesday, October 21, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_600

Mon 05/13/2024 to Tue 05/14/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - NE - NY	<b>800 MW</b>	
Impacts Total Transfer Capability	600 MW	
TTC with All Lines In Service	1400 MW	

### E13THSTA-FARRAGUT\_345\_45

Tue 05/14/2024 to Tue 05/14/2024  
0130 Continuous 0200  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

### SCH-NE-NYISO\_LIMIT\_800

Tue 05/14/2024 to Tue 05/14/2024  
0700 Continuous 2259  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - NE - NY	<b>1000 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

### VOLNEY\_-CLAY\_345\_6

Tue 05/14/2024 to Tue 05/14/2024  
0730 Continuous 1430  
Work scheduled by: NGrid

	FWD (Import)	REV (Export)
OSWEGO EXPORT	<b>5250 MW</b>	
Impacts Total Transfer Capability	0 MW	
TTC with All Lines In Service	5250 MW	

### SCH-NE-NYISO\_LIMIT\_600

Tue 05/14/2024 to Wed 05/15/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - NE - NY	<b>800 MW</b>	
Impacts Total Transfer Capability	600 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NE-NYISO\_LIMIT\_800

Wed 05/15/2024 to Wed 05/15/2024  
0700 Continuous 2259  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - NE - NY	<b>1000 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, April 22, 2024 to Tuesday, October 21, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### CLAY\_\_-EDIC\_\_345\_2-15

Wed 05/15/2024 to Wed 05/15/2024  
0730 Continuous 1430  
Work scheduled by: NGrid

OSWEGO EXPORT FWD (Import) REV (Export)  
**4850 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

### SCH-NE-NYISO\_LIMIT\_600

Wed 05/15/2024 to Thu 05/16/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

SCH - NE - NY FWD (Import) REV (Export)  
**800 MW**  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 1400 MW

### GOETHALS\_345KV\_5

Thu 05/16/2024 to Thu 05/16/2024  
0001 Continuous 0030  
Work scheduled by: ConEd

CANCELLED by TO 04/18/2024 10:15

STATEN ISLAND FWD (Import) REV (Export)  
Impacts Total Transfer Capability  
TTC with All Lines In Service

### HUDSONP\_-FARRAGUT\_345\_B3402 , LINDEN\_-GOETHALS\_230\_A2253

Thu 05/16/2024 to Sat 05/18/2024  
0001 0300  
Work scheduled by:

SCH - PJ - NY FWD (Import) REV (Export)  
**2200 MW**  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 2250 MW

### LINDEN\_-GOETHALS\_230\_A2253

Thu 05/16/2024 to Sat 05/18/2024  
0001 Continuous 0300  
Work scheduled by: ConEd

CANCELLED by TO 04/18/2024 10:15

SCH - PJ - NY FWD (Import) REV (Export)  
Impacts Total Transfer Capability  
TTC with All Lines In Service

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, April 22, 2024 to Tuesday, October 21, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MARION\_-FARRAGUT\_345\_C3403 , HUDSONP\_-FARRAGUT\_345\_B3402 , LINDEN\_-GOETHALS\_230\_A2253

Thu 05/16/2024 to Sat 05/18/2024  
0001 0300

Work scheduled by:

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**2200 MW**

50 MW

2250 MW

### MARION\_-FARRAGUT\_345\_C3403 , LINDEN\_-GOETHALS\_230\_A2253

Thu 05/16/2024 to Sat 05/18/2024  
0001 0300

Work scheduled by:

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**2200 MW**

50 MW

2250 MW

### SCH-NE-NYISO\_LIMIT\_800

Thu 05/16/2024 to Thu 05/16/2024  
0700 Continuous 2259

Work scheduled by: ConEd

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**1000 MW**

400 MW

1400 MW

### NINEMILE-CLAY\_\_\_345\_8

Thu 05/16/2024 to Thu 05/16/2024  
0730 Continuous 1430

Work scheduled by: NGrid

OSWEGO EXPORT

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**5150 MW**

100 MW

5250 MW

### SCH-NE-NYISO\_LIMIT\_600

Thu 05/16/2024 to Fri 05/17/2024  
2300 Continuous 0659

Work scheduled by: ConEd

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**800 MW**

600 MW

1400 MW

### BUCHAN\_S-MILLWOOD\_345\_W97

Fri 05/17/2024 to Sat 05/18/2024  
0001 Continuous 0200

Work scheduled by: ConEd

UPNY CONED

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**8015 MW**

35 MW

8050 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, April 22, 2024 to Tuesday, October 21, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### NRTH1385-NOR HBR\_138\_601

Fri 05/17/2024 to Sun 05/19/2024  
0700 Continuous 1500  
Work scheduled by: LI

	FWD (Import)	REV (Export)
SCH - NPX_1385	100 MW	100 MW
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

### NRTH1385-NOR HBR\_138\_602

Fri 05/17/2024 to Sun 05/19/2024  
0700 Continuous 1500  
Work scheduled by: LI

	FWD (Import)	REV (Export)
SCH - NPX_1385	100 MW	100 MW
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

### NRTH1385-NOR HBR\_138\_603

Fri 05/17/2024 to Sun 05/19/2024  
0700 Continuous 1500  
Work scheduled by: LI

	FWD (Import)	REV (Export)
SCH - NPX_1385	100 MW	100 MW
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

### NRTH1385-NORHBR\_138\_601 , NRTH1385-NORHBR\_138\_602

Fri 05/17/2024 to Sun 05/19/2024  
0700 1500  
Work scheduled by:

	FWD (Import)	REV (Export)
SCH - NPX_1385	0 MW	0 MW
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

### NRTH1385-NORHBR\_138\_601 , NRTH1385-NORHBR\_138\_603

Fri 05/17/2024 to Sun 05/19/2024  
0700 1500  
Work scheduled by:

	FWD (Import)	REV (Export)
SCH - NPX_1385	0 MW	0 MW
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

### NRTH1385-NORHBR\_138\_602 , NRTH1385-NORHBR\_138\_603

Fri 05/17/2024 to Sun 05/19/2024  
0700 1500  
Work scheduled by:

	FWD (Import)	REV (Export)
SCH - NPX_1385	0 MW	0 MW
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, April 22, 2024 to Tuesday, October 21, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### NRTH1385-NRTHPORT\_138\_NNC

Fri 05/17/2024 to Sun 05/19/2024  
0700 Continuous 1500

SCH - NPX\_1385

FWD (Import)

REV (Export)

0 MW

0 MW

Impacts Total Transfer Capability

200 MW

200 MW

TTC with All Lines In Service

200 MW

200 MW

### SCH-NE-NYISO\_LIMIT\_800

Fri 05/17/2024 to Fri 05/17/2024  
0700 Continuous 2200

SCH - NE - NY

FWD (Import)

REV (Export)

1000 MW

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

1400 MW

### GOETHALS\_345KV\_5

Sat 05/18/2024 to Sat 05/18/2024  
0230 Continuous 0300

CANCELLED by TO 04/18/2024 10:15

STATEN ISLAND

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

TTC with All Lines In Service

### KNICRBKR-PLSNTVLY\_345\_Y57

Sat 05/18/2024 to Sun 05/26/2024  
2300 Continuous 0100

ARR: 78

UPNY CONED

FWD (Import)

REV (Export)

7885 MW

Impacts Total Transfer Capability

165 MW

TTC with All Lines In Service

8050 MW

### FITZPTRK-EDIC\_\_\_345\_FE-1

Mon 05/20/2024 to Thu 05/23/2024  
0700 Continuous 1730

OSWEGO EXPORT

FWD (Import)

REV (Export)

4800 MW

Impacts Total Transfer Capability

450 MW

TTC with All Lines In Service

5250 MW

### FITZPTRK-EDIC\_\_\_345\_FE-1

Mon 05/20/2024 to Thu 05/23/2024  
0700 Continuous 1730

CENTRAL EAST - VC

FWD (Import)

REV (Export)

3520 MW

Impacts Total Transfer Capability

205 MW

TTC with All Lines In Service

3725 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, April 22, 2024 to Tuesday, October 21, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### GOETHALS\_345KV\_5

FWD (Import) REV (Export)

Tue 05/21/2024 to Tue 05/21/2024  
0001 Continuous 0030

UPDATED by ConEd 04/18/2024 10:18

STATEN ISLAND

Impacts Total Transfer Capability

Work scheduled by: ConEd

TTC with All Lines In Service

### HUDSONP\_-FARRAGUT\_345\_B3402 , LINDEN\_-GOETHALS\_230\_A2253

FWD (Import) REV (Export)

Tue 05/21/2024 to Sat 05/25/2024  
0001 0300

SCH - PJ - NY

**2200 MW**

Impacts Total Transfer Capability

50 MW

Work scheduled by:

TTC with All Lines In Service

2250 MW

### LINDEN\_-GOETHALS\_230\_A2253

FWD (Import) REV (Export)

Tue 05/21/2024 to Sat 05/25/2024  
0001 Continuous 0300

UPDATED by ConEd 04/18/2024 10:18

SCH - PJ - NY

Impacts Total Transfer Capability

Work scheduled by: ConEd

TTC with All Lines In Service

### MARION\_-FARRAGUT\_345\_C3403 , HUDSONP\_-FARRAGUT\_345\_B3402 , LINDEN\_-GOETHALS\_230\_A2253

FWD (Import) REV (Export)

Tue 05/21/2024 to Sat 05/25/2024  
0001 0300

SCH - PJ - NY

**2200 MW**

Impacts Total Transfer Capability

50 MW

Work scheduled by:

TTC with All Lines In Service

2250 MW

### MARION\_-FARRAGUT\_345\_C3403 , LINDEN\_-GOETHALS\_230\_A2253

FWD (Import) REV (Export)

Tue 05/21/2024 to Sat 05/25/2024  
0001 0300

SCH - PJ - NY

**2200 MW**

Impacts Total Transfer Capability

50 MW

Work scheduled by:

TTC with All Lines In Service

2250 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, April 22, 2024 to Tuesday, October 21, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### GOETHALS\_345KV\_5

Sat 05/25/2024 to Sat 05/25/2024  
0230 Continuous 0300

UPDATED by ConEd 04/18/2024 10:18

STATEN ISLAND

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

TTC with All Lines In Service

### FITZPTRK-EDIC\_345\_FE-1

Tue 05/28/2024 to Fri 05/31/2024  
0700 Continuous 1530

OSWEGO EXPORT

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

TTC with All Lines In Service

**4800 MW**

450 MW

5250 MW

### FITZPTRK-EDIC\_345\_FE-1

Tue 05/28/2024 to Fri 05/31/2024  
0700 Continuous 1530

CENTRAL EAST - VC

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

TTC with All Lines In Service

**3520 MW**

205 MW

3725 MW

### LEEDS\_345\_LEEDS SVC

Tue 05/28/2024 to Tue 05/28/2024  
0830 Continuous 1630

CENTRAL EAST - VC

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

TTC with All Lines In Service

**3675 MW**

50 MW

3725 MW

### CHATGUAY-MASSENA\_765\_7040

Wed 05/29/2024 to Sat 06/01/2024  
1800 Continuous 0500

UPDATED by NYPA 02/02/2024 10:05

SCH - HQ - NY

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

TTC with All Lines In Service

**0 MW**

1500 MW

1500 MW

**0 MW**

1000 MW

1000 MW

### CHATGUAY-MASSENA\_765\_7040

Wed 05/29/2024 to Sat 06/01/2024  
1800 Continuous 0500

UPDATED by NYPA 02/02/2024 10:05

MOSES SOUTH

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

TTC with All Lines In Service

**1550 MW**

1600 MW

3150 MW

Work scheduled by: NYPA



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, April 22, 2024 to Tuesday, October 21, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MARCY\_\_\_765\_345\_AT1

Wed 05/29/2024 to Sat 06/01/2024  
1800 Continuous 0500  
Work scheduled by: NYPA

UPDATED by NYPA 02/02/2024 10:05

ARR: 19

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1750 MW**  
1400 MW  
3150 MW

### MARCY\_\_\_765\_345\_AT2

Wed 05/29/2024 to Sat 06/01/2024  
1800 Continuous 0500  
Work scheduled by: NYPA

UPDATED by NYPA 02/02/2024 10:05

ARR: 19

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1700 MW**  
1450 MW  
3150 MW

### MASSENA\_-MARCY\_\_\_765\_MSU1

Wed 05/29/2024 to Sat 06/01/2024  
1800 Continuous 0500  
Work scheduled by: NYPA

UPDATED by NYPA 02/02/2024 10:05

SCH - HQ\_CEDARS  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**90 MW**  
180 MW  
270 MW

### MASSENA\_-MARCY\_\_\_765\_MSU1

Wed 05/29/2024 to Sat 06/01/2024  
1800 Continuous 0500  
Work scheduled by: NYPA

UPDATED by NYPA 02/02/2024 10:05

SCH - HQ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**475 MW** **1000 MW**  
1025 MW 0 MW  
1500 MW 1000 MW

### MASSENA\_-MARCY\_\_\_765\_MSU1

Wed 05/29/2024 to Sat 06/01/2024  
1800 Continuous 0500  
Work scheduled by: NYPA

UPDATED by NYPA 02/02/2024 10:05

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**500 MW**  
2650 MW  
3150 MW

### MASSENA\_-MARCY\_\_\_765\_MSU1

Wed 05/29/2024 to Sat 06/01/2024  
1800 Continuous 0500  
Work scheduled by: NYPA

UPDATED by NYPA 02/02/2024 10:05

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**2595 MW**  
1130 MW  
3725 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, April 22, 2024 to Tuesday, October 21, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MASSENA\_MARCY\_\_765\_MSU1 , CHATGUAY-MASSENA\_765\_7040

Wed 05/29/2024 to Sat 06/01/2024  
1800 0500

Work scheduled by:

MOSES SOUTH **500 MW**  
Impacts Total Transfer Capability 2650 MW  
TTC with All Lines In Service 3150 MW

### MOSES\_-MASSENA\_230\_MMS2 , MOSES\_-MASSENA\_230\_MMS1

Wed 05/29/2024 to Sat 06/01/2024  
1800 0500

Work scheduled by:

SCH - HQ\_CEDARS **90 MW**  
Impacts Total Transfer Capability 180 MW  
TTC with All Lines In Service 270 MW

### MOSES\_-MASSENA\_230\_MMS2 , MOSES\_-MASSENA\_230\_MMS1

Wed 05/29/2024 to Sat 06/01/2024  
1800 0500

Work scheduled by:

SCH - HQ - NY **850 MW** **0 MW**  
Impacts Total Transfer Capability 650 MW 1000 MW  
TTC with All Lines In Service 1500 MW 1000 MW

### BECK\_-PACKARD\_230\_BP76

Fri 05/31/2024 to Fri 05/31/2024  
0730 Continuous 1630

Work scheduled by: NGrid

SCH - OH - NY **1600 MW** **1050 MW**  
Impacts Total Transfer Capability 450 MW 600 MW  
TTC with All Lines In Service 2050 MW 1650 MW

### CHASLAKE-PORTER\_\_230\_11

Sat 06/01/2024 to Wed 07/03/2024  
0530 Continuous 1600

Work scheduled by: NGrid

MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

### CRICKVLY-PLSNTVLY\_345\_F84

Mon 06/03/2024 to Tue 06/04/2024  
0001 Continuous 2200

Work scheduled by: ConEd

SCH - NE - NY **600 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 1400 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, April 22, 2024 to Tuesday, October 21, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### CRICKVLY-PLSNTVLY\_345\_F84

Mon 06/03/2024 to Tue 06/04/2024  
0001 Continuous 2200  
Work scheduled by: ConEd

SCH - NPX\_1385  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
100 MW	100 MW
100 MW	100 MW
200 MW	200 MW

### WATRCURE-OAKDALE\_345\_31

Mon 06/03/2024 to Fri 06/07/2024  
0700 Continuous 1430  
Work scheduled by: NYSEG

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
2050 MW	
200 MW	
2250 MW	

### DUNWODIE\_345KV\_3

Sat 06/08/2024 to Mon 06/10/2024  
0001 Continuous 0200  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
3800 MW	
800 MW	
4600 MW	

### DUNWODIE\_345KV\_4

Sat 06/08/2024 to Mon 06/10/2024  
0001 Continuous 0200  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
3800 MW	
800 MW	
4600 MW	

### NIAGARA\_345\_230\_AT4

Tue 06/11/2024 to Wed 06/12/2024  
0500 Continuous 1900  
Work scheduled by: NYPA

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
	1200 MW
	450 MW
	1650 MW

### CHASLAKE-PORTER\_230\_11

Mon 07/08/2024 to Fri 08/30/2024  
0700 Continuous 1900  
Work scheduled by: NGrid

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
2100 MW	
1050 MW	
3150 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, April 22, 2024 to Tuesday, October 21, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### ROSETON\_EFISHKIL\_345\_RFK305

Sat 07/20/2024 to Sun 07/21/2024  
0700 Continuous 1600  
Work scheduled by: CHGE

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 7215 MW  
REV (Export) 835 MW  
8050 MW

### LEEDS\_345\_LEEDS SVC

Mon 07/22/2024 to Thu 07/25/2024  
0730 Continuous 1600  
Work scheduled by: NGrid

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 3675 MW  
REV (Export) 50 MW  
3725 MW

### FRASER\_345\_FRASER SVC

Mon 07/29/2024 to Fri 08/02/2024  
0800 Continuous 1400  
Work scheduled by: NYSEG

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 3655 MW  
REV (Export) 70 MW  
3725 MW

### EDIC\_-GORDONRD\_345\_14

Mon 08/19/2024 to Fri 08/30/2024  
0630 Continuous 1800  
Work scheduled by: NGrid

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 2770 MW  
REV (Export) 955 MW  
3725 MW

### EDIC\_-PRINCTWN\_345\_351

Mon 08/19/2024 to Sat 08/24/2024  
0700 Continuous 1700  
Work scheduled by: NGrid  
UPDATED by NGrid 02/02/2024 14:41

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 3335 MW  
REV (Export) 390 MW  
3725 MW

### MARCY\_-EDIC\_345\_UE1-7

Sun 08/25/2024 to Fri 08/30/2024  
0800 Continuous 1600  
Work scheduled by: NGrid

ARR: 16 & 19

OSWEGO EXPORT  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 5250 MW  
REV (Export) 0 MW  
5250 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, April 22, 2024 to Tuesday, October 21, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### CHASLAKE-PORTER\_\_230\_11

Tue 09/03/2024 to Fri 11/15/2024  
0530 Continuous 2000  
Work scheduled by: NGrid

	FWD (Import)	REV (Export)
MOSES SOUTH	<b>2100 MW</b>	
Impacts Total Transfer Capability	1050 MW	
TTC with All Lines In Service	3150 MW	

### EDIC\_\_GORDONRD\_345\_14

Tue 09/03/2024 to Mon 10/14/2024  
0600 Continuous 1800  
Work scheduled by: NGrid

	FWD (Import)	REV (Export)
CENTRAL EAST - VC	<b>2770 MW</b>	
Impacts Total Transfer Capability	955 MW	
TTC with All Lines In Service	3725 MW	

### FITZPTRK-EDIC\_\_345\_FE-1

Mon 09/09/2024 to Mon 09/09/2024  
0001 Continuous 0100  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
OSWEGO EXPORT	<b>4800 MW</b>	
Impacts Total Transfer Capability	450 MW	
TTC with All Lines In Service	5250 MW	

### FITZPTRK-EDIC\_\_345\_FE-1

Mon 09/09/2024 to Mon 09/09/2024  
0001 Continuous 0100  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
CENTRAL EAST - VC	<b>3520 MW</b>	
Impacts Total Transfer Capability	205 MW	
TTC with All Lines In Service	3725 MW	

### EDIC\_\_PRINCTWN\_345\_351

Mon 09/09/2024 to Wed 09/11/2024  
0700 Continuous 1700  
Work scheduled by: NGrid

	FWD (Import)	REV (Export)
CENTRAL EAST - VC	<b>3335 MW</b>	
Impacts Total Transfer Capability	390 MW	
TTC with All Lines In Service	3725 MW	

### ROCHESTR-PANNELL\_345\_RP1

Mon 09/09/2024 to Fri 09/13/2024  
0700 Continuous 1530  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
DYSINGER EAST	<b>2300 MW</b>	
Impacts Total Transfer Capability	900 MW	
TTC with All Lines In Service	3200 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, April 22, 2024 to Tuesday, October 21, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MARCY\_\_-EDIC\_\_345\_UE1-7

Thu 09/12/2024 to Sat 09/14/2024

0700 Continuous 1700

Work scheduled by: NGrid

ARR: 16 & 19

OSWEGO EXPORT

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**5250 MW**

0 MW

5250 MW

### MOTTHAVN-RAINEY\_\_345\_Q11

Sun 09/15/2024 to Sat 10/26/2024

0001 Continuous 0300

Work scheduled by: ConEd

SPR/DUN-SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**3800 MW**

800 MW

4600 MW

### W49TH\_ST\_345KV\_6

Sun 09/15/2024 to Fri 09/27/2024

0001 Continuous 0100

Work scheduled by: ConEd

SCH - PJM\_HTP

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**300 MW**

360 MW

660 MW

### W49TH\_ST\_345KV\_8

Sun 09/15/2024 to Fri 09/27/2024

0001 Continuous 0100

Work scheduled by: ConEd

SCH - PJM\_HTP

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**450 MW**

210 MW

660 MW

### DYSINGER-STA\_255\_345\_DH2

Mon 09/16/2024 to Mon 10/28/2024

0500 Continuous 1900

Work scheduled by: NYPA

DYSINGER EAST

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**2850 MW**

350 MW

3200 MW

### ROCHESTR-PANNELL\_345\_RP2

Mon 09/16/2024 to Fri 09/20/2024

0700 Continuous 1530

Work scheduled by: NYPA

DYSINGER EAST

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**2300 MW**

900 MW

3200 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, April 22, 2024 to Tuesday, October 21, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### STLAWRNC-MOSES\_\_\_230\_L34P

Mon 09/16/2024 to Fri 09/20/2024  
0700 Continuous 1530  
Work scheduled by: NYPA

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### PANNELL\_-CLAY\_\_\_345\_1

Mon 09/23/2024 to Fri 09/27/2024  
0700 Continuous 1530  
Work scheduled by: NYPA

WEST CENTRAL  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1300 MW**  
950 MW  
2250 MW

### STLAWRNC-MOSES\_\_\_230\_L34P

Mon 09/23/2024 to Fri 09/27/2024  
0700 Continuous 1530  
Work scheduled by: NYPA

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### FITZPTRK-EDIC\_\_\_345\_FE-1

Thu 09/26/2024 to Thu 09/26/2024  
0900 Continuous 1000  
Work scheduled by: NYPA

OSWEGO EXPORT  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**4800 MW**  
450 MW  
5250 MW

### FITZPTRK-EDIC\_\_\_345\_FE-1

Thu 09/26/2024 to Thu 09/26/2024  
0900 Continuous 1000  
Work scheduled by: NYPA

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3520 MW**  
205 MW  
3725 MW

### W49TH\_ST-E13THSTA\_345\_M55

Fri 09/27/2024 to Tue 11/19/2024  
0001 Continuous 0200  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3800 MW**  
800 MW  
4600 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, April 22, 2024 to Tuesday, October 21, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### W49TH\_ST\_345KV\_6

Fri 09/27/2024 to Tue 11/19/2024

0101 Continuous 0200

Work scheduled by: ConEd

SCH - PJM\_HTP

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**300 MW**

360 MW

660 MW

### STLAWRNC-MOSES\_230\_L34P

Mon 09/30/2024 to Fri 10/04/2024

0700 Continuous 1530

Work scheduled by: NYPA

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**300 MW**

360 MW

660 MW

### FITZPTRK-EDIC\_345\_FE-1

Mon 09/30/2024 to Fri 10/04/2024

1700 Continuous 1530

Work scheduled by: NYPA

OSWEGO EXPORT

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**4800 MW**

450 MW

5250 MW

### FITZPTRK-EDIC\_345\_FE-1

Mon 09/30/2024 to Fri 10/04/2024

1700 Continuous 1530

Work scheduled by: NYPA

CENTRAL EAST - VC

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**3520 MW**

205 MW

3725 MW

### BECK\_-NIAGARA\_345\_PA302

Mon 10/07/2024 to Fri 10/11/2024

0500 Continuous 1900

Work scheduled by: NYPA

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**1000 MW**

1050 MW

2050 MW

**850 MW**

800 MW

1650 MW

### NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE

Mon 10/07/2024 to Fri 10/11/2024

0600 Continuous 1600

Work scheduled by: LI

SCH - PJM\_NEPTUNE

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**0 MW**

660 MW

660 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, April 22, 2024 to Tuesday, October 21, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### NEWBRDGE\_345\_138\_BK\_1

Mon 10/07/2024 to Fri 10/11/2024  
0600 Continuous 1600

Work scheduled by: LI

SCH - PJM\_NEPTUNE

FWD (Import)

REV (Export)

**375 MW**

Impacts Total Transfer Capability

285 MW

TTC with All Lines In Service

660 MW

### NEWBRDGE\_345\_138\_BK\_2

Mon 10/07/2024 to Fri 10/11/2024  
0600 Continuous 1600

Work scheduled by: LI

SCH - PJM\_NEPTUNE

FWD (Import)

REV (Export)

**375 MW**

Impacts Total Transfer Capability

285 MW

TTC with All Lines In Service

660 MW

### NEWBRDGE-DUFFYAVE\_345\_501

Mon 10/07/2024 to Fri 10/11/2024  
0600 Continuous 1600

Work scheduled by: LI

SCH - PJM\_NEPTUNE

FWD (Import)

REV (Export)

**0 MW**

Impacts Total Transfer Capability

660 MW

TTC with All Lines In Service

660 MW

### SHOR\_NPX-SHOREHAM\_138\_CSC

Mon 10/07/2024 to Fri 10/11/2024  
0600 Continuous 1800

Work scheduled by: LI

SCH - NPX\_CSC

FWD (Import)

REV (Export)

**0 MW**

**0 MW**

Impacts Total Transfer Capability

330 MW

330 MW

TTC with All Lines In Service

330 MW

330 MW

### MARCY\_\_FRASANNX\_345\_UCC2-41

Wed 10/09/2024 to Thu 10/10/2024  
0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC

FWD (Import)

REV (Export)

**3225 MW**

Impacts Total Transfer Capability

500 MW

TTC with All Lines In Service

3725 MW

### MARCY\_\_N.SCTLND\_345\_18

Tue 10/15/2024 to Thu 10/17/2024  
0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC

FWD (Import)

REV (Export)

**2665 MW**

Impacts Total Transfer Capability

1060 MW

TTC with All Lines In Service

3725 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, April 22, 2024 to Tuesday, October 21, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MARCY\_\_N.SCTLND\_345\_18

Mon 10/21/2024 to Fri 10/25/2024  
0700 Continuous 1530

ARR: 19

Work scheduled by: NYPA

CENTRAL EAST - VC **2665 MW**  
Impacts Total Transfer Capability 1060 MW  
TTC with All Lines In Service 3725 MW

FWD (Import) REV (Export)

### MARCY\_\_345KV\_CSC

Mon 10/28/2024 to Sun 11/10/2024  
0700 Continuous 1530

Work scheduled by: NYPA

CENTRAL EAST - VC **3650 MW**  
Impacts Total Transfer Capability 75 MW  
TTC with All Lines In Service 3725 MW

FWD (Import) REV (Export)

### DYSINGER-STA\_255\_345\_DH2

Tue 10/29/2024 to Thu 10/31/2024  
0500 Continuous 2100

Work scheduled by: NYPA

DYSINGER EAST **2850 MW**  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 3200 MW

FWD (Import) REV (Export)

### DYSINGER-STA\_255\_345\_DH1

Mon 11/04/2024 to Sat 11/16/2024  
0500 Continuous 1900

Work scheduled by: NYPA

DYSINGER EAST **2850 MW**  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 3200 MW

FWD (Import) REV (Export)

### LINDN\_CG-LNDVFT\_\_345\_V-3022

Tue 11/12/2024 to Tue 11/12/2024  
0800 Continuous 2359

Work scheduled by: PJM

SCH - PJM\_VFT **0 MW** **0 MW**  
Impacts Total Transfer Capability 315 MW 315 MW  
TTC with All Lines In Service 315 MW 315 MW

FWD (Import) REV (Export)

### BECK\_\_-NIAGARA\_230\_PA27

Fri 11/15/2024 to Fri 11/15/2024  
0500 Continuous 1900

Work scheduled by: NYPA

SCH - OH - NY **2100 MW**  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 2450 MW

FWD (Import) REV (Export)

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, April 22, 2024 to Tuesday, October 21, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### OSWEGO\_\_VOLNEY\_\_345\_12

Fri 11/15/2024 to Fri 12/13/2024  
0730 Continuous 1600  
Work scheduled by: NGrid

OSWEGO EXPORT FWD (Import) REV (Export)  
5250 MW  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

### CHATGUAY-MASSENA\_\_765\_7040

Sat 11/16/2024 to Fri 11/29/2024  
0001 Continuous 2359  
Work scheduled by: NYPA

SCH - HQ - NY FWD (Import) REV (Export)  
0 MW 0 MW  
Impacts Total Transfer Capability 1500 MW 1000 MW  
TTC with All Lines In Service 1500 MW 1000 MW

### CHATGUAY-MASSENA\_\_765\_7040

Sat 11/16/2024 to Fri 11/29/2024  
0001 Continuous 2359  
Work scheduled by: NYPA

MOSES SOUTH FWD (Import) REV (Export)  
1550 MW  
Impacts Total Transfer Capability 1600 MW  
TTC with All Lines In Service 3150 MW

### MARCY\_\_765\_345\_AT1

Sat 11/16/2024 to Fri 11/29/2024  
0001 Continuous 2359  
Work scheduled by: NYPA

ARR: 19

MOSES SOUTH FWD (Import) REV (Export)  
1750 MW  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 3150 MW

### MARCY\_\_765\_345\_AT2

Sat 11/16/2024 to Fri 11/29/2024  
0001 Continuous 2359  
Work scheduled by: NYPA

ARR: 19

MOSES SOUTH FWD (Import) REV (Export)  
1700 MW  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

### MASSENA-MARCY\_\_765\_MSU1

Sat 11/16/2024 to Fri 11/29/2024  
0001 Continuous 2359  
Work scheduled by: NYPA

SCH - HQ\_CEDARS FWD (Import) REV (Export)  
90 MW  
Impacts Total Transfer Capability 189 MW  
TTC with All Lines In Service 279 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, April 22, 2024 to Tuesday, October 21, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MASSENA\_-MARCY\_\_\_765\_MSU1

Sat 11/16/2024 to Fri 11/29/2024  
0001 Continuous 2359  
Work scheduled by: NYPA

SCH - HQ - NY	FWD (Import)	REV (Export)
	<b>475 MW</b>	<b>1000 MW</b>
Impacts Total Transfer Capability	1025 MW	0 MW
TTC with All Lines In Service	1500 MW	1000 MW

### MASSENA\_-MARCY\_\_\_765\_MSU1

Sat 11/16/2024 to Fri 11/29/2024  
0001 Continuous 2359  
Work scheduled by: NYPA

MOSES SOUTH	FWD (Import)	REV (Export)
	<b>500 MW</b>	
Impacts Total Transfer Capability	2650 MW	
TTC with All Lines In Service	3150 MW	

### MASSENA\_-MARCY\_\_\_765\_MSU1

Sat 11/16/2024 to Fri 11/29/2024  
0001 Continuous 2359  
Work scheduled by: NYPA

CENTRAL EAST - VC	FWD (Import)	REV (Export)
	<b>2595 MW</b>	
Impacts Total Transfer Capability	1130 MW	
TTC with All Lines In Service	3725 MW	

### MASSENA\_-MARCY\_\_\_765\_MSU1 , CHATGUAY-MASSENA\_765\_7040

Sat 11/16/2024 to Fri 11/29/2024  
0001 2359  
Work scheduled by:

MOSES SOUTH	FWD (Import)	REV (Export)
	<b>500 MW</b>	
Impacts Total Transfer Capability	2650 MW	
TTC with All Lines In Service	3150 MW	

### MOSES\_-MASSENA\_230\_MMS2 , MOSES\_-MASSENA\_230\_MMS1

Sat 11/16/2024 to Fri 11/29/2024  
0001 2359  
Work scheduled by:

SCH - HQ_CEDARS	FWD (Import)	REV (Export)
	<b>90 MW</b>	
Impacts Total Transfer Capability	189 MW	
TTC with All Lines In Service	279 MW	

### MOSES\_-MASSENA\_230\_MMS2 , MOSES\_-MASSENA\_230\_MMS1

Sat 11/16/2024 to Fri 11/29/2024  
0001 2359  
Work scheduled by:

SCH - HQ - NY	FWD (Import)	REV (Export)
	<b>850 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	650 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, April 22, 2024 to Tuesday, October 21, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### LINDN\_CG-LNDVFT\_\_345\_V-3022

Fri 11/22/2024 to Fri 11/22/2024  
1500 Continuous 1800

Work scheduled by: PJM

SCH - PJM\_VFT

FWD (Import)

REV (Export)

0 MW

0 MW

Impacts Total Transfer Capability

315 MW

315 MW

TTC with All Lines In Service

315 MW

315 MW

### ADIRNDCK-PORTER\_\_230\_12

Sun 12/01/2024 to Tue 12/24/2024  
0530 Continuous 1700

Work scheduled by: NGrid

MOSES SOUTH

FWD (Import)

REV (Export)

2300 MW

Impacts Total Transfer Capability

850 MW

TTC with All Lines In Service

3150 MW

### E13THSTA-FARRAGUT\_345\_46

Wed 12/18/2024 to Fri 12/20/2024  
0201 Continuous 0300

Work scheduled by: ConEd

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

3800 MW

Impacts Total Transfer Capability

800 MW

TTC with All Lines In Service

4600 MW

### ADIRNDCK-PORTER\_\_230\_12

Thu 01/02/2025 to Sat 05/31/2025  
0530 Continuous 1700

Work scheduled by: NGrid

MOSES SOUTH

FWD (Import)

REV (Export)

2300 MW

Impacts Total Transfer Capability

850 MW

TTC with All Lines In Service

3150 MW

### OSWEGO\_\_VOLNEY\_\_345\_11

Mon 01/06/2025 to Fri 01/24/2025  
0700 Continuous 1700

Work scheduled by: NGrid

OSWEGO EXPORT

FWD (Import)

REV (Export)

5250 MW

Impacts Total Transfer Capability

0 MW

TTC with All Lines In Service

5250 MW

### E13THSTA-FARRAGUT\_345\_46

Fri 01/10/2025 to Wed 01/15/2025  
0001 Continuous 0300

Work scheduled by: ConEd

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

3800 MW

Impacts Total Transfer Capability

800 MW

TTC with All Lines In Service

4600 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, April 22, 2024 to Tuesday, October 21, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### OSWEGO\_-ELBRIDGE\_345\_17

Mon 01/27/2025 to Fri 02/14/2025  
0630 Continuous 1730  
Work scheduled by: NGrid

ARR: 75

OSWEGO EXPORT  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**5250 MW**  
0 MW  
5250 MW

### ELBRIDGE-LAFAYTTE\_345\_17-LE

Wed 02/12/2025 to Fri 02/14/2025  
0700 Continuous 1730  
Work scheduled by: NGrid

ARR: 75

OSWEGO EXPORT  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**5250 MW**  
0 MW  
5250 MW

### GOETHALS\_345KV\_5

Mon 09/08/2025 to Mon 09/08/2025  
0301 Continuous 0330  
Work scheduled by: ConEd

STATEN ISLAND  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### GOETHALS\_345KV\_5

Tue 09/09/2025 to Tue 09/09/2025  
2330 Continuous 2359  
Work scheduled by: ConEd

STATEN ISLAND  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### GOETHALS\_345KV\_5

Mon 09/15/2025 to Mon 09/15/2025  
0230 Continuous 0300  
Work scheduled by: ConEd

STATEN ISLAND  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### GOETHALS\_345KV\_5

Mon 09/15/2025 to Mon 09/15/2025  
0301 Continuous 0330  
Work scheduled by: ConEd

STATEN ISLAND  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, April 22, 2024 to Tuesday, October 21, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### ADIRNDCK-PORTER\_\_230\_12

Mon 09/15/2025 to Sun 10/12/2025  
0600 Continuous 1700  
Work scheduled by: NGrid

	FWD (Import)	REV (Export)
MOSES SOUTH	<b>2100 MW</b>	
Impacts Total Transfer Capability	1050 MW	
TTC with All Lines In Service	3150 MW	

### GOETHALS\_345KV\_5

Tue 09/16/2025 to Tue 09/16/2025  
2330 Continuous 2359  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
STATEN ISLAND		
Impacts Total Transfer Capability		
TTC with All Lines In Service		

### GOETHALS\_345KV\_5

Fri 09/26/2025 to Fri 09/26/2025  
0230 Continuous 0300  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
STATEN ISLAND		
Impacts Total Transfer Capability		
TTC with All Lines In Service		

### BECK\_\_-NIAGARA\_230\_PA27

Mon 09/29/2025 to Wed 11/26/2025  
0500 Continuous 1900  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - OH - NY	<b>1900 MW</b>	<b>1650 MW</b>
Impacts Total Transfer Capability	150 MW	0 MW
TTC with All Lines In Service	2050 MW	1650 MW