

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, April 24, 2024 to Thursday, October 23, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### HUDSONP\_-FARRAGUT\_345\_B3402

Mon 01/15/2018 to Tue 12/31/2024  
0001 Continuous 2359  
Work scheduled by: ConEd

EXT FORCED by ConEd 03/11/2024 11:26

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### MARION\_-FARRAGUT\_345\_C3403

Mon 01/15/2018 to Tue 12/31/2024  
0001 Continuous 2359  
Work scheduled by: ConEd

EXT FORCED by ConEd 03/11/2024 11:26

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### MARION\_-FARRAGUT\_345\_C3403 , HUDSONP\_-FARRAGUT\_345\_B3402

Mon 01/15/2018 to Tue 12/31/2024  
0001 2359  
Work scheduled by:

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**2400 MW** **2400 MW**  
150 MW 250 MW  
2550 MW 2650 MW

### SCH-IMO-NYISO\_LIMIT\_1900

Wed 11/01/2023 to Tue 04/30/2024  
0001 Continuous 2359  
Work scheduled by: IESO

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**2200 MW**  
250 MW  
2450 MW

### ADIRNDCK-PORTER\_\_230\_12

Tue 01/02/2024 to Wed 05/29/2024  
0630 Continuous 1730  
Work scheduled by: NGrid

UPDATED by NGrid 07/11/2023 11:44

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**2300 MW**  
850 MW  
3150 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, April 24, 2024 to Thursday, October 23, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-IMO-NYISO\_LIMIT\_1750

Tue 01/02/2024 to Wed 05/29/2024  
0630 Continuous 1730  
Work scheduled by: NGrid

UPDATED by NGrid 07/11/2023 11:44

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**2050 MW**

400 MW

2450 MW

### SPRNBK\_-W49TH\_ST\_345\_M51

Tue 01/30/2024 to Wed 05/15/2024  
0202 Continuous 2359  
Work scheduled by: ConEd

EXT FORCED by ConEd 04/08/2024 15:10

SPR/DUN-SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**3200 MW**

1400 MW

4600 MW

### SHORE\_RD\_345\_138\_BK 1

Mon 02/12/2024 to Fri 05/03/2024  
0001 Continuous 2359  
Work scheduled by: LI

UPDATED by LI 02/07/2024 12:08

CONED - LIPA

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**1350 MW**

150 MW

1500 MW

### BECK\_-PACKARD\_230\_BP76

Mon 03/04/2024 to Fri 05/24/2024  
0500 Continuous 1600  
Work scheduled by: NGrid

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**1800 MW**

**1350 MW**

650 MW

550 MW

2450 MW

1900 MW

### SCH-IMO-NYISO\_LIMIT\_1300

Mon 03/04/2024 to Mon 05/20/2024  
0500 Continuous 0800  
Work scheduled by: NGrid

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**1600 MW**

850 MW

2450 MW

### SCH-HQ\_CEDARS-NYISO\_LIMIT\_240

Mon 03/11/2024 to Thu 10/03/2024  
0800 Continuous 1500  
Work scheduled by: HQ

EXTENDED by HQ 04/23/2024 09:40

SCH - HQ\_CEDARS

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**240 MW**

39 MW

279 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, April 24, 2024 to Thursday, October 23, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NYISO-HQ\_CEDARS\_LIMIT\_0

Mon 03/11/2024 to Thu 10/03/2024  
0800 Continuous 1500

EXTENDED by HQ 04/23/2024 09:40

SCH - HQ\_CEDARS

FWD (Import)

REV (Export)

**0 MW**

Impacts Total Transfer Capability

100 MW

TTC with All Lines In Service

100 MW

Work scheduled by: HQ

### RAMAPO\_\_BUCHAN\_N\_345\_Y94

Tue 04/02/2024 to Tue 04/30/2024  
0201 Continuous 0200

UPNY CONED

FWD (Import)

REV (Export)

**7755 MW**

Impacts Total Transfer Capability

295 MW

TTC with All Lines In Service

8050 MW

Work scheduled by: ConEd

### MOTTHAVN-RAINEY\_\_345\_Q12

Thu 04/04/2024 to Thu 04/25/2024  
0001 Continuous 0200

EXTENDED by ConEd 04/03/2024 10:26

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

**3800 MW**

Impacts Total Transfer Capability

800 MW

TTC with All Lines In Service

4600 MW

Work scheduled by: ConEd

### FRASER\_\_345\_FRASER SVC

Sat 04/06/2024 to Fri 04/26/2024  
1758 Continuous 2359

EXT FORCED by NYSEG 04/11/2024 14:44

CENTRAL EAST - VC

FWD (Import)

REV (Export)

**3655 MW**

Impacts Total Transfer Capability

70 MW

TTC with All Lines In Service

3725 MW

Work scheduled by: NYSEG

### BERKSHIR-NORTHFLD\_345\_312

Tue 04/09/2024 to Fri 05/10/2024  
0600 Continuous 1500

UPDATED by ISONE 04/02/2024 13:47

SCH - NPX\_1385

FWD (Import)

REV (Export)

**100 MW**

**100 MW**

Impacts Total Transfer Capability

100 MW

100 MW

TTC with All Lines In Service

200 MW

200 MW

Work scheduled by: NGrid

### BERKSHIR-NORTHFLD\_345\_312

Tue 04/09/2024 to Fri 05/10/2024  
0600 Continuous 1500

UPDATED by ISONE 04/02/2024 13:47

SCH - NE - NY

FWD (Import)

REV (Export)

**1300 MW**

Impacts Total Transfer Capability

100 MW

TTC with All Lines In Service

1400 MW

Work scheduled by: NGrid

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, April 24, 2024 to Thursday, October 23, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_700

Tue 04/09/2024 to Fri 05/10/2024  
0600 Continuous 1500  
Work scheduled by: NGrid

UPDATED by ISONE 04/02/2024 13:47

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**900 MW**  
500 MW  
1400 MW

### SCH-NYISO-NE\_LIMIT\_900

Tue 04/09/2024 to Fri 05/10/2024  
0600 Continuous 2359  
Work scheduled by: NGrid

UPDATED by ISONE 04/02/2024 13:47

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1100 MW**  
700 MW  
1800 MW

### SCH-NPX\_1385-NYISO\_LIMIT\_100

Mon 04/15/2024 to Fri 04/26/2024  
0600 Continuous 2200  
Work scheduled by: ISONE

UPDATED by ISONE 04/09/2024 13:34

SCH - NPX\_1385  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**100 MW**  
100 MW  
200 MW

### DUNWODIE\_345KV\_4

Tue 04/16/2024 to Mon 04/29/2024  
1045 Continuous 2359  
Work scheduled by: ConEd

FORCED by ConEd 04/16/2024 14:42

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3800 MW**  
800 MW  
4600 MW

### PANNELL-CLAY\_345\_1

Mon 04/22/2024 to Fri 04/26/2024  
0700 Continuous 1530  
Work scheduled by: NYPA

WEST CENTRAL  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1300 MW**  
950 MW  
2250 MW

### ELBRIDGE-LAFAYTTE\_345\_17-LE

Mon 04/22/2024 to Fri 04/26/2024  
0800 Continuous 1630  
Work scheduled by: NGrid

UPDATED by NGrid 04/16/2024 13:38

ARR: 75

OSWEGO EXPORT  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**5250 MW**  
0 MW  
5250 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, April 24, 2024 to Thursday, October 23, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### OSWEGO\_-ELBRIDGE\_345\_17

Tue 04/23/2024 to Sat 04/27/2024  
0730 Continuous 1630

ARR: 75

Work scheduled by: NGrid

OSWEGO EXPORT

FWD (Import)

REV (Export)

**5250 MW**

Impacts Total Transfer Capability

0 MW

TTC with All Lines In Service

5250 MW

### SCH-NE-NYISO\_LIMIT\_600

Tue 04/23/2024 to Wed 04/24/2024  
2300 Continuous 0659

Work scheduled by: ConEd

SCH - NE - NY

FWD (Import)

REV (Export)

**800 MW**

Impacts Total Transfer Capability

600 MW

TTC with All Lines In Service

1400 MW

### SCH-NE-NYISO\_LIMIT\_800

Wed 04/24/2024 to Wed 04/24/2024  
0700 Continuous 2259

Work scheduled by: ConEd

SCH - NE - NY

FWD (Import)

REV (Export)

**1000 MW**

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

1400 MW

### DUNWODIE-SHORE\_RD\_345\_Y50

Wed 04/24/2024 to Sat 04/27/2024  
1529 Continuous 1900

Work scheduled by: ConEd

CONED - LIPA

FWD (Import)

REV (Export)

**800 MW**

Impacts Total Transfer Capability

700 MW

TTC with All Lines In Service

1500 MW

### SHORE\_RD\_345\_138\_BK 2

Wed 04/24/2024 to Sat 04/27/2024  
1529 Continuous 1900

Work scheduled by: ConEd

CONED - LIPA

FWD (Import)

REV (Export)

**1350 MW**

Impacts Total Transfer Capability

150 MW

TTC with All Lines In Service

1500 MW

### SCH-NE-NYISO\_LIMIT\_600

Wed 04/24/2024 to Thu 04/25/2024  
2300 Continuous 0659

Work scheduled by: ConEd

SCH - NE - NY

FWD (Import)

REV (Export)

**800 MW**

Impacts Total Transfer Capability

600 MW

TTC with All Lines In Service

1400 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, April 24, 2024 to Thursday, October 23, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_800

Thu 04/25/2024 to Thu 04/25/2024  
 0700 Continuous 2259  
 Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - NE - NY	<b>1000 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NE-NYISO\_LIMIT\_600

Thu 04/25/2024 to Fri 04/26/2024  
 2300 Continuous 0659  
 Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - NE - NY	<b>800 MW</b>	
Impacts Total Transfer Capability	600 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NE-NYISO\_LIMIT\_800

Fri 04/26/2024 to Fri 04/26/2024  
 0700 Continuous 2259  
 Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - NE - NY	<b>1000 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NE-NYISO\_LIMIT\_600

Fri 04/26/2024 to Sat 04/27/2024  
 2300 Continuous 0659  
 Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - NE - NY	<b>800 MW</b>	
Impacts Total Transfer Capability	600 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NE-NYISO\_LIMIT\_800

Sat 04/27/2024 to Sat 04/27/2024  
 0700 Continuous 2259  
 Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - NE - NY	<b>1000 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NE-NYISO\_LIMIT\_600

Sat 04/27/2024 to Sun 04/28/2024  
 2300 Continuous 0659  
 Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - NE - NY	<b>800 MW</b>	
Impacts Total Transfer Capability	600 MW	
TTC with All Lines In Service	1400 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, April 24, 2024 to Thursday, October 23, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### CHAT\_DC\_GC2

Sun 04/28/2024 to Thu 05/23/2024  
0600 Continuous 1900  
Work scheduled by: HQ

FWD (Import) REV (Export)  
MOSES SOUTH **2850 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

### CHAT\_DC\_GC2

Sun 04/28/2024 to Thu 05/23/2024  
0600 Continuous 1900  
Work scheduled by: HQ

FWD (Import) REV (Export)  
SCH - HQ - NY **500 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1000 MW

### SCH-NE-NYISO\_LIMIT\_800

Sun 04/28/2024 to Sun 04/28/2024  
0700 Continuous 2259  
Work scheduled by: ConEd

FWD (Import) REV (Export)  
SCH - NE - NY **1000 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 1400 MW

### SCH-NE-NYISO\_LIMIT\_600

Sun 04/28/2024 to Mon 04/29/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

FWD (Import) REV (Export)  
SCH - NE - NY **800 MW**  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 1400 MW

### SHOR\_NPX-SHOREHAM\_138\_CSC

Mon 04/29/2024 to Sat 05/04/2024  
0600 Continuous 1800  
Work scheduled by: LI

FWD (Import) REV (Export)  
SCH - NPX\_CSC **0 MW** **0 MW**  
Impacts Total Transfer Capability 330 MW 330 MW  
TTC with All Lines In Service 330 MW 330 MW

### MARCY\_\_FRASANNX\_345\_UCC2-41

Mon 04/29/2024 to Fri 05/24/2024  
0700 Continuous 1730  
Work scheduled by: NYPA

UPDATED by NYPA 04/16/2024 10:08

ARR: 19

FWD (Import) REV (Export)  
CENTRAL EAST - VC **3225 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 3725 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, April 24, 2024 to Thursday, October 23, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### PANNELL\_-CLAY\_\_\_345\_2

Mon 04/29/2024 to Fri 05/03/2024  
0700 Continuous 1530

Work scheduled by: NYPA

WEST CENTRAL FWD (Import) REV (Export)  
**1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

### SCH-HQ-NYISO\_LIMIT\_1400

Mon 04/29/2024 to Thu 05/23/2024  
0700 Continuous 1900

Work scheduled by: HQ

SCH - HQ - NY FWD (Import) REV (Export)  
**1400 MW**  
Impacts Total Transfer Capability 100 MW  
TTC with All Lines In Service 1500 MW

### SCH-NE-NYISO\_LIMIT\_800

Mon 04/29/2024 to Mon 04/29/2024  
0700 Continuous 2259

Work scheduled by: ConEd

SCH - NE - NY FWD (Import) REV (Export)  
**1000 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 1400 MW

### SCH-NE-NYISO\_LIMIT\_600

Mon 04/29/2024 to Tue 04/30/2024  
2300 Continuous 0659

Work scheduled by: ConEd

SCH - NE - NY FWD (Import) REV (Export)  
**800 MW**  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 1400 MW

### DUNWODIE\_345KV\_8

Tue 04/30/2024 to Tue 04/30/2024  
0001 Continuous 2200

Work scheduled by: ConEd

SPR/DUN-SOUTH FWD (Import) REV (Export)  
**3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

### LADENTWN-LOVETT\_\_\_345\_Y66

Tue 04/30/2024 to Sun 05/19/2024  
0201 Continuous 2359

Work scheduled by: ConEd

UPNY CONED FWD (Import) REV (Export)  
**7695 MW**  
Impacts Total Transfer Capability 355 MW  
TTC with All Lines In Service 8050 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, April 24, 2024 to Thursday, October 23, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### LOVETT\_-BUCHAN\_S\_345\_Y88

Tue 04/30/2024 to Sun 05/19/2024  
0201 Continuous 2359  
Work scheduled by: ConEd

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **7695 MW**  
REV (Export)  
355 MW  
8050 MW

### SCH-NE-NYISO\_LIMIT\_800

Tue 04/30/2024 to Tue 04/30/2024  
0700 Continuous 2259  
Work scheduled by: ConEd

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **1000 MW**  
REV (Export)  
400 MW  
1400 MW

### SCH-NE-NYISO\_LIMIT\_600

Tue 04/30/2024 to Wed 05/01/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **800 MW**  
REV (Export)  
600 MW  
1400 MW

### W49TH\_ST\_345KV\_5

Wed 05/01/2024 to Fri 05/03/2024  
0001 Continuous 0200  
Work scheduled by: ConEd

SCH - PJM\_HTP  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **300 MW**  
REV (Export)  
360 MW  
660 MW

### W49TH\_ST\_345KV\_7

Wed 05/01/2024 to Fri 05/03/2024  
0001 Continuous 0200  
Work scheduled by: ConEd

SCH - PJM\_HTP  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **300 MW**  
REV (Export)  
360 MW  
660 MW

### MOSES\_-ADIRNDCK\_230\_MA1

Wed 05/01/2024 to Mon 05/06/2024  
0600 Continuous 0700  
Work scheduled by: NYPA

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **2100 MW**  
REV (Export)  
1050 MW  
3150 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, April 24, 2024 to Thursday, October 23, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_800

Wed 05/01/2024 to Wed 05/01/2024  
0700 Continuous 2259  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - NE - NY	<b>1000 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NE-NYISO\_LIMIT\_600

Wed 05/01/2024 to Thu 05/02/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - NE - NY	<b>800 MW</b>	
Impacts Total Transfer Capability	600 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NE-NYISO\_LIMIT\_800

Thu 05/02/2024 to Thu 05/02/2024  
0700 Continuous 2259  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - NE - NY	<b>1000 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NE-NYISO\_LIMIT\_600

Thu 05/02/2024 to Fri 05/03/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - NE - NY	<b>800 MW</b>	
Impacts Total Transfer Capability	600 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NE-NYISO\_LIMIT\_800

Fri 05/03/2024 to Fri 05/03/2024  
0700 Continuous 2259  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - NE - NY	<b>1000 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NE-NYISO\_LIMIT\_600

Fri 05/03/2024 to Sat 05/04/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - NE - NY	<b>800 MW</b>	
Impacts Total Transfer Capability	600 MW	
TTC with All Lines In Service	1400 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, April 24, 2024 to Thursday, October 23, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_800

Sat 05/04/2024 to Sat 05/04/2024  
0700 Continuous 2259  
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>1000 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NE-NYISO\_LIMIT\_600

Sat 05/04/2024 to Sun 05/05/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>800 MW</b>	
Impacts Total Transfer Capability	600 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NE-NYISO\_LIMIT\_800

Sun 05/05/2024 to Sun 05/05/2024  
0700 Continuous 2259  
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>1000 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NE-NYISO\_LIMIT\_600

Sun 05/05/2024 to Mon 05/06/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>800 MW</b>	
Impacts Total Transfer Capability	600 MW	
TTC with All Lines In Service	1400 MW	

### EGRDNCTY\_345\_138\_AT1

Mon 05/06/2024 to Mon 05/06/2024  
0001 Continuous 0030  
Work scheduled by: ConEd

CONED - LIPA	FWD (Import)	REV (Export)
	<b>1250 MW</b>	
Impacts Total Transfer Capability	250 MW	
TTC with All Lines In Service	1500 MW	

### EGRDNCTY\_345\_138\_AT2

Mon 05/06/2024 to Mon 05/06/2024  
0001 Continuous 0030  
Work scheduled by: ConEd

CONED - LIPA	FWD (Import)	REV (Export)
	<b>1250 MW</b>	
Impacts Total Transfer Capability	250 MW	
TTC with All Lines In Service	1500 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, April 24, 2024 to Thursday, October 23, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_800

Mon 05/06/2024 to Mon 05/06/2024  
0700 Continuous 2259  
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>1000 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NE-NYISO\_LIMIT\_600

Mon 05/06/2024 to Tue 05/07/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>800 MW</b>	
Impacts Total Transfer Capability	600 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NE-NYISO\_LIMIT\_800

Tue 05/07/2024 to Tue 05/07/2024  
0700 Continuous 2259  
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>1000 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

### PANNELL-CLAY\_345\_2

Tue 05/07/2024 to Tue 05/07/2024  
0730 Continuous 1430  
Work scheduled by: NGrid

WEST CENTRAL	FWD (Import)	REV (Export)
	<b>1300 MW</b>	
Impacts Total Transfer Capability	950 MW	
TTC with All Lines In Service	2250 MW	

### EGRDNCTY\_345\_138\_AT1

Tue 05/07/2024 to Tue 05/07/2024  
2130 Continuous 2200  
Work scheduled by: ConEd

CONED - LIPA	FWD (Import)	REV (Export)
	<b>1250 MW</b>	
Impacts Total Transfer Capability	250 MW	
TTC with All Lines In Service	1500 MW	

### EGRDNCTY\_345\_138\_AT2

Tue 05/07/2024 to Tue 05/07/2024  
2130 Continuous 2200  
Work scheduled by: ConEd

CONED - LIPA	FWD (Import)	REV (Export)
	<b>1250 MW</b>	
Impacts Total Transfer Capability	250 MW	
TTC with All Lines In Service	1500 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, April 24, 2024 to Thursday, October 23, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_600

Tue 05/07/2024 to Wed 05/08/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

SCH - NE - NY FWD (Import) REV (Export)  
**800 MW**  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 1400 MW

### SCH-NE-NYISO\_LIMIT\_800

Wed 05/08/2024 to Wed 05/08/2024  
0700 Continuous 2259  
Work scheduled by: ConEd

SCH - NE - NY FWD (Import) REV (Export)  
**1000 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 1400 MW

### CLAY\_\_-INDPDNCE\_345\_26

Wed 05/08/2024 to Wed 05/08/2024  
0730 Continuous 1430  
Work scheduled by: NGrid

OSWEGO EXPORT FWD (Import) REV (Export)  
**5000 MW**  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 5250 MW

### SCH-NE-NYISO\_LIMIT\_600

Wed 05/08/2024 to Thu 05/09/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

SCH - NE - NY FWD (Import) REV (Export)  
**800 MW**  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 1400 MW

### E13THSTA-FARRAGUT\_345\_45

Thu 05/09/2024 to Thu 05/09/2024  
0301 Continuous 0331  
Work scheduled by: ConEd

CANCELLED by TO 04/23/2024 07:33

SPR/DUN-SOUTH FWD (Import) REV (Export)  
**3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

### SCH-NE-NYISO\_LIMIT\_800

Thu 05/09/2024 to Thu 05/09/2024  
0700 Continuous 2259  
Work scheduled by: ConEd

SCH - NE - NY FWD (Import) REV (Export)  
**1000 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 1400 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, April 24, 2024 to Thursday, October 23, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### PANNELL-CLAY\_\_\_345\_1

Thu 05/09/2024 to Thu 05/09/2024  
0730 Continuous 1430

Work scheduled by: NGrid

WEST CENTRAL  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

FWD (Import) REV (Export)

### SCH-NE-NYISO\_LIMIT\_600

Thu 05/09/2024 to Fri 05/10/2024  
2300 Continuous 0659

Work scheduled by: ConEd

SCH - NE - NY  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 1400 MW

FWD (Import) REV (Export)

### SCH-NE-NYISO\_LIMIT\_800

Fri 05/10/2024 to Fri 05/10/2024  
0700 Continuous 2259

Work scheduled by: ConEd

SCH - NE - NY  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 1400 MW

FWD (Import) REV (Export)

### BERKSHIR-ALPS\_\_\_345\_393

Fri 05/10/2024 to Fri 05/10/2024  
1430 Continuous 1500

Work scheduled by: NGrid

UPDATED by ISONE 04/02/2024 13:47

ARR: 78

SCH - NPX\_1385  
Impacts Total Transfer Capability 100 MW 100 MW  
TTC with All Lines In Service 200 MW 200 MW

FWD (Import) REV (Export)

### BERKSHIR-ALPS\_\_\_345\_393

Fri 05/10/2024 to Fri 05/10/2024  
1430 Continuous 1500

Work scheduled by: NGrid

UPDATED by ISONE 04/02/2024 13:47

ARR: 78

SCH - NE - NY  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1400 MW

FWD (Import) REV (Export)

### BERKSHIR-ALPS\_\_\_345\_393 , BERKSHIR-NORTHFLD\_345\_312

Fri 05/10/2024 to Fri 05/10/2024  
1430 Continuous 1500

Work scheduled by:

ARR: 78

SCH - NE - NY  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1400 MW

FWD (Import) REV (Export)

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, April 24, 2024 to Thursday, October 23, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_600

Fri 05/10/2024 to Sat 05/11/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>800 MW</b>	
Impacts Total Transfer Capability	600 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NE-NYISO\_LIMIT\_800

Sat 05/11/2024 to Sat 05/11/2024  
0700 Continuous 2259  
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>1000 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NE-NYISO\_LIMIT\_600

Sat 05/11/2024 to Sun 05/12/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>800 MW</b>	
Impacts Total Transfer Capability	600 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NE-NYISO\_LIMIT\_800

Sun 05/12/2024 to Sun 05/12/2024  
0700 Continuous 2259  
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>1000 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NE-NYISO\_LIMIT\_600

Sun 05/12/2024 to Mon 05/13/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>800 MW</b>	
Impacts Total Transfer Capability	600 MW	
TTC with All Lines In Service	1400 MW	

### NIAGARA\_ROBNSNRD\_230\_64

Mon 05/13/2024 to Fri 05/17/2024  
0500 Continuous 1900  
Work scheduled by: NYPA

SCH - OH - NY	FWD (Import)	REV (Export)
		<b>1500 MW</b>
Impacts Total Transfer Capability		150 MW
TTC with All Lines In Service		1650 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, April 24, 2024 to Thursday, October 23, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### NEPTUNE\_DUFFYAVE\_345\_NEPTUNE

Mon 05/13/2024 to Fri 05/17/2024  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM_NEPTUNE	FWD (Import)	REV (Export)
	<b>0 MW</b>	
Impacts Total Transfer Capability	660 MW	
TTC with All Lines In Service	660 MW	

### NEWBRDGE\_345\_138\_BK\_1

Mon 05/13/2024 to Fri 05/17/2024  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM_NEPTUNE	FWD (Import)	REV (Export)
	<b>375 MW</b>	
Impacts Total Transfer Capability	285 MW	
TTC with All Lines In Service	660 MW	

### NEWBRDGE\_345\_138\_BK\_2

Mon 05/13/2024 to Fri 05/17/2024  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM_NEPTUNE	FWD (Import)	REV (Export)
	<b>375 MW</b>	
Impacts Total Transfer Capability	285 MW	
TTC with All Lines In Service	660 MW	

### NEWBRDGE-DUFFYAVE\_345\_501

Mon 05/13/2024 to Fri 05/17/2024  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM_NEPTUNE	FWD (Import)	REV (Export)
	<b>0 MW</b>	
Impacts Total Transfer Capability	660 MW	
TTC with All Lines In Service	660 MW	

### SCH-NE-NYISO\_LIMIT\_800

Mon 05/13/2024 to Mon 05/13/2024  
0700 Continuous 2259  
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>1000 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NE-NYISO\_LIMIT\_600

Mon 05/13/2024 to Tue 05/14/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>800 MW</b>	
Impacts Total Transfer Capability	600 MW	
TTC with All Lines In Service	1400 MW	



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, April 24, 2024 to Thursday, October 23, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### E13THSTA-FARRAGUT\_345\_45

Tue 05/14/2024 to Tue 05/14/2024  
0130 Continuous 0200

CANCELLED by TO 04/23/2024 07:33

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

**3800 MW**

Impacts Total Transfer Capability

800 MW

TTC with All Lines In Service

4600 MW

Work scheduled by: ConEd

### SCH-NE-NYISO\_LIMIT\_800

Tue 05/14/2024 to Tue 05/14/2024  
0700 Continuous 2259

SCH - NE - NY

FWD (Import)

REV (Export)

**1000 MW**

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

1400 MW

Work scheduled by: ConEd

### VOLNEY\_-CLAY\_\_\_345\_6

Tue 05/14/2024 to Tue 05/14/2024  
0730 Continuous 1430

OSWEGO EXPORT

FWD (Import)

REV (Export)

**5250 MW**

Impacts Total Transfer Capability

0 MW

TTC with All Lines In Service

5250 MW

Work scheduled by: NGrid

### SCH-NE-NYISO\_LIMIT\_600

Tue 05/14/2024 to Wed 05/15/2024  
2300 Continuous 0659

SCH - NE - NY

FWD (Import)

REV (Export)

**800 MW**

Impacts Total Transfer Capability

600 MW

TTC with All Lines In Service

1400 MW

Work scheduled by: ConEd

### SCH-NE-NYISO\_LIMIT\_800

Wed 05/15/2024 to Wed 05/15/2024  
0700 Continuous 2259

SCH - NE - NY

FWD (Import)

REV (Export)

**1000 MW**

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

1400 MW

Work scheduled by: ConEd

### CLAY\_-EDIC\_\_\_345\_2-15

Wed 05/15/2024 to Wed 05/15/2024  
0730 Continuous 1430

OSWEGO EXPORT

FWD (Import)

REV (Export)

**4850 MW**

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

5250 MW

Work scheduled by: NGrid

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, April 24, 2024 to Thursday, October 23, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_600

Wed 05/15/2024 to Thu 05/16/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - NE - NY	<b>800 MW</b>	
Impacts Total Transfer Capability	600 MW	
TTC with All Lines In Service	1400 MW	

### SPRNBK\_345KV\_RN55

Wed 05/15/2024 to Wed 05/15/2024  
2330 Continuous 2359  
Work scheduled by: ConEd  
EXT FORCED by ConEd 04/08/2024 15:10

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	<b>3200 MW</b>	
Impacts Total Transfer Capability	1400 MW	
TTC with All Lines In Service	4600 MW	

### SPRNBK\_345KV\_RS3 , SPRNBK\_345KV\_RS4

Thu 05/16/2024 to Thu 05/16/2024  
0300 0330  
Work scheduled by:

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	<b>3200 MW</b>	
Impacts Total Transfer Capability	1400 MW	
TTC with All Lines In Service	4600 MW	

### SCH-NE-NYISO\_LIMIT\_800

Thu 05/16/2024 to Thu 05/16/2024  
0700 Continuous 2259  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - NE - NY	<b>1000 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

### NINEMILE-CLAY\_345\_8

Thu 05/16/2024 to Thu 05/16/2024  
0730 Continuous 1430  
Work scheduled by: NGrid

	FWD (Import)	REV (Export)
OSWEGO EXPORT	<b>5150 MW</b>	
Impacts Total Transfer Capability	100 MW	
TTC with All Lines In Service	5250 MW	

### SCH-NE-NYISO\_LIMIT\_600

Thu 05/16/2024 to Fri 05/17/2024  
2300 Continuous 0659  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - NE - NY	<b>800 MW</b>	
Impacts Total Transfer Capability	600 MW	
TTC with All Lines In Service	1400 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, April 24, 2024 to Thursday, October 23, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### BUCHAN\_S-MILLWOOD\_345\_W97

Fri 05/17/2024 to Sat 05/18/2024  
0001 Continuous 0200  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
UPNY CONED	<b>8015 MW</b>	
Impacts Total Transfer Capability	35 MW	
TTC with All Lines In Service	8050 MW	

### NRTH1385-NOR HBR\_138\_601

Fri 05/17/2024 to Sun 05/19/2024  
0700 Continuous 1500  
Work scheduled by: LI

	FWD (Import)	REV (Export)
SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

### NRTH1385-NOR HBR\_138\_602

Fri 05/17/2024 to Sun 05/19/2024  
0700 Continuous 1500  
Work scheduled by: LI

	FWD (Import)	REV (Export)
SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

### NRTH1385-NOR HBR\_138\_603

Fri 05/17/2024 to Sun 05/19/2024  
0700 Continuous 1500  
Work scheduled by: LI

	FWD (Import)	REV (Export)
SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

### NRTH1385-NORHBR\_138\_601 , NRTH1385-NORHBR\_138\_602

Fri 05/17/2024 to Sun 05/19/2024  
0700 1500  
Work scheduled by:

	FWD (Import)	REV (Export)
SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

### NRTH1385-NORHBR\_138\_601 , NRTH1385-NORHBR\_138\_603

Fri 05/17/2024 to Sun 05/19/2024  
0700 1500  
Work scheduled by:

	FWD (Import)	REV (Export)
SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, April 24, 2024 to Thursday, October 23, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>NRTH1385-NORHBR_138_602 , NRTH1385-NORHBR_138_603</b>					FWD (Import)	REV (Export)
Fri 05/17/2024	to	Sun 05/19/2024		SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
0700		1500		Impacts Total Transfer Capability	200 MW	200 MW
Work scheduled by:				TTC with All Lines In Service	200 MW	200 MW
<b>NRTH1385-NRTHPORT_138_NNC</b>					FWD (Import)	REV (Export)
Fri 05/17/2024	to	Sun 05/19/2024		SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
0700	Continuous	1500		Impacts Total Transfer Capability	200 MW	200 MW
Work scheduled by: LI				TTC with All Lines In Service	200 MW	200 MW
<b>SCH-NE-NYISO_LIMIT_800</b>					FWD (Import)	REV (Export)
Fri 05/17/2024	to	Fri 05/17/2024		SCH - NE - NY	<b>1000 MW</b>	
0700	Continuous	2200		Impacts Total Transfer Capability	400 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	1400 MW	
<b>KNICRBKR-PLSNTVLY_345_Y57</b>					FWD (Import)	REV (Export)
Sat 05/18/2024	to	Sun 05/26/2024		UPNY CONED	<b>7885 MW</b>	
2300	Continuous	0100	ARR: 78	Impacts Total Transfer Capability	165 MW	
Work scheduled by: NGrid				TTC with All Lines In Service	8050 MW	
<b>FITZPTRK-EDIC____345_FE-1</b>					FWD (Import)	REV (Export)
Mon 05/20/2024	to	Thu 05/23/2024		OSWEGO EXPORT	<b>4800 MW</b>	
0700	Continuous	1730		Impacts Total Transfer Capability	450 MW	
Work scheduled by: NYPA				TTC with All Lines In Service	5250 MW	
<b>FITZPTRK-EDIC____345_FE-1</b>					FWD (Import)	REV (Export)
Mon 05/20/2024	to	Thu 05/23/2024		CENTRAL EAST - VC	<b>3520 MW</b>	
0700	Continuous	1730		Impacts Total Transfer Capability	205 MW	
Work scheduled by: NYPA				TTC with All Lines In Service	3725 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, April 24, 2024 to Thursday, October 23, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SPRNBK\_345KV\_RS3 , SPRNBK\_345KV\_RS4

Mon 05/20/2024 to Mon 05/20/2024  
2130 2200

Work scheduled by:

SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

### GOETHALS\_345KV\_5

Tue 05/21/2024 to Tue 05/21/2024  
0001 Continuous 0030

Work scheduled by: ConEd

UPDATED by ConEd 04/18/2024 10:18

STATEN ISLAND  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### HUDSONP\_-FARRAGUT\_345\_B3402 , LINDEN\_-GOETHALS\_230\_A2253

Tue 05/21/2024 to Sat 05/25/2024  
0001 0300

Work scheduled by:

SCH - PJ - NY **2200 MW**  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 2250 MW

FWD (Import) REV (Export)

### LINDEN\_-GOETHALS\_230\_A2253

Tue 05/21/2024 to Sat 05/25/2024  
0001 Continuous 0300

Work scheduled by: ConEd

UPDATED by ConEd 04/18/2024 10:18

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### MARION\_-FARRAGUT\_345\_C3403 , HUDSONP\_-FARRAGUT\_345\_B3402 , LINDEN\_-GOETHALS\_230\_A2253

Tue 05/21/2024 to Sat 05/25/2024  
0001 0300

Work scheduled by:

SCH - PJ - NY **2200 MW**  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 2250 MW

FWD (Import) REV (Export)

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, April 24, 2024 to Thursday, October 23, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MARION\_-FARRAGUT\_345\_C3403 , LINDEN\_-GOETHALS\_230\_A2253

Tue 05/21/2024 to Sat 05/25/2024  
0001 0300

SCH - PJ - NY

FWD (Import)

REV (Export)

**2200 MW**

Impacts Total Transfer Capability

50 MW

TTC with All Lines In Service

2250 MW

Work scheduled by:

### GOETHALS\_345KV\_5

Sat 05/25/2024 to Sat 05/25/2024  
0230 Continuous 0300

UPDATED by ConEd 04/18/2024 10:18

STATEN ISLAND

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: ConEd

### OSWEGO\_-VOLNEY\_\_345\_11

Mon 05/27/2024 to Sat 06/01/2024  
0700 Continuous 0800

OSWEGO EXPORT

FWD (Import)

REV (Export)

**5250 MW**

Impacts Total Transfer Capability

0 MW

TTC with All Lines In Service

5250 MW

Work scheduled by: NGrid

### FITZPTRK-EDIC\_\_345\_FE-1

Tue 05/28/2024 to Fri 05/31/2024  
0700 Continuous 1530

OSWEGO EXPORT

FWD (Import)

REV (Export)

**4800 MW**

Impacts Total Transfer Capability

450 MW

TTC with All Lines In Service

5250 MW

Work scheduled by: NYPA

### FITZPTRK-EDIC\_\_345\_FE-1

Tue 05/28/2024 to Fri 05/31/2024  
0700 Continuous 1530

CENTRAL EAST - VC

FWD (Import)

REV (Export)

**3520 MW**

Impacts Total Transfer Capability

205 MW

TTC with All Lines In Service

3725 MW

Work scheduled by: NYPA

### LEEDS\_\_345\_LEEDS SVC

Tue 05/28/2024 to Tue 05/28/2024  
0830 Continuous 1630

CENTRAL EAST - VC

FWD (Import)

REV (Export)

**3675 MW**

Impacts Total Transfer Capability

50 MW

TTC with All Lines In Service

3725 MW

Work scheduled by: NGrid

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, April 24, 2024 to Thursday, October 23, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### CHATGUAY-MASSENA\_765\_7040

Wed 05/29/2024 to Sat 06/01/2024  
1800 Continuous 0500

UPDATED by NYPA 02/02/2024 10:05

SCH - HQ - NY

FWD (Import)

REV (Export)

**0 MW**

**0 MW**

Impacts Total Transfer Capability

1500 MW

1000 MW

TTC with All Lines In Service

1500 MW

1000 MW

Work scheduled by: NYPA

### CHATGUAY-MASSENA\_765\_7040

Wed 05/29/2024 to Sat 06/01/2024  
1800 Continuous 0500

UPDATED by NYPA 02/02/2024 10:05

MOSES SOUTH

FWD (Import)

REV (Export)

**1550 MW**

Impacts Total Transfer Capability

1600 MW

TTC with All Lines In Service

3150 MW

Work scheduled by: NYPA

### MARCY\_765\_345\_AT1

Wed 05/29/2024 to Sat 06/01/2024  
1800 Continuous 0500

UPDATED by NYPA 02/02/2024 10:05

MOSES SOUTH

FWD (Import)

REV (Export)

**1750 MW**

Impacts Total Transfer Capability

1400 MW

TTC with All Lines In Service

3150 MW

Work scheduled by: NYPA

ARR: 19

### MARCY\_765\_345\_AT2

Wed 05/29/2024 to Sat 06/01/2024  
1800 Continuous 0500

UPDATED by NYPA 02/02/2024 10:05

MOSES SOUTH

FWD (Import)

REV (Export)

**1700 MW**

Impacts Total Transfer Capability

1450 MW

TTC with All Lines In Service

3150 MW

Work scheduled by: NYPA

ARR: 19

### MASSENA-MARCY\_765\_MSU1

Wed 05/29/2024 to Sat 06/01/2024  
1800 Continuous 0500

UPDATED by NYPA 02/02/2024 10:05

SCH - HQ\_CEDARS

FWD (Import)

REV (Export)

**90 MW**

Impacts Total Transfer Capability

180 MW

TTC with All Lines In Service

270 MW

Work scheduled by: NYPA

### MASSENA-MARCY\_765\_MSU1

Wed 05/29/2024 to Sat 06/01/2024  
1800 Continuous 0500

UPDATED by NYPA 02/02/2024 10:05

SCH - HQ - NY

FWD (Import)

REV (Export)

**475 MW**

**1000 MW**

Impacts Total Transfer Capability

1025 MW

0 MW

TTC with All Lines In Service

1500 MW

1000 MW

Work scheduled by: NYPA

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, April 24, 2024 to Thursday, October 23, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MASSENA_-MARCY___765_MSU1</b>						FWD (Import)	REV (Export)
Wed 05/29/2024	to	Sat 06/01/2024			MOSES SOUTH	<b>500 MW</b>	
1800	Continuous	0500	<u>UPDATED by NYPA 02/02/2024 10:05</u>		Impacts Total Transfer Capability	2650 MW	
Work scheduled by: NYPA					TTC with All Lines In Service	3150 MW	
<b>MASSENA_-MARCY___765_MSU1</b>						FWD (Import)	REV (Export)
Wed 05/29/2024	to	Sat 06/01/2024			CENTRAL EAST - VC	<b>2595 MW</b>	
1800	Continuous	0500	<u>UPDATED by NYPA 02/02/2024 10:05</u>		Impacts Total Transfer Capability	1130 MW	
Work scheduled by: NYPA					TTC with All Lines In Service	3725 MW	
<b>MASSENA_-MARCY___765_MSU1 , CHATGUAY-MASSENA_765_7040</b>						FWD (Import)	REV (Export)
Wed 05/29/2024	to	Sat 06/01/2024			MOSES SOUTH	<b>500 MW</b>	
1800		0500			Impacts Total Transfer Capability	2650 MW	
Work scheduled by:					TTC with All Lines In Service	3150 MW	
<b>MOSES_-MASSENA_230_MMS2 , MOSES_-MASSENA_230_MMS1</b>						FWD (Import)	REV (Export)
Wed 05/29/2024	to	Sat 06/01/2024			SCH - HQ_CEDARS	<b>90 MW</b>	
1800		0500			Impacts Total Transfer Capability	180 MW	
Work scheduled by:					TTC with All Lines In Service	270 MW	
<b>MOSES_-MASSENA_230_MMS2 , MOSES_-MASSENA_230_MMS1</b>						FWD (Import)	REV (Export)
Wed 05/29/2024	to	Sat 06/01/2024			SCH - HQ - NY	<b>850 MW</b>	<b>0 MW</b>
1800		0500			Impacts Total Transfer Capability	650 MW	1000 MW
Work scheduled by:					TTC with All Lines In Service	1500 MW	1000 MW
<b>BECK_-PACKARD_230_BP76</b>						FWD (Import)	REV (Export)
Fri 05/31/2024	to	Fri 05/31/2024			SCH - OH - NY	<b>1600 MW</b>	<b>1050 MW</b>
0730	Continuous	1630			Impacts Total Transfer Capability	450 MW	600 MW
Work scheduled by: NGrid					TTC with All Lines In Service	2050 MW	1650 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, April 24, 2024 to Thursday, October 23, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### CHASLAKE-PORTER\_\_230\_11

Sat 06/01/2024 to Wed 07/03/2024  
0530 Continuous 1600  
Work scheduled by: NGrid

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 2100 MW  
REV (Export) 1050 MW  
3150 MW

### CRICKVLY-PLSNTVLY\_345\_F84

Mon 06/03/2024 to Tue 06/04/2024  
0001 Continuous 2200  
Work scheduled by: ConEd

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 600 MW  
REV (Export) 800 MW  
1400 MW

### CRICKVLY-PLSNTVLY\_345\_F84

Mon 06/03/2024 to Tue 06/04/2024  
0001 Continuous 2200  
Work scheduled by: ConEd

SCH - NPX\_1385  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 100 MW  
REV (Export) 100 MW  
100 MW  
200 MW

### WOOD\_ST\_-PLSNTVLE\_345\_Y87

Mon 06/03/2024 to Tue 06/04/2024  
0301 Continuous 0259  
Work scheduled by: ConEd

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 7470 MW  
REV (Export) 580 MW  
8050 MW

### VOLNEY\_-CLAY\_\_345\_6

Mon 06/03/2024 to Sat 06/08/2024  
0700 Continuous 1700  
Work scheduled by: NGrid

OSWEGO EXPORT  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 5250 MW  
REV (Export) 0 MW  
5250 MW

### WATRCURE-OAKDALE\_\_345\_31

Mon 06/03/2024 to Fri 06/07/2024  
0700 Continuous 1430  
Work scheduled by: NYSEG

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 2050 MW  
REV (Export) 200 MW  
2250 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, April 24, 2024 to Thursday, October 23, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### KNICRBKR-ALPS\_\_\_345\_6

Wed 06/05/2024 to Tue 07/02/2024  
0730 Continuous 1630

Work scheduled by: NGrid

SCH - NE - NY

FWD (Import)

REV (Export)

**750 MW**

Impacts Total Transfer Capability

650 MW

TTC with All Lines In Service

1400 MW

### KNICRBKR-ALPS\_\_\_345\_6

Wed 06/05/2024 to Tue 07/02/2024  
0730 Continuous 1630

Work scheduled by: NGrid

SCH - NPX\_1385

FWD (Import)

REV (Export)

**100 MW**

**100 MW**

Impacts Total Transfer Capability

100 MW

100 MW

TTC with All Lines In Service

200 MW

200 MW

### DUNWODIE\_345KV\_3

Sat 06/08/2024 to Mon 06/10/2024  
0001 Continuous 0200

Work scheduled by: ConEd

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

**3800 MW**

Impacts Total Transfer Capability

800 MW

TTC with All Lines In Service

4600 MW

### DUNWODIE\_345KV\_4

Sat 06/08/2024 to Mon 06/10/2024  
0001 Continuous 0200

Work scheduled by: ConEd

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

**3800 MW**

Impacts Total Transfer Capability

800 MW

TTC with All Lines In Service

4600 MW

### OSWEGO\_-VOLNEY\_\_\_345\_12

Mon 06/10/2024 to Sat 06/15/2024  
0700 Continuous 1700

Work scheduled by: NGrid

OSWEGO EXPORT

FWD (Import)

REV (Export)

**5250 MW**

Impacts Total Transfer Capability

0 MW

TTC with All Lines In Service

5250 MW

### NIAGARA\_345\_230\_AT4

Tue 06/11/2024 to Wed 06/12/2024  
0500 Continuous 1900

Work scheduled by: NYPA

SCH - OH - NY

FWD (Import)

REV (Export)

**1200 MW**

Impacts Total Transfer Capability

450 MW

TTC with All Lines In Service

1650 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, April 24, 2024 to Thursday, October 23, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### VOLNEY\_-MARCY\_\_345\_19

Mon 06/17/2024 to Sat 06/22/2024

0730 Continuous 1700

Work scheduled by: NGrid

ARR: 19

OSWEGO EXPORT

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**4900 MW**

350 MW

5250 MW

### VOLNEY\_-MARCY\_\_345\_19

Mon 06/17/2024 to Sat 06/22/2024

0730 Continuous 1700

Work scheduled by: NGrid

ARR: 19

CENTRAL EAST - VC

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**3525 MW**

200 MW

3725 MW

### CHASLAKE-PORTER\_\_230\_11

Mon 07/08/2024 to Fri 08/30/2024

0700 Continuous 1900

Work scheduled by: NGrid

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**2100 MW**

1050 MW

3150 MW

### ROSETON\_-EFISHKIL\_345\_RFK305

Sat 07/20/2024 to Sun 07/21/2024

0700 Continuous 1600

Work scheduled by: CHGE

UPNY CONED

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**7215 MW**

835 MW

8050 MW

### LEEDS\_\_345\_LEEDS SVC

Mon 07/22/2024 to Thu 07/25/2024

0730 Continuous 1600

Work scheduled by: NGrid

CENTRAL EAST - VC

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**3675 MW**

50 MW

3725 MW

### FRASER\_\_345\_FRASER SVC

Mon 07/29/2024 to Fri 08/02/2024

0800 Continuous 1400

Work scheduled by: NYSEG

CENTRAL EAST - VC

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**3655 MW**

70 MW

3725 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, April 24, 2024 to Thursday, October 23, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>EDIC___-GORDONRD_345_14</b>					FWD (Import)	REV (Export)
Mon 08/19/2024	to	Fri 08/30/2024		CENTRAL EAST - VC	<b>2770 MW</b>	
0630	Continuous	1800		Impacts Total Transfer Capability	955 MW	
Work scheduled by: NGrid				TTC with All Lines In Service	3725 MW	
<b>EDIC___-PRINCTWN_345_351</b>					FWD (Import)	REV (Export)
Mon 08/19/2024	to	Sat 08/24/2024	<u>UPDATED by NGrid 02/02/2024 14:41</u>	CENTRAL EAST - VC	<b>3335 MW</b>	
0700	Continuous	1700		Impacts Total Transfer Capability	390 MW	
Work scheduled by: NGrid				TTC with All Lines In Service	3725 MW	
<b>MARCY___EDIC___345_UE1-7</b>					FWD (Import)	REV (Export)
Sun 08/25/2024	to	Fri 08/30/2024		OSWEGO EXPORT	<b>5250 MW</b>	
0800	Continuous	1600	ARR: 16 & 19	Impacts Total Transfer Capability	0 MW	
Work scheduled by: NGrid				TTC with All Lines In Service	5250 MW	
<b>CHASLAKE-PORTER__230_11</b>					FWD (Import)	REV (Export)
Tue 09/03/2024	to	Fri 11/15/2024		MOSES SOUTH	<b>2100 MW</b>	
0530	Continuous	2000		Impacts Total Transfer Capability	1050 MW	
Work scheduled by: NGrid				TTC with All Lines In Service	3150 MW	
<b>EDIC___-GORDONRD_345_14</b>					FWD (Import)	REV (Export)
Tue 09/03/2024	to	Mon 10/14/2024		CENTRAL EAST - VC	<b>2770 MW</b>	
0600	Continuous	1800		Impacts Total Transfer Capability	955 MW	
Work scheduled by: NGrid				TTC with All Lines In Service	3725 MW	
<b>FITZPTRK-EDIC___345_FE-1</b>					FWD (Import)	REV (Export)
Mon 09/09/2024	to	Mon 09/09/2024		OSWEGO EXPORT	<b>4800 MW</b>	
0001	Continuous	0100		Impacts Total Transfer Capability	450 MW	
Work scheduled by: NYPA				TTC with All Lines In Service	5250 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, April 24, 2024 to Thursday, October 23, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### FITZPTRK-EDIC\_\_345\_FE-1

Mon 09/09/2024 to Mon 09/09/2024  
0001 Continuous 0100  
Work scheduled by: NYPA

FWD (Import) REV (Export)  
CENTRAL EAST - VC **3520 MW**  
Impacts Total Transfer Capability 205 MW  
TTC with All Lines In Service 3725 MW

### EDIC\_\_-PRINCTWN\_345\_351

Mon 09/09/2024 to Wed 09/11/2024  
0700 Continuous 1700  
Work scheduled by: NGrid

FWD (Import) REV (Export)  
CENTRAL EAST - VC **3335 MW**  
Impacts Total Transfer Capability 390 MW  
TTC with All Lines In Service 3725 MW

### ROCHESTR-PANNELL\_345\_RP1

Mon 09/09/2024 to Fri 09/13/2024  
0700 Continuous 1530  
Work scheduled by: NYPA

FWD (Import) REV (Export)  
DYSINGER EAST **2300 MW**  
Impacts Total Transfer Capability 900 MW  
TTC with All Lines In Service 3200 MW

### MARCY\_\_-EDIC\_\_345\_UE1-7

Thu 09/12/2024 to Sat 09/14/2024  
0700 Continuous 1700  
Work scheduled by: NGrid  
ARR: 16 & 19

FWD (Import) REV (Export)  
OSWEGO EXPORT **5250 MW**  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

### MOTTHAVN-RAINEY\_\_345\_Q11

Sun 09/15/2024 to Sat 10/26/2024  
0001 Continuous 0300  
Work scheduled by: ConEd

FWD (Import) REV (Export)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

### W49TH\_ST\_345KV\_6

Sun 09/15/2024 to Fri 09/27/2024  
0001 Continuous 0100  
Work scheduled by: ConEd

FWD (Import) REV (Export)  
SCH - PJM\_HTP **300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, April 24, 2024 to Thursday, October 23, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### W49TH\_ST\_345KV\_8

Sun 09/15/2024 to Fri 09/27/2024  
0001 Continuous 0100  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - PJM_HTP	<b>450 MW</b>	
Impacts Total Transfer Capability	210 MW	
TTC with All Lines In Service	660 MW	

### DYSINGER-STA\_255\_345\_DH2

Mon 09/16/2024 to Mon 10/28/2024  
0500 Continuous 1900  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
DYSINGER EAST	<b>2850 MW</b>	
Impacts Total Transfer Capability	350 MW	
TTC with All Lines In Service	3200 MW	

### ROCHESTR-PANNELL\_345\_RP2

Mon 09/16/2024 to Fri 09/20/2024  
0700 Continuous 1530  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
DYSINGER EAST	<b>2300 MW</b>	
Impacts Total Transfer Capability	900 MW	
TTC with All Lines In Service	3200 MW	

### STLAWRNC-MOSES\_230\_L34P

Mon 09/16/2024 to Fri 09/20/2024  
0700 Continuous 1530  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - OH - NY		
Impacts Total Transfer Capability		
TTC with All Lines In Service		

### PANNELL-CLAY\_345\_1

Mon 09/23/2024 to Fri 09/27/2024  
0700 Continuous 1530  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
WEST CENTRAL	<b>1300 MW</b>	
Impacts Total Transfer Capability	950 MW	
TTC with All Lines In Service	2250 MW	

### STLAWRNC-MOSES\_230\_L34P

Mon 09/23/2024 to Fri 09/27/2024  
0700 Continuous 1530  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - OH - NY		
Impacts Total Transfer Capability		
TTC with All Lines In Service		

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, April 24, 2024 to Thursday, October 23, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FITZPTRK-EDIC___345_FE-1				FWD (Import)	REV (Export)
Thu 09/26/2024	to	Thu 09/26/2024	OSWEGO EXPORT	<b>4800 MW</b>	
0900	Continuous	1000	Impacts Total Transfer Capability	450 MW	
Work scheduled by: NYPA			TTC with All Lines In Service	5250 MW	
FITZPTRK-EDIC___345_FE-1				FWD (Import)	REV (Export)
Thu 09/26/2024	to	Thu 09/26/2024	CENTRAL EAST - VC	<b>3520 MW</b>	
0900	Continuous	1000	Impacts Total Transfer Capability	205 MW	
Work scheduled by: NYPA			TTC with All Lines In Service	3725 MW	
W49TH_ST-E13THSTA_345_M55				FWD (Import)	REV (Export)
Fri 09/27/2024	to	Tue 11/19/2024	SPR/DUN-SOUTH	<b>3800 MW</b>	
0001	Continuous	0200	Impacts Total Transfer Capability	800 MW	
Work scheduled by: ConEd			TTC with All Lines In Service	4600 MW	
W49TH_ST_345KV_6				FWD (Import)	REV (Export)
Fri 09/27/2024	to	Tue 11/19/2024	SCH - PJM_HTP	<b>300 MW</b>	
0101	Continuous	0200	Impacts Total Transfer Capability	360 MW	
Work scheduled by: ConEd			TTC with All Lines In Service	660 MW	
STLAWRNC-MOSES___230_L34P				FWD (Import)	REV (Export)
Mon 09/30/2024	to	Fri 10/04/2024	SCH - OH - NY		
0700	Continuous	1530	Impacts Total Transfer Capability		
Work scheduled by: NYPA			TTC with All Lines In Service		
FITZPTRK-EDIC___345_FE-1				FWD (Import)	REV (Export)
Mon 09/30/2024	to	Fri 10/04/2024	OSWEGO EXPORT	<b>4800 MW</b>	
1700	Continuous	1530	Impacts Total Transfer Capability	450 MW	
Work scheduled by: NYPA			TTC with All Lines In Service	5250 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, April 24, 2024 to Thursday, October 23, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>FITZPTRK-EDIC_345_FE-1</b>					FWD (Import)	REV (Export)
Mon 09/30/2024	to	Fri 10/04/2024		CENTRAL EAST - VC	<b>3520 MW</b>	
1700	Continuous	1530		Impacts Total Transfer Capability	205 MW	
Work scheduled by: NYPA				TTC with All Lines In Service	3725 MW	
<b>BECK_-NIAGARA_345_PA302</b>					FWD (Import)	REV (Export)
Mon 10/07/2024	to	Fri 10/11/2024		SCH - OH - NY	<b>1000 MW</b>	<b>850 MW</b>
0500	Continuous	1900		Impacts Total Transfer Capability	1050 MW	800 MW
Work scheduled by: NYPA				TTC with All Lines In Service	2050 MW	1650 MW
<b>NEPTUNE_-DUFFYAVE_345_NEPTUNE</b>					FWD (Import)	REV (Export)
Mon 10/07/2024	to	Fri 10/11/2024		SCH - PJM_NEPTUNE	<b>0 MW</b>	
0600	Continuous	1600		Impacts Total Transfer Capability	660 MW	
Work scheduled by: LI				TTC with All Lines In Service	660 MW	
<b>NEWBRDGE_345_138_BK_1</b>					FWD (Import)	REV (Export)
Mon 10/07/2024	to	Fri 10/11/2024		SCH - PJM_NEPTUNE	<b>375 MW</b>	
0600	Continuous	1600		Impacts Total Transfer Capability	285 MW	
Work scheduled by: LI				TTC with All Lines In Service	660 MW	
<b>NEWBRDGE_345_138_BK_2</b>					FWD (Import)	REV (Export)
Mon 10/07/2024	to	Fri 10/11/2024		SCH - PJM_NEPTUNE	<b>375 MW</b>	
0600	Continuous	1600		Impacts Total Transfer Capability	285 MW	
Work scheduled by: LI				TTC with All Lines In Service	660 MW	
<b>NEWBRDGE-DUFFYAVE_345_501</b>					FWD (Import)	REV (Export)
Mon 10/07/2024	to	Fri 10/11/2024		SCH - PJM_NEPTUNE	<b>0 MW</b>	
0600	Continuous	1600		Impacts Total Transfer Capability	660 MW	
Work scheduled by: LI				TTC with All Lines In Service	660 MW	



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, April 24, 2024 to Thursday, October 23, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SHOR\_NPX-SHOREHAM\_138\_CSC

Mon 10/07/2024 to Fri 10/11/2024  
0600 Continuous 1800

Work scheduled by: LI

SCH - NPX\_CSC

FWD (Import)

REV (Export)

0 MW

0 MW

Impacts Total Transfer Capability

330 MW

330 MW

TTC with All Lines In Service

330 MW

330 MW

### MARCY\_\_FRASANNX\_345\_UCC2-41

Wed 10/09/2024 to Thu 10/10/2024  
0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC

FWD (Import)

REV (Export)

3225 MW

Impacts Total Transfer Capability

500 MW

TTC with All Lines In Service

3725 MW

### MARCY\_\_N.SCTLND\_345\_18

Tue 10/15/2024 to Thu 10/17/2024  
0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC

FWD (Import)

REV (Export)

2665 MW

Impacts Total Transfer Capability

1060 MW

TTC with All Lines In Service

3725 MW

### MARCY\_\_N.SCTLND\_345\_18

Mon 10/21/2024 to Fri 10/25/2024  
0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC

FWD (Import)

REV (Export)

2665 MW

Impacts Total Transfer Capability

1060 MW

TTC with All Lines In Service

3725 MW

### MARCY\_\_345KV\_CSC

Mon 10/28/2024 to Sun 11/10/2024  
0700 Continuous 1530

Work scheduled by: NYPA

CENTRAL EAST - VC

FWD (Import)

REV (Export)

3650 MW

Impacts Total Transfer Capability

75 MW

TTC with All Lines In Service

3725 MW

### DYSINGER-STA\_255\_345\_DH2

Tue 10/29/2024 to Thu 10/31/2024  
0500 Continuous 2100

Work scheduled by: NYPA

DYSINGER EAST

FWD (Import)

REV (Export)

2850 MW

Impacts Total Transfer Capability

350 MW

TTC with All Lines In Service

3200 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, April 24, 2024 to Thursday, October 23, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### DYSINGER-STA\_255\_345\_DH1

Mon 11/04/2024 to Sat 11/16/2024  
0500 Continuous 1900  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
DYSINGER EAST	<b>2850 MW</b>	
Impacts Total Transfer Capability	350 MW	
TTC with All Lines In Service	3200 MW	

### LINDN\_CG-LNDVFT\_345\_V-3022

Tue 11/12/2024 to Tue 11/12/2024  
0800 Continuous 2359  
Work scheduled by: PJM

	FWD (Import)	REV (Export)
SCH - PJM_VFT	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	315 MW	315 MW
TTC with All Lines In Service	315 MW	315 MW

### BECK\_-NIAGARA\_230\_PA27

Fri 11/15/2024 to Fri 11/15/2024  
0500 Continuous 1900  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - OH - NY	<b>2100 MW</b>	
Impacts Total Transfer Capability	350 MW	
TTC with All Lines In Service	2450 MW	

### OSWEGO\_-VOLNEY\_345\_12

Fri 11/15/2024 to Fri 12/13/2024  
0730 Continuous 1600  
Work scheduled by: NGrid

	FWD (Import)	REV (Export)
OSWEGO EXPORT	<b>5250 MW</b>	
Impacts Total Transfer Capability	0 MW	
TTC with All Lines In Service	5250 MW	

### CHATGUAY-MASSENA\_765\_7040

Sat 11/16/2024 to Fri 11/29/2024  
0001 Continuous 2359  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - HQ - NY	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	1500 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

### CHATGUAY-MASSENA\_765\_7040

Sat 11/16/2024 to Fri 11/29/2024  
0001 Continuous 2359  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
MOSES SOUTH	<b>1550 MW</b>	
Impacts Total Transfer Capability	1600 MW	
TTC with All Lines In Service	3150 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, April 24, 2024 to Thursday, October 23, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MARCY\_\_\_765\_345\_AT1

Sat 11/16/2024 to Fri 11/29/2024  
0001 Continuous 2359  
Work scheduled by: NYPA

ARR: 19

MOSES SOUTH **1750 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 3150 MW

FWD (Import)

REV (Export)

### MARCY\_\_\_765\_345\_AT2

Sat 11/16/2024 to Fri 11/29/2024  
0001 Continuous 2359  
Work scheduled by: NYPA

ARR: 19

MOSES SOUTH **1700 MW**  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

FWD (Import)

REV (Export)

### MASSENA\_-MARCY\_\_\_765\_MSU1

Sat 11/16/2024 to Fri 11/29/2024  
0001 Continuous 2359  
Work scheduled by: NYPA

SCH - HQ\_CEDARS **90 MW**  
Impacts Total Transfer Capability 189 MW  
TTC with All Lines In Service 279 MW

FWD (Import)

REV (Export)

### MASSENA\_-MARCY\_\_\_765\_MSU1

Sat 11/16/2024 to Fri 11/29/2024  
0001 Continuous 2359  
Work scheduled by: NYPA

SCH - HQ - NY **475 MW** **1000 MW**  
Impacts Total Transfer Capability 1025 MW 0 MW  
TTC with All Lines In Service 1500 MW 1000 MW

FWD (Import)

REV (Export)

### MASSENA\_-MARCY\_\_\_765\_MSU1

Sat 11/16/2024 to Fri 11/29/2024  
0001 Continuous 2359  
Work scheduled by: NYPA

MOSES SOUTH **500 MW**  
Impacts Total Transfer Capability 2650 MW  
TTC with All Lines In Service 3150 MW

FWD (Import)

REV (Export)

### MASSENA\_-MARCY\_\_\_765\_MSU1

Sat 11/16/2024 to Fri 11/29/2024  
0001 Continuous 2359  
Work scheduled by: NYPA

CENTRAL EAST - VC **2595 MW**  
Impacts Total Transfer Capability 1130 MW  
TTC with All Lines In Service 3725 MW

FWD (Import)

REV (Export)

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, April 24, 2024 to Thursday, October 23, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MASSENA\_MARCY\_\_765\_MSU1 , CHATGUAY-MASSENA\_765\_7040

Sat 11/16/2024 to Fri 11/29/2024  
0001 2359

Work scheduled by:

MOSES SOUTH **500 MW**  
Impacts Total Transfer Capability 2650 MW  
TTC with All Lines In Service 3150 MW

### MOSES\_\_-MASSENA\_230\_MMS2 , MOSES\_\_-MASSENA\_230\_MMS1

Sat 11/16/2024 to Fri 11/29/2024  
0001 2359

Work scheduled by:

SCH - HQ\_CEDARS **90 MW**  
Impacts Total Transfer Capability 189 MW  
TTC with All Lines In Service 279 MW

### MOSES\_\_-MASSENA\_230\_MMS2 , MOSES\_\_-MASSENA\_230\_MMS1

Sat 11/16/2024 to Fri 11/29/2024  
0001 2359

Work scheduled by:

SCH - HQ - NY **850 MW** **0 MW**  
Impacts Total Transfer Capability 650 MW 1000 MW  
TTC with All Lines In Service 1500 MW 1000 MW

### LINDN\_CG-LNDVFT\_\_345\_V-3022

Fri 11/22/2024 to Fri 11/22/2024  
1500 Continuous 1800

Work scheduled by: PJM

SCH - PJM\_VFT **0 MW** **0 MW**  
Impacts Total Transfer Capability 315 MW 315 MW  
TTC with All Lines In Service 315 MW 315 MW

### ADIRNDCK-PORTER\_\_230\_12

Sun 12/01/2024 to Tue 12/24/2024  
0530 Continuous 1700

Work scheduled by: NGrid

MOSES SOUTH **2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

### E13THSTA-FARRAGUT\_345\_46

Wed 12/18/2024 to Fri 12/20/2024  
0201 Continuous 0300

Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, April 24, 2024 to Thursday, October 23, 2025

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### ADIRNDCK-PORTER\_\_230\_12

Thu 01/02/2025 to Sat 05/31/2025  
0530 Continuous 1700  
Work scheduled by: NGrid

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **2300 MW**  
850 MW  
3150 MW

### OSWEGO\_-VOLNEY\_\_345\_11

Mon 01/06/2025 to Fri 01/24/2025  
0700 Continuous 1700  
Work scheduled by: NGrid

OSWEGO EXPORT  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **5250 MW**  
0 MW  
5250 MW

### E13THSTA-FARRAGUT\_345\_46

Fri 01/10/2025 to Wed 01/15/2025  
0001 Continuous 0300  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **3800 MW**  
800 MW  
4600 MW

### OSWEGO\_-ELBRIDGE\_345\_17

Mon 01/27/2025 to Fri 02/14/2025  
0630 Continuous 1730  
Work scheduled by: NGrid  
ARR: 75

OSWEGO EXPORT  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **5250 MW**  
0 MW  
5250 MW

### ELBRIDGE-LAFAYTTE\_345\_17-LE

Wed 02/12/2025 to Fri 02/14/2025  
0700 Continuous 1730  
Work scheduled by: NGrid  
ARR: 75

OSWEGO EXPORT  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **5250 MW**  
0 MW  
5250 MW

### GOETHALS\_345KV\_5

Mon 09/08/2025 to Mon 09/08/2025  
0301 Continuous 0330  
Work scheduled by: ConEd

STATEN ISLAND  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **5250 MW**  
0 MW  
5250 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, April 24, 2024 to Thursday, October 23, 2025

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### GOETHALS\_345KV\_5

Tue 09/09/2025 to Tue 09/09/2025  
2330 Continuous 2359  
Work scheduled by: ConEd

STATEN ISLAND  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### GOETHALS\_345KV\_5

Mon 09/15/2025 to Mon 09/15/2025  
0230 Continuous 0300  
Work scheduled by: ConEd

STATEN ISLAND  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### GOETHALS\_345KV\_5

Mon 09/15/2025 to Mon 09/15/2025  
0301 Continuous 0330  
Work scheduled by: ConEd

STATEN ISLAND  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### ADIRNDCK-PORTER\_\_230\_12

Mon 09/15/2025 to Sun 10/12/2025  
0600 Continuous 1700  
Work scheduled by: NGrid

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**2100 MW**  
1050 MW  
3150 MW

### GOETHALS\_345KV\_5

Tue 09/16/2025 to Tue 09/16/2025  
2330 Continuous 2359  
Work scheduled by: ConEd

STATEN ISLAND  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### GOETHALS\_345KV\_5

Fri 09/26/2025 to Fri 09/26/2025  
0230 Continuous 0300  
Work scheduled by: ConEd

STATEN ISLAND  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

<b>BECK___-NIAGARA_230_PA27</b>				FWD (Import)	REV (Export)
Mon 09/29/2025	to	Wed 11/26/2025	SCH - OH - NY	<b>1900 MW</b>	<b>1650 MW</b>
0500	Continuous	1900	Impacts Total Transfer Capability	150 MW	0 MW
Work scheduled by: NYPA			TTC with All Lines In Service	2050 MW	1650 MW