

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, July 7, 2024 to Tuesday, January 6, 2026

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_10_BYPASS , SPRNBRK_345KV_R5S3_BYPASS ,
SPRNBRK_345KV_R4S3_BYPASS , DUNWODIE_345KV_9_BYPASS

Sun 02/01/2015 to Fri 02/01/2030
0000 0000

Work scheduled by:

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

4350 MW

Impacts Total Transfer Capability

250 MW

TTC with All Lines In Service

4600 MW

DUNWODIE_345KV_10_BYPASS , SPRNBRK_345KV_R5S3_BYPASS ,
SPRNBRK_345KV_R4S3_BYPASS , DUNWODIE_345KV_9_BYPASS

Sun 02/01/2015 to Fri 02/01/2030
0000 0000

Work scheduled by:

UPNY CONED

FWD (Import)

REV (Export)

7505 MW

Impacts Total Transfer Capability

545 MW

TTC with All Lines In Service

8050 MW

HUDSONP_-FARRAGUT_345_B3402

Mon 01/15/2018 to Tue 12/31/2024
0001 Continuous 2359

Work scheduled by: ConEd

EXT FORCED by ConEd 03/11/2024 11:26

SCH - PJ - NY

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

TTC with All Lines In Service

MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Tue 12/31/2024
0001 Continuous 2359

Work scheduled by: ConEd

EXT FORCED by ConEd 03/11/2024 11:26

SCH - PJ - NY

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

TTC with All Lines In Service

MARION_-FARRAGUT_345_C3403 , HUDSONP_-
FARRAGUT_345_B3402

Mon 01/15/2018 to Tue 12/31/2024
0001 2359

Work scheduled by:

SCH - PJ - NY

FWD (Import)

REV (Export)

2000 MW

1000 MW

Impacts Total Transfer Capability

200 MW

200 MW

TTC with All Lines In Service

2200 MW

1200 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, July 7, 2024 to Tuesday, January 6, 2026

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-HQ_CEDARS-NYISO_LIMIT_240

Mon 03/11/2024 to Thu 10/03/2024
0800 Continuous 1500

EXTENDED by HQ 04/23/2024 09:40

SCH - HQ_CEDARS

FWD (Import)

REV (Export)

240 MW

Impacts Total Transfer Capability

30 MW

TTC with All Lines In Service

270 MW

Work scheduled by: HQ

SCH-NYISO-HQ_CEDARS_LIMIT_0

Mon 03/11/2024 to Thu 10/03/2024
0800 Continuous 1500

EXTENDED by HQ 04/23/2024 09:40

SCH - HQ_CEDARS

FWD (Import)

REV (Export)

0 MW

Impacts Total Transfer Capability

100 MW

TTC with All Lines In Service

100 MW

Work scheduled by: HQ

MARCY_SO_SERIES_COMP_I/S

Fri 05/24/2024 to Sun 09/01/2024
1634 Continuous 2359

CENTRAL EAST - VC

FWD (Import)

REV (Export)

3510 MW

Impacts Total Transfer Capability

215 MW

TTC with All Lines In Service

3725 MW

Work scheduled by: NYPA

MARCY_345KV_CSC

Sat 06/15/2024 to Sat 05/24/2025
0001 Continuous 2359

FORCED by NYPA 06/11/2024 15:44

CENTRAL EAST - VC

FWD (Import)

REV (Export)

3650 MW

Impacts Total Transfer Capability

75 MW

TTC with All Lines In Service

3725 MW

Work scheduled by: NYPA

DUNWODIE-SHORE_RD_345_Y50

Mon 06/17/2024 to Wed 07/31/2024
2226 Continuous 2359

EXT FORCED by LI 06/25/2024 08:16

CONED - LIPA

FWD (Import)

REV (Export)

800 MW

Impacts Total Transfer Capability

700 MW

TTC with All Lines In Service

1500 MW

Work scheduled by: LI

SHORE_RD_345_138_BK 1

Mon 06/17/2024 to Wed 07/31/2024
2226 Continuous 2359

EXT FORCED by LI 06/25/2024 08:16

CONED - LIPA

FWD (Import)

REV (Export)

1350 MW

Impacts Total Transfer Capability

150 MW

TTC with All Lines In Service

1500 MW

Work scheduled by: LI

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, July 7, 2024 to Tuesday, January 6, 2026

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SHORE_RD_345_138_BK 2

Mon 06/17/2024 to Wed 07/31/2024
2226 Continuous 2359

EXT FORCED by LI 06/25/2024 08:16

CONED - LIPA

FWD (Import)

REV (Export)

1350 MW

Impacts Total Transfer Capability

150 MW

TTC with All Lines In Service

1500 MW

Work scheduled by: LI

FRASER__345_FRASER SVC

Sun 06/23/2024 to Mon 07/29/2024
1245 Continuous 0759

CENTRAL EAST - VC

FWD (Import)

REV (Export)

3655 MW

Impacts Total Transfer Capability

70 MW

TTC with All Lines In Service

3725 MW

Work scheduled by: NYSEG

SCH-HQ-NYISO_LIMIT_1050

Wed 06/26/2024 to Thu 08/08/2024
2300 Continuous 1700

SCH - HQ - NY

FWD (Import)

REV (Export)

1050 MW

Impacts Total Transfer Capability

450 MW

TTC with All Lines In Service

1500 MW

Work scheduled by: HQ

SCH-NYISO-HQ_LIMIT_750

Fri 06/28/2024 to Tue 12/31/2024
0000 Continuous 2359

SCH - HQ - NY

FWD (Import)

REV (Export)

750 MW

Impacts Total Transfer Capability

250 MW

TTC with All Lines In Service

1000 MW

Work scheduled by: HQ

SCH-HQ_CEDARS-NYISO_LIMIT_160

Fri 07/05/2024 to Tue 07/09/2024
0001 Continuous 2359

SCH - HQ_CEDARS

FWD (Import)

REV (Export)

160 MW

Impacts Total Transfer Capability

110 MW

TTC with All Lines In Service

270 MW

Work scheduled by: NYISO

CHAT_DC_GC1

Mon 07/08/2024 to Mon 07/08/2024
0700 Continuous 0900

MOSES SOUTH

FWD (Import)

REV (Export)

2850 MW

Impacts Total Transfer Capability

300 MW

TTC with All Lines In Service

3150 MW

Work scheduled by: HQ

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, July 7, 2024 to Tuesday, January 6, 2026

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 6150 MW |
| UPNY CONED | 8050 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3150 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

| | | | | | |
|----------------------------------|------------|----------------|-----------------------------------|----------------|---------------|
| CHAT_DC_GC1 | | | | FWD (Import) | REV (Export) |
| Mon 07/08/2024 | to | Mon 07/08/2024 | SCH - HQ - NY | | 500 MW |
| 0700 | Continuous | 0900 | Impacts Total Transfer Capability | 500 MW | |
| Work scheduled by: HQ | | | TTC with All Lines In Service | 1000 MW | |
| CHAT_DC_GC2 | | | | FWD (Import) | REV (Export) |
| Mon 07/08/2024 | to | Mon 07/08/2024 | MOSES SOUTH | 2850 MW | |
| 0700 | Continuous | 0900 | Impacts Total Transfer Capability | 300 MW | |
| Work scheduled by: HQ | | | TTC with All Lines In Service | 3150 MW | |
| CHAT_DC_GC2 | | | | FWD (Import) | REV (Export) |
| Mon 07/08/2024 | to | Mon 07/08/2024 | SCH - HQ - NY | | 500 MW |
| 0700 | Continuous | 0900 | Impacts Total Transfer Capability | 500 MW | |
| Work scheduled by: HQ | | | TTC with All Lines In Service | 1000 MW | |
| CHAT_DC_GC2 , CHAT_DC_GC1 | | | | FWD (Import) | REV (Export) |
| Mon 07/08/2024 | to | Mon 07/08/2024 | MOSES SOUTH | 2550 MW | |
| 0700 | | 0900 | Impacts Total Transfer Capability | 600 MW | |
| Work scheduled by: | | | TTC with All Lines In Service | 3150 MW | |
| CHAT_DC_GC2 , CHAT_DC_GC1 | | | | FWD (Import) | REV (Export) |
| Mon 07/08/2024 | to | Mon 07/08/2024 | SCH - HQ - NY | 1370 MW | 0 MW |
| 0700 | | 0900 | Impacts Total Transfer Capability | 130 MW | 1000 MW |
| Work scheduled by: | | | TTC with All Lines In Service | 1500 MW | 1000 MW |
| SCH-HQ-NYISO_LIMIT_500 | | | | FWD (Import) | REV (Export) |
| Mon 07/08/2024 | to | Mon 07/08/2024 | SCH - HQ - NY | 500 MW | |
| 0700 | Continuous | 0900 | Impacts Total Transfer Capability | 1000 MW | |
| Work scheduled by: HQ | | | TTC with All Lines In Service | 1500 MW | |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, July 7, 2024 to Tuesday, January 6, 2026

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHASLAKE-PORTER__230_11

Tue 07/09/2024 to Fri 08/30/2024
0700 Continuous 1900

UPDATED by NYISO 07/07/2024 14:31

MOSES SOUTH

FWD (Import)

REV (Export)

2100 MW

Impacts Total Transfer Capability

1050 MW

TTC with All Lines In Service

3150 MW

Work scheduled by: NGrid

SCH-NYISO-IMO_NIAGARA_CB_3002

Wed 07/10/2024 to Wed 07/10/2024
0500 Continuous 1600

SCH - OH - NY

FWD (Import)

REV (Export)

1350 MW

1200 MW

Impacts Total Transfer Capability

650 MW

400 MW

TTC with All Lines In Service

2000 MW

1600 MW

Work scheduled by: NYPA

MARCY__FRASANNX_345_UCC2-41

Wed 07/10/2024 to Fri 07/19/2024
0700 Continuous 1730

UPDATED by NYPA 06/06/2024 13:49

CENTRAL EAST - VC

FWD (Import)

REV (Export)

3225 MW

Impacts Total Transfer Capability

500 MW

TTC with All Lines In Service

3725 MW

Work scheduled by: NYPA

ARR: 19

NIAGARA__PACKARD__230_62

Mon 07/15/2024 to Fri 07/19/2024
0700 Continuous 1700

SCH - OH - NY

FWD (Import)

REV (Export)

1450 MW

1500 MW

Impacts Total Transfer Capability

550 MW

100 MW

TTC with All Lines In Service

2000 MW

1600 MW

Work scheduled by: NGrid

WATRCURE-OAKDALE_345_31

Tue 07/16/2024 to Thu 07/18/2024
0700 Continuous 1600

SCH - PJ - NY

FWD (Import)

REV (Export)

2050 MW

Impacts Total Transfer Capability

150 MW

TTC with All Lines In Service

2200 MW

Work scheduled by: NYSEG

NIAGARA_345_230_AT4

Sat 07/20/2024 to Sat 07/20/2024
0500 Continuous 2300

SCH - OH - NY

FWD (Import)

REV (Export)

1200 MW

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

1600 MW

Work scheduled by: NYPA

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, July 7, 2024 to Tuesday, January 6, 2026

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ROSETON_-EFISHKIL_345_RFK305

Sat 07/20/2024 to Sun 07/21/2024

0700 Continuous 1600

Work scheduled by: CHGE

UPNY CONED

FWD (Import)

REV (Export)

7215 MW

Impacts Total Transfer Capability

835 MW

TTC with All Lines In Service

8050 MW

LEEDS__345_LEEDS SVC

Mon 07/22/2024 to Thu 07/25/2024

0730 Continuous 1600

Work scheduled by: NGrid

CENTRAL EAST - VC

FWD (Import)

REV (Export)

3675 MW

Impacts Total Transfer Capability

50 MW

TTC with All Lines In Service

3725 MW

VOLNEY_-MARCY__345_19

Mon 07/22/2024 to Sat 07/27/2024

0730 Continuous 1700

Work scheduled by: NGrid

ARR: 19

OSWEGO EXPORT

FWD (Import)

REV (Export)

4900 MW

Impacts Total Transfer Capability

350 MW

TTC with All Lines In Service

5250 MW

VOLNEY_-MARCY__345_19

Mon 07/22/2024 to Sat 07/27/2024

0730 Continuous 1700

Work scheduled by: NGrid

ARR: 19

CENTRAL EAST - VC

FWD (Import)

REV (Export)

3525 MW

Impacts Total Transfer Capability

200 MW

TTC with All Lines In Service

3725 MW

FRASER__345_FRASER SVC

Mon 07/29/2024 to Fri 08/02/2024

0800 Continuous 1400

Work scheduled by: NYSEG

CENTRAL EAST - VC

FWD (Import)

REV (Export)

3655 MW

Impacts Total Transfer Capability

70 MW

TTC with All Lines In Service

3725 MW

SCH-NYISO-HQ_LIMIT_300

Sun 08/18/2024 to Tue 08/27/2024

0700 Continuous 1700

Work scheduled by: HQ

SCH - HQ - NY

FWD (Import)

REV (Export)

300 MW

Impacts Total Transfer Capability

700 MW

TTC with All Lines In Service

1000 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, July 7, 2024 to Tuesday, January 6, 2026

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

| | | | | | | |
|--------------------------------|------------|----------------|--|-----------------------------------|----------------|--------------|
| EDIC__-GORDONRD_345_14 | | | | | FWD (Import) | REV (Export) |
| Mon 08/19/2024 | to | Fri 08/30/2024 | | CENTRAL EAST - VC | 2770 MW | |
| 0630 | Continuous | 1800 | | Impacts Total Transfer Capability | 955 MW | |
| Work scheduled by: NGrid | | | | TTC with All Lines In Service | 3725 MW | |
| EDIC__-PRINCTWN_345_351 | | | | | FWD (Import) | REV (Export) |
| Mon 08/19/2024 | to | Sat 08/24/2024 | <u>UPDATED by NGrid 02/02/2024 14:41</u> | CENTRAL EAST - VC | 3335 MW | |
| 0700 | Continuous | 1700 | | Impacts Total Transfer Capability | 390 MW | |
| Work scheduled by: NGrid | | | | TTC with All Lines In Service | 3725 MW | |
| MARCY__-EDIC__345_UE1-7 | | | | | FWD (Import) | REV (Export) |
| Sun 08/25/2024 | to | Fri 08/30/2024 | | OSWEGO EXPORT | 5250 MW | |
| 0800 | Continuous | 1600 | ARR: 16 & 19 | Impacts Total Transfer Capability | 0 MW | |
| Work scheduled by: NGrid | | | | TTC with All Lines In Service | 5250 MW | |
| CHASLAKE-PORTER__230_11 | | | | | FWD (Import) | REV (Export) |
| Tue 09/03/2024 | to | Fri 11/15/2024 | <u>UPDATED by NYISO 07/07/2024 14:31</u> | MOSES SOUTH | 2100 MW | |
| 0530 | Continuous | 2000 | | Impacts Total Transfer Capability | 1050 MW | |
| Work scheduled by: NGrid | | | | TTC with All Lines In Service | 3150 MW | |
| EDIC__-GORDONRD_345_14 | | | | | FWD (Import) | REV (Export) |
| Tue 09/03/2024 | to | Mon 10/14/2024 | | CENTRAL EAST - VC | 2770 MW | |
| 0600 | Continuous | 1800 | | Impacts Total Transfer Capability | 955 MW | |
| Work scheduled by: NGrid | | | | TTC with All Lines In Service | 3725 MW | |
| FITZPTRK-EDIC__345_FE-1 | | | | | FWD (Import) | REV (Export) |
| Thu 09/05/2024 | to | Thu 09/05/2024 | <u>UPDATED by NYPA 05/01/2024 14:45</u> | OSWEGO EXPORT | 4800 MW | |
| 0001 | Continuous | 0100 | | Impacts Total Transfer Capability | 450 MW | |
| Work scheduled by: NYPA | | | | TTC with All Lines In Service | 5250 MW | |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, July 7, 2024 to Tuesday, January 6, 2026

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 6150 MW |
| UPNY CONED | 8050 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3150 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FITZPTRK-EDIC___345_FE-1

Thu 09/05/2024 to Thu 09/05/2024
0001 Continuous 0100
Work scheduled by: NYPA

UPDATED by NYPA 05/01/2024 14:45

CENTRAL EAST - VC
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
3520 MW
205 MW
3725 MW

W49TH_ST-E13THSTA_345_M54

Sun 09/08/2024 to Sun 09/08/2024
0001 Continuous 0030
Work scheduled by: ConEd

SPR/DUN-SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
3800 MW
800 MW
4600 MW

W49TH_ST-E13THSTA_345_M54

Sun 09/08/2024 to Sun 09/08/2024
0330 Continuous 0400
Work scheduled by: ConEd

SPR/DUN-SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
3800 MW
800 MW
4600 MW

EDIC___-PRINCTWN_345_351

Mon 09/09/2024 to Wed 09/11/2024
0700 Continuous 1700
Work scheduled by: NGrid

CENTRAL EAST - VC
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
3335 MW
390 MW
3725 MW

ROCHESTR-PANNELL_345_RP1

Mon 09/09/2024 to Fri 09/13/2024
0700 Continuous 1530
Work scheduled by: NYPA

DYSINGER EAST
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
2300 MW
900 MW
3200 MW

W49TH_ST_345KV_6

Thu 09/12/2024 to Thu 09/12/2024
0001 Continuous 0030
Work scheduled by: ConEd

SCH - PJM_HTP
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
300 MW
360 MW
660 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, July 7, 2024 to Tuesday, January 6, 2026

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_8

Thu 09/12/2024 to Thu 09/12/2024
0001 Continuous 0030
Work scheduled by: ConEd

SCH - PJM_HTP FWD (Import) REV (Export)
450 MW
Impacts Total Transfer Capability 210 MW
TTC with All Lines In Service 660 MW

W49TH_ST_345KV_6

Thu 09/12/2024 to Thu 09/12/2024
0330 Continuous 0400
Work scheduled by: ConEd

SCH - PJM_HTP FWD (Import) REV (Export)
300 MW
Impacts Total Transfer Capability 360 MW
TTC with All Lines In Service 660 MW

W49TH_ST_345KV_8

Thu 09/12/2024 to Thu 09/12/2024
0330 Continuous 0400
Work scheduled by: ConEd

SCH - PJM_HTP FWD (Import) REV (Export)
450 MW
Impacts Total Transfer Capability 210 MW
TTC with All Lines In Service 660 MW

MARCY_-EDIC_345_UE1-7

Thu 09/12/2024 to Sat 09/14/2024
0700 Continuous 1700
Work scheduled by: NGrid ARR: 16 & 19

OSWEGO EXPORT FWD (Import) REV (Export)
5250 MW
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 5250 MW

W49TH_ST_345KV_6

Thu 09/12/2024 to Thu 09/12/2024
1700 Continuous 1730
Work scheduled by: ConEd

SCH - PJM_HTP FWD (Import) REV (Export)
300 MW
Impacts Total Transfer Capability 360 MW
TTC with All Lines In Service 660 MW

W49TH_ST_345KV_8

Thu 09/12/2024 to Thu 09/12/2024
1700 Continuous 1730
Work scheduled by: ConEd

SCH - PJM_HTP FWD (Import) REV (Export)
450 MW
Impacts Total Transfer Capability 210 MW
TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, July 7, 2024 to Tuesday, January 6, 2026

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOTTHAVN-RAINEY__345_Q11

Sun 09/15/2024 to Sat 10/26/2024

0001 Continuous 0300

Work scheduled by: ConEd

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

3800 MW

Impacts Total Transfer Capability

800 MW

TTC with All Lines In Service

4600 MW

W49TH_ST_345KV_6

Sun 09/15/2024 to Sun 09/15/2024

0001 Continuous 0030

Work scheduled by: ConEd

SCH - PJM_HTP

FWD (Import)

REV (Export)

300 MW

Impacts Total Transfer Capability

360 MW

TTC with All Lines In Service

660 MW

W49TH_ST_345KV_8

Sun 09/15/2024 to Sun 09/15/2024

0001 Continuous 0030

Work scheduled by: ConEd

SCH - PJM_HTP

FWD (Import)

REV (Export)

450 MW

Impacts Total Transfer Capability

210 MW

TTC with All Lines In Service

660 MW

LONG_MTN-CRICKVLY_345_398

Mon 09/16/2024 to Sun 09/29/2024

0001 Continuous 2200

Work scheduled by: ConEd

UPDATED by ConEd 06/26/2024 12:49

SCH - NPX_1385

FWD (Import)

REV (Export)

100 MW

100 MW

Impacts Total Transfer Capability

100 MW

100 MW

TTC with All Lines In Service

200 MW

200 MW

LONG_MTN-CRICKVLY_345_398

Mon 09/16/2024 to Sun 09/29/2024

0001 Continuous 2200

Work scheduled by: ConEd

UPDATED by ConEd 06/26/2024 12:49

SCH - NE - NY

FWD (Import)

REV (Export)

800 MW

1200 MW

Impacts Total Transfer Capability

600 MW

400 MW

TTC with All Lines In Service

1400 MW

1600 MW

W49TH_ST_345KV_6

Mon 09/16/2024 to Mon 09/16/2024

0001 Continuous 0030

Work scheduled by: ConEd

SCH - PJM_HTP

FWD (Import)

REV (Export)

300 MW

Impacts Total Transfer Capability

360 MW

TTC with All Lines In Service

660 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, July 7, 2024 to Tuesday, January 6, 2026

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 6150 MW |
| UPNY CONED | 8050 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3150 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_8

Mon 09/16/2024 to Mon 09/16/2024
0001 Continuous 0030
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|-----------------------------------|---------------|--------------|
| SCH - PJM_HTP | 450 MW | |
| Impacts Total Transfer Capability | 210 MW | |
| TTC with All Lines In Service | 660 MW | |

NEPTUNE_DUFFYAVE_345_NEPTUNE

Mon 09/16/2024 to Wed 09/25/2024
0100 Continuous 0800
Work scheduled by: LI

| | FWD (Import) | REV (Export) |
|-----------------------------------|--------------|--------------|
| SCH - PJM_NEPTUNE | 0 MW | |
| Impacts Total Transfer Capability | 660 MW | |
| TTC with All Lines In Service | 660 MW | |

NEWBRDGE_345_138_BK_1

Mon 09/16/2024 to Wed 09/25/2024
0100 Continuous 0800
Work scheduled by: LI

| | FWD (Import) | REV (Export) |
|-----------------------------------|---------------|--------------|
| SCH - PJM_NEPTUNE | 375 MW | |
| Impacts Total Transfer Capability | 285 MW | |
| TTC with All Lines In Service | 660 MW | |

NEWBRDGE_345_138_BK_2

Mon 09/16/2024 to Wed 09/25/2024
0100 Continuous 0800
Work scheduled by: LI

| | FWD (Import) | REV (Export) |
|-----------------------------------|---------------|--------------|
| SCH - PJM_NEPTUNE | 375 MW | |
| Impacts Total Transfer Capability | 285 MW | |
| TTC with All Lines In Service | 660 MW | |

NEWBRDGE-DUFFYAVE_345_501

Mon 09/16/2024 to Wed 09/25/2024
0100 Continuous 0800
Work scheduled by: LI

| | FWD (Import) | REV (Export) |
|-----------------------------------|--------------|--------------|
| SCH - PJM_NEPTUNE | 0 MW | |
| Impacts Total Transfer Capability | 660 MW | |
| TTC with All Lines In Service | 660 MW | |

SCH-NE-NYISO_LIMIT_500

Mon 09/16/2024 to Sun 09/29/2024
0630 Continuous 2200
Work scheduled by: ConEd

UPDATED by ConEd 06/26/2024 12:49

| | FWD (Import) | REV (Export) |
|-----------------------------------|---------------|--------------|
| SCH - NE - NY | 700 MW | |
| Impacts Total Transfer Capability | 700 MW | |
| TTC with All Lines In Service | 1400 MW | |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, July 7, 2024 to Tuesday, January 6, 2026

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

| | | | | | | |
|---------------------------------|------------|----------------|--|-----------------------------------|----------------|--------------|
| ROCHESTR-PANNELL_345_RP2 | | | | | FWD (Import) | REV (Export) |
| Mon 09/16/2024 | to | Fri 09/20/2024 | | DYSINGER EAST | 2300 MW | |
| 0700 | Continuous | 1530 | | Impacts Total Transfer Capability | 900 MW | |
| Work scheduled by: NYPA | | | | TTC with All Lines In Service | 3200 MW | |
| STLAWRNC-MOSES_230_L34P | | | | | FWD (Import) | REV (Export) |
| Mon 09/16/2024 | to | Fri 09/20/2024 | | SCH - OH - NY | | |
| 0700 | Continuous | 1530 | | Impacts Total Transfer Capability | | |
| Work scheduled by: NYPA | | | | TTC with All Lines In Service | | |
| W49TH_ST_345KV_6 | | | | | FWD (Import) | REV (Export) |
| Mon 09/16/2024 | to | Mon 09/16/2024 | | SCH - PJM_HTP | 300 MW | |
| 1800 | Continuous | 1830 | | Impacts Total Transfer Capability | 360 MW | |
| Work scheduled by: ConEd | | | | TTC with All Lines In Service | 660 MW | |
| W49TH_ST_345KV_8 | | | | | FWD (Import) | REV (Export) |
| Mon 09/16/2024 | to | Mon 09/16/2024 | | SCH - PJM_HTP | 450 MW | |
| 1800 | Continuous | 1830 | | Impacts Total Transfer Capability | 210 MW | |
| Work scheduled by: ConEd | | | | TTC with All Lines In Service | 660 MW | |
| E13THSTA-FARRAGUT_345_45 | | | | | FWD (Import) | REV (Export) |
| Tue 09/17/2024 | to | Tue 09/17/2024 | | SPR/DUN-SOUTH | 3800 MW | |
| 0001 | Continuous | 0030 | | Impacts Total Transfer Capability | 800 MW | |
| Work scheduled by: ConEd | | | | TTC with All Lines In Service | 4600 MW | |
| W49TH_ST_345KV_6 | | | | | FWD (Import) | REV (Export) |
| Thu 09/19/2024 | to | Thu 09/19/2024 | | SCH - PJM_HTP | 300 MW | |
| 0130 | Continuous | 0200 | | Impacts Total Transfer Capability | 360 MW | |
| Work scheduled by: ConEd | | | | TTC with All Lines In Service | 660 MW | |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, July 7, 2024 to Tuesday, January 6, 2026

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_8

Thu 09/19/2024 to Thu 09/19/2024
0130 Continuous 0200
Work scheduled by: ConEd

SCH - PJM_HTP
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) **450 MW**
210 MW
660 MW
REV (Export)

LONG_MTN-CRICKVLY_345_398 , ROTTRDAM-EASTOVER_230_38

Thu 09/19/2024 to Thu 09/19/2024
0830 1130
Work scheduled by: ARR: 77

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) **800 MW**
600 MW
1400 MW
REV (Export) **1200 MW**
400 MW
1600 MW

ROTTRDAM-EASTOVER_230_38

Thu 09/19/2024 to Thu 09/19/2024
0830 Daily 1130
Work scheduled by: NGrid
CANCELLED by NYISO 07/03/2024 11:55
ARR: 77

SCH - NE - NY
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) **800 MW**
600 MW
1400 MW
REV (Export) **1200 MW**
400 MW
1600 MW

W49TH_ST_345KV_6

Fri 09/20/2024 to Fri 09/20/2024
0130 Continuous 0200
Work scheduled by: ConEd

SCH - PJM_HTP
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) **300 MW**
360 MW
660 MW
REV (Export)

W49TH_ST_345KV_8

Fri 09/20/2024 to Fri 09/20/2024
0130 Continuous 0200
Work scheduled by: ConEd

SCH - PJM_HTP
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) **450 MW**
210 MW
660 MW
REV (Export)

E13THSTA-FARRAGUT_345_45

Sun 09/22/2024 to Sun 09/22/2024
0130 Continuous 0200
Work scheduled by: ConEd

SPR/DUN-SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) **3800 MW**
800 MW
4600 MW
REV (Export)

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, July 7, 2024 to Tuesday, January 6, 2026

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FITZPTRK-EDIC__345_FE-1

Sun 09/22/2024 to Sun 09/22/2024
0900 Continuous 1000

UPDATED by NYPA 05/01/2024 14:42

OSWEGO EXPORT

FWD (Import)

REV (Export)

4800 MW

Impacts Total Transfer Capability

450 MW

TTC with All Lines In Service

5250 MW

Work scheduled by: NYPA

FITZPTRK-EDIC__345_FE-1

Sun 09/22/2024 to Sun 09/22/2024
0900 Continuous 1000

UPDATED by NYPA 05/01/2024 14:42

CENTRAL EAST - VC

FWD (Import)

REV (Export)

3520 MW

Impacts Total Transfer Capability

205 MW

TTC with All Lines In Service

3725 MW

Work scheduled by: NYPA

W49TH_ST_345KV_6

Mon 09/23/2024 to Mon 09/23/2024
0130 Continuous 0159

SCH - PJM_HTP

FWD (Import)

REV (Export)

300 MW

Impacts Total Transfer Capability

360 MW

TTC with All Lines In Service

660 MW

Work scheduled by: ConEd

W49TH_ST_345KV_8

Mon 09/23/2024 to Mon 09/23/2024
0130 Continuous 0159

SCH - PJM_HTP

FWD (Import)

REV (Export)

450 MW

Impacts Total Transfer Capability

210 MW

TTC with All Lines In Service

660 MW

Work scheduled by: ConEd

W49TH_ST_345KV_6

Mon 09/23/2024 to Tue 11/19/2024
0201 Continuous 0200

UPDATED by ConEd 06/18/2024 12:03

SCH - PJM_HTP

FWD (Import)

REV (Export)

300 MW

Impacts Total Transfer Capability

360 MW

TTC with All Lines In Service

660 MW

Work scheduled by: ConEd

W49TH_ST-E13THSTA_345_M55

Mon 09/23/2024 to Tue 11/19/2024
0201 Continuous 0200

UPDATED by ConEd 06/18/2024 12:03

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

3800 MW

Impacts Total Transfer Capability

800 MW

TTC with All Lines In Service

4600 MW

Work scheduled by: ConEd

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, July 7, 2024 to Tuesday, January 6, 2026

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PANNELL_-CLAY___345_1

Mon 09/23/2024 to Fri 09/27/2024

0700 Continuous 1530

Work scheduled by: NYPA

WEST CENTRAL

FWD (Import)

REV (Export)

1300 MW

Impacts Total Transfer Capability

950 MW

TTC with All Lines In Service

2250 MW

STLAWRNC-MOSES___230_L34P

Mon 09/23/2024 to Fri 09/27/2024

0700 Continuous 1530

Work scheduled by: NYPA

SCH - OH - NY

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

TTC with All Lines In Service

LADENTWN-LOVETT___345_Y66

Thu 09/26/2024 to Fri 11/01/2024

0200 Continuous 0200

Work scheduled by: ORU

UPNY CONED

FWD (Import)

REV (Export)

7695 MW

Impacts Total Transfer Capability

355 MW

TTC with All Lines In Service

8050 MW

LOVETT_-BUCHAN_S_345_Y88

Thu 09/26/2024 to Fri 11/01/2024

0200 Continuous 0200

Work scheduled by: ORU

UPNY CONED

FWD (Import)

REV (Export)

7695 MW

Impacts Total Transfer Capability

355 MW

TTC with All Lines In Service

8050 MW

STLAWRNC-MOSES___230_L34P

Mon 09/30/2024 to Fri 10/04/2024

0700 Continuous 1530

Work scheduled by: NYPA

SCH - OH - NY

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

TTC with All Lines In Service

FITZPTRK-EDIC___345_FE-1

Mon 09/30/2024 to Fri 10/04/2024

1700 Continuous 1530

Work scheduled by: NYPA

OSWEGO EXPORT

FWD (Import)

REV (Export)

4800 MW

Impacts Total Transfer Capability

450 MW

TTC with All Lines In Service

5250 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, July 7, 2024 to Tuesday, January 6, 2026

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

| | | | | | | |
|----------------------------------|------------|----------------|---------|-----------------------------------|----------------|----------------|
| FITZPTRK-EDIC_345_FE-1 | | | | | FWD (Import) | REV (Export) |
| Mon 09/30/2024 | to | Fri 10/04/2024 | | CENTRAL EAST - VC | 3520 MW | |
| 1700 | Continuous | 1530 | | Impacts Total Transfer Capability | 205 MW | |
| Work scheduled by: NYPA | | | | TTC with All Lines In Service | 3725 MW | |
| BECK_-NIAGARA_345_PA302 | | | | | FWD (Import) | REV (Export) |
| Mon 10/07/2024 | to | Fri 10/11/2024 | | SCH - OH - NY | 900 MW | 850 MW |
| 0500 | Continuous | 1900 | | Impacts Total Transfer Capability | 1100 MW | 750 MW |
| Work scheduled by: NYPA | | | | TTC with All Lines In Service | 2000 MW | 1600 MW |
| SHOR_NPX-SHOREHAM_138_CSC | | | | | FWD (Import) | REV (Export) |
| Mon 10/07/2024 | to | Fri 10/11/2024 | | SCH - NPX_CSC | 0 MW | 0 MW |
| 0600 | Continuous | 1800 | | Impacts Total Transfer Capability | 330 MW | 330 MW |
| Work scheduled by: LI | | | | TTC with All Lines In Service | 330 MW | 330 MW |
| KNICRBKR-PLSNTVLY_345_Y57 | | | | | FWD (Import) | REV (Export) |
| Tue 10/08/2024 | to | Thu 10/10/2024 | | UPNY CONED | 7885 MW | |
| 0001 | Continuous | 2200 | ARR: 78 | Impacts Total Transfer Capability | 165 MW | |
| Work scheduled by: ConEd | | | | TTC with All Lines In Service | 8050 MW | |
| MARCY_-N.SCTLND_345_18 | | | | | FWD (Import) | REV (Export) |
| Tue 10/15/2024 | to | Thu 10/17/2024 | | CENTRAL EAST - VC | 2665 MW | |
| 0700 | Continuous | 1530 | ARR: 19 | Impacts Total Transfer Capability | 1060 MW | |
| Work scheduled by: NYPA | | | | TTC with All Lines In Service | 3725 MW | |
| BECK_-NIAGARA_230_PA27 | | | | | FWD (Import) | REV (Export) |
| Fri 10/18/2024 | to | Fri 10/18/2024 | | SCH - OH - NY | 1900 MW | 1650 MW |
| 0500 | Continuous | 1900 | | Impacts Total Transfer Capability | 100 MW | -50 MW |
| Work scheduled by: NYPA | | | | TTC with All Lines In Service | 2000 MW | 1600 MW |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, July 7, 2024 to Tuesday, January 6, 2026

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 6150 MW |
| UPNY CONED | 8050 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3150 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY__-N.SCTLND_345_18

Mon 10/21/2024 to Fri 10/25/2024
 0700 Continuous 1530

Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

2665 MW

1060 MW

3725 MW

EGRDNCTY_345_138_AT1

Tue 10/22/2024 to Thu 10/24/2024
 0001 Continuous 2200

Work scheduled by: ConEd

CONED - LIPA

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

1250 MW

250 MW

1500 MW

EGRDNCTY_345_138_AT2

Tue 10/22/2024 to Thu 10/24/2024
 0001 Continuous 2200

Work scheduled by: ConEd

CONED - LIPA

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

1250 MW

250 MW

1500 MW

SPRNBK_-EGRDNCTR_345_Y49

Tue 10/22/2024 to Thu 10/24/2024
 0001 Continuous 2200

Work scheduled by: ConEd

CONED - LIPA

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

775 MW

725 MW

1500 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, July 7, 2024 to Tuesday, January 6, 2026

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DYSINGER-STA_255_345_DH1

Mon 11/04/2024 to Sat 11/16/2024
0500 Continuous 1900
Work scheduled by: NYPA

| | | |
|-----------------------------------|----------------|--------------|
| | FWD (Import) | REV (Export) |
| DYSINGER EAST | 2850 MW | |
| Impacts Total Transfer Capability | 350 MW | |
| TTC with All Lines In Service | 3200 MW | |

LONG_MTN-CRICKVLY_345_398

Tue 11/05/2024 to Sat 11/30/2024
0001 Continuous 2200
Work scheduled by: ConEd

| | | |
|-----------------------------------|---------------|---------------|
| | FWD (Import) | REV (Export) |
| SCH - NPX_1385 | 100 MW | 100 MW |
| Impacts Total Transfer Capability | 100 MW | 100 MW |
| TTC with All Lines In Service | 200 MW | 200 MW |

LONG_MTN-CRICKVLY_345_398

Tue 11/05/2024 to Sat 11/30/2024
0001 Continuous 2200
Work scheduled by: ConEd

| | | |
|-----------------------------------|---------------|----------------|
| | FWD (Import) | REV (Export) |
| SCH - NE - NY | 800 MW | 1200 MW |
| Impacts Total Transfer Capability | 600 MW | 600 MW |
| TTC with All Lines In Service | 1400 MW | 1800 MW |

LINDN_CG-LNDVFT_345_V-3022

Tue 11/12/2024 to Tue 11/12/2024
0800 Continuous 2359
Work scheduled by: PJM

| | | |
|-----------------------------------|--------------|--------------|
| | FWD (Import) | REV (Export) |
| SCH - PJM_VFT | 0 MW | 0 MW |
| Impacts Total Transfer Capability | 315 MW | 315 MW |
| TTC with All Lines In Service | 315 MW | 315 MW |

OSWEGO_-VOLNEY_345_12

Fri 11/15/2024 to Fri 12/13/2024
0730 Continuous 1600
Work scheduled by: NGrid

| | | |
|-----------------------------------|----------------|--------------|
| | FWD (Import) | REV (Export) |
| OSWEGO EXPORT | 5250 MW | |
| Impacts Total Transfer Capability | 0 MW | |
| TTC with All Lines In Service | 5250 MW | |

CHATGUAY-MASSENA_765_7040

Sat 11/16/2024 to Fri 11/29/2024
0001 Continuous 2359
Work scheduled by: NYPA

| | | |
|-----------------------------------|--------------|--------------|
| | FWD (Import) | REV (Export) |
| SCH - HQ - NY | 0 MW | 0 MW |
| Impacts Total Transfer Capability | 1500 MW | 1000 MW |
| TTC with All Lines In Service | 1500 MW | 1000 MW |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, July 7, 2024 to Tuesday, January 6, 2026

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHATGUAY-MASSENA__765_7040

Sat 11/16/2024 to Fri 11/29/2024

0001 Continuous 2359

Work scheduled by: NYPA

MOSES SOUTH

FWD (Import)

REV (Export)

1550 MW

Impacts Total Transfer Capability

1600 MW

TTC with All Lines In Service

3150 MW

CHATGUAY-MASSENA__765_7040 , MASSENA-MARCY__765_MSU1

Sat 11/16/2024 to Fri 11/29/2024

0001 2359

Work scheduled by:

MOSES SOUTH

FWD (Import)

REV (Export)

500 MW

Impacts Total Transfer Capability

2650 MW

TTC with All Lines In Service

3150 MW

MARCY__765_345_AT1

Sat 11/16/2024 to Fri 11/29/2024

0001 Continuous 2359

Work scheduled by: NYPA

ARR: 19

MOSES SOUTH

FWD (Import)

REV (Export)

1750 MW

Impacts Total Transfer Capability

1400 MW

TTC with All Lines In Service

3150 MW

MARCY__765_345_AT2

Sat 11/16/2024 to Fri 11/29/2024

0001 Continuous 2359

Work scheduled by: NYPA

ARR: 19

MOSES SOUTH

FWD (Import)

REV (Export)

1700 MW

Impacts Total Transfer Capability

1450 MW

TTC with All Lines In Service

3150 MW

MASSENA-MARCY__765_MSU1

Sat 11/16/2024 to Fri 11/29/2024

0001 Continuous 2359

Work scheduled by: NYPA

SCH - HQ_CEDARS

FWD (Import)

REV (Export)

90 MW

Impacts Total Transfer Capability

189 MW

TTC with All Lines In Service

279 MW

MASSENA-MARCY__765_MSU1

Sat 11/16/2024 to Fri 11/29/2024

0001 Continuous 2359

Work scheduled by: NYPA

SCH - HQ - NY

FWD (Import)

REV (Export)

475 MW

1000 MW

Impacts Total Transfer Capability

1025 MW

0 MW

TTC with All Lines In Service

1500 MW

1000 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, July 7, 2024 to Tuesday, January 6, 2026

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA_MARCY__765_MSU1

Sat 11/16/2024 to Fri 11/29/2024

0001 Continuous 2359

Work scheduled by: NYPA

MOSES SOUTH

FWD (Import)

REV (Export)

500 MW

Impacts Total Transfer Capability

2650 MW

TTC with All Lines In Service

3150 MW

MASSENA_MARCY__765_MSU1

Sat 11/16/2024 to Fri 11/29/2024

0001 Continuous 2359

Work scheduled by: NYPA

CENTRAL EAST - VC

FWD (Import)

REV (Export)

2595 MW

Impacts Total Transfer Capability

1130 MW

TTC with All Lines In Service

3725 MW

MOSES_-MASSENA_230_MMS2 , MOSES_-MASSENA_230_MMS1

Sat 11/16/2024 to Fri 11/29/2024

0001 2359

Work scheduled by:

SCH - HQ_CEDARS

FWD (Import)

REV (Export)

90 MW

Impacts Total Transfer Capability

189 MW

TTC with All Lines In Service

279 MW

MOSES_-MASSENA_230_MMS2 , MOSES_-MASSENA_230_MMS1

Sat 11/16/2024 to Fri 11/29/2024

0001 2359

Work scheduled by:

SCH - HQ - NY

FWD (Import)

REV (Export)

850 MW

0 MW

Impacts Total Transfer Capability

650 MW

1000 MW

TTC with All Lines In Service

1500 MW

1000 MW

MILLWOOD-EASTVIEW_345_W99

Mon 11/18/2024 to Fri 11/22/2024

0001 Continuous 2200

Work scheduled by: ConEd

UPNY CONED

FWD (Import)

REV (Export)

7810 MW

Impacts Total Transfer Capability

240 MW

TTC with All Lines In Service

8050 MW

W49TH_ST_345KV_6

Tue 11/19/2024 to Thu 12/12/2024

0201 Continuous 0000

Work scheduled by: ConEd

UPDATED by ConEd 06/18/2024 12:10

SCH - PJM_HTP

FWD (Import)

REV (Export)

310 MW

Impacts Total Transfer Capability

350 MW

TTC with All Lines In Service

660 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, July 7, 2024 to Tuesday, January 6, 2026

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST-E13THSTA_345_M55

Tue 11/19/2024 to Fri 12/13/2024
0201 Continuous 0200

UPDATED by ConEd 06/18/2024 12:10

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

3800 MW

Impacts Total Transfer Capability

800 MW

TTC with All Lines In Service

4600 MW

Work scheduled by: ConEd

LINDN_CG-LNDVFT_345_V-3022

Fri 11/22/2024 to Fri 11/22/2024
1500 Continuous 1800

SCH - PJM_VFT

FWD (Import)

REV (Export)

0 MW

0 MW

Impacts Total Transfer Capability

315 MW

315 MW

TTC with All Lines In Service

315 MW

315 MW

Work scheduled by: PJM

ADIRNDCK-PORTER_230_12

Mon 12/02/2024 to Tue 12/24/2024
0530 Continuous 1700

MOSES SOUTH

FWD (Import)

REV (Export)

2300 MW

Impacts Total Transfer Capability

850 MW

TTC with All Lines In Service

3150 MW

Work scheduled by: NGrid

W49TH_ST_345KV_6

Thu 12/12/2024 to Fri 12/13/2024
0001 Continuous 2359

SCH - PJM_HTP

FWD (Import)

REV (Export)

310 MW

Impacts Total Transfer Capability

350 MW

TTC with All Lines In Service

660 MW

Work scheduled by: ConEd

W49TH_ST_345KV_8

Thu 12/12/2024 to Fri 12/13/2024
0001 Continuous 2359

SCH - PJM_HTP

FWD (Import)

REV (Export)

310 MW

Impacts Total Transfer Capability

350 MW

TTC with All Lines In Service

660 MW

Work scheduled by: ConEd

SPRNBK-TREMONT_345_X28

Mon 12/16/2024 to Tue 12/17/2024
0001 Continuous 0200

UPDATED by ConEd 07/02/2024 11:14

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

4200 MW

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

4600 MW

Work scheduled by: ConEd

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, July 7, 2024 to Tuesday, January 6, 2026

| | |
|-------------------|---------|
| CENTRAL EAST | 7550 MW |
| CENTRAL EAST - VC | 3725 MW |
| TOTAL EAST | 6150 MW |
| UPNY CONED | 8050 MW |
| SPR/DUN-SOUTH | 4600 MW |
| DYSINGER EAST | 3200 MW |
| MOSES SOUTH | 3150 MW |

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_5

Mon 12/16/2024 to Wed 12/18/2024
0001 Continuous 0100
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|-----------------------------------|---------------|--------------|
| SCH - PJM_HTP | 300 MW | |
| Impacts Total Transfer Capability | 360 MW | |
| TTC with All Lines In Service | 660 MW | |

W49TH_ST_345KV_7

Mon 12/16/2024 to Wed 12/18/2024
0001 Continuous 0100
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|-----------------------------------|---------------|--------------|
| SCH - PJM_HTP | 300 MW | |
| Impacts Total Transfer Capability | 360 MW | |
| TTC with All Lines In Service | 660 MW | |

E13THSTA-FARRAGUT_345_46

Wed 12/18/2024 to Fri 12/20/2024
0201 Continuous 0300
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|-----------------------------------|----------------|--------------|
| SPR/DUN-SOUTH | 3800 MW | |
| Impacts Total Transfer Capability | 800 MW | |
| TTC with All Lines In Service | 4600 MW | |

ADIRNDCK-PORTER_230_12

Thu 01/02/2025 to Sat 05/31/2025
0530 Continuous 1700
Work scheduled by: NGrid

| | FWD (Import) | REV (Export) |
|-----------------------------------|----------------|--------------|
| MOSES SOUTH | 2300 MW | |
| Impacts Total Transfer Capability | 850 MW | |
| TTC with All Lines In Service | 3150 MW | |

OSWEGO_-VOLNEY_345_11

Mon 01/06/2025 to Fri 01/24/2025
0700 Continuous 1700
Work scheduled by: NGrid

| | FWD (Import) | REV (Export) |
|-----------------------------------|----------------|--------------|
| OSWEGO EXPORT | 5250 MW | |
| Impacts Total Transfer Capability | 0 MW | |
| TTC with All Lines In Service | 5250 MW | |

E13THSTA-FARRAGUT_345_46

Fri 01/10/2025 to Wed 01/15/2025
0001 Continuous 0300
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|-----------------------------------|----------------|--------------|
| SPR/DUN-SOUTH | 3800 MW | |
| Impacts Total Transfer Capability | 800 MW | |
| TTC with All Lines In Service | 4600 MW | |

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, July 7, 2024 to Tuesday, January 6, 2026

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

OSWEGO_-ELBRIDGE_345_17

Mon 01/27/2025 to Fri 02/14/2025
0630 Continuous 1730

ARR: 75

FWD (Import) REV (Export)

OSWEGO EXPORT 5250 MW
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 5250 MW

ELBRIDGE-LAFAYTTE_345_17-LE

Wed 02/12/2025 to Fri 02/14/2025
0700 Continuous 1730

ARR: 75

FWD (Import) REV (Export)

OSWEGO EXPORT 5250 MW
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 5250 MW

GOETHALS_345KV_5

Mon 09/08/2025 to Mon 09/08/2025
0301 Continuous 0330

FWD (Import) REV (Export)

STATEN ISLAND
Impacts Total Transfer Capability
TTC with All Lines In Service

GOETHALS_345KV_5

Tue 09/09/2025 to Tue 09/09/2025
2330 Continuous 2359

FWD (Import) REV (Export)

STATEN ISLAND
Impacts Total Transfer Capability
TTC with All Lines In Service

GOETHALS_345KV_5

Mon 09/15/2025 to Mon 09/15/2025
0230 Continuous 0300

FWD (Import) REV (Export)

STATEN ISLAND
Impacts Total Transfer Capability
TTC with All Lines In Service

ADIRNDCK-PORTER__230_12

Mon 09/15/2025 to Sun 10/12/2025
0600 Continuous 1700

FWD (Import) REV (Export)

MOSES SOUTH 2100 MW
Impacts Total Transfer Capability 1050 MW
TTC with All Lines In Service 3150 MW

Work scheduled by: NGrid

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Sunday, July 7, 2024 to Tuesday, January 6, 2026

CENTRAL EAST 7550 MW
CENTRAL EAST - VC 3725 MW
TOTAL EAST 6150 MW
UPNY CONED 8050 MW
SPR/DUN-SOUTH 4600 MW
DYSINGER EAST 3200 MW
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

BECK__-NIAGARA_230_PA27

Mon 09/29/2025 to Wed 11/26/2025
0500 Continuous 1900
Work scheduled by: NYPA

SCH - OH - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

| FWD (Import) | REV (Export) |
|--------------|--------------|
| 1900 MW | 1650 MW |
| 100 MW | -50 MW |
| 2000 MW | 1600 MW |

HUDSONP_-FARRAGUT_345_B3402

Tue 09/30/2025 to Sat 10/04/2025
0001 Continuous 0300
Work scheduled by: ConEd

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

| FWD (Import) | REV (Export) |
|--------------|--------------|
| | |

HUDSONP_-FARRAGUT_345_B3402

Wed 10/22/2025 to Wed 10/22/2025
0301 Continuous 1500
Work scheduled by: ConEd

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

| FWD (Import) | REV (Export) |
|--------------|--------------|
| | |

HUDSONP_-FARRAGUT_345_B3402

Fri 10/24/2025 to Sun 10/26/2025
0001 Continuous 0300
Work scheduled by: ConEd

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

| FWD (Import) | REV (Export) |
|--------------|--------------|
| | |