

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, September 28, 2024 to Friday, March 27, 2026

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE\_345KV\_10\_BYPASS , SPRNBRK\_345KV\_R5S3\_BYPASS ,  
SPRNBRK\_345KV\_R4S3\_BYPASS , DUNWODIE\_345KV\_9\_BYPASS

Sun 02/01/2015 to Fri 02/01/2030  
0000 0000

Work scheduled by:

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

**4350 MW**

Impacts Total Transfer Capability

250 MW

TTC with All Lines In Service

4600 MW

DUNWODIE\_345KV\_10\_BYPASS , SPRNBRK\_345KV\_R5S3\_BYPASS ,  
SPRNBRK\_345KV\_R4S3\_BYPASS , DUNWODIE\_345KV\_9\_BYPASS

Sun 02/01/2015 to Fri 02/01/2030  
0000 0000

Work scheduled by:

UPNY CONED

FWD (Import)

REV (Export)

**7505 MW**

Impacts Total Transfer Capability

545 MW

TTC with All Lines In Service

8050 MW

HUDSONP\_-FARRAGUT\_345\_B3402

Mon 01/15/2018 to Tue 12/31/2024  
0001 Continuous 2359

Work scheduled by: ConEd

EXT FORCED by ConEd 03/11/2024 11:26

SCH - PJ - NY

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

TTC with All Lines In Service

MARION\_-FARRAGUT\_345\_C3403

Mon 01/15/2018 to Tue 12/31/2024  
0001 Continuous 2359

Work scheduled by: ConEd

EXT FORCED by ConEd 03/11/2024 11:26

SCH - PJ - NY

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

TTC with All Lines In Service

MARION\_-FARRAGUT\_345\_C3403 , HUDSONP\_-  
FARRAGUT\_345\_B3402

Mon 01/15/2018 to Tue 12/31/2024  
0001 2359

Work scheduled by:

SCH - PJ - NY

FWD (Import)

REV (Export)

**2000 MW**

**1000 MW**

Impacts Total Transfer Capability

200 MW

200 MW

TTC with All Lines In Service

2200 MW

1200 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, September 28, 2024 to Friday, March 27, 2026

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-HQ\_CEDARS-NYISO\_LIMIT\_240

Mon 03/11/2024 to Fri 10/04/2024  
0800 Continuous 1500

EXTENDED by HQ 04/23/2024 09:40

SCH - HQ\_CEDARS

FWD (Import)

REV (Export)

**240 MW**

Impacts Total Transfer Capability

30 MW

TTC with All Lines In Service

270 MW

Work scheduled by: HQ

### SCH-NYISO-HQ\_CEDARS\_LIMIT\_0

Mon 03/11/2024 to Fri 10/04/2024  
0800 Continuous 1500

EXTENDED by HQ 04/23/2024 09:40

SCH - HQ\_CEDARS

FWD (Import)

REV (Export)

**0 MW**

Impacts Total Transfer Capability

100 MW

TTC with All Lines In Service

100 MW

Work scheduled by: HQ

### LOVETT\_\_345\_138\_BK\_192

Wed 04/17/2024 to Fri 11/01/2024  
1121 Continuous 0200

EXT FORCED by ORU 05/07/2024 15:02

UPNY CONED

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

TTC with All Lines In Service

Work scheduled by: ORU

### MARCY\_\_345KV\_CSC

Sat 06/15/2024 to Sat 05/24/2025  
0001 Continuous 2359

FORCED by NYPA 06/11/2024 15:44

CENTRAL EAST - VC

FWD (Import)

REV (Export)

**3650 MW**

Impacts Total Transfer Capability

75 MW

TTC with All Lines In Service

3725 MW

Work scheduled by: NYPA

### DUNWODIE-SHORE\_RD\_345\_Y50

Mon 06/17/2024 to Mon 10/21/2024  
2226 Continuous 2359

EXT FORCED by LI 08/29/2024 16:17

CONED - LIPA

FWD (Import)

REV (Export)

**800 MW**

Impacts Total Transfer Capability

700 MW

TTC with All Lines In Service

1500 MW

Work scheduled by: LI

### SHORE\_RD\_345\_138\_BK\_1

Mon 06/17/2024 to Mon 10/21/2024  
2226 Continuous 2359

EXT FORCED by LI 08/29/2024 16:17

CONED - LIPA

FWD (Import)

REV (Export)

**1350 MW**

Impacts Total Transfer Capability

150 MW

TTC with All Lines In Service

1500 MW

Work scheduled by: LI

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, September 28, 2024 to Friday, March 27, 2026

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SHORE\_RD\_345\_138\_BK 2

Mon 06/17/2024 to Mon 10/21/2024  
2226 Continuous 2359

EXT FORCED by LI 08/29/2024 16:17

CONED - LIPA

FWD (Import)

REV (Export)

**1350 MW**

Impacts Total Transfer Capability

150 MW

TTC with All Lines In Service

1500 MW

Work scheduled by: LI

### SCH-NYISO-HQ\_LIMIT\_750

Fri 06/28/2024 to Tue 12/31/2024  
0000 Continuous 2359

SCH - HQ - NY

FWD (Import)

REV (Export)

**750 MW**

Impacts Total Transfer Capability

250 MW

TTC with All Lines In Service

1000 MW

Work scheduled by: HQ

### SCH-NYISO-HQ\_LIMIT\_800

Mon 08/12/2024 to Mon 10/28/2024  
0500 Continuous 2000

SCH - HQ - NY

FWD (Import)

REV (Export)

**800 MW**

Impacts Total Transfer Capability

200 MW

TTC with All Lines In Service

1000 MW

Work scheduled by: HQ

### CHASLAKE-PORTER\_\_230\_11

Tue 09/03/2024 to Fri 11/15/2024  
0530 Continuous 2000

UPDATED by NGrid 08/29/2024 09:15

MOSES SOUTH

FWD (Import)

REV (Export)

**2100 MW**

Impacts Total Transfer Capability

1050 MW

TTC with All Lines In Service

3150 MW

Work scheduled by: NGrid

### EDIC\_\_GORDONRD\_345\_14

Tue 09/03/2024 to Mon 10/14/2024  
0700 Continuous 1800

UPDATED by NGrid 08/19/2024 09:28

CENTRAL EAST - VC

FWD (Import)

REV (Export)

**2770 MW**

Impacts Total Transfer Capability

955 MW

TTC with All Lines In Service

3725 MW

Work scheduled by: NGrid

### SCH-NYISO-HQ\_LIMIT\_500

Sun 09/22/2024 to Thu 10/03/2024  
0700 Continuous 1900

UPDATED by HQ 09/24/2024 08:18

SCH - HQ - NY

FWD (Import)

REV (Export)

**500 MW**

Impacts Total Transfer Capability

500 MW

TTC with All Lines In Service

1000 MW

Work scheduled by: HQ

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, September 28, 2024 to Friday, March 27, 2026

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### LADENTWN-LOVETT\_\_345\_Y66

Thu 09/26/2024 to Fri 11/01/2024  
0200 Continuous 0200  
Work scheduled by: ORU

UPNY CONED FWD (Import) REV (Export)  
Impacts Total Transfer Capability 7695 MW 355 MW  
TTC with All Lines In Service 8050 MW

### LOVETT\_-BUCHAN\_S\_345\_Y88

Thu 09/26/2024 to Fri 11/01/2024  
0200 Continuous 0200  
Work scheduled by: ORU

UPNY CONED FWD (Import) REV (Export)  
Impacts Total Transfer Capability 7695 MW 355 MW  
TTC with All Lines In Service 8050 MW

### W49TH\_ST\_345KV\_6

Fri 09/27/2024 to Tue 11/19/2024  
0101 Continuous 0200  
Work scheduled by: ConEd  
UPDATED by ConEd 09/25/2024 08:24

SCH - PJM\_HTP FWD (Import) REV (Export)  
Impacts Total Transfer Capability 300 MW 360 MW  
TTC with All Lines In Service 660 MW

### W49TH\_ST-E13THSTA\_345\_M55

Fri 09/27/2024 to Tue 11/19/2024  
0101 Continuous 0200  
Work scheduled by: ConEd  
UPDATED by ConEd 09/25/2024 08:24

SPR/DUN-SOUTH FWD (Import) REV (Export)  
Impacts Total Transfer Capability 3800 MW 800 MW  
TTC with All Lines In Service 4600 MW

### SCH-NYISO-HQ\_LIMIT\_300

Fri 09/27/2024 to Sat 09/28/2024  
2000 Daily 0800  
Work scheduled by: HQ

SCH - HQ - NY FWD (Import) REV (Export)  
Impacts Total Transfer Capability 300 MW 700 MW  
TTC with All Lines In Service 1000 MW

### SCH-NYISO-HQ\_LIMIT\_300

Sat 09/28/2024 to Sun 09/29/2024  
2000 Daily 0800  
Work scheduled by: HQ

SCH - HQ - NY FWD (Import) REV (Export)  
Impacts Total Transfer Capability 300 MW 700 MW  
TTC with All Lines In Service 1000 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, September 28, 2024 to Friday, March 27, 2026

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-HQ-NYISO\_LIMIT\_1100

Sun 09/29/2024 to Fri 10/04/2024  
0500 Continuous 1900

Work scheduled by: HQ

SCH - HQ - NY

FWD (Import)

REV (Export)

**1100 MW**

Impacts Total Transfer Capability

400 MW

TTC with All Lines In Service

1500 MW

### SCH-NYISO-HQ\_LIMIT\_300

Sun 09/29/2024 to Mon 09/30/2024  
2000 Daily 0800

Work scheduled by: HQ

SCH - HQ - NY

FWD (Import)

REV (Export)

**300 MW**

Impacts Total Transfer Capability

700 MW

TTC with All Lines In Service

1000 MW

### SCH-IMO\_NY\_NIAG\_SOUTH\_BUS\_W/BB

Mon 09/30/2024 to Wed 10/02/2024  
0500 Continuous 2100

Work scheduled by: NYPA

SCH - OH - NY

FWD (Import)

REV (Export)

**1350 MW**

**1200 MW**

Impacts Total Transfer Capability

650 MW

400 MW

TTC with All Lines In Service

2000 MW

1600 MW

### SCH-HQ\_CEDARS-NYISO\_LIMIT\_80

Mon 09/30/2024 to Fri 10/11/2024  
0600 Continuous 1700

Work scheduled by: HQ

UPDATED by HQ 09/25/2024 14:36

SCH - HQ\_CEDARS

FWD (Import)

REV (Export)

**80 MW**

Impacts Total Transfer Capability

190 MW

TTC with All Lines In Service

270 MW

### FROST\_BR-LONG\_MTN\_345\_352

Mon 09/30/2024 to Thu 10/31/2024  
0830 Continuous 2359

Work scheduled by: ISONE

SCH - NE - NY

FWD (Import)

REV (Export)

**1150 MW**

Impacts Total Transfer Capability

250 MW

TTC with All Lines In Service

1400 MW

### PRINCTWN-N.SCTLND\_345\_55

Mon 09/30/2024 to Mon 09/30/2024  
0830 Continuous 1130

Work scheduled by: NGrid

CENTRAL EAST - VC

FWD (Import)

REV (Export)

**3645 MW**

Impacts Total Transfer Capability

80 MW

TTC with All Lines In Service

3725 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, September 28, 2024 to Friday, March 27, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_800

Mon 09/30/2024 to Thu 10/31/2024  
0830 Continuous 2359  
Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>1000 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NYISO-HQ\_LIMIT\_300

Mon 09/30/2024 to Tue 10/01/2024  
2000 Daily 0800  
Work scheduled by: HQ

SCH - HQ - NY	FWD (Import)	REV (Export)
		<b>300 MW</b>
Impacts Total Transfer Capability		700 MW
TTC with All Lines In Service		1000 MW

### SCH-NE-NYISO\_LIMIT\_300

Mon 09/30/2024 to Tue 10/01/2024  
2300 Daily 0700  
Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>500 MW</b>	
Impacts Total Transfer Capability	900 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NYISO-HQ\_LIMIT\_300

Tue 10/01/2024 to Wed 10/02/2024  
2000 Daily 0800  
Work scheduled by: HQ

SCH - HQ - NY	FWD (Import)	REV (Export)
		<b>300 MW</b>
Impacts Total Transfer Capability		700 MW
TTC with All Lines In Service		1000 MW

### SCH-NE-NYISO\_LIMIT\_300

Tue 10/01/2024 to Wed 10/02/2024  
2300 Daily 0700  
Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>500 MW</b>	
Impacts Total Transfer Capability	900 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NYISO-HQ\_LIMIT\_300

Wed 10/02/2024 to Thu 10/03/2024  
2000 Daily 0800  
Work scheduled by: HQ

SCH - HQ - NY	FWD (Import)	REV (Export)
		<b>300 MW</b>
Impacts Total Transfer Capability		700 MW
TTC with All Lines In Service		1000 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, September 28, 2024 to Friday, March 27, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_300

Wed 10/02/2024 to Thu 10/03/2024  
2300 Daily 0700

Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>500 MW</b>	
Impacts Total Transfer Capability	900 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NYISO-HQ\_LIMIT\_300

Thu 10/03/2024 to Fri 10/04/2024  
2000 Daily 0800

Work scheduled by: HQ

SCH - HQ - NY	FWD (Import)	REV (Export)
		<b>300 MW</b>
Impacts Total Transfer Capability		700 MW
TTC with All Lines In Service		1000 MW

### SCH-NE-NYISO\_LIMIT\_300

Thu 10/03/2024 to Fri 10/04/2024  
2300 Daily 0700

Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>500 MW</b>	
Impacts Total Transfer Capability	900 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NYISO-HQ\_LIMIT\_300

Fri 10/04/2024 to Sat 10/05/2024  
2000 Daily 0800

Work scheduled by: HQ

SCH - HQ - NY	FWD (Import)	REV (Export)
		<b>300 MW</b>
Impacts Total Transfer Capability		700 MW
TTC with All Lines In Service		1000 MW

### SCH-NE-NYISO\_LIMIT\_300

Fri 10/04/2024 to Sat 10/05/2024  
2300 Daily 0700

Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>500 MW</b>	
Impacts Total Transfer Capability	900 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NYISO-HQ\_LIMIT\_300

Sat 10/05/2024 to Sun 10/06/2024  
2000 Daily 0800

Work scheduled by: HQ

SCH - HQ - NY	FWD (Import)	REV (Export)
		<b>300 MW</b>
Impacts Total Transfer Capability		700 MW
TTC with All Lines In Service		1000 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, September 28, 2024 to Friday, March 27, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_300

Sat 10/05/2024 to Sun 10/06/2024  
2300 Daily 0700

Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>500 MW</b>	
Impacts Total Transfer Capability	900 MW	
TTC with All Lines In Service	1400 MW	

### SHOR\_NPX-SHOREHAM\_138\_CSC

Sun 10/06/2024 to Sat 10/19/2024  
1700 Continuous 2000

Work scheduled by: LI

SCH - NPX_CSC	FWD (Import)	REV (Export)
	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	330 MW	330 MW
TTC with All Lines In Service	330 MW	330 MW

### SCH-NYISO-HQ\_LIMIT\_300

Sun 10/06/2024 to Mon 10/07/2024  
2000 Daily 0800

Work scheduled by: HQ

SCH - HQ - NY	FWD (Import)	REV (Export)
		<b>300 MW</b>
Impacts Total Transfer Capability		700 MW
TTC with All Lines In Service		1000 MW

### SCH-NE-NYISO\_LIMIT\_300

Sun 10/06/2024 to Mon 10/07/2024  
2300 Daily 0700

Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>500 MW</b>	
Impacts Total Transfer Capability	900 MW	
TTC with All Lines In Service	1400 MW	

### BEAR SWP-EASTOVER\_230\_E205W

Mon 10/07/2024 to Tue 10/29/2024  
0001 Continuous 1500

Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
Impacts Total Transfer Capability		
TTC with All Lines In Service		

### BECK\_\_-NIAGARA\_345\_PA302

Mon 10/07/2024 to Fri 10/11/2024  
0500 Continuous 1900

Work scheduled by: NYPA

SCH - OH - NY	FWD (Import)	REV (Export)
	<b>1000 MW</b>	<b>850 MW</b>
Impacts Total Transfer Capability	1000 MW	750 MW
TTC with All Lines In Service	2000 MW	1600 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, September 28, 2024 to Friday, March 27, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NYISO-HQ\_LIMIT\_500

Mon 10/07/2024 to Fri 10/11/2024  
0600 Continuous 1900  
Work scheduled by: HQ

	FWD (Import)	REV (Export)
SCH - HQ - NY		<b>500 MW</b>
Impacts Total Transfer Capability		500 MW
TTC with All Lines In Service		1000 MW

### DENNISON-ROSEMNTA\_115\_1/11

Mon 10/07/2024 to Mon 10/07/2024  
0700 Continuous 1700  
Work scheduled by: HQ

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS	<b>95 MW</b>	<b>40 MW</b>
Impacts Total Transfer Capability	175 MW	60 MW
TTC with All Lines In Service	270 MW	100 MW

### SCH-HQ\_CEDARS-NYISO\_LIMIT\_80

Mon 10/07/2024 to Mon 10/07/2024  
0700 Continuous 1700  
Work scheduled by: HQ

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS	<b>80 MW</b>	
Impacts Total Transfer Capability	190 MW	
TTC with All Lines In Service	270 MW	

### HOMRC\_NY-MAINS\_NY\_345\_47

Mon 10/07/2024 to Fri 10/11/2024  
0800 Continuous 1600  
Work scheduled by: NYSEG

	FWD (Import)	REV (Export)
SCH - PJ - NY		
Impacts Total Transfer Capability		
TTC with All Lines In Service		

### SCH-NYISO-HQ\_LIMIT\_300

Mon 10/07/2024 to Tue 10/08/2024  
2000 Daily 0800  
Work scheduled by: HQ

	FWD (Import)	REV (Export)
SCH - HQ - NY		<b>300 MW</b>
Impacts Total Transfer Capability		700 MW
TTC with All Lines In Service		1000 MW

### SCH-NE-NYISO\_LIMIT\_300

Mon 10/07/2024 to Tue 10/08/2024  
2300 Daily 0700  
Work scheduled by: ISONE

	FWD (Import)	REV (Export)
SCH - NE - NY	<b>500 MW</b>	
Impacts Total Transfer Capability	900 MW	
TTC with All Lines In Service	1400 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, September 28, 2024 to Friday, March 27, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### KNICRBKR-PLSNTVLY\_345\_Y57

Tue 10/08/2024 to Thu 10/10/2024  
0001 Continuous 2200  
Work scheduled by: ConEd

UPDATED by NGrid 09/11/2024 14:08

ARR: 78

UPNY CONED

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

**7885 MW**

165 MW

8050 MW

REV (Export)

### SCH-NYISO-HQ\_LIMIT\_300

Tue 10/08/2024 to Wed 10/09/2024  
2000 Daily 0800  
Work scheduled by: HQ

SCH - HQ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

**300 MW**

700 MW

1000 MW

REV (Export)

### SCH-NE-NYISO\_LIMIT\_300

Tue 10/08/2024 to Wed 10/09/2024  
2300 Daily 0700  
Work scheduled by: ISONE

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

**500 MW**

900 MW

1400 MW

REV (Export)

### SCH-NE-NYISO\_LIMIT\_300

Wed 10/09/2024 to Thu 10/10/2024  
2300 Daily 0700  
Work scheduled by: ISONE

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

**500 MW**

900 MW

1400 MW

REV (Export)

### SCH-HQ-NYISO\_LIMIT\_500

Thu 10/10/2024 to Sat 10/12/2024  
0500 Continuous 2300  
Work scheduled by: HQ

SCH - HQ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

**500 MW**

1000 MW

1500 MW

REV (Export)

### SCH-NE-NYISO\_LIMIT\_300

Thu 10/10/2024 to Fri 10/11/2024  
2300 Daily 0700  
Work scheduled by: ISONE

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

**500 MW**

900 MW

1400 MW

REV (Export)

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, September 28, 2024 to Friday, March 27, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_300

Fri 10/11/2024 to Sat 10/12/2024  
2300 Daily 0700

Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**500 MW**  
900 MW  
1400 MW

### SCH-NE-NYISO\_LIMIT\_300

Sat 10/12/2024 to Sun 10/13/2024  
2300 Daily 0700

Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**500 MW**  
900 MW  
1400 MW

### CHAT\_DC\_GC1

Sun 10/13/2024 to Sun 11/24/2024  
0500 Continuous 2100

Work scheduled by: HQ

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**2850 MW**  
300 MW  
3150 MW

### CHAT\_DC\_GC1

Sun 10/13/2024 to Sun 11/24/2024  
0500 Continuous 2100

Work scheduled by: HQ

SCH - HQ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**500 MW**  
500 MW  
1000 MW

### SCH-HQ-NYISO\_LIMIT\_1100

Sun 10/13/2024 to Sun 11/24/2024  
0500 Continuous 2100

Work scheduled by: HQ

SCH - HQ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1100 MW**  
400 MW  
1500 MW

### SCH-NYISO-HQ\_LIMIT\_300

Sun 10/13/2024 to Sun 11/24/2024  
0500 Continuous 2100

Work scheduled by: HQ

SCH - HQ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**300 MW**  
700 MW  
1000 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, September 28, 2024 to Friday, March 27, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_300

Sun 10/13/2024 to Mon 10/14/2024  
2300 Daily 0700

Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>500 MW</b>	
Impacts Total Transfer Capability	900 MW	
TTC with All Lines In Service	1400 MW	

### ALCOA\_PA\_115KV\_R8105

Mon 10/14/2024 to Fri 10/18/2024  
0630 Continuous 1800

Work scheduled by: NGrid

MOSES SOUTH	FWD (Import)	REV (Export)
	<b>3100 MW</b>	
Impacts Total Transfer Capability	50 MW	
TTC with All Lines In Service	3150 MW	

### SCH-HQ\_CEDARS-NYISO\_LIMIT\_100

Mon 10/14/2024 to Fri 10/18/2024  
0630 Continuous 1800

Work scheduled by: NGrid

SCH - HQ_CEDARS	FWD (Import)	REV (Export)
	<b>100 MW</b>	
Impacts Total Transfer Capability	170 MW	
TTC with All Lines In Service	270 MW	

### SCH-NE-NYISO\_LIMIT\_300

Mon 10/14/2024 to Tue 10/15/2024  
2300 Daily 0700

Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>500 MW</b>	
Impacts Total Transfer Capability	900 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NE-NYISO\_LIMIT\_300

Tue 10/15/2024 to Wed 10/16/2024  
2300 Daily 0700

Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>500 MW</b>	
Impacts Total Transfer Capability	900 MW	
TTC with All Lines In Service	1400 MW	

### DYSINGER-STA\_255\_345\_DH2

Wed 10/16/2024 to Wed 10/16/2024  
0800 Continuous 1600

Work scheduled by: NT

DYSINGER EAST	FWD (Import)	REV (Export)
	<b>2850 MW</b>	
Impacts Total Transfer Capability	350 MW	
TTC with All Lines In Service	3200 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, September 28, 2024 to Friday, March 27, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_300

Wed 10/16/2024 to Thu 10/17/2024  
2300 Daily 0700

Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>500 MW</b>	
Impacts Total Transfer Capability	900 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NE-NYISO\_LIMIT\_300

Thu 10/17/2024 to Fri 10/18/2024  
2300 Daily 0700

Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>500 MW</b>	
Impacts Total Transfer Capability	900 MW	
TTC with All Lines In Service	1400 MW	

### BECK\_\_-NIAGARA\_230\_PA27

Fri 10/18/2024 to Fri 10/18/2024  
0500 Continuous 1900

Work scheduled by: NYPA

SCH - OH - NY	FWD (Import)	REV (Export)
	<b>1900 MW</b>	<b>1650 MW</b>
Impacts Total Transfer Capability	100 MW	-50 MW
TTC with All Lines In Service	2000 MW	1600 MW

### SCH-NE-NYISO\_LIMIT\_300

Fri 10/18/2024 to Sat 10/19/2024  
2300 Daily 0700

Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>500 MW</b>	
Impacts Total Transfer Capability	900 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NE-NYISO\_LIMIT\_300

Sat 10/19/2024 to Sun 10/20/2024  
2300 Daily 0700

Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>500 MW</b>	
Impacts Total Transfer Capability	900 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NE-NYISO\_LIMIT\_300

Sun 10/20/2024 to Mon 10/21/2024  
2300 Daily 0700

Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>500 MW</b>	
Impacts Total Transfer Capability	900 MW	
TTC with All Lines In Service	1400 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, September 28, 2024 to Friday, March 27, 2026

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MARCY\_\_N.SCTLND\_345\_18

Mon 10/21/2024 to Fri 10/25/2024  
0500 Continuous 1730

UPDATED by NYPA 09/23/2024 10:24

ARR: 19

CENTRAL EAST - VC

FWD (Import)

REV (Export)

2665 MW

Impacts Total Transfer Capability

1060 MW

TTC with All Lines In Service

3725 MW

### CEDARS\_-ROSEMNTB\_115\_2/22

Mon 10/21/2024 to Mon 10/21/2024  
0700 Continuous 1600

FWD (Import)

REV (Export)

SCH - HQ\_CEDARS

95 MW

40 MW

Impacts Total Transfer Capability

175 MW

60 MW

TTC with All Lines In Service

270 MW

100 MW

### DENNISON-ROSEMNTB\_115\_2/22

Mon 10/21/2024 to Mon 10/21/2024  
0700 Continuous 1600

FWD (Import)

REV (Export)

SCH - HQ\_CEDARS

95 MW

40 MW

Impacts Total Transfer Capability

175 MW

60 MW

TTC with All Lines In Service

270 MW

100 MW

### SCH-HQ\_CEDARS-NYISO\_LIMIT\_80

Mon 10/21/2024 to Mon 10/21/2024  
0700 Continuous 1600

FWD (Import)

REV (Export)

SCH - HQ\_CEDARS

80 MW

Impacts Total Transfer Capability

190 MW

TTC with All Lines In Service

270 MW

### SCH-NE-NYISO\_LIMIT\_300

Mon 10/21/2024 to Tue 10/22/2024  
2300 Daily 0700

FWD (Import)

REV (Export)

SCH - NE - NY

500 MW

Impacts Total Transfer Capability

900 MW

TTC with All Lines In Service

1400 MW

### EGRDNCTY\_345\_138\_AT1

Tue 10/22/2024 to Thu 10/24/2024  
0001 Continuous 2200

FWD (Import)

REV (Export)

CONED - LIPA

1250 MW

Impacts Total Transfer Capability

250 MW

TTC with All Lines In Service

1500 MW

Work scheduled by: ConEd

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, September 28, 2024 to Friday, March 27, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### EGRDNCTY\_345\_138\_AT2

Tue 10/22/2024 to Thu 10/24/2024  
0001 Continuous 2200  
Work scheduled by: ConEd

CONED - LIPA **1250 MW**  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 1500 MW

FWD (Import) REV (Export)

### SPRNBK\_-EGRDNCTR\_345\_Y49

Tue 10/22/2024 to Thu 10/24/2024  
0001 Continuous 2200  
Work scheduled by: ConEd

CONED - LIPA **775 MW**  
Impacts Total Transfer Capability 725 MW  
TTC with All Lines In Service 1500 MW

FWD (Import) REV (Export)

### SCH-NE-NYISO\_LIMIT\_300

Tue 10/22/2024 to Wed 10/23/2024  
2300 Daily 0700  
Work scheduled by: ISONE

SCH - NE - NY **500 MW**  
Impacts Total Transfer Capability 900 MW  
TTC with All Lines In Service 1400 MW

FWD (Import) REV (Export)

### BECK\_-PACKARD\_230\_BP76

Wed 10/23/2024 to Sun 10/27/2024  
0600 Continuous 1730  
Work scheduled by: NGrid

SCH - OH - NY **1600 MW** **1050 MW**  
Impacts Total Transfer Capability 400 MW 550 MW  
TTC with All Lines In Service 2000 MW 1600 MW

FWD (Import) REV (Export)

### SCH-NE-NYISO\_LIMIT\_300

Wed 10/23/2024 to Thu 10/24/2024  
2300 Daily 0700  
Work scheduled by: ISONE

SCH - NE - NY **500 MW**  
Impacts Total Transfer Capability 900 MW  
TTC with All Lines In Service 1400 MW

FWD (Import) REV (Export)

### SCH-NE-NYISO\_LIMIT\_300

Thu 10/24/2024 to Fri 10/25/2024  
2300 Daily 0700  
Work scheduled by: ISONE

SCH - NE - NY **500 MW**  
Impacts Total Transfer Capability 900 MW  
TTC with All Lines In Service 1400 MW

FWD (Import) REV (Export)

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, September 28, 2024 to Friday, March 27, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_300

Fri 10/25/2024 to Sat 10/26/2024  
2300 Daily 0700

Work scheduled by: ISONE

SCH - NE - NY **500 MW**  
Impacts Total Transfer Capability 900 MW  
TTC with All Lines In Service 1400 MW

FWD (Import) REV (Export)

### SCH-NE-NYISO\_LIMIT\_300

Sat 10/26/2024 to Sun 10/27/2024  
2300 Daily 0700

Work scheduled by: ISONE

SCH - NE - NY **500 MW**  
Impacts Total Transfer Capability 900 MW  
TTC with All Lines In Service 1400 MW

FWD (Import) REV (Export)

### SCH-NE-NYISO\_LIMIT\_300

Sun 10/27/2024 to Mon 10/28/2024  
2300 Daily 0700

Work scheduled by: ISONE

SCH - NE - NY **500 MW**  
Impacts Total Transfer Capability 900 MW  
TTC with All Lines In Service 1400 MW

FWD (Import) REV (Export)

### ALCOA\_PA\_115KV\_R8105

Mon 10/28/2024 to Fri 11/15/2024  
0630 Continuous 1800

Work scheduled by: NGrid

MOSES SOUTH **3100 MW**  
Impacts Total Transfer Capability 50 MW  
TTC with All Lines In Service 3150 MW

FWD (Import) REV (Export)

### SCH-HQ\_CEDARS-NYISO\_LIMIT\_100

Mon 10/28/2024 to Fri 11/15/2024  
0630 Continuous 1800

Work scheduled by: NGrid

SCH - HQ\_CEDARS **100 MW**  
Impacts Total Transfer Capability 170 MW  
TTC with All Lines In Service 270 MW

FWD (Import) REV (Export)

### HOMR\_NYW-PIERC\_NY\_345\_48

Mon 10/28/2024 to Fri 11/01/2024  
0800 Continuous 1600

Work scheduled by: PJM

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, September 28, 2024 to Friday, March 27, 2026

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_300

Mon 10/28/2024 to Tue 10/29/2024  
2300 Daily 0700  
Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)  
**500 MW**  
Impacts Total Transfer Capability 900 MW  
TTC with All Lines In Service 1400 MW

### SCH-NE-NYISO\_LIMIT\_300

Tue 10/29/2024 to Wed 10/30/2024  
2300 Daily 0700  
Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)  
**500 MW**  
Impacts Total Transfer Capability 900 MW  
TTC with All Lines In Service 1400 MW

### SCH-NE-NYISO\_LIMIT\_300

Wed 10/30/2024 to Thu 10/31/2024  
2300 Daily 0700  
Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)  
**500 MW**  
Impacts Total Transfer Capability 900 MW  
TTC with All Lines In Service 1400 MW

### FROST\_BR-LONG\_MTN\_345\_352

Fri 11/01/2024 to Mon 11/04/2024  
0001 Continuous 1200  
Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)  
**1400 MW**  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 1400 MW

### SCH-NYISO-NE\_LIMIT\_800

Fri 11/01/2024 to Fri 11/01/2024  
0700 Continuous 1700  
Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)  
**1000 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 1800 MW

### MILLWOOD-EASTVIEW\_345\_W85

Sat 11/02/2024 to Sat 11/02/2024  
0001 Continuous 0030  
Work scheduled by: ConEd

UPDATED by ConEd 09/23/2024 07:54

UPNY CONED FWD (Import) REV (Export)  
**7810 MW**  
Impacts Total Transfer Capability 240 MW  
TTC with All Lines In Service 8050 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, September 28, 2024 to Friday, March 27, 2026

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SPRNBK\_345KV\_RNS3

Sat 11/02/2024 to Sat 11/02/2024  
0001 Continuous 0030

UPDATED by ConEd 09/23/2024 07:54

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

**3800 MW**

Impacts Total Transfer Capability

800 MW

TTC with All Lines In Service

4600 MW

### LONG\_MTN-CRICKVLY\_345\_398

Tue 11/05/2024 to Sat 11/30/2024  
0001 Continuous 2200

SCH - NPX\_1385

FWD (Import)

REV (Export)

**100 MW**

**100 MW**

Impacts Total Transfer Capability

100 MW

100 MW

TTC with All Lines In Service

200 MW

200 MW

### LONG\_MTN-CRICKVLY\_345\_398

Tue 11/05/2024 to Sat 11/30/2024  
0001 Continuous 2200

SCH - NE - NY

FWD (Import)

REV (Export)

**800 MW**

**1200 MW**

Impacts Total Transfer Capability

600 MW

600 MW

TTC with All Lines In Service

1400 MW

1800 MW

### MILLWOOD-EASTVIEW\_345\_W85

Wed 11/06/2024 to Wed 11/06/2024  
0130 Continuous 0200

UPDATED by ConEd 09/23/2024 07:54

UPNY CONED

FWD (Import)

REV (Export)

**7810 MW**

Impacts Total Transfer Capability

240 MW

TTC with All Lines In Service

8050 MW

### SPRNBK\_345KV\_RNS3

Wed 11/06/2024 to Wed 11/06/2024  
0130 Continuous 0200

UPDATED by ConEd 09/23/2024 07:54

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

**3800 MW**

Impacts Total Transfer Capability

800 MW

TTC with All Lines In Service

4600 MW

### DUNWODIE\_345KV\_6

Tue 11/12/2024 to Tue 11/12/2024  
0001 Continuous 0030

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

**3800 MW**

Impacts Total Transfer Capability

800 MW

TTC with All Lines In Service

4600 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, September 28, 2024 to Friday, March 27, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### DUNWODIE\_345KV\_8

Tue 11/12/2024 to Tue 11/12/2024  
0001 Continuous 0030  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

### LINDN\_CG-LNDVFT\_\_345\_V-3022

Tue 11/12/2024 to Tue 11/12/2024  
0800 Continuous 2359  
Work scheduled by: PJM

	FWD (Import)	REV (Export)
SCH - PJM_VFT	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	315 MW	315 MW
TTC with All Lines In Service	315 MW	315 MW

### HOMRC\_NY-MAINS\_NY\_345\_47

Wed 11/13/2024 to Wed 12/18/2024  
0800 Continuous 1600  
Work scheduled by: NYSEG

	FWD (Import)	REV (Export)
SCH - PJ - NY		
Impacts Total Transfer Capability		
TTC with All Lines In Service		

### DUNWODIE\_345KV\_6

Wed 11/13/2024 to Wed 11/13/2024  
2130 Continuous 2200  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

### DUNWODIE\_345KV\_8

Wed 11/13/2024 to Wed 11/13/2024  
2130 Continuous 2200  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

### MILLWOOD-EASTVIEW\_345\_W85

Thu 11/14/2024 to Thu 11/14/2024  
0001 Continuous 0030  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
UPNY CONED	<b>7810 MW</b>	
Impacts Total Transfer Capability	240 MW	
TTC with All Lines In Service	8050 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, September 28, 2024 to Friday, March 27, 2026

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>SPRNBK__345KV_RNS3</b>					FWD (Import)	REV (Export)
Thu 11/14/2024	to	Thu 11/14/2024		SPR/DUN-SOUTH	<b>3800 MW</b>	
0001	Continuous	0030		Impacts Total Transfer Capability	800 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	4600 MW	
<b>OSWEGO__VOLNEY__345_12</b>					FWD (Import)	REV (Export)
Fri 11/15/2024	to	Mon 11/25/2024	<u>UPDATED by NGrid 09/10/2024 12:14</u>	OSWEGO EXPORT	<b>5250 MW</b>	
0730	Continuous	1600		Impacts Total Transfer Capability	0 MW	
Work scheduled by: NGrid				TTC with All Lines In Service	5250 MW	
<b>CHATGUAY-MASSENA__765_7040</b>					FWD (Import)	REV (Export)
Sat 11/16/2024	to	Fri 11/29/2024		SCH - HQ - NY	<b>0 MW</b>	<b>0 MW</b>
0001	Continuous	2359		Impacts Total Transfer Capability	1500 MW	1000 MW
Work scheduled by: NYPA				TTC with All Lines In Service	1500 MW	1000 MW
<b>CHATGUAY-MASSENA__765_7040</b>					FWD (Import)	REV (Export)
Sat 11/16/2024	to	Fri 11/29/2024		MOSES SOUTH	<b>1550 MW</b>	
0001	Continuous	2359		Impacts Total Transfer Capability	1600 MW	
Work scheduled by: NYPA				TTC with All Lines In Service	3150 MW	
<b>CHATGUAY-MASSENA__765_7040 , MASSENA-MARCY__765_MSU1</b>					FWD (Import)	REV (Export)
Sat 11/16/2024	to	Fri 11/29/2024		MOSES SOUTH	<b>500 MW</b>	
0001		2359		Impacts Total Transfer Capability	2650 MW	
Work scheduled by:				TTC with All Lines In Service	3150 MW	
<b>MARCY__765_345_AT1</b>					FWD (Import)	REV (Export)
Sat 11/16/2024	to	Fri 11/29/2024		MOSES SOUTH	<b>1750 MW</b>	
0001	Continuous	2359	ARR: 19	Impacts Total Transfer Capability	1400 MW	
Work scheduled by: NYPA				TTC with All Lines In Service	3150 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, September 28, 2024 to Friday, March 27, 2026

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MARCY\_\_\_765\_345\_AT2

Sat 11/16/2024 to Fri 11/29/2024

0001 Continuous 2359

Work scheduled by: NYPA

ARR: 19

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**1700 MW**

1450 MW

3150 MW

### MASSENA\_-MARCY\_\_\_765\_MSU1

Sat 11/16/2024 to Fri 11/29/2024

0001 Continuous 2359

Work scheduled by: NYPA

SCH - HQ\_CEDARS

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**90 MW**

189 MW

279 MW

### MASSENA\_-MARCY\_\_\_765\_MSU1

Sat 11/16/2024 to Fri 11/29/2024

0001 Continuous 2359

Work scheduled by: NYPA

SCH - HQ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**475 MW**

**1000 MW**

1025 MW

0 MW

1500 MW

1000 MW

### MASSENA\_-MARCY\_\_\_765\_MSU1

Sat 11/16/2024 to Fri 11/29/2024

0001 Continuous 2359

Work scheduled by: NYPA

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**500 MW**

2650 MW

3150 MW

### MASSENA\_-MARCY\_\_\_765\_MSU1

Sat 11/16/2024 to Fri 11/29/2024

0001 Continuous 2359

Work scheduled by: NYPA

CENTRAL EAST - VC

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**2595 MW**

1130 MW

3725 MW

### MOSES\_\_\_-MASSENA\_230\_MMS1 , MOSES\_\_\_-MASSENA\_230\_MMS2

Sat 11/16/2024 to Fri 11/29/2024

0001 2359

Work scheduled by:

SCH - HQ\_CEDARS

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**90 MW**

189 MW

279 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, September 28, 2024 to Friday, March 27, 2026

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MOSES\_\_-MASSENA\_230\_MMS1 , MOSES\_\_-MASSENA\_230\_MMS2

Sat 11/16/2024 to Fri 11/29/2024  
0001 2359

Work scheduled by:

SCH - HQ - NY

FWD (Import)

REV (Export)

**850 MW**

**0 MW**

Impacts Total Transfer Capability

650 MW

1000 MW

TTC with All Lines In Service

1500 MW

1000 MW

### W49TH\_ST\_345KV\_8

Sun 11/17/2024 to Sat 11/30/2024  
0001 Continuous 0200

Work scheduled by: ConEd

UPDATED by ConEd 09/18/2024 15:33

SCH - PJM\_HTP

FWD (Import)

REV (Export)

**310 MW**

Impacts Total Transfer Capability

350 MW

TTC with All Lines In Service

660 MW

### MILLWOOD-EASTVIEW\_345\_W85

Mon 11/18/2024 to Mon 11/18/2024  
0130 Continuous 0200

Work scheduled by: ConEd

UPNY CONED

FWD (Import)

REV (Export)

**7810 MW**

Impacts Total Transfer Capability

240 MW

TTC with All Lines In Service

8050 MW

### SPRNBK\_345KV\_RNS3

Mon 11/18/2024 to Mon 11/18/2024  
0130 Continuous 0200

Work scheduled by: ConEd

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

**3800 MW**

Impacts Total Transfer Capability

800 MW

TTC with All Lines In Service

4600 MW

### MILLWOOD-EASTVIEW\_345\_W99

Mon 11/18/2024 to Fri 11/22/2024  
0201 Continuous 2200

Work scheduled by: ConEd

UPNY CONED

FWD (Import)

REV (Export)

**7810 MW**

Impacts Total Transfer Capability

240 MW

TTC with All Lines In Service

8050 MW

### W49TH\_ST\_345KV\_6

Tue 11/19/2024 to Tue 12/17/2024  
0201 Continuous 0200

Work scheduled by: ConEd

UPDATED by ConEd 09/18/2024 15:33

SCH - PJM\_HTP

FWD (Import)

REV (Export)

**310 MW**

Impacts Total Transfer Capability

350 MW

TTC with All Lines In Service

660 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, September 28, 2024 to Friday, March 27, 2026

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### W49TH\_ST-E13THSTA\_345\_M55

Tue 11/19/2024 to Tue 12/17/2024  
0201 Continuous 0200

UPDATED by ConEd 09/18/2024 15:33

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

**3800 MW**

Impacts Total Transfer Capability

800 MW

TTC with All Lines In Service

4600 MW

Work scheduled by: ConEd

### LINDN\_CG-LNDVFT\_345\_V-3022

Fri 11/22/2024 to Fri 11/22/2024  
1500 Continuous 1800

SCH - PJM\_VFT

FWD (Import)

REV (Export)

**0 MW**

**0 MW**

Impacts Total Transfer Capability

315 MW

315 MW

TTC with All Lines In Service

315 MW

315 MW

Work scheduled by: PJM

### E13THSTA-FARRAGUT\_345\_46

Sun 11/24/2024 to Sat 11/30/2024  
0001 Continuous 0200

CANCELLED by TO 09/27/2024 10:33

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

**3800 MW**

Impacts Total Transfer Capability

800 MW

TTC with All Lines In Service

4600 MW

Work scheduled by: ConEd

### KNICRBKR-PLSNTVLY\_345\_Y57

Sun 12/01/2024 to Sun 12/22/2024  
0530 Continuous 1830

ARR: 78

UPNY CONED

FWD (Import)

REV (Export)

**7885 MW**

Impacts Total Transfer Capability

165 MW

TTC with All Lines In Service

8050 MW

Work scheduled by: NGrid

### ADIRNDCK-PORTER\_230\_12

Mon 12/02/2024 to Tue 12/24/2024  
0530 Continuous 1700

MOSES SOUTH

FWD (Import)

REV (Export)

**2300 MW**

Impacts Total Transfer Capability

850 MW

TTC with All Lines In Service

3150 MW

Work scheduled by: NGrid

### OSWEGO\_-VOLNEY\_345\_11

Tue 12/03/2024 to Fri 12/13/2024  
0700 Continuous 1700

OSWEGO EXPORT

FWD (Import)

REV (Export)

**5250 MW**

Impacts Total Transfer Capability

0 MW

TTC with All Lines In Service

5250 MW

Work scheduled by: NGrid

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, September 28, 2024 to Friday, March 27, 2026

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SPRNBK-TREMONT\_345\_X28

Mon 12/16/2024 to Tue 12/17/2024  
0001 Continuous 1800  
Work scheduled by: ConEd

UPDATED by ConEd 08/30/2024 14:08

SPR/DUN-SOUTH **4200 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

### W49TH\_ST\_345KV\_5

Mon 12/16/2024 to Thu 12/19/2024  
0001 Continuous 0200  
Work scheduled by: ConEd

UPDATED by ConEd 09/09/2024 09:31

SCH - PJM\_HTP **300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

### W49TH\_ST\_345KV\_7

Mon 12/16/2024 to Mon 12/23/2024  
0001 Continuous 0200  
Work scheduled by: ConEd

UPDATED by ConEd 09/09/2024 09:31

SCH - PJM\_HTP **300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

### E13THSTA-FARRAGUT\_345\_46

Wed 12/18/2024 to Fri 12/20/2024  
0201 Continuous 0300  
Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

### MILLWOOD-EASTVIEW\_345\_W99

Fri 12/20/2024 to Fri 12/20/2024  
0001 Continuous 2200  
Work scheduled by: ConEd

UPNY CONED **7810 MW**  
Impacts Total Transfer Capability 240 MW  
TTC with All Lines In Service 8050 MW

FWD (Import) REV (Export)

### W49TH\_ST\_345KV\_5

Tue 12/24/2024 to Tue 12/24/2024  
0130 Continuous 0200  
Work scheduled by: ConEd

UPDATED by ConEd 09/09/2024 09:31

SCH - PJM\_HTP **300 MW**  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, September 28, 2024 to Friday, March 27, 2026

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### W49TH\_ST\_345KV\_7

Tue 12/24/2024 to Tue 12/24/2024  
0130 Continuous 0200

UPDATED by ConEd 09/09/2024 09:31

SCH - PJM\_HTP

FWD (Import)

REV (Export)

300 MW

Impacts Total Transfer Capability

360 MW

TTC with All Lines In Service

660 MW

Work scheduled by: ConEd

### ADIRNDCK-PORTER\_\_230\_12

Thu 01/02/2025 to Sat 05/31/2025  
0530 Continuous 1700

MOSES SOUTH

FWD (Import)

REV (Export)

2300 MW

Impacts Total Transfer Capability

850 MW

TTC with All Lines In Service

3150 MW

Work scheduled by: NGrid

### KNICRBKR-PLSNTVLY\_345\_Y57

Thu 01/02/2025 to Wed 01/15/2025  
0530 Continuous 1830

ARR: 78

UPNY CONED

FWD (Import)

REV (Export)

7885 MW

Impacts Total Transfer Capability

165 MW

TTC with All Lines In Service

8050 MW

Work scheduled by: NGrid

### DUNWODIE\_345KV\_5

Sat 01/04/2025 to Sun 01/05/2025  
0001 Continuous 0259

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

3800 MW

Impacts Total Transfer Capability

800 MW

TTC with All Lines In Service

4600 MW

Work scheduled by: ConEd

### DUNWODIE\_345KV\_7

Sat 01/04/2025 to Sun 01/05/2025  
0001 Continuous 0259

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

3800 MW

Impacts Total Transfer Capability

800 MW

TTC with All Lines In Service

4600 MW

Work scheduled by: ConEd

### SPRNBKR\_345KV\_RNS3

Sat 01/04/2025 to Sun 01/05/2025  
0001 Continuous 0259

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

3800 MW

Impacts Total Transfer Capability

800 MW

TTC with All Lines In Service

4600 MW

Work scheduled by: ConEd

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, September 28, 2024 to Friday, March 27, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SPRNBK-DUNWODIE\_345\_W75

Sat 01/04/2025 to Sun 01/05/2025  
 0001 Continuous 0259  
 Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

### OSWEGO-ELBRIDGE\_345\_17

Mon 01/06/2025 to Fri 01/31/2025  
 0630 Continuous 1730  
 Work scheduled by: NGrid

ARR: 75

	FWD (Import)	REV (Export)
OSWEGO EXPORT	<b>5250 MW</b>	
Impacts Total Transfer Capability	0 MW	
TTC with All Lines In Service	5250 MW	

### E13THSTA-FARRAGUT\_345\_46

Tue 01/14/2025 to Sun 01/19/2025  
 0001 Continuous 0300  
 Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

### BUCHAN\_S-MILLWOOD\_345\_W97

Wed 01/15/2025 to Sat 01/18/2025  
 0200 Continuous 0159  
 Work scheduled by: ConEd

	FWD (Import)	REV (Export)
UPNY CONED	<b>8015 MW</b>	
Impacts Total Transfer Capability	35 MW	
TTC with All Lines In Service	8050 MW	

### BUCHAN\_S-MILLWOOD\_345\_W98

Sat 01/18/2025 to Tue 01/21/2025  
 0200 Continuous 0200  
 Work scheduled by: ConEd

	FWD (Import)	REV (Export)
UPNY CONED	<b>8015 MW</b>	
Impacts Total Transfer Capability	35 MW	
TTC with All Lines In Service	8050 MW	

### KNICRBKR-ALPS\_345\_6

Mon 01/20/2025 to Tue 01/21/2025  
 0530 Continuous 1830  
 Work scheduled by: NGrid

	FWD (Import)	REV (Export)
SCH - NE - NY	<b>900 MW</b>	
Impacts Total Transfer Capability	500 MW	
TTC with All Lines In Service	1400 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, September 28, 2024 to Friday, March 27, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>KNICRBKR-ALPS__345_6</b>					FWD (Import)	REV (Export)
Mon 01/20/2025	to	Tue 01/21/2025		SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
0530	Continuous	1830		Impacts Total Transfer Capability	100 MW	100 MW
Work scheduled by: NGrid				TTC with All Lines In Service	200 MW	200 MW
<b>HOPATCON-RAMAPO__500_5018</b>					FWD (Import)	REV (Export)
Wed 01/29/2025	to	Sat 02/01/2025		SCH - PJ - NY	<b>1400 MW</b>	<b>1200 MW</b>
0001	Continuous	0200		Impacts Total Transfer Capability	1150 MW	1450 MW
Work scheduled by: PJM				TTC with All Lines In Service	2550 MW	2650 MW
<b>HOPATCON-RAMAPO__500_5018</b>					FWD (Import)	REV (Export)
Wed 01/29/2025	to	Sat 02/01/2025		UPNY CONED	<b>7795 MW</b>	
0001	Continuous	0200		Impacts Total Transfer Capability	255 MW	
Work scheduled by: PJM				TTC with All Lines In Service	8050 MW	
<b>HOPATCON-RAMAPO__500_5018</b>					FWD (Import)	REV (Export)
Wed 01/29/2025	to	Sat 02/01/2025		TOTAL EAST	<b>6800 MW</b>	
0001	Continuous	0200		Impacts Total Transfer Capability	-650 MW	
Work scheduled by: PJM				TTC with All Lines In Service	6150 MW	
<b>RAMAPO__345_345_PAR3500</b>					FWD (Import)	REV (Export)
Wed 01/29/2025	to	Sat 02/01/2025		SCH - PJ - NY		<b>1250 MW</b>
0001	Continuous	0200		Impacts Total Transfer Capability		1400 MW
Work scheduled by: PJM				TTC with All Lines In Service		2650 MW
<b>RAMAPO__345_345_PAR4500</b>					FWD (Import)	REV (Export)
Wed 01/29/2025	to	Sat 02/01/2025		SCH - PJ - NY		<b>1250 MW</b>
0001	Continuous	0200		Impacts Total Transfer Capability		1400 MW
Work scheduled by: PJM				TTC with All Lines In Service		2650 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, September 28, 2024 to Friday, March 27, 2026

CENTRAL EAST 7550 MW  
 CENTRAL EAST - VC 3725 MW  
 TOTAL EAST 6150 MW  
 UPNY CONED 8050 MW  
 SPR/DUN-SOUTH 4600 MW  
 DYSINGER EAST 3200 MW  
 MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>RAMAPO__500_345_BK_1500</b>					FWD (Import)	REV (Export)
Wed 01/29/2025	to	Sat 02/01/2025		SCH - PJ - NY	<b>1400 MW</b>	<b>1200 MW</b>
0001	Continuous	0200		Impacts Total Transfer Capability	1150 MW	1450 MW
Work scheduled by: PJM				TTC with All Lines In Service	2550 MW	2650 MW
<b>RAMAPO__500_345_BK_1500</b>					FWD (Import)	REV (Export)
Wed 01/29/2025	to	Sat 02/01/2025		UPNY CONED	<b>7795 MW</b>	
0001	Continuous	0200		Impacts Total Transfer Capability	255 MW	
Work scheduled by: PJM				TTC with All Lines In Service	8050 MW	
<b>ELBRIDGE-LAFAYTTE_345_17-LE</b>					FWD (Import)	REV (Export)
Wed 01/29/2025	to	Fri 01/31/2025		OSWEGO EXPORT	<b>5250 MW</b>	
0700	Continuous	1730	ARR: 75	Impacts Total Transfer Capability	0 MW	
Work scheduled by: NGrid				TTC with All Lines In Service	5250 MW	
<b>MILLWOOD-EASTVIEW_345_W82</b>					FWD (Import)	REV (Export)
Mon 02/10/2025	to	Fri 02/14/2025		UPNY CONED	<b>7810 MW</b>	
0001	Continuous	2200		Impacts Total Transfer Capability	240 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	8050 MW	
<b>WOOD_ST_-PLSNTVLE_345_Y86</b>					FWD (Import)	REV (Export)
Mon 02/17/2025	to	Mon 02/17/2025		UPNY CONED	<b>7475 MW</b>	
0001	Continuous	0030		Impacts Total Transfer Capability	575 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	8050 MW	
<b>WOOD_ST_-PLSNTVLE_345_Y86</b>					FWD (Import)	REV (Export)
Fri 02/21/2025	to	Fri 02/21/2025		UPNY CONED	<b>7475 MW</b>	
0130	Continuous	0200		Impacts Total Transfer Capability	575 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	8050 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, September 28, 2024 to Friday, March 27, 2026

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### NIAGARA\_ROBNSNRD\_230\_64

Fri 03/28/2025 to Fri 03/28/2025  
0500 Continuous 1900  
Work scheduled by: NYPA

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 1900 MW  
REV (Export) 0 MW  
1900 MW

### MOTTHAVN-RAINEY\_\_345\_Q11

Sat 04/05/2025 to Sun 04/13/2025  
0101 Continuous 0300  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 3800 MW  
REV (Export) 800 MW  
4600 MW

### NIAGARA\_DYSINGER\_345\_ND2

Mon 04/07/2025 to Fri 04/11/2025  
0500 Continuous 1730  
Work scheduled by: NYPA

DYSINGER EAST  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 2700 MW  
REV (Export) 500 MW  
3200 MW

### LINDN\_CG-LNDVFT\_\_345\_V-3022

Mon 04/07/2025 to Sat 04/12/2025  
0800 Continuous 1500  
Work scheduled by: PJM

SCH - PJM\_VFT  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 0 MW  
REV (Export) 0 MW  
315 MW  
315 MW

### NIAGARA\_DYSINGER\_345\_ND2

Mon 04/14/2025 to Thu 04/17/2025  
0500 Continuous 1730  
Work scheduled by: NYPA

DYSINGER EAST  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 2700 MW  
REV (Export) 500 MW  
3200 MW

### E13THSTA-FARRAGUT\_345\_45

Tue 04/15/2025 to Sun 04/20/2025  
0001 Continuous 0200  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 3800 MW  
REV (Export) 800 MW  
4600 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, September 28, 2024 to Friday, March 27, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### W49TH\_ST-E13THSTA\_345\_M54

Tue 04/15/2025 to Sun 04/20/2025  
0001 Continuous 0200  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

### LINDN\_CG-LNDVFT\_345\_V-3022

Thu 04/17/2025 to Thu 04/17/2025  
1500 Continuous 1800  
Work scheduled by: PJM

	FWD (Import)	REV (Export)
SCH - PJM_VFT	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	315 MW	315 MW
TTC with All Lines In Service	315 MW	315 MW

### NIAGARA\_PACKARD\_230\_61

Mon 04/21/2025 to Fri 04/25/2025  
0500 Continuous 1900  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - OH - NY	<b>2200 MW</b>	<b>1850 MW</b>
Impacts Total Transfer Capability	250 MW	50 MW
TTC with All Lines In Service	2450 MW	1900 MW

### PANNELL-CLAY\_345\_1

Mon 04/21/2025 to Fri 04/25/2025  
0700 Continuous 1530  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
WEST CENTRAL	<b>1300 MW</b>	
Impacts Total Transfer Capability	950 MW	
TTC with All Lines In Service	2250 MW	

### PANNELL-CLAY\_345\_2

Mon 04/28/2025 to Fri 05/02/2025  
0700 Continuous 1530  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
WEST CENTRAL	<b>1300 MW</b>	
Impacts Total Transfer Capability	950 MW	
TTC with All Lines In Service	2250 MW	

### LONG\_MTN-CRICKVLY\_345\_398

Tue 05/06/2025 to Thu 05/29/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, September 28, 2024 to Friday, March 27, 2026

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### LONG\_MTN-CRICKVLY\_345\_398

Tue 05/06/2025 to Thu 05/29/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - NE - NY	800 MW	1200 MW
Impacts Total Transfer Capability	600 MW	400 MW
TTC with All Lines In Service	1400 MW	1600 MW

### NEPTUNE-DUFFYAVE\_345\_NEPTUNE

Mon 05/12/2025 to Fri 05/16/2025  
0600 Continuous 1600  
Work scheduled by: LI

	FWD (Import)	REV (Export)
SCH - PJM_NEPTUNE	0 MW	
Impacts Total Transfer Capability	660 MW	
TTC with All Lines In Service	660 MW	

### NEWBRDGE\_345\_138\_BK\_1

Mon 05/12/2025 to Fri 05/16/2025  
0600 Continuous 1600  
Work scheduled by: LI

	FWD (Import)	REV (Export)
SCH - PJM_NEPTUNE	375 MW	
Impacts Total Transfer Capability	285 MW	
TTC with All Lines In Service	660 MW	

### NEWBRDGE\_345\_138\_BK\_2

Mon 05/12/2025 to Fri 05/16/2025  
0600 Continuous 1600  
Work scheduled by: LI

	FWD (Import)	REV (Export)
SCH - PJM_NEPTUNE	375 MW	
Impacts Total Transfer Capability	285 MW	
TTC with All Lines In Service	660 MW	

### NEWBRDGE-DUFFYAVE\_345\_501

Mon 05/12/2025 to Fri 05/16/2025  
0600 Continuous 1600  
Work scheduled by: LI

	FWD (Import)	REV (Export)
SCH - PJM_NEPTUNE	0 MW	
Impacts Total Transfer Capability	660 MW	
TTC with All Lines In Service	660 MW	

### DYSINGER-ST\_255\_345\_DH1

Tue 09/02/2025 to Mon 09/15/2025  
0500 Continuous 2100  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
DYSINGER EAST	2850 MW	
Impacts Total Transfer Capability	350 MW	
TTC with All Lines In Service	3200 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, September 28, 2024 to Friday, March 27, 2026

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### GOETHALS\_345KV\_5

Mon 09/08/2025 to Mon 09/08/2025  
0301 Continuous 0330  
Work scheduled by: ConEd

STATEN ISLAND  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### CLAY\_-EDIC\_345\_2-15

Mon 09/08/2025 to Fri 09/12/2025  
0700 Continuous 1530  
Work scheduled by: NYPA

OSWEGO EXPORT  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**4850 MW**  
400 MW  
5250 MW

### MOSES\_-ADIRNDCK\_230\_MA1

Tue 09/09/2025 to Sun 10/12/2025  
0700 Continuous 1730  
Work scheduled by: NYPA

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**2100 MW**  
1050 MW  
3150 MW

### GOETHALS\_345KV\_5

Tue 09/09/2025 to Tue 09/09/2025  
2330 Continuous 2359  
Work scheduled by: ConEd

STATEN ISLAND  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### GOETHALS\_345KV\_5

Mon 09/15/2025 to Mon 09/15/2025  
0230 Continuous 0300  
Work scheduled by: ConEd

STATEN ISLAND  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### ADIRNDCK-PORTER\_230\_12

Mon 09/15/2025 to Sun 10/12/2025  
0600 Continuous 1700  
Work scheduled by: NGrid

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**2100 MW**  
1050 MW  
3150 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, September 28, 2024 to Friday, March 27, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### DYSINGER-ST\_A\_255\_345\_DH2

Tue 09/16/2025 to Tue 10/28/2025  
0500 Continuous 1900  
Work scheduled by: NYPA

DYSINGER EAST	FWD (Import)	REV (Export)
	<b>2850 MW</b>	
Impacts Total Transfer Capability	350 MW	
TTC with All Lines In Service	3200 MW	

### PANNELL\_-CLAY\_\_\_345\_1

Mon 09/29/2025 to Fri 10/03/2025  
0700 Continuous 1530  
Work scheduled by: NYPA

WEST CENTRAL	FWD (Import)	REV (Export)
	<b>1300 MW</b>	
Impacts Total Transfer Capability	950 MW	
TTC with All Lines In Service	2250 MW	

### PANNELL\_-CLAY\_\_\_345\_2

Mon 10/06/2025 to Fri 10/10/2025  
0700 Continuous 1530  
Work scheduled by: NYPA

WEST CENTRAL	FWD (Import)	REV (Export)
	<b>1300 MW</b>	
Impacts Total Transfer Capability	950 MW	
TTC with All Lines In Service	2250 MW	

### NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE

Mon 10/13/2025 to Thu 10/16/2025  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM_NEPTUNE	FWD (Import)	REV (Export)
	<b>0 MW</b>	
Impacts Total Transfer Capability	660 MW	
TTC with All Lines In Service	660 MW	

### NEWBRDGE\_345\_138\_BK\_1

Mon 10/13/2025 to Thu 10/16/2025  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM_NEPTUNE	FWD (Import)	REV (Export)
	<b>375 MW</b>	
Impacts Total Transfer Capability	285 MW	
TTC with All Lines In Service	660 MW	

### NEWBRDGE\_345\_138\_BK\_2

Mon 10/13/2025 to Thu 10/16/2025  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM_NEPTUNE	FWD (Import)	REV (Export)
	<b>375 MW</b>	
Impacts Total Transfer Capability	285 MW	
TTC with All Lines In Service	660 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, September 28, 2024 to Friday, March 27, 2026

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### NEWBRDGE-DUFFYAVE\_345\_501

Mon 10/13/2025 to Thu 10/16/2025  
0600 Continuous 1600

Work scheduled by: LI

SCH - PJM\_NEPTUNE

FWD (Import)

REV (Export)

**0 MW**

Impacts Total Transfer Capability

660 MW

TTC with All Lines In Service

660 MW

### MOSES\_\_-ADIRNDCK\_230\_MA2

Mon 10/13/2025 to Mon 11/24/2025  
0700 Continuous 1730

Work scheduled by: NYPA

MOSES SOUTH

FWD (Import)

REV (Export)

**2100 MW**

Impacts Total Transfer Capability

1050 MW

TTC with All Lines In Service

3150 MW

### EDIC\_\_-PRINCTWN\_345\_351

Tue 10/14/2025 to Fri 10/17/2025  
0600 Continuous 1830

Work scheduled by: NGrid

CENTRAL EAST - VC

FWD (Import)

REV (Export)

**3335 MW**

Impacts Total Transfer Capability

390 MW

TTC with All Lines In Service

3725 MW

### MARION\_-FARRAGUT\_345\_C3403

Sat 11/01/2025 to Mon 11/03/2025  
0001 Continuous 0300

Work scheduled by: ConEd

SCH - PJ - NY

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

TTC with All Lines In Service

### CHATGUAY-MASSENA\_765\_7040

Sun 11/16/2025 to Sun 11/30/2025  
0001 Continuous 2359

Work scheduled by: NYPA

SCH - HQ - NY

FWD (Import)

REV (Export)

**0 MW**

**0 MW**

Impacts Total Transfer Capability

1500 MW

1000 MW

TTC with All Lines In Service

1500 MW

1000 MW

### CHATGUAY-MASSENA\_765\_7040

Sun 11/16/2025 to Sun 11/30/2025  
0001 Continuous 2359

Work scheduled by: NYPA

MOSES SOUTH

FWD (Import)

REV (Export)

**1550 MW**

Impacts Total Transfer Capability

1600 MW

TTC with All Lines In Service

3150 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, September 28, 2024 to Friday, March 27, 2026

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MOSES__-MASSENA_230_MMS1 , MOSES__-MASSENA_230_MMS2</b>					FWD (Import)	REV (Export)
Sun 11/16/2025	to	Sun 11/30/2025		SCH - HQ_CEDARS	<b>90 MW</b>	
0001		2359		Impacts Total Transfer Capability	189 MW	
Work scheduled by:				TTC with All Lines In Service	279 MW	
<b>MOSES__-MASSENA_230_MMS1 , MOSES__-MASSENA_230_MMS2</b>					FWD (Import)	REV (Export)
Sun 11/16/2025	to	Sun 11/30/2025		SCH - HQ - NY	<b>850 MW</b>	<b>0 MW</b>
0001		2359		Impacts Total Transfer Capability	650 MW	1000 MW
Work scheduled by:				TTC with All Lines In Service	1500 MW	1000 MW
<b>MOSES__-MASSENA_230_MMS1 , MOSES__-MASSENA_230_MMS2 , MOSES__-ADIRNDCK_230_MA2</b>					FWD (Import)	REV (Export)
Sun 11/16/2025	to	Mon 11/24/2025		SCH - HQ_CEDARS	<b>90 MW</b>	
0001		1730		Impacts Total Transfer Capability	189 MW	
Work scheduled by:				TTC with All Lines In Service	279 MW	
<b>MARION__FARRAGUT_345_C3403</b>					FWD (Import)	REV (Export)
Wed 12/10/2025	to	Mon 12/15/2025		SCH - PJ - NY		
0001	Continuous	0300		Impacts Total Transfer Capability		
Work scheduled by: ConEd				TTC with All Lines In Service		
<b>GOETHALS_345KV_5</b>					FWD (Import)	REV (Export)
Sat 01/17/2026	to	Sat 01/17/2026	<u>UPDATED by ConEd 07/10/2024 16:09</u>	STATEN ISLAND		
0301	Continuous	0330		Impacts Total Transfer Capability		
Work scheduled by: ConEd				TTC with All Lines In Service		
<b>DYSINGER-STA_255_345_DH2</b>					FWD (Import)	REV (Export)
Mon 03/02/2026	to	Fri 03/13/2026		DYSINGER EAST	<b>2850 MW</b>	
0500	Continuous	1900		Impacts Total Transfer Capability	350 MW	
Work scheduled by: NYPA				TTC with All Lines In Service	3200 MW	

**Saturday, September 28, 2024 to Friday, March 27, 2026**

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

<b>DYSINGER-STA_255_345_DH1</b>			FWD (Import)	REV (Export)
Mon 03/16/2026	to	Tue 04/07/2026	DYSINGER EAST	<b>2850 MW</b>
0500	Continuous	2100	Impacts Total Transfer Capability	350 MW
Work scheduled by: NYPA			TTC with All Lines In Service	3200 MW