

NYISO TRANSFER LIMITATIONS

Seasonal Limits		Sunday, November 10, 2024 to Saturday, May 9, 2026				
CENTRAL EAST	7550 MW	<b>The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.</b>				
CENTRAL EAST - VC	3725 MW					
TOTAL EAST	6150 MW					
UPNY CONED	8050 MW					
SPR/DUN-SOUTH	4600 MW					
DYSINGER EAST	3200 MW					
MOSES SOUTH	3150 MW					
HUDSONP_-FARRAGUT_345_B3402					FWD (Import)	REV (Export)
Mon 01/15/2018	to	Wed 04/30/2025	<u>EXT FORCED by ConEd 03/11/2024 11:26</u>	SCH - PJ - NY		
0001	Continuous	2359		Impacts Total Transfer Capability		
Work scheduled by: ConEd				TTC with All Lines In Service		
MARION_-FARRAGUT_345_C3403					FWD (Import)	REV (Export)
Mon 01/15/2018	to	Wed 04/30/2025	<u>EXT FORCED by ConEd 03/11/2024 11:26</u>	SCH - PJ - NY		
0001	Continuous	2359		Impacts Total Transfer Capability		
Work scheduled by: ConEd				TTC with All Lines In Service		
MARION_-FARRAGUT_345_C3403 , HUDSONP_-FARRAGUT_345_B3402					FWD (Import)	REV (Export)
Mon 01/15/2018	to	Wed 04/30/2025		SCH - PJ - NY	<b>2400 MW</b>	<b>2400 MW</b>
0001		2359		Impacts Total Transfer Capability	200 MW	300 MW
Work scheduled by:				TTC with All Lines In Service	2600 MW	2700 MW
SCH-HQ_CEDARS-NYISO_LIMIT_240					FWD (Import)	REV (Export)
Mon 03/11/2024	to	Thu 12/05/2024	<u>EXTENDED by HQ, 10/28/2024 10:45</u>	SCH - HQ_CEDARS	<b>240 MW</b>	
0800	Continuous	1900		Impacts Total Transfer Capability	39 MW	
Work scheduled by: HQ				TTC with All Lines In Service	279 MW	
SCH-NYISO-HQ_CEDARS_LIMIT_0					FWD (Import)	REV (Export)
Mon 03/11/2024	to	Thu 12/05/2024	<u>EXTENDED by HQ, 10/28/2024 10:45</u>	SCH - HQ_CEDARS		<b>0 MW</b>
0800	Continuous	1900		Impacts Total Transfer Capability		100 MW
Work scheduled by: HQ				TTC with All Lines In Service		100 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, November 10, 2024 to Saturday, May 9, 2026

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MARCY\_\_345KV\_CSC

Sat 06/15/2024 to Sat 05/24/2025  
0001 Continuous 2359  
Work scheduled by: NYPA

FORCED by NYPA 06/11/2024 15:44

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3650 MW**  
75 MW  
3725 MW

### CHASLAKE-PORTER\_\_230\_11

Tue 09/03/2024 to Fri 11/15/2024  
0530 Continuous 2000  
Work scheduled by: NGrid

UPDATED by NGrid 08/29/2024 09:15

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**2300 MW**  
850 MW  
3150 MW

### W49TH\_ST\_345KV\_6

Fri 09/27/2024 to Thu 12/05/2024  
0101 Continuous 0200  
Work scheduled by: ConEd

UPDATED by ConEd 09/25/2024 08:24

SCH - PJM\_HTP  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**300 MW**  
360 MW  
660 MW

### W49TH\_ST-E13THSTA\_345\_M55

Fri 09/27/2024 to Thu 12/05/2024  
0101 Continuous 0200  
Work scheduled by: ConEd

UPDATED by ConEd 09/25/2024 08:24

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3800 MW**  
800 MW  
4600 MW

### MARCY\_\_765\_345\_AT1

Mon 10/14/2024 to Fri 11/29/2024  
2110 Continuous 2359  
Work scheduled by: NYPA

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1750 MW**  
1400 MW  
3150 MW

### ALCOA\_PA\_115KV\_R8105

Mon 10/28/2024 to Fri 11/15/2024  
0630 Continuous 1800  
Work scheduled by: NGrid

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3100 MW**  
50 MW  
3150 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, November 10, 2024 to Saturday, May 9, 2026

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-HQ\_CEDARS-NYISO\_LIMIT\_100

Mon 10/28/2024 to Fri 11/15/2024  
0630 Continuous 1800  
Work scheduled by: NGrid

SCH - HQ\_CEDARS FWD (Import) REV (Export)  
**100 MW**  
Impacts Total Transfer Capability 179 MW  
TTC with All Lines In Service 279 MW

### SCH-IMO-NYISO\_LIMIT\_1900

Fri 11/01/2024 to Wed 04/30/2025  
0001 Continuous 2359  
Work scheduled by: IESO

SCH - OH - NY FWD (Import) REV (Export)  
**2200 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 2500 MW

### CHAT\_DC\_GC1

Mon 11/04/2024 to Fri 11/29/2024  
0500 Continuous 0600  
Work scheduled by: HQ

UPDATED by HQ, 11/03/2024 12:27

MOSES SOUTH FWD (Import) REV (Export)  
**2850 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 3150 MW

### CHAT\_DC\_GC1

Mon 11/04/2024 to Fri 11/29/2024  
0500 Continuous 0600  
Work scheduled by: HQ

UPDATED by HQ, 11/03/2024 12:27

SCH - HQ - NY FWD (Import) REV (Export)  
**500 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 1000 MW

### SCH-HQ-NYISO\_LIMIT\_1100

Mon 11/04/2024 to Fri 11/29/2024  
0500 Continuous 0600  
Work scheduled by: HQ

UPDATED by HQ, 11/03/2024 12:27

SCH - HQ - NY FWD (Import) REV (Export)  
**1100 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 1500 MW

### EGRDNCTY\_345\_138\_AT1

Mon 11/04/2024 to Fri 11/15/2024  
0700 Continuous 1500  
Work scheduled by: NYPA

CONED - LIPA FWD (Import) REV (Export)  
**1250 MW**  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 1500 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, November 10, 2024 to Saturday, May 9, 2026

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### EGRDNCTY\_345\_138\_AT2

Mon 11/04/2024 to Fri 11/15/2024  
0700 Continuous 1500  
Work scheduled by: NYPA

FWD (Import) REV (Export)  
CONED - LIPA **1250 MW**  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 1500 MW

### SPRNBK\_-EGRDNCTR\_345\_Y49

Mon 11/04/2024 to Fri 11/15/2024  
0700 Continuous 1500  
Work scheduled by: NYPA

FWD (Import) REV (Export)  
CONED - LIPA **775 MW**  
Impacts Total Transfer Capability 725 MW  
TTC with All Lines In Service 1500 MW

### BECK\_-NIAGARA\_345\_PA302

Mon 11/04/2024 to Fri 12/06/2024  
0945 Continuous 1600  
Work scheduled by: IESO

FWD (Import) REV (Export)  
SCH - OH - NY **1150 MW 1000 MW**  
Impacts Total Transfer Capability 1350 MW 850 MW  
TTC with All Lines In Service 2500 MW 1850 MW

### S.RIPLEY-DUNKIRK\_230\_68

Fri 11/08/2024 to Fri 11/15/2024  
1113 Continuous 1800  
Work scheduled by: PJM  
EXT FORCED by PJM 11/08/2024 15:51

FWD (Import) REV (Export)  
SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

### E13THSTA-FARRAGUT\_345\_46

Sat 11/09/2024 to Thu 11/14/2024  
0001 Continuous 0200  
Work scheduled by: ConEd

FWD (Import) REV (Export)  
SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

### LONG\_MTN-CRICKVLY\_345\_398

Sat 11/09/2024 to Wed 12/04/2024  
0001 Continuous 2200  
Work scheduled by: ConEd  
UPDATED by ConEd 11/03/2024 14:22

FWD (Import) REV (Export)  
SCH - NPX\_1385 **100 MW 100 MW**  
Impacts Total Transfer Capability 100 MW 100 MW  
TTC with All Lines In Service 200 MW 200 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, November 10, 2024 to Saturday, May 9, 2026

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### LONG\_MTN-CRICKVLY\_345\_398

Sat 11/09/2024 to Wed 12/04/2024  
0001 Continuous 2200  
Work scheduled by: ConEd

UPDATED by ConEd 11/03/2024 14:22

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**800 MW 1200 MW**  
600 MW 600 MW  
1400 MW 1800 MW

### MILLWOOD-EASTVIEW\_345\_W99

Mon 11/11/2024 to Mon 11/11/2024  
0001 Continuous 0030  
Work scheduled by: ConEd

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**7810 MW**  
240 MW  
8050 MW

### SPRNBK\_345KV\_RNS5

Mon 11/11/2024 to Mon 11/11/2024  
0001 Continuous 0030  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3200 MW**  
1400 MW  
4600 MW

### SCH-NE-NYISO\_LIMIT\_300

Mon 11/11/2024 to Mon 11/11/2024  
0400 Continuous 0659  
Work scheduled by: ISONE

UPDATED by ISONE 11/07/2024 16:03

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**500 MW**  
900 MW  
1400 MW

### MILLWOOD-EASTVIEW\_345\_W99

Mon 11/11/2024 to Mon 11/11/2024  
2130 Continuous 2200  
Work scheduled by: ConEd

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**7810 MW**  
240 MW  
8050 MW

### SPRNBK\_345KV\_RNS5

Mon 11/11/2024 to Mon 11/11/2024  
2130 Continuous 2200  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3200 MW**  
1400 MW  
4600 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, November 10, 2024 to Saturday, May 9, 2026

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_300

Mon 11/11/2024 to Tue 11/12/2024  
2300 Continuous 0659  
Work scheduled by: ISONE

UPDATED by ISONE 11/07/2024 16:03

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**500 MW**  
900 MW  
1400 MW

### LINDN\_CG-LNDVFT\_345\_V-3022

Tue 11/12/2024 to Fri 11/15/2024  
0800 Continuous 1600  
Work scheduled by: PJM

SCH - PJM\_VFT  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**0 MW** **0 MW**  
315 MW 315 MW  
315 MW 315 MW

### SCH-HQ-NYISO\_LIMIT\_500

Wed 11/13/2024 to Fri 11/15/2024  
0600 Continuous 1800  
Work scheduled by: HQ

SCH - HQ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**500 MW**  
1000 MW  
1500 MW

### SCH-NYISO-HQ\_LIMIT\_500

Wed 11/13/2024 to Fri 11/15/2024  
0600 Continuous 1800  
Work scheduled by: HQ

SCH - HQ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**500 MW**  
500 MW  
1000 MW

### HOMRC\_NY-MAINS\_NY\_345\_47

Wed 11/13/2024 to Wed 12/18/2024  
0800 Continuous 1600  
Work scheduled by: NYSEG

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**500 MW**  
500 MW  
1000 MW

### MILLWOOD-EASTVIEW\_345\_W85

Thu 11/14/2024 to Thu 11/14/2024  
0001 Continuous 0030  
Work scheduled by: ConEd

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**7810 MW**  
240 MW  
8050 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, November 10, 2024 to Saturday, May 9, 2026

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SPRNBK\_345KV\_RNS3

Thu 11/14/2024 to Thu 11/14/2024  
0001 Continuous 0030  
Work scheduled by: ConEd

SPR/DUN-SOUTH FWD (Import) REV (Export)  
**3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

### ROSETON\_EFISHKIL\_345\_RFK305

Thu 11/14/2024 to Sat 11/16/2024  
0600 Continuous 1600  
Work scheduled by: CHGE

UPDATED by CHGE 10/28/2024 14:55

UPNY CONED FWD (Import) REV (Export)  
**7215 MW**  
Impacts Total Transfer Capability 835 MW  
TTC with All Lines In Service 8050 MW

### OSWEGO\_VOLNEY\_345\_12

Fri 11/15/2024 to Mon 11/25/2024  
0730 Continuous 1600  
Work scheduled by: NGrid

UPDATED by NGrid 09/10/2024 12:14

OSWEGO EXPORT FWD (Import) REV (Export)  
**5250 MW**  
Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

### CHATGUAY-MASSENA\_765\_7040

Sat 11/16/2024 to Fri 11/29/2024  
0001 Continuous 2359  
Work scheduled by: NYPA

UPDATED by NYPA 11/07/2024 13:51

SCH - HQ - NY FWD (Import) REV (Export)  
**0 MW 0 MW**  
Impacts Total Transfer Capability 1500 MW 1000 MW  
TTC with All Lines In Service 1500 MW 1000 MW

### CHATGUAY-MASSENA\_765\_7040

Sat 11/16/2024 to Fri 11/29/2024  
0001 Continuous 2359  
Work scheduled by: NYPA

UPDATED by NYPA 11/07/2024 13:51

MOSES SOUTH FWD (Import) REV (Export)  
**1550 MW**  
Impacts Total Transfer Capability 1600 MW  
TTC with All Lines In Service 3150 MW

### CHATGUAY-MASSENA\_765\_7040 , MASSENA-MARCY\_765\_MSU1

Sat 11/16/2024 to Fri 11/29/2024  
0001 2359  
Work scheduled by:

MOSES SOUTH FWD (Import) REV (Export)  
**500 MW**  
Impacts Total Transfer Capability 2650 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, November 10, 2024 to Saturday, May 9, 2026

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MARCY\_\_\_765\_345\_AT2

Sat 11/16/2024 to Fri 11/29/2024  
0001 Continuous 2359  
Work scheduled by: NYPA

UPDATED by NYPA 11/07/2024 13:51

ARR: 19

MOSES SOUTH

Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**1700 MW**  
1450 MW  
3150 MW

### MASSENA\_-MARCY\_\_\_765\_MSU1

Sat 11/16/2024 to Fri 11/29/2024  
0001 Continuous 2359  
Work scheduled by: NYPA

UPDATED by NYPA 11/07/2024 13:51

SCH - HQ\_CEDARS

Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**90 MW**  
189 MW  
279 MW

### MASSENA\_-MARCY\_\_\_765\_MSU1

Sat 11/16/2024 to Fri 11/29/2024  
0001 Continuous 2359  
Work scheduled by: NYPA

UPDATED by NYPA 11/07/2024 13:51

SCH - HQ - NY

Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**475 MW 1000 MW**  
1025 MW 0 MW  
1500 MW 1000 MW

### MASSENA\_-MARCY\_\_\_765\_MSU1

Sat 11/16/2024 to Fri 11/29/2024  
0001 Continuous 2359  
Work scheduled by: NYPA

UPDATED by NYPA 11/07/2024 13:51

MOSES SOUTH

Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**500 MW**  
2650 MW  
3150 MW

### MASSENA\_-MARCY\_\_\_765\_MSU1

Sat 11/16/2024 to Fri 11/29/2024  
0001 Continuous 2359  
Work scheduled by: NYPA

UPDATED by NYPA 11/07/2024 13:51

CENTRAL EAST - VC

Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**2595 MW**  
1130 MW  
3725 MW

### MOSES\_\_\_-MASSENA\_230\_MMS1 , MOSES\_\_\_-MASSENA\_230\_MMS2

Sat 11/16/2024 to Fri 11/29/2024  
0001 2359  
Work scheduled by:

SCH - HQ\_CEDARS

Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**90 MW**  
189 MW  
279 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, November 10, 2024 to Saturday, May 9, 2026

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MOSES\_\_-MASSENA\_230\_MMS1 , MOSES\_\_-MASSENA\_230\_MMS2

Sat 11/16/2024 to Fri 11/29/2024  
0001 2359  
Work scheduled by:

	FWD (Import)	REV (Export)
SCH - HQ - NY	<b>850 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	650 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

### MILLWOOD-EASTVIEW\_345\_W85

Mon 11/18/2024 to Mon 11/18/2024  
0130 Continuous 0200  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
UPNY CONED	<b>7810 MW</b>	
Impacts Total Transfer Capability	240 MW	
TTC with All Lines In Service	8050 MW	

### SPRNBK\_345KV\_RNS3

Mon 11/18/2024 to Mon 11/18/2024  
0130 Continuous 0200  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

### MILLWOOD-EASTVIEW\_345\_W99

Mon 11/18/2024 to Fri 11/22/2024  
0201 Continuous 2200  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
UPNY CONED	<b>7810 MW</b>	
Impacts Total Transfer Capability	240 MW	
TTC with All Lines In Service	8050 MW	

### NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE

Mon 11/18/2024 to Fri 11/22/2024  
0600 Continuous 1800  
Work scheduled by: LI

	FWD (Import)	REV (Export)
SCH - PJM_NEPTUNE	<b>0 MW</b>	
Impacts Total Transfer Capability	660 MW	
TTC with All Lines In Service	660 MW	

### NEWBRDGE\_345\_138\_BK\_1

Mon 11/18/2024 to Fri 11/22/2024  
0600 Continuous 1800  
Work scheduled by: LI

	FWD (Import)	REV (Export)
SCH - PJM_NEPTUNE	<b>375 MW</b>	
Impacts Total Transfer Capability	285 MW	
TTC with All Lines In Service	660 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, November 10, 2024 to Saturday, May 9, 2026

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### NEWBRDGE\_345\_138\_BK\_2

Mon 11/18/2024 to Fri 11/22/2024  
0600 Continuous 1800  
Work scheduled by: LI

SCH - PJM\_NEPTUNE FWD (Import) REV (Export)  
**375 MW**  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 660 MW

### NEWBRDGE-DUFFYAVE\_345\_501

Mon 11/18/2024 to Fri 11/22/2024  
0600 Continuous 1800  
Work scheduled by: LI

SCH - PJM\_NEPTUNE FWD (Import) REV (Export)  
**0 MW**  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

### MARCY\_\_FRASANNX\_345\_UCC2-41

Mon 11/18/2024 to Tue 11/26/2024 UPDATED by NYPA 11/08/2024 09:42  
0700 Continuous 1730  
Work scheduled by: NYPA ARR: 19

CENTRAL EAST - VC FWD (Import) REV (Export)  
**3225 MW**  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 3725 MW

### LINDN\_CG-LNDVFT\_\_345\_V-3022

Fri 11/22/2024 to Fri 11/22/2024  
1500 Continuous 2000  
Work scheduled by: PJM

SCH - PJM\_VFT FWD (Import) REV (Export)  
**0 MW 0 MW**  
Impacts Total Transfer Capability 315 MW 315 MW  
TTC with All Lines In Service 315 MW 315 MW

### KNICRBKR-PLSNTVLY\_345\_Y57

Sun 12/01/2024 to Sun 12/22/2024 UPDATED by NGrid 10/29/2024 11:28  
0530 Continuous 1830  
Work scheduled by: NGrid ARR: 78

UPNY CONED FWD (Import) REV (Export)  
**7885 MW**  
Impacts Total Transfer Capability 165 MW  
TTC with All Lines In Service 8050 MW

### ADIRNDCK-PORTER\_\_230\_12

Mon 12/02/2024 to Tue 12/24/2024  
0530 Continuous 1700  
Work scheduled by: NGrid

MOSES SOUTH FWD (Import) REV (Export)  
**2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, November 10, 2024 to Saturday, May 9, 2026

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SHOR\_NPX-SHOREHAM\_138\_CSC

Tue 12/03/2024 to Tue 12/03/2024  
0001 Daily 2359  
Work scheduled by: LI

	FWD (Import)	REV (Export)
SCH - NPX_CSC	0 MW	0 MW
Impacts Total Transfer Capability	330 MW	330 MW
TTC with All Lines In Service	330 MW	330 MW

### OSWEGO\_VOLNEY\_345\_11

Tue 12/03/2024 to Fri 12/13/2024  
0700 Continuous 1700  
Work scheduled by: NGrid

	FWD (Import)	REV (Export)
OSWEGO EXPORT	5250 MW	
Impacts Total Transfer Capability	0 MW	
TTC with All Lines In Service	5250 MW	

### W49TH\_ST\_345KV\_8

Thu 12/05/2024 to Wed 12/18/2024  
0001 Continuous 0200  
Work scheduled by: ConEd

UPDATED by ConEd 09/18/2024 15:33

	FWD (Import)	REV (Export)
SCH - PJM_HTP	310 MW	
Impacts Total Transfer Capability	350 MW	
TTC with All Lines In Service	660 MW	

### W49TH\_ST\_345KV\_6

Thu 12/05/2024 to Sun 01/05/2025  
0201 Continuous 0200  
Work scheduled by: ConEd

UPDATED by ConEd 09/18/2024 15:33

	FWD (Import)	REV (Export)
SCH - PJM_HTP	300 MW	
Impacts Total Transfer Capability	360 MW	
TTC with All Lines In Service	660 MW	

### W49TH\_ST-E13THSTA\_345\_M55

Thu 12/05/2024 to Sun 01/05/2025  
0201 Continuous 0200  
Work scheduled by: ConEd

UPDATED by ConEd 09/18/2024 15:33

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	3800 MW	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

### ELBRIDGE-LAFAYTTE\_345\_17-LE

Mon 12/16/2024 to Sat 12/21/2024  
0800 Continuous 1630  
Work scheduled by: NGrid

ARR: 75

	FWD (Import)	REV (Export)
OSWEGO EXPORT	5250 MW	
Impacts Total Transfer Capability	0 MW	
TTC with All Lines In Service	5250 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, November 10, 2024 to Saturday, May 9, 2026

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### OSWEGO\_-ELBRIDGE\_345\_17

Mon 12/16/2024 to Mon 12/16/2024  
0800 Continuous 0900  
Work scheduled by: NGrid

ARR: 75

OSWEGO EXPORT

FWD (Import)

REV (Export)

**5250 MW**

Impacts Total Transfer Capability

0 MW

TTC with All Lines In Service

5250 MW

### W49TH\_ST\_345KV\_5

Tue 12/17/2024 to Thu 12/19/2024  
0001 Continuous 0200  
Work scheduled by: ConEd

UPDATED by ConEd 09/09/2024 09:31

SCH - PJM\_HTP

FWD (Import)

REV (Export)

**300 MW**

Impacts Total Transfer Capability

360 MW

TTC with All Lines In Service

660 MW

### W49TH\_ST\_345KV\_7

Tue 12/17/2024 to Mon 12/23/2024  
0001 Continuous 0200  
Work scheduled by: ConEd

UPDATED by ConEd 09/09/2024 09:31

SCH - PJM\_HTP

FWD (Import)

REV (Export)

**300 MW**

Impacts Total Transfer Capability

360 MW

TTC with All Lines In Service

660 MW

### E13THSTA-FARRAGUT\_345\_46

Wed 12/18/2024 to Fri 12/20/2024  
0201 Continuous 0300  
Work scheduled by: ConEd

SPR/DUN-SOUTH

FWD (Import)

REV (Export)

**3800 MW**

Impacts Total Transfer Capability

800 MW

TTC with All Lines In Service

4600 MW

### MILLWOOD-EASTVIEW\_345\_W99

Fri 12/20/2024 to Fri 12/20/2024  
0001 Continuous 2200  
Work scheduled by: ConEd

UPNY CONED

FWD (Import)

REV (Export)

**7810 MW**

Impacts Total Transfer Capability

240 MW

TTC with All Lines In Service

8050 MW

### OSWEGO\_-ELBRIDGE\_345\_17

Sat 12/21/2024 to Sat 12/21/2024  
1530 Continuous 1630  
Work scheduled by: NGrid

ARR: 75

OSWEGO EXPORT

FWD (Import)

REV (Export)

**5250 MW**

Impacts Total Transfer Capability

0 MW

TTC with All Lines In Service

5250 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, November 10, 2024 to Saturday, May 9, 2026

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### W49TH\_ST\_345KV\_5

Tue 12/24/2024 to Tue 12/24/2024  
0130 Continuous 0200  
Work scheduled by: ConEd

UPDATED by ConEd 09/09/2024 09:31

SCH - PJM\_HTP

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**300 MW**

360 MW

660 MW

### W49TH\_ST\_345KV\_7

Tue 12/24/2024 to Tue 12/24/2024  
0130 Continuous 0200  
Work scheduled by: ConEd

UPDATED by ConEd 09/09/2024 09:31

SCH - PJM\_HTP

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**300 MW**

360 MW

660 MW

### HUDSONTP-W49TH\_ST\_345\_Y56

Mon 12/30/2024 to Wed 01/01/2025  
0001 Continuous 0100  
Work scheduled by: ConEd

SCH - PJM\_HTP

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**0 MW**

660 MW

660 MW

### W49TH\_ST\_345KV\_7

Mon 12/30/2024 to Wed 01/01/2025  
0001 Continuous 0100  
Work scheduled by: ConEd

SCH - PJM\_HTP

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**300 MW**

360 MW

660 MW

### W49TH\_ST\_345KV\_8

Mon 12/30/2024 to Wed 01/01/2025  
0001 Continuous 0100  
Work scheduled by: ConEd

SCH - PJM\_HTP

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**310 MW**

350 MW

660 MW

### MILLWOOD-EASTVIEW\_345\_W85

Thu 01/02/2025 to Thu 01/02/2025  
0001 Continuous 0030  
Work scheduled by: ConEd

UPNY CONED

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**7810 MW**

240 MW

8050 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, November 10, 2024 to Saturday, May 9, 2026

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SPRNBKR\_345KV\_RNS3

Thu 01/02/2025 to Thu 01/02/2025  
0001 Continuous 1830  
Work scheduled by: ConEd

SPR/DUN-SOUTH FWD (Import) REV (Export)  
**3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

### ADIRNDCK-PORTER\_230\_12

Thu 01/02/2025 to Sat 05/31/2025  
0530 Continuous 1700  
Work scheduled by: NGrid

MOSES SOUTH FWD (Import) REV (Export)  
**2300 MW**  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

### KNICRBKR-PLSNTVLY\_345\_Y57

Thu 01/02/2025 to Wed 01/15/2025  
0530 Continuous 1830  
Work scheduled by: NGrid ARR: 78

UPNY CONED FWD (Import) REV (Export)  
**7885 MW**  
Impacts Total Transfer Capability 165 MW  
TTC with All Lines In Service 8050 MW

### MILLWOOD-EASTVIEW\_345\_W85

Thu 01/02/2025 to Thu 01/02/2025  
1800 Continuous 1830  
Work scheduled by: ConEd

UPNY CONED FWD (Import) REV (Export)  
**7810 MW**  
Impacts Total Transfer Capability 240 MW  
TTC with All Lines In Service 8050 MW

### DUNWODIE\_345KV\_5

Sat 01/04/2025 to Sun 01/05/2025  
0001 Continuous 0259  
Work scheduled by: ConEd

SPR/DUN-SOUTH FWD (Import) REV (Export)  
**3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

### DUNWODIE\_345KV\_7

Sat 01/04/2025 to Sun 01/05/2025  
0001 Continuous 0259  
Work scheduled by: ConEd

SPR/DUN-SOUTH FWD (Import) REV (Export)  
**3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits		Sunday, November 10, 2024 to Saturday, May 9, 2026				
CENTRAL EAST	7550 MW	<b>The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.</b>				
CENTRAL EAST - VC	3725 MW					
TOTAL EAST	6150 MW					
UPNY CONED	8050 MW					
SPR/DUN-SOUTH	4600 MW					
DYSINGER EAST	3200 MW					
MOSES SOUTH	3150 MW					
<b>SPRNBK_345KV_RNS3</b>					FWD (Import)	REV (Export)
Sat 01/04/2025	to	Sun 01/05/2025		SPR/DUN-SOUTH	<b>3800 MW</b>	
0001	Continuous	0259		Impacts Total Transfer Capability	800 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	4600 MW	
<b>SPRNBK_DUNWODIE_345_W75</b>					FWD (Import)	REV (Export)
Sat 01/04/2025	to	Sun 01/05/2025		SPR/DUN-SOUTH	<b>3800 MW</b>	
0001	Continuous	0259		Impacts Total Transfer Capability	800 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	4600 MW	
<b>OSWEGO_ELBRIDGE_345_17</b>					FWD (Import)	REV (Export)
Mon 01/06/2025	to	Fri 01/31/2025		OSWEGO EXPORT	<b>5250 MW</b>	
0630	Continuous	1730	ARR: 75	Impacts Total Transfer Capability	0 MW	
Work scheduled by: NGrid				TTC with All Lines In Service	5250 MW	
<b>E13THSTA-FARRAGUT_345_46</b>					FWD (Import)	REV (Export)
Tue 01/14/2025	to	Sun 01/19/2025		SPR/DUN-SOUTH	<b>3800 MW</b>	
0001	Continuous	0300		Impacts Total Transfer Capability	800 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	4600 MW	
<b>BUCHAN_S-MILLWOOD_345_W97</b>					FWD (Import)	REV (Export)
Wed 01/15/2025	to	Sat 01/18/2025		UPNY CONED	<b>8015 MW</b>	
0200	Continuous	0159		Impacts Total Transfer Capability	35 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	8050 MW	
<b>BUCHAN_S-MILLWOOD_345_W98</b>					FWD (Import)	REV (Export)
Sat 01/18/2025	to	Tue 01/21/2025		UPNY CONED	<b>8015 MW</b>	
0200	Continuous	0200		Impacts Total Transfer Capability	35 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	8050 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, November 10, 2024 to Saturday, May 9, 2026

CENTRAL EAST 7550 MW  
 CENTRAL EAST - VC 3725 MW  
 TOTAL EAST 6150 MW  
 UPNY CONED 8050 MW  
 SPR/DUN-SOUTH 4600 MW  
 DYSINGER EAST 3200 MW  
 MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### KNICRBKR-ALPS\_\_\_345\_6

Mon 01/20/2025 to Tue 01/21/2025  
 0530 Continuous 1830  
 Work scheduled by: NGrid

SCH - NE - NY FWD (Import) REV (Export)  
**900 MW**  
 Impacts Total Transfer Capability 500 MW  
 TTC with All Lines In Service 1400 MW

### KNICRBKR-ALPS\_\_\_345\_6

Mon 01/20/2025 to Tue 01/21/2025  
 0530 Continuous 1830  
 Work scheduled by: NGrid

SCH - NPX\_1385 FWD (Import) REV (Export)  
**100 MW 100 MW**  
 Impacts Total Transfer Capability 100 MW 100 MW  
 TTC with All Lines In Service 200 MW 200 MW

### E13THSTA-FARRAGUT\_345\_46

Tue 01/21/2025 to Thu 01/23/2025  
 0001 Continuous 0100  
 Work scheduled by: ConEd

SPR/DUN-SOUTH FWD (Import) REV (Export)  
**3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

### RAMAPO\_-BUCHAN\_N\_345\_Y94

Wed 01/22/2025 to Wed 01/22/2025  
 0001 Continuous 0030  
 Work scheduled by: ConEd

UPNY CONED FWD (Import) REV (Export)  
**7755 MW**  
 Impacts Total Transfer Capability 295 MW  
 TTC with All Lines In Service 8050 MW

### RAMAPO\_-BUCHAN\_N\_345\_Y94

Sat 01/25/2025 to Sat 01/25/2025  
 2130 Continuous 2200  
 Work scheduled by: ConEd

UPNY CONED FWD (Import) REV (Export)  
**7755 MW**  
 Impacts Total Transfer Capability 295 MW  
 TTC with All Lines In Service 8050 MW

### DUNWODIE\_345KV\_7

Mon 01/27/2025 to Sun 02/02/2025  
 0001 Continuous 2200  
 Work scheduled by: ConEd

SPR/DUN-SOUTH FWD (Import) REV (Export)  
**3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, November 10, 2024 to Saturday, May 9, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### DUNWODIE\_345KV\_8

Mon 01/27/2025 to Sun 02/02/2025  
 0001 Continuous 2200  
 Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

### DUNWODIE-MOTTHAVN\_345\_72

Mon 01/27/2025 to Sun 02/02/2025  
 0001 Continuous 2200  
 Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

### HOPATCON-RAMAPO\_\_500\_5018

Tue 01/28/2025 to Sat 02/01/2025  
 0001 Continuous 0200  
 Work scheduled by: PJM

	FWD (Import)	REV (Export)
SCH - PJ - NY	<b>1400 MW</b>	<b>1200 MW</b>
Impacts Total Transfer Capability	1200 MW	1500 MW
TTC with All Lines In Service	2600 MW	2700 MW

### HOPATCON-RAMAPO\_\_500\_5018

Tue 01/28/2025 to Sat 02/01/2025  
 0001 Continuous 0200  
 Work scheduled by: PJM

	FWD (Import)	REV (Export)
UPNY CONED	<b>7795 MW</b>	
Impacts Total Transfer Capability	255 MW	
TTC with All Lines In Service	8050 MW	

### HOPATCON-RAMAPO\_\_500\_5018

Tue 01/28/2025 to Sat 02/01/2025  
 0001 Continuous 0200  
 Work scheduled by: PJM

	FWD (Import)	REV (Export)
TOTAL EAST	<b>6800 MW</b>	
Impacts Total Transfer Capability	-650 MW	
TTC with All Lines In Service	6150 MW	

### RAMAPO\_\_345\_345\_PAR3500

Tue 01/28/2025 to Sat 02/01/2025  
 0001 Continuous 0200  
 Work scheduled by: PJM

	FWD (Import)	REV (Export)
SCH - PJ - NY		<b>1250 MW</b>
Impacts Total Transfer Capability		1450 MW
TTC with All Lines In Service		2700 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, November 10, 2024 to Saturday, May 9, 2026

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### RAMAPO\_\_345\_345\_PAR4500

Tue 01/28/2025 to Sat 02/01/2025  
0001 Continuous 0200  
Work scheduled by: PJM

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 1250 MW  
REV (Export) 1450 MW  
2700 MW

### RAMAPO\_\_500\_345\_BK 1500

Tue 01/28/2025 to Sat 02/01/2025  
0001 Continuous 0200  
Work scheduled by: PJM

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 1400 MW  
REV (Export) 1200 MW  
1200 MW  
2600 MW  
2700 MW

### RAMAPO\_\_500\_345\_BK 1500

Tue 01/28/2025 to Sat 02/01/2025  
0001 Continuous 0200  
Work scheduled by: PJM

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 7795 MW  
REV (Export) 255 MW  
8050 MW

### ELBRIDGE-LAFAYTTE\_345\_17-LE

Wed 01/29/2025 to Fri 01/31/2025  
0700 Continuous 1730  
Work scheduled by: NGrid

ARR: 75

OSWEGO EXPORT  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 5250 MW  
REV (Export) 0 MW  
5250 MW

### PIERCBRK-FIVEMILE\_345\_37

Tue 02/04/2025 to Tue 02/04/2025  
0900 Daily 1030  
Work scheduled by: NGrid

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import)  
REV (Export)

### MILLWOOD-EASTVIEW\_345\_W82

Mon 02/10/2025 to Fri 02/14/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 7810 MW  
REV (Export) 240 MW  
8050 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits		Sunday, November 10, 2024 to Saturday, May 9, 2026			
CENTRAL EAST	7550 MW		<b>The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.</b>		
CENTRAL EAST - VC	3725 MW				
TOTAL EAST	6150 MW				
UPNY CONED	8050 MW				
SPR/DUN-SOUTH	4600 MW				
DYSINGER EAST	3200 MW				
MOSES SOUTH	3150 MW				
<b>ROSETON_EFISHKIL_345_RFK305</b>				FWD (Import)	REV (Export)
Mon 02/10/2025	to	Wed 02/12/2025	UPNY CONED	<b>7215 MW</b>	
0001	Continuous	0200	Impacts Total Transfer Capability	835 MW	
Work scheduled by: ConEd			TTC with All Lines In Service	8050 MW	
<b>WOOD_ST_PLSNTVLE_345_Y86</b>				FWD (Import)	REV (Export)
Mon 02/17/2025	to	Mon 02/17/2025	UPNY CONED	<b>7475 MW</b>	
0001	Continuous	0030	Impacts Total Transfer Capability	575 MW	
Work scheduled by: ConEd			TTC with All Lines In Service	8050 MW	
<b>WOOD_ST_PLSNTVLE_345_Y86</b>				FWD (Import)	REV (Export)
Fri 02/21/2025	to	Fri 02/21/2025	UPNY CONED	<b>7475 MW</b>	
0130	Continuous	0200	Impacts Total Transfer Capability	575 MW	
Work scheduled by: ConEd			TTC with All Lines In Service	8050 MW	
<b>SPRNBK_TREMONT_345_X28</b>				FWD (Import)	REV (Export)
Sat 03/01/2025	to	Tue 03/04/2025	SPR/DUN-SOUTH	<b>4200 MW</b>	
0001	Continuous	0200	Impacts Total Transfer Capability	400 MW	
Work scheduled by: ConEd			TTC with All Lines In Service	4600 MW	
<b>RAMAPO_BUCHAN_N_345_Y94</b>				FWD (Import)	REV (Export)
Mon 03/03/2025	to	Sat 03/08/2025	UPNY CONED	<b>7755 MW</b>	
0001	Continuous	0200	Impacts Total Transfer Capability	295 MW	
Work scheduled by: ConEd			TTC with All Lines In Service	8050 MW	
<b>MOTTHAVN-RAINEY_345_Q11</b>				FWD (Import)	REV (Export)
Tue 03/04/2025	to	Mon 04/14/2025	SPR/DUN-SOUTH	<b>3800 MW</b>	
0201	Continuous	0300	Impacts Total Transfer Capability	800 MW	
Work scheduled by: ConEd			TTC with All Lines In Service	4600 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, November 10, 2024 to Saturday, May 9, 2026

CENTRAL EAST 7550 MW  
 CENTRAL EAST - VC 3725 MW  
 TOTAL EAST 6150 MW  
 UPNY CONED 8050 MW  
 SPR/DUN-SOUTH 4600 MW  
 DYSINGER EAST 3200 MW  
 MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### STLAWRNC-MOSES\_\_230\_L33P

Mon 03/17/2025 to Fri 03/21/2025  
 0700 Continuous 1530  
 Work scheduled by: NYPA

SCH - OH - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

### ROCHESTR-PANNELL\_345\_RP1

Mon 03/24/2025 to Tue 03/25/2025  
 0730 Continuous 1500  
 Work scheduled by: NYSEG

UPDATED by RGE 11/08/2024 10:56

DYSINGER EAST  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**2300 MW**  
 900 MW  
 3200 MW

### ROCHESTR-PANNELL\_345\_RP2

Wed 03/26/2025 to Thu 03/27/2025  
 0730 Continuous 1500  
 Work scheduled by: RGE

UPDATED by RGE 11/08/2024 10:51

DYSINGER EAST  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**2300 MW**  
 900 MW  
 3200 MW

### NIAGARA\_ROBNSNRD\_230\_64

Fri 03/28/2025 to Fri 03/28/2025  
 0500 Continuous 1900  
 Work scheduled by: NYPA

SCH - OH - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**1900 MW**  
 -50 MW  
 1850 MW

### NIAGARA\_DYSINGER\_345\_ND2

Mon 04/07/2025 to Fri 04/11/2025  
 0500 Continuous 1730  
 Work scheduled by: NYPA

DYSINGER EAST  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**2700 MW**  
 500 MW  
 3200 MW

### LINDN\_CG-LNDVFT\_\_345\_V-3022

Mon 04/07/2025 to Sat 04/12/2025  
 0800 Continuous 1500  
 Work scheduled by: PJM

SCH - PJM\_VFT  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**0 MW** **0 MW**  
 315 MW 315 MW  
 315 MW 315 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, November 10, 2024 to Saturday, May 9, 2026

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### RAMAPO\_\_BUCHAN\_N\_345\_Y94

Sat 04/12/2025 to Sat 04/19/2025  
0001 Continuous 0200  
Work scheduled by: ConEd

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 7755 MW  
REV (Export) 295 MW  
8050 MW

### SPRNBK\_-TREMONT\_345\_X28

Mon 04/14/2025 to Sun 04/20/2025  
0001 Continuous 0200  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 4200 MW  
REV (Export) 400 MW  
4600 MW

### NIAGARA\_-DYSINGER\_345\_ND2

Mon 04/14/2025 to Thu 04/17/2025  
0500 Continuous 1730  
Work scheduled by: NYPA

DYSINGER EAST  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 2700 MW  
REV (Export) 500 MW  
3200 MW

### E13THSTA-FARRAGUT\_345\_45

Tue 04/15/2025 to Sun 04/20/2025  
0001 Continuous 0200  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 3800 MW  
REV (Export) 800 MW  
4600 MW

### W49TH\_ST-E13THSTA\_345\_M54

Tue 04/15/2025 to Sun 04/20/2025  
0001 Continuous 0200  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 3800 MW  
REV (Export) 800 MW  
4600 MW

### MOSES\_\_-ADIRNDCK\_230\_MA1

Tue 04/15/2025 to Tue 04/15/2025  
0700 Continuous 1530  
Work scheduled by: NYPA

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 2300 MW  
REV (Export) 850 MW  
3150 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, November 10, 2024 to Saturday, May 9, 2026

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### LINDN\_CG-LNDVFT\_\_345\_V-3022

Thu 04/17/2025 to Thu 04/17/2025  
1500 Continuous 1800  
Work scheduled by: PJM

SCH - PJM\_VFT  
FWD (Import) 0 MW REV (Export) 0 MW  
Impacts Total Transfer Capability 315 MW 315 MW  
TTC with All Lines In Service 315 MW 315 MW

### NIAGARA\_PACKARD\_230\_61

Mon 04/21/2025 to Fri 04/25/2025  
0500 Continuous 1900  
Work scheduled by: NYPA

SCH - OH - NY  
FWD (Import) 2200 MW REV (Export) 1850 MW  
Impacts Total Transfer Capability 300 MW 0 MW  
TTC with All Lines In Service 2500 MW 1850 MW

### PANNELL\_CLAY\_\_345\_1

Mon 04/21/2025 to Fri 04/25/2025  
0700 Continuous 1530  
Work scheduled by: NYPA

WEST CENTRAL  
FWD (Import) 1300 MW REV (Export)  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

### MOSES\_\_ADIRNDCK\_230\_MA2

Tue 04/22/2025 to Tue 04/22/2025  
0700 Continuous 1530  
Work scheduled by: NYPA

MOSES SOUTH  
FWD (Import) 2300 MW REV (Export)  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

### BUCHAN\_S-MILLWOOD\_345\_W97

Mon 04/28/2025 to Tue 04/29/2025  
0001 Continuous 0230  
Work scheduled by: ConEd

UPNY CONED  
FWD (Import) 8015 MW REV (Export)  
Impacts Total Transfer Capability 35 MW  
TTC with All Lines In Service 8050 MW

### PANNELL\_CLAY\_\_345\_2

Mon 04/28/2025 to Fri 05/02/2025  
0700 Continuous 1530  
Work scheduled by: NYPA

WEST CENTRAL  
FWD (Import) 1300 MW REV (Export)  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, November 10, 2024 to Saturday, May 9, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### LONG\_MTN-CRICKVLY\_345\_398

Tue 05/06/2025 to Thu 05/29/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

### LONG\_MTN-CRICKVLY\_345\_398

Tue 05/06/2025 to Thu 05/29/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - NE - NY	<b>800 MW</b>	<b>1200 MW</b>
Impacts Total Transfer Capability	600 MW	400 MW
TTC with All Lines In Service	1400 MW	1600 MW

### WOOD\_ST-PLSNTVLE\_345\_Y87

Wed 05/07/2025 to Fri 05/09/2025  
2200 Continuous 0259  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
UPNY CONED	<b>7470 MW</b>	
Impacts Total Transfer Capability	580 MW	
TTC with All Lines In Service	8050 MW	

### DUNWODIE\_345KV\_6

Fri 05/09/2025 to Fri 05/09/2025  
0001 Continuous 0030  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

### DUNWODIE\_345KV\_8

Fri 05/09/2025 to Fri 05/09/2025  
0001 Continuous 0030  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

### DUNWODIE\_345KV\_6

Sun 05/11/2025 to Sun 05/11/2025  
1830 Continuous 1900  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, November 10, 2024 to Saturday, May 9, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### DUNWODIE\_345KV\_8

Sun 05/11/2025 to Sun 05/11/2025  
1830 Continuous 1900  
Work scheduled by: ConEd

SPR/DUN-SOUTH FWD (Import) REV (Export)  
**3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

### NEPTUNE\_DUFFYAVE\_345\_NEPTUNE

Mon 05/12/2025 to Fri 05/16/2025  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE FWD (Import) REV (Export)  
**0 MW**  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

### NEWBRDGE\_345\_138\_BK\_1

Mon 05/12/2025 to Fri 05/16/2025  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE FWD (Import) REV (Export)  
**375 MW**  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 660 MW

### NEWBRDGE\_345\_138\_BK\_2

Mon 05/12/2025 to Fri 05/16/2025  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE FWD (Import) REV (Export)  
**375 MW**  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 660 MW

### NEWBRDGE-DUFFYAVE\_345\_501

Mon 05/12/2025 to Fri 05/16/2025  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE FWD (Import) REV (Export)  
**0 MW**  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

### SAND\_BAR-PLATSBRG\_115\_PV20

Mon 07/07/2025 to Fri 07/11/2025  
0700 Continuous 1530  
Work scheduled by: NYPA

SCH - NE - NY FWD (Import) REV (Export)  
Impacts Total Transfer Capability  
TTC with All Lines In Service



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, November 10, 2024 to Saturday, May 9, 2026

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SAND\_BAR-PLATSBRG\_115\_PV20

Mon 07/07/2025 to Fri 07/11/2025  
0700 Continuous 1530  
Work scheduled by: NYPA

CENTRAL EAST - VC FWD (Import) REV (Export)  
**3625 MW**  
Impacts Total Transfer Capability 100 MW  
TTC with All Lines In Service 3725 MW

### NIAGARA\_345\_230\_AT4

Tue 07/08/2025 to Tue 07/08/2025  
0500 Continuous 1900  
Work scheduled by: NYPA

SCH - OH - NY FWD (Import) REV (Export)  
**1200 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 1600 MW

### DYSINGER-STA\_255\_345\_DH1

Tue 09/02/2025 to Mon 09/15/2025  
0500 Continuous 2100  
Work scheduled by: NYPA

DYSINGER EAST FWD (Import) REV (Export)  
**2850 MW**  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 3200 MW

### GOETHALS\_345KV\_5

Mon 09/08/2025 to Mon 09/08/2025  
0301 Continuous 0330  
Work scheduled by: ConEd

STATEN ISLAND FWD (Import) REV (Export)  
Impacts Total Transfer Capability  
TTC with All Lines In Service

### CLAY\_-EDIC\_345\_2-15

Mon 09/08/2025 to Fri 09/12/2025  
0700 Continuous 1530  
Work scheduled by: NYPA

OSWEGO EXPORT FWD (Import) REV (Export)  
**4850 MW**  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 5250 MW

### MOSES\_-ADIRNDCK\_230\_MA1

Tue 09/09/2025 to Sun 10/12/2025  
0700 Continuous 1730  
Work scheduled by: NYPA

MOSES SOUTH FWD (Import) REV (Export)  
**2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, November 10, 2024 to Saturday, May 9, 2026

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### GOETHALS\_345KV\_5

Tue 09/09/2025 to Tue 09/09/2025  
2330 Continuous 2359  
Work scheduled by: ConEd

STATEN ISLAND  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### DUNWODIE\_345KV\_4

Sat 09/13/2025 to Sun 09/14/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

UPDATED by ConEd 11/08/2024 12:36

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**3800 MW**  
800 MW  
4600 MW

### DUNWODIE\_345KV\_6

Sat 09/13/2025 to Sun 09/14/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

UPDATED by ConEd 11/08/2024 12:36

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**3800 MW**  
800 MW  
4600 MW

### DUNWODIE-SHORE\_RD\_345\_Y50

Sat 09/13/2025 to Sun 09/14/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

UPDATED by ConEd 11/08/2024 12:36

CONED - LIPA  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**800 MW**  
700 MW  
1500 MW

### SHORE\_RD\_345\_138\_BK 1

Sat 09/13/2025 to Sun 09/14/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

UPDATED by ConEd 11/08/2024 12:36

CONED - LIPA  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**1350 MW**  
150 MW  
1500 MW

### SHORE\_RD\_345\_138\_BK 2

Sat 09/13/2025 to Sun 09/14/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

UPDATED by ConEd 11/08/2024 12:36

CONED - LIPA  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**1350 MW**  
150 MW  
1500 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, November 10, 2024 to Saturday, May 9, 2026

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SPRNBK\_345KV\_RNS4

Mon 09/15/2025 to Thu 10/02/2025  
0001 Continuous 0200  
Work scheduled by: ConEd

SPR/DUN-SOUTH FWD (Import) REV (Export)  
**3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

### SPRNBK\_W49TH\_ST\_345\_M52

Mon 09/15/2025 to Thu 10/02/2025  
0001 Continuous 0200  
Work scheduled by: ConEd

SPR/DUN-SOUTH FWD (Import) REV (Export)  
**3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

### W49TH\_ST\_345KV\_5

Mon 09/15/2025 to Mon 09/15/2025  
0001 Continuous 0030  
Work scheduled by: ConEd

SCH - PJM\_HTP FWD (Import) REV (Export)  
**460 MW**  
Impacts Total Transfer Capability 200 MW  
TTC with All Lines In Service 660 MW

### GOETHALS\_345KV\_5

Mon 09/15/2025 to Mon 09/15/2025  
0230 Continuous 0300  
Work scheduled by: ConEd

STATEN ISLAND FWD (Import) REV (Export)  
Impacts Total Transfer Capability  
TTC with All Lines In Service

### ADIRNDCK-PORTER\_230\_12

Mon 09/15/2025 to Sun 10/12/2025  
0600 Continuous 1700  
Work scheduled by: NGrid

MOSES SOUTH FWD (Import) REV (Export)  
**2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

### DYSINGER-STA\_255\_345\_DH2

Tue 09/16/2025 to Tue 10/28/2025  
0500 Continuous 1900  
Work scheduled by: NYPA

DYSINGER EAST FWD (Import) REV (Export)  
**2850 MW**  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 3200 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, November 10, 2024 to Saturday, May 9, 2026

CENTRAL EAST 7550 MW  
 CENTRAL EAST - VC 3725 MW  
 TOTAL EAST 6150 MW  
 UPNY CONED 8050 MW  
 SPR/DUN-SOUTH 4600 MW  
 DYSINGER EAST 3200 MW  
 MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### PANNELL\_CLAY\_345\_1

Mon 09/29/2025 to Fri 10/03/2025  
 0700 Continuous 1530  
 Work scheduled by: NYPA

WEST CENTRAL FWD (Import) REV (Export)  
**1300 MW**  
 Impacts Total Transfer Capability 950 MW  
 TTC with All Lines In Service 2250 MW

### W49TH\_ST\_345KV\_5

Thu 10/02/2025 to Thu 10/02/2025  
 0130 Continuous 0200  
 Work scheduled by: ConEd

SCH - PJM\_HTP FWD (Import) REV (Export)  
**460 MW**  
 Impacts Total Transfer Capability 200 MW  
 TTC with All Lines In Service 660 MW

### PANNELL\_CLAY\_345\_2

Mon 10/06/2025 to Fri 10/10/2025  
 0700 Continuous 1530  
 Work scheduled by: NYPA

WEST CENTRAL FWD (Import) REV (Export)  
**1300 MW**  
 Impacts Total Transfer Capability 950 MW  
 TTC with All Lines In Service 2250 MW

### NEPTUNE\_DUFFYAVE\_345\_NEPTUNE

Mon 10/13/2025 to Thu 10/16/2025  
 0600 Continuous 1600  
 Work scheduled by: LI

SCH - PJM\_NEPTUNE FWD (Import) REV (Export)  
**0 MW**  
 Impacts Total Transfer Capability 660 MW  
 TTC with All Lines In Service 660 MW

### NEWBRDGE\_345\_138\_BK\_1

Mon 10/13/2025 to Thu 10/16/2025  
 0600 Continuous 1600  
 Work scheduled by: LI

SCH - PJM\_NEPTUNE FWD (Import) REV (Export)  
**375 MW**  
 Impacts Total Transfer Capability 285 MW  
 TTC with All Lines In Service 660 MW

### NEWBRDGE\_345\_138\_BK\_2

Mon 10/13/2025 to Thu 10/16/2025  
 0600 Continuous 1600  
 Work scheduled by: LI

SCH - PJM\_NEPTUNE FWD (Import) REV (Export)  
**375 MW**  
 Impacts Total Transfer Capability 285 MW  
 TTC with All Lines In Service 660 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Sunday, November 10, 2024 to Saturday, May 9, 2026

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### NEWBRDGE-DUFFYAVE\_345\_501

Mon 10/13/2025 to Thu 10/16/2025  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 0 MW  
REV (Export) 660 MW  
660 MW

### MOSES\_-ADIRNDCK\_230\_MA2

Mon 10/13/2025 to Mon 11/24/2025  
0700 Continuous 1730  
Work scheduled by: NYPA

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 2100 MW  
REV (Export) 1050 MW  
3150 MW

### EDIC\_-PRINCTWN\_345\_351

Tue 10/14/2025 to Fri 10/17/2025  
0600 Continuous 1830  
Work scheduled by: NGrid

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 3335 MW  
REV (Export) 390 MW  
3725 MW

### MARION\_-FARRAGUT\_345\_C3403

Sat 11/01/2025 to Mon 11/03/2025  
0001 Continuous 0300  
Work scheduled by: ConEd

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) REV (Export)

### CHATGUAY-MASSENA\_765\_7040

Sun 11/16/2025 to Sun 11/30/2025  
0001 Continuous 2359  
Work scheduled by: NYPA

SCH - HQ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 0 MW  
REV (Export) 0 MW  
1500 MW 1000 MW  
1500 MW 1000 MW

### CHATGUAY-MASSENA\_765\_7040

Sun 11/16/2025 to Sun 11/30/2025  
0001 Continuous 2359  
Work scheduled by: NYPA

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 1550 MW  
REV (Export) 1600 MW  
3150 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits		Sunday, November 10, 2024 to Saturday, May 9, 2026			
CENTRAL EAST	7550 MW	<b>The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.</b>			
CENTRAL EAST - VC	3725 MW				
TOTAL EAST	6150 MW				
UPNY CONED	8050 MW				
SPR/DUN-SOUTH	4600 MW				
DYSINGER EAST	3200 MW				
MOSES SOUTH	3150 MW				
<b>MOSES__-MASSENA_230_MMS1 , MOSES__-MASSENA_230_MMS2</b>				FWD (Import)	REV (Export)
Sun 11/16/2025	to	Sun 11/30/2025	SCH - HQ_CEDARS	<b>90 MW</b>	
0001		2359	Impacts Total Transfer Capability	189 MW	
Work scheduled by:			TTC with All Lines In Service	279 MW	
<b>MOSES__-MASSENA_230_MMS1 , MOSES__-MASSENA_230_MMS2</b>				FWD (Import)	REV (Export)
Sun 11/16/2025	to	Sun 11/30/2025	SCH - HQ - NY	<b>850 MW</b>	<b>0 MW</b>
0001		2359	Impacts Total Transfer Capability	650 MW	1000 MW
Work scheduled by:			TTC with All Lines In Service	1500 MW	1000 MW
<b>MOSES__-MASSENA_230_MMS1 , MOSES__-MASSENA_230_MMS2 , MOSES__-ADIRNDCK_230_MA2</b>				FWD (Import)	REV (Export)
Sun 11/16/2025	to	Mon 11/24/2025	SCH - HQ_CEDARS	<b>90 MW</b>	
0001		1730	Impacts Total Transfer Capability	189 MW	
Work scheduled by:			TTC with All Lines In Service	279 MW	
<b>MARION_-FARRAGUT_345_C3403</b>				FWD (Import)	REV (Export)
Wed 12/10/2025	to	Mon 12/15/2025	SCH - PJ - NY		
0001	Continuous	0300	Impacts Total Transfer Capability		
Work scheduled by:	ConEd		TTC with All Lines In Service		
<b>GOETHALS_345KV_5</b>				FWD (Import)	REV (Export)
Sat 01/17/2026	to	Sat 01/17/2026	STATEN ISLAND		
0301	Continuous	0330	Impacts Total Transfer Capability		
Work scheduled by:	ConEd		TTC with All Lines In Service		

UPDATED by ConEd 07/10/2024 16:09

NYISO TRANSFER LIMITATIONS

Seasonal Limits			Sunday, November 10, 2024 to Saturday, May 9, 2026		
CENTRAL EAST	7550 MW		<b>The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.</b>		
CENTRAL EAST - VC	3725 MW				
TOTAL EAST	6150 MW				
UPNY CONED	8050 MW				
SPR/DUN-SOUTH	4600 MW				
DYSINGER EAST	3200 MW				
MOSES SOUTH	3150 MW				
<b>DYSINGER-STA_255_345_DH2</b>				FWD (Import)	REV (Export)
Mon 03/02/2026	to	Fri 03/13/2026	DYSINGER EAST	<b>2850 MW</b>	
0500	Continuous	1900	Impacts Total Transfer Capability	350 MW	
Work scheduled by: NYPA			TTC with All Lines In Service	3200 MW	
<b>DYSINGER-STA_255_345_DH1</b>				FWD (Import)	REV (Export)
Mon 03/16/2026	to	Tue 04/07/2026	DYSINGER EAST	<b>2850 MW</b>	
0500	Continuous	2100	Impacts Total Transfer Capability	350 MW	
Work scheduled by: NYPA			TTC with All Lines In Service	3200 MW	
<b>DYSINGER-STA_255_345_DH2</b>				FWD (Import)	REV (Export)
Wed 04/08/2026	to	Mon 04/20/2026	DYSINGER EAST	<b>2850 MW</b>	
0500	Continuous	2100	Impacts Total Transfer Capability	350 MW	
Work scheduled by: NYPA			TTC with All Lines In Service	3200 MW	
<b>DYSINGER-STA_255_345_DH1</b>				FWD (Import)	REV (Export)
Tue 04/21/2026	to	Fri 05/01/2026	DYSINGER EAST	<b>2850 MW</b>	
0500	Continuous	2100	Impacts Total Transfer Capability	350 MW	
Work scheduled by: NYPA			TTC with All Lines In Service	3200 MW	
<b>GOETHALS_345KV_5</b>				FWD (Import)	REV (Export)
Sat 04/25/2026	to	Sat 04/25/2026	<u>UPDATED by ConEd 07/10/2024 16:09</u>	STATEN ISLAND	
2330	Continuous	2359		Impacts Total Transfer Capability	
Work scheduled by: ConEd				TTC with All Lines In Service	
<b>GOETHALS_345KV_5</b>				FWD (Import)	REV (Export)
Mon 04/27/2026	to	Mon 04/27/2026	<u>UPDATED by ConEd 07/10/2024 16:09</u>	STATEN ISLAND	
0001	Continuous	0030		Impacts Total Transfer Capability	
Work scheduled by: ConEd				TTC with All Lines In Service	

NYISO TRANSFER LIMITATIONS

Seasonal Limits		Sunday, November 10, 2024 to Saturday, May 9, 2026	
CENTRAL EAST	7550 MW	<b>The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.</b>	
CENTRAL EAST - VC	3725 MW		
TOTAL EAST	6150 MW		
UPNY CONED	8050 MW		
SPR/DUN-SOUTH	4600 MW		
DYSINGER EAST	3200 MW		
MOSES SOUTH	3150 MW		
GOETHALS_345KV_5		FWD (Import)    REV (Export)	
Tue 05/05/2026	to	Tue 05/05/2026	<u>UPDATED by ConEd 07/10/2024 16:09</u>
0230	Continuous	0300	STATEN ISLAND
Work scheduled by: ConEd			Impacts Total Transfer Capability
			TTC with All Lines In Service