

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, December 17, 2024 to Tuesday, June 16, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONP_-FARRAGUT_345_B3402

Mon 01/15/2018 to Thu 05/01/2025
0001 Continuous 0100
Work scheduled by: ConEd

EXT FORCED by ConEd 03/11/2024 11:26

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Thu 05/01/2025
0001 Continuous 0100
Work scheduled by: ConEd

EXT FORCED by ConEd 03/11/2024 11:26

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

MARION_-FARRAGUT_345_C3403 , HUDSONP_-FARRAGUT_345_B3402

Mon 01/15/2018 to Thu 05/01/2025
0001 0100
Work scheduled by:

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
2400 MW 2400 MW
200 MW 300 MW
2600 MW 2700 MW

MARCY__345KV_CSC

Sat 06/15/2024 to Sat 05/24/2025
0001 Continuous 2359
Work scheduled by: NYPA

FORCED by NYPA 06/11/2024 15:44

CENTRAL EAST - VC
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
3650 MW
75 MW
3725 MW

W49TH_ST_345KV_6

Fri 09/27/2024 to Mon 12/30/2024
0101 Continuous 2359
Work scheduled by: ConEd

UPDATED by ConEd 09/25/2024 08:24

SCH - PJM_HTP
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
300 MW
360 MW
660 MW

W49TH_ST-E13THSTA_345_M55

Fri 09/27/2024 to Mon 12/30/2024
0101 Continuous 2359
Work scheduled by: ConEd

UPDATED by ConEd 09/25/2024 08:24

SPR/DUN-SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
3800 MW
800 MW
4600 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, December 17, 2024 to Tuesday, June 16, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___765_345_AT1

Mon 10/14/2024 to Fri 01/24/2025
2110 Continuous 2359
Work scheduled by: NYPA

MOSES SOUTH **1750 MW**
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 3150 MW

SCH-IMO-NYISO_LIMIT_1900

Fri 11/01/2024 to Wed 04/30/2025
0001 Continuous 2359
Work scheduled by: IESO

SCH - OH - NY **2200 MW**
Impacts Total Transfer Capability 300 MW
TTC with All Lines In Service 2500 MW

S.RIPLEY-DUNKIRK_230_68

Fri 11/08/2024 to Fri 01/31/2025
1113 Continuous 1800
Work scheduled by: PJM

EXT FORCED by NGrid 11/13/2024 16:46

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

HOMRC_NY-MAINS_NY_345_47

Wed 11/13/2024 to Wed 12/18/2024
0800 Continuous 1600
Work scheduled by: NYSEG

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

ADIRNDCK-PORTER_230_12

Mon 12/02/2024 to Fri 12/20/2024
0530 Continuous 1700
Work scheduled by: NGrid

MOSES SOUTH **2300 MW**
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

KNICRBKR-PLSNTVLY_345_Y57

Mon 12/02/2024 to Sun 12/22/2024
0530 Continuous 1830
Work scheduled by: NGrid

UPDATED by NGrid 11/14/2024 14:59

ARR: 78

UPNY CONED **7885 MW**
Impacts Total Transfer Capability 165 MW
TTC with All Lines In Service 8050 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits		Tuesday, December 17, 2024 to Tuesday, June 16, 2026			
CENTRAL EAST	7550 MW	The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.			
CENTRAL EAST - VC	3725 MW				
TOTAL EAST	6150 MW				
UPNY CONED	8050 MW				
SPR/DUN-SOUTH	4600 MW				
DYSINGER EAST	3200 MW				
MOSES SOUTH	3150 MW				
<hr/>					
SCH-HQ-NYISO_LIMIT_1100				FWD (Import)	REV (Export)
Wed 12/04/2024	to	Wed 03/19/2025	SCH - HQ - NY	1100 MW	
1801	Continuous	1600	Impacts Total Transfer Capability	400 MW	
Work scheduled by: HQ			TTC with All Lines In Service	1500 MW	
<hr/>					
SPRNBK_W49TH_ST_345_M52				FWD (Import)	REV (Export)
Thu 12/05/2024	to	Tue 12/24/2024	SPR/DUN-SOUTH	3200 MW	
0750	Continuous	2300	Impacts Total Transfer Capability	1400 MW	
Work scheduled by: ConEd			TTC with All Lines In Service	4600 MW	
<hr/>					
SCH-IMO-NYISO_LIMIT_1000				FWD (Import)	REV (Export)
Sat 12/07/2024	to	Thu 12/19/2024	SCH - OH - NY	1300 MW	
0715	Continuous	1600	Impacts Total Transfer Capability	1200 MW	
Work scheduled by: IESO			TTC with All Lines In Service	2500 MW	
<hr/>					
SCH-NYISO-IMO_LIMIT_1300				FWD (Import)	REV (Export)
Sat 12/07/2024	to	Thu 12/19/2024	SCH - OH - NY	1600 MW	
0715	Continuous	1600	Impacts Total Transfer Capability	250 MW	
Work scheduled by: IESO			TTC with All Lines In Service	1850 MW	
<hr/>					
ALCOA_PA_115KV_R8105				FWD (Import)	REV (Export)
Mon 12/09/2024	to	Fri 12/20/2024	MOSES SOUTH	3100 MW	
0530	Continuous	1800	Impacts Total Transfer Capability	50 MW	
Work scheduled by: NGrid			TTC with All Lines In Service	3150 MW	
<hr/>					
SCH-HQ_CEDARS-NYISO_LIMIT_100				FWD (Import)	REV (Export)
Mon 12/09/2024	to	Fri 12/20/2024	SCH - HQ_CEDARS	100 MW	
0530	Continuous	1800	Impacts Total Transfer Capability	179 MW	
Work scheduled by: HQ			TTC with All Lines In Service	279 MW	

UPDATED by HQ 12/04/2024 16:45

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, December 17, 2024 to Tuesday, June 16, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ELBRIDGE-LAFAYTTE_345_17-LE

Mon 12/16/2024 to Sat 12/21/2024
0800 Continuous 1630
Work scheduled by: NGrid

ARR: 75

OSWEGO EXPORT

Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

5250 MW
0 MW
5250 MW

DUNWODIE_345KV_6

Tue 12/17/2024 to Tue 12/17/2024
0001 Continuous 0030
Work scheduled by: ConEd

CANCELLED by TO 12/16/2024 12:57

SPR/DUN-SOUTH

Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

3800 MW
800 MW
4600 MW

DUNWODIE_345KV_8

Tue 12/17/2024 to Tue 12/17/2024
0001 Continuous 0030
Work scheduled by: ConEd

CANCELLED by TO 12/16/2024 12:57

SPR/DUN-SOUTH

Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

3800 MW
800 MW
4600 MW

WOOD_ST_PLSNTVLE_345_Y87

Tue 12/17/2024 to Tue 12/17/2024
0001 Continuous 0030
Work scheduled by: ConEd

CANCELLED by TO 12/16/2024 12:57

UPNY CONED

Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

7470 MW
580 MW
8050 MW

DUNWODIE_345KV_6

Tue 12/17/2024 to Tue 12/17/2024
2130 Continuous 2200
Work scheduled by: ConEd

CANCELLED by TO 12/16/2024 12:57

SPR/DUN-SOUTH

Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

3800 MW
800 MW
4600 MW

DUNWODIE_345KV_8

Tue 12/17/2024 to Tue 12/17/2024
2130 Continuous 2200
Work scheduled by: ConEd

CANCELLED by TO 12/16/2024 12:57

SPR/DUN-SOUTH

Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

3800 MW
800 MW
4600 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, December 17, 2024 to Tuesday, June 16, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

WOOD_ST_PLSNTVLE_345_Y87

Tue 12/17/2024 to Tue 12/17/2024
2130 Continuous 2200
Work scheduled by: ConEd

CANCELLED by TO 12/16/2024 12:57

UPNY CONED
Impacts Total Transfer Capability 580 MW
TTC with All Lines In Service 8050 MW

FWD (Import) REV (Export)

7470 MW

MOSES__ADIRNDCK_230_MA2

Wed 12/18/2024 to Wed 12/18/2024
0600 Continuous 1800
Work scheduled by: NYPA

UPDATED by NYPA 12/16/2024 14:07

MOSES SOUTH
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

FWD (Import) REV (Export)

2300 MW

MILLWOOD-EASTVIEW_345_W99

Fri 12/20/2024 to Fri 12/20/2024
0001 Continuous 2200
Work scheduled by: ConEd

UPNY CONED
Impacts Total Transfer Capability 240 MW
TTC with All Lines In Service 8050 MW

FWD (Import) REV (Export)

7810 MW

MILLWOOD-EASTVIEW_345_W82

Sat 12/21/2024 to Sat 12/21/2024
0001 Continuous 2200
Work scheduled by: ConEd

UPNY CONED
Impacts Total Transfer Capability 240 MW
TTC with All Lines In Service 8050 MW

FWD (Import) REV (Export)

7810 MW

SPRNBK_345KV_RNS4

Sat 12/21/2024 to Sat 12/21/2024
0001 Continuous 0030
Work scheduled by: ConEd

SPR/DUN-SOUTH
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

3200 MW

OSWEGO__ELBRIDGE_345_17

Sat 12/21/2024 to Sat 12/21/2024
1530 Continuous 1630
Work scheduled by: NGrid

ARR: 75

OSWEGO EXPORT
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 5250 MW

FWD (Import) REV (Export)

5250 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, December 17, 2024 to Tuesday, June 16, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK_345KV_RNS4

Sat 12/21/2024 to Sat 12/21/2024
2130 Continuous 2200
Work scheduled by: ConEd

SPR/DUN-SOUTH
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

3200 MW

W49TH_ST_345KV_6

Tue 12/31/2024 to Sun 02/02/2025
0001 Continuous 0200
Work scheduled by: ConEd

UPDATED by ConEd 12/08/2024 14:37

SCH - PJM_HTP
Impacts Total Transfer Capability 360 MW
TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

300 MW

W49TH_ST_345KV_8

Tue 12/31/2024 to Sun 01/19/2025
0001 Continuous 2359
Work scheduled by: ConEd

UPDATED by ConEd 12/08/2024 14:37

SCH - PJM_HTP
Impacts Total Transfer Capability 350 MW
TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

310 MW

W49TH_ST-E13THSTA_345_M55

Tue 12/31/2024 to Sun 02/02/2025
0001 Continuous 0200
Work scheduled by: ConEd

UPDATED by ConEd 12/08/2024 14:37

SPR/DUN-SOUTH
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

3800 MW

MILLWOOD-EASTVIEW_345_W85

Thu 01/02/2025 to Thu 01/02/2025
0001 Continuous 0030
Work scheduled by: ConEd

UPNY CONED
Impacts Total Transfer Capability 240 MW
TTC with All Lines In Service 8050 MW

FWD (Import) REV (Export)

7810 MW

SPRNBK_345KV_RNS3

Thu 01/02/2025 to Thu 01/02/2025
0001 Continuous 1830
Work scheduled by: ConEd

SPR/DUN-SOUTH
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

3800 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, December 17, 2024 to Tuesday, June 16, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

KNICRBKR-PLSNTVLY_345_Y57

Thu 01/02/2025 to Wed 01/15/2025
0530 Continuous 1830
Work scheduled by: NGrid

ARR: 78

UPNY CONED
Impacts Total Transfer Capability 7885 MW
TTC with All Lines In Service 165 MW
8050 MW

FWD (Import) REV (Export)

MILLWOOD-EASTVIEW_345_W85

Thu 01/02/2025 to Thu 01/02/2025
1800 Continuous 1830
Work scheduled by: ConEd

UPNY CONED
Impacts Total Transfer Capability 7810 MW
TTC with All Lines In Service 240 MW
8050 MW

FWD (Import) REV (Export)

DUNWODIE_345KV_5

Sat 01/04/2025 to Sun 01/05/2025
0001 Continuous 0259
Work scheduled by: ConEd

SPR/DUN-SOUTH
Impacts Total Transfer Capability 3800 MW
TTC with All Lines In Service 800 MW
4600 MW

FWD (Import) REV (Export)

DUNWODIE_345KV_7

Sat 01/04/2025 to Sun 01/05/2025
0001 Continuous 0259
Work scheduled by: ConEd

SPR/DUN-SOUTH
Impacts Total Transfer Capability 3800 MW
TTC with All Lines In Service 800 MW
4600 MW

FWD (Import) REV (Export)

SPRNBKR_345KV_RNS3

Sat 01/04/2025 to Sun 01/05/2025
0001 Continuous 0259
Work scheduled by: ConEd

SPR/DUN-SOUTH
Impacts Total Transfer Capability 3800 MW
TTC with All Lines In Service 800 MW
4600 MW

FWD (Import) REV (Export)

SPRNBKR_DUNWODIE_345_W75

Sat 01/04/2025 to Sun 01/05/2025
0001 Continuous 0259
Work scheduled by: ConEd

SPR/DUN-SOUTH
Impacts Total Transfer Capability 3800 MW
TTC with All Lines In Service 800 MW
4600 MW

FWD (Import) REV (Export)

NYISO TRANSFER LIMITATIONS

Seasonal Limits		Tuesday, December 17, 2024 to Tuesday, June 16, 2026				
CENTRAL EAST	7550 MW	The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.				
CENTRAL EAST - VC	3725 MW					
TOTAL EAST	6150 MW					
UPNY CONED	8050 MW					
SPR/DUN-SOUTH	4600 MW					
DYSINGER EAST	3200 MW					
MOSES SOUTH	3150 MW					
NRTH1385-NOR HBR_138_601					FWD (Import)	REV (Export)
Mon 01/06/2025	to	Fri 01/10/2025	SCH - NPX_1385	100 MW	100 MW	
0500	Continuous	1500	Impacts Total Transfer Capability	100 MW	100 MW	
Work scheduled by: LI			TTC with All Lines In Service	200 MW	200 MW	
NRTH1385-NOR HBR_138_602					FWD (Import)	REV (Export)
Mon 01/06/2025	to	Fri 01/10/2025	SCH - NPX_1385	100 MW	100 MW	
0500	Continuous	1500	Impacts Total Transfer Capability	100 MW	100 MW	
Work scheduled by: LI			TTC with All Lines In Service	200 MW	200 MW	
NRTH1385-NOR HBR_138_603					FWD (Import)	REV (Export)
Mon 01/06/2025	to	Fri 01/10/2025	SCH - NPX_1385	100 MW	100 MW	
0500	Continuous	1500	Impacts Total Transfer Capability	100 MW	100 MW	
Work scheduled by: LI			TTC with All Lines In Service	200 MW	200 MW	
NRTH1385-NORHBR_138_601 , NRTH1385-NORHBR_138_602					FWD (Import)	REV (Export)
Mon 01/06/2025	to	Fri 01/10/2025	SCH - NPX_1385	0 MW	0 MW	
0500		1500	Impacts Total Transfer Capability	200 MW	200 MW	
Work scheduled by:			TTC with All Lines In Service	200 MW	200 MW	
NRTH1385-NORHBR_138_601 , NRTH1385-NORHBR_138_603					FWD (Import)	REV (Export)
Mon 01/06/2025	to	Fri 01/10/2025	SCH - NPX_1385	0 MW	0 MW	
0500		1500	Impacts Total Transfer Capability	200 MW	200 MW	
Work scheduled by:			TTC with All Lines In Service	200 MW	200 MW	
NRTH1385-NORHBR_138_603 , NRTH1385-NORHBR_138_602					FWD (Import)	REV (Export)
Mon 01/06/2025	to	Fri 01/10/2025	SCH - NPX_1385	0 MW	0 MW	
0500		1500	Impacts Total Transfer Capability	200 MW	200 MW	
Work scheduled by:			TTC with All Lines In Service	200 MW	200 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, December 17, 2024 to Tuesday, June 16, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NRTH1385-NRTHPORT_138_NNC

Mon 01/06/2025 to Fri 01/10/2025
0500 Continuous 1500
Work scheduled by: LI

SCH - NPX_1385

FWD (Import) REV (Export)

Impacts Total Transfer Capability

0 MW 0 MW

TTC with All Lines In Service

200 MW 200 MW

200 MW 200 MW

ADIRNDCK-PORTER_230_12

Mon 01/06/2025 to Sat 05/31/2025
0530 Continuous 1700
Work scheduled by: NGrid

MOSES SOUTH

FWD (Import) REV (Export)

Impacts Total Transfer Capability

2300 MW

TTC with All Lines In Service

850 MW

3150 MW

ELBRIDGE-LAFAYTTE_345_17-LE

Mon 01/06/2025 to Mon 01/06/2025
0630 Continuous 0800
Work scheduled by: NGrid

ARR: 75

OSWEGO EXPORT

FWD (Import) REV (Export)

Impacts Total Transfer Capability

5250 MW

TTC with All Lines In Service

0 MW

5250 MW

OSWEGO_-ELBRIDGE_345_17

Mon 01/06/2025 to Fri 01/31/2025
0630 Continuous 1730
Work scheduled by: NGrid

ARR: 75

OSWEGO EXPORT

FWD (Import) REV (Export)

Impacts Total Transfer Capability

5250 MW

TTC with All Lines In Service

0 MW

5250 MW

BECK_-NIAGARA_345_PA301

Tue 01/07/2025 to Tue 01/07/2025
0500 Continuous 2100
Work scheduled by: NYPA

SCH - OH - NY

FWD (Import) REV (Export)

Impacts Total Transfer Capability

1150 MW 1000 MW

TTC with All Lines In Service

1350 MW 850 MW

2500 MW 1850 MW

MOSES_-ADIRNDCK_230_MA1

Tue 01/07/2025 to Tue 01/07/2025
0600 Continuous 2230
Work scheduled by: NYPA

MOSES SOUTH

FWD (Import) REV (Export)

Impacts Total Transfer Capability

2300 MW

TTC with All Lines In Service

850 MW

3150 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, December 17, 2024 to Tuesday, June 16, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_6

Thu 01/09/2025 to Tue 01/14/2025
0001 Continuous 2200
Work scheduled by: ConEd

SPR/DUN-SOUTH FWD (Import) REV (Export)
Impacts Total Transfer Capability **3800 MW** 800 MW
TTC with All Lines In Service 4600 MW

DUNWODIE_345KV_8

Thu 01/09/2025 to Tue 01/14/2025
0001 Continuous 2200
Work scheduled by: ConEd

SPR/DUN-SOUTH FWD (Import) REV (Export)
Impacts Total Transfer Capability **3800 MW** 800 MW
TTC with All Lines In Service 4600 MW

WOOD_ST_-PLSNTVLE_345_Y87

Thu 01/09/2025 to Tue 01/14/2025
0001 Continuous 2200
Work scheduled by: ConEd

UPNY CONED FWD (Import) REV (Export)
Impacts Total Transfer Capability **7470 MW** 580 MW
TTC with All Lines In Service 8050 MW

BUCHAN_S-MILLWOOD_345_W97

Wed 01/15/2025 to Sat 01/18/2025
0200 Continuous 0159
Work scheduled by: ConEd

UPNY CONED FWD (Import) REV (Export)
Impacts Total Transfer Capability **8015 MW** 35 MW
TTC with All Lines In Service 8050 MW

BUCHAN_S-MILLWOOD_345_W98

Sat 01/18/2025 to Tue 01/21/2025
0200 Continuous 0200
Work scheduled by: ConEd

UPNY CONED FWD (Import) REV (Export)
Impacts Total Transfer Capability **8015 MW** 35 MW
TTC with All Lines In Service 8050 MW

E13THSTA-FARRAGUT_345_46

Mon 01/20/2025 to Sat 01/25/2025
0001 Continuous 0300
Work scheduled by: ConEd

UPDATED by ConEd 12/17/2024 16:45

SPR/DUN-SOUTH FWD (Import) REV (Export)
Impacts Total Transfer Capability **3800 MW** 800 MW
TTC with All Lines In Service 4600 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, December 17, 2024 to Tuesday, June 16, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

KNICRBKR-ALPS___345_6

Mon 01/20/2025 to Tue 01/21/2025
0530 Continuous 1830
Work scheduled by: NGrid

SCH - NE - NY	FWD (Import)	REV (Export)
	900 MW	
Impacts Total Transfer Capability	500 MW	
TTC with All Lines In Service	1400 MW	

KNICRBKR-ALPS___345_6

Mon 01/20/2025 to Tue 01/21/2025
0530 Continuous 1830
Work scheduled by: NGrid

SCH - NPX_1385	FWD (Import)	REV (Export)
	100 MW	100 MW
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

RAMAPO_-BUCHAN_N_345_Y94

Wed 01/22/2025 to Wed 01/22/2025
0001 Continuous 0030
Work scheduled by: ConEd

UPNY CONED	FWD (Import)	REV (Export)
	7755 MW	
Impacts Total Transfer Capability	295 MW	
TTC with All Lines In Service	8050 MW	

RAMAPO_-BUCHAN_N_345_Y94

Sat 01/25/2025 to Sat 01/25/2025
2130 Continuous 2200
Work scheduled by: ConEd

UPNY CONED	FWD (Import)	REV (Export)
	7755 MW	
Impacts Total Transfer Capability	295 MW	
TTC with All Lines In Service	8050 MW	

DUNWODIE_345KV_7

Sun 01/26/2025 to Sun 02/02/2025
0001 Continuous 2200
Work scheduled by: ConEd

UPDATED by ConEd 11/22/2024 08:59

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	3800 MW	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

DUNWODIE_345KV_8

Sun 01/26/2025 to Sun 02/02/2025
0001 Continuous 2200
Work scheduled by: ConEd

UPDATED by ConEd 11/22/2024 08:59

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	3800 MW	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits		Tuesday, December 17, 2024 to Tuesday, June 16, 2026				
CENTRAL EAST	7550 MW	The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.				
CENTRAL EAST - VC	3725 MW					
TOTAL EAST	6150 MW					
UPNY CONED	8050 MW					
SPR/DUN-SOUTH	4600 MW					
DYSINGER EAST	3200 MW					
MOSES SOUTH	3150 MW					
DUNWODIE-MOTTHAVN_345_72					FWD (Import)	REV (Export)
Sun 01/26/2025	to	Sun 02/02/2025	<u>UPDATED by ConEd 11/22/2024 08:59</u>		SPR/DUN-SOUTH	3800 MW
0001	Continuous	2200			Impacts Total Transfer Capability	800 MW
Work scheduled by: ConEd		TTC with All Lines In Service			4600 MW	
ELBRIDGE-LAFAYTTE_345_17-LE					FWD (Import)	REV (Export)
Mon 01/27/2025	to	Fri 01/31/2025	ARR: 75		OSWEGO EXPORT	5250 MW
0700	Continuous	1730			Impacts Total Transfer Capability	0 MW
Work scheduled by: NGrid		TTC with All Lines In Service			5250 MW	
HOPATCON-RAMAPO__500_5018					FWD (Import)	REV (Export)
Tue 01/28/2025	to	Sat 02/01/2025			SCH - PJ - NY	1400 MW 1200 MW
0001	Continuous	0200			Impacts Total Transfer Capability	1200 MW 1500 MW
Work scheduled by: PJM		TTC with All Lines In Service			2600 MW 2700 MW	
HOPATCON-RAMAPO__500_5018					FWD (Import)	REV (Export)
Tue 01/28/2025	to	Sat 02/01/2025			UPNY CONED	7795 MW
0001	Continuous	0200			Impacts Total Transfer Capability	255 MW
Work scheduled by: PJM		TTC with All Lines In Service			8050 MW	
HOPATCON-RAMAPO__500_5018					FWD (Import)	REV (Export)
Tue 01/28/2025	to	Sat 02/01/2025			TOTAL EAST	6800 MW
0001	Continuous	0200			Impacts Total Transfer Capability	-650 MW
Work scheduled by: PJM		TTC with All Lines In Service			6150 MW	
RAMAPO__345_345_PAR3500					FWD (Import)	REV (Export)
Tue 01/28/2025	to	Sat 02/01/2025			SCH - PJ - NY	2550 MW 1250 MW
0001	Continuous	0200			Impacts Total Transfer Capability	50 MW 1450 MW
Work scheduled by: PJM		TTC with All Lines In Service			2600 MW 2700 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits		Tuesday, December 17, 2024 to Tuesday, June 16, 2026				
CENTRAL EAST	7550 MW		The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.			
CENTRAL EAST - VC	3725 MW					
TOTAL EAST	6150 MW					
UPNY CONED	8050 MW					
SPR/DUN-SOUTH	4600 MW					
DYSINGER EAST	3200 MW					
MOSES SOUTH	3150 MW					
RAMAPO__345_345_PAR4500				FWD (Import)	REV (Export)	
Tue 01/28/2025	to	Sat 02/01/2025	SCH - PJ - NY	2550 MW	1250 MW	
0001	Continuous	0200	Impacts Total Transfer Capability	50 MW	1450 MW	
Work scheduled by: PJM			TTC with All Lines In Service	2600 MW	2700 MW	
RAMAPO__500_345_BK 1500				FWD (Import)	REV (Export)	
Tue 01/28/2025	to	Sat 02/01/2025	SCH - PJ - NY	1400 MW	1200 MW	
0001	Continuous	0200	Impacts Total Transfer Capability	1200 MW	1500 MW	
Work scheduled by: PJM			TTC with All Lines In Service	2600 MW	2700 MW	
RAMAPO__500_345_BK 1500				FWD (Import)	REV (Export)	
Tue 01/28/2025	to	Sat 02/01/2025	UPNY CONED	7795 MW		
0001	Continuous	0200	Impacts Total Transfer Capability	255 MW		
Work scheduled by: PJM			TTC with All Lines In Service	8050 MW		
PIERCBRK-FIVEMILE_345_37				FWD (Import)	REV (Export)	
Tue 02/04/2025	to	Tue 02/04/2025	SCH - PJ - NY			
0900	Daily	1030	Impacts Total Transfer Capability			
Work scheduled by: NGrid			TTC with All Lines In Service			
ROSETON_EFISHKIL_345_RFK305				FWD (Import)	REV (Export)	
Sun 02/09/2025	to	Wed 02/12/2025	UPNY CONED	7215 MW		
0001	Continuous	0200	Impacts Total Transfer Capability	835 MW		
Work scheduled by: ConEd			TTC with All Lines In Service	8050 MW		
MILLWOOD-EASTVIEW_345_W82				FWD (Import)	REV (Export)	
Mon 02/10/2025	to	Fri 02/14/2025	UPNY CONED	7810 MW		
0001	Continuous	2200	Impacts Total Transfer Capability	240 MW		
Work scheduled by: ConEd			TTC with All Lines In Service	8050 MW		

NYISO TRANSFER LIMITATIONS

Seasonal Limits			Tuesday, December 17, 2024 to Tuesday, June 16, 2026		
CENTRAL EAST	7550 MW		The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.		
CENTRAL EAST - VC	3725 MW				
TOTAL EAST	6150 MW				
UPNY CONED	8050 MW				
SPR/DUN-SOUTH	4600 MW				
DYSINGER EAST	3200 MW				
MOSES SOUTH	3150 MW				
FRASER__345_FRASER SVC				FWD (Import)	REV (Export)
Mon 02/10/2025	to	Fri 02/14/2025	CENTRAL EAST - VC	3655 MW	
0700	Continuous	1500	Impacts Total Transfer Capability	70 MW	
Work scheduled by: NYSEG			TTC with All Lines In Service	3725 MW	
WOOD_ST_PLSNTVLE_345_Y86				FWD (Import)	REV (Export)
Mon 02/17/2025	to	Mon 02/17/2025	UPNY CONED	7475 MW	
0001	Continuous	0030	Impacts Total Transfer Capability	575 MW	
Work scheduled by: ConEd			TTC with All Lines In Service	8050 MW	
BECK__-PACKARD_230_BP76				FWD (Import)	REV (Export)
Thu 02/20/2025	to	Thu 02/20/2025	SCH - OH - NY	1800 MW	1300 MW
0730	Continuous	1630	Impacts Total Transfer Capability	700 MW	550 MW
Work scheduled by: NGrid			TTC with All Lines In Service	2500 MW	1850 MW
WOOD_ST_PLSNTVLE_345_Y86				FWD (Import)	REV (Export)
Fri 02/21/2025	to	Fri 02/21/2025	UPNY CONED	7475 MW	
0130	Continuous	0200	Impacts Total Transfer Capability	575 MW	
Work scheduled by: ConEd			TTC with All Lines In Service	8050 MW	
BERKSHIR-ALPS__345_393				FWD (Import)	REV (Export)
Mon 02/24/2025	to	Mon 02/24/2025	SCH - NPX_1385	100 MW	100 MW
0730	Continuous	1530	Impacts Total Transfer Capability	100 MW	100 MW
Work scheduled by: NGrid			TTC with All Lines In Service	200 MW	200 MW
BERKSHIR-ALPS__345_393				FWD (Import)	REV (Export)
Mon 02/24/2025	to	Mon 02/24/2025	SCH - NE - NY	1100 MW	1600 MW
0730	Continuous	1530	Impacts Total Transfer Capability	300 MW	200 MW
Work scheduled by: NGrid			TTC with All Lines In Service	1400 MW	1800 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, December 17, 2024 to Tuesday, June 16, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK_-TREMONT_345_X28

Sat 03/01/2025 to Tue 03/04/2025
0001 Continuous 0200
Work scheduled by: ConEd

SPR/DUN-SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) REV (Export)
4200 MW
400 MW
4600 MW

RAMAPO_-BUCHAN_N_345_Y94

Mon 03/03/2025 to Sat 03/08/2025
0001 Continuous 0200
Work scheduled by: ConEd

UPNY CONED
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) REV (Export)
7755 MW
295 MW
8050 MW

MOTHAVN-RAINEY_345_Q11

Tue 03/04/2025 to Mon 04/14/2025
0201 Continuous 0300
Work scheduled by: ConEd

SPR/DUN-SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) REV (Export)
3800 MW
800 MW
4600 MW

MOSES_-ADIRNDCK_230_MA1

Fri 03/14/2025 to Sat 03/29/2025
0700 Continuous 1730
Work scheduled by: NYPA

MOSES SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) REV (Export)
2300 MW
850 MW
3150 MW

NINEMILE-CLAY_345_8

Mon 03/17/2025 to Mon 03/17/2025
0001 Continuous 0100
Work scheduled by: NGrid

OSWEGO EXPORT
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) REV (Export)
5150 MW
100 MW
5250 MW

SCRIBA_-VOLNEY_345_20

Mon 03/17/2025 to Mon 03/17/2025
0700 Daily 1900
Work scheduled by: NGrid

OSWEGO EXPORT
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) REV (Export)
5250 MW
0 MW
5250 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits		Tuesday, December 17, 2024 to Tuesday, June 16, 2026			
CENTRAL EAST	7550 MW	The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.			
CENTRAL EAST - VC	3725 MW				
TOTAL EAST	6150 MW				
UPNY CONED	8050 MW				
SPR/DUN-SOUTH	4600 MW				
DYSINGER EAST	3200 MW				
MOSES SOUTH	3150 MW				
STLAWRNC-MOSES__230_L33P				FWD (Import)	REV (Export)
Mon 03/17/2025	to	Fri 03/21/2025	SCH - OH - NY		
0700	Continuous	1530	Impacts Total Transfer Capability		
Work scheduled by: NYPA			TTC with All Lines In Service		
NINEMILE-CLAY__345_8				FWD (Import)	REV (Export)
Mon 03/17/2025	to	Tue 03/18/2025	OSWEGO EXPORT	5150 MW	
2130	Continuous	2300	Impacts Total Transfer Capability	100 MW	
Work scheduled by: NGrid			TTC with All Lines In Service	5250 MW	
ROCHESTR-PANNELL__345_RP1				FWD (Import)	REV (Export)
Mon 03/24/2025	to	Tue 03/25/2025	<u>UPDATED by RGE 11/08/2024 10:56</u>	DYSINGER EAST	2300 MW
0730	Continuous	1500	Impacts Total Transfer Capability	900 MW	
Work scheduled by: NYSEG			TTC with All Lines In Service	3200 MW	
NINEMILE-CLAY__345_8				FWD (Import)	REV (Export)
Tue 03/25/2025	to	Tue 03/25/2025	OSWEGO EXPORT	5150 MW	
0200	Continuous	0300	Impacts Total Transfer Capability	100 MW	
Work scheduled by: NGrid			TTC with All Lines In Service	5250 MW	
ROCHESTR-PANNELL__345_RP2				FWD (Import)	REV (Export)
Wed 03/26/2025	to	Thu 03/27/2025	<u>UPDATED by RGE 11/08/2024 10:51</u>	DYSINGER EAST	2300 MW
0730	Continuous	1500	Impacts Total Transfer Capability	900 MW	
Work scheduled by: RGE			TTC with All Lines In Service	3200 MW	
NIAGARA_-ROBNSNRD_230_64				FWD (Import)	REV (Export)
Fri 03/28/2025	to	Fri 03/28/2025	SCH - OH - NY		
0500	Continuous	1900	Impacts Total Transfer Capability		
Work scheduled by: NYPA			TTC with All Lines In Service		

NYISO TRANSFER LIMITATIONS

Seasonal Limits		Tuesday, December 17, 2024 to Tuesday, June 16, 2026			
CENTRAL EAST	7550 MW	The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.			
CENTRAL EAST - VC	3725 MW				
TOTAL EAST	6150 MW				
UPNY CONED	8050 MW				
SPR/DUN-SOUTH	4600 MW				
DYSINGER EAST	3200 MW				
MOSES SOUTH	3150 MW				
<hr/>					
NINEMILE-CLAY___345_8				FWD (Import)	REV (Export)
Wed 04/02/2025	to	Wed 04/02/2025	OSWEGO EXPORT	5150 MW	
1900	Continuous	2000	Impacts Total Transfer Capability	100 MW	
Work scheduled by: NGrid			TTC with All Lines In Service	5250 MW	
<hr/>					
NIAGARA_-DYSINGER_345_ND2				FWD (Import)	REV (Export)
Mon 04/07/2025	to	Fri 04/11/2025	DYSINGER EAST	2700 MW	
0500	Continuous	1730	Impacts Total Transfer Capability	500 MW	
Work scheduled by: NYPA			TTC with All Lines In Service	3200 MW	
<hr/>					
LINDN_CG-LNDVFT___345_V-3022				FWD (Import)	REV (Export)
Mon 04/07/2025	to	Sat 04/12/2025	SCH - PJM_VFT	0 MW	0 MW
0800	Continuous	1500	Impacts Total Transfer Capability	315 MW	315 MW
Work scheduled by: PJM			TTC with All Lines In Service	315 MW	315 MW
<hr/>					
RAMAPO_-BUCHAN_N_345_Y94				FWD (Import)	REV (Export)
Sat 04/12/2025	to	Sat 04/19/2025	UPNY CONED	7755 MW	
0001	Continuous	0200	Impacts Total Transfer Capability	295 MW	
Work scheduled by: ConEd			TTC with All Lines In Service	8050 MW	
<hr/>					
SPRNBRK_-TREMONT___345_X28				FWD (Import)	REV (Export)
Mon 04/14/2025	to	Sun 04/20/2025	SPR/DUN-SOUTH	4200 MW	
0001	Continuous	0200	Impacts Total Transfer Capability	400 MW	
Work scheduled by: ConEd			TTC with All Lines In Service	4600 MW	
<hr/>					
NIAGARA_-DYSINGER_345_ND2				FWD (Import)	REV (Export)
Mon 04/14/2025	to	Thu 04/17/2025	DYSINGER EAST	2700 MW	
0500	Continuous	1730	Impacts Total Transfer Capability	500 MW	
Work scheduled by: NYPA			TTC with All Lines In Service	3200 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits		Tuesday, December 17, 2024 to Tuesday, June 16, 2026				
CENTRAL EAST	7550 MW	The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.				
CENTRAL EAST - VC	3725 MW					
TOTAL EAST	6150 MW					
UPNY CONED	8050 MW					
SPR/DUN-SOUTH	4600 MW					
DYSINGER EAST	3200 MW					
MOSES SOUTH	3150 MW					
E13THSTA-FARRAGUT_345_45					FWD (Import)	REV (Export)
Tue 04/15/2025	to	Sun 04/20/2025	SPR/DUN-SOUTH	3800 MW		
0001	Continuous	0200	Impacts Total Transfer Capability	800 MW		
Work scheduled by: ConEd			TTC with All Lines In Service	4600 MW		
W49TH_ST-E13THSTA_345_M54					FWD (Import)	REV (Export)
Tue 04/15/2025	to	Sun 04/20/2025	SPR/DUN-SOUTH	3800 MW		
0001	Continuous	0200	Impacts Total Transfer Capability	800 MW		
Work scheduled by: ConEd			TTC with All Lines In Service	4600 MW		
MOSES_-_ADIRNDCK_230_MA1					FWD (Import)	REV (Export)
Tue 04/15/2025	to	Tue 04/15/2025	MOSES SOUTH	2300 MW		
0700	Continuous	1530	Impacts Total Transfer Capability	850 MW		
Work scheduled by: NYPA			TTC with All Lines In Service	3150 MW		
LINDN_CG-LNDVFT__345_V-3022					FWD (Import)	REV (Export)
Thu 04/17/2025	to	Thu 04/17/2025	SCH - PJM_VFT	0 MW	0 MW	
1500	Continuous	1800	Impacts Total Transfer Capability	315 MW	315 MW	
Work scheduled by: PJM			TTC with All Lines In Service	315 MW	315 MW	
NIAGARA_-PACKARD_230_61					FWD (Import)	REV (Export)
Mon 04/21/2025	to	Fri 04/25/2025	SCH - OH - NY	2450 MW	1800 MW	
0500	Continuous	1900	Impacts Total Transfer Capability	50 MW	50 MW	
Work scheduled by: NYPA			TTC with All Lines In Service	2500 MW	1850 MW	
PANNELL_-CLAY__345_1					FWD (Import)	REV (Export)
Mon 04/21/2025	to	Fri 04/25/2025	WEST CENTRAL	1300 MW		
0700	Continuous	1530	Impacts Total Transfer Capability	950 MW		
Work scheduled by: NYPA			TTC with All Lines In Service	2250 MW		

NYISO TRANSFER LIMITATIONS

Seasonal Limits		Tuesday, December 17, 2024 to Tuesday, June 16, 2026				
CENTRAL EAST	7550 MW	The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.				
CENTRAL EAST - VC	3725 MW					
TOTAL EAST	6150 MW					
UPNY CONED	8050 MW					
SPR/DUN-SOUTH	4600 MW					
DYSINGER EAST	3200 MW					
MOSES SOUTH	3150 MW					
<hr/>						
MOSES __ADIRNDCK_230_MA2				FWD (Import)	REV (Export)	
Tue 04/22/2025	to	Tue 04/22/2025	MOSES SOUTH	2300 MW		
0700	Continuous	1530	Impacts Total Transfer Capability	850 MW		
Work scheduled by: NYPA			TTC with All Lines In Service	3150 MW		
<hr/>						
MARCY __765_345_AT1				FWD (Import)	REV (Export)	
Fri 04/25/2025	to	Fri 04/25/2025	MOSES SOUTH	1750 MW		
0500	Continuous	1730	Impacts Total Transfer Capability	1400 MW		
Work scheduled by: NYPA		ARR: 19	TTC with All Lines In Service	3150 MW		
<hr/>						
MARCY __765_345_AT2				FWD (Import)	REV (Export)	
Sat 04/26/2025	to	Sat 04/26/2025	MOSES SOUTH	1700 MW		
0500	Continuous	1730	Impacts Total Transfer Capability	1450 MW		
Work scheduled by: NYPA		ARR: 19	TTC with All Lines In Service	3150 MW		
<hr/>						
BUCHAN _S-MILLWOOD_345_W97				FWD (Import)	REV (Export)	
Mon 04/28/2025	to	Tue 04/29/2025	UPNY CONED	8015 MW		
0001	Continuous	0230	Impacts Total Transfer Capability	35 MW		
Work scheduled by: ConEd			TTC with All Lines In Service	8050 MW		
<hr/>						
PANNELL _CLAY __345_2				FWD (Import)	REV (Export)	
Mon 04/28/2025	to	Fri 05/02/2025	WEST CENTRAL	1300 MW		
0700	Continuous	1530	Impacts Total Transfer Capability	950 MW		
Work scheduled by: NYPA			TTC with All Lines In Service	2250 MW		
<hr/>						
E13THSTA-FARRAGUT_345_46				FWD (Import)	REV (Export)	
Tue 05/06/2025	to	Sat 05/10/2025	SPR/DUN-SOUTH	3800 MW		
0001	Continuous	0200	Impacts Total Transfer Capability	800 MW		
Work scheduled by: ConEd			TTC with All Lines In Service	4600 MW		

NYISO TRANSFER LIMITATIONS

Seasonal Limits		Tuesday, December 17, 2024 to Tuesday, June 16, 2026				
CENTRAL EAST	7550 MW	The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.				
CENTRAL EAST - VC	3725 MW					
TOTAL EAST	6150 MW					
UPNY CONED	8050 MW					
SPR/DUN-SOUTH	4600 MW					
DYSINGER EAST	3200 MW					
MOSES SOUTH	3150 MW					
LONG_MTN-CRICKVLY_345_398					FWD (Import)	REV (Export)
Tue 05/06/2025	to	Thu 05/29/2025	SCH - NPX_1385	100 MW	100 MW	
0001	Continuous	2200	Impacts Total Transfer Capability	100 MW	100 MW	
Work scheduled by: ConEd			TTC with All Lines In Service	200 MW	200 MW	
LONG_MTN-CRICKVLY_345_398					FWD (Import)	REV (Export)
Tue 05/06/2025	to	Thu 05/29/2025	SCH - NE - NY	800 MW	1200 MW	
0001	Continuous	2200	Impacts Total Transfer Capability	600 MW	400 MW	
Work scheduled by: ConEd			TTC with All Lines In Service	1400 MW	1600 MW	
W49TH_ST_345KV_6					FWD (Import)	REV (Export)
Tue 05/06/2025	to	Tue 05/06/2025	SCH - PJM_HTP	300 MW		
0001	Continuous	0030	Impacts Total Transfer Capability	360 MW		
Work scheduled by: ConEd			TTC with All Lines In Service	660 MW		
W49TH_ST-E13THSTA_345_M55					FWD (Import)	REV (Export)
Tue 05/06/2025	to	Sat 05/10/2025	SPR/DUN-SOUTH	3800 MW		
0001	Continuous	0200	Impacts Total Transfer Capability	800 MW		
Work scheduled by: ConEd			TTC with All Lines In Service	4600 MW		
WOOD_ST-PLSNTVLE_345_Y87					FWD (Import)	REV (Export)
Wed 05/07/2025	to	Fri 05/09/2025	UPNY CONED	7470 MW		
2200	Continuous	0259	Impacts Total Transfer Capability	580 MW		
Work scheduled by: ConEd			TTC with All Lines In Service	8050 MW		
DUNWODIE_345KV_6					FWD (Import)	REV (Export)
Fri 05/09/2025	to	Fri 05/09/2025	SPR/DUN-SOUTH	3800 MW		
0001	Continuous	0030	Impacts Total Transfer Capability	800 MW		
Work scheduled by: ConEd			TTC with All Lines In Service	4600 MW		

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, December 17, 2024 to Tuesday, June 16, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_8

Fri 05/09/2025 to Fri 05/09/2025
0001 Continuous 0030
Work scheduled by: ConEd

SPR/DUN-SOUTH
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

W49TH_ST_345KV_6

Sat 05/10/2025 to Sat 05/10/2025
0130 Continuous 0200
Work scheduled by: ConEd

SCH - PJM_HTP
Impacts Total Transfer Capability 360 MW
TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

DUNWODIE_345KV_6

Sun 05/11/2025 to Sun 05/11/2025
1830 Continuous 1900
Work scheduled by: ConEd

SPR/DUN-SOUTH
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

DUNWODIE_345KV_8

Sun 05/11/2025 to Sun 05/11/2025
1830 Continuous 1900
Work scheduled by: ConEd

SPR/DUN-SOUTH
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

NEPTUNE_DUFFYAVE_345_NEPTUNE

Mon 05/12/2025 to Fri 05/16/2025
0600 Continuous 1600
Work scheduled by: LI

SCH - PJM_NEPTUNE
Impacts Total Transfer Capability 660 MW
TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

NEWBRDGE_345_138_BK_1

Mon 05/12/2025 to Fri 05/16/2025
0600 Continuous 1600
Work scheduled by: LI

SCH - PJM_NEPTUNE
Impacts Total Transfer Capability 285 MW
TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

NYISO TRANSFER LIMITATIONS

Seasonal Limits			Tuesday, December 17, 2024 to Tuesday, June 16, 2026		
CENTRAL EAST	7550 MW		The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.		
CENTRAL EAST - VC	3725 MW				
TOTAL EAST	6150 MW				
UPNY CONED	8050 MW				
SPR/DUN-SOUTH	4600 MW				
DYSINGER EAST	3200 MW				
MOSES SOUTH	3150 MW				
NEWBRDGE_345_138_BK_2				FWD (Import)	REV (Export)
Mon 05/12/2025	to	Fri 05/16/2025	SCH - PJM_NEPTUNE	375 MW	
0600	Continuous	1600	Impacts Total Transfer Capability	285 MW	
Work scheduled by: LI			TTC with All Lines In Service	660 MW	
NEWBRDGE-DUFFYAVE_345_501				FWD (Import)	REV (Export)
Mon 05/12/2025	to	Fri 05/16/2025	SCH - PJM_NEPTUNE	0 MW	
0600	Continuous	1600	Impacts Total Transfer Capability	660 MW	
Work scheduled by: LI			TTC with All Lines In Service	660 MW	
SAND_BAR-PLATSBRG_115_PV20				FWD (Import)	REV (Export)
Mon 07/07/2025	to	Fri 07/11/2025	SCH - NE - NY		
0700	Continuous	1530	Impacts Total Transfer Capability		
Work scheduled by: NYPA			TTC with All Lines In Service		
SAND_BAR-PLATSBRG_115_PV20				FWD (Import)	REV (Export)
Mon 07/07/2025	to	Fri 07/11/2025	CENTRAL EAST - VC	3625 MW	
0700	Continuous	1530	Impacts Total Transfer Capability	100 MW	
Work scheduled by: NYPA			TTC with All Lines In Service	3725 MW	
NIAGARA_345_230_AT4				FWD (Import)	REV (Export)
Tue 07/08/2025	to	Tue 07/08/2025	SCH - OH - NY	1200 MW	
0500	Continuous	1900	Impacts Total Transfer Capability		400 MW
Work scheduled by: NYPA			TTC with All Lines In Service		1600 MW
DYSINGER-STA_255_345_DH1				FWD (Import)	REV (Export)
Tue 09/02/2025	to	Mon 09/15/2025	DYSINGER EAST	2850 MW	
0500	Continuous	2100	Impacts Total Transfer Capability	350 MW	
Work scheduled by: NYPA			TTC with All Lines In Service	3200 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, December 17, 2024 to Tuesday, June 16, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

GOETHALS_345KV_5

Mon 09/08/2025 to Mon 09/08/2025
0301 Continuous 0330
Work scheduled by: ConEd

STATEN ISLAND
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

CLAY__-EDIC__345_2-15

Mon 09/08/2025 to Fri 09/12/2025
0700 Continuous 1530
Work scheduled by: NYPA

OSWEGO EXPORT
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

4850 MW
400 MW
5250 MW

MOSES__-ADIRNDCK_230_MA1

Tue 09/09/2025 to Sun 10/12/2025
0700 Continuous 1730
Work scheduled by: NYPA

MOSES SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

2100 MW
1050 MW
3150 MW

GOETHALS_345KV_5

Tue 09/09/2025 to Tue 09/09/2025
2330 Continuous 2359
Work scheduled by: ConEd

STATEN ISLAND
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

DUNWODIE_345KV_4

Sat 09/13/2025 to Sun 09/14/2025
0001 Continuous 2200
Work scheduled by: ConEd

UPDATED by ConEd 11/08/2024 12:36

SPR/DUN-SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

3800 MW
800 MW
4600 MW

DUNWODIE_345KV_6

Sat 09/13/2025 to Sun 09/14/2025
0001 Continuous 2200
Work scheduled by: ConEd

UPDATED by ConEd 11/08/2024 12:36

SPR/DUN-SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

3800 MW
800 MW
4600 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, December 17, 2024 to Tuesday, June 16, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE-SHORE_RD_345_Y50

Sat 09/13/2025 to Sun 09/14/2025
0001 Continuous 2200
Work scheduled by: ConEd

UPDATED by ConEd 11/08/2024 12:36

CONED - LIPA
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
800 MW
700 MW
1500 MW

SHORE_RD_345_138_BK 1

Sat 09/13/2025 to Sun 09/14/2025
0001 Continuous 2200
Work scheduled by: ConEd

UPDATED by ConEd 11/08/2024 12:36

CONED - LIPA
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
1350 MW
150 MW
1500 MW

SHORE_RD_345_138_BK 2

Sat 09/13/2025 to Sun 09/14/2025
0001 Continuous 2200
Work scheduled by: ConEd

UPDATED by ConEd 11/08/2024 12:36

CONED - LIPA
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
1350 MW
150 MW
1500 MW

SPRNBK_345KV_RNS4

Mon 09/15/2025 to Thu 10/02/2025
0001 Continuous 0200
Work scheduled by: ConEd

SPR/DUN-SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
3200 MW
1400 MW
4600 MW

SPRNBK_W49TH_ST_345_M52

Mon 09/15/2025 to Thu 10/02/2025
0001 Continuous 0200
Work scheduled by: ConEd

SPR/DUN-SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
3200 MW
1400 MW
4600 MW

W49TH_ST_345KV_5

Mon 09/15/2025 to Mon 09/15/2025
0001 Continuous 0030
Work scheduled by: ConEd

SCH - PJM_HTP
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
460 MW
200 MW
660 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits		Tuesday, December 17, 2024 to Tuesday, June 16, 2026			
CENTRAL EAST	7550 MW	<div>The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.</div>			
CENTRAL EAST - VC	3725 MW				
TOTAL EAST	6150 MW				
UPNY CONED	8050 MW				
SPR/DUN-SOUTH	4600 MW				
DYSINGER EAST	3200 MW				
MOSES SOUTH	3150 MW				
GOETHALS_345KV_5				FWD (Import)	REV (Export)
Mon 09/15/2025	to	Mon 09/15/2025	STATEN ISLAND		
0230	Continuous	0300	Impacts Total Transfer Capability		
Work scheduled by: ConEd			TTC with All Lines In Service		
ADIRNDCK-PORTER__230_12				FWD (Import)	REV (Export)
Mon 09/15/2025	to	Sun 10/12/2025	MOSES SOUTH	2100 MW	
0600	Continuous	1700	Impacts Total Transfer Capability	1050 MW	
Work scheduled by: NGrid			TTC with All Lines In Service	3150 MW	
DYSINGER-STA_255_345_DH2				FWD (Import)	REV (Export)
Tue 09/16/2025	to	Tue 10/28/2025	DYSINGER EAST	2850 MW	
0500	Continuous	1900	Impacts Total Transfer Capability	350 MW	
Work scheduled by: NYPA			TTC with All Lines In Service	3200 MW	
MARCY__FRASANNX_345_UCC2-41				FWD (Import)	REV (Export)
Mon 09/22/2025	to	Mon 10/06/2025	CENTRAL EAST - VC	3225 MW	
0700	Continuous	1730	Impacts Total Transfer Capability	500 MW	
Work scheduled by: NYPA			TTC with All Lines In Service	3725 MW	
PANNELL_-CLAY__345_1				FWD (Import)	REV (Export)
Mon 09/29/2025	to	Fri 10/03/2025	WEST CENTRAL	1300 MW	
0700	Continuous	1530	Impacts Total Transfer Capability	950 MW	
Work scheduled by: NYPA			TTC with All Lines In Service	2250 MW	
W49TH_ST_345KV_5				FWD (Import)	REV (Export)
Thu 10/02/2025	to	Thu 10/02/2025	SCH - PJM_HTP	460 MW	
0130	Continuous	0200	Impacts Total Transfer Capability	200 MW	
Work scheduled by: ConEd			TTC with All Lines In Service	660 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, December 17, 2024 to Tuesday, June 16, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PANNELL__CLAY___345_2

Mon 10/06/2025 to Fri 10/10/2025
0700 Continuous 1530
Work scheduled by: NYPA

WEST CENTRAL
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) REV (Export)
1300 MW
950 MW
2250 MW

NEPTUNE__DUFFYAVE_345_NEPTUNE

Mon 10/13/2025 to Thu 10/16/2025
0600 Continuous 1600
Work scheduled by: LI

SCH - PJM_NEPTUNE
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) REV (Export)
0 MW
660 MW
660 MW

NEWBRDGE_345_138_BK_1

Mon 10/13/2025 to Thu 10/16/2025
0600 Continuous 1600
Work scheduled by: LI

SCH - PJM_NEPTUNE
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) REV (Export)
375 MW
285 MW
660 MW

NEWBRDGE_345_138_BK_2

Mon 10/13/2025 to Thu 10/16/2025
0600 Continuous 1600
Work scheduled by: LI

SCH - PJM_NEPTUNE
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) REV (Export)
375 MW
285 MW
660 MW

NEWBRDGE-DUFFYAVE_345_501

Mon 10/13/2025 to Thu 10/16/2025
0600 Continuous 1600
Work scheduled by: LI

SCH - PJM_NEPTUNE
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) REV (Export)
0 MW
660 MW
660 MW

MOSES__ADIRNDCK_230_MA2

Mon 10/13/2025 to Mon 11/24/2025
0700 Continuous 1730
Work scheduled by: NYPA

MOSES SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) REV (Export)
2100 MW
1050 MW
3150 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, December 17, 2024 to Tuesday, June 16, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EDIC__-PRINCTWN_345_351				FWD (Import)	REV (Export)
Tue 10/14/2025	to	Fri 10/17/2025	CENTRAL EAST - VC	3335 MW	
0600	Continuous	1830	Impacts Total Transfer Capability	390 MW	
Work scheduled by: NGrid			TTC with All Lines In Service	3725 MW	
SPRNBK_-TREMONT_345_X28				FWD (Import)	REV (Export)
Mon 10/27/2025	to	Fri 10/31/2025	SPR/DUN-SOUTH	4200 MW	
0001	Continuous	1800	Impacts Total Transfer Capability	400 MW	
Work scheduled by: ConEd			TTC with All Lines In Service	4600 MW	
MARION_-FARRAGUT_345_C3403				FWD (Import)	REV (Export)
Sat 11/01/2025	to	Mon 11/03/2025	SCH - PJ - NY		
0001	Continuous	0300	Impacts Total Transfer Capability		
Work scheduled by: ConEd			TTC with All Lines In Service		
CHATGUAY-MASSENA_765_7040				FWD (Import)	REV (Export)
Sun 11/16/2025	to	Sun 11/30/2025	SCH - HQ - NY	0 MW	0 MW
0001	Continuous	2359	Impacts Total Transfer Capability	1500 MW	1000 MW
Work scheduled by: NYPA			TTC with All Lines In Service	1500 MW	1000 MW
CHATGUAY-MASSENA_765_7040				FWD (Import)	REV (Export)
Sun 11/16/2025	to	Sun 11/30/2025	MOSES SOUTH	1550 MW	
0001	Continuous	2359	Impacts Total Transfer Capability	1600 MW	
Work scheduled by: NYPA			TTC with All Lines In Service	3150 MW	
MOSES__-ADIRNDCK_230_MA2 , MOSES__-MASSENA_230_MMS2 , MOSES__-MASSENA_230_MMS1				FWD (Import)	REV (Export)
Sun 11/16/2025	to	Mon 11/24/2025	SCH - HQ_CEDARS	90 MW	
0001		1730	Impacts Total Transfer Capability	189 MW	
Work scheduled by:			TTC with All Lines In Service	279 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits		Tuesday, December 17, 2024 to Tuesday, June 16, 2026			
CENTRAL EAST	7550 MW	The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.			
CENTRAL EAST - VC	3725 MW				
TOTAL EAST	6150 MW				
UPNY CONED	8050 MW				
SPR/DUN-SOUTH	4600 MW				
DYSINGER EAST	3200 MW				
MOSES SOUTH	3150 MW				
<hr/>					
MOSES__-MASSENA_230_MMS2 , MOSES__-MASSENA_230_MMS1				FWD (Import)	REV (Export)
Sun 11/16/2025	to	Sun 11/30/2025	SCH - HQ_CEDARS	90 MW	
0001		2359	Impacts Total Transfer Capability	189 MW	
Work scheduled by:			TTC with All Lines In Service	279 MW	
<hr/>					
MOSES__-MASSENA_230_MMS2 , MOSES__-MASSENA_230_MMS1				FWD (Import)	REV (Export)
Sun 11/16/2025	to	Sun 11/30/2025	SCH - HQ - NY	850 MW	0 MW
0001		2359	Impacts Total Transfer Capability	650 MW	1000 MW
Work scheduled by:			TTC with All Lines In Service	1500 MW	1000 MW
<hr/>					
MOTHAVN-RAINEY__345_Q11				FWD (Import)	REV (Export)
Mon 12/01/2025	to	Tue 12/02/2025	SPR/DUN-SOUTH	3800 MW	
0001	Continuous	0230	Impacts Total Transfer Capability	800 MW	
Work scheduled by:	ConEd		TTC with All Lines In Service	4600 MW	
<hr/>					
MARION_-FARRAGUT_345_C3403				FWD (Import)	REV (Export)
Wed 12/10/2025	to	Mon 12/15/2025	SCH - PJ - NY		
0001	Continuous	0300	Impacts Total Transfer Capability		
Work scheduled by:	ConEd		TTC with All Lines In Service		
<hr/>					
GOETHALS_345KV_5				FWD (Import)	REV (Export)
Sat 01/17/2026	to	Sat 01/17/2026	STATEN ISLAND		
0301	Continuous	0330	Impacts Total Transfer Capability		
Work scheduled by:	ConEd		TTC with All Lines In Service		
<hr/>					
DYSINGER-STA_255_345_DH2				FWD (Import)	REV (Export)
Mon 03/02/2026	to	Fri 03/13/2026	DYSINGER EAST	2850 MW	
0500	Continuous	1900	Impacts Total Transfer Capability	350 MW	
Work scheduled by:	NYPA		TTC with All Lines In Service	3200 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, December 17, 2024 to Tuesday, June 16, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DYSINGER-STA_255_345_DH1

Mon 03/16/2026 to Tue 04/07/2026
0500 Continuous 2100
Work scheduled by: NYPA

DYSINGER EAST **2850 MW**
Impacts Total Transfer Capability 350 MW
TTC with All Lines In Service 3200 MW

DYSINGER-STA_255_345_DH2

Wed 04/08/2026 to Mon 04/20/2026
0500 Continuous 2100
Work scheduled by: NYPA

DYSINGER EAST **2850 MW**
Impacts Total Transfer Capability 350 MW
TTC with All Lines In Service 3200 MW

DYSINGER-STA_255_345_DH1

Tue 04/21/2026 to Fri 05/01/2026
0500 Continuous 2100
Work scheduled by: NYPA

DYSINGER EAST **2850 MW**
Impacts Total Transfer Capability 350 MW
TTC with All Lines In Service 3200 MW

GOETHALS_345KV_5

Sat 04/25/2026 to Sat 04/25/2026
2330 Continuous 2359
Work scheduled by: ConEd

UPDATED by ConEd 07/10/2024 16:09

STATEN ISLAND
Impacts Total Transfer Capability
TTC with All Lines In Service

GOETHALS_345KV_5

Mon 04/27/2026 to Mon 04/27/2026
0001 Continuous 0030
Work scheduled by: ConEd

UPDATED by ConEd 07/10/2024 16:09

STATEN ISLAND
Impacts Total Transfer Capability
TTC with All Lines In Service

GOETHALS_345KV_5

Tue 05/05/2026 to Tue 05/05/2026
0230 Continuous 0300
Work scheduled by: ConEd

UPDATED by ConEd 07/10/2024 16:09

STATEN ISLAND
Impacts Total Transfer Capability
TTC with All Lines In Service

NYISO TRANSFER LIMITATIONS

Seasonal Limits		Tuesday, December 17, 2024 to Tuesday, June 16, 2026			
CENTRAL EAST	7550 MW	The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.			
CENTRAL EAST - VC	3725 MW				
TOTAL EAST	6150 MW				
UPNY CONED	8050 MW				
SPR/DUN-SOUTH	4600 MW				
DYSINGER EAST	3200 MW				
MOSES SOUTH	3150 MW				
NEPTUNE_DUFFYAVE_345_NEPTUNE				FWD (Import)	REV (Export)
Mon 05/11/2026	to	Fri 05/15/2026	SCH - PJM_NEPTUNE	0 MW	
0600	Continuous	1600	Impacts Total Transfer Capability	660 MW	
Work scheduled by: LI			TTC with All Lines In Service	660 MW	
NEWBRDGE_345_138_BK_1				FWD (Import)	REV (Export)
Mon 05/11/2026	to	Fri 05/15/2026	SCH - PJM_NEPTUNE	375 MW	
0600	Continuous	1600	Impacts Total Transfer Capability	285 MW	
Work scheduled by: LI			TTC with All Lines In Service	660 MW	
NEWBRDGE_345_138_BK_2				FWD (Import)	REV (Export)
Mon 05/11/2026	to	Fri 05/15/2026	SCH - PJM_NEPTUNE	375 MW	
0600	Continuous	1600	Impacts Total Transfer Capability	285 MW	
Work scheduled by: LI			TTC with All Lines In Service	660 MW	
NEWBRDGE-DUFFYAVE_345_501				FWD (Import)	REV (Export)
Mon 05/11/2026	to	Fri 05/15/2026	SCH - PJM_NEPTUNE	0 MW	
0600	Continuous	1600	Impacts Total Transfer Capability	660 MW	
Work scheduled by: LI			TTC with All Lines In Service	660 MW	