

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Friday, December 27, 2024 to Friday, June 26, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONP_-FARRAGUT_345_B3402

Mon 01/15/2018 to Thu 05/01/2025
0001 Continuous 0100
Work scheduled by: ConEd

EXT FORCED by ConEd 03/11/2024 11:26

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Thu 05/01/2025
0001 Continuous 0100
Work scheduled by: ConEd

EXT FORCED by ConEd 03/11/2024 11:26

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

MARION_-FARRAGUT_345_C3403 , HUDSONP_-FARRAGUT_345_B3402

Mon 01/15/2018 to Thu 05/01/2025
0001 0100
Work scheduled by:

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
2400 MW	2400 MW
200 MW	300 MW
2600 MW	2700 MW

MARCY__345KV_CSC

Sat 06/15/2024 to Sat 05/24/2025
0001 Continuous 2359
Work scheduled by: NYPA

FORCED by NYPA 06/11/2024 15:44

CENTRAL EAST - VC
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
3650 MW	
75 MW	
3725 MW	

W49TH_ST_345KV_6

Fri 09/27/2024 to Mon 12/30/2024
0101 Continuous 2359
Work scheduled by: ConEd

UPDATED by ConEd 09/25/2024 08:24

SCH - PJM_HTP
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
300 MW	
360 MW	
660 MW	

W49TH_ST-E13THSTA_345_M55

Fri 09/27/2024 to Mon 12/30/2024
0101 Continuous 2359
Work scheduled by: ConEd

UPDATED by ConEd 09/25/2024 08:24

SPR/DUN-SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
3800 MW	
800 MW	
4600 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Friday, December 27, 2024 to Friday, June 26, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___765_345_AT1

Mon 10/14/2024 to Fri 01/24/2025
2110 Continuous 2359
Work scheduled by: NYPA

MOSES SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) 1750 MW
REV (Export) 1400 MW
3150 MW

SCH-IMO-NYISO_LIMIT_1900

Fri 11/01/2024 to Wed 04/30/2025
0001 Continuous 2359
Work scheduled by: IESO

SCH - OH - NY
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) 2200 MW
REV (Export) 300 MW
2500 MW

S.RIPLEY-DUNKIRK_230_68

Fri 11/08/2024 to Fri 01/31/2025
1113 Continuous 1800
Work scheduled by: PJM
EXT FORCED by NGrid 11/13/2024 16:46

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) REV (Export)

SCH-HQ-NYISO_LIMIT_1100

Wed 12/04/2024 to Wed 03/19/2025
1801 Continuous 1600
Work scheduled by: HQ

SCH - HQ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) 1100 MW
REV (Export) 400 MW
1500 MW

SCH-PJM-NYISO_LIMIT_1900

Wed 12/25/2024 to Fri 12/27/2024
0001 Continuous 2359
Work scheduled by: NYISO

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) 2200 MW
REV (Export) 400 MW
2600 MW

SCH-PJM-NYISO_LIMIT_1700

Sat 12/28/2024 to Wed 01/08/2025
0001 Continuous 2359
Work scheduled by: NYISO

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) 2000 MW
REV (Export) 600 MW
2600 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Friday, December 27, 2024 to Friday, June 26, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EGRDNCTY_345_138_AT2

Mon 12/30/2024 to Mon 12/30/2024
0700 Continuous 1200
Work scheduled by: NYPA

CONED - LIPA
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
1250 MW
250 MW
1500 MW

ROSETON_EFISHKIL_345_RFK305

Mon 12/30/2024 to Tue 12/31/2024
0700 Continuous 1600
Work scheduled by: CHGE

UPNY CONED
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
7215 MW
835 MW
8050 MW

EGRDNCTY_345_138_AT1

Mon 12/30/2024 to Mon 12/30/2024
1201 Continuous 1700
Work scheduled by: NYPA

CONED - LIPA
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
1250 MW
250 MW
1500 MW

W49TH_ST_345KV_6

Tue 12/31/2024 to Wed 01/29/2025
0001 Continuous 0200
Work scheduled by: ConEd

UPDATED by ConEd 12/18/2024 15:15

SCH - PJM_HTP
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
300 MW
360 MW
660 MW

W49TH_ST_345KV_8

Tue 12/31/2024 to Sun 01/19/2025
0001 Continuous 2359
Work scheduled by: ConEd

UPDATED by ConEd 12/18/2024 15:15

SCH - PJM_HTP
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
310 MW
350 MW
660 MW

W49TH_ST-E13THSTA_345_M55

Tue 12/31/2024 to Wed 01/29/2025
0001 Continuous 0200
Work scheduled by: ConEd

UPDATED by ConEd 12/18/2024 15:15

SPR/DUN-SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
3800 MW
800 MW
4600 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Friday, December 27, 2024 to Friday, June 26, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MILLWOOD-EASTVIEW_345_W85

Thu 01/02/2025 to Thu 01/02/2025
0001 Continuous 0030
Work scheduled by: ConEd

UPNY CONED
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
7810 MW
240 MW
8050 MW

SPRNBK_345KV_RNS3

Thu 01/02/2025 to Thu 01/02/2025
0001 Continuous 1830
Work scheduled by: ConEd

SPR/DUN-SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
3800 MW
800 MW
4600 MW

KNICRBKR-PLSNTVLY_345_Y57

Thu 01/02/2025 to Wed 01/15/2025
0530 Continuous 1830
Work scheduled by: NGrid ARR: 78

UPNY CONED
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
7885 MW
165 MW
8050 MW

MILLWOOD-EASTVIEW_345_W85

Thu 01/02/2025 to Thu 01/02/2025
1800 Continuous 1830
Work scheduled by: ConEd

UPNY CONED
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
7810 MW
240 MW
8050 MW

DUNWODIE_345KV_5

Sat 01/04/2025 to Sun 01/05/2025
0001 Continuous 0259
Work scheduled by: ConEd

SPR/DUN-SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
3800 MW
800 MW
4600 MW

DUNWODIE_345KV_7

Sat 01/04/2025 to Sun 01/05/2025
0001 Continuous 0259
Work scheduled by: ConEd

SPR/DUN-SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
3800 MW
800 MW
4600 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits		Friday, December 27, 2024 to Friday, June 26, 2026				
CENTRAL EAST	7550 MW	The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.				
CENTRAL EAST - VC	3725 MW					
TOTAL EAST	6150 MW					
UPNY CONED	8050 MW					
SPR/DUN-SOUTH	4600 MW					
DYSINGER EAST	3200 MW					
MOSES SOUTH	3150 MW					
SPRNBK_345KV_RNS3					FWD (Import)	REV (Export)
Sat 01/04/2025	to	Sun 01/05/2025	SPR/DUN-SOUTH	3800 MW		
0001	Continuous	0259	Impacts Total Transfer Capability	800 MW		
Work scheduled by: ConEd			TTC with All Lines In Service	4600 MW		
SPRNBK_DUNWODIE_345_W75					FWD (Import)	REV (Export)
Sat 01/04/2025	to	Sun 01/05/2025	SPR/DUN-SOUTH	3800 MW		
0001	Continuous	0259	Impacts Total Transfer Capability	800 MW		
Work scheduled by: ConEd			TTC with All Lines In Service	4600 MW		
NRTH1385-NOR HBR_138_601					FWD (Import)	REV (Export)
Mon 01/06/2025	to	Fri 01/10/2025	SCH - NPX_1385	100 MW	100 MW	
0500	Continuous	1500	Impacts Total Transfer Capability	100 MW	100 MW	
Work scheduled by: LI			TTC with All Lines In Service	200 MW	200 MW	
NRTH1385-NOR HBR_138_602					FWD (Import)	REV (Export)
Mon 01/06/2025	to	Fri 01/10/2025	SCH - NPX_1385	100 MW	100 MW	
0500	Continuous	1500	Impacts Total Transfer Capability	100 MW	100 MW	
Work scheduled by: LI			TTC with All Lines In Service	200 MW	200 MW	
NRTH1385-NOR HBR_138_603					FWD (Import)	REV (Export)
Mon 01/06/2025	to	Fri 01/10/2025	SCH - NPX_1385	100 MW	100 MW	
0500	Continuous	1500	Impacts Total Transfer Capability	100 MW	100 MW	
Work scheduled by: LI			TTC with All Lines In Service	200 MW	200 MW	
NRTH1385-NORHBR_138_601 , NRTH1385-NORHBR_138_602					FWD (Import)	REV (Export)
Mon 01/06/2025	to	Fri 01/10/2025	SCH - NPX_1385	0 MW	0 MW	
0500		1500	Impacts Total Transfer Capability	200 MW	200 MW	
Work scheduled by:			TTC with All Lines In Service	200 MW	200 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Friday, December 27, 2024 to Friday, June 26, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NRTH1385-NORHBR_138_601 , NRTH1385-NORHBR_138_603

Mon 01/06/2025 to Fri 01/10/2025
0500 1500
Work scheduled by:

SCH - NPX_1385

FWD (Import) REV (Export)

Impacts Total Transfer Capability

0 MW 0 MW

TTC with All Lines In Service

200 MW 200 MW

200 MW 200 MW

NRTH1385-NORHBR_138_603 , NRTH1385-NORHBR_138_602

Mon 01/06/2025 to Fri 01/10/2025
0500 1500
Work scheduled by:

SCH - NPX_1385

FWD (Import) REV (Export)

Impacts Total Transfer Capability

0 MW 0 MW

TTC with All Lines In Service

200 MW 200 MW

200 MW 200 MW

NRTH1385-NRTHPORT_138_NNC

Mon 01/06/2025 to Fri 01/10/2025
0500 Continuous 1500
Work scheduled by: LI

SCH - NPX_1385

FWD (Import) REV (Export)

Impacts Total Transfer Capability

0 MW 0 MW

TTC with All Lines In Service

200 MW 200 MW

200 MW 200 MW

ADIRNDCK-PORTER_230_12

Mon 01/06/2025 to Sat 05/31/2025
0530 Continuous 1700
Work scheduled by: NGrid

MOSES SOUTH

FWD (Import) REV (Export)

Impacts Total Transfer Capability

2300 MW

TTC with All Lines In Service

850 MW

3150 MW

ELBRIDGE-LAFAYTTE_345_17-LE

Mon 01/06/2025 to Mon 01/06/2025
0630 Continuous 0800
Work scheduled by: NGrid

ARR: 75

OSWEGO EXPORT

FWD (Import) REV (Export)

Impacts Total Transfer Capability

5250 MW

TTC with All Lines In Service

0 MW

5250 MW

OSWEGO_-ELBRIDGE_345_17

Mon 01/06/2025 to Fri 01/31/2025
0630 Continuous 1730
Work scheduled by: NGrid

ARR: 75

OSWEGO EXPORT

FWD (Import) REV (Export)

Impacts Total Transfer Capability

5250 MW

TTC with All Lines In Service

0 MW

5250 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Friday, December 27, 2024 to Friday, June 26, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES__-ADIRNDCK_230_MA1

Tue 01/07/2025 to Tue 01/07/2025
0600 Continuous 2230
Work scheduled by: NYPA

MOSES SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) REV (Export)
2300 MW
850 MW
3150 MW

DUNWODIE_345KV_6

Thu 01/09/2025 to Tue 01/14/2025
0001 Continuous 2200
Work scheduled by: ConEd

SPR/DUN-SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) REV (Export)
3800 MW
800 MW
4600 MW

DUNWODIE_345KV_8

Thu 01/09/2025 to Tue 01/14/2025
0001 Continuous 2200
Work scheduled by: ConEd

SPR/DUN-SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) REV (Export)
3800 MW
800 MW
4600 MW

WOOD_ST_-PLSNTVLE_345_Y87

Thu 01/09/2025 to Tue 01/14/2025
0001 Continuous 2200
Work scheduled by: ConEd

UPNY CONED
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) REV (Export)
7470 MW
580 MW
8050 MW

BUCHAN_S-MILLWOOD_345_W97

Wed 01/15/2025 to Sat 01/18/2025
0200 Continuous 0159
Work scheduled by: ConEd

UPNY CONED
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) REV (Export)
8015 MW
35 MW
8050 MW

BUCHAN_S-MILLWOOD_345_W98

Sat 01/18/2025 to Tue 01/21/2025
0200 Continuous 0200
Work scheduled by: ConEd

UPNY CONED
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) REV (Export)
8015 MW
35 MW
8050 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits		Friday, December 27, 2024 to Friday, June 26, 2026				
CENTRAL EAST	7550 MW	The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.				
CENTRAL EAST - VC	3725 MW					
TOTAL EAST	6150 MW					
UPNY CONED	8050 MW					
SPR/DUN-SOUTH	4600 MW					
DYSINGER EAST	3200 MW					
MOSES SOUTH	3150 MW					
KNICRBKR-ALPS___345_6					FWD (Import)	REV (Export)
Mon 01/20/2025	to	Tue 01/21/2025	SCH - NE - NY	900 MW		
0530	Continuous	1830	Impacts Total Transfer Capability	500 MW		
Work scheduled by: NGrid			TTC with All Lines In Service	1400 MW		
KNICRBKR-ALPS___345_6					FWD (Import)	REV (Export)
Mon 01/20/2025	to	Tue 01/21/2025	SCH - NPX_1385	100 MW	100 MW	
0530	Continuous	1830	Impacts Total Transfer Capability	100 MW	100 MW	
Work scheduled by: NGrid			TTC with All Lines In Service	200 MW	200 MW	
RAMAPO_-BUCHAN_N_345_Y94					FWD (Import)	REV (Export)
Wed 01/22/2025	to	Wed 01/22/2025	UPNY CONED	7755 MW		
0001	Continuous	0030	Impacts Total Transfer Capability	295 MW		
Work scheduled by: ConEd			TTC with All Lines In Service	8050 MW		
RAMAPO_-BUCHAN_N_345_Y94					FWD (Import)	REV (Export)
Sat 01/25/2025	to	Sat 01/25/2025	UPNY CONED	7755 MW		
2130	Continuous	2200	Impacts Total Transfer Capability	295 MW		
Work scheduled by: ConEd			TTC with All Lines In Service	8050 MW		
DUNWODIE_345KV_7					FWD (Import)	REV (Export)
Sun 01/26/2025	to	Sun 02/02/2025	<u>UPDATED by ConEd 11/22/2024 08:59</u>	SPR/DUN-SOUTH	3800 MW	
0001	Continuous	2200		Impacts Total Transfer Capability	800 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	4600 MW	
DUNWODIE_345KV_8					FWD (Import)	REV (Export)
Sun 01/26/2025	to	Sun 02/02/2025	<u>UPDATED by ConEd 11/22/2024 08:59</u>	SPR/DUN-SOUTH	3800 MW	
0001	Continuous	2200		Impacts Total Transfer Capability	800 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	4600 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits		Friday, December 27, 2024 to Friday, June 26, 2026									
CENTRAL EAST	7550 MW	The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.									
CENTRAL EAST - VC	3725 MW										
TOTAL EAST	6150 MW										
UPNY CONED	8050 MW										
SPR/DUN-SOUTH	4600 MW										
DYSINGER EAST	3200 MW										
MOSES SOUTH	3150 MW										
<hr/>											
DUNWODIE-MOTTHAVN_345_72										FWD (Import)	REV (Export)
Sun 01/26/2025	to	Sun 02/02/2025	<u>UPDATED by ConEd 11/22/2024 08:59</u>				SPR/DUN-SOUTH	3800 MW			
0001	Continuous	2200					Impacts Total Transfer Capability	800 MW			
Work scheduled by: ConEd							TTC with All Lines In Service	4600 MW			
<hr/>											
ELBRIDGE-LAFAYTTE_345_17-LE										FWD (Import)	REV (Export)
Mon 01/27/2025	to	Fri 01/31/2025	ARR: 75				OSWEGO EXPORT	5250 MW			
0700	Continuous	1730					Impacts Total Transfer Capability	0 MW			
Work scheduled by: NGrid							TTC with All Lines In Service	5250 MW			
<hr/>											
HOPATCON-RAMAPO__500_5018										FWD (Import)	REV (Export)
Tue 01/28/2025	to	Sat 02/01/2025					SCH - PJ - NY	1400 MW	1200 MW		
0001	Continuous	0200					Impacts Total Transfer Capability	1200 MW	1500 MW		
Work scheduled by: PJM							TTC with All Lines In Service	2600 MW	2700 MW		
<hr/>											
HOPATCON-RAMAPO__500_5018										FWD (Import)	REV (Export)
Tue 01/28/2025	to	Sat 02/01/2025					UPNY CONED	7795 MW			
0001	Continuous	0200					Impacts Total Transfer Capability	255 MW			
Work scheduled by: PJM							TTC with All Lines In Service	8050 MW			
<hr/>											
HOPATCON-RAMAPO__500_5018										FWD (Import)	REV (Export)
Tue 01/28/2025	to	Sat 02/01/2025					TOTAL EAST	6800 MW			
0001	Continuous	0200					Impacts Total Transfer Capability	-650 MW			
Work scheduled by: PJM							TTC with All Lines In Service	6150 MW			
<hr/>											
RAMAPO__345_345_PAR3500										FWD (Import)	REV (Export)
Tue 01/28/2025	to	Sat 02/01/2025					SCH - PJ - NY	2550 MW	1250 MW		
0001	Continuous	0200					Impacts Total Transfer Capability	50 MW	1450 MW		
Work scheduled by: PJM							TTC with All Lines In Service	2600 MW	2700 MW		

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Friday, December 27, 2024 to Friday, June 26, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

RAMAPO__345_345_PAR4500

Tue 01/28/2025 to Sat 02/01/2025
0001 Continuous 0200
Work scheduled by: PJM

SCH - PJ - NY	FWD (Import)	REV (Export)
	2550 MW	1250 MW
Impacts Total Transfer Capability	50 MW	1450 MW
TTC with All Lines In Service	2600 MW	2700 MW

RAMAPO__500_345_BK 1500

Tue 01/28/2025 to Sat 02/01/2025
0001 Continuous 0200
Work scheduled by: PJM

SCH - PJ - NY	FWD (Import)	REV (Export)
	1400 MW	1200 MW
Impacts Total Transfer Capability	1200 MW	1500 MW
TTC with All Lines In Service	2600 MW	2700 MW

RAMAPO__500_345_BK 1500

Tue 01/28/2025 to Sat 02/01/2025
0001 Continuous 0200
Work scheduled by: PJM

UPNY CONED	FWD (Import)	REV (Export)
	7795 MW	
Impacts Total Transfer Capability	255 MW	
TTC with All Lines In Service	8050 MW	

BECK__-NIAGARA_345_PA301

Tue 02/04/2025 to Tue 02/04/2025
0500 Continuous 2100
Work scheduled by: NYPA

SCH - OH - NY	FWD (Import)	REV (Export)
	1150 MW	1000 MW
Impacts Total Transfer Capability	1350 MW	850 MW
TTC with All Lines In Service	2500 MW	1850 MW

PIERCBRK-FIVEMILE_345_37

Tue 02/04/2025 to Tue 02/04/2025
0900 Daily 1030
Work scheduled by: NGrid

SCH - PJ - NY	FWD (Import)	REV (Export)
Impacts Total Transfer Capability		
TTC with All Lines In Service		

ROSETON_-EFISHKIL_345_RFK305

Sun 02/09/2025 to Wed 02/12/2025
0001 Continuous 0200
Work scheduled by: ConEd

UPNY CONED	FWD (Import)	REV (Export)
	7215 MW	
Impacts Total Transfer Capability	835 MW	
TTC with All Lines In Service	8050 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits		Friday, December 27, 2024 to Friday, June 26, 2026				
CENTRAL EAST	7550 MW	The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.				
CENTRAL EAST - VC	3725 MW					
TOTAL EAST	6150 MW					
UPNY CONED	8050 MW					
SPR/DUN-SOUTH	4600 MW					
DYSINGER EAST	3200 MW					
MOSES SOUTH	3150 MW					
					FWD (Import)	REV (Export)
MILLWOOD-EASTVIEW_345_W82		Mon 02/10/2025	to	Fri 02/14/2025	UPNY CONED	7810 MW
	0001	Continuous		2200	Impacts Total Transfer Capability	240 MW
Work scheduled by: ConEd					TTC with All Lines In Service	8050 MW
					FWD (Import)	REV (Export)
FRASER_345_FRASER SVC		Mon 02/10/2025	to	Fri 02/14/2025	CENTRAL EAST - VC	3655 MW
	0700	Continuous		1500	Impacts Total Transfer Capability	70 MW
Work scheduled by: NYSEG					TTC with All Lines In Service	3725 MW
					FWD (Import)	REV (Export)
WOOD_ST_PLSNTVLE_345_Y86		Mon 02/17/2025	to	Mon 02/17/2025	UPNY CONED	7475 MW
	0001	Continuous		0030	Impacts Total Transfer Capability	575 MW
Work scheduled by: ConEd					TTC with All Lines In Service	8050 MW
					FWD (Import)	REV (Export)
BECK__PACKARD_230_BP76		Thu 02/20/2025	to	Thu 02/20/2025	SCH - OH - NY	1800 MW 1300 MW
	0730	Continuous		1630	Impacts Total Transfer Capability	700 MW 550 MW
Work scheduled by: NGrid					TTC with All Lines In Service	2500 MW 1850 MW
					FWD (Import)	REV (Export)
WOOD_ST_PLSNTVLE_345_Y86		Fri 02/21/2025	to	Fri 02/21/2025	UPNY CONED	7475 MW
	0130	Continuous		0200	Impacts Total Transfer Capability	575 MW
Work scheduled by: ConEd					TTC with All Lines In Service	8050 MW
					FWD (Import)	REV (Export)
BERKSHIR-ALPS_345_393		Mon 02/24/2025	to	Mon 02/24/2025	SCH - NPX_1385	100 MW 100 MW
	0730	Continuous		1530	Impacts Total Transfer Capability	100 MW 100 MW
Work scheduled by: NGrid					TTC with All Lines In Service	200 MW 200 MW
					ARR: 78	

NYISO TRANSFER LIMITATIONS

Seasonal Limits		Friday, December 27, 2024 to Friday, June 26, 2026					
CENTRAL EAST	7550 MW	The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.					
CENTRAL EAST - VC	3725 MW						
TOTAL EAST	6150 MW						
UPNY CONED	8050 MW						
SPR/DUN-SOUTH	4600 MW						
DYSINGER EAST	3200 MW						
MOSES SOUTH	3150 MW						
BERKSHIR-ALPS___345_393						FWD (Import)	REV (Export)
Mon 02/24/2025	to	Mon 02/24/2025			SCH - NE - NY	1100 MW	1600 MW
0730	Continuous	1530		ARR: 78	Impacts Total Transfer Capability	300 MW	200 MW
Work scheduled by: NGrid					TTC with All Lines In Service	1400 MW	1800 MW
SPRNBK_-TREMONT_345_X28						FWD (Import)	REV (Export)
Fri 02/28/2025	to	Tue 03/04/2025	<u>UPDATED by ConEd 12/24/2024 09:22</u>		SPR/DUN-SOUTH	4200 MW	
0001	Continuous	0200			Impacts Total Transfer Capability	400 MW	
Work scheduled by: ConEd					TTC with All Lines In Service	4600 MW	
RAMAPO_-BUCHAN_N_345_Y94						FWD (Import)	REV (Export)
Mon 03/03/2025	to	Sat 03/08/2025			UPNY CONED	7755 MW	
0001	Continuous	0200			Impacts Total Transfer Capability	295 MW	
Work scheduled by: ConEd					TTC with All Lines In Service	8050 MW	
MOTTHAVN-RAINEY___345_Q11						FWD (Import)	REV (Export)
Tue 03/04/2025	to	Mon 04/14/2025			SPR/DUN-SOUTH	3800 MW	
0201	Continuous	0300			Impacts Total Transfer Capability	800 MW	
Work scheduled by: ConEd					TTC with All Lines In Service	4600 MW	
MOSES___ADIRNDCK_230_MA1						FWD (Import)	REV (Export)
Fri 03/14/2025	to	Sat 03/29/2025			MOSES SOUTH	2300 MW	
0700	Continuous	1730			Impacts Total Transfer Capability	850 MW	
Work scheduled by: NYPA					TTC with All Lines In Service	3150 MW	
NINEMILE-CLAY___345_8						FWD (Import)	REV (Export)
Mon 03/17/2025	to	Mon 03/17/2025			OSWEGO EXPORT	5150 MW	
0001	Continuous	0100			Impacts Total Transfer Capability	100 MW	
Work scheduled by: NGrid					TTC with All Lines In Service	5250 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits		Friday, December 27, 2024 to Friday, June 26, 2026				
CENTRAL EAST	7550 MW	The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.				
CENTRAL EAST - VC	3725 MW					
TOTAL EAST	6150 MW					
UPNY CONED	8050 MW					
SPR/DUN-SOUTH	4600 MW					
DYSINGER EAST	3200 MW					
MOSES SOUTH	3150 MW					
STLAWRNC-MOSES__230_L33P					FWD (Import)	REV (Export)
Mon 03/17/2025	to	Fri 03/21/2025	SCH - OH - NY			
0600	Continuous	1730	Impacts Total Transfer Capability			
Work scheduled by: NYPA				TTC with All Lines In Service		
SCRIBA_-VOLNEY__345_20					FWD (Import)	REV (Export)
Mon 03/17/2025	to	Mon 03/17/2025	OSWEGO EXPORT		5250 MW	
0700	Daily	1900	Impacts Total Transfer Capability		0 MW	
Work scheduled by: NGrid				TTC with All Lines In Service	5250 MW	
NINEMILE-CLAY__345_8					FWD (Import)	REV (Export)
Mon 03/17/2025	to	Tue 03/18/2025	OSWEGO EXPORT		5150 MW	
2130	Continuous	2300	Impacts Total Transfer Capability		100 MW	
Work scheduled by: NGrid				TTC with All Lines In Service	5250 MW	
ROCHESTR-PANNELL__345_RP1					FWD (Import)	REV (Export)
Mon 03/24/2025	to	Tue 03/25/2025	DYSINGER EAST		2300 MW	
0730	Continuous	1500	Impacts Total Transfer Capability		900 MW	
Work scheduled by: NYSEG		UPDATED by RGE 11/08/2024 10:56		TTC with All Lines In Service	3200 MW	
NINEMILE-CLAY__345_8					FWD (Import)	REV (Export)
Tue 03/25/2025	to	Tue 03/25/2025	OSWEGO EXPORT		5150 MW	
0200	Continuous	0300	Impacts Total Transfer Capability		100 MW	
Work scheduled by: NGrid				TTC with All Lines In Service	5250 MW	
ROCHESTR-PANNELL__345_RP2					FWD (Import)	REV (Export)
Wed 03/26/2025	to	Thu 03/27/2025	DYSINGER EAST		2300 MW	
0730	Continuous	1500	Impacts Total Transfer Capability		900 MW	
Work scheduled by: RGE		UPDATED by RGE 11/08/2024 10:51		TTC with All Lines In Service	3200 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Friday, December 27, 2024 to Friday, June 26, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_-ROBNSNRD_230_64

Fri 03/28/2025 to Fri 03/28/2025
0500 Continuous 1900
Work scheduled by: NYPA

SCH - OH - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

NINEMILE-CLAY___345_8

Wed 04/02/2025 to Wed 04/02/2025
1900 Continuous 2000
Work scheduled by: NGrid

OSWEGO EXPORT
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

NIAGARA_-DYSINGER_345_ND2

Mon 04/07/2025 to Fri 04/11/2025
0500 Continuous 1730
Work scheduled by: NYPA

DYSINGER EAST
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

LINDN_CG-LNDVFT__345_V-3022

Mon 04/07/2025 to Sat 04/12/2025
0800 Continuous 1500
Work scheduled by: PJM

SCH - PJM_VFT
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

RAMAPO_-BUCHAN_N_345_Y94

Sat 04/12/2025 to Sat 04/19/2025
0001 Continuous 0200
Work scheduled by: ConEd

UPNY CONED
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

SPRNBK_-TREMONT__345_X28

Mon 04/14/2025 to Sun 04/20/2025
0001 Continuous 0200
Work scheduled by: ConEd

UPDATED by ConEd 12/24/2024 09:22

SPR/DUN-SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Friday, December 27, 2024 to Friday, June 26, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_-DYSINGER_345_ND2

Mon 04/14/2025 to Thu 04/17/2025
0500 Continuous 1730
Work scheduled by: NYPA

DYSINGER EAST
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
2700 MW	
500 MW	
3200 MW	

E13THSTA-FARRAGUT_345_45

Tue 04/15/2025 to Sun 04/20/2025
0001 Continuous 0200
Work scheduled by: ConEd

SPR/DUN-SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
3800 MW	
800 MW	
4600 MW	

W49TH_ST-E13THSTA_345_M54

Tue 04/15/2025 to Sun 04/20/2025
0001 Continuous 0200
Work scheduled by: ConEd

SPR/DUN-SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
3800 MW	
800 MW	
4600 MW	

MOSES__-ADIRNDCK_230_MA1

Tue 04/15/2025 to Tue 04/15/2025
0700 Continuous 1530
Work scheduled by: NYPA

MOSES SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
2300 MW	
850 MW	
3150 MW	

LINDN_CG-LNDVFT__345_V-3022

Thu 04/17/2025 to Thu 04/17/2025
1500 Continuous 1800
Work scheduled by: PJM

SCH - PJM_VFT
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
0 MW	0 MW
315 MW	315 MW
315 MW	315 MW

NIAGARA_-PACKARD_230_61

Mon 04/21/2025 to Fri 04/25/2025
0500 Continuous 1900
Work scheduled by: NYPA

SCH - OH - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
2450 MW	1800 MW
50 MW	50 MW
2500 MW	1850 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Friday, December 27, 2024 to Friday, June 26, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PANNELL__CLAY__345_1

Mon 04/21/2025 to Fri 04/25/2025
0700 Continuous 1530
Work scheduled by: NYPA

WEST CENTRAL
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

FWD (Import) REV (Export)

1300 MW

MOSES__ADIRNDCK_230_MA2

Tue 04/22/2025 to Tue 04/22/2025
0700 Continuous 1530
Work scheduled by: NYPA

MOSES SOUTH
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

FWD (Import) REV (Export)

2300 MW

MARCY__765_345_AT1

Fri 04/25/2025 to Fri 04/25/2025
0500 Continuous 1730
Work scheduled by: NYPA ARR: 19

MOSES SOUTH
Impacts Total Transfer Capability 1400 MW
TTC with All Lines In Service 3150 MW

FWD (Import) REV (Export)

1750 MW

MARCY__765_345_AT2

Sat 04/26/2025 to Sat 04/26/2025
0500 Continuous 1730
Work scheduled by: NYPA ARR: 19

MOSES SOUTH
Impacts Total Transfer Capability 1450 MW
TTC with All Lines In Service 3150 MW

FWD (Import) REV (Export)

1700 MW

BUCHAN_S-MILLWOOD_345_W97

Mon 04/28/2025 to Tue 04/29/2025
0001 Continuous 0230
Work scheduled by: ConEd

UPNY CONED
Impacts Total Transfer Capability 35 MW
TTC with All Lines In Service 8050 MW

FWD (Import) REV (Export)

8015 MW

PANNELL__CLAY__345_2

Mon 04/28/2025 to Fri 05/02/2025
0700 Continuous 1530
Work scheduled by: NYPA

WEST CENTRAL
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

FWD (Import) REV (Export)

1300 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Friday, December 27, 2024 to Friday, June 26, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

E13THSTA-FARRAGUT_345_46

Tue 05/06/2025 to Sat 05/10/2025
0001 Continuous 0200
Work scheduled by: ConEd

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	3800 MW	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

LONG_MTN-CRICKVLY_345_398

Tue 05/06/2025 to Thu 05/29/2025
0001 Continuous 2200
Work scheduled by: ConEd

SCH - NPX_1385	FWD (Import)	REV (Export)
	100 MW	100 MW
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

LONG_MTN-CRICKVLY_345_398

Tue 05/06/2025 to Thu 05/29/2025
0001 Continuous 2200
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	800 MW	1200 MW
Impacts Total Transfer Capability	600 MW	400 MW
TTC with All Lines In Service	1400 MW	1600 MW

W49TH_ST_345KV_6

Tue 05/06/2025 to Tue 05/06/2025
0001 Continuous 0030
Work scheduled by: ConEd

SCH - PJM_HTP	FWD (Import)	REV (Export)
	300 MW	
Impacts Total Transfer Capability	360 MW	
TTC with All Lines In Service	660 MW	

W49TH_ST-E13THSTA_345_M55

Tue 05/06/2025 to Sat 05/10/2025
0001 Continuous 0200
Work scheduled by: ConEd

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	3800 MW	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

WOOD_ST-PLSNTVLE_345_Y87

Wed 05/07/2025 to Fri 05/09/2025
2200 Continuous 0259
Work scheduled by: ConEd

UPNY CONED	FWD (Import)	REV (Export)
	7470 MW	
Impacts Total Transfer Capability	580 MW	
TTC with All Lines In Service	8050 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits		Friday, December 27, 2024 to Friday, June 26, 2026			
CENTRAL EAST	7550 MW	The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.			
CENTRAL EAST - VC	3725 MW				
TOTAL EAST	6150 MW				
UPNY CONED	8050 MW				
SPR/DUN-SOUTH	4600 MW				
DYSINGER EAST	3200 MW				
MOSES SOUTH	3150 MW				
<hr/>					
DUNWODIE_345KV_6				FWD (Import)	REV (Export)
Fri 05/09/2025	to	Fri 05/09/2025	SPR/DUN-SOUTH	3800 MW	
0001	Continuous	0030	Impacts Total Transfer Capability	800 MW	
Work scheduled by: ConEd			TTC with All Lines In Service	4600 MW	
<hr/>					
DUNWODIE_345KV_8				FWD (Import)	REV (Export)
Fri 05/09/2025	to	Fri 05/09/2025	SPR/DUN-SOUTH	3800 MW	
0001	Continuous	0030	Impacts Total Transfer Capability	800 MW	
Work scheduled by: ConEd			TTC with All Lines In Service	4600 MW	
<hr/>					
W49TH_ST_345KV_6				FWD (Import)	REV (Export)
Sat 05/10/2025	to	Sat 05/10/2025	SCH - PJM_HTP	300 MW	
0130	Continuous	0200	Impacts Total Transfer Capability	360 MW	
Work scheduled by: ConEd			TTC with All Lines In Service	660 MW	
<hr/>					
DUNWODIE_345KV_6				FWD (Import)	REV (Export)
Sun 05/11/2025	to	Sun 05/11/2025	SPR/DUN-SOUTH	3800 MW	
1830	Continuous	1900	Impacts Total Transfer Capability	800 MW	
Work scheduled by: ConEd			TTC with All Lines In Service	4600 MW	
<hr/>					
DUNWODIE_345KV_8				FWD (Import)	REV (Export)
Sun 05/11/2025	to	Sun 05/11/2025	SPR/DUN-SOUTH	3800 MW	
1830	Continuous	1900	Impacts Total Transfer Capability	800 MW	
Work scheduled by: ConEd			TTC with All Lines In Service	4600 MW	
<hr/>					
NEPTUNE_DUFFYAVE_345_NEPTUNE				FWD (Import)	REV (Export)
Mon 05/12/2025	to	Fri 05/16/2025	SCH - PJM_NEPTUNE	0 MW	
0600	Continuous	1600	Impacts Total Transfer Capability	660 MW	
Work scheduled by: LI			TTC with All Lines In Service	660 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Friday, December 27, 2024 to Friday, June 26, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEWBRDGE_345_138_BK_1

Mon 05/12/2025 to Fri 05/16/2025
0600 Continuous 1600
Work scheduled by: LI

SCH - PJM_NEPTUNE **375 MW**
Impacts Total Transfer Capability 285 MW
TTC with All Lines In Service 660 MW

NEWBRDGE_345_138_BK_2

Mon 05/12/2025 to Fri 05/16/2025
0600 Continuous 1600
Work scheduled by: LI

SCH - PJM_NEPTUNE **375 MW**
Impacts Total Transfer Capability 285 MW
TTC with All Lines In Service 660 MW

NEWBRDGE-DUFFYAVE_345_501

Mon 05/12/2025 to Fri 05/16/2025
0600 Continuous 1600
Work scheduled by: LI

SCH - PJM_NEPTUNE **0 MW**
Impacts Total Transfer Capability 660 MW
TTC with All Lines In Service 660 MW

SAND_BAR-PLATSBRG_115_PV20

Mon 07/07/2025 to Fri 07/11/2025
0700 Continuous 1530
Work scheduled by: NYPA

SCH - NE - NY **0 MW**
Impacts Total Transfer Capability 100 MW
TTC with All Lines In Service 3725 MW

SAND_BAR-PLATSBRG_115_PV20

Mon 07/07/2025 to Fri 07/11/2025
0700 Continuous 1530
Work scheduled by: NYPA

CENTRAL EAST - VC **3625 MW**
Impacts Total Transfer Capability 100 MW
TTC with All Lines In Service 3725 MW

NIAGARA_345_230_AT4

Tue 07/08/2025 to Tue 07/08/2025
0500 Continuous 1900
Work scheduled by: NYPA

SCH - OH - NY **1200 MW**
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 1600 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Friday, December 27, 2024 to Friday, June 26, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DYSINGER-STA_255_345_DH1

Tue 09/02/2025 to Mon 09/15/2025
0500 Continuous 2100
Work scheduled by: NYPA

DYSINGER EAST
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
2850 MW	
350 MW	
3200 MW	

GOETHALS_345KV_5

Mon 09/08/2025 to Mon 09/08/2025
0301 Continuous 0330
Work scheduled by: ConEd

STATEN ISLAND
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)

CLAY__-EDIC__345_2-15

Mon 09/08/2025 to Fri 09/12/2025
0700 Continuous 1530
Work scheduled by: NYPA

OSWEGO EXPORT
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
4850 MW	
400 MW	
5250 MW	

MOSES__-ADIRNDCK_230_MA1

Tue 09/09/2025 to Sun 10/12/2025
0700 Continuous 1730
Work scheduled by: NYPA

MOSES SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
2100 MW	
1050 MW	
3150 MW	

GOETHALS_345KV_5

Tue 09/09/2025 to Tue 09/09/2025
2330 Continuous 2359
Work scheduled by: ConEd

STATEN ISLAND
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)

DUNWODIE_345KV_4

Sat 09/13/2025 to Sun 09/14/2025
0001 Continuous 2200
Work scheduled by: ConEd

UPDATED by ConEd 11/08/2024 12:36

SPR/DUN-SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
3800 MW	
800 MW	
4600 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Friday, December 27, 2024 to Friday, June 26, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_6

Sat 09/13/2025 to Sun 09/14/2025
0001 Continuous 2200
Work scheduled by: ConEd

UPDATED by ConEd 11/08/2024 12:36

SPR/DUN-SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
3800 MW
800 MW
4600 MW

DUNWODIE-SHORE_RD_345_Y50

Sat 09/13/2025 to Sun 09/14/2025
0001 Continuous 2200
Work scheduled by: ConEd

UPDATED by ConEd 11/08/2024 12:36

CONED - LIPA
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
800 MW
700 MW
1500 MW

SHORE_RD_345_138_BK 1

Sat 09/13/2025 to Sun 09/14/2025
0001 Continuous 2200
Work scheduled by: ConEd

UPDATED by ConEd 11/08/2024 12:36

CONED - LIPA
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
1350 MW
150 MW
1500 MW

SHORE_RD_345_138_BK 2

Sat 09/13/2025 to Sun 09/14/2025
0001 Continuous 2200
Work scheduled by: ConEd

UPDATED by ConEd 11/08/2024 12:36

CONED - LIPA
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
1350 MW
150 MW
1500 MW

SPRNBRK_345KV_RNS4

Mon 09/15/2025 to Thu 10/02/2025
0001 Continuous 0200
Work scheduled by: ConEd

SPR/DUN-SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
3200 MW
1400 MW
4600 MW

SPRNBRK_-W49TH_ST_345_M52

Mon 09/15/2025 to Thu 10/02/2025
0001 Continuous 0200
Work scheduled by: ConEd

SPR/DUN-SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
3200 MW
1400 MW
4600 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Friday, December 27, 2024 to Friday, June 26, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_5

Mon 09/15/2025 to Mon 09/15/2025
0001 Continuous 0030
Work scheduled by: ConEd

SCH - PJM_HTP

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

460 MW

200 MW

660 MW

GOETHALS_345KV_5

Mon 09/15/2025 to Mon 09/15/2025
0230 Continuous 0300
Work scheduled by: ConEd

STATEN ISLAND

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

ADIRNDCK-PORTER_230_12

Mon 09/15/2025 to Sun 10/12/2025
0600 Continuous 1700
Work scheduled by: NGrid

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

2100 MW

1050 MW

3150 MW

DYSINGER-STA_255_345_DH2

Tue 09/16/2025 to Tue 10/28/2025
0500 Continuous 1900
Work scheduled by: NYPA

DYSINGER EAST

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

2850 MW

350 MW

3200 MW

MARCY__FRASANNX_345_UCC2-41

Mon 09/22/2025 to Mon 10/06/2025
0700 Continuous 1730
Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

3225 MW

500 MW

3725 MW

PANNELL_-CLAY__345_1

Mon 09/29/2025 to Fri 10/03/2025
0700 Continuous 1530
Work scheduled by: NYPA

WEST CENTRAL

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

1300 MW

950 MW

2250 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Friday, December 27, 2024 to Friday, June 26, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST_345KV_5

Thu 10/02/2025 to Thu 10/02/2025
0130 Continuous 0200
Work scheduled by: ConEd

SCH - PJM_HTP
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
460 MW
200 MW
660 MW

PANNELL-CLAY_345_2

Mon 10/06/2025 to Fri 10/10/2025
0700 Continuous 1530
Work scheduled by: NYPA

WEST CENTRAL
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
1300 MW
950 MW
2250 MW

NEPTUNE-DUFFYAVE_345_NEPTUNE

Mon 10/13/2025 to Thu 10/16/2025
0600 Continuous 1600
Work scheduled by: LI

SCH - PJM_NEPTUNE
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
0 MW
660 MW
660 MW

NEWBRDGE_345_138_BK_1

Mon 10/13/2025 to Thu 10/16/2025
0600 Continuous 1600
Work scheduled by: LI

SCH - PJM_NEPTUNE
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
375 MW
285 MW
660 MW

NEWBRDGE_345_138_BK_2

Mon 10/13/2025 to Thu 10/16/2025
0600 Continuous 1600
Work scheduled by: LI

SCH - PJM_NEPTUNE
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
375 MW
285 MW
660 MW

NEWBRDGE-DUFFYAVE_345_501

Mon 10/13/2025 to Thu 10/16/2025
0600 Continuous 1600
Work scheduled by: LI

SCH - PJM_NEPTUNE
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
0 MW
660 MW
660 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Friday, December 27, 2024 to Friday, June 26, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES__-ADIRNDCK_230_MA2

Mon 10/13/2025 to Mon 11/24/2025
0700 Continuous 1730
Work scheduled by: NYPA

MOSES SOUTH	FWD (Import)	REV (Export)
	2100 MW	
Impacts Total Transfer Capability	1050 MW	
TTC with All Lines In Service	3150 MW	

EDIC__-PRINCTWN_345_351

Tue 10/14/2025 to Fri 10/17/2025
0600 Continuous 1830
Work scheduled by: NGrid

CENTRAL EAST - VC	FWD (Import)	REV (Export)
	3335 MW	
Impacts Total Transfer Capability	390 MW	
TTC with All Lines In Service	3725 MW	

SPRNBK_-TREMONT_345_X28

Mon 10/27/2025 to Fri 10/31/2025
0001 Continuous 1800
Work scheduled by: ConEd

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	4200 MW	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	4600 MW	

CHATGUAY-MASSENA_765_7040

Sun 11/16/2025 to Sun 11/30/2025
0001 Continuous 2359
Work scheduled by: NYPA

SCH - HQ - NY	FWD (Import)	REV (Export)
	0 MW	0 MW
Impacts Total Transfer Capability	1500 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

CHATGUAY-MASSENA_765_7040

Sun 11/16/2025 to Sun 11/30/2025
0001 Continuous 2359
Work scheduled by: NYPA

MOSES SOUTH	FWD (Import)	REV (Export)
	1550 MW	
Impacts Total Transfer Capability	1600 MW	
TTC with All Lines In Service	3150 MW	

MOSES__-ADIRNDCK_230_MA2 , MOSES__-MASSENA_230_MMS2 , MOSES__-MASSENA_230_MMS1

Sun 11/16/2025 to Mon 11/24/2025
0001 1730
Work scheduled by:

SCH - HQ_CEDARS	FWD (Import)	REV (Export)
	90 MW	
Impacts Total Transfer Capability	189 MW	
TTC with All Lines In Service	279 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Friday, December 27, 2024 to Friday, June 26, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES__-MASSENA_230_MMS2 , MOSES__-MASSENA_230_MMS1

Sun 11/16/2025 to Sun 11/30/2025
0001 2359
Work scheduled by:

SCH - HQ_CEDARS	FWD (Import)	REV (Export)
	90 MW	
Impacts Total Transfer Capability	189 MW	
TTC with All Lines In Service	279 MW	

MOSES__-MASSENA_230_MMS2 , MOSES__-MASSENA_230_MMS1

Sun 11/16/2025 to Sun 11/30/2025
0001 2359
Work scheduled by:

SCH - HQ - NY	FWD (Import)	REV (Export)
	850 MW	0 MW
Impacts Total Transfer Capability	650 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

MOTTHAVN-RAINEY__345_Q11

Mon 12/01/2025 to Tue 12/02/2025
0001 Continuous 0230
Work scheduled by: ConEd

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	3800 MW	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

GOETHALS_345KV_5

Sat 01/17/2026 to Sat 01/17/2026
0301 Continuous 0330
Work scheduled by: ConEd

UPDATED by ConEd 07/10/2024 16:09

STATEN ISLAND	FWD (Import)	REV (Export)
Impacts Total Transfer Capability		
TTC with All Lines In Service		

DYSINGER-STA_255_345_DH2

Mon 03/02/2026 to Fri 03/13/2026
0500 Continuous 1900
Work scheduled by: NYPA

DYSINGER EAST	FWD (Import)	REV (Export)
	2850 MW	
Impacts Total Transfer Capability	350 MW	
TTC with All Lines In Service	3200 MW	

DYSINGER-STA_255_345_DH1

Mon 03/16/2026 to Tue 04/07/2026
0500 Continuous 2100
Work scheduled by: NYPA

DYSINGER EAST	FWD (Import)	REV (Export)
	2850 MW	
Impacts Total Transfer Capability	350 MW	
TTC with All Lines In Service	3200 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Friday, December 27, 2024 to Friday, June 26, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DYSINGER-STA_255_345_DH2

Wed 04/08/2026 to Mon 04/20/2026
0500 Continuous 2100
Work scheduled by: NYPA

DYSINGER EAST **2850 MW**
Impacts Total Transfer Capability 350 MW
TTC with All Lines In Service 3200 MW

DYSINGER-STA_255_345_DH1

Tue 04/21/2026 to Fri 05/01/2026
0500 Continuous 2100
Work scheduled by: NYPA

DYSINGER EAST **2850 MW**
Impacts Total Transfer Capability 350 MW
TTC with All Lines In Service 3200 MW

GOETHALS_345KV_5

Sat 04/25/2026 to Sat 04/25/2026
2330 Continuous 2359
Work scheduled by: ConEd

UPDATED by ConEd 07/10/2024 16:09

STATEN ISLAND
Impacts Total Transfer Capability
TTC with All Lines In Service

GOETHALS_345KV_5

Mon 04/27/2026 to Mon 04/27/2026
0001 Continuous 0030
Work scheduled by: ConEd

UPDATED by ConEd 07/10/2024 16:09

STATEN ISLAND
Impacts Total Transfer Capability
TTC with All Lines In Service

GOETHALS_345KV_5

Tue 05/05/2026 to Tue 05/05/2026
0230 Continuous 0300
Work scheduled by: ConEd

UPDATED by ConEd 07/10/2024 16:09

STATEN ISLAND
Impacts Total Transfer Capability
TTC with All Lines In Service

NEPTUNE_DUFFYAVE_345_NEPTUNE

Mon 05/11/2026 to Fri 05/15/2026
0600 Continuous 1600
Work scheduled by: LI

SCH - PJM_NEPTUNE **0 MW**
Impacts Total Transfer Capability 660 MW
TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits		Friday, December 27, 2024 to Friday, June 26, 2026			
CENTRAL EAST	7550 MW	The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.			
CENTRAL EAST - VC	3725 MW				
TOTAL EAST	6150 MW				
UPNY CONED	8050 MW				
SPR/DUN-SOUTH	4600 MW				
DYSINGER EAST	3200 MW				
MOSES SOUTH	3150 MW				
<hr/>					
NEWBRDGE_345_138_BK_1				FWD (Import)	REV (Export)
Mon 05/11/2026	to	Fri 05/15/2026	SCH - PJM_NEPTUNE	375 MW	
0600	Continuous	1600	Impacts Total Transfer Capability	285 MW	
Work scheduled by: LI			TTC with All Lines In Service	660 MW	
<hr/>					
NEWBRDGE_345_138_BK_2				FWD (Import)	REV (Export)
Mon 05/11/2026	to	Fri 05/15/2026	SCH - PJM_NEPTUNE	375 MW	
0600	Continuous	1600	Impacts Total Transfer Capability	285 MW	
Work scheduled by: LI			TTC with All Lines In Service	660 MW	
<hr/>					
NEWBRDGE-DUFFYAVE_345_501				FWD (Import)	REV (Export)
Mon 05/11/2026	to	Fri 05/15/2026	SCH - PJM_NEPTUNE	0 MW	
0600	Continuous	1600	Impacts Total Transfer Capability	660 MW	
Work scheduled by: LI			TTC with All Lines In Service	660 MW	