

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, December 30, 2024 to Tuesday, June 30, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### HUDSONP\_-FARRAGUT\_345\_B3402

Mon 01/15/2018 to Thu 05/01/2025  
0001 Continuous 0100  
Work scheduled by: ConEd

EXT FORCED by ConEd 03/11/2024 11:26

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### MARION\_-FARRAGUT\_345\_C3403

Mon 01/15/2018 to Thu 05/01/2025  
0001 Continuous 0100  
Work scheduled by: ConEd

EXT FORCED by ConEd 03/11/2024 11:26

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### MARION\_-FARRAGUT\_345\_C3403 , HUDSONP\_-FARRAGUT\_345\_B3402

Mon 01/15/2018 to Thu 05/01/2025  
0001 0100  
Work scheduled by:

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>2400 MW</b>	<b>2400 MW</b>
200 MW	300 MW
2600 MW	2700 MW

### MARCY\_\_345KV\_CSC

Sat 06/15/2024 to Sat 05/24/2025  
0001 Continuous 2359  
Work scheduled by: NYPA

FORCED by NYPA 06/11/2024 15:44

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>3650 MW</b>	
75 MW	
3725 MW	

### W49TH\_ST\_345KV\_6

Fri 09/27/2024 to Thu 01/02/2025  
0101 Continuous 2359  
Work scheduled by: ConEd

UPDATED by ConEd 09/25/2024 08:24

SCH - PJM\_HTP  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>300 MW</b>	
360 MW	
660 MW	

### W49TH\_ST-E13THSTA\_345\_M55

Fri 09/27/2024 to Thu 01/02/2025  
0101 Continuous 2359  
Work scheduled by: ConEd

UPDATED by ConEd 09/25/2024 08:24

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>3800 MW</b>	
800 MW	
4600 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, December 30, 2024 to Tuesday, June 30, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MARCY\_\_\_765\_345\_AT1

Mon 10/14/2024 to Fri 01/24/2025  
2110 Continuous 2359  
Work scheduled by: NYPA

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) REV (Export)  
**1750 MW**  
1400 MW  
3150 MW

### SCH-IMO-NYISO\_LIMIT\_1900

Fri 11/01/2024 to Wed 04/30/2025  
0001 Continuous 2359  
Work scheduled by: IESO

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) REV (Export)  
**2200 MW**  
300 MW  
2500 MW

### S.RIPLEY-DUNKIRK\_230\_68

Fri 11/08/2024 to Fri 01/31/2025  
1113 Continuous 1800  
Work scheduled by: PJM  
EXT FORCED by NGrid 11/13/2024 16:46

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) REV (Export)

### SCH-HQ-NYISO\_LIMIT\_1100

Wed 12/04/2024 to Wed 03/19/2025  
1801 Continuous 1600  
Work scheduled by: HQ

SCH - HQ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) REV (Export)  
**1100 MW**  
400 MW  
1500 MW

### SCH-PJM-NYISO\_LIMIT\_1700

Sat 12/28/2024 to Wed 01/08/2025  
0001 Continuous 2359  
Work scheduled by: NYISO

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) REV (Export)  
**2000 MW**  
600 MW  
2600 MW

### EGRDNCTY\_345\_138\_AT2

Mon 12/30/2024 to Mon 12/30/2024  
0700 Continuous 1200  
Work scheduled by: NYPA

CONED - LIPA  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) REV (Export)  
**1250 MW**  
250 MW  
1500 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, December 30, 2024 to Tuesday, June 30, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### ROSETON\_EFISHKIL\_345\_RFK305

Mon 12/30/2024 to Tue 12/31/2024  
0700 Continuous 1600  
Work scheduled by: CHGE

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) REV (Export)  
**7215 MW**  
835 MW  
8050 MW

### EGRDNCTY\_345\_138\_AT1

Mon 12/30/2024 to Mon 12/30/2024  
1201 Continuous 1700  
Work scheduled by: NYPA

CONED - LIPA  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) REV (Export)  
**1250 MW**  
250 MW  
1500 MW

### MILLWOOD-EASTVIEW\_345\_W85

Thu 01/02/2025 to Thu 01/02/2025  
0001 Continuous 0030  
Work scheduled by: ConEd

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) REV (Export)  
**7810 MW**  
240 MW  
8050 MW

### SPRNBKR\_345KV\_RNS3

Thu 01/02/2025 to Thu 01/02/2025  
0001 Continuous 1830  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) REV (Export)  
**3800 MW**  
800 MW  
4600 MW

### KNICRBKR-PLSNTVLY\_345\_Y57

Thu 01/02/2025 to Wed 01/15/2025  
0530 Continuous 1830  
Work scheduled by: NGrid

ARR: 78

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) REV (Export)  
**7885 MW**  
165 MW  
8050 MW

### MILLWOOD-EASTVIEW\_345\_W85

Thu 01/02/2025 to Thu 01/02/2025  
1800 Continuous 1830  
Work scheduled by: ConEd

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) REV (Export)  
**7810 MW**  
240 MW  
8050 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, December 30, 2024 to Tuesday, June 30, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### W49TH\_ST\_345KV\_6

Fri 01/03/2025 to Wed 01/29/2025  
0001 Continuous 0200  
Work scheduled by: ConEd

UPDATED by ConEd 12/18/2024 15:15

SCH - PJM\_HTP

Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**300 MW**  
360 MW  
660 MW

### W49TH\_ST\_345KV\_8

Fri 01/03/2025 to Wed 01/29/2025  
0001 Continuous 0200  
Work scheduled by: ConEd

UPDATED by ConEd 12/18/2024 15:15

SCH - PJM\_HTP

Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**310 MW**  
350 MW  
660 MW

### W49TH\_ST-E13THSTA\_345\_M55

Fri 01/03/2025 to Wed 01/29/2025  
0001 Continuous 0200  
Work scheduled by: ConEd

UPDATED by ConEd 12/18/2024 15:15

SPR/DUN-SOUTH

Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**3800 MW**  
800 MW  
4600 MW

### DUNWODIE\_345KV\_5

Sat 01/04/2025 to Sun 01/05/2025  
0001 Continuous 0259  
Work scheduled by: ConEd

SPR/DUN-SOUTH

Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**3800 MW**  
800 MW  
4600 MW

### DUNWODIE\_345KV\_7

Sat 01/04/2025 to Sun 01/05/2025  
0001 Continuous 0259  
Work scheduled by: ConEd

SPR/DUN-SOUTH

Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**3800 MW**  
800 MW  
4600 MW

### SPRNBK\_345KV\_RNS3

Sat 01/04/2025 to Sun 01/05/2025  
0001 Continuous 0259  
Work scheduled by: ConEd

SPR/DUN-SOUTH

Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**3800 MW**  
800 MW  
4600 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, December 30, 2024 to Tuesday, June 30, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SPRNBK\_DUNWODIE\_345\_W75

Sat 01/04/2025 to Sun 01/05/2025  
0001 Continuous 0259  
Work scheduled by: ConEd

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

### NRTH1385-NOR HBR\_138\_601

Mon 01/06/2025 to Fri 01/10/2025  
0500 Continuous 1500  
Work scheduled by: LI

SCH - NPX_1385	FWD (Import)	REV (Export)
	<b>100 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

### NRTH1385-NOR HBR\_138\_602

Mon 01/06/2025 to Fri 01/10/2025  
0500 Continuous 1500  
Work scheduled by: LI

SCH - NPX_1385	FWD (Import)	REV (Export)
	<b>100 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

### NRTH1385-NOR HBR\_138\_603

Mon 01/06/2025 to Fri 01/10/2025  
0500 Continuous 1500  
Work scheduled by: LI

SCH - NPX_1385	FWD (Import)	REV (Export)
	<b>100 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

### NRTH1385-NORHBR\_138\_601 , NRTH1385-NORHBR\_138\_602

Mon 01/06/2025 to Fri 01/10/2025  
0500 1500  
Work scheduled by:

SCH - NPX_1385	FWD (Import)	REV (Export)
	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

### NRTH1385-NORHBR\_138\_601 , NRTH1385-NORHBR\_138\_603

Mon 01/06/2025 to Fri 01/10/2025  
0500 1500  
Work scheduled by:

SCH - NPX_1385	FWD (Import)	REV (Export)
	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, December 30, 2024 to Tuesday, June 30, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### NRTH1385-NORHBR\_138\_603 , NRTH1385-NORHBR\_138\_602

Mon 01/06/2025 to Fri 01/10/2025  
0500 1500  
Work scheduled by:

SCH - NPX\_1385

FWD (Import) REV (Export)

Impacts Total Transfer Capability 200 MW 200 MW  
TTC with All Lines In Service 200 MW 200 MW

### NRTH1385-NRTHPORT\_138\_NNC

Mon 01/06/2025 to Fri 01/10/2025  
0500 Continuous 1500  
Work scheduled by: LI

SCH - NPX\_1385

FWD (Import) REV (Export)

Impacts Total Transfer Capability 200 MW 200 MW  
TTC with All Lines In Service 200 MW 200 MW

### ADIRNDCK-PORTER\_230\_12

Mon 01/06/2025 to Sat 05/31/2025  
0530 Continuous 1700  
Work scheduled by: NGrid

MOSES SOUTH

FWD (Import) REV (Export)

Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

### ELBRIDGE-LAFAYTTE\_345\_17-LE

Mon 01/06/2025 to Mon 01/06/2025  
0630 Continuous 0800  
Work scheduled by: NGrid

ARR: 75

OSWEGO EXPORT

FWD (Import) REV (Export)

Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

### OSWEGO\_-ELBRIDGE\_345\_17

Mon 01/06/2025 to Fri 01/31/2025  
0630 Continuous 1730  
Work scheduled by: NGrid

ARR: 75

OSWEGO EXPORT

FWD (Import) REV (Export)

Impacts Total Transfer Capability 0 MW  
TTC with All Lines In Service 5250 MW

### MOSES\_-ADIRNDCK\_230\_MA1

Tue 01/07/2025 to Tue 01/07/2025  
0600 Continuous 2230  
Work scheduled by: NYPA

MOSES SOUTH

FWD (Import) REV (Export)

Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, December 30, 2024 to Tuesday, June 30, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### DUNWODIE\_345KV\_6

Thu 01/09/2025 to Tue 01/14/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

CANCELLED by TO 12/30/2024 11:26

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3800 MW**  
800 MW  
4600 MW

### DUNWODIE\_345KV\_8

Thu 01/09/2025 to Tue 01/14/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

CANCELLED by TO 12/30/2024 11:26

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3800 MW**  
800 MW  
4600 MW

### WOOD\_ST\_-PLSNTVLE\_345\_Y87

Thu 01/09/2025 to Tue 01/14/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

CANCELLED by TO 12/30/2024 11:26

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**7470 MW**  
580 MW  
8050 MW

### CHAT\_DC\_GC1

Mon 01/13/2025 to Mon 01/13/2025  
0600 Continuous 0700  
Work scheduled by: HQ

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**2850 MW**  
300 MW  
3150 MW

### CHAT\_DC\_GC1

Mon 01/13/2025 to Mon 01/13/2025  
0600 Continuous 0700  
Work scheduled by: HQ

SCH - HQ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**500 MW**  
500 MW  
1000 MW

### CHAT\_DC\_GC1 , CHAT\_DC\_GC2

Mon 01/13/2025 to Mon 01/13/2025  
0600 0700  
Work scheduled by:

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**2550 MW**  
600 MW  
3150 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits		Monday, December 30, 2024 to Tuesday, June 30, 2026				
CENTRAL EAST	7550 MW	<b>The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.</b>				
CENTRAL EAST - VC	3725 MW					
TOTAL EAST	6150 MW					
UPNY CONED	8050 MW					
SPR/DUN-SOUTH	4600 MW					
DYSINGER EAST	3200 MW					
MOSES SOUTH	3150 MW					
<hr/>						
<b>CHAT_DC_GC1 , CHAT_DC_GC2</b>				FWD (Import)	REV (Export)	
Mon 01/13/2025	to	Mon 01/13/2025	SCH - HQ - NY	<b>1370 MW</b>	<b>0 MW</b>	
0600		0700	Impacts Total Transfer Capability	130 MW	1000 MW	
Work scheduled by:			TTC with All Lines In Service	1500 MW	1000 MW	
<hr/>						
<b>CHAT_DC_GC2</b>				FWD (Import)	REV (Export)	
Mon 01/13/2025	to	Mon 01/13/2025	MOSES SOUTH	<b>2850 MW</b>		
0600	Continuous	0700	Impacts Total Transfer Capability	300 MW		
Work scheduled by: HQ			TTC with All Lines In Service	3150 MW		
<hr/>						
<b>CHAT_DC_GC2</b>				FWD (Import)	REV (Export)	
Mon 01/13/2025	to	Mon 01/13/2025	SCH - HQ - NY		<b>500 MW</b>	
0600	Continuous	0700	Impacts Total Transfer Capability		500 MW	
Work scheduled by: HQ			TTC with All Lines In Service		1000 MW	
<hr/>						
<b>SCH-HQ-NYISO_LIMIT_600</b>				FWD (Import)	REV (Export)	
Mon 01/13/2025	to	Mon 01/13/2025	SCH - HQ - NY	<b>600 MW</b>		
0600	Continuous	0700	Impacts Total Transfer Capability	900 MW		
Work scheduled by: HQ			TTC with All Lines In Service	1500 MW		
<hr/>						
<b>CHAT_DC_GC1</b>				FWD (Import)	REV (Export)	
Tue 01/14/2025	to	Tue 01/14/2025	MOSES SOUTH	<b>2850 MW</b>		
1700	Continuous	1859	Impacts Total Transfer Capability	300 MW		
Work scheduled by: HQ			TTC with All Lines In Service	3150 MW		
<hr/>						
<b>CHAT_DC_GC1</b>				FWD (Import)	REV (Export)	
Tue 01/14/2025	to	Tue 01/14/2025	SCH - HQ - NY		<b>500 MW</b>	
1700	Continuous	1859	Impacts Total Transfer Capability		500 MW	
Work scheduled by: HQ			TTC with All Lines In Service		1000 MW	



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, December 30, 2024 to Tuesday, June 30, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### CHAT\_DC\_GC1 , CHAT\_DC\_GC2

Tue 01/14/2025 to Tue 01/14/2025  
1700 1859  
Work scheduled by:

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**2550 MW**  
600 MW  
3150 MW

### CHAT\_DC\_GC1 , CHAT\_DC\_GC2

Tue 01/14/2025 to Tue 01/14/2025  
1700 1859  
Work scheduled by:

SCH - HQ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1370 MW** **0 MW**  
130 MW 1000 MW  
1500 MW 1000 MW

### CHAT\_DC\_GC2

Tue 01/14/2025 to Tue 01/14/2025  
1700 Continuous 1859  
Work scheduled by: HQ

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**2850 MW**  
300 MW  
3150 MW

### CHAT\_DC\_GC2

Tue 01/14/2025 to Tue 01/14/2025  
1700 Continuous 1859  
Work scheduled by: HQ

SCH - HQ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**500 MW**  
500 MW  
1000 MW

### SCH-HQ-NYISO\_LIMIT\_600

Tue 01/14/2025 to Tue 01/14/2025  
1700 Continuous 1859  
Work scheduled by: HQ

SCH - HQ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**600 MW**  
900 MW  
1500 MW

### BUCHAN\_S-MILLWOOD\_345\_W97

Wed 01/15/2025 to Sat 01/18/2025  
0200 Continuous 0159  
Work scheduled by: ConEd

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**8015 MW**  
35 MW  
8050 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits		Monday, December 30, 2024 to Tuesday, June 30, 2026				
CENTRAL EAST	7550 MW	<b>The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.</b>				
CENTRAL EAST - VC	3725 MW					
TOTAL EAST	6150 MW					
UPNY CONED	8050 MW					
SPR/DUN-SOUTH	4600 MW					
DYSINGER EAST	3200 MW					
MOSES SOUTH	3150 MW					
<b>BUCHAN_S-MILLWOOD_345_W98</b>					FWD (Import)	REV (Export)
Sat 01/18/2025	to	Tue 01/21/2025	UPNY CONED	<b>8015 MW</b>		
0200	Continuous	0200	Impacts Total Transfer Capability	35 MW		
Work scheduled by: ConEd			TTC with All Lines In Service	8050 MW		
<b>KNICRBKR-ALPS____345_6</b>					FWD (Import)	REV (Export)
Mon 01/20/2025	to	Tue 01/21/2025	SCH - NE - NY	<b>900 MW</b>		
0530	Continuous	1830	Impacts Total Transfer Capability	500 MW		
Work scheduled by: NGrid			TTC with All Lines In Service	1400 MW		
<b>KNICRBKR-ALPS____345_6</b>					FWD (Import)	REV (Export)
Mon 01/20/2025	to	Tue 01/21/2025	SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>	
0530	Continuous	1830	Impacts Total Transfer Capability	100 MW	100 MW	
Work scheduled by: NGrid			TTC with All Lines In Service	200 MW	200 MW	
<b>RAMAPO_-BUCHAN_N_345_Y94</b>					FWD (Import)	REV (Export)
Wed 01/22/2025	to	Wed 01/22/2025	UPNY CONED	<b>7755 MW</b>		
0001	Continuous	0030	Impacts Total Transfer Capability	295 MW		
Work scheduled by: ConEd			TTC with All Lines In Service	8050 MW		
<b>RAMAPO_-BUCHAN_N_345_Y94</b>					FWD (Import)	REV (Export)
Sat 01/25/2025	to	Sat 01/25/2025	UPNY CONED	<b>7755 MW</b>		
2130	Continuous	2200	Impacts Total Transfer Capability	295 MW		
Work scheduled by: ConEd			TTC with All Lines In Service	8050 MW		
<b>DUNWODIE_345KV_7</b>					FWD (Import)	REV (Export)
Sun 01/26/2025	to	Sun 02/02/2025	SPR/DUN-SOUTH	<b>3800 MW</b>		
0001	Continuous	2200	Impacts Total Transfer Capability	800 MW		
Work scheduled by: ConEd			TTC with All Lines In Service	4600 MW		

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, December 30, 2024 to Tuesday, June 30, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### DUNWODIE\_345KV\_8

Sun 01/26/2025 to Sun 02/02/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

UPDATED by ConEd 11/22/2024 08:59

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3800 MW**  
800 MW  
4600 MW

### DUNWODIE-MOTTHAVN\_345\_72

Sun 01/26/2025 to Sun 02/02/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

UPDATED by ConEd 11/22/2024 08:59

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3800 MW**  
800 MW  
4600 MW

### ELBRIDGE-LAFAYTTE\_345\_17-LE

Mon 01/27/2025 to Fri 01/31/2025  
0700 Continuous 1730  
Work scheduled by: NGrid

ARR: 75

OSWEGO EXPORT  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**5250 MW**  
0 MW  
5250 MW

### HOPATCON-RAMAPO\_\_500\_5018

Tue 01/28/2025 to Sat 02/01/2025  
0001 Continuous 0200  
Work scheduled by: PJM

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1400 MW** **1200 MW**  
1200 MW 1500 MW  
2600 MW 2700 MW

### HOPATCON-RAMAPO\_\_500\_5018

Tue 01/28/2025 to Sat 02/01/2025  
0001 Continuous 0200  
Work scheduled by: PJM

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**7795 MW**  
255 MW  
8050 MW

### HOPATCON-RAMAPO\_\_500\_5018

Tue 01/28/2025 to Sat 02/01/2025  
0001 Continuous 0200  
Work scheduled by: PJM

TOTAL EAST  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**6800 MW**  
-650 MW  
6150 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits			Monday, December 30, 2024 to Tuesday, June 30, 2026		
CENTRAL EAST	7550 MW		<b>The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.</b>		
CENTRAL EAST - VC	3725 MW				
TOTAL EAST	6150 MW				
UPNY CONED	8050 MW				
SPR/DUN-SOUTH	4600 MW				
DYSINGER EAST	3200 MW				
MOSES SOUTH	3150 MW				
<b>RAMAPO__345_345_PAR3500</b>				FWD (Import)	REV (Export)
Tue 01/28/2025	to	Sat 02/01/2025	SCH - PJ - NY	<b>2550 MW</b>	<b>1250 MW</b>
0001	Continuous	0200	Impacts Total Transfer Capability	50 MW	1450 MW
Work scheduled by: PJM			TTC with All Lines In Service	2600 MW	2700 MW
<b>RAMAPO__345_345_PAR4500</b>				FWD (Import)	REV (Export)
Tue 01/28/2025	to	Sat 02/01/2025	SCH - PJ - NY	<b>2550 MW</b>	<b>1250 MW</b>
0001	Continuous	0200	Impacts Total Transfer Capability	50 MW	1450 MW
Work scheduled by: PJM			TTC with All Lines In Service	2600 MW	2700 MW
<b>RAMAPO__500_345_BK 1500</b>				FWD (Import)	REV (Export)
Tue 01/28/2025	to	Sat 02/01/2025	SCH - PJ - NY	<b>1400 MW</b>	<b>1200 MW</b>
0001	Continuous	0200	Impacts Total Transfer Capability	1200 MW	1500 MW
Work scheduled by: PJM			TTC with All Lines In Service	2600 MW	2700 MW
<b>RAMAPO__500_345_BK 1500</b>				FWD (Import)	REV (Export)
Tue 01/28/2025	to	Sat 02/01/2025	UPNY CONED	<b>7795 MW</b>	
0001	Continuous	0200	Impacts Total Transfer Capability	255 MW	
Work scheduled by: PJM			TTC with All Lines In Service	8050 MW	
<b>BECK__-NIAGARA_345_PA301</b>				FWD (Import)	REV (Export)
Tue 02/04/2025	to	Tue 02/04/2025	SCH - OH - NY	<b>1150 MW</b>	<b>1000 MW</b>
0500	Continuous	2100	Impacts Total Transfer Capability	1350 MW	850 MW
Work scheduled by: NYPA			TTC with All Lines In Service	2500 MW	1850 MW
<b>PIERCBRK-FIVEMILE_345_37</b>				FWD (Import)	REV (Export)
Tue 02/04/2025	to	Tue 02/04/2025	SCH - PJ - NY		
0900	Daily	1030	Impacts Total Transfer Capability		
Work scheduled by: NGrid			TTC with All Lines In Service		

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, December 30, 2024 to Tuesday, June 30, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### ROSETON\_EFISHKIL\_345\_RFK305

Sun 02/09/2025 to Wed 02/12/2025  
0001 Continuous 0200  
Work scheduled by: ConEd

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **7215 MW**  
835 MW  
8050 MW

### MILLWOOD-EASTVIEW\_345\_W82

Mon 02/10/2025 to Fri 02/14/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **7810 MW**  
240 MW  
8050 MW

### FRASER\_345\_FRASER SVC

Mon 02/10/2025 to Fri 02/14/2025  
0700 Continuous 1500  
Work scheduled by: NYSEG

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **3655 MW**  
70 MW  
3725 MW

### WOOD\_ST\_PLSNTVLE\_345\_Y86

Mon 02/17/2025 to Mon 02/17/2025  
0001 Continuous 0030  
Work scheduled by: ConEd

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **7475 MW**  
575 MW  
8050 MW

### BECK\_\_PACKARD\_230\_BP76

Thu 02/20/2025 to Thu 02/20/2025  
0730 Continuous 1630  
Work scheduled by: NGrid

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **1800 MW**  
700 MW  
2500 MW  
REV (Export) **1300 MW**  
550 MW  
1850 MW

### WOOD\_ST\_PLSNTVLE\_345\_Y86

Fri 02/21/2025 to Fri 02/21/2025  
0130 Continuous 0200  
Work scheduled by: ConEd

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **7475 MW**  
575 MW  
8050 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, December 30, 2024 to Tuesday, June 30, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### BERKSHIR-ALPS\_\_\_345\_393

Mon 02/24/2025 to Mon 02/24/2025  
0730 Continuous 1530  
Work scheduled by: NGrid

ARR: 78

SCH - NPX\_1385

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

**100 MW**

100 MW

200 MW

REV (Export)

**100 MW**

100 MW

200 MW

### BERKSHIR-ALPS\_\_\_345\_393

Mon 02/24/2025 to Mon 02/24/2025  
0730 Continuous 1530  
Work scheduled by: NGrid

ARR: 78

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

**1100 MW**

300 MW

1400 MW

REV (Export)

**1600 MW**

200 MW

1800 MW

### SPRNBK\_-TREMONT\_345\_X28

Fri 02/28/2025 to Tue 03/04/2025  
0001 Continuous 0200  
Work scheduled by: ConEd

UPDATED by ConEd 12/24/2024 09:22

SPR/DUN-SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

**4200 MW**

400 MW

4600 MW

REV (Export)

### RAMAPO\_-BUCHAN\_N\_345\_Y94

Mon 03/03/2025 to Sat 03/08/2025  
0001 Continuous 0200  
Work scheduled by: ConEd

UPNY CONED

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

**7755 MW**

295 MW

8050 MW

REV (Export)

### MOTTHAVN-RAINEY\_\_\_345\_Q11

Tue 03/04/2025 to Mon 04/14/2025  
0201 Continuous 0300  
Work scheduled by: ConEd

SPR/DUN-SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

**3800 MW**

800 MW

4600 MW

REV (Export)

### MOSES\_\_\_ADIRNDCK\_230\_MA1

Fri 03/14/2025 to Sat 03/29/2025  
0700 Continuous 1730  
Work scheduled by: NYPA

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

**2300 MW**

850 MW

3150 MW

REV (Export)

NYISO TRANSFER LIMITATIONS

Seasonal Limits		Monday, December 30, 2024 to Tuesday, June 30, 2026			
CENTRAL EAST	7550 MW	<div>The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.</div>			
CENTRAL EAST - VC	3725 MW				
TOTAL EAST	6150 MW				
UPNY CONED	8050 MW				
SPR/DUN-SOUTH	4600 MW				
DYSINGER EAST	3200 MW				
MOSES SOUTH	3150 MW				
NINEMILE-CLAY___345_8				FWD (Import)	REV (Export)
Mon 03/17/2025	to	Mon 03/17/2025	OSWEGO EXPORT	5150 MW	
0001	Continuous	0100	Impacts Total Transfer Capability	100 MW	
Work scheduled by: NGrid			TTC with All Lines In Service	5250 MW	
STLAWRNC-MOSES___230_L33P				FWD (Import)	REV (Export)
Mon 03/17/2025	to	Fri 03/21/2025	SCH - OH - NY		
0600	Continuous	1730	Impacts Total Transfer Capability		
Work scheduled by: NYPA			TTC with All Lines In Service		
SCRIBA_-VOLNEY___345_20				FWD (Import)	REV (Export)
Mon 03/17/2025	to	Mon 03/17/2025	OSWEGO EXPORT	5250 MW	
0700	Daily	1900	Impacts Total Transfer Capability	0 MW	
Work scheduled by: NGrid			TTC with All Lines In Service	5250 MW	
NINEMILE-CLAY___345_8				FWD (Import)	REV (Export)
Mon 03/17/2025	to	Tue 03/18/2025	OSWEGO EXPORT	5150 MW	
2130	Continuous	2300	Impacts Total Transfer Capability	100 MW	
Work scheduled by: NGrid			TTC with All Lines In Service	5250 MW	
ROCHESTR-PANNELL___345_RP1				FWD (Import)	REV (Export)
Mon 03/24/2025	to	Tue 03/25/2025	<div>UPDATED by RGE 11/08/2024 10:56</div> DYSINGER EAST	2300 MW	
0730	Continuous	1500	Impacts Total Transfer Capability	900 MW	
Work scheduled by: NYSEG			TTC with All Lines In Service	3200 MW	
NINEMILE-CLAY___345_8				FWD (Import)	REV (Export)
Tue 03/25/2025	to	Tue 03/25/2025	OSWEGO EXPORT	5150 MW	
0200	Continuous	0300	Impacts Total Transfer Capability	100 MW	
Work scheduled by: NGrid			TTC with All Lines In Service	5250 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits		Monday, December 30, 2024 to Tuesday, June 30, 2026				
CENTRAL EAST	7550 MW	<b>The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.</b>				
CENTRAL EAST - VC	3725 MW					
TOTAL EAST	6150 MW					
UPNY CONED	8050 MW					
SPR/DUN-SOUTH	4600 MW					
DYSINGER EAST	3200 MW					
MOSES SOUTH	3150 MW					
ROCHESTR-PANNELL_345_RP2					FWD (Import)	REV (Export)
Wed 03/26/2025	to	Thu 03/27/2025	<u>UPDATED by RGE 11/08/2024 10:51</u>		DYSINGER EAST	<b>2300 MW</b>
0730	Continuous	1500			Impacts Total Transfer Capability	900 MW
Work scheduled by: RGE		TTC with All Lines In Service			3200 MW	
NIAGARA-ROBNSNRD_230_64					FWD (Import)	REV (Export)
Fri 03/28/2025	to	Fri 03/28/2025			SCH - OH - NY	
0500	Continuous	1900			Impacts Total Transfer Capability	
Work scheduled by: NYPA		TTC with All Lines In Service				
BERKSHIR-ALPS_345_393					FWD (Import)	REV (Export)
Mon 03/31/2025	to	Mon 03/31/2025	ARR: 78		SCH - NPX_1385	<b>100 MW</b> <b>100 MW</b>
0700	Continuous	1600			Impacts Total Transfer Capability	100 MW 100 MW
Work scheduled by: NGrid		TTC with All Lines In Service			200 MW 200 MW	
BERKSHIR-ALPS_345_393					FWD (Import)	REV (Export)
Mon 03/31/2025	to	Mon 03/31/2025	ARR: 78		SCH - NE - NY	<b>1100 MW</b> <b>1600 MW</b>
0700	Continuous	1600			Impacts Total Transfer Capability	300 MW 200 MW
Work scheduled by: NGrid		TTC with All Lines In Service			1400 MW 1800 MW	
BERKSHIR-ALPS_345_393 , BERKSHIR-NORTHFLD_345_312					FWD (Import)	REV (Export)
Mon 03/31/2025	to	Mon 03/31/2025	ARR: 78		SCH - NE - NY	<b>1100 MW</b> <b>1100 MW</b>
0700		1600			Impacts Total Transfer Capability	300 MW 700 MW
Work scheduled by:		TTC with All Lines In Service			1400 MW 1800 MW	
BERKSHIR-NORTHFLD_345_312					FWD (Import)	REV (Export)
Mon 03/31/2025	to	Mon 03/31/2025			SCH - NPX_1385	<b>100 MW</b> <b>100 MW</b>
0700	Continuous	1600			Impacts Total Transfer Capability	100 MW 100 MW
Work scheduled by: NGrid		TTC with All Lines In Service			200 MW 200 MW	



NYISO TRANSFER LIMITATIONS

Seasonal Limits

Monday, December 30, 2024 to Tuesday, June 30, 2026

CENTRAL EAST	7550 MW	The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.				
CENTRAL EAST - VC	3725 MW					
TOTAL EAST	6150 MW					
UPNY CONED	8050 MW					
SPR/DUN-SOUTH	4600 MW					
DYSINGER EAST	3200 MW					
MOSES SOUTH	3150 MW					
BERKSHIR-NORTHFLD_345_312					FWD (Import)	REV (Export)
Mon 03/31/2025	to	Mon 03/31/2025	SCH - NE - NY	1300 MW		
0700	Continuous	1600	Impacts Total Transfer Capability	100 MW		
Work scheduled by: NGrid			TTC with All Lines In Service	1400 MW		
NINEMILE-CLAY___345_8					FWD (Import)	REV (Export)
Wed 04/02/2025	to	Wed 04/02/2025	OSWEGO EXPORT	5150 MW		
1900	Continuous	2000	Impacts Total Transfer Capability	100 MW		
Work scheduled by: NGrid			TTC with All Lines In Service	5250 MW		
NIAGARA_-DYSINGER_345_ND2					FWD (Import)	REV (Export)
Mon 04/07/2025	to	Fri 04/11/2025	DYSINGER EAST	2700 MW		
0500	Continuous	1730	Impacts Total Transfer Capability	500 MW		
Work scheduled by: NYPA			TTC with All Lines In Service	3200 MW		
LINDN_CG-LNDVFT__345_V-3022					FWD (Import)	REV (Export)
Mon 04/07/2025	to	Sat 04/12/2025	SCH - PJM_VFT	0 MW	0 MW	
0800	Continuous	1500	Impacts Total Transfer Capability	315 MW	315 MW	
Work scheduled by: PJM			TTC with All Lines In Service	315 MW	315 MW	
RAMAPO_-BUCHAN_N_345_Y94					FWD (Import)	REV (Export)
Sat 04/12/2025	to	Sat 04/19/2025	UPNY CONED	7755 MW		
0001	Continuous	0200	Impacts Total Transfer Capability	295 MW		
Work scheduled by: ConEd			TTC with All Lines In Service	8050 MW		
SPRNBK_-TREMONT__345_X28					FWD (Import)	REV (Export)
Mon 04/14/2025	to	Sun 04/20/2025	SPR/DUN-SOUTH	4200 MW		
0001	Continuous	0200	Impacts Total Transfer Capability	400 MW		
Work scheduled by: ConEd			TTC with All Lines In Service	4600 MW		

UPDATED by ConEd 12/24/2024 09:22

NYISO TRANSFER LIMITATIONS

Seasonal Limits		Monday, December 30, 2024 to Tuesday, June 30, 2026				
CENTRAL EAST	7550 MW	<b>The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.</b>				
CENTRAL EAST - VC	3725 MW					
TOTAL EAST	6150 MW					
UPNY CONED	8050 MW					
SPR/DUN-SOUTH	4600 MW					
DYSINGER EAST	3200 MW					
MOSES SOUTH	3150 MW					
<hr/>						
<b>NIAGARA_-DYSINGER_345_ND2</b>				FWD (Import)	REV (Export)	
Mon 04/14/2025	to	Thu 04/17/2025	DYSINGER EAST	<b>2700 MW</b>		
0500	Continuous	1730	Impacts Total Transfer Capability	500 MW		
Work scheduled by: NYPA			TTC with All Lines In Service	3200 MW		
<hr/>						
<b>E13THSTA-FARRAGUT_345_45</b>				FWD (Import)	REV (Export)	
Tue 04/15/2025	to	Sun 04/20/2025	SPR/DUN-SOUTH	<b>3800 MW</b>		
0001	Continuous	0200	Impacts Total Transfer Capability	800 MW		
Work scheduled by: ConEd			TTC with All Lines In Service	4600 MW		
<hr/>						
<b>W49TH_ST-E13THSTA_345_M54</b>				FWD (Import)	REV (Export)	
Tue 04/15/2025	to	Sun 04/20/2025	SPR/DUN-SOUTH	<b>3800 MW</b>		
0001	Continuous	0200	Impacts Total Transfer Capability	800 MW		
Work scheduled by: ConEd			TTC with All Lines In Service	4600 MW		
<hr/>						
<b>MOSES__-ADIRNDCK_230_MA1</b>				FWD (Import)	REV (Export)	
Tue 04/15/2025	to	Tue 04/15/2025	MOSES SOUTH	<b>2300 MW</b>		
0700	Continuous	1530	Impacts Total Transfer Capability	850 MW		
Work scheduled by: NYPA			TTC with All Lines In Service	3150 MW		
<hr/>						
<b>LINDN_CG-LNDVFT__345_V-3022</b>				FWD (Import)	REV (Export)	
Thu 04/17/2025	to	Thu 04/17/2025	SCH - PJM_VFT	<b>0 MW</b>	<b>0 MW</b>	
1500	Continuous	1800	Impacts Total Transfer Capability	315 MW	315 MW	
Work scheduled by: PJM			TTC with All Lines In Service	315 MW	315 MW	
<hr/>						
<b>NIAGARA_-PACKARD_230_61</b>				FWD (Import)	REV (Export)	
Mon 04/21/2025	to	Fri 04/25/2025	SCH - OH - NY	<b>2450 MW</b>	<b>1800 MW</b>	
0500	Continuous	1900	Impacts Total Transfer Capability	50 MW	50 MW	
Work scheduled by: NYPA			TTC with All Lines In Service	2500 MW	1850 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, December 30, 2024 to Tuesday, June 30, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### PANNELL\_\_CLAY\_\_345\_1

Mon 04/21/2025 to Fri 04/25/2025  
0700 Continuous 1530  
Work scheduled by: NYPA

WEST CENTRAL  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

FWD (Import) REV (Export)

**1300 MW**

### MOSES\_\_ADIRNDCK\_230\_MA2

Tue 04/22/2025 to Tue 04/22/2025  
0700 Continuous 1530  
Work scheduled by: NYPA

MOSES SOUTH  
Impacts Total Transfer Capability 850 MW  
TTC with All Lines In Service 3150 MW

FWD (Import) REV (Export)

**2300 MW**

### MARCY\_\_765\_345\_AT1

Fri 04/25/2025 to Fri 04/25/2025  
0500 Continuous 1730  
Work scheduled by: NYPA ARR: 19

MOSES SOUTH  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 3150 MW

FWD (Import) REV (Export)

**1750 MW**

### MARCY\_\_765\_345\_AT2

Sat 04/26/2025 to Sat 04/26/2025  
0500 Continuous 1730  
Work scheduled by: NYPA ARR: 19

MOSES SOUTH  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

FWD (Import) REV (Export)

**1700 MW**

### BUCHAN\_S-MILLWOOD\_345\_W97

Mon 04/28/2025 to Tue 04/29/2025  
0001 Continuous 0230  
Work scheduled by: ConEd

UPNY CONED  
Impacts Total Transfer Capability 35 MW  
TTC with All Lines In Service 8050 MW

FWD (Import) REV (Export)

**8015 MW**

### PANNELL\_\_CLAY\_\_345\_2

Mon 04/28/2025 to Fri 05/02/2025  
0700 Continuous 1530  
Work scheduled by: NYPA

WEST CENTRAL  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

FWD (Import) REV (Export)

**1300 MW**

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, December 30, 2024 to Tuesday, June 30, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### E13THSTA-FARRAGUT\_345\_46

Tue 05/06/2025 to Sat 05/10/2025  
0001 Continuous 0200  
Work scheduled by: ConEd

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

### LONG\_MTN-CRICKVLY\_345\_398

Tue 05/06/2025 to Thu 05/29/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

SCH - NPX_1385	FWD (Import)	REV (Export)
	<b>100 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

### LONG\_MTN-CRICKVLY\_345\_398

Tue 05/06/2025 to Thu 05/29/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>800 MW</b>	<b>1200 MW</b>
Impacts Total Transfer Capability	600 MW	400 MW
TTC with All Lines In Service	1400 MW	1600 MW

### W49TH\_ST\_345KV\_6

Tue 05/06/2025 to Tue 05/06/2025  
0001 Continuous 0030  
Work scheduled by: ConEd

SCH - PJM_HTP	FWD (Import)	REV (Export)
	<b>300 MW</b>	
Impacts Total Transfer Capability	360 MW	
TTC with All Lines In Service	660 MW	

### W49TH\_ST-E13THSTA\_345\_M55

Tue 05/06/2025 to Sat 05/10/2025  
0001 Continuous 0200  
Work scheduled by: ConEd

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

### WOOD\_ST-PLSNTVLE\_345\_Y87

Wed 05/07/2025 to Fri 05/09/2025  
2200 Continuous 0259  
Work scheduled by: ConEd

UPNY CONED	FWD (Import)	REV (Export)
	<b>7470 MW</b>	
Impacts Total Transfer Capability	580 MW	
TTC with All Lines In Service	8050 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, December 30, 2024 to Tuesday, June 30, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### DUNWODIE\_345KV\_6

Fri 05/09/2025 to Fri 05/09/2025  
0001 Continuous 0030  
Work scheduled by: ConEd

SPR/DUN-SOUTH FWD (Import) REV (Export)  
Impacts Total Transfer Capability **3800 MW**  
TTC with All Lines In Service 800 MW  
4600 MW

### DUNWODIE\_345KV\_8

Fri 05/09/2025 to Fri 05/09/2025  
0001 Continuous 0030  
Work scheduled by: ConEd

SPR/DUN-SOUTH FWD (Import) REV (Export)  
Impacts Total Transfer Capability **3800 MW**  
TTC with All Lines In Service 800 MW  
4600 MW

### W49TH\_ST\_345KV\_6

Sat 05/10/2025 to Sat 05/10/2025  
0130 Continuous 0200  
Work scheduled by: ConEd

SCH - PJM\_HTP FWD (Import) REV (Export)  
Impacts Total Transfer Capability **300 MW**  
TTC with All Lines In Service 360 MW  
660 MW

### DUNWODIE\_345KV\_6

Sun 05/11/2025 to Sun 05/11/2025  
1830 Continuous 1900  
Work scheduled by: ConEd

SPR/DUN-SOUTH FWD (Import) REV (Export)  
Impacts Total Transfer Capability **3800 MW**  
TTC with All Lines In Service 800 MW  
4600 MW

### DUNWODIE\_345KV\_8

Sun 05/11/2025 to Sun 05/11/2025  
1830 Continuous 1900  
Work scheduled by: ConEd

SPR/DUN-SOUTH FWD (Import) REV (Export)  
Impacts Total Transfer Capability **3800 MW**  
TTC with All Lines In Service 800 MW  
4600 MW

### NEPTUNE\_DUFFYAVE\_345\_NEPTUNE

Mon 05/12/2025 to Fri 05/16/2025  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE FWD (Import) REV (Export)  
Impacts Total Transfer Capability **0 MW**  
TTC with All Lines In Service 660 MW  
660 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits		Monday, December 30, 2024 to Tuesday, June 30, 2026			
CENTRAL EAST	7550 MW	<div>The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.</div>			
CENTRAL EAST - VC	3725 MW				
TOTAL EAST	6150 MW				
UPNY CONED	8050 MW				
SPR/DUN-SOUTH	4600 MW				
DYSINGER EAST	3200 MW				
MOSES SOUTH	3150 MW				
NEWBRDGE_345_138_BK_1				FWD (Import)	REV (Export)
Mon 05/12/2025	to	Fri 05/16/2025	SCH - PJM_NEPTUNE	375 MW	
0600	Continuous	1600	Impacts Total Transfer Capability	285 MW	
Work scheduled by: LI			TTC with All Lines In Service	660 MW	
NEWBRDGE_345_138_BK_2				FWD (Import)	REV (Export)
Mon 05/12/2025	to	Fri 05/16/2025	SCH - PJM_NEPTUNE	375 MW	
0600	Continuous	1600	Impacts Total Transfer Capability	285 MW	
Work scheduled by: LI			TTC with All Lines In Service	660 MW	
NEWBRDGE-DUFFYAVE_345_501				FWD (Import)	REV (Export)
Mon 05/12/2025	to	Fri 05/16/2025	SCH - PJM_NEPTUNE	0 MW	
0600	Continuous	1600	Impacts Total Transfer Capability	660 MW	
Work scheduled by: LI			TTC with All Lines In Service	660 MW	
SAND_BAR-PLATSBRG_115_PV20				FWD (Import)	REV (Export)
Mon 07/07/2025	to	Fri 07/11/2025	SCH - NE - NY		
0700	Continuous	1530	Impacts Total Transfer Capability		
Work scheduled by: NYPA			TTC with All Lines In Service		
SAND_BAR-PLATSBRG_115_PV20				FWD (Import)	REV (Export)
Mon 07/07/2025	to	Fri 07/11/2025	CENTRAL EAST - VC	3625 MW	
0700	Continuous	1530	Impacts Total Transfer Capability	100 MW	
Work scheduled by: NYPA			TTC with All Lines In Service	3725 MW	
NIAGARA_345_230_AT4				FWD (Import)	REV (Export)
Tue 07/08/2025	to	Tue 07/08/2025	SCH - OH - NY		1200 MW
0500	Continuous	1900	Impacts Total Transfer Capability		400 MW
Work scheduled by: NYPA			TTC with All Lines In Service		1600 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, December 30, 2024 to Tuesday, June 30, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### DYSINGER-STA\_255\_345\_DH1

Tue 09/02/2025 to Mon 09/15/2025  
0500 Continuous 2100  
Work scheduled by: NYPA

DYSINGER EAST  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>2850 MW</b>	
350 MW	
3200 MW	

### GOETHALS\_345KV\_5

Mon 09/08/2025 to Mon 09/08/2025  
0301 Continuous 0330  
Work scheduled by: ConEd

STATEN ISLAND  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)

### CLAY\_\_-EDIC\_\_345\_2-15

Mon 09/08/2025 to Fri 09/12/2025  
0700 Continuous 1530  
Work scheduled by: NYPA

OSWEGO EXPORT  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>4850 MW</b>	
400 MW	
5250 MW	

### MOSES\_\_-ADIRNDCK\_230\_MA1

Tue 09/09/2025 to Sun 10/12/2025  
0700 Continuous 1730  
Work scheduled by: NYPA

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>2100 MW</b>	
1050 MW	
3150 MW	

### GOETHALS\_345KV\_5

Tue 09/09/2025 to Tue 09/09/2025  
2330 Continuous 2359  
Work scheduled by: ConEd

STATEN ISLAND  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)

### DUNWODIE\_345KV\_4

Sat 09/13/2025 to Sun 09/14/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

UPDATED by ConEd 11/08/2024 12:36

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>3800 MW</b>	
800 MW	
4600 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, December 30, 2024 to Tuesday, June 30, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### DUNWODIE\_345KV\_6

Sat 09/13/2025 to Sun 09/14/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

UPDATED by ConEd 11/08/2024 12:36

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3800 MW**  
800 MW  
4600 MW

### DUNWODIE-SHORE\_RD\_345\_Y50

Sat 09/13/2025 to Sun 09/14/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

UPDATED by ConEd 11/08/2024 12:36

CONED - LIPA  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**800 MW**  
700 MW  
1500 MW

### SHORE\_RD\_345\_138\_BK 1

Sat 09/13/2025 to Sun 09/14/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

UPDATED by ConEd 11/08/2024 12:36

CONED - LIPA  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1350 MW**  
150 MW  
1500 MW

### SHORE\_RD\_345\_138\_BK 2

Sat 09/13/2025 to Sun 09/14/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

UPDATED by ConEd 11/08/2024 12:36

CONED - LIPA  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1350 MW**  
150 MW  
1500 MW

### SPRNBRK\_345KV\_RNS4

Mon 09/15/2025 to Thu 10/02/2025  
0001 Continuous 0200  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3200 MW**  
1400 MW  
4600 MW

### SPRNBRK\_-W49TH\_ST\_345\_M52

Mon 09/15/2025 to Thu 10/02/2025  
0001 Continuous 0200  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3200 MW**  
1400 MW  
4600 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, December 30, 2024 to Tuesday, June 30, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### W49TH\_ST\_345KV\_5

Mon 09/15/2025 to Mon 09/15/2025  
0001 Continuous 0030  
Work scheduled by: ConEd

SCH - PJM\_HTP

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**460 MW**

200 MW

660 MW

### GOETHALS\_345KV\_5

Mon 09/15/2025 to Mon 09/15/2025  
0230 Continuous 0300  
Work scheduled by: ConEd

STATEN ISLAND

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

### ADIRNDCK-PORTER\_230\_12

Mon 09/15/2025 to Sun 10/12/2025  
0600 Continuous 1700  
Work scheduled by: NGrid

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**2100 MW**

1050 MW

3150 MW

### DYSINGER-STA\_255\_345\_DH2

Tue 09/16/2025 to Tue 10/28/2025  
0500 Continuous 1900  
Work scheduled by: NYPA

DYSINGER EAST

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**2850 MW**

350 MW

3200 MW

### MARCY\_\_FRASANNX\_345\_UCC2-41

Mon 09/22/2025 to Mon 10/06/2025  
0700 Continuous 1730  
Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**3225 MW**

500 MW

3725 MW

### PANNELL\_-CLAY\_\_345\_1

Mon 09/29/2025 to Fri 10/03/2025  
0700 Continuous 1530  
Work scheduled by: NYPA

WEST CENTRAL

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**1300 MW**

950 MW

2250 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, December 30, 2024 to Tuesday, June 30, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### W49TH\_ST\_345KV\_5

Thu 10/02/2025 to Thu 10/02/2025  
0130 Continuous 0200  
Work scheduled by: ConEd

SCH - PJM\_HTP

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**460 MW**

200 MW

660 MW

### PANNELL\_-CLAY\_\_\_345\_2

Mon 10/06/2025 to Fri 10/10/2025  
0700 Continuous 1530  
Work scheduled by: NYPA

WEST CENTRAL

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**1300 MW**

950 MW

2250 MW

### NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE

Mon 10/13/2025 to Thu 10/16/2025  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**0 MW**

660 MW

660 MW

### NEWBRDGE\_345\_138\_BK\_1

Mon 10/13/2025 to Thu 10/16/2025  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**375 MW**

285 MW

660 MW

### NEWBRDGE\_345\_138\_BK\_2

Mon 10/13/2025 to Thu 10/16/2025  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**375 MW**

285 MW

660 MW

### NEWBRDGE-DUFFYAVE\_345\_501

Mon 10/13/2025 to Thu 10/16/2025  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**0 MW**

660 MW

660 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, December 30, 2024 to Tuesday, June 30, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MOSES\_\_-ADIRNDCK\_230\_MA2

Mon 10/13/2025 to Mon 11/24/2025  
0700 Continuous 1730  
Work scheduled by: NYPA

MOSES SOUTH	FWD (Import)	REV (Export)
	<b>2100 MW</b>	
Impacts Total Transfer Capability	1050 MW	
TTC with All Lines In Service	3150 MW	

### EDIC\_\_-PRINCTWN\_345\_351

Tue 10/14/2025 to Fri 10/17/2025  
0600 Continuous 1830  
Work scheduled by: NGrid

CENTRAL EAST - VC	FWD (Import)	REV (Export)
	<b>3335 MW</b>	
Impacts Total Transfer Capability	390 MW	
TTC with All Lines In Service	3725 MW	

### SPRNBK\_-TREMONT\_345\_X28

Mon 10/27/2025 to Fri 10/31/2025  
0001 Continuous 1800  
Work scheduled by: ConEd

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	<b>4200 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	4600 MW	

### CHATGUAY-MASSENA\_765\_7040

Sun 11/16/2025 to Sun 11/30/2025  
0001 Continuous 2359  
Work scheduled by: NYPA

SCH - HQ - NY	FWD (Import)	REV (Export)
	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	1500 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

### CHATGUAY-MASSENA\_765\_7040

Sun 11/16/2025 to Sun 11/30/2025  
0001 Continuous 2359  
Work scheduled by: NYPA

MOSES SOUTH	FWD (Import)	REV (Export)
	<b>1550 MW</b>	
Impacts Total Transfer Capability	1600 MW	
TTC with All Lines In Service	3150 MW	

### MOSES\_\_-ADIRNDCK\_230\_MA2 , MOSES\_\_-MASSENA\_230\_MMS2 , MOSES\_\_-MASSENA\_230\_MMS1

Sun 11/16/2025 to Mon 11/24/2025  
0001 1730  
Work scheduled by:

SCH - HQ_CEDARS	FWD (Import)	REV (Export)
	<b>90 MW</b>	
Impacts Total Transfer Capability	189 MW	
TTC with All Lines In Service	279 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits		Monday, December 30, 2024 to Tuesday, June 30, 2026			
CENTRAL EAST	7550 MW	<b>The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.</b>			
CENTRAL EAST - VC	3725 MW				
TOTAL EAST	6150 MW				
UPNY CONED	8050 MW				
SPR/DUN-SOUTH	4600 MW				
DYSINGER EAST	3200 MW				
MOSES SOUTH	3150 MW				
<hr/>					
<b>MOSES__-MASSENA_230_MMS2 , MOSES__-MASSENA_230_MMS1</b>				FWD (Import)	REV (Export)
Sun 11/16/2025	to	Sun 11/30/2025	SCH - HQ_CEDARS	<b>90 MW</b>	
0001		2359	Impacts Total Transfer Capability	189 MW	
Work scheduled by:			TTC with All Lines In Service	279 MW	
<hr/>					
<b>MOSES__-MASSENA_230_MMS2 , MOSES__-MASSENA_230_MMS1</b>				FWD (Import)	REV (Export)
Sun 11/16/2025	to	Sun 11/30/2025	SCH - HQ - NY	<b>850 MW</b>	<b>0 MW</b>
0001		2359	Impacts Total Transfer Capability	650 MW	1000 MW
Work scheduled by:			TTC with All Lines In Service	1500 MW	1000 MW
<hr/>					
<b>MOTTHAVN-RAINEY__345_Q11</b>				FWD (Import)	REV (Export)
Mon 12/01/2025	to	Tue 12/02/2025	SPR/DUN-SOUTH	<b>3800 MW</b>	
0001	Continuous	0230	Impacts Total Transfer Capability	800 MW	
Work scheduled by: ConEd			TTC with All Lines In Service	4600 MW	
<hr/>					
<b>GOETHALS_345KV_5</b>				FWD (Import)	REV (Export)
Sat 01/17/2026	to	Sat 01/17/2026	<u>UPDATED by ConEd 07/10/2024 16:09</u>	STATEN ISLAND	
0301	Continuous	0330	Impacts Total Transfer Capability		
Work scheduled by: ConEd			TTC with All Lines In Service		
<hr/>					
<b>DYSINGER-STA_255_345_DH2</b>				FWD (Import)	REV (Export)
Mon 03/02/2026	to	Fri 03/13/2026	DYSINGER EAST	<b>2850 MW</b>	
0500	Continuous	1900	Impacts Total Transfer Capability	350 MW	
Work scheduled by: NYPA			TTC with All Lines In Service	3200 MW	
<hr/>					
<b>DYSINGER-STA_255_345_DH1</b>				FWD (Import)	REV (Export)
Mon 03/16/2026	to	Tue 04/07/2026	DYSINGER EAST	<b>2850 MW</b>	
0500	Continuous	2100	Impacts Total Transfer Capability	350 MW	
Work scheduled by: NYPA			TTC with All Lines In Service	3200 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Monday, December 30, 2024 to Tuesday, June 30, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### DYSINGER-STA\_255\_345\_DH2

Wed 04/08/2026 to Mon 04/20/2026  
0500 Continuous 2100  
Work scheduled by: NYPA

DYSINGER EAST **2850 MW**  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 3200 MW

### DYSINGER-STA\_255\_345\_DH1

Tue 04/21/2026 to Fri 05/01/2026  
0500 Continuous 2100  
Work scheduled by: NYPA

DYSINGER EAST **2850 MW**  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 3200 MW

### GOETHALS\_345KV\_5

Sat 04/25/2026 to Sat 04/25/2026  
2330 Continuous 2359  
Work scheduled by: ConEd

UPDATED by ConEd 07/10/2024 16:09

STATEN ISLAND  
Impacts Total Transfer Capability  
TTC with All Lines In Service

### GOETHALS\_345KV\_5

Mon 04/27/2026 to Mon 04/27/2026  
0001 Continuous 0030  
Work scheduled by: ConEd

UPDATED by ConEd 07/10/2024 16:09

STATEN ISLAND  
Impacts Total Transfer Capability  
TTC with All Lines In Service

### GOETHALS\_345KV\_5

Tue 05/05/2026 to Tue 05/05/2026  
0230 Continuous 0300  
Work scheduled by: ConEd

UPDATED by ConEd 07/10/2024 16:09

STATEN ISLAND  
Impacts Total Transfer Capability  
TTC with All Lines In Service

### NEPTUNE\_DUFFYAVE\_345\_NEPTUNE

Mon 05/11/2026 to Fri 05/15/2026  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE **0 MW**  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits		Monday, December 30, 2024 to Tuesday, June 30, 2026			
CENTRAL EAST	7550 MW	<div>The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.</div>			
CENTRAL EAST - VC	3725 MW				
TOTAL EAST	6150 MW				
UPNY CONED	8050 MW				
SPR/DUN-SOUTH	4600 MW				
DYSINGER EAST	3200 MW				
MOSES SOUTH	3150 MW				
<hr/>					
NEWBRDGE_345_138_BK_1				FWD (Import)	REV (Export)
Mon 05/11/2026	to	Fri 05/15/2026	SCH - PJM_NEPTUNE	375 MW	
0600	Continuous	1600	Impacts Total Transfer Capability	285 MW	
Work scheduled by: LI			TTC with All Lines In Service	660 MW	
<hr/>					
NEWBRDGE_345_138_BK_2				FWD (Import)	REV (Export)
Mon 05/11/2026	to	Fri 05/15/2026	SCH - PJM_NEPTUNE	375 MW	
0600	Continuous	1600	Impacts Total Transfer Capability	285 MW	
Work scheduled by: LI			TTC with All Lines In Service	660 MW	
<hr/>					
NEWBRDGE-DUFFYAVE_345_501				FWD (Import)	REV (Export)
Mon 05/11/2026	to	Fri 05/15/2026	SCH - PJM_NEPTUNE	0 MW	
0600	Continuous	1600	Impacts Total Transfer Capability	660 MW	
Work scheduled by: LI			TTC with All Lines In Service	660 MW	