

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, December 31, 2024 to Tuesday, June 30, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONP_-FARRAGUT_345_B3402

Mon 01/15/2018 to Thu 05/01/2025
0001 Continuous 0100
Work scheduled by: ConEd

EXT FORCED by ConEd 03/11/2024 11:26

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

MARION_-FARRAGUT_345_C3403

Mon 01/15/2018 to Thu 05/01/2025
0001 Continuous 0100
Work scheduled by: ConEd

EXT FORCED by ConEd 03/11/2024 11:26

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

MARION_-FARRAGUT_345_C3403 , HUDSONP_-FARRAGUT_345_B3402

Mon 01/15/2018 to Thu 05/01/2025
0001 0100
Work scheduled by:

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
2400 MW 2400 MW
200 MW 300 MW
2600 MW 2700 MW

MARCY__345KV_CSC

Sat 06/15/2024 to Sat 05/24/2025
0001 Continuous 2359
Work scheduled by: NYPA

FORCED by NYPA 06/11/2024 15:44

CENTRAL EAST - VC
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
3650 MW
75 MW
3725 MW

W49TH_ST_345KV_6

Fri 09/27/2024 to Thu 01/02/2025
0101 Continuous 2359
Work scheduled by: ConEd

UPDATED by ConEd 09/25/2024 08:24

SCH - PJM_HTP
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
300 MW
360 MW
660 MW

W49TH_ST-E13THSTA_345_M55

Fri 09/27/2024 to Thu 01/02/2025
0101 Continuous 2359
Work scheduled by: ConEd

UPDATED by ConEd 09/25/2024 08:24

SPR/DUN-SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
3800 MW
800 MW
4600 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, December 31, 2024 to Tuesday, June 30, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___765_345_AT1

Mon 10/14/2024 to Fri 01/24/2025
2110 Continuous 2359
Work scheduled by: NYPA

FORCED by NYISO 12/31/2024 11:15

MOSES SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
1750 MW
1400 MW
3150 MW

SCH-IMO-NYISO_LIMIT_1900

Fri 11/01/2024 to Wed 04/30/2025
0001 Continuous 2359
Work scheduled by: IESO

SCH - OH - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
2200 MW
300 MW
2500 MW

S.RIPLEY-DUNKIRK_230_68

Fri 11/08/2024 to Fri 01/31/2025
1113 Continuous 1800
Work scheduled by: PJM

EXT FORCED by NGrid 11/13/2024 16:46

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
2000 MW
600 MW
2600 MW

SCH-HQ-NYISO_LIMIT_1100

Wed 12/04/2024 to Wed 03/19/2025
1801 Continuous 1600
Work scheduled by: HQ

SCH - HQ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
1100 MW
400 MW
1500 MW

SCH-PJM-NYISO_LIMIT_1700

Sat 12/28/2024 to Wed 01/08/2025
0001 Continuous 2359
Work scheduled by: NYISO

SCH - PJ - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
2000 MW
600 MW
2600 MW

ROSETON_EFISHKIL_345_RFK305

Mon 12/30/2024 to Fri 01/03/2025
0700 Continuous 1600
Work scheduled by: CHGE

UPNY CONED
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
7215 MW
835 MW
8050 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, December 31, 2024 to Tuesday, June 30, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MILLWOOD-EASTVIEW_345_W85

Thu 01/02/2025 to Thu 01/02/2025
0001 Continuous 0030
Work scheduled by: ConEd

UPNY CONED
Impacts Total Transfer Capability 240 MW
TTC with All Lines In Service 8050 MW

FWD (Import) REV (Export)

SPRNBKR_345KV_RNS3

Thu 01/02/2025 to Thu 01/02/2025
0001 Continuous 1830
Work scheduled by: ConEd

SPR/DUN-SOUTH
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

KNICRBKR-PLSNTVLY_345_Y57

Thu 01/02/2025 to Wed 01/15/2025
0530 Continuous 1830
Work scheduled by: NGrid ARR: 78

UPNY CONED
Impacts Total Transfer Capability 165 MW
TTC with All Lines In Service 8050 MW

FWD (Import) REV (Export)

MILLWOOD-EASTVIEW_345_W85

Thu 01/02/2025 to Thu 01/02/2025
1800 Continuous 1830
Work scheduled by: ConEd

UPNY CONED
Impacts Total Transfer Capability 240 MW
TTC with All Lines In Service 8050 MW

FWD (Import) REV (Export)

W49TH_ST_345KV_6

Fri 01/03/2025 to Wed 01/29/2025
0001 Continuous 0200
Work scheduled by: ConEd UPDATED by ConEd 12/18/2024 15:15

SCH - PJM_HTP
Impacts Total Transfer Capability 360 MW
TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

W49TH_ST_345KV_8

Fri 01/03/2025 to Wed 01/29/2025
0001 Continuous 0200
Work scheduled by: ConEd UPDATED by ConEd 12/18/2024 15:15

SCH - PJM_HTP
Impacts Total Transfer Capability 350 MW
TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, December 31, 2024 to Tuesday, June 30, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST-E13THSTA_345_M55

Fri 01/03/2025 to Wed 01/29/2025
0001 Continuous 0200
Work scheduled by: ConEd

UPDATED by ConEd 12/18/2024 15:15

SPR/DUN-SOUTH
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

3800 MW

DUNWODIE_345KV_5

Sat 01/04/2025 to Sun 01/05/2025
0001 Continuous 0259
Work scheduled by: ConEd

SPR/DUN-SOUTH
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

3800 MW

DUNWODIE_345KV_7

Sat 01/04/2025 to Sun 01/05/2025
0001 Continuous 0259
Work scheduled by: ConEd

SPR/DUN-SOUTH
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

3800 MW

SPRNBK_345KV_RNS3

Sat 01/04/2025 to Sun 01/05/2025
0001 Continuous 0259
Work scheduled by: ConEd

SPR/DUN-SOUTH
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

3800 MW

SPRNBK_DUNWODIE_345_W75

Sat 01/04/2025 to Sun 01/05/2025
0001 Continuous 0259
Work scheduled by: ConEd

SPR/DUN-SOUTH
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

3800 MW

NRTH1385-NOR HBR_138_601

Mon 01/06/2025 to Fri 01/10/2025
0500 Continuous 1500
Work scheduled by: LI

SCH - NPX_1385
Impacts Total Transfer Capability 100 MW 100 MW
TTC with All Lines In Service 200 MW 200 MW

FWD (Import) REV (Export)

100 MW

100 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits		Tuesday, December 31, 2024 to Tuesday, June 30, 2026				
CENTRAL EAST	7550 MW	The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.				
CENTRAL EAST - VC	3725 MW					
TOTAL EAST	6150 MW					
UPNY CONED	8050 MW					
SPR/DUN-SOUTH	4600 MW					
DYSINGER EAST	3200 MW					
MOSES SOUTH	3150 MW					
NRTH1385-NOR HBR_138_602					FWD (Import)	REV (Export)
Mon 01/06/2025	to	Fri 01/10/2025	SCH - NPX_1385	100 MW	100 MW	
0500	Continuous	1500	Impacts Total Transfer Capability	100 MW	100 MW	
Work scheduled by: LI			TTC with All Lines In Service	200 MW	200 MW	
NRTH1385-NOR HBR_138_603					FWD (Import)	REV (Export)
Mon 01/06/2025	to	Fri 01/10/2025	SCH - NPX_1385	100 MW	100 MW	
0500	Continuous	1500	Impacts Total Transfer Capability	100 MW	100 MW	
Work scheduled by: LI			TTC with All Lines In Service	200 MW	200 MW	
NRTH1385-NORHBR_138_601 , NRTH1385-NORHBR_138_602					FWD (Import)	REV (Export)
Mon 01/06/2025	to	Fri 01/10/2025	SCH - NPX_1385	0 MW	0 MW	
0500		1500	Impacts Total Transfer Capability	200 MW	200 MW	
Work scheduled by:			TTC with All Lines In Service	200 MW	200 MW	
NRTH1385-NORHBR_138_601 , NRTH1385-NORHBR_138_603					FWD (Import)	REV (Export)
Mon 01/06/2025	to	Fri 01/10/2025	SCH - NPX_1385	0 MW	0 MW	
0500		1500	Impacts Total Transfer Capability	200 MW	200 MW	
Work scheduled by:			TTC with All Lines In Service	200 MW	200 MW	
NRTH1385-NORHBR_138_603 , NRTH1385-NORHBR_138_602					FWD (Import)	REV (Export)
Mon 01/06/2025	to	Fri 01/10/2025	SCH - NPX_1385	0 MW	0 MW	
0500		1500	Impacts Total Transfer Capability	200 MW	200 MW	
Work scheduled by:			TTC with All Lines In Service	200 MW	200 MW	
NRTH1385-NRTHPORT_138_NNC					FWD (Import)	REV (Export)
Mon 01/06/2025	to	Fri 01/10/2025	SCH - NPX_1385	0 MW	0 MW	
0500	Continuous	1500	Impacts Total Transfer Capability	200 MW	200 MW	
Work scheduled by: LI			TTC with All Lines In Service	200 MW	200 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, December 31, 2024 to Tuesday, June 30, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ADIRNDCK-PORTER_230_12

Mon 01/06/2025 to Sat 05/31/2025
0530 Continuous 1700
Work scheduled by: NGrid

MOSES SOUTH
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

FWD (Import) REV (Export)

ELBRIDGE-LAFAYTTE_345_17-LE

Mon 01/06/2025 to Mon 01/06/2025
0630 Continuous 0800
Work scheduled by: NGrid

ARR: 75

OSWEGO EXPORT
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 5250 MW

FWD (Import) REV (Export)

OSWEGO_-ELBRIDGE_345_17

Mon 01/06/2025 to Fri 01/31/2025
0630 Continuous 1730
Work scheduled by: NGrid

ARR: 75

OSWEGO EXPORT
Impacts Total Transfer Capability 0 MW
TTC with All Lines In Service 5250 MW

FWD (Import) REV (Export)

MOSES_-ADIRNDCK_230_MA1

Tue 01/07/2025 to Tue 01/07/2025
0600 Continuous 2230
Work scheduled by: NYPA

MOSES SOUTH
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

FWD (Import) REV (Export)

DUNWODIE_345KV_6

Thu 01/09/2025 to Tue 01/14/2025
0001 Continuous 2200
Work scheduled by: ConEd

CANCELLED by TO 12/30/2024 11:26

SPR/DUN-SOUTH
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

DUNWODIE_345KV_8

Thu 01/09/2025 to Tue 01/14/2025
0001 Continuous 2200
Work scheduled by: ConEd

CANCELLED by TO 12/30/2024 11:26

SPR/DUN-SOUTH
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, December 31, 2024 to Tuesday, June 30, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

WOOD_ST_PLSNTVLE_345_Y87

Thu 01/09/2025 to Tue 01/14/2025
0001 Continuous 2200
Work scheduled by: ConEd

CANCELLED by TO 12/30/2024 11:26

UPNY CONED
Impacts Total Transfer Capability 580 MW
TTC with All Lines In Service 8050 MW

FWD (Import) REV (Export)

7470 MW

CHAT_DC_GC1

Mon 01/13/2025 to Mon 01/13/2025
0600 Continuous 0700
Work scheduled by: HQ

MOSES SOUTH
Impacts Total Transfer Capability 300 MW
TTC with All Lines In Service 3150 MW

FWD (Import) REV (Export)

2850 MW

CHAT_DC_GC1

Mon 01/13/2025 to Mon 01/13/2025
0600 Continuous 0700
Work scheduled by: HQ

SCH - HQ - NY
Impacts Total Transfer Capability 500 MW
TTC with All Lines In Service 1000 MW

FWD (Import) REV (Export)

500 MW

CHAT_DC_GC1 , CHAT_DC_GC2

Mon 01/13/2025 to Mon 01/13/2025
0600 0700
Work scheduled by:

MOSES SOUTH
Impacts Total Transfer Capability 600 MW
TTC with All Lines In Service 3150 MW

FWD (Import) REV (Export)

2550 MW

CHAT_DC_GC1 , CHAT_DC_GC2

Mon 01/13/2025 to Mon 01/13/2025
0600 0700
Work scheduled by:

SCH - HQ - NY
Impacts Total Transfer Capability 130 MW 1000 MW
TTC with All Lines In Service 1500 MW 1000 MW

FWD (Import) REV (Export)

1370 MW

0 MW

CHAT_DC_GC2

Mon 01/13/2025 to Mon 01/13/2025
0600 Continuous 0700
Work scheduled by: HQ

MOSES SOUTH
Impacts Total Transfer Capability 300 MW
TTC with All Lines In Service 3150 MW

FWD (Import) REV (Export)

2850 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits		Tuesday, December 31, 2024 to Tuesday, June 30, 2026			
CENTRAL EAST	7550 MW	The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.			
CENTRAL EAST - VC	3725 MW				
TOTAL EAST	6150 MW				
UPNY CONED	8050 MW				
SPR/DUN-SOUTH	4600 MW				
DYSINGER EAST	3200 MW				
MOSES SOUTH	3150 MW				
CHAT_DC_GC2			FWD (Import)	REV (Export)	
Mon 01/13/2025	to Mon 01/13/2025	SCH - HQ - NY		500 MW	
0600	Continuous 0700	Impacts Total Transfer Capability		500 MW	
Work scheduled by: HQ		TTC with All Lines In Service		1000 MW	
SCH-HQ-NYISO_LIMIT_600			FWD (Import)	REV (Export)	
Mon 01/13/2025	to Mon 01/13/2025	SCH - HQ - NY		600 MW	
0600	Continuous 0700	Impacts Total Transfer Capability		900 MW	
Work scheduled by: HQ		TTC with All Lines In Service		1500 MW	
CHAT_DC_GC1			FWD (Import)	REV (Export)	
Tue 01/14/2025	to Tue 01/14/2025	MOSES SOUTH		2850 MW	
1700	Continuous 1859	Impacts Total Transfer Capability		300 MW	
Work scheduled by: HQ		TTC with All Lines In Service		3150 MW	
CHAT_DC_GC1			FWD (Import)	REV (Export)	
Tue 01/14/2025	to Tue 01/14/2025	SCH - HQ - NY		500 MW	
1700	Continuous 1859	Impacts Total Transfer Capability		500 MW	
Work scheduled by: HQ		TTC with All Lines In Service		1000 MW	
CHAT_DC_GC1 , CHAT_DC_GC2			FWD (Import)	REV (Export)	
Tue 01/14/2025	to Tue 01/14/2025	MOSES SOUTH		2550 MW	
1700	1859	Impacts Total Transfer Capability		600 MW	
Work scheduled by:		TTC with All Lines In Service		3150 MW	
CHAT_DC_GC1 , CHAT_DC_GC2			FWD (Import)	REV (Export)	
Tue 01/14/2025	to Tue 01/14/2025	SCH - HQ - NY		1370 MW	
1700	1859	Impacts Total Transfer Capability		130 MW	
Work scheduled by:		TTC with All Lines In Service		1000 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits		Tuesday, December 31, 2024 to Tuesday, June 30, 2026			
CENTRAL EAST	7550 MW	The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.			
CENTRAL EAST - VC	3725 MW				
TOTAL EAST	6150 MW				
UPNY CONED	8050 MW				
SPR/DUN-SOUTH	4600 MW				
DYSINGER EAST	3200 MW				
MOSES SOUTH	3150 MW				
CHAT_DC_GC2				FWD (Import)	REV (Export)
Tue 01/14/2025	to	Tue 01/14/2025	MOSES SOUTH	2850 MW	
1700	Continuous	1859	Impacts Total Transfer Capability	300 MW	
Work scheduled by: HQ			TTC with All Lines In Service	3150 MW	
CHAT_DC_GC2				FWD (Import)	REV (Export)
Tue 01/14/2025	to	Tue 01/14/2025	SCH - HQ - NY	500 MW	
1700	Continuous	1859	Impacts Total Transfer Capability	500 MW	
Work scheduled by: HQ			TTC with All Lines In Service	1000 MW	
SCH-HQ-NYISO_LIMIT_600				FWD (Import)	REV (Export)
Tue 01/14/2025	to	Tue 01/14/2025	SCH - HQ - NY	600 MW	
1700	Continuous	1859	Impacts Total Transfer Capability	900 MW	
Work scheduled by: HQ			TTC with All Lines In Service	1500 MW	
BUCHAN_S-MILLWOOD_345_W97				FWD (Import)	REV (Export)
Wed 01/15/2025	to	Sat 01/18/2025	UPNY CONED	8015 MW	
0200	Continuous	0159	Impacts Total Transfer Capability	35 MW	
Work scheduled by: ConEd			TTC with All Lines In Service	8050 MW	
BUCHAN_S-MILLWOOD_345_W98				FWD (Import)	REV (Export)
Sat 01/18/2025	to	Tue 01/21/2025	UPNY CONED	8015 MW	
0200	Continuous	0200	Impacts Total Transfer Capability	35 MW	
Work scheduled by: ConEd			TTC with All Lines In Service	8050 MW	
KNICRBKR-ALPS___345_6				FWD (Import)	REV (Export)
Mon 01/20/2025	to	Tue 01/21/2025	SCH - NE - NY	900 MW	
0530	Continuous	1830	Impacts Total Transfer Capability	500 MW	
Work scheduled by: NGrid			TTC with All Lines In Service	1400 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, December 31, 2024 to Tuesday, June 30, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

KNICRBKR-ALPS___345_6

Mon 01/20/2025 to Tue 01/21/2025
0530 Continuous 1830
Work scheduled by: NGrid

SCH - NPX_1385

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

100 MW 100 MW

100 MW 100 MW

200 MW 200 MW

RAMAPO_-BUCHAN_N_345_Y94

Wed 01/22/2025 to Wed 01/22/2025
0001 Continuous 0030
Work scheduled by: ConEd

UPNY CONED

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

7755 MW

295 MW

8050 MW

RAMAPO_-BUCHAN_N_345_Y94

Sat 01/25/2025 to Sat 01/25/2025
2130 Continuous 2200
Work scheduled by: ConEd

UPNY CONED

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

7755 MW

295 MW

8050 MW

DUNWODIE_345KV_7

Sun 01/26/2025 to Sun 02/02/2025
0001 Continuous 2200
Work scheduled by: ConEd

UPDATED by ConEd 11/22/2024 08:59

SPR/DUN-SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

3800 MW

800 MW

4600 MW

DUNWODIE_345KV_8

Sun 01/26/2025 to Sun 02/02/2025
0001 Continuous 2200
Work scheduled by: ConEd

UPDATED by ConEd 11/22/2024 08:59

SPR/DUN-SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

3800 MW

800 MW

4600 MW

DUNWODIE-MOTTHAVN_345_72

Sun 01/26/2025 to Sun 02/02/2025
0001 Continuous 2200
Work scheduled by: ConEd

UPDATED by ConEd 11/22/2024 08:59

SPR/DUN-SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

3800 MW

800 MW

4600 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits		Tuesday, December 31, 2024 to Tuesday, June 30, 2026					
CENTRAL EAST	7550 MW	<div>The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.</div>					
CENTRAL EAST - VC	3725 MW						
TOTAL EAST	6150 MW						
UPNY CONED	8050 MW						
SPR/DUN-SOUTH	4600 MW						
DYSINGER EAST	3200 MW						
MOSES SOUTH	3150 MW						
<hr/>							
ELBRIDGE-LAFAYTTE_345_17-LE						FWD (Import)	REV (Export)
Mon 01/27/2025	to	Fri 01/31/2025			OSWEGO EXPORT	5250 MW	
0700	Continuous	1730	ARR: 75		Impacts Total Transfer Capability	0 MW	
Work scheduled by: NGrid					TTC with All Lines In Service	5250 MW	
<hr/>							
HOPATCON-RAMAPO__500_5018						FWD (Import)	REV (Export)
Tue 01/28/2025	to	Sat 02/01/2025			SCH - PJ - NY	1400 MW	1200 MW
0001	Continuous	0200			Impacts Total Transfer Capability	1200 MW	1500 MW
Work scheduled by: PJM					TTC with All Lines In Service	2600 MW	2700 MW
<hr/>							
HOPATCON-RAMAPO__500_5018						FWD (Import)	REV (Export)
Tue 01/28/2025	to	Sat 02/01/2025			UPNY CONED	7795 MW	
0001	Continuous	0200			Impacts Total Transfer Capability	255 MW	
Work scheduled by: PJM					TTC with All Lines In Service	8050 MW	
<hr/>							
HOPATCON-RAMAPO__500_5018						FWD (Import)	REV (Export)
Tue 01/28/2025	to	Sat 02/01/2025			TOTAL EAST	6800 MW	
0001	Continuous	0200			Impacts Total Transfer Capability	-650 MW	
Work scheduled by: PJM					TTC with All Lines In Service	6150 MW	
<hr/>							
RAMAPO__345_345_PAR3500						FWD (Import)	REV (Export)
Tue 01/28/2025	to	Sat 02/01/2025			SCH - PJ - NY	2550 MW	1250 MW
0001	Continuous	0200			Impacts Total Transfer Capability	50 MW	1450 MW
Work scheduled by: PJM					TTC with All Lines In Service	2600 MW	2700 MW
<hr/>							
RAMAPO__345_345_PAR4500						FWD (Import)	REV (Export)
Tue 01/28/2025	to	Sat 02/01/2025			SCH - PJ - NY	2550 MW	1250 MW
0001	Continuous	0200			Impacts Total Transfer Capability	50 MW	1450 MW
Work scheduled by: PJM					TTC with All Lines In Service	2600 MW	2700 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits		Tuesday, December 31, 2024 to Tuesday, June 30, 2026				
CENTRAL EAST	7550 MW		The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.			
CENTRAL EAST - VC	3725 MW					
TOTAL EAST	6150 MW					
UPNY CONED	8050 MW					
SPR/DUN-SOUTH	4600 MW					
DYSINGER EAST	3200 MW					
MOSES SOUTH	3150 MW					
<hr/>				FWD (Import)	REV (Export)	
RAMAPO__500_345_BK 1500						
Tue 01/28/2025	to	Sat 02/01/2025	SCH - PJ - NY	1400 MW	1200 MW	
0001	Continuous	0200	Impacts Total Transfer Capability	1200 MW	1500 MW	
Work scheduled by: PJM			TTC with All Lines In Service	2600 MW	2700 MW	
<hr/>				FWD (Import)	REV (Export)	
RAMAPO__500_345_BK 1500						
Tue 01/28/2025	to	Sat 02/01/2025	UPNY CONED	7795 MW		
0001	Continuous	0200	Impacts Total Transfer Capability	255 MW		
Work scheduled by: PJM			TTC with All Lines In Service	8050 MW		
<hr/>				FWD (Import)	REV (Export)	
BECK__-NIAGARA_345_PA301						
Tue 02/04/2025	to	Tue 02/04/2025	SCH - OH - NY	1150 MW	1000 MW	
0500	Continuous	2100	Impacts Total Transfer Capability	1350 MW	850 MW	
Work scheduled by: NYPA			TTC with All Lines In Service	2500 MW	1850 MW	
<hr/>				FWD (Import)	REV (Export)	
PIERCBRK-FIVEMILE_345_37						
Tue 02/04/2025	to	Tue 02/04/2025	SCH - PJ - NY			
0900	Daily	1030	Impacts Total Transfer Capability			
Work scheduled by: NGrid			TTC with All Lines In Service			
<hr/>				FWD (Import)	REV (Export)	
ROSETON_EFISHKIL_345_RFK305						
Sun 02/09/2025	to	Wed 02/12/2025	UPNY CONED	7215 MW		
0001	Continuous	0200	Impacts Total Transfer Capability	835 MW		
Work scheduled by: ConEd			TTC with All Lines In Service	8050 MW		
<hr/>				FWD (Import)	REV (Export)	
MILLWOOD-EASTVIEW_345_W82						
Mon 02/10/2025	to	Fri 02/14/2025	UPNY CONED	7810 MW		
0001	Continuous	2200	Impacts Total Transfer Capability	240 MW		
Work scheduled by: ConEd			TTC with All Lines In Service	8050 MW		

NYISO TRANSFER LIMITATIONS

Seasonal Limits			Tuesday, December 31, 2024 to Tuesday, June 30, 2026		
CENTRAL EAST	7550 MW		The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.		
CENTRAL EAST - VC	3725 MW				
TOTAL EAST	6150 MW				
UPNY CONED	8050 MW				
SPR/DUN-SOUTH	4600 MW				
DYSINGER EAST	3200 MW				
MOSES SOUTH	3150 MW				
FRASER__345_FRASER SVC				FWD (Import)	REV (Export)
Mon 02/10/2025	to	Fri 02/14/2025	CENTRAL EAST - VC	3655 MW	
0700	Continuous	1500	Impacts Total Transfer Capability	70 MW	
Work scheduled by: NYSEG			TTC with All Lines In Service	3725 MW	
WOOD_ST_PLSNTVLE_345_Y86				FWD (Import)	REV (Export)
Mon 02/17/2025	to	Mon 02/17/2025	UPNY CONED	7475 MW	
0001	Continuous	0030	Impacts Total Transfer Capability	575 MW	
Work scheduled by: ConEd			TTC with All Lines In Service	8050 MW	
BECK__-PACKARD_230_BP76				FWD (Import)	REV (Export)
Thu 02/20/2025	to	Thu 02/20/2025	SCH - OH - NY	1800 MW	1300 MW
0730	Continuous	1630	Impacts Total Transfer Capability	700 MW	550 MW
Work scheduled by: NGrid			TTC with All Lines In Service	2500 MW	1850 MW
WOOD_ST_PLSNTVLE_345_Y86				FWD (Import)	REV (Export)
Fri 02/21/2025	to	Fri 02/21/2025	UPNY CONED	7475 MW	
0130	Continuous	0200	Impacts Total Transfer Capability	575 MW	
Work scheduled by: ConEd			TTC with All Lines In Service	8050 MW	
BERKSHIR-ALPS__345_393				FWD (Import)	REV (Export)
Mon 02/24/2025	to	Mon 02/24/2025	SCH - NPX_1385	100 MW	100 MW
0730	Continuous	1530	Impacts Total Transfer Capability	100 MW	100 MW
Work scheduled by: NGrid			TTC with All Lines In Service	200 MW	200 MW
			ARR: 78		
BERKSHIR-ALPS__345_393				FWD (Import)	REV (Export)
Mon 02/24/2025	to	Mon 02/24/2025	SCH - NE - NY	1100 MW	1600 MW
0730	Continuous	1530	Impacts Total Transfer Capability	300 MW	200 MW
Work scheduled by: NGrid			TTC with All Lines In Service	1400 MW	1800 MW
			ARR: 78		

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, December 31, 2024 to Tuesday, June 30, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK_-TREMONT_345_X28

Fri 02/28/2025 to Tue 03/04/2025
0001 Continuous 0200
Work scheduled by: ConEd

UPDATED by ConEd 12/24/2024 09:22

SPR/DUN-SOUTH
Impacts Total Transfer Capability 400 MW
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

4200 MW

RAMAPO_-BUCHAN_N_345_Y94

Mon 03/03/2025 to Sat 03/08/2025
0001 Continuous 0200
Work scheduled by: ConEd

UPNY CONED
Impacts Total Transfer Capability 295 MW
TTC with All Lines In Service 8050 MW

FWD (Import) REV (Export)

7755 MW

MOTHAVN-RAINEY_345_Q11

Tue 03/04/2025 to Mon 04/14/2025
0201 Continuous 0300
Work scheduled by: ConEd

SPR/DUN-SOUTH
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

3800 MW

MOSES_-ADIRNDCK_230_MA1

Fri 03/14/2025 to Sat 03/29/2025
0700 Continuous 1730
Work scheduled by: NYPA

MOSES SOUTH
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

FWD (Import) REV (Export)

2300 MW

NINEMILE-CLAY_345_8

Mon 03/17/2025 to Mon 03/17/2025
0001 Continuous 0100
Work scheduled by: NGrid

OSWEGO EXPORT
Impacts Total Transfer Capability 100 MW
TTC with All Lines In Service 5250 MW

FWD (Import) REV (Export)

5150 MW

STLAWRNC-MOSES_230_L33P

Mon 03/17/2025 to Fri 03/21/2025
0600 Continuous 1730
Work scheduled by: NYPA

SCH - OH - NY
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

NYISO TRANSFER LIMITATIONS

Seasonal Limits		Tuesday, December 31, 2024 to Tuesday, June 30, 2026				
CENTRAL EAST	7550 MW	The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.				
CENTRAL EAST - VC	3725 MW					
TOTAL EAST	6150 MW					
UPNY CONED	8050 MW					
SPR/DUN-SOUTH	4600 MW					
DYSINGER EAST	3200 MW					
MOSES SOUTH	3150 MW					
<hr/>						
SCRIBA__VOLNEY__345_20					FWD (Import)	REV (Export)
Mon 03/17/2025	to	Mon 03/17/2025		OSWEGO EXPORT	5250 MW	
0700	Daily	1900		Impacts Total Transfer Capability	0 MW	
Work scheduled by: NGrid				TTC with All Lines In Service	5250 MW	
<hr/>						
NINEMILE-CLAY__345_8					FWD (Import)	REV (Export)
Mon 03/17/2025	to	Tue 03/18/2025		OSWEGO EXPORT	5150 MW	
2130	Continuous	2300		Impacts Total Transfer Capability	100 MW	
Work scheduled by: NGrid				TTC with All Lines In Service	5250 MW	
<hr/>						
ROCHESTR-PANNELL__345_RP1					FWD (Import)	REV (Export)
Mon 03/24/2025	to	Tue 03/25/2025	<u>UPDATED by RGE 11/08/2024 10:56</u>	DYSINGER EAST	2300 MW	
0730	Continuous	1500		Impacts Total Transfer Capability	900 MW	
Work scheduled by: NYSEG				TTC with All Lines In Service	3200 MW	
<hr/>						
NINEMILE-CLAY__345_8					FWD (Import)	REV (Export)
Tue 03/25/2025	to	Tue 03/25/2025		OSWEGO EXPORT	5150 MW	
0200	Continuous	0300		Impacts Total Transfer Capability	100 MW	
Work scheduled by: NGrid				TTC with All Lines In Service	5250 MW	
<hr/>						
ROCHESTR-PANNELL__345_RP2					FWD (Import)	REV (Export)
Wed 03/26/2025	to	Thu 03/27/2025	<u>UPDATED by RGE 11/08/2024 10:51</u>	DYSINGER EAST	2300 MW	
0730	Continuous	1500		Impacts Total Transfer Capability	900 MW	
Work scheduled by: RGE				TTC with All Lines In Service	3200 MW	
<hr/>						
NIAGARA_-ROBNSNRD_230_64					FWD (Import)	REV (Export)
Fri 03/28/2025	to	Fri 03/28/2025		SCH - OH - NY		
0500	Continuous	1900		Impacts Total Transfer Capability		
Work scheduled by: NYPA				TTC with All Lines In Service		

NYISO TRANSFER LIMITATIONS

Seasonal Limits		Tuesday, December 31, 2024 to Tuesday, June 30, 2026						
CENTRAL EAST	7550 MW	The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.						
CENTRAL EAST - VC	3725 MW							
TOTAL EAST	6150 MW							
UPNY CONED	8050 MW							
SPR/DUN-SOUTH	4600 MW							
DYSINGER EAST	3200 MW							
MOSES SOUTH	3150 MW							
<hr/>								
BERKSHIR-ALPS___345_393							FWD (Import)	REV (Export)
Mon 03/31/2025	to	Mon 03/31/2025				SCH - NPX_1385	100 MW	100 MW
0700	Continuous	1600				Impacts Total Transfer Capability	100 MW	100 MW
Work scheduled by: NGrid		ARR: 78			TTC with All Lines In Service	200 MW	200 MW	
<hr/>								
BERKSHIR-ALPS___345_393							FWD (Import)	REV (Export)
Mon 03/31/2025	to	Mon 03/31/2025				SCH - NE - NY	1100 MW	1600 MW
0700	Continuous	1600				Impacts Total Transfer Capability	300 MW	200 MW
Work scheduled by: NGrid		ARR: 78			TTC with All Lines In Service	1400 MW	1800 MW	
<hr/>								
BERKSHIR-ALPS___345_393 , BERKSHIR-NORTHFLD_345_312							FWD (Import)	REV (Export)
Mon 03/31/2025	to	Mon 03/31/2025				SCH - NE - NY	1100 MW	1100 MW
0700		1600				Impacts Total Transfer Capability	300 MW	700 MW
Work scheduled by:		ARR: 78			TTC with All Lines In Service	1400 MW	1800 MW	
<hr/>								
BERKSHIR-NORTHFLD_345_312							FWD (Import)	REV (Export)
Mon 03/31/2025	to	Mon 03/31/2025				SCH - NPX_1385	100 MW	100 MW
0700	Continuous	1600				Impacts Total Transfer Capability	100 MW	100 MW
Work scheduled by: NGrid					TTC with All Lines In Service	200 MW	200 MW	
<hr/>								
BERKSHIR-NORTHFLD_345_312							FWD (Import)	REV (Export)
Mon 03/31/2025	to	Mon 03/31/2025				SCH - NE - NY	1300 MW	
0700	Continuous	1600				Impacts Total Transfer Capability	100 MW	
Work scheduled by: NGrid					TTC with All Lines In Service	1400 MW		
<hr/>								
NINEMILE-CLAY___345_8							FWD (Import)	REV (Export)
Wed 04/02/2025	to	Wed 04/02/2025				OSWEGO EXPORT	5150 MW	
1900	Continuous	2000				Impacts Total Transfer Capability	100 MW	
Work scheduled by: NGrid					TTC with All Lines In Service	5250 MW		

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, December 31, 2024 to Tuesday, June 30, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_-DYSINGER_345_ND2

Mon 04/07/2025 to Fri 04/11/2025
0500 Continuous 1730
Work scheduled by: NYPA

DYSINGER EAST
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) 2700 MW
REV (Export) 500 MW
3200 MW

LINDN_CG-LNDVFT__345_V-3022

Mon 04/07/2025 to Sat 04/12/2025
0800 Continuous 1500
Work scheduled by: PJM

SCH - PJM_VFT
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) 0 MW
REV (Export) 0 MW
315 MW
315 MW

RAMAPO_-BUCHAN_N_345_Y94

Sat 04/12/2025 to Sat 04/19/2025
0001 Continuous 0200
Work scheduled by: ConEd

UPNY CONED
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) 7755 MW
REV (Export) 295 MW
8050 MW

SPRNBK_-TREMONT_345_X28

Mon 04/14/2025 to Sun 04/20/2025
0001 Continuous 0200
Work scheduled by: ConEd
UPDATED by ConEd 12/24/2024 09:22

SPR/DUN-SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) 4200 MW
REV (Export) 400 MW
4600 MW

NIAGARA_-DYSINGER_345_ND2

Mon 04/14/2025 to Thu 04/17/2025
0500 Continuous 1730
Work scheduled by: NYPA

DYSINGER EAST
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) 2700 MW
REV (Export) 500 MW
3200 MW

E13THSTA-FARRAGUT_345_45

Tue 04/15/2025 to Sun 04/20/2025
0001 Continuous 0200
Work scheduled by: ConEd

SPR/DUN-SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) 3800 MW
REV (Export) 800 MW
4600 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, December 31, 2024 to Tuesday, June 30, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST-E13THSTA_345_M54

Tue 04/15/2025 to Sun 04/20/2025
0001 Continuous 0200
Work scheduled by: ConEd

SPR/DUN-SOUTH
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

3800 MW

MOSES__-ADIRNDCK_230_MA1

Tue 04/15/2025 to Tue 04/15/2025
0700 Continuous 1530
Work scheduled by: NYPA

MOSES SOUTH
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

FWD (Import) REV (Export)

2300 MW

LINDN_CG-LNDVFT__345_V-3022

Thu 04/17/2025 to Thu 04/17/2025
1500 Continuous 1800
Work scheduled by: PJM

SCH - PJM_VFT
Impacts Total Transfer Capability 315 MW 315 MW
TTC with All Lines In Service 315 MW 315 MW

FWD (Import) REV (Export)

0 MW

0 MW

NIAGARA_-PACKARD_230_61

Mon 04/21/2025 to Fri 04/25/2025
0500 Continuous 1900
Work scheduled by: NYPA

SCH - OH - NY
Impacts Total Transfer Capability 50 MW 50 MW
TTC with All Lines In Service 2500 MW 1850 MW

FWD (Import) REV (Export)

2450 MW

1800 MW

PANNELL_-CLAY__345_1

Mon 04/21/2025 to Fri 04/25/2025
0700 Continuous 1530
Work scheduled by: NYPA

WEST CENTRAL
Impacts Total Transfer Capability 950 MW
TTC with All Lines In Service 2250 MW

FWD (Import) REV (Export)

1300 MW

MOSES__-ADIRNDCK_230_MA2

Tue 04/22/2025 to Tue 04/22/2025
0700 Continuous 1530
Work scheduled by: NYPA

MOSES SOUTH
Impacts Total Transfer Capability 850 MW
TTC with All Lines In Service 3150 MW

FWD (Import) REV (Export)

2300 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits		Tuesday, December 31, 2024 to Tuesday, June 30, 2026					
CENTRAL EAST	7550 MW	The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.					
CENTRAL EAST - VC	3725 MW						
TOTAL EAST	6150 MW						
UPNY CONED	8050 MW						
SPR/DUN-SOUTH	4600 MW						
DYSINGER EAST	3200 MW						
MOSES SOUTH	3150 MW						
MARCY___765_345_AT1						FWD (Import)	REV (Export)
Fri 04/25/2025	to	Fri 04/25/2025			MOSES SOUTH	1750 MW	
0500	Continuous	1730			Impacts Total Transfer Capability	1400 MW	
Work scheduled by: NYPA		ARR: 19			TTC with All Lines In Service	3150 MW	
MARCY___765_345_AT2						FWD (Import)	REV (Export)
Sat 04/26/2025	to	Sat 04/26/2025			MOSES SOUTH	1700 MW	
0500	Continuous	1730			Impacts Total Transfer Capability	1450 MW	
Work scheduled by: NYPA		ARR: 19			TTC with All Lines In Service	3150 MW	
BUCHAN_S-MILLWOOD_345_W97						FWD (Import)	REV (Export)
Mon 04/28/2025	to	Tue 04/29/2025			UPNY CONED	8015 MW	
0001	Continuous	0230			Impacts Total Transfer Capability	35 MW	
Work scheduled by: ConEd					TTC with All Lines In Service	8050 MW	
PANNELL_-CLAY___345_2						FWD (Import)	REV (Export)
Mon 04/28/2025	to	Fri 05/02/2025			WEST CENTRAL	1300 MW	
0700	Continuous	1530			Impacts Total Transfer Capability	950 MW	
Work scheduled by: NYPA					TTC with All Lines In Service	2250 MW	
E13THSTA-FARRAGUT_345_46						FWD (Import)	REV (Export)
Tue 05/06/2025	to	Sat 05/10/2025			SPR/DUN-SOUTH	3800 MW	
0001	Continuous	0200			Impacts Total Transfer Capability	800 MW	
Work scheduled by: ConEd					TTC with All Lines In Service	4600 MW	
LONG_MTN-CRICKVLY_345_398						FWD (Import)	REV (Export)
Tue 05/06/2025	to	Thu 05/29/2025			SCH - NPX_1385	100 MW	100 MW
0001	Continuous	2200			Impacts Total Transfer Capability	100 MW	100 MW
Work scheduled by: ConEd					TTC with All Lines In Service	200 MW	200 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits		Tuesday, December 31, 2024 to Tuesday, June 30, 2026				
CENTRAL EAST	7550 MW	The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.				
CENTRAL EAST - VC	3725 MW					
TOTAL EAST	6150 MW					
UPNY CONED	8050 MW					
SPR/DUN-SOUTH	4600 MW					
DYSINGER EAST	3200 MW					
MOSES SOUTH	3150 MW					
LONG_MTN-CRICKVLY_345_398					FWD (Import)	REV (Export)
Tue 05/06/2025	to	Thu 05/29/2025	SCH - NE - NY	800 MW	1200 MW	
0001	Continuous	2200	Impacts Total Transfer Capability	600 MW	400 MW	
Work scheduled by: ConEd			TTC with All Lines In Service	1400 MW	1600 MW	
W49TH_ST_345KV_6					FWD (Import)	REV (Export)
Tue 05/06/2025	to	Tue 05/06/2025	SCH - PJM_HTP	300 MW		
0001	Continuous	0030	Impacts Total Transfer Capability	360 MW		
Work scheduled by: ConEd			TTC with All Lines In Service	660 MW		
W49TH_ST-E13THSTA_345_M55					FWD (Import)	REV (Export)
Tue 05/06/2025	to	Sat 05/10/2025	SPR/DUN-SOUTH	3800 MW		
0001	Continuous	0200	Impacts Total Transfer Capability	800 MW		
Work scheduled by: ConEd			TTC with All Lines In Service	4600 MW		
WOOD_ST_PLSNTVLE_345_Y87					FWD (Import)	REV (Export)
Wed 05/07/2025	to	Fri 05/09/2025	UPNY CONED	7470 MW		
2200	Continuous	0259	Impacts Total Transfer Capability	580 MW		
Work scheduled by: ConEd			TTC with All Lines In Service	8050 MW		
DUNWODIE_345KV_6					FWD (Import)	REV (Export)
Fri 05/09/2025	to	Fri 05/09/2025	SPR/DUN-SOUTH	3800 MW		
0001	Continuous	0030	Impacts Total Transfer Capability	800 MW		
Work scheduled by: ConEd			TTC with All Lines In Service	4600 MW		
DUNWODIE_345KV_8					FWD (Import)	REV (Export)
Fri 05/09/2025	to	Fri 05/09/2025	SPR/DUN-SOUTH	3800 MW		
0001	Continuous	0030	Impacts Total Transfer Capability	800 MW		
Work scheduled by: ConEd			TTC with All Lines In Service	4600 MW		

NYISO TRANSFER LIMITATIONS

Seasonal Limits		Tuesday, December 31, 2024 to Tuesday, June 30, 2026			
CENTRAL EAST	7550 MW	The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.			
CENTRAL EAST - VC	3725 MW				
TOTAL EAST	6150 MW				
UPNY CONED	8050 MW				
SPR/DUN-SOUTH	4600 MW				
DYSINGER EAST	3200 MW				
MOSES SOUTH	3150 MW				
W49TH_ST_345KV_6				FWD (Import)	REV (Export)
Sat 05/10/2025	to	Sat 05/10/2025	SCH - PJM_HTP	300 MW	
0130	Continuous	0200	Impacts Total Transfer Capability	360 MW	
Work scheduled by: ConEd			TTC with All Lines In Service	660 MW	
DUNWODIE_345KV_6				FWD (Import)	REV (Export)
Sun 05/11/2025	to	Sun 05/11/2025	SPR/DUN-SOUTH	3800 MW	
1830	Continuous	1900	Impacts Total Transfer Capability	800 MW	
Work scheduled by: ConEd			TTC with All Lines In Service	4600 MW	
DUNWODIE_345KV_8				FWD (Import)	REV (Export)
Sun 05/11/2025	to	Sun 05/11/2025	SPR/DUN-SOUTH	3800 MW	
1830	Continuous	1900	Impacts Total Transfer Capability	800 MW	
Work scheduled by: ConEd			TTC with All Lines In Service	4600 MW	
NEPTUNE_DUFFYAVE_345_NEPTUNE				FWD (Import)	REV (Export)
Mon 05/12/2025	to	Fri 05/16/2025	SCH - PJM_NEPTUNE	0 MW	
0600	Continuous	1600	Impacts Total Transfer Capability	660 MW	
Work scheduled by: LI			TTC with All Lines In Service	660 MW	
NEWBRDGE_345_138_BK_1				FWD (Import)	REV (Export)
Mon 05/12/2025	to	Fri 05/16/2025	SCH - PJM_NEPTUNE	375 MW	
0600	Continuous	1600	Impacts Total Transfer Capability	285 MW	
Work scheduled by: LI			TTC with All Lines In Service	660 MW	
NEWBRDGE_345_138_BK_2				FWD (Import)	REV (Export)
Mon 05/12/2025	to	Fri 05/16/2025	SCH - PJM_NEPTUNE	375 MW	
0600	Continuous	1600	Impacts Total Transfer Capability	285 MW	
Work scheduled by: LI			TTC with All Lines In Service	660 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, December 31, 2024 to Tuesday, June 30, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEWBRDGE-DUFFYAVE_345_501

Mon 05/12/2025 to Fri 05/16/2025
0600 Continuous 1600
Work scheduled by: LI

SCH - PJM_NEPTUNE

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

0 MW

660 MW

660 MW

SAND_BAR-PLATSBRG_115_PV20

Mon 07/07/2025 to Fri 07/11/2025
0700 Continuous 1530
Work scheduled by: NYPA

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

0 MW

660 MW

660 MW

SAND_BAR-PLATSBRG_115_PV20

Mon 07/07/2025 to Fri 07/11/2025
0700 Continuous 1530
Work scheduled by: NYPA

CENTRAL EAST - VC

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

3625 MW

100 MW

3725 MW

NIAGARA_345_230_AT4

Tue 07/08/2025 to Tue 07/08/2025
0500 Continuous 1900
Work scheduled by: NYPA

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

1200 MW

400 MW

1600 MW

DYSINGER-STA_255_345_DH1

Tue 09/02/2025 to Mon 09/15/2025
0500 Continuous 2100
Work scheduled by: NYPA

DYSINGER EAST

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

2850 MW

350 MW

3200 MW

GOETHALS_345KV_5

Mon 09/08/2025 to Mon 09/08/2025
0301 Continuous 0330
Work scheduled by: ConEd

STATEN ISLAND

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, December 31, 2024 to Tuesday, June 30, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CLAY__-EDIC__345_2-15

Mon 09/08/2025 to Fri 09/12/2025
0700 Continuous 1530
Work scheduled by: NYPA

OSWEGO EXPORT
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
4850 MW	
400 MW	
5250 MW	

MOSES__-ADIRNDCK_230_MA1

Tue 09/09/2025 to Sun 10/12/2025
0700 Continuous 1730
Work scheduled by: NYPA

MOSES SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
2100 MW	
1050 MW	
3150 MW	

GOETHALS_345KV_5

Tue 09/09/2025 to Tue 09/09/2025
2330 Continuous 2359
Work scheduled by: ConEd

STATEN ISLAND
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)

DUNWODIE_345KV_4

Sat 09/13/2025 to Sun 09/14/2025
0001 Continuous 2200
Work scheduled by: ConEd

UPDATED by ConEd 11/08/2024 12:36

SPR/DUN-SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
3800 MW	
800 MW	
4600 MW	

DUNWODIE_345KV_6

Sat 09/13/2025 to Sun 09/14/2025
0001 Continuous 2200
Work scheduled by: ConEd

UPDATED by ConEd 11/08/2024 12:36

SPR/DUN-SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
3800 MW	
800 MW	
4600 MW	

DUNWODIE-SHORE_RD_345_Y50

Sat 09/13/2025 to Sun 09/14/2025
0001 Continuous 2200
Work scheduled by: ConEd

UPDATED by ConEd 11/08/2024 12:36

CONED - LIPA
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import)	REV (Export)
800 MW	
700 MW	
1500 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits		Tuesday, December 31, 2024 to Tuesday, June 30, 2026				
CENTRAL EAST	7550 MW	The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.				
CENTRAL EAST - VC	3725 MW					
TOTAL EAST	6150 MW					
UPNY CONED	8050 MW					
SPR/DUN-SOUTH	4600 MW					
DYSINGER EAST	3200 MW					
MOSES SOUTH	3150 MW					
<hr/>						
SHORE_RD_345_138_BK 1					FWD (Import)	REV (Export)
Sat 09/13/2025	to	Sun 09/14/2025	<u>UPDATED by ConEd 11/08/2024 12:36</u>	CONED - LIPA	1350 MW	
0001	Continuous	2200		Impacts Total Transfer Capability	150 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	1500 MW	
<hr/>						
SHORE_RD_345_138_BK 2					FWD (Import)	REV (Export)
Sat 09/13/2025	to	Sun 09/14/2025	<u>UPDATED by ConEd 11/08/2024 12:36</u>	CONED - LIPA	1350 MW	
0001	Continuous	2200		Impacts Total Transfer Capability	150 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	1500 MW	
<hr/>						
SPRNBK_345KV_RNS4					FWD (Import)	REV (Export)
Mon 09/15/2025	to	Thu 10/02/2025		SPR/DUN-SOUTH	3200 MW	
0001	Continuous	0200		Impacts Total Transfer Capability	1400 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	4600 MW	
<hr/>						
SPRNBK_-W49TH_ST_345_M52					FWD (Import)	REV (Export)
Mon 09/15/2025	to	Thu 10/02/2025		SPR/DUN-SOUTH	3200 MW	
0001	Continuous	0200		Impacts Total Transfer Capability	1400 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	4600 MW	
<hr/>						
W49TH_ST_345KV_5					FWD (Import)	REV (Export)
Mon 09/15/2025	to	Mon 09/15/2025		SCH - PJM_HTP	460 MW	
0001	Continuous	0030		Impacts Total Transfer Capability	200 MW	
Work scheduled by: ConEd				TTC with All Lines In Service	660 MW	
<hr/>						
GOETHALS_345KV_5					FWD (Import)	REV (Export)
Mon 09/15/2025	to	Mon 09/15/2025		STATEN ISLAND		
0230	Continuous	0300		Impacts Total Transfer Capability		
Work scheduled by: ConEd				TTC with All Lines In Service		

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, December 31, 2024 to Tuesday, June 30, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

ADIRNDCK-PORTER__230_12

Mon 09/15/2025 to Sun 10/12/2025
0600 Continuous 1700
Work scheduled by: NGrid

MOSES SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) **2100 MW**
REV (Export) 1050 MW
3150 MW

DYSINGER-STA_255_345_DH2

Tue 09/16/2025 to Tue 10/28/2025
0500 Continuous 1900
Work scheduled by: NYPA

DYSINGER EAST
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) **2850 MW**
REV (Export) 350 MW
3200 MW

MARCY__FRASANNX_345_UCC2-41

Mon 09/22/2025 to Mon 10/06/2025
0700 Continuous 1730
Work scheduled by: NYPA
ARR: 19

CENTRAL EAST - VC
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) **3225 MW**
REV (Export) 500 MW
3725 MW

PANNELL_-CLAY___345_1

Mon 09/29/2025 to Fri 10/03/2025
0700 Continuous 1530
Work scheduled by: NYPA

WEST CENTRAL
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) **1300 MW**
REV (Export) 950 MW
2250 MW

W49TH_ST_345KV_5

Thu 10/02/2025 to Thu 10/02/2025
0130 Continuous 0200
Work scheduled by: ConEd

SCH - PJM_HTP
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) **460 MW**
REV (Export) 200 MW
660 MW

PANNELL_-CLAY___345_2

Mon 10/06/2025 to Fri 10/10/2025
0700 Continuous 1530
Work scheduled by: NYPA

WEST CENTRAL
Impacts Total Transfer Capability
TTC with All Lines In Service
FWD (Import) **1300 MW**
REV (Export) 950 MW
2250 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, December 31, 2024 to Tuesday, June 30, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEPTUNE_DUFFYAVE_345_NEPTUNE

Mon 10/13/2025 to Thu 10/16/2025
0600 Continuous 1600
Work scheduled by: LI

SCH - PJM_NEPTUNE
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
0 MW
660 MW
660 MW

NEWBRDGE_345_138_BK_1

Mon 10/13/2025 to Thu 10/16/2025
0600 Continuous 1600
Work scheduled by: LI

SCH - PJM_NEPTUNE
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
375 MW
285 MW
660 MW

NEWBRDGE_345_138_BK_2

Mon 10/13/2025 to Thu 10/16/2025
0600 Continuous 1600
Work scheduled by: LI

SCH - PJM_NEPTUNE
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
375 MW
285 MW
660 MW

NEWBRDGE-DUFFYAVE_345_501

Mon 10/13/2025 to Thu 10/16/2025
0600 Continuous 1600
Work scheduled by: LI

SCH - PJM_NEPTUNE
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
0 MW
660 MW
660 MW

MOSES__ADIRNDCK_230_MA2

Mon 10/13/2025 to Mon 11/24/2025
0700 Continuous 1730
Work scheduled by: NYPA

MOSES SOUTH
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
2100 MW
1050 MW
3150 MW

EDIC__PRINCTWN_345_351

Tue 10/14/2025 to Fri 10/17/2025
0600 Continuous 1830
Work scheduled by: NGrid

CENTRAL EAST - VC
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
3335 MW
390 MW
3725 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, December 31, 2024 to Tuesday, June 30, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBK_-TREMONT_345_X28

Mon 10/27/2025 to Fri 10/31/2025
0001 Continuous 1800
Work scheduled by: ConEd

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	4200 MW	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	4600 MW	

CHATGUAY-MASSENA_765_7040

Sun 11/16/2025 to Sun 11/30/2025
0001 Continuous 2359
Work scheduled by: NYPA

SCH - HQ - NY	FWD (Import)	REV (Export)
	0 MW	0 MW
Impacts Total Transfer Capability	1500 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

CHATGUAY-MASSENA_765_7040

Sun 11/16/2025 to Sun 11/30/2025
0001 Continuous 2359
Work scheduled by: NYPA

MOSES SOUTH	FWD (Import)	REV (Export)
	1550 MW	
Impacts Total Transfer Capability	1600 MW	
TTC with All Lines In Service	3150 MW	

MOSES_-ADIRNDCK_230_MA2 , MOSES_-MASSENA_230_MMS2 , MOSES_-MASSENA_230_MMS1

Sun 11/16/2025 to Mon 11/24/2025
0001 1730
Work scheduled by:

SCH - HQ_CEDARS	FWD (Import)	REV (Export)
	90 MW	
Impacts Total Transfer Capability	189 MW	
TTC with All Lines In Service	279 MW	

MOSES_-MASSENA_230_MMS2 , MOSES_-MASSENA_230_MMS1

Sun 11/16/2025 to Sun 11/30/2025
0001 2359
Work scheduled by:

SCH - HQ_CEDARS	FWD (Import)	REV (Export)
	90 MW	
Impacts Total Transfer Capability	189 MW	
TTC with All Lines In Service	279 MW	

MOSES_-MASSENA_230_MMS2 , MOSES_-MASSENA_230_MMS1

Sun 11/16/2025 to Sun 11/30/2025
0001 2359
Work scheduled by:

SCH - HQ - NY	FWD (Import)	REV (Export)
	850 MW	0 MW
Impacts Total Transfer Capability	650 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, December 31, 2024 to Tuesday, June 30, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOTTHAVN-RAINEY__345_Q11

Mon 12/01/2025 to Tue 12/02/2025
0001 Continuous 0230
Work scheduled by: ConEd

SPR/DUN-SOUTH
Impacts Total Transfer Capability 800 MW
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

GOETHALS_345KV_5

Sat 01/17/2026 to Sat 01/17/2026
0301 Continuous 0330
Work scheduled by: ConEd

UPDATED by ConEd 07/10/2024 16:09

STATEN ISLAND
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

DYSINGER-STA_255_345_DH2

Mon 03/02/2026 to Fri 03/13/2026
0500 Continuous 1900
Work scheduled by: NYPA

DYSINGER EAST
Impacts Total Transfer Capability 350 MW
TTC with All Lines In Service 3200 MW

FWD (Import) REV (Export)

DYSINGER-STA_255_345_DH1

Mon 03/16/2026 to Tue 04/07/2026
0500 Continuous 2100
Work scheduled by: NYPA

DYSINGER EAST
Impacts Total Transfer Capability 350 MW
TTC with All Lines In Service 3200 MW

FWD (Import) REV (Export)

DYSINGER-STA_255_345_DH2

Wed 04/08/2026 to Mon 04/20/2026
0500 Continuous 2100
Work scheduled by: NYPA

DYSINGER EAST
Impacts Total Transfer Capability 350 MW
TTC with All Lines In Service 3200 MW

FWD (Import) REV (Export)

DYSINGER-STA_255_345_DH1

Tue 04/21/2026 to Fri 05/01/2026
0500 Continuous 2100
Work scheduled by: NYPA

DYSINGER EAST
Impacts Total Transfer Capability 350 MW
TTC with All Lines In Service 3200 MW

FWD (Import) REV (Export)

NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, December 31, 2024 to Tuesday, June 30, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

GOETHALS_345KV_5

Sat 04/25/2026 to Sat 04/25/2026
2330 Continuous 2359
Work scheduled by: ConEd

UPDATED by ConEd 07/10/2024 16:09

STATEN ISLAND
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

GOETHALS_345KV_5

Mon 04/27/2026 to Mon 04/27/2026
0001 Continuous 0030
Work scheduled by: ConEd

UPDATED by ConEd 07/10/2024 16:09

STATEN ISLAND
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

GOETHALS_345KV_5

Tue 05/05/2026 to Tue 05/05/2026
0230 Continuous 0300
Work scheduled by: ConEd

UPDATED by ConEd 07/10/2024 16:09

STATEN ISLAND
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)

NEPTUNE_DUFFYAVE_345_NEPTUNE

Mon 05/11/2026 to Fri 05/15/2026
0600 Continuous 1600
Work scheduled by: LI

SCH - PJM_NEPTUNE
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
0 MW
660 MW
660 MW

NEWBRDGE_345_138_BK_1

Mon 05/11/2026 to Fri 05/15/2026
0600 Continuous 1600
Work scheduled by: LI

SCH - PJM_NEPTUNE
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
375 MW
285 MW
660 MW

NEWBRDGE_345_138_BK_2

Mon 05/11/2026 to Fri 05/15/2026
0600 Continuous 1600
Work scheduled by: LI

SCH - PJM_NEPTUNE
Impacts Total Transfer Capability
TTC with All Lines In Service

FWD (Import) REV (Export)
375 MW
285 MW
660 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits		Tuesday, December 31, 2024 to Tuesday, June 30, 2026			
CENTRAL EAST	7550 MW	<div>The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.</div>			
CENTRAL EAST - VC	3725 MW				
TOTAL EAST	6150 MW				
UPNY CONED	8050 MW				
SPR/DUN-SOUTH	4600 MW				
DYSINGER EAST	3200 MW				
MOSES SOUTH	3150 MW				
NEWBRDGE-DUFFYAVE_345_501				FWD (Import)	REV (Export)
Mon 05/11/2026	to	Fri 05/15/2026	SCH - PJM_NEPTUNE	0 MW	
0600	Continuous	1600	Impacts Total Transfer Capability	660 MW	
Work scheduled by: LI			TTC with All Lines In Service	660 MW	