

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Tuesday, January 21, 2025 to Monday, July 20, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### HUDSONP\_-FARRAGUT\_345\_B3402

Mon 01/15/2018 to Thu 05/01/2025  
0001 Continuous 0100  
Work scheduled by: ConEd

EXT FORCED by ConEd 03/11/2024 11:26

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### MARION\_-FARRAGUT\_345\_C3403

Mon 01/15/2018 to Thu 05/01/2025  
0001 Continuous 0100  
Work scheduled by: ConEd

EXT FORCED by ConEd 03/11/2024 11:26

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### MARION\_-FARRAGUT\_345\_C3403 , HUDSONP\_-FARRAGUT\_345\_B3402

Mon 01/15/2018 to Thu 05/01/2025  
0001 0100  
Work scheduled by:

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>2400 MW</b>	<b>2400 MW</b>
200 MW	300 MW
2600 MW	2700 MW

### MARCY\_\_\_345KV\_CSC

Sat 06/15/2024 to Sat 05/24/2025  
0001 Continuous 2359  
Work scheduled by: NYPA

FORCED by NYPA 06/11/2024 15:44

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>3650 MW</b>	
75 MW	
3725 MW	

### MARCY\_\_\_765\_345\_AT1

Mon 10/14/2024 to Fri 02/14/2025  
2110 Continuous 2359  
Work scheduled by: NYPA

EXT FORCED by NYPA 01/16/2025 08:31

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>1750 MW</b>	
1400 MW	
3150 MW	

### SCH-IMO-NYISO\_LIMIT\_1900

Fri 11/01/2024 to Wed 04/30/2025  
0001 Continuous 2359  
Work scheduled by: IESO

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>2200 MW</b>	
300 MW	
2500 MW	



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Tuesday, January 21, 2025 to Monday, July 20, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### S.RIPLEY-DUNKIRK\_230\_68

Fri 11/08/2024 to Fri 01/31/2025  
1113 Continuous 1800  
Work scheduled by: PJM

EXT FORCED by NGrid 11/13/2024 16:46

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### W49TH\_ST\_345KV\_6

Fri 01/03/2025 to Sun 02/09/2025  
0001 Continuous 0200  
Work scheduled by: ConEd

UPDATED by ConEd 01/21/2025 16:11

SCH - PJM\_HTP  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**300 MW**  
360 MW  
660 MW

### W49TH\_ST-E13THSTA\_345\_M55

Fri 01/03/2025 to Sun 02/09/2025  
0001 Continuous 0200  
Work scheduled by: ConEd

UPDATED by ConEd 01/21/2025 16:11

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**3800 MW**  
800 MW  
4600 MW

### SCH-PJM-NYISO\_LIMIT\_1400

Wed 01/08/2025 to Wed 02/05/2025  
0001 Continuous 2359  
Work scheduled by: NYISO

EXT FORCED by NYISO 01/21/2025 15:26

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**1700 MW**  
900 MW  
2600 MW

### W49TH\_ST\_345KV\_8

Thu 01/09/2025 to Sun 01/26/2025  
0201 Continuous 2359  
Work scheduled by: ConEd

UPDATED by ConEd 01/21/2025 16:11

SCH - PJM\_HTP  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**310 MW**  
350 MW  
660 MW

### BUCHAN\_S-MILLWOOD\_345\_W98

Sun 01/19/2025 to Tue 01/21/2025  
0201 Continuous 0200  
Work scheduled by: ConEd

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**8015 MW**  
35 MW  
8050 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Tuesday, January 21, 2025 to Monday, July 20, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### ADIRNDCK-PORTER\_\_230\_12

Thu 01/23/2025 to Sat 05/31/2025  
0530 Continuous 1700  
Work scheduled by: NGrid

UPDATED by NGrid 01/17/2025 09:10

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**2300 MW**  
850 MW  
3150 MW

### DUNWODIE\_345KV\_7

Sun 01/26/2025 to Sun 02/02/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

UPDATED by ConEd 11/22/2024 08:59

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3800 MW**  
800 MW  
4600 MW

### DUNWODIE\_345KV\_8

Sun 01/26/2025 to Sun 02/02/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

UPDATED by ConEd 11/22/2024 08:59

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3800 MW**  
800 MW  
4600 MW

### DUNWODIE-MOTTHAVN\_345\_72

Sun 01/26/2025 to Sun 02/02/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

UPDATED by ConEd 11/22/2024 08:59

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3800 MW**  
800 MW  
4600 MW

### HOPATCON-RAMAPO\_\_500\_5018

Tue 01/28/2025 to Sat 02/01/2025  
0001 Continuous 0200  
Work scheduled by: PJM

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1400 MW 1200 MW**  
1200 MW 1500 MW  
2600 MW 2700 MW

### HOPATCON-RAMAPO\_\_500\_5018

Tue 01/28/2025 to Sat 02/01/2025  
0001 Continuous 0200  
Work scheduled by: PJM

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**7795 MW**  
255 MW  
8050 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Tuesday, January 21, 2025 to Monday, July 20, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### HOPATCON-RAMAPO\_\_500\_5018

Tue 01/28/2025 to Sat 02/01/2025  
0001 Continuous 0200  
Work scheduled by: PJM

TOTAL EAST	FWD (Import)	REV (Export)
	<b>6800 MW</b>	
Impacts Total Transfer Capability	-650 MW	
TTC with All Lines In Service	6150 MW	

### RAMAPO\_\_345\_345\_PAR3500

Tue 01/28/2025 to Sat 02/01/2025  
0001 Continuous 0200  
Work scheduled by: PJM

SCH - PJ - NY	FWD (Import)	REV (Export)
	<b>2550 MW</b>	<b>1250 MW</b>
Impacts Total Transfer Capability	50 MW	1450 MW
TTC with All Lines In Service	2600 MW	2700 MW

### RAMAPO\_\_345\_345\_PAR4500

Tue 01/28/2025 to Sat 02/01/2025  
0001 Continuous 0200  
Work scheduled by: PJM

SCH - PJ - NY	FWD (Import)	REV (Export)
	<b>2550 MW</b>	<b>1250 MW</b>
Impacts Total Transfer Capability	50 MW	1450 MW
TTC with All Lines In Service	2600 MW	2700 MW

### RAMAPO\_\_500\_345\_BK 1500

Tue 01/28/2025 to Sat 02/01/2025  
0001 Continuous 0200  
Work scheduled by: PJM

SCH - PJ - NY	FWD (Import)	REV (Export)
	<b>1400 MW</b>	<b>1200 MW</b>
Impacts Total Transfer Capability	1200 MW	1500 MW
TTC with All Lines In Service	2600 MW	2700 MW

### RAMAPO\_\_500\_345\_BK 1500

Tue 01/28/2025 to Sat 02/01/2025  
0001 Continuous 0200  
Work scheduled by: PJM

UPNY CONED	FWD (Import)	REV (Export)
	<b>7795 MW</b>	
Impacts Total Transfer Capability	255 MW	
TTC with All Lines In Service	8050 MW	

### CEDARS\_\_ROSEMNTA\_115\_1/11

Tue 01/28/2025 to Tue 01/28/2025  
0800 Continuous 1400  
Work scheduled by: HQ

UPDATED by NGrid 01/16/2025 13:43

SCH - HQ_CEDARS	FWD (Import)	REV (Export)
	<b>95 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability	184 MW	0 MW
TTC with All Lines In Service	279 MW	100 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Tuesday, January 21, 2025 to Monday, July 20, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### DENNISON-ROSEMNTA\_115\_1/11

Tue 01/28/2025 to Tue 01/28/2025  
0800 Continuous 1400  
Work scheduled by: HQ

UPDATED by NGrid 01/16/2025 13:43

SCH - HQ\_CEDARS

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**95 MW 100 MW**

184 MW 0 MW

279 MW 100 MW

### SCH-HQ\_CEDARS-NYISO\_LIMIT\_80

Tue 01/28/2025 to Tue 01/28/2025  
0800 Continuous 1400  
Work scheduled by: HQ

UPDATED by NGrid 01/16/2025 13:43

SCH - HQ\_CEDARS

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**80 MW**

199 MW

279 MW

### CEDARS\_-ROSEMNTB\_115\_2/22

Thu 01/30/2025 to Thu 01/30/2025  
0800 Continuous 1400  
Work scheduled by: HQ

UPDATED by NGrid 01/16/2025 13:47

SCH - HQ\_CEDARS

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**95 MW 100 MW**

184 MW 0 MW

279 MW 100 MW

### DENNISON-ROSEMNTB\_115\_2/22

Thu 01/30/2025 to Thu 01/30/2025  
0800 Continuous 1400  
Work scheduled by: HQ

UPDATED by NGrid 01/16/2025 13:47

SCH - HQ\_CEDARS

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**95 MW 100 MW**

184 MW 0 MW

279 MW 100 MW

### SCH-HQ\_CEDARS-NYISO\_LIMIT\_80

Thu 01/30/2025 to Thu 01/30/2025  
0800 Continuous 1400  
Work scheduled by: HQ

UPDATED by NGrid 01/16/2025 13:47

SCH - HQ\_CEDARS

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**80 MW**

199 MW

279 MW

### BECK\_-NIAGARA\_345\_PA301

Tue 02/04/2025 to Tue 02/04/2025  
0500 Continuous 2100  
Work scheduled by: NYPA

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**1150 MW 1000 MW**

1350 MW 850 MW

2500 MW 1850 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Tuesday, January 21, 2025 to Monday, July 20, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### FIVEMILE-ESTOLERD\_345\_29

Tue 02/04/2025 to Tue 02/04/2025  
0800 Continuous 0845  
Work scheduled by: NGrid

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**2600 MW**

100 MW

2700 MW

### PIERCBRK-FIVEMILE\_345\_37

Tue 02/04/2025 to Tue 02/04/2025  
0900 Daily 1030  
Work scheduled by: NGrid

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

### ROSETON\_EFISHKIL\_345\_RFK305

Sun 02/09/2025 to Wed 02/12/2025  
0001 Continuous 0200  
Work scheduled by: ConEd

UPNY CONED

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**7215 MW**

835 MW

8050 MW

### MILLWOOD-EASTVIEW\_345\_W82

Mon 02/10/2025 to Fri 02/14/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

UPNY CONED

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**7810 MW**

240 MW

8050 MW

### FRASER\_\_345\_FRASER SVC

Mon 02/10/2025 to Fri 02/14/2025  
0700 Continuous 1500  
Work scheduled by: NYSEG

CENTRAL EAST - VC

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**3655 MW**

70 MW

3725 MW

### MOSES\_\_-ADIRNDCK\_230\_MA2

Wed 02/12/2025 to Wed 02/12/2025  
0700 Continuous 1530  
Work scheduled by: NYPA

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**2300 MW**

850 MW

3150 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Tuesday, January 21, 2025 to Monday, July 20, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### WOOD\_ST\_PLSNTVLE\_345\_Y86

Mon 02/17/2025 to Mon 02/17/2025  
0001 Continuous 0030  
Work scheduled by: ConEd

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **7475 MW**  
575 MW  
8050 MW  
REV (Export)

### BECK\_\_PACKARD\_230\_BP76

Thu 02/20/2025 to Thu 02/20/2025  
0730 Continuous 1630  
Work scheduled by: NGrid

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **1800 MW**  
700 MW  
2500 MW  
REV (Export) **1300 MW**  
550 MW  
1850 MW

### WOOD\_ST\_PLSNTVLE\_345\_Y86

Fri 02/21/2025 to Fri 02/21/2025  
0130 Continuous 0200  
Work scheduled by: ConEd

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **7475 MW**  
575 MW  
8050 MW  
REV (Export)

### BERKSHIR-ALPS\_\_345\_393

Mon 02/24/2025 to Mon 02/24/2025  
0730 Continuous 1530  
Work scheduled by: NGrid  
ARR: 78

SCH - NPX\_1385  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **100 MW**  
100 MW  
200 MW  
REV (Export) **100 MW**  
100 MW  
200 MW

### BERKSHIR-ALPS\_\_345\_393

Mon 02/24/2025 to Mon 02/24/2025  
0730 Continuous 1530  
Work scheduled by: NGrid  
ARR: 78

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **1100 MW**  
300 MW  
1400 MW  
REV (Export) **1600 MW**  
200 MW  
1800 MW

### SPRNBK\_TREMONT\_345\_X28

Fri 02/28/2025 to Tue 03/04/2025  
0001 Continuous 0200  
Work scheduled by: ConEd  
UPDATED by ConEd 12/24/2024 09:22

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **4200 MW**  
400 MW  
4600 MW  
REV (Export)



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Tuesday, January 21, 2025 to Monday, July 20, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### RAMAPO\_\_BUCHAN\_N\_345\_Y94

Mon 03/03/2025 to Sat 03/08/2025  
0001 Continuous 0200  
Work scheduled by: ConEd

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) REV (Export)  
**7755 MW**  
295 MW  
8050 MW

### ALCOA\_PA\_115KV\_R8105

Mon 03/03/2025 to Fri 03/07/2025  
0500 Continuous 1800  
Work scheduled by: NGrid

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) REV (Export)  
**3100 MW**  
50 MW  
3150 MW

### MOTTHAVN-RAINEY\_\_345\_Q11

Tue 03/04/2025 to Mon 04/14/2025  
0201 Continuous 0300  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) REV (Export)  
**3800 MW**  
800 MW  
4600 MW

### MOSES\_\_ADIRNDCK\_230\_MA1

Thu 03/13/2025 to Sat 03/29/2025  
1931 Continuous 2300  
Work scheduled by: NYPA

UPDATED by NYPA 01/06/2025 14:13

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) REV (Export)  
**2300 MW**  
850 MW  
3150 MW

### NINEMILE-CLAY\_\_345\_8

Mon 03/17/2025 to Mon 03/17/2025  
0001 Continuous 0100  
Work scheduled by: NGrid

OSWEGO EXPORT  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) REV (Export)  
**5150 MW**  
100 MW  
5250 MW

### STLAWRNC-MOSES\_\_230\_L33P

Mon 03/17/2025 to Fri 03/21/2025  
0600 Continuous 1730  
Work scheduled by: NYPA

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) REV (Export)



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Tuesday, January 21, 2025 to Monday, July 20, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCRIBA\_\_VOLNEY\_\_345\_20

Mon 03/17/2025 to Mon 03/17/2025  
0700 Daily 1900  
Work scheduled by: NGrid

OSWEGO EXPORT FWD (Import) REV (Export)  
Impacts Total Transfer Capability **5250 MW**  
TTC with All Lines In Service 0 MW  
5250 MW

### NINEMILE-CLAY\_\_345\_8

Mon 03/17/2025 to Tue 03/18/2025  
2130 Continuous 2300  
Work scheduled by: NGrid

OSWEGO EXPORT FWD (Import) REV (Export)  
Impacts Total Transfer Capability **5150 MW**  
TTC with All Lines In Service 100 MW  
5250 MW

### SCRIBA\_\_VOLNEY\_\_345\_21

Thu 03/20/2025 to Fri 03/21/2025  
0700 Continuous 1900  
Work scheduled by: NGrid

OSWEGO EXPORT FWD (Import) REV (Export)  
Impacts Total Transfer Capability **5250 MW**  
TTC with All Lines In Service 0 MW  
5250 MW

### ROCHESTR-PANNELL\_345\_RP1

Mon 03/24/2025 to Tue 03/25/2025  
0730 Continuous 1500  
Work scheduled by: NYSEG

UPDATED by RGE 11/08/2024 10:56

DYSINGER EAST FWD (Import) REV (Export)  
Impacts Total Transfer Capability **2300 MW**  
TTC with All Lines In Service 900 MW  
3200 MW

### NINEMILE-CLAY\_\_345\_8

Tue 03/25/2025 to Tue 03/25/2025  
0200 Continuous 0300  
Work scheduled by: NGrid

OSWEGO EXPORT FWD (Import) REV (Export)  
Impacts Total Transfer Capability **5150 MW**  
TTC with All Lines In Service 100 MW  
5250 MW

### ROCHESTR-PANNELL\_345\_RP2

Wed 03/26/2025 to Thu 03/27/2025  
0730 Continuous 1500  
Work scheduled by: RGE

UPDATED by RGE 11/08/2024 10:51

DYSINGER EAST FWD (Import) REV (Export)  
Impacts Total Transfer Capability **2300 MW**  
TTC with All Lines In Service 900 MW  
3200 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Tuesday, January 21, 2025 to Monday, July 20, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>NIAGARA_-ROBNSNRD_230_64</b>						FWD (Import)	REV (Export)
Fri 03/28/2025	to	Fri 03/28/2025			SCH - OH - NY		
0500	Continuous	1900			Impacts Total Transfer Capability		
Work scheduled by: NYPA						TTC with All Lines In Service	
<b>BERKSHIR-ALPS___345_393</b>						FWD (Import)	REV (Export)
Mon 03/31/2025	to	Mon 03/31/2025			SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
0700	Continuous	1600			Impacts Total Transfer Capability	100 MW	100 MW
Work scheduled by: NGrid						TTC with All Lines In Service	200 MW
<b>BERKSHIR-ALPS___345_393</b>						FWD (Import)	REV (Export)
Mon 03/31/2025	to	Mon 03/31/2025			SCH - NE - NY	<b>1100 MW</b>	<b>1600 MW</b>
0700	Continuous	1600			Impacts Total Transfer Capability	300 MW	200 MW
Work scheduled by: NGrid						TTC with All Lines In Service	1400 MW
<b>BERKSHIR-ALPS___345_393 , BERKSHIR-NORTHFLD_345_312</b>						FWD (Import)	REV (Export)
Mon 03/31/2025	to	Mon 03/31/2025			SCH - NE - NY	<b>1100 MW</b>	<b>1100 MW</b>
0700		1600			Impacts Total Transfer Capability	300 MW	700 MW
Work scheduled by:						TTC with All Lines In Service	1400 MW
<b>BERKSHIR-NORTHFLD_345_312</b>						FWD (Import)	REV (Export)
Mon 03/31/2025	to	Mon 03/31/2025			SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
0700	Continuous	1600			Impacts Total Transfer Capability	100 MW	100 MW
Work scheduled by: NGrid						TTC with All Lines In Service	200 MW
<b>BERKSHIR-NORTHFLD_345_312</b>						FWD (Import)	REV (Export)
Mon 03/31/2025	to	Mon 03/31/2025			SCH - NE - NY	<b>1300 MW</b>	
0700	Continuous	1600			Impacts Total Transfer Capability	100 MW	
Work scheduled by: NGrid						TTC with All Lines In Service	1400 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Tuesday, January 21, 2025 to Monday, July 20, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MOSES\_\_ADIRNDCK\_230\_MA2

Tue 04/01/2025 to Tue 04/01/2025  
0500 Continuous 2230  
Work scheduled by: NYPA

MOSES SOUTH	FWD (Import)	REV (Export)
	<b>2300 MW</b>	
Impacts Total Transfer Capability	850 MW	
TTC with All Lines In Service	3150 MW	

### NINEMILE-CLAY\_\_345\_8

Wed 04/02/2025 to Wed 04/02/2025  
1900 Continuous 2000  
Work scheduled by: NGrid

OSWEGO EXPORT	FWD (Import)	REV (Export)
	<b>5150 MW</b>	
Impacts Total Transfer Capability	100 MW	
TTC with All Lines In Service	5250 MW	

### NIAGARA\_-DYSINGER\_345\_ND2

Mon 04/07/2025 to Fri 04/11/2025  
0500 Continuous 1730  
Work scheduled by: NYPA

DYSINGER EAST	FWD (Import)	REV (Export)
	<b>2700 MW</b>	
Impacts Total Transfer Capability	500 MW	
TTC with All Lines In Service	3200 MW	

### LINDN\_CG-LNDVFT\_\_345\_V-3022

Mon 04/07/2025 to Sat 04/12/2025  
0800 Continuous 1500  
Work scheduled by: PJM

SCH - PJM_VFT	FWD (Import)	REV (Export)
	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	315 MW	315 MW
TTC with All Lines In Service	315 MW	315 MW

### BECK\_\_-NIAGARA\_345\_PA301

Fri 04/11/2025 to Fri 04/11/2025  
0500 Continuous 1700  
Work scheduled by: NYPA

SCH - OH - NY	FWD (Import)	REV (Export)
	<b>1150 MW</b>	<b>1000 MW</b>
Impacts Total Transfer Capability	1350 MW	850 MW
TTC with All Lines In Service	2500 MW	1850 MW

### RAMAPO\_-BUCHAN\_N\_345\_Y94

Sat 04/12/2025 to Sat 04/19/2025  
0001 Continuous 0200  
Work scheduled by: ConEd

UPNY CONED	FWD (Import)	REV (Export)
	<b>7755 MW</b>	
Impacts Total Transfer Capability	295 MW	
TTC with All Lines In Service	8050 MW	



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Tuesday, January 21, 2025 to Monday, July 20, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SPRNBK\_TREMONT\_345\_X28

Mon 04/14/2025 to Sun 04/20/2025  
0001 Continuous 0200  
Work scheduled by: ConEd

UPDATED by ConEd 12/24/2024 09:22

SPR/DUN-SOUTH

Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**4200 MW**  
400 MW  
4600 MW

### NIAGARA\_DYSINGER\_345\_ND2

Mon 04/14/2025 to Fri 04/18/2025  
0500 Continuous 1730  
Work scheduled by: NYPA

DYSINGER EAST

Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**2700 MW**  
500 MW  
3200 MW

### E13THSTA-FARRAGUT\_345\_45

Tue 04/15/2025 to Sun 04/20/2025  
0001 Continuous 0200  
Work scheduled by: ConEd

SPR/DUN-SOUTH

Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**3800 MW**  
800 MW  
4600 MW

### W49TH\_ST-E13THSTA\_345\_M54

Tue 04/15/2025 to Sun 04/20/2025  
0001 Continuous 0200  
Work scheduled by: ConEd

SPR/DUN-SOUTH

Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**3800 MW**  
800 MW  
4600 MW

### MOSES\_\_ADIRNDCK\_230\_MA1

Tue 04/15/2025 to Tue 04/15/2025  
0700 Continuous 1530  
Work scheduled by: NYPA

MOSES SOUTH

Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**2300 MW**  
850 MW  
3150 MW

### LINDN\_CG-LNDVFT\_345\_V-3022

Thu 04/17/2025 to Thu 04/17/2025  
1500 Continuous 1800  
Work scheduled by: PJM

SCH - PJM\_VFT

Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**0 MW** **0 MW**  
315 MW 315 MW  
315 MW 315 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Tuesday, January 21, 2025 to Monday, July 20, 2026

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### NIAGARA\_\_PACKARD\_\_230\_61

Mon 04/21/2025 to Fri 04/25/2025  
0500 Continuous 1900  
Work scheduled by: NYPA

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
2450 MW	1800 MW
50 MW	50 MW
2500 MW	1850 MW

### PANNELL\_\_CLAY\_\_345\_1

Mon 04/21/2025 to Fri 04/25/2025  
0700 Continuous 1530  
Work scheduled by: NYPA

WEST CENTRAL  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
1300 MW	
950 MW	
2250 MW	

### MOSES\_\_ADIRNDCK\_230\_MA2

Tue 04/22/2025 to Tue 04/22/2025  
0700 Continuous 1530  
Work scheduled by: NYPA

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
2300 MW	
850 MW	
3150 MW	

### BECK\_\_NIAGARA\_345\_PA302

Fri 04/25/2025 to Fri 04/25/2025  
0500 Continuous 1700  
Work scheduled by: NYPA

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
1150 MW	1000 MW
1350 MW	850 MW
2500 MW	1850 MW

### MARCY\_\_765\_345\_AT1

Fri 04/25/2025 to Fri 04/25/2025  
0500 Continuous 1730  
Work scheduled by: NYPA

ARR: 19

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
1750 MW	
1400 MW	
3150 MW	

### MARCY\_\_765\_345\_AT2

Sat 04/26/2025 to Sat 04/26/2025  
0500 Continuous 1730  
Work scheduled by: NYPA

ARR: 19

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
1700 MW	
1450 MW	
3150 MW	



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Tuesday, January 21, 2025 to Monday, July 20, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### BUCHAN\_S-MILLWOOD\_345\_W97

Mon 04/28/2025 to Tue 04/29/2025  
0001 Continuous 0230  
Work scheduled by: ConEd

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **8015 MW**  
35 MW  
8050 MW

### PANNELL-CLAY\_345\_2

Mon 04/28/2025 to Fri 05/02/2025  
0700 Continuous 1530  
Work scheduled by: NYPA

WEST CENTRAL  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **1300 MW**  
950 MW  
2250 MW

### E13THSTA-FARRAGUT\_345\_46

Tue 05/06/2025 to Sat 05/10/2025  
0001 Continuous 0200  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **3800 MW**  
800 MW  
4600 MW

### LONG\_MTN-CRICKVLY\_345\_398

Tue 05/06/2025 to Thu 05/29/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

SCH - NPX\_1385  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **100 MW** **100 MW**  
100 MW  
200 MW

### LONG\_MTN-CRICKVLY\_345\_398

Tue 05/06/2025 to Thu 05/29/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **800 MW** **1200 MW**  
600 MW  
1400 MW

### W49TH\_ST\_345KV\_6

Tue 05/06/2025 to Tue 05/06/2025  
0001 Continuous 0030  
Work scheduled by: ConEd

SCH - PJM\_HTP  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **300 MW**  
360 MW  
660 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Tuesday, January 21, 2025 to Monday, July 20, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### W49TH\_ST-E13THSTA\_345\_M55

Tue 05/06/2025 to Sat 05/10/2025  
0001 Continuous 0200  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

**3800 MW**  
800 MW  
4600 MW

### WOOD\_ST\_PLSNTVLE\_345\_Y87

Wed 05/07/2025 to Fri 05/09/2025  
2200 Continuous 0259  
Work scheduled by: ConEd

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service

**7470 MW**  
580 MW  
8050 MW

### DUNWODIE\_345KV\_6

Fri 05/09/2025 to Fri 05/09/2025  
0001 Continuous 0030  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

**3800 MW**  
800 MW  
4600 MW

### DUNWODIE\_345KV\_8

Fri 05/09/2025 to Fri 05/09/2025  
0001 Continuous 0030  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

**3800 MW**  
800 MW  
4600 MW

### W49TH\_ST\_345KV\_6

Sat 05/10/2025 to Sat 05/10/2025  
0130 Continuous 0200  
Work scheduled by: ConEd

SCH - PJM\_HTP  
Impacts Total Transfer Capability  
TTC with All Lines In Service

**300 MW**  
360 MW  
660 MW

### DUNWODIE\_345KV\_6

Sun 05/11/2025 to Sun 05/11/2025  
1830 Continuous 1900  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

**3800 MW**  
800 MW  
4600 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Tuesday, January 21, 2025 to Monday, July 20, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### DUNWODIE\_345KV\_8

Sun 05/11/2025 to Sun 05/11/2025  
1830 Continuous 1900  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) REV (Export)  
**3800 MW**  
800 MW  
4600 MW

### MOSES\_-\_ADIRNDCK\_230\_MA2

Mon 05/12/2025 to Fri 05/30/2025  
0500 Continuous 2230  
Work scheduled by: NYPA

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) REV (Export)  
**2100 MW**  
1050 MW  
3150 MW

### NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE

Mon 05/12/2025 to Fri 05/16/2025  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) REV (Export)  
**0 MW**  
660 MW  
660 MW

### NEWBRDGE\_345\_138\_BK\_1

Mon 05/12/2025 to Fri 05/16/2025  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) REV (Export)  
**375 MW**  
285 MW  
660 MW

### NEWBRDGE\_345\_138\_BK\_2

Mon 05/12/2025 to Fri 05/16/2025  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) REV (Export)  
**375 MW**  
285 MW  
660 MW

### NEWBRDGE-DUFFYAVE\_345\_501

Mon 05/12/2025 to Fri 05/16/2025  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) REV (Export)  
**0 MW**  
660 MW  
660 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Tuesday, January 21, 2025 to Monday, July 20, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SAND\_BAR-PLATSBRG\_115\_PV20

Mon 07/07/2025 to Fri 07/11/2025  
0700 Continuous 1530  
Work scheduled by: NYPA

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### SAND\_BAR-PLATSBRG\_115\_PV20

Mon 07/07/2025 to Fri 07/11/2025  
0700 Continuous 1530  
Work scheduled by: NYPA

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**3625 MW**  
100 MW  
3725 MW

### NIAGARA\_345\_230\_AT4

Tue 07/08/2025 to Tue 07/08/2025  
0500 Continuous 1900  
Work scheduled by: NYPA

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**1200 MW**  
400 MW  
1600 MW

### DYSINGER-STA\_255\_345\_DH1

Tue 09/02/2025 to Mon 09/15/2025  
0500 Continuous 2100  
Work scheduled by: NYPA

DYSINGER EAST  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**2850 MW**  
350 MW  
3200 MW

### GOETHALS\_345KV\_5

Mon 09/08/2025 to Mon 09/08/2025  
0301 Continuous 0330  
Work scheduled by: ConEd

STATEN ISLAND  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### CLAY\_\_-EDIC\_\_345\_2-15

Mon 09/08/2025 to Fri 09/12/2025  
0700 Continuous 1530  
Work scheduled by: NYPA

OSWEGO EXPORT  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**4850 MW**  
400 MW  
5250 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Tuesday, January 21, 2025 to Monday, July 20, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MOSES\_\_-ADIRNDCK\_230\_MA1

Tue 09/09/2025 to Sun 10/12/2025  
0700 Continuous 1730  
Work scheduled by: NYPA

MOSES SOUTH  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

FWD (Import) REV (Export)

### GOETHALS\_345KV\_5

Tue 09/09/2025 to Tue 09/09/2025  
2330 Continuous 2359  
Work scheduled by: ConEd

STATEN ISLAND  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### DUNWODIE\_345KV\_4

Sat 09/13/2025 to Sun 09/14/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

UPDATED by ConEd 11/08/2024 12:36

SPR/DUN-SOUTH  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

### DUNWODIE\_345KV\_6

Sat 09/13/2025 to Sun 09/14/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

UPDATED by ConEd 11/08/2024 12:36

SPR/DUN-SOUTH  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

### DUNWODIE-SHORE\_RD\_345\_Y50

Sat 09/13/2025 to Sun 09/14/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

UPDATED by ConEd 11/08/2024 12:36

CONED - LIPA  
Impacts Total Transfer Capability 700 MW  
TTC with All Lines In Service 1500 MW

FWD (Import) REV (Export)

### SHORE\_RD\_345\_138\_BK 1

Sat 09/13/2025 to Sun 09/14/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

UPDATED by ConEd 11/08/2024 12:36

CONED - LIPA  
Impacts Total Transfer Capability 150 MW  
TTC with All Lines In Service 1500 MW

FWD (Import) REV (Export)



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Tuesday, January 21, 2025 to Monday, July 20, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SHORE\_RD\_345\_138\_BK 2

Sat 09/13/2025 to Sun 09/14/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

UPDATED by ConEd 11/08/2024 12:36

CONED - LIPA  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1350 MW**  
150 MW  
1500 MW

### SPRNBK\_345KV\_RNS4

Mon 09/15/2025 to Thu 10/02/2025  
0001 Continuous 0200  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3200 MW**  
1400 MW  
4600 MW

### SPRNBK\_-W49TH\_ST\_345\_M52

Mon 09/15/2025 to Thu 10/02/2025  
0001 Continuous 0200  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3200 MW**  
1400 MW  
4600 MW

### W49TH\_ST\_345KV\_5

Mon 09/15/2025 to Mon 09/15/2025  
0001 Continuous 0030  
Work scheduled by: ConEd

SCH - PJM\_HTP  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**460 MW**  
200 MW  
660 MW

### GOETHALS\_345KV\_5

Mon 09/15/2025 to Mon 09/15/2025  
0230 Continuous 0300  
Work scheduled by: ConEd

STATEN ISLAND  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3200 MW**  
1400 MW  
4600 MW

### ADIRNDCK-PORTER\_230\_12

Mon 09/15/2025 to Sun 10/12/2025  
0600 Continuous 1700  
Work scheduled by: NGrid

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**2100 MW**  
1050 MW  
3150 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Tuesday, January 21, 2025 to Monday, July 20, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MARCY\_\_\_345KV\_CSC

Mon 09/15/2025 to Sun 09/21/2025  
0600 Continuous 1730  
Work scheduled by: NYPA

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3650 MW**  
75 MW  
3725 MW

### DYSINGER-STA\_255\_345\_DH2

Tue 09/16/2025 to Tue 10/28/2025  
0500 Continuous 1900  
Work scheduled by: NYPA

DYSINGER EAST  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**2850 MW**  
350 MW  
3200 MW

### MARION\_-FARRAGUT\_345\_C3403

Thu 09/18/2025 to Sat 09/20/2025  
0001 Continuous 0300  
Work scheduled by: ConEd

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### MARCY\_-FRASANNX\_345\_UCC2-41

Mon 09/22/2025 to Mon 10/06/2025  
0700 Continuous 1730  
Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3225 MW**  
500 MW  
3725 MW

### PANNELL\_-CLAY\_\_\_345\_1

Mon 09/29/2025 to Fri 10/03/2025  
0700 Continuous 1530  
Work scheduled by: NYPA

WEST CENTRAL  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1300 MW**  
950 MW  
2250 MW

### W49TH\_ST\_345KV\_5

Thu 10/02/2025 to Thu 10/02/2025  
0130 Continuous 0200  
Work scheduled by: ConEd

SCH - PJM\_HTP  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**460 MW**  
200 MW  
660 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Tuesday, January 21, 2025 to Monday, July 20, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### PANNELL\_\_CLAY\_\_345\_2

Mon 10/06/2025 to Fri 10/10/2025  
0700 Continuous 1530  
Work scheduled by: NYPA

WEST CENTRAL  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 1300 MW  
REV (Export) 950 MW  
2250 MW

### NEPTUNE\_\_DUFFYAVE\_345\_NEPTUNE

Mon 10/13/2025 to Thu 10/16/2025  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 0 MW  
REV (Export) 660 MW  
660 MW

### NEWBRDGE\_345\_138\_BK\_1

Mon 10/13/2025 to Thu 10/16/2025  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 375 MW  
REV (Export) 285 MW  
660 MW

### NEWBRDGE\_345\_138\_BK\_2

Mon 10/13/2025 to Thu 10/16/2025  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 375 MW  
REV (Export) 285 MW  
660 MW

### NEWBRDGE-DUFFYAVE\_345\_501

Mon 10/13/2025 to Thu 10/16/2025  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 0 MW  
REV (Export) 660 MW  
660 MW

### MOSES\_\_ADIRNDCK\_230\_MA2

Mon 10/13/2025 to Mon 11/24/2025  
0700 Continuous 1730  
Work scheduled by: NYPA

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 2100 MW  
REV (Export) 1050 MW  
3150 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Tuesday, January 21, 2025 to Monday, July 20, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### EDIC\_\_-PRINCTWN\_345\_351

Tue 10/14/2025 to Fri 10/17/2025  
0600 Continuous 1830  
Work scheduled by: NGrid

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>3335 MW</b>	
390 MW	
3725 MW	

### MARION\_-FARRAGUT\_345\_C3403

Mon 10/27/2025 to Sat 11/01/2025  
0001 Continuous 0300  
Work scheduled by: ConEd

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)

### SPRNBK\_-TREMONT\_345\_X28

Mon 10/27/2025 to Fri 10/31/2025  
0001 Continuous 1800  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>4200 MW</b>	
400 MW	
4600 MW	

### CHATGUAY-MASSENA\_765\_7040

Sun 11/16/2025 to Sun 11/30/2025  
0001 Continuous 2359  
Work scheduled by: NYPA

SCH - HQ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>0 MW</b>	<b>0 MW</b>
1500 MW	1000 MW
1500 MW	1000 MW

### CHATGUAY-MASSENA\_765\_7040

Sun 11/16/2025 to Sun 11/30/2025  
0001 Continuous 2359  
Work scheduled by: NYPA

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>1550 MW</b>	
1600 MW	
3150 MW	

### MOSES\_\_-ADIRNDCK\_230\_MA2 , MOSES\_\_-MASSENA\_230\_MMS2 , MOSES\_\_-MASSENA\_230\_MMS1

Sun 11/16/2025 to Mon 11/24/2025  
0001 1730  
Work scheduled by:

SCH - HQ\_CEDARS  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>90 MW</b>	
189 MW	
279 MW	



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Tuesday, January 21, 2025 to Monday, July 20, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MOSES\_\_-MASSENA\_230\_MMS2 , MOSES\_\_-MASSENA\_230\_MMS1

Sun 11/16/2025 to Sun 11/30/2025  
0001 2359  
Work scheduled by:

SCH - HQ_CEDARS	FWD (Import)	REV (Export)
	<b>90 MW</b>	
Impacts Total Transfer Capability	189 MW	
TTC with All Lines In Service	279 MW	

### MOSES\_\_-MASSENA\_230\_MMS2 , MOSES\_\_-MASSENA\_230\_MMS1

Sun 11/16/2025 to Sun 11/30/2025  
0001 2359  
Work scheduled by:

SCH - HQ - NY	FWD (Import)	REV (Export)
	<b>850 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	650 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

### MOTTHAVN-RAINEY\_\_345\_Q11

Mon 12/01/2025 to Tue 12/02/2025  
0001 Continuous 0230  
Work scheduled by: ConEd

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

### GOETHALS\_345KV\_5

Sat 01/17/2026 to Sat 01/17/2026  
0301 Continuous 0330  
Work scheduled by: ConEd

UPDATED by ConEd 07/10/2024 16:09

STATEN ISLAND	FWD (Import)	REV (Export)
Impacts Total Transfer Capability		
TTC with All Lines In Service		

### DYSINGER-STA\_255\_345\_DH2

Mon 03/02/2026 to Fri 03/13/2026  
0500 Continuous 1900  
Work scheduled by: NYPA

DYSINGER EAST	FWD (Import)	REV (Export)
	<b>2850 MW</b>	
Impacts Total Transfer Capability	350 MW	
TTC with All Lines In Service	3200 MW	

### DYSINGER-STA\_255\_345\_DH1

Mon 03/16/2026 to Tue 04/07/2026  
0500 Continuous 2100  
Work scheduled by: NYPA

DYSINGER EAST	FWD (Import)	REV (Export)
	<b>2850 MW</b>	
Impacts Total Transfer Capability	350 MW	
TTC with All Lines In Service	3200 MW	



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Tuesday, January 21, 2025 to Monday, July 20, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### DYSINGER-STA\_255\_345\_DH2

Wed 04/08/2026 to Mon 04/20/2026  
0500 Continuous 2100  
Work scheduled by: NYPA

DYSINGER EAST **2850 MW**  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 3200 MW

### DYSINGER-STA\_255\_345\_DH1

Tue 04/21/2026 to Fri 05/01/2026  
0500 Continuous 2100  
Work scheduled by: NYPA

DYSINGER EAST **2850 MW**  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 3200 MW

### GOETHALS\_345KV\_5

Sat 04/25/2026 to Sat 04/25/2026  
2330 Continuous 2359  
Work scheduled by: ConEd

UPDATED by ConEd 07/10/2024 16:09

STATEN ISLAND  
Impacts Total Transfer Capability  
TTC with All Lines In Service

### GOETHALS\_345KV\_5

Mon 04/27/2026 to Mon 04/27/2026  
0001 Continuous 0030  
Work scheduled by: ConEd

UPDATED by ConEd 07/10/2024 16:09

STATEN ISLAND  
Impacts Total Transfer Capability  
TTC with All Lines In Service

### DYSINGER-STA\_255\_345\_DH2

Sat 05/02/2026 to Mon 05/11/2026  
0500 Continuous 2100  
Work scheduled by: NYPA

DYSINGER EAST **2850 MW**  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 3200 MW

### GOETHALS\_345KV\_5

Tue 05/05/2026 to Tue 05/05/2026  
0230 Continuous 0300  
Work scheduled by: ConEd

UPDATED by ConEd 07/10/2024 16:09

STATEN ISLAND  
Impacts Total Transfer Capability  
TTC with All Lines In Service



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Tuesday, January 21, 2025 to Monday, July 20, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### NEPTUNE\_DUFFYAVE\_345\_NEPTUNE

Mon 05/11/2026 to Fri 05/15/2026  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**0 MW**

660 MW

660 MW

### NEWBRDGE\_345\_138\_BK\_1

Mon 05/11/2026 to Fri 05/15/2026  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**375 MW**

285 MW

660 MW

### NEWBRDGE\_345\_138\_BK\_2

Mon 05/11/2026 to Fri 05/15/2026  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**375 MW**

285 MW

660 MW

### NEWBRDGE-DUFFYAVE\_345\_501

Mon 05/11/2026 to Fri 05/15/2026  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**0 MW**

660 MW

660 MW

### DYSINGER-STA\_255\_345\_DH1

Tue 05/12/2026 to Mon 05/25/2026  
0500 Continuous 2100  
Work scheduled by: NYPA

DYSINGER EAST

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**2850 MW**

350 MW

3200 MW