

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Tuesday, January 28, 2025 to Monday, July 27, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### HUDSONP\_-FARRAGUT\_345\_B3402

Mon 01/15/2018 to Thu 05/01/2025  
0001 Continuous 0100  
Work scheduled by: ConEd

EXT FORCED by ConEd 03/11/2024 11:26

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### MARION\_-FARRAGUT\_345\_C3403

Mon 01/15/2018 to Thu 05/01/2025  
0001 Continuous 0100  
Work scheduled by: ConEd

EXT FORCED by ConEd 03/11/2024 11:26

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### MARION\_-FARRAGUT\_345\_C3403 , HUDSONP\_-FARRAGUT\_345\_B3402

Mon 01/15/2018 to Thu 05/01/2025  
0001 0100  
Work scheduled by:

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**2400 MW 2400 MW**  
200 MW 300 MW  
2600 MW 2700 MW

### MARCY\_\_\_345KV\_CSC

Sat 06/15/2024 to Sat 05/24/2025  
0001 Continuous 2359  
Work scheduled by: NYPA

FORCED by NYPA 06/11/2024 15:44

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3650 MW**  
75 MW  
3725 MW

### MARCY\_\_\_765\_345\_AT1

Mon 10/14/2024 to Fri 02/14/2025  
2110 Continuous 2359  
Work scheduled by: NYPA

EXT FORCED by NYPA 01/16/2025 08:31

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1750 MW**  
1400 MW  
3150 MW

### SCH-IMO-NYISO\_LIMIT\_1900

Fri 11/01/2024 to Wed 04/30/2025  
0001 Continuous 2359  
Work scheduled by: IESO

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**2200 MW**  
300 MW  
2500 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Tuesday, January 28, 2025 to Monday, July 27, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### S.RIPLEY-DUNKIRK\_230\_68

Fri 11/08/2024 to Tue 02/04/2025  
1113 Continuous 1800  
Work scheduled by: PJM

EXT FORCED by NGrid 11/13/2024 16:46

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### W49TH\_ST\_345KV\_6

Fri 01/03/2025 to Fri 02/14/2025  
0001 Continuous 0200  
Work scheduled by: ConEd

UPDATED by ConEd 01/21/2025 16:11

SCH - PJM\_HTP  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**300 MW**  
360 MW  
660 MW

### W49TH\_ST-E13THSTA\_345\_M55

Fri 01/03/2025 to Fri 02/14/2025  
0001 Continuous 0200  
Work scheduled by: ConEd

UPDATED by ConEd 01/21/2025 16:11

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**3800 MW**  
800 MW  
4600 MW

### SCH-PJM-NYISO\_LIMIT\_1400

Wed 01/08/2025 to Tue 01/28/2025  
0001 Continuous 2359  
Work scheduled by: NYISO

EXT FORCED by NYISO 01/21/2025 15:26

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**1700 MW**  
900 MW  
2600 MW

### W49TH\_ST\_345KV\_8

Thu 01/09/2025 to Wed 01/29/2025  
0201 Continuous 2359  
Work scheduled by: ConEd

UPDATED by ConEd 01/21/2025 16:11

SCH - PJM\_HTP  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**310 MW**  
350 MW  
660 MW

### DUNWODIE-SHORE\_RD\_345\_Y50

Wed 01/22/2025 to Sun 02/02/2025  
0721 Continuous 2359  
Work scheduled by: ConEd

EXTENDED by ConEd 01/22/2025 15:57

CONED - LIPA  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**800 MW**  
700 MW  
1500 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Tuesday, January 28, 2025 to Monday, July 27, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### HOPATCON-RAMAPO\_\_500\_5018

Tue 01/28/2025 to Sat 02/01/2025  
0001 Continuous 0200  
Work scheduled by: PJM

SCH - PJ - NY	FWD (Import)	REV (Export)
	<b>1400 MW</b>	<b>1200 MW</b>
Impacts Total Transfer Capability	1200 MW	1500 MW
TTC with All Lines In Service	2600 MW	2700 MW

### HOPATCON-RAMAPO\_\_500\_5018

Tue 01/28/2025 to Sat 02/01/2025  
0001 Continuous 0200  
Work scheduled by: PJM

UPNY CONED	FWD (Import)	REV (Export)
	<b>7795 MW</b>	
Impacts Total Transfer Capability	255 MW	
TTC with All Lines In Service	8050 MW	

### HOPATCON-RAMAPO\_\_500\_5018

Tue 01/28/2025 to Sat 02/01/2025  
0001 Continuous 0200  
Work scheduled by: PJM

TOTAL EAST	FWD (Import)	REV (Export)
	<b>6800 MW</b>	
Impacts Total Transfer Capability	-650 MW	
TTC with All Lines In Service	6150 MW	

### RAMAPO\_\_345\_345\_PAR3500

Tue 01/28/2025 to Sat 02/01/2025  
0001 Continuous 0200  
Work scheduled by: PJM

SCH - PJ - NY	FWD (Import)	REV (Export)
	<b>2550 MW</b>	<b>1250 MW</b>
Impacts Total Transfer Capability	50 MW	1450 MW
TTC with All Lines In Service	2600 MW	2700 MW

### RAMAPO\_\_345\_345\_PAR4500

Tue 01/28/2025 to Sat 02/01/2025  
0001 Continuous 0200  
Work scheduled by: PJM

SCH - PJ - NY	FWD (Import)	REV (Export)
	<b>2550 MW</b>	<b>1250 MW</b>
Impacts Total Transfer Capability	50 MW	1450 MW
TTC with All Lines In Service	2600 MW	2700 MW

### RAMAPO\_\_500\_345\_BK 1500

Tue 01/28/2025 to Sat 02/01/2025  
0001 Continuous 0200  
Work scheduled by: PJM

SCH - PJ - NY	FWD (Import)	REV (Export)
	<b>1400 MW</b>	<b>1200 MW</b>
Impacts Total Transfer Capability	1200 MW	1500 MW
TTC with All Lines In Service	2600 MW	2700 MW





# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Tuesday, January 28, 2025 to Monday, July 27, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MILLWOOD-EASTVIEW\_345\_W82

Mon 02/10/2025 to Fri 02/14/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

UPNY CONED	FWD (Import)	REV (Export)
	<b>7810 MW</b>	
Impacts Total Transfer Capability	240 MW	
TTC with All Lines In Service	8050 MW	

### FRASER\_345\_FRASER SVC

Mon 02/10/2025 to Fri 02/14/2025  
0700 Continuous 1500  
Work scheduled by: NYSEG

CENTRAL EAST - VC	FWD (Import)	REV (Export)
	<b>3655 MW</b>	
Impacts Total Transfer Capability	70 MW	
TTC with All Lines In Service	3725 MW	

### MOSES\_-ADIRNDCK\_230\_MA2

Wed 02/12/2025 to Wed 02/12/2025  
0700 Continuous 1530  
Work scheduled by: NYPA

MOSES SOUTH	FWD (Import)	REV (Export)
	<b>2300 MW</b>	
Impacts Total Transfer Capability	850 MW	
TTC with All Lines In Service	3150 MW	

### BERKSHIR-ALPS\_345\_393

Thu 02/13/2025 to Thu 02/13/2025 UPDATED by ISONE 01/23/2025 14:24  
0730 Continuous 1530  
Work scheduled by: NGrid  
ARR: 78

SCH - NPX_1385	FWD (Import)	REV (Export)
	<b>100 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

### BERKSHIR-ALPS\_345\_393

Thu 02/13/2025 to Thu 02/13/2025 UPDATED by ISONE 01/23/2025 14:24  
0730 Continuous 1530  
Work scheduled by: NGrid  
ARR: 78

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>1100 MW</b>	<b>1600 MW</b>
Impacts Total Transfer Capability	300 MW	200 MW
TTC with All Lines In Service	1400 MW	1800 MW

### BERKSHIR-ALPS\_345\_393 , BERKSHIR-NORTHFLD\_345\_312

Thu 02/13/2025 to Thu 02/13/2025  
0730 1530  
Work scheduled by:  
ARR: 78

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>1100 MW</b>	<b>1100 MW</b>
Impacts Total Transfer Capability	300 MW	700 MW
TTC with All Lines In Service	1400 MW	1800 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Tuesday, January 28, 2025 to Monday, July 27, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### BERKSHIR-NORTHFLD\_345\_312

Thu 02/13/2025 to Thu 02/13/2025  
0730 Continuous 1530  
Work scheduled by: NGrid

UPDATED by ISONE 01/23/2025 14:24

SCH - NPX\_1385  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>100 MW</b>	<b>100 MW</b>
100 MW	100 MW
200 MW	200 MW

### BERKSHIR-NORTHFLD\_345\_312

Thu 02/13/2025 to Thu 02/13/2025  
0730 Continuous 1530  
Work scheduled by: NGrid

UPDATED by ISONE 01/23/2025 14:24

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>1300 MW</b>	
100 MW	
1400 MW	

### SCH-NE-NYISO\_LIMIT\_800

Thu 02/13/2025 to Thu 02/13/2025  
0730 Continuous 1530  
Work scheduled by: NGrid

UPDATED by ISONE 01/23/2025 14:24

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>1000 MW</b>	
400 MW	
1400 MW	

### SCH-NPX\_1385-NYISO\_LIMIT\_50

Thu 02/13/2025 to Thu 02/13/2025  
0730 Continuous 1530  
Work scheduled by: NGrid

UPDATED by ISONE 01/23/2025 14:24

SCH - NPX\_1385  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>50 MW</b>	
150 MW	
200 MW	

### SCH-NYISO-NPX\_1385\_LIMIT\_50

Thu 02/13/2025 to Thu 02/13/2025  
0730 Continuous 1530  
Work scheduled by: NGrid

UPDATED by ISONE 01/23/2025 14:24

SCH - NPX\_1385  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
	<b>50 MW</b>
	150 MW
	200 MW

### WOOD\_ST\_PLSNTVLE\_345\_Y86

Mon 02/17/2025 to Mon 02/17/2025  
0001 Continuous 0030  
Work scheduled by: ConEd

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
	<b>7475 MW</b>
	575 MW
	8050 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Tuesday, January 28, 2025 to Monday, July 27, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SPRNBK\_-TREMONT\_345\_X28

Fri 02/28/2025 to Tue 03/04/2025  
0001 Continuous 0200  
Work scheduled by: ConEd

UPDATED by ConEd 12/24/2024 09:22

SPR/DUN-SOUTH

Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**4200 MW**  
400 MW  
4600 MW

### MOSES\_-ADIRNDCK\_230\_MA2

Fri 02/28/2025 to Fri 02/28/2025  
1400 Continuous 1530  
Work scheduled by: NYPA

MOSES SOUTH

Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**2300 MW**  
850 MW  
3150 MW

### RAMAPO\_-BUCHAN\_N\_345\_Y94

Mon 03/03/2025 to Sat 03/08/2025  
0001 Continuous 0200  
Work scheduled by: ConEd

UPNY CONED

Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**7755 MW**  
295 MW  
8050 MW

### ALCOA\_PA\_115KV\_R8105

Mon 03/03/2025 to Fri 03/07/2025  
0500 Continuous 1800  
Work scheduled by: NGrid

MOSES SOUTH

Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**3100 MW**  
50 MW  
3150 MW

### MOTHAVN-RAINEY\_345\_Q11

Tue 03/04/2025 to Mon 04/14/2025  
0201 Continuous 0300  
Work scheduled by: ConEd

SPR/DUN-SOUTH

Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**3800 MW**  
800 MW  
4600 MW

### MOSES\_-ADIRNDCK\_230\_MA1

Thu 03/13/2025 to Sat 03/29/2025  
1931 Continuous 2300  
Work scheduled by: NYPA

UPDATED by NYPA 01/06/2025 14:13

MOSES SOUTH

Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**2300 MW**  
850 MW  
3150 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits		Tuesday, January 28, 2025 to Monday, July 27, 2026			
CENTRAL EAST	7550 MW	The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.			
CENTRAL EAST - VC	3725 MW				
TOTAL EAST	6150 MW				
UPNY CONED	8050 MW				
SPR/DUN-SOUTH	4600 MW				
DYSINGER EAST	3200 MW				
MOSES SOUTH	3150 MW				
NINEMILE-CLAY___345_8				FWD (Import)	REV (Export)
Mon 03/17/2025	to	Mon 03/17/2025	OSWEGO EXPORT	5150 MW	
0001	Continuous	0100	Impacts Total Transfer Capability	100 MW	
Work scheduled by: NGrid			TTC with All Lines In Service	5250 MW	
STLAWRNC-MOSES___230_L33P				FWD (Import)	REV (Export)
Mon 03/17/2025	to	Fri 03/21/2025	SCH - OH - NY		
0600	Continuous	1730	Impacts Total Transfer Capability		
Work scheduled by: NYPA			TTC with All Lines In Service		
SCRIBA_-VOLNEY___345_20				FWD (Import)	REV (Export)
Mon 03/17/2025	to	Mon 03/17/2025	OSWEGO EXPORT	5250 MW	
0700	Daily	1900	Impacts Total Transfer Capability	0 MW	
Work scheduled by: NGrid			TTC with All Lines In Service	5250 MW	
NINEMILE-CLAY___345_8				FWD (Import)	REV (Export)
Mon 03/17/2025	to	Tue 03/18/2025	OSWEGO EXPORT	5150 MW	
2130	Continuous	2300	Impacts Total Transfer Capability	100 MW	
Work scheduled by: NGrid			TTC with All Lines In Service	5250 MW	
SCRIBA_-VOLNEY___345_21				FWD (Import)	REV (Export)
Thu 03/20/2025	to	Fri 03/21/2025	OSWEGO EXPORT	5250 MW	
0700	Continuous	1900	Impacts Total Transfer Capability	0 MW	
Work scheduled by: NGrid			TTC with All Lines In Service	5250 MW	
ROCHESTR-PANNELL___345_RP1				FWD (Import)	REV (Export)
Mon 03/24/2025	to	Tue 03/25/2025	DYSINGER EAST	2300 MW	
0730	Continuous	1500	Impacts Total Transfer Capability	900 MW	
Work scheduled by: NYSEG			TTC with All Lines In Service	3200 MW	









# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Tuesday, January 28, 2025 to Monday, July 27, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### CEDARS\_\_ROSEMNTA\_115\_1/11

Tue 04/22/2025 to Thu 04/24/2025  
0700 Continuous 1600  
Work scheduled by: HQ

SCH - HQ_CEDARS	FWD (Import)	REV (Export)
	<b>95 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability	184 MW	0 MW
TTC with All Lines In Service	279 MW	100 MW

### DENNISON-ROSEMNTA\_115\_1/11

Tue 04/22/2025 to Thu 04/24/2025  
0700 Continuous 1600  
Work scheduled by: HQ

SCH - HQ_CEDARS	FWD (Import)	REV (Export)
	<b>95 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability	184 MW	0 MW
TTC with All Lines In Service	279 MW	100 MW

### MOSES\_\_ADIRNDCK\_230\_MA2

Tue 04/22/2025 to Tue 04/22/2025  
0700 Continuous 1530  
Work scheduled by: NYPA

MOSES SOUTH	FWD (Import)	REV (Export)
	<b>2300 MW</b>	
Impacts Total Transfer Capability	850 MW	
TTC with All Lines In Service	3150 MW	

### SCH-HQ\_CEDARS-NYISO\_LIMIT\_80

Tue 04/22/2025 to Thu 04/24/2025  
0700 Continuous 1600  
Work scheduled by: HQ

SCH - HQ_CEDARS	FWD (Import)	REV (Export)
	<b>80 MW</b>	
Impacts Total Transfer Capability	199 MW	
TTC with All Lines In Service	279 MW	

### LINDN\_CG-LNDVFT\_\_345\_V-3022

Thu 04/24/2025 to Thu 04/24/2025  
1500 Continuous 1800  
Work scheduled by: PJM

UPDATED by PJM 01/28/2025 14:45

SCH - PJM_VFT	FWD (Import)	REV (Export)
	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	315 MW	315 MW
TTC with All Lines In Service	315 MW	315 MW

### BECK\_\_NIAGARA\_345\_PA302

Fri 04/25/2025 to Fri 04/25/2025  
0500 Continuous 1700  
Work scheduled by: NYPA

SCH - OH - NY	FWD (Import)	REV (Export)
	<b>1150 MW</b>	<b>1000 MW</b>
Impacts Total Transfer Capability	1350 MW	850 MW
TTC with All Lines In Service	2500 MW	1850 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Tuesday, January 28, 2025 to Monday, July 27, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MARCY\_\_765\_345\_AT1

Fri 04/25/2025 to Fri 04/25/2025  
0500 Continuous 1730  
Work scheduled by: NYPA

ARR: 19

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1750 MW**  
1400 MW  
3150 MW

### MARCY\_\_765\_345\_AT2

Sat 04/26/2025 to Sat 04/26/2025  
0500 Continuous 1730  
Work scheduled by: NYPA

ARR: 19

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1700 MW**  
1450 MW  
3150 MW

### BUCHAN\_S-MILLWOOD\_345\_W97

Mon 04/28/2025 to Tue 04/29/2025  
0001 Continuous 0230  
Work scheduled by: ConEd

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**8015 MW**  
35 MW  
8050 MW

### CEDARS\_\_ROSEMNTA\_115\_1/11

Mon 04/28/2025 to Tue 04/29/2025  
0700 Continuous 1600  
Work scheduled by: HQ

SCH - HQ\_CEDARS  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**95 MW** **100 MW**  
184 MW 0 MW  
279 MW 100 MW

### DENNISON-ROSEMNTA\_115\_1/11

Mon 04/28/2025 to Tue 04/29/2025  
0700 Continuous 1600  
Work scheduled by: HQ

SCH - HQ\_CEDARS  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**95 MW** **100 MW**  
184 MW 0 MW  
279 MW 100 MW

### PANNELL\_-CLAY\_\_345\_2

Mon 04/28/2025 to Fri 05/02/2025  
0700 Continuous 1530  
Work scheduled by: NYPA

WEST CENTRAL  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1300 MW**  
950 MW  
2250 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Tuesday, January 28, 2025 to Monday, July 27, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-HQ\_CEDARS-NYISO\_LIMIT\_80

Mon 04/28/2025 to Tue 04/29/2025  
0700 Continuous 1600  
Work scheduled by: HQ

SCH - HQ\_CEDARS  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**80 MW**  
199 MW  
279 MW

### BECK\_\_-PACKARD\_230\_BP76

Tue 04/29/2025 to Tue 04/29/2025  
0800 Continuous 1530  
Work scheduled by: NGrid

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1800 MW** **1300 MW**  
700 MW 550 MW  
2500 MW 1850 MW

### CEDARS\_\_ROSEMNTB\_115\_2/22

Wed 04/30/2025 to Thu 05/01/2025  
0700 Continuous 1600  
Work scheduled by: HQ

SCH - HQ\_CEDARS  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**95 MW** **100 MW**  
184 MW 0 MW  
279 MW 100 MW

### DENNISON-ROSEMNTB\_115\_2/22

Wed 04/30/2025 to Thu 05/01/2025  
0700 Continuous 1600  
Work scheduled by: HQ

SCH - HQ\_CEDARS  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**95 MW** **100 MW**  
184 MW 0 MW  
279 MW 100 MW

### SCH-HQ\_CEDARS-NYISO\_LIMIT\_80

Wed 04/30/2025 to Thu 05/01/2025  
0700 Continuous 1600  
Work scheduled by: HQ

SCH - HQ\_CEDARS  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**80 MW**  
199 MW  
279 MW

### NIAGARA\_\_PACKARD\_230\_62

Wed 04/30/2025 to Wed 04/30/2025  
0800 Continuous 1530  
Work scheduled by: NGrid

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**2000 MW** **1800 MW**  
500 MW 50 MW  
2500 MW 1850 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Tuesday, January 28, 2025 to Monday, July 27, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### ----- CEDARS\_-ROSEMNTB\_115\_2/22

Mon 05/05/2025 to Thu 05/08/2025  
0700 Continuous 1600  
Work scheduled by: HQ

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS	<b>95 MW</b>	<b>40 MW</b>
Impacts Total Transfer Capability	175 MW	60 MW
TTC with All Lines In Service	270 MW	100 MW

### ----- DENNISON-ROSEMNTB\_115\_2/22

Mon 05/05/2025 to Thu 05/08/2025  
0700 Continuous 1600  
Work scheduled by: HQ

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS	<b>95 MW</b>	<b>40 MW</b>
Impacts Total Transfer Capability	175 MW	60 MW
TTC with All Lines In Service	270 MW	100 MW

### ----- SCH-HQ\_CEDARS-NYISO\_LIMIT\_80

Mon 05/05/2025 to Thu 05/08/2025  
0700 Continuous 1600  
Work scheduled by: HQ

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS	<b>80 MW</b>	
Impacts Total Transfer Capability	190 MW	
TTC with All Lines In Service	270 MW	

### ----- E13THSTA-FARRAGUT\_345\_46

Tue 05/06/2025 to Sat 05/10/2025  
0001 Continuous 0200  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

### ----- LONG\_MTN-CRICKVLY\_345\_398

Tue 05/06/2025 to Thu 05/29/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - NPX_1385	<b>100 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

### ----- LONG\_MTN-CRICKVLY\_345\_398

Tue 05/06/2025 to Thu 05/29/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - NE - NY	<b>800 MW</b>	<b>1200 MW</b>
Impacts Total Transfer Capability	600 MW	400 MW
TTC with All Lines In Service	1400 MW	1600 MW





# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Tuesday, January 28, 2025 to Monday, July 27, 2026

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 6150 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### NEWBRDGE-DUFFYAVE\_345\_501

Mon 05/12/2025 to Fri 05/16/2025  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE

FWD (Import) REV (Export)

Impacts Total Transfer Capability

0 MW

TTC with All Lines In Service

660 MW

660 MW

### HOMRC\_NY-MAINS\_NY\_345\_47

Mon 06/09/2025 to Fri 06/13/2025  
0800 Continuous 1600  
Work scheduled by: NYSEG

SCH - PJ - NY

FWD (Import) REV (Export)

Impacts Total Transfer Capability

TTC with All Lines In Service

### HOMRC\_NY-MAINS\_NY\_345\_47

Mon 06/16/2025 to Fri 06/20/2025  
0800 Continuous 1600  
Work scheduled by: NYSEG

SCH - PJ - NY

FWD (Import) REV (Export)

Impacts Total Transfer Capability

TTC with All Lines In Service

### HOMRC\_NY-MAINS\_NY\_345\_47

Mon 06/23/2025 to Fri 06/27/2025  
0800 Continuous 1600  
Work scheduled by: NYSEG

SCH - PJ - NY

FWD (Import) REV (Export)

Impacts Total Transfer Capability

TTC with All Lines In Service

### HOMRC\_NY-MAINS\_NY\_345\_47

Mon 06/30/2025 to Thu 07/03/2025  
0800 Continuous 1600  
Work scheduled by: NYSEG

SCH - PJ - NY

FWD (Import) REV (Export)

Impacts Total Transfer Capability

TTC with All Lines In Service

### NIAGARA\_345\_230\_AT4

Mon 07/07/2025 to Fri 07/11/2025  
0500 Continuous 1900  
Work scheduled by: NYPA

UPDATED by NYPA 01/28/2025 08:46

SCH - OH - NY

FWD (Import) REV (Export)

Impacts Total Transfer Capability

TTC with All Lines In Service

1200 MW

400 MW

1600 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Tuesday, January 28, 2025 to Monday, July 27, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SAND\_BAR-PLATSBRG\_115\_PV20

Mon 07/07/2025 to Fri 07/11/2025  
0700 Continuous 1530  
Work scheduled by: NYPA

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### SAND\_BAR-PLATSBRG\_115\_PV20

Mon 07/07/2025 to Fri 07/11/2025  
0700 Continuous 1530  
Work scheduled by: NYPA

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**3625 MW**  
100 MW  
3725 MW

### HOMRC-NY-MAINS\_NY\_345\_47

Mon 07/07/2025 to Fri 07/11/2025  
0800 Continuous 1600  
Work scheduled by: NYSEG

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### DYSINGER-ST\_255\_345\_DH1

Tue 09/02/2025 to Mon 09/15/2025  
0500 Continuous 2100  
Work scheduled by: NYPA

DYSINGER EAST  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**2850 MW**  
350 MW  
3200 MW

### GOETHALS\_345KV\_5

Mon 09/08/2025 to Mon 09/08/2025  
0301 Continuous 0330  
Work scheduled by: ConEd

STATEN ISLAND  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### CLAY\_\_-EDIC\_\_345\_2-15

Mon 09/08/2025 to Fri 09/12/2025  
0700 Continuous 1530  
Work scheduled by: NYPA

OSWEGO EXPORT  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**4850 MW**  
400 MW  
5250 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Tuesday, January 28, 2025 to Monday, July 27, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MOSES\_\_-ADIRNDCK\_230\_MA1

Tue 09/09/2025 to Sun 10/12/2025  
0700 Continuous 1730  
Work scheduled by: NYPA

MOSES SOUTH  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

FWD (Import) REV (Export)

### GOETHALS\_345KV\_5

Tue 09/09/2025 to Tue 09/09/2025  
2330 Continuous 2359  
Work scheduled by: ConEd

STATEN ISLAND  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### DUNWODIE\_345KV\_4

Sat 09/13/2025 to Sun 09/14/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

UPDATED by ConEd 11/08/2024 12:36

SPR/DUN-SOUTH  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

### DUNWODIE\_345KV\_6

Sat 09/13/2025 to Sun 09/14/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

UPDATED by ConEd 11/08/2024 12:36

SPR/DUN-SOUTH  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

### DUNWODIE-SHORE\_RD\_345\_Y50

Sat 09/13/2025 to Sun 09/14/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

UPDATED by ConEd 11/08/2024 12:36

CONED - LIPA  
Impacts Total Transfer Capability 700 MW  
TTC with All Lines In Service 1500 MW

FWD (Import) REV (Export)

### SHORE\_RD\_345\_138\_BK 1

Sat 09/13/2025 to Sun 09/14/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

UPDATED by ConEd 11/08/2024 12:36

CONED - LIPA  
Impacts Total Transfer Capability 150 MW  
TTC with All Lines In Service 1500 MW

FWD (Import) REV (Export)

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Tuesday, January 28, 2025 to Monday, July 27, 2026

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	6150 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SHORE\_RD\_345\_138\_BK 2

Sat 09/13/2025 to Sun 09/14/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

UPDATED by ConEd 11/08/2024 12:36

CONED - LIPA  
Impacts Total Transfer Capability 150 MW  
TTC with All Lines In Service 1500 MW

FWD (Import) REV (Export)

**1350 MW**

### SPRNBK\_345KV\_RNS4

Mon 09/15/2025 to Thu 10/02/2025  
0001 Continuous 0200  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

**3200 MW**

### SPRNBK\_-W49TH\_ST\_345\_M52

Mon 09/15/2025 to Thu 10/02/2025  
0001 Continuous 0200  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

**3200 MW**

### W49TH\_ST\_345KV\_5

Mon 09/15/2025 to Mon 09/15/2025  
0001 Continuous 0030  
Work scheduled by: ConEd

SCH - PJM\_HTP  
Impacts Total Transfer Capability 200 MW  
TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

**460 MW**

### GOETHALS\_345KV\_5

Mon 09/15/2025 to Mon 09/15/2025  
0230 Continuous 0300  
Work scheduled by: ConEd

STATEN ISLAND  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### ADIRNDCK-PORTER\_230\_12

Mon 09/15/2025 to Sun 10/12/2025  
0600 Continuous 1700  
Work scheduled by: NGrid

MOSES SOUTH  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

FWD (Import) REV (Export)

**2100 MW**













