

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, July 24, 2025 to Saturday, January 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### HUDSONP\_-FARRAGUT\_345\_B3402

Mon 01/15/2018 to Sat 11/01/2025  
0001 Continuous 0100  
Work scheduled by: ConEd

EXT FORCED by ConEd 03/11/2024 11:26

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### MARION\_-FARRAGUT\_345\_C3403

Mon 01/15/2018 to Sat 11/01/2025  
0001 Continuous 0100  
Work scheduled by: ConEd

EXT FORCED by ConEd 03/11/2024 11:26

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### MARION\_-FARRAGUT\_345\_C3403 , HUDSONP\_-FARRAGUT\_345\_B3402

Mon 01/15/2018 to Sat 11/01/2025  
0001 0100  
Work scheduled by:

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**2000 MW 1050 MW**  
200 MW 150 MW  
2200 MW 1200 MW

### OSWEGO\_COMPLEX\_AVR\_O/S

Wed 01/29/2025 to Sun 09/13/2026  
0001 Continuous 2359  
Work scheduled by: NGrid

FORCED by NGrid 01/27/2025 10:33

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3640 MW**  
85 MW  
3725 MW

### DOVER\_-CRICKVLY\_345\_Y17

Wed 02/12/2025 to Sun 11/23/2025  
1220 Continuous 2300  
Work scheduled by: NYISO

UPDATED by NYISO 05/27/2025 11:59

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### DOVER\_-CRICKVLY\_345\_Y17

Wed 02/12/2025 to Sun 11/23/2025  
1220 Continuous 2300  
Work scheduled by: NYISO

UPDATED by NYISO 05/27/2025 11:59

SCH - NPX\_1385  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, July 24, 2025 to Saturday, January 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### LONG\_MTN-DOVER\_\_345\_398

Wed 02/12/2025 to Sun 11/23/2025  
1221 Continuous 2300  
Work scheduled by: NYISO

UPDATED by NYISO 05/27/2025 11:59

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### LONG\_MTN-DOVER\_\_345\_398

Wed 02/12/2025 to Sun 11/23/2025  
1221 Continuous 2300  
Work scheduled by: NYISO

UPDATED by NYISO 05/27/2025 11:59

SCH - NPX\_1385  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### SCH-NYISO-HQ\_CEDARS\_LIMIT\_40

Tue 06/03/2025 to Fri 08/01/2025  
0001 Continuous 0000  
Work scheduled by: HQ

FORCED by HQ, 06/02/2025 15:40

SCH - HQ\_CEDARS  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**40 MW**  
60 MW  
100 MW

### DYSINGER-STA\_255\_345\_DH2

Mon 07/21/2025 to Thu 07/24/2025  
0500 Continuous 1200  
Work scheduled by: NYPA

UPDATED by NYPA 07/22/2025 13:35

DYSINGER EAST  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**2850 MW**  
350 MW  
3200 MW

### HOMRC\_NY-MAINS\_NY\_345\_47

Mon 07/21/2025 to Thu 07/24/2025  
0800 Continuous 1200  
Work scheduled by: NYSEG

UPDATED by NYSEG 07/22/2025 11:30

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### SCH-NYISO-HQ\_LIMIT\_0

Fri 07/25/2025 to Fri 07/25/2025  
0500 Continuous 1900  
Work scheduled by: HQ

SCH - HQ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**0 MW**  
1000 MW  
1000 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, July 24, 2025 to Saturday, January 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-HQ-NYISO\_LIMIT\_1400

Fri 07/25/2025 to Fri 07/25/2025  
0600 Continuous 1900  
Work scheduled by: HQ

CANCELLED by TO 07/23/2025 16:23

SCH - HQ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1400 MW**  
100 MW  
1500 MW

### SCH-NYISO-HQ\_LIMIT\_750

Mon 07/28/2025 to Tue 07/29/2025  
0600 Continuous 1900  
Work scheduled by: HQ

CANCELLED by NYISO 07/24/2025 11:23

SCH - HQ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**750 MW**  
250 MW  
1000 MW

### CEDARS\_\_ROSEMNTA\_115\_1/11

Tue 07/29/2025 to Tue 07/29/2025  
0600 Continuous 1800  
Work scheduled by: HQ

SCH - HQ\_CEDARS  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**95 MW 40 MW**  
175 MW 60 MW  
270 MW 100 MW

### DENNISON-ROSEMNTA\_115\_1/11

Tue 07/29/2025 to Tue 07/29/2025  
0600 Continuous 1800  
Work scheduled by: HQ

SCH - HQ\_CEDARS  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**95 MW 40 MW**  
175 MW 60 MW  
270 MW 100 MW

### SCH-HQ\_CEDARS-NYISO\_LIMIT\_80

Tue 07/29/2025 to Tue 07/29/2025  
0600 Continuous 1800  
Work scheduled by: HQ

SCH - HQ\_CEDARS  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**80 MW**  
190 MW  
270 MW

### DYSINGER-STA\_255\_345\_DH2

Wed 07/30/2025 to Sun 08/10/2025  
0500 Continuous 1900  
Work scheduled by: NYPA

UPDATED by NYPA 07/22/2025 13:35

DYSINGER EAST  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**2850 MW**  
350 MW  
3200 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, July 24, 2025 to Saturday, January 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### HOMRC\_NY-MAINS\_NY\_345\_47

Wed 07/30/2025 to Fri 08/08/2025  
0700 Continuous 1500  
Work scheduled by: NYSEG

UPDATED by NYSEG 07/22/2025 11:30

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### W49TH\_ST\_345KV\_6

Sat 08/02/2025 to Sat 08/02/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

SCH - PJM\_HTP  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**300 MW**  
360 MW  
660 MW

### CEDARS\_-ROSEMNTA\_115\_1/11

Tue 08/05/2025 to Wed 08/06/2025  
0700 Continuous 1800  
Work scheduled by: HQ

SCH - HQ\_CEDARS  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**95 MW 40 MW**  
175 MW 60 MW  
270 MW 100 MW

### DENNISON-ROSEMNTA\_115\_1/11

Tue 08/05/2025 to Wed 08/06/2025  
0700 Continuous 1800  
Work scheduled by: HQ

SCH - HQ\_CEDARS  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**95 MW 40 MW**  
175 MW 60 MW  
270 MW 100 MW

### SAND\_BAR-PLATSBRG\_115\_PV20

Tue 08/05/2025 to Fri 08/08/2025  
0700 Continuous 1630  
Work scheduled by: NYPA

UPDATED by NYPA 03/13/2025 13:53

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### SAND\_BAR-PLATSBRG\_115\_PV20

Tue 08/05/2025 to Fri 08/08/2025  
0700 Continuous 1630  
Work scheduled by: NYPA

UPDATED by NYPA 03/13/2025 13:53

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**3625 MW**  
100 MW  
3725 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, July 24, 2025 to Saturday, January 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-HQ\_CEDARS-NYISO\_LIMIT\_80

Tue 08/05/2025 to Wed 08/06/2025  
0700 Continuous 1800  
Work scheduled by: HQ

SCH - HQ\_CEDARS  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**80 MW**  
190 MW  
270 MW

### BECK\_\_-NIAGARA\_345\_PA301

Tue 08/05/2025 to Fri 08/08/2025  
0800 Continuous 1600  
Work scheduled by: IESO

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1000 MW** **850 MW**  
1000 MW 750 MW  
2000 MW 1600 MW

### EDIC\_\_-GORDONRD\_345\_14

Sat 08/09/2025 to Sun 08/10/2025  
0630 Continuous 1700  
Work scheduled by: NGrid

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**2770 MW**  
955 MW  
3725 MW

### EDIC\_\_-FRASER\_345\_EF24-40

Mon 08/11/2025 to Fri 08/15/2025  
0830 Continuous 1400  
Work scheduled by: NYSEG

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3225 MW**  
500 MW  
3725 MW

### CEDARS\_\_-ROSEMNTB\_115\_2/22

Wed 08/13/2025 to Thu 08/14/2025  
0700 Continuous 1800  
Work scheduled by: HQ

SCH - HQ\_CEDARS  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**95 MW** **40 MW**  
175 MW 60 MW  
270 MW 100 MW

### DENNISON-ROSEMNTB\_115\_2/22

Wed 08/13/2025 to Thu 08/14/2025  
0700 Continuous 1800  
Work scheduled by: HQ

SCH - HQ\_CEDARS  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**95 MW** **40 MW**  
175 MW 60 MW  
270 MW 100 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, July 24, 2025 to Saturday, January 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-HQ\_CEDARS-NYISO\_LIMIT\_80

Wed 08/13/2025 to Thu 08/14/2025  
0700 Continuous 1800  
Work scheduled by: HQ

SCH - HQ_CEDARS	FWD (Import)	REV (Export)
	<b>80 MW</b>	
Impacts Total Transfer Capability	190 MW	
TTC with All Lines In Service	270 MW	

### W49TH\_ST\_345KV\_5

Sat 08/16/2025 to Mon 08/18/2025  
0001 Continuous 0100  
Work scheduled by: ConEd

SCH - PJM_HTP	FWD (Import)	REV (Export)
	<b>460 MW</b>	
Impacts Total Transfer Capability	200 MW	
TTC with All Lines In Service	660 MW	

### W49TH\_ST\_345KV\_7

Sat 08/16/2025 to Mon 08/18/2025  
0001 Continuous 0100  
Work scheduled by: ConEd

SCH - PJM_HTP	FWD (Import)	REV (Export)
	<b>460 MW</b>	
Impacts Total Transfer Capability	200 MW	
TTC with All Lines In Service	660 MW	

### BUCHAN\_S-MILLWOOD\_345\_W98

Sat 08/23/2025 to Sun 08/24/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

UPNY CONED	FWD (Import)	REV (Export)
	<b>8015 MW</b>	
Impacts Total Transfer Capability	35 MW	
TTC with All Lines In Service	8050 MW	

### WOOD\_ST\_PLSNTVLE\_345\_Y86

Mon 09/01/2025 to Wed 09/03/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

UPNY CONED	FWD (Import)	REV (Export)
	<b>7475 MW</b>	
Impacts Total Transfer Capability	575 MW	
TTC with All Lines In Service	8050 MW	

### DYSINGER-STA\_255\_345\_DH1

Tue 09/02/2025 to Mon 09/15/2025  
0500 Continuous 2100  
Work scheduled by: NYPA

DYSINGER EAST	FWD (Import)	REV (Export)
	<b>2850 MW</b>	
Impacts Total Transfer Capability	350 MW	
TTC with All Lines In Service	3200 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, July 24, 2025 to Saturday, January 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MOSES\_\_ADIRNDCK\_230\_MA1

Tue 09/02/2025 to Sun 10/12/2025  
 0700 Continuous 1730  
 Work scheduled by: NYPA

UPDATED by NYPA 05/20/2025 13:57

MOSES SOUTH  
 Impacts Total Transfer Capability 1050 MW  
 TTC with All Lines In Service 3150 MW

FWD (Import) REV (Export)

**2100 MW**

### MARCY\_\_N.SCTLND\_345\_18

Wed 09/03/2025 to Wed 09/03/2025  
 0830 Continuous 1130  
 Work scheduled by: NGrid

ARR: 19

CENTRAL EAST - VC  
 Impacts Total Transfer Capability 1060 MW  
 TTC with All Lines In Service 3725 MW

FWD (Import) REV (Export)

**2665 MW**

### W49TH\_ST\_345KV\_6

Fri 09/05/2025 to Fri 09/05/2025  
 0001 Continuous 0030  
 Work scheduled by: ConEd

SCH - PJM\_HTP  
 Impacts Total Transfer Capability 360 MW  
 TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

**300 MW**

### W49TH\_ST\_345KV\_8

Fri 09/05/2025 to Fri 09/05/2025  
 0001 Continuous 0030  
 Work scheduled by: ConEd

SCH - PJM\_HTP  
 Impacts Total Transfer Capability 310 MW  
 TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

**350 MW**

### W49TH\_ST\_345KV\_6

Fri 09/05/2025 to Fri 09/05/2025  
 2130 Continuous 2200  
 Work scheduled by: ConEd

SCH - PJM\_HTP  
 Impacts Total Transfer Capability 360 MW  
 TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

**300 MW**

### W49TH\_ST\_345KV\_8

Fri 09/05/2025 to Fri 09/05/2025  
 2130 Continuous 2200  
 Work scheduled by: ConEd

SCH - PJM\_HTP  
 Impacts Total Transfer Capability 310 MW  
 TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

**350 MW**

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, July 24, 2025 to Saturday, January 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### HOMRC\_NY-MAINS\_NY\_345\_47

Mon 09/08/2025 to Mon 10/06/2025  
0800 Continuous 1600  
Work scheduled by: NYSEG

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### GORDONRD-ROTTRDAM\_230\_30

Tue 09/09/2025 to Wed 09/10/2025  
0830 Continuous 1430  
Work scheduled by: NGrid

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### SCH-NE-NYISO\_LIMIT\_900

Fri 09/12/2025 to Fri 09/12/2025  
0800 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### SCH-NE-NYISO\_LIMIT\_1000

Fri 09/12/2025 to Sat 09/13/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### MILLWOOD-EASTVIEW\_345\_W82

Sat 09/13/2025 to Sat 09/13/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### SPRNBK\_345KV\_RNS4

Sat 09/13/2025 to Sat 09/13/2025  
0001 Continuous 0030  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, July 24, 2025 to Saturday, January 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_900

Sat 09/13/2025 to Sat 09/13/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1100 MW**  
300 MW  
1400 MW

### SPRNBK\_345KV\_RNS4

Sat 09/13/2025 to Sat 09/13/2025  
2130 Continuous 2200  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3200 MW**  
1400 MW  
4600 MW

### SCH-NE-NYISO\_LIMIT\_1000

Sat 09/13/2025 to Sun 09/14/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1200 MW**  
200 MW  
1400 MW

### SCH-NE-NYISO\_LIMIT\_900

Sun 09/14/2025 to Sun 09/14/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1100 MW**  
300 MW  
1400 MW

### SCH-NE-NYISO\_LIMIT\_1000

Sun 09/14/2025 to Mon 09/15/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1200 MW**  
200 MW  
1400 MW

### RAMAPO\_-BUCHAN\_N\_345\_Y94

Mon 09/15/2025 to Wed 09/17/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

UPDATED by ConEd 06/18/2025 12:30

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**7755 MW**  
295 MW  
8050 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, July 24, 2025 to Saturday, January 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SPRNBK\_345KV\_RNS4

Mon 09/15/2025 to Thu 10/02/2025  
0001 Continuous 0200  
Work scheduled by: ConEd

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	<b>3200 MW</b>	
Impacts Total Transfer Capability	1400 MW	
TTC with All Lines In Service	4600 MW	

### SPRNBK\_W49TH\_ST\_345\_M52

Mon 09/15/2025 to Thu 10/02/2025  
0001 Continuous 0200  
Work scheduled by: ConEd

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	<b>3200 MW</b>	
Impacts Total Transfer Capability	1400 MW	
TTC with All Lines In Service	4600 MW	

### W49TH\_ST\_345KV\_5

Mon 09/15/2025 to Mon 09/15/2025  
0001 Continuous 0030  
Work scheduled by: ConEd

SCH - PJM_HTP	FWD (Import)	REV (Export)
	<b>460 MW</b>	
Impacts Total Transfer Capability	200 MW	
TTC with All Lines In Service	660 MW	

### GOETHALS\_345KV\_5

Mon 09/15/2025 to Mon 09/15/2025  
0230 Continuous 0300  
Work scheduled by: ConEd

STATEN ISLAND	FWD (Import)	REV (Export)
Impacts Total Transfer Capability		
TTC with All Lines In Service		

### ADIRNDCK-PORTER\_\_230\_12

Mon 09/15/2025 to Sun 10/12/2025  
0600 Continuous 1700  
Work scheduled by: NGrid

MOSES SOUTH	FWD (Import)	REV (Export)
	<b>2100 MW</b>	
Impacts Total Transfer Capability	1050 MW	
TTC with All Lines In Service	3150 MW	

### MARCY\_\_345KV\_CSC

Mon 09/15/2025 to Wed 09/24/2025  
0600 Continuous 1730  
Work scheduled by: NYPA

CENTRAL EAST - VC	FWD (Import)	REV (Export)
	<b>3650 MW</b>	
Impacts Total Transfer Capability	75 MW	
TTC with All Lines In Service	3725 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, July 24, 2025 to Saturday, January 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### DOVER\_\_CRICKVLY\_345\_Y17 , NRTH1385-NORHBR\_138\_601

Mon 09/15/2025 to Fri 10/10/2025  
0700 1500  
Work scheduled by:

SCH - NPX\_1385  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### DOVER\_\_CRICKVLY\_345\_Y17 , NRTH1385-NORHBR\_138\_602

Mon 09/15/2025 to Fri 10/10/2025  
0700 1500  
Work scheduled by:

SCH - NPX\_1385  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### DOVER\_\_CRICKVLY\_345\_Y17 , NRTH1385-NORHBR\_138\_603

Mon 09/15/2025 to Fri 10/10/2025  
0700 1500  
Work scheduled by:

SCH - NPX\_1385  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### LONG\_MTN-DOVER\_\_345\_398 , NRTH1385-NORHBR\_138\_601

Mon 09/15/2025 to Fri 10/10/2025  
0700 1500  
Work scheduled by:

SCH - NPX\_1385  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### LONG\_MTN-DOVER\_\_345\_398 , NRTH1385-NORHBR\_138\_602

Mon 09/15/2025 to Fri 10/10/2025  
0700 1500  
Work scheduled by:

SCH - NPX\_1385  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### LONG\_MTN-DOVER\_\_345\_398 , NRTH1385-NORHBR\_138\_603

Mon 09/15/2025 to Fri 10/10/2025  
0700 1500  
Work scheduled by:

SCH - NPX\_1385  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

NYISO TRANSFER LIMITATIONS

Seasonal Limits		Thursday, July 24, 2025 to Saturday, January 23, 2027				
CENTRAL EAST	7550 MW	<b>The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.</b>				
CENTRAL EAST - VC	3725 MW					
TOTAL EAST	7550 MW					
UPNY CONED	8050 MW					
SPR/DUN-SOUTH	4600 MW					
DYSINGER EAST	3200 MW					
MOSES SOUTH	3150 MW					
<b>NRTH1385-NOR HBR_138_601</b>					FWD (Import)	REV (Export)
Mon 09/15/2025	to	Fri 10/10/2025	SCH - NPX_1385	<b>25 MW</b>	<b>25 MW</b>	
0700	Continuous	1500	Impacts Total Transfer Capability	100 MW	100 MW	
Work scheduled by: LI			TTC with All Lines In Service	125 MW	125 MW	
<b>NRTH1385-NOR HBR_138_602</b>					FWD (Import)	REV (Export)
Mon 09/15/2025	to	Fri 10/10/2025	SCH - NPX_1385	<b>25 MW</b>	<b>25 MW</b>	
0700	Continuous	1500	Impacts Total Transfer Capability	100 MW	100 MW	
Work scheduled by: LI			TTC with All Lines In Service	125 MW	125 MW	
<b>NRTH1385-NOR HBR_138_603</b>					FWD (Import)	REV (Export)
Mon 09/15/2025	to	Fri 10/10/2025	SCH - NPX_1385	<b>25 MW</b>	<b>25 MW</b>	
0700	Continuous	1500	Impacts Total Transfer Capability	100 MW	100 MW	
Work scheduled by: LI			TTC with All Lines In Service	125 MW	125 MW	
<b>NRTH1385-NORHBR_138_601 , NRTH1385-NORHBR_138_602</b>					FWD (Import)	REV (Export)
Mon 09/15/2025	to	Fri 10/10/2025	SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>	
0700		1500	Impacts Total Transfer Capability	125 MW	125 MW	
Work scheduled by:			TTC with All Lines In Service	125 MW	125 MW	
<b>NRTH1385-NORHBR_138_601 , NRTH1385-NORHBR_138_603</b>					FWD (Import)	REV (Export)
Mon 09/15/2025	to	Fri 10/10/2025	SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>	
0700		1500	Impacts Total Transfer Capability	125 MW	125 MW	
Work scheduled by:			TTC with All Lines In Service	125 MW	125 MW	
<b>NRTH1385-NORHBR_138_602 , NRTH1385-NORHBR_138_603</b>					FWD (Import)	REV (Export)
Mon 09/15/2025	to	Fri 10/10/2025	SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>	
0700		1500	Impacts Total Transfer Capability	125 MW	125 MW	
Work scheduled by:			TTC with All Lines In Service	125 MW	125 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, July 24, 2025 to Saturday, January 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### NRTH1385-NRTHPORT\_138\_NNC

Mon 09/15/2025 to Fri 10/10/2025  
0700 Continuous 1500  
Work scheduled by: LI

SCH - NPX\_1385

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

**0 MW**

125 MW

125 MW

REV (Export)

**0 MW**

125 MW

125 MW

### SCH-NE-NYISO\_LIMIT\_900

Mon 09/15/2025 to Mon 09/15/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

**1100 MW**

300 MW

1400 MW

REV (Export)

### SCH-NE-NYISO\_LIMIT\_1000

Mon 09/15/2025 to Tue 09/16/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

**1200 MW**

200 MW

1400 MW

REV (Export)

### DYSINGER-STA\_255\_345\_DH2

Tue 09/16/2025 to Tue 10/28/2025  
0500 Continuous 1900  
Work scheduled by: NYPA

DYSINGER EAST

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

**2850 MW**

350 MW

3200 MW

REV (Export)

### SCH-NE-NYISO\_LIMIT\_900

Tue 09/16/2025 to Tue 09/16/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

**1100 MW**

300 MW

1400 MW

REV (Export)

### SCH-NE-NYISO\_LIMIT\_1000

Tue 09/16/2025 to Wed 09/17/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

**1200 MW**

200 MW

1400 MW

REV (Export)

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, July 24, 2025 to Saturday, January 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_900

Wed 09/17/2025 to Wed 09/17/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1100 MW**  
300 MW  
1400 MW

### SCH-NE-NYISO\_LIMIT\_1000

Wed 09/17/2025 to Thu 09/18/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1200 MW**  
200 MW  
1400 MW

### RAMAPO\_-BUCHAN\_N\_345\_Y94

Thu 09/18/2025 to Sat 09/20/2025  
0001 Continuous 0259  
Work scheduled by: ConEd

EXTENDED by ConEd 06/12/2025 10:19

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**7755 MW**  
295 MW  
8050 MW

### SCH-NE-NYISO\_LIMIT\_900

Thu 09/18/2025 to Thu 09/18/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1100 MW**  
300 MW  
1400 MW

### SCH-NE-NYISO\_LIMIT\_1000

Thu 09/18/2025 to Fri 09/19/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1200 MW**  
200 MW  
1400 MW

### SCH-NE-NYISO\_LIMIT\_900

Fri 09/19/2025 to Fri 09/19/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1100 MW**  
300 MW  
1400 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, July 24, 2025 to Saturday, January 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_1000

Fri 09/19/2025 to Sat 09/20/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1200 MW**  
200 MW  
1400 MW

### SCH-NE-NYISO\_LIMIT\_900

Sat 09/20/2025 to Sat 09/20/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1100 MW**  
300 MW  
1400 MW

### SCH-NE-NYISO\_LIMIT\_1000

Sat 09/20/2025 to Sun 09/21/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1200 MW**  
200 MW  
1400 MW

### SCH-NE-NYISO\_LIMIT\_900

Sun 09/21/2025 to Sun 09/21/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1100 MW**  
300 MW  
1400 MW

### SCH-NE-NYISO\_LIMIT\_1000

Sun 09/21/2025 to Mon 09/22/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1200 MW**  
200 MW  
1400 MW

### WOOD\_ST\_PLSNTVLE\_345\_Y86

Mon 09/22/2025 to Fri 09/26/2025  
0001 Continuous 0200  
Work scheduled by: ConEd

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**7475 MW**  
575 MW  
8050 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, July 24, 2025 to Saturday, January 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_900

Mon 09/22/2025 to Mon 09/22/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1100 MW**  
300 MW  
1400 MW

### SCH-NE-NYISO\_LIMIT\_1000

Mon 09/22/2025 to Tue 09/23/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1200 MW**  
200 MW  
1400 MW

### SCH-NE-NYISO\_LIMIT\_900

Tue 09/23/2025 to Tue 09/23/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1100 MW**  
300 MW  
1400 MW

### SCH-NE-NYISO\_LIMIT\_1000

Tue 09/23/2025 to Wed 09/24/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1200 MW**  
200 MW  
1400 MW

### SCH-NE-NYISO\_LIMIT\_900

Wed 09/24/2025 to Wed 09/24/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1100 MW**  
300 MW  
1400 MW

### SCH-NE-NYISO\_LIMIT\_1000

Wed 09/24/2025 to Thu 09/25/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1200 MW**  
200 MW  
1400 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, July 24, 2025 to Saturday, January 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MARCY\_\_FRASANNX\_345\_UCC2-41

Thu 09/25/2025 to Fri 10/17/2025  
0700 Continuous 1730  
Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3225 MW**  
500 MW  
3725 MW

### SCH-NE-NYISO\_LIMIT\_900

Thu 09/25/2025 to Thu 09/25/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1100 MW**  
300 MW  
1400 MW

### SCH-NE-NYISO\_LIMIT\_1000

Thu 09/25/2025 to Fri 09/26/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1200 MW**  
200 MW  
1400 MW

### SCH-NE-NYISO\_LIMIT\_900

Fri 09/26/2025 to Fri 09/26/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1100 MW**  
300 MW  
1400 MW

### SCH-NE-NYISO\_LIMIT\_600

Fri 09/26/2025 to Sat 09/27/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**800 MW**  
600 MW  
1400 MW

### SCH-NE-NYISO\_LIMIT\_900

Sat 09/27/2025 to Sat 09/27/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1100 MW**  
300 MW  
1400 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, July 24, 2025 to Saturday, January 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_600

Sat 09/27/2025 to Sun 09/28/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY **800 MW**  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 1400 MW

### SCH-NE-NYISO\_LIMIT\_900

Sun 09/28/2025 to Sun 09/28/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY **1100 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 1400 MW

### SCH-NE-NYISO\_LIMIT\_600

Sun 09/28/2025 to Mon 09/29/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY **800 MW**  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 1400 MW

### PANNELL\_-CLAY\_\_\_345\_1

Mon 09/29/2025 to Fri 10/03/2025  
0700 Continuous 1530  
Work scheduled by: NYPA

WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

### SCH-NE-NYISO\_LIMIT\_900

Mon 09/29/2025 to Mon 09/29/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY **1100 MW**  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 1400 MW

### SCH-NE-NYISO\_LIMIT\_600

Mon 09/29/2025 to Tue 09/30/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY **800 MW**  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 1400 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, July 24, 2025 to Saturday, January 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_900

Tue 09/30/2025 to Tue 09/30/2025  
0700 Daily 0800  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1100 MW**  
300 MW  
1400 MW

### DUNWODIE\_345KV\_6

Wed 10/01/2025 to Sat 10/04/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3800 MW**  
800 MW  
4600 MW

### DUNWODIE\_345KV\_8

Wed 10/01/2025 to Sat 10/04/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3800 MW**  
800 MW  
4600 MW

### W49TH\_ST\_345KV\_5

Thu 10/02/2025 to Thu 10/02/2025  
0130 Continuous 0200  
Work scheduled by: ConEd

SCH - PJM\_HTP  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**460 MW**  
200 MW  
660 MW

### PANNELL\_-CLAY\_\_\_345\_2

Mon 10/06/2025 to Fri 10/10/2025  
0700 Continuous 1530  
Work scheduled by: NYPA

WEST CENTRAL  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1300 MW**  
950 MW  
2250 MW

### ROCHESTR-PANNELL\_345\_RP2

Mon 10/06/2025 to Wed 10/08/2025  
0730 Continuous 1500  
Work scheduled by: RGE

DYSINGER EAST  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**2300 MW**  
900 MW  
3200 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, July 24, 2025 to Saturday, January 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MILLWOOD-EASTVIEW\_345\_W85

Fri 10/10/2025 to Sun 10/19/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **7810 MW**  
REV (Export) 240 MW  
8050 MW

### SPRNBK\_345KV\_RNS3

Fri 10/10/2025 to Fri 10/10/2025  
0001 Continuous 0030  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **3800 MW**  
REV (Export) 800 MW  
4600 MW

### DUNWODIE\_345KV\_3

Mon 10/13/2025 to Mon 10/13/2025  
0001 Continuous 0030  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **3800 MW**  
REV (Export) 800 MW  
4600 MW

### DUNWODIE\_345KV\_5

Mon 10/13/2025 to Mon 10/13/2025  
0001 Continuous 0030  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **3800 MW**  
REV (Export) 800 MW  
4600 MW

### DUNWODIE-MOTTHAVN\_345\_71

Mon 10/13/2025 to Tue 10/14/2025  
0001 Continuous 0200  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **3800 MW**  
REV (Export) 800 MW  
4600 MW

### NEPTUNE\_DUFFYAVE\_345\_NEPTUNE

Mon 10/13/2025 to Thu 10/16/2025  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **0 MW**  
REV (Export) 660 MW  
660 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, July 24, 2025 to Saturday, January 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### NEWBRDGE\_345\_138\_BK\_1

Mon 10/13/2025 to Thu 10/16/2025  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**375 MW**  
285 MW  
660 MW

### NEWBRDGE\_345\_138\_BK\_2

Mon 10/13/2025 to Thu 10/16/2025  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**375 MW**  
285 MW  
660 MW

### NEWBRDGE-DUFFYAVE\_345\_501

Mon 10/13/2025 to Thu 10/16/2025  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**0 MW**  
660 MW  
660 MW

### MOSES\_\_-ADIRNDCK\_230\_MA2

Mon 10/13/2025 to Sat 11/15/2025  
0700 Continuous 1730  
Work scheduled by: NYPA

UPDATED by NYPA 02/21/2025 15:57

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**2100 MW**  
1050 MW  
3150 MW

### DUNWODIE\_345KV\_3

Tue 10/14/2025 to Tue 10/14/2025  
0130 Continuous 0200  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3800 MW**  
800 MW  
4600 MW

### DUNWODIE\_345KV\_5

Tue 10/14/2025 to Tue 10/14/2025  
0130 Continuous 0200  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3800 MW**  
800 MW  
4600 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, July 24, 2025 to Saturday, January 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### EDIC\_\_-PRINCTWN\_345\_351

Tue 10/14/2025 to Fri 10/17/2025  
0600 Continuous 1830  
Work scheduled by: NGrid

CENTRAL EAST - VC  
Impacts Total Transfer Capability 3335 MW  
TTC with All Lines In Service 390 MW  
TTC with All Lines In Service 3725 MW

FWD (Import) REV (Export)

### MARCY\_\_765\_345\_AT2

Wed 10/15/2025 to Wed 10/15/2025  
0500 Continuous 1730  
Work scheduled by: NYPA  
UPDATED by NYPA 04/22/2025 12:32  
ARR: 19

MOSES SOUTH  
Impacts Total Transfer Capability 1700 MW  
TTC with All Lines In Service 1450 MW  
TTC with All Lines In Service 3150 MW

FWD (Import) REV (Export)

### SPRNBK\_345KV\_RNS3

Sun 10/19/2025 to Sun 10/19/2025  
2130 Continuous 2200  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability 3800 MW  
TTC with All Lines In Service 800 MW  
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

### E13THSTA-FARRAGUT\_345\_45

Mon 10/20/2025 to Sat 10/25/2025  
0001 Continuous 0159  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability 3800 MW  
TTC with All Lines In Service 800 MW  
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

### W49TH\_ST-E13THSTA\_345\_M54

Mon 10/20/2025 to Sat 10/25/2025  
0001 Continuous 0159  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability 3800 MW  
TTC with All Lines In Service 800 MW  
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

### GOETHALS\_345KV\_5

Wed 10/22/2025 to Thu 10/23/2025  
0001 Continuous 0200  
Work scheduled by: ConEd  
EXTENDED by ConEd 05/27/2025 11:13

STATEN ISLAND  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, July 24, 2025 to Saturday, January 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### HUDSONP\_FARRAGUT\_345\_B3402 , LINDEN\_GOETHALS\_230\_A2253

Wed 10/22/2025 to Thu 10/23/2025  
0001 0200  
Work scheduled by:

SCH - PJ - NY	FWD (Import)	REV (Export)
	<b>2000 MW</b>	<b>1000 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	2200 MW	1200 MW

### LINDEN\_GOETHALS\_230\_A2253

Wed 10/22/2025 to Thu 10/23/2025  
0001 Continuous 0200 EXTENDED by ConEd 05/27/2025 11:13  
Work scheduled by: ConEd

SCH - PJ - NY	FWD (Import)	REV (Export)
Impacts Total Transfer Capability		
TTC with All Lines In Service		

### LONG\_MTN-CRICKVLY\_345\_398

Wed 10/22/2025 to Fri 11/21/2025  
0001 Continuous 2300 UPDATED by ConEd 07/23/2025 12:25  
Work scheduled by: ConEd

SCH - NPX_1385	FWD (Import)	REV (Export)
	<b>25 MW</b>	<b>25 MW</b>
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	125 MW	125 MW

### LONG\_MTN-CRICKVLY\_345\_398

Wed 10/22/2025 to Fri 11/21/2025  
0001 Continuous 2300 UPDATED by ConEd 07/23/2025 12:25  
Work scheduled by: ConEd

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>800 MW</b>	<b>1200 MW</b>
Impacts Total Transfer Capability	600 MW	400 MW
TTC with All Lines In Service	1400 MW	1600 MW

### MARION\_FARRAGUT\_345\_C3403 , HUDSONP\_FARRAGUT\_345\_B3402 , LINDEN\_GOETHALS\_230\_A2253

Wed 10/22/2025 to Thu 10/23/2025  
0001 0200  
Work scheduled by:

SCH - PJ - NY	FWD (Import)	REV (Export)
	<b>2000 MW</b>	<b>1000 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	2200 MW	1200 MW

### MARION\_FARRAGUT\_345\_C3403 , LINDEN\_GOETHALS\_230\_A2253

Wed 10/22/2025 to Thu 10/23/2025  
0001 0200  
Work scheduled by:

SCH - PJ - NY	FWD (Import)	REV (Export)
	<b>2000 MW</b>	<b>1000 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	2200 MW	1200 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, July 24, 2025 to Saturday, January 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_500

Wed 10/22/2025 to Fri 11/21/2025  
0001 Continuous 2300  
Work scheduled by: ConEd

UPDATED by ConEd 07/23/2025 12:25

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**700 MW**  
700 MW  
1400 MW

### RAMAPO\_-BUCHAN\_N\_345\_Y94

Fri 10/24/2025 to Fri 10/24/2025  
0001 Continuous 0030  
Work scheduled by: ConEd

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**7755 MW**  
295 MW  
8050 MW

### SPRNBK\_-TREMONT\_345\_X28

Sat 10/25/2025 to Sun 10/26/2025  
0001 Continuous 0200  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**4200 MW**  
400 MW  
4600 MW

### RAMAPO\_-BUCHAN\_N\_345\_Y94

Sat 10/25/2025 to Sat 10/25/2025  
0130 Continuous 0200  
Work scheduled by: ConEd

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**7755 MW**  
295 MW  
8050 MW

### SPRNBK\_-TREMONT\_345\_X28

Mon 10/27/2025 to Fri 10/31/2025  
0001 Continuous 1800  
Work scheduled by: ConEd

UPDATED by ConEd 04/09/2025 09:25

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**4200 MW**  
400 MW  
4600 MW

### FROST\_BR-LONG\_MTN\_345\_352

Mon 10/27/2025 to Wed 10/29/2025  
0830 Continuous 1500  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1150 MW**  
250 MW  
1400 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, July 24, 2025 to Saturday, January 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### EDIC\_\_GORDONRD\_345\_14

Tue 10/28/2025 to Tue 10/28/2025  
0800 Daily 0900  
Work scheduled by: NGrid

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>2770 MW</b>	
955 MW	
3725 MW	

### BECK\_\_NIAGARA\_345\_PA302

Tue 10/28/2025 to Tue 10/28/2025  
0900 Continuous 1700  
Work scheduled by: IESO

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>1000 MW</b>	<b>850 MW</b>
1000 MW	750 MW
2000 MW	1600 MW

### LINDN\_CG-LNDVFT\_345\_V-3022

Mon 11/03/2025 to Thu 11/06/2025  
0800 Continuous 1500  
Work scheduled by: PJM

SCH - PJM\_VFT  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>0 MW</b>	<b>0 MW</b>
315 MW	315 MW
315 MW	315 MW

### MOTTHAVN-RAINEY\_345\_Q11

Wed 11/05/2025 to Wed 12/17/2025  
0001 Continuous 0100  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>3800 MW</b>	
800 MW	
4600 MW	

### LINDN\_CG-LNDVFT\_345\_V-3022

Thu 11/13/2025 to Thu 11/13/2025  
1500 Continuous 1800  
Work scheduled by: PJM

SCH - PJM\_VFT  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>0 MW</b>	<b>0 MW</b>
315 MW	315 MW
315 MW	315 MW

### CHATGUAY-MASSENA\_765\_7040

Sun 11/16/2025 to Sun 11/30/2025  
0001 Continuous 2359  
Work scheduled by: NYPA

SCH - HQ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>0 MW</b>	<b>0 MW</b>
1500 MW	1000 MW
1500 MW	1000 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, July 24, 2025 to Saturday, January 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### CHATGUAY-MASSENA\_\_765\_7040

Sun 11/16/2025 to Sun 11/30/2025  
0001 Continuous 2359  
Work scheduled by: NYPA

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **1550 MW**  
REV (Export) 1600 MW  
3150 MW

### CHATGUAY-MASSENA\_\_765\_7040 , MASSENA-MARCY\_\_765\_MSU1

Sun 11/16/2025 to Sun 11/30/2025  
0001 2359  
Work scheduled by:

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **500 MW**  
REV (Export) 2650 MW  
3150 MW

### MARCY\_\_765\_345\_AT1

Sun 11/16/2025 to Sun 11/30/2025  
0001 Continuous 2359  
Work scheduled by: NYPA

UPDATED by NYPA 02/21/2025 15:46  
ARR: 19

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **1750 MW**  
REV (Export) 1400 MW  
3150 MW

### MARCY\_\_765\_345\_AT2

Sun 11/16/2025 to Sun 11/30/2025  
0001 Continuous 2359  
Work scheduled by: NYPA

UPDATED by NYPA 02/21/2025 15:46  
ARR: 19

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **1700 MW**  
REV (Export) 1450 MW  
3150 MW

### MASSENA-MARCY\_\_765\_MSU1

Sun 11/16/2025 to Sun 11/30/2025  
0001 Continuous 2359  
Work scheduled by: NYPA

UPDATED by NYPA 02/21/2025 15:46

SCH - HQ\_CEDARS  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **90 MW**  
REV (Export) 189 MW  
279 MW

### MASSENA-MARCY\_\_765\_MSU1

Sun 11/16/2025 to Sun 11/30/2025  
0001 Continuous 2359  
Work scheduled by: NYPA

UPDATED by NYPA 02/21/2025 15:46

SCH - HQ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **475 MW**  
REV (Export) **1000 MW**  
1025 MW  
1500 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, July 24, 2025 to Saturday, January 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MASSENA\_MARCY\_\_765\_MSU1

Sun 11/16/2025 to Sun 11/30/2025  
0001 Continuous 2359  
Work scheduled by: NYPA

UPDATED by NYPA 02/21/2025 15:46

MOSES SOUTH

Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**500 MW**  
2650 MW  
3150 MW

### MASSENA\_MARCY\_\_765\_MSU1

Sun 11/16/2025 to Sun 11/30/2025  
0001 Continuous 2359  
Work scheduled by: NYPA

UPDATED by NYPA 02/21/2025 15:46

CENTRAL EAST - VC

Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**2595 MW**  
1130 MW  
3725 MW

### MOSES\_\_-MASSENA\_230\_MMS2 , MOSES\_\_-MASSENA\_230\_MMS1

Sun 11/16/2025 to Sun 11/30/2025  
0001 2359  
Work scheduled by:

SCH - HQ\_CEDARS

Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**90 MW**  
189 MW  
279 MW

### MOSES\_\_-MASSENA\_230\_MMS2 , MOSES\_\_-MASSENA\_230\_MMS1

Sun 11/16/2025 to Sun 11/30/2025  
0001 2359  
Work scheduled by:

SCH - HQ - NY

Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**850 MW** **0 MW**  
650 MW 1000 MW  
1500 MW 1000 MW

### RAMAPO\_\_-BUCHAN\_N\_345\_Y94

Mon 11/17/2025 to Mon 11/17/2025  
0201 Continuous 0230  
Work scheduled by: ConEd

UPNY CONED

Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**7755 MW**  
295 MW  
8050 MW

### RAMAPO\_\_-BUCHAN\_N\_345\_Y94

Tue 11/18/2025 to Tue 11/18/2025  
0130 Continuous 0200  
Work scheduled by: ConEd

UPNY CONED

Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**7755 MW**  
295 MW  
8050 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, July 24, 2025 to Saturday, January 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### BECK\_\_-NIAGARA\_230\_PA27

Thu 11/20/2025 to Thu 11/20/2025  
0800 Continuous 1600  
Work scheduled by: IESO

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**2050 MW**  
450 MW  
2500 MW

### MILLWOOD-EASTVIEW\_345\_W82

Wed 12/10/2025 to Fri 12/19/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**7810 MW**  
240 MW  
8050 MW

### SPRNBK\_345KV\_RNS4

Wed 12/10/2025 to Wed 12/10/2025  
0001 Continuous 0030  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3200 MW**  
1400 MW  
4600 MW

### SPRNBK\_345KV\_RNS4

Fri 12/19/2025 to Fri 12/19/2025  
2130 Continuous 2200  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3200 MW**  
1400 MW  
4600 MW

### MILLWOOD-EASTVIEW\_345\_W99

Mon 12/22/2025 to Mon 12/22/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**7810 MW**  
240 MW  
8050 MW

### MILLWOOD-EASTVIEW\_345\_W99

Tue 12/23/2025 to Thu 12/25/2025  
0001 Continuous 0259  
Work scheduled by: ConEd

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**7810 MW**  
240 MW  
8050 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, July 24, 2025 to Saturday, January 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SPRNBK\_345KV\_RNS5

Tue 12/23/2025 to Thu 12/25/2025  
0001 Continuous 0259  
Work scheduled by: ConEd

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	<b>3200 MW</b>	
Impacts Total Transfer Capability	1400 MW	
TTC with All Lines In Service	4600 MW	

### E13THSTA-FARRAGUT\_345\_46

Wed 01/07/2026 to Fri 01/09/2026  
0301 Continuous 0300  
Work scheduled by: ConEd

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

### E13THSTA-FARRAGUT\_345\_46

Sat 01/31/2026 to Thu 02/05/2026  
0001 Continuous 0300  
Work scheduled by: ConEd

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

### MARCY\_\_N.SCTLND\_345\_18

Mon 02/09/2026 to Fri 02/13/2026  
0700 Continuous 1530  
Work scheduled by: NYPA ARR: 19

CENTRAL EAST - VC	FWD (Import)	REV (Export)
	<b>2665 MW</b>	
Impacts Total Transfer Capability	1060 MW	
TTC with All Lines In Service	3725 MW	

### NIAGARA\_-DYSINGER\_345\_ND1

Thu 02/12/2026 to Thu 02/12/2026  
0500 Continuous 1900  
Work scheduled by: NYPA

DYSINGER EAST	FWD (Import)	REV (Export)
	<b>2700 MW</b>	
Impacts Total Transfer Capability	500 MW	
TTC with All Lines In Service	3200 MW	

### DUNWODIE\_345KV\_7

Sun 03/01/2026 to Sun 03/01/2026  
0001 Continuous 0030  
Work scheduled by: ConEd

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, July 24, 2025 to Saturday, January 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### DUNWODIE\_345KV\_8

Sun 03/01/2026 to Sun 03/01/2026  
0001 Continuous 0030  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>3800 MW</b>	
800 MW	
4600 MW	

### DUNWODIE-MOTTHAVN\_345\_72

Sun 03/01/2026 to Mon 04/13/2026  
0001 Continuous 0259  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>3800 MW</b>	
800 MW	
4600 MW	

### DYSINGER-STA\_255\_345\_DH2

Mon 03/02/2026 to Sun 03/15/2026  
0500 Continuous 1900  
Work scheduled by: NYPA

EXTENDED by NYPA 06/17/2025 15:09

DYSINGER EAST  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>2850 MW</b>	
350 MW	
3200 MW	

### DYSINGER-STA\_255\_345\_DH1

Mon 03/16/2026 to Tue 04/07/2026  
0500 Continuous 2100  
Work scheduled by: NYPA

DYSINGER EAST  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>2850 MW</b>	
350 MW	
3200 MW	

### BECK\_\_-NIAGARA\_345\_PA302

Mon 03/16/2026 to Fri 03/20/2026  
0630 Continuous 1600  
Work scheduled by: IESO

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>1150 MW</b>	<b>1000 MW</b>
1350 MW	850 MW
2500 MW	1850 MW

### DYSINGER-STA\_255\_345\_DH2

Wed 04/08/2026 to Mon 04/20/2026  
0500 Continuous 2100  
Work scheduled by: NYPA

DYSINGER EAST  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>2850 MW</b>	
350 MW	
3200 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, July 24, 2025 to Saturday, January 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### DUNWODIE\_345KV\_7

Mon 04/13/2026 to Mon 04/13/2026  
0230 Continuous 0259  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

### DUNWODIE\_345KV\_8

Mon 04/13/2026 to Mon 04/13/2026  
0230 Continuous 0259  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

### STLAWRNC-MOSES\_\_230\_L34P

Mon 04/13/2026 to Fri 04/17/2026  
0600 Continuous 1630  
Work scheduled by: NYPA

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### ROSETON\_EFISHKIL\_345\_RFK305

Mon 04/13/2026 to Fri 04/24/2026  
0700 Continuous 1530  
Work scheduled by: NYPA

UPNY CONED  
Impacts Total Transfer Capability 835 MW  
TTC with All Lines In Service 8050 MW

FWD (Import) REV (Export)

### STLAWRNC-MOSES\_\_230\_L33P

Mon 04/20/2026 to Fri 04/24/2026  
0600 Continuous 1630  
Work scheduled by: NYPA

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### DYSINGER-STA\_255\_345\_DH1

Tue 04/21/2026 to Fri 05/01/2026  
0500 Continuous 2100  
Work scheduled by: NYPA

DYSINGER EAST  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 3200 MW

FWD (Import) REV (Export)

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, July 24, 2025 to Saturday, January 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### BECK\_\_-NIAGARA\_345\_PA301

Mon 04/27/2026 to Fri 05/01/2026  
0630 Continuous 1600  
Work scheduled by: IESO

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**1150 MW 1000 MW**

1350 MW 850 MW

2500 MW 1850 MW

### GOETHALS\_345KV\_5

Fri 05/01/2026 to Thu 05/07/2026  
0001 Continuous 0300  
Work scheduled by: ConEd

UPDATED by ConEd 03/04/2025 07:30

STATEN ISLAND

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

### DYSINGER-STA\_255\_345\_DH2

Sat 05/02/2026 to Mon 05/11/2026  
0500 Continuous 2100  
Work scheduled by: NYPA

DYSINGER EAST

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**2850 MW**

350 MW

3200 MW

### INGHAM\_C\_115\_115\_PAR 2

Mon 05/04/2026 to Fri 05/22/2026  
0600 Continuous 1600  
Work scheduled by: NGrid

CENTRAL EAST - VC

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**3605 MW**

120 MW

3725 MW

### MARCY\_\_FRASANNX\_345\_UCC2-41

Wed 05/06/2026 to Fri 05/22/2026  
0700 Continuous 1530  
Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**3225 MW**

500 MW

3725 MW

### NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE

Mon 05/11/2026 to Fri 05/15/2026  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**0 MW**

660 MW

660 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, July 24, 2025 to Saturday, January 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### NEWBRDGE\_345\_138\_BK\_1

Mon 05/11/2026 to Fri 05/15/2026  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE **375 MW**  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 660 MW

### NEWBRDGE\_345\_138\_BK\_2

Mon 05/11/2026 to Fri 05/15/2026  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE **375 MW**  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 660 MW

### NEWBRDGE-DUFFYAVE\_345\_501

Mon 05/11/2026 to Fri 05/15/2026  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE **0 MW**  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

### BECK\_\_\_-PACKARD\_230\_BP76

Mon 05/11/2026 to Fri 05/15/2026  
0630 Continuous 1600  
Work scheduled by: IESO

SCH - OH - NY **1600 MW** **1050 MW**  
Impacts Total Transfer Capability 400 MW 550 MW  
TTC with All Lines In Service 2000 MW 1600 MW

### DYSINGER-STA\_255\_345\_DH1

Tue 05/12/2026 to Mon 05/25/2026  
0500 Continuous 2100  
Work scheduled by: NYPA

DYSINGER EAST **2850 MW**  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 3200 MW

### W49TH\_ST\_345KV\_5

Fri 05/15/2026 to Fri 05/15/2026  
0001 Continuous 0030  
Work scheduled by: ConEd

SCH - PJM\_HTP **460 MW**  
Impacts Total Transfer Capability 200 MW  
TTC with All Lines In Service 660 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, July 24, 2025 to Saturday, January 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### W49TH\_ST\_345KV\_7

Fri 05/15/2026 to Fri 05/15/2026  
0001 Continuous 0030  
Work scheduled by: ConEd

SCH - PJM\_HTP

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**460 MW**

200 MW

660 MW

### W49TH\_ST\_345KV\_5

Fri 05/15/2026 to Fri 05/15/2026  
1430 Continuous 1500  
Work scheduled by: ConEd

SCH - PJM\_HTP

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**460 MW**

200 MW

660 MW

### W49TH\_ST\_345KV\_7

Fri 05/15/2026 to Fri 05/15/2026  
1430 Continuous 1500  
Work scheduled by: ConEd

SCH - PJM\_HTP

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**460 MW**

200 MW

660 MW

### W49TH\_ST\_345KV\_5

Sat 05/16/2026 to Sat 05/16/2026  
0001 Continuous 0030  
Work scheduled by: ConEd

SCH - PJM\_HTP

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**460 MW**

200 MW

660 MW

### W49TH\_ST\_345KV\_7

Sat 05/16/2026 to Sat 05/16/2026  
0001 Continuous 0030  
Work scheduled by: ConEd

SCH - PJM\_HTP

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**460 MW**

200 MW

660 MW

### W49TH\_ST\_345KV\_5

Mon 05/18/2026 to Mon 05/18/2026  
0030 Continuous 0100  
Work scheduled by: ConEd

SCH - PJM\_HTP

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**460 MW**

200 MW

660 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, July 24, 2025 to Saturday, January 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### W49TH\_ST\_345KV\_7

Mon 05/18/2026 to Mon 05/18/2026  
0030 Continuous 0100  
Work scheduled by: ConEd

SCH - PJM\_HTP

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**460 MW**

200 MW

660 MW

### NIAGARA\_345\_230\_AT4

Tue 05/26/2026 to Sat 05/30/2026  
0500 Continuous 1900  
Work scheduled by: NYPA

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**1200 MW**

400 MW

1600 MW

### MARCY\_\_345KV\_CSC

Mon 06/01/2026 to Sun 06/14/2026  
0700 Continuous 1530  
Work scheduled by: NYPA

CENTRAL EAST - VC

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**3650 MW**

75 MW

3725 MW

### MARCY\_\_765\_345\_AT1

Wed 09/09/2026 to Thu 09/10/2026  
0700 Continuous 1530  
Work scheduled by: NYPA

ARR: 19

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**1750 MW**

1400 MW

3150 MW

### MARCY\_\_765\_345\_AT2

Fri 09/11/2026 to Sat 09/12/2026  
0700 Continuous 1530  
Work scheduled by: NYPA

ARR: 19

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**1700 MW**

1450 MW

3150 MW

### MOTTHAVN-RAINEY\_\_345\_Q12

Tue 09/15/2026 to Sun 10/25/2026  
0201 Continuous 0400  
Work scheduled by: ConEd

SPR/DUN-SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**3800 MW**

800 MW

4600 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, July 24, 2025 to Saturday, January 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MARCY__FRASANNX_345_UCC2-41</b>					FWD (Import)	REV (Export)
Tue 09/15/2026	to	Tue 09/29/2026		CENTRAL EAST - VC	<b>3225 MW</b>	
0700	Continuous	1530	ARR: 19	Impacts Total Transfer Capability	500 MW	
Work scheduled by: NYPA				TTC with All Lines In Service	3725 MW	
<b>PANNELL_-CLAY__345_1</b>					FWD (Import)	REV (Export)
Mon 09/28/2026	to	Fri 10/02/2026		WEST CENTRAL	<b>1300 MW</b>	
0700	Continuous	1530		Impacts Total Transfer Capability	950 MW	
Work scheduled by: NYPA				TTC with All Lines In Service	2250 MW	
<b>SAND_BAR-PLATSBRG_115_PV20</b>					FWD (Import)	REV (Export)
Mon 09/28/2026	to	Fri 10/02/2026		SCH - NE - NY		
0900	Continuous	1630		Impacts Total Transfer Capability		
Work scheduled by: NYPA				TTC with All Lines In Service		
<b>SAND_BAR-PLATSBRG_115_PV20</b>					FWD (Import)	REV (Export)
Mon 09/28/2026	to	Fri 10/02/2026		CENTRAL EAST - VC	<b>3625 MW</b>	
0900	Continuous	1630		Impacts Total Transfer Capability	100 MW	
Work scheduled by: NYPA				TTC with All Lines In Service	3725 MW	
<b>PANNELL_-CLAY__345_2</b>					FWD (Import)	REV (Export)
Mon 10/05/2026	to	Fri 10/09/2026		WEST CENTRAL	<b>1300 MW</b>	
0700	Continuous	1530		Impacts Total Transfer Capability	950 MW	
Work scheduled by: NYPA				TTC with All Lines In Service	2250 MW	
<b>NEPTUNE_-DUFFYAVE_345_NEPTUNE</b>					FWD (Import)	REV (Export)
Mon 10/12/2026	to	Thu 10/15/2026		SCH - PJM_NEPTUNE	<b>0 MW</b>	
0600	Continuous	1600		Impacts Total Transfer Capability	660 MW	
Work scheduled by: LI				TTC with All Lines In Service	660 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, July 24, 2025 to Saturday, January 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### NEWBRDGE\_345\_138\_BK\_1

Mon 10/12/2026 to Thu 10/15/2026  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM_NEPTUNE	FWD (Import)	REV (Export)
	<b>375 MW</b>	
Impacts Total Transfer Capability	285 MW	
TTC with All Lines In Service	660 MW	

### NEWBRDGE\_345\_138\_BK\_2

Mon 10/12/2026 to Thu 10/15/2026  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM_NEPTUNE	FWD (Import)	REV (Export)
	<b>375 MW</b>	
Impacts Total Transfer Capability	285 MW	
TTC with All Lines In Service	660 MW	

### NEWBRDGE-DUFFYAVE\_345\_501

Mon 10/12/2026 to Thu 10/15/2026  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM_NEPTUNE	FWD (Import)	REV (Export)
	<b>0 MW</b>	
Impacts Total Transfer Capability	660 MW	
TTC with All Lines In Service	660 MW	

### CHATGUAY-MASSENA\_765\_7040

Wed 10/14/2026 to Wed 10/28/2026  
0001 Continuous 2359  
Work scheduled by: NYPA

SCH - HQ - NY	FWD (Import)	REV (Export)
	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	1500 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

### CHATGUAY-MASSENA\_765\_7040

Wed 10/14/2026 to Wed 10/28/2026  
0001 Continuous 2359  
Work scheduled by: NYPA

MOSES SOUTH	FWD (Import)	REV (Export)
	<b>1550 MW</b>	
Impacts Total Transfer Capability	1600 MW	
TTC with All Lines In Service	3150 MW	

### CHATGUAY-MASSENA\_765\_7040 , MASSENA-MARCY\_765\_MSU1

Wed 10/14/2026 to Wed 10/28/2026  
0001 2359  
Work scheduled by:

MOSES SOUTH	FWD (Import)	REV (Export)
	<b>500 MW</b>	
Impacts Total Transfer Capability	2650 MW	
TTC with All Lines In Service	3150 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, July 24, 2025 to Saturday, January 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MARCY\_\_\_765\_345\_AT1

Wed 10/14/2026 to Wed 10/28/2026  
0001 Continuous 2359  
Work scheduled by: NYPA

ARR: 19

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

**1750 MW**

1400 MW

3150 MW

REV (Export)

### MARCY\_\_\_765\_345\_AT2

Wed 10/14/2026 to Wed 10/28/2026  
0001 Continuous 2359  
Work scheduled by: NYPA

ARR: 19

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

**1700 MW**

1450 MW

3150 MW

REV (Export)

### MASSENA\_-MARCY\_\_\_765\_MSU1

Wed 10/14/2026 to Wed 10/28/2026  
0001 Continuous 2359  
Work scheduled by: NYPA

SCH - HQ\_CEDARS

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

**90 MW**

180 MW

270 MW

REV (Export)

### MASSENA\_-MARCY\_\_\_765\_MSU1

Wed 10/14/2026 to Wed 10/28/2026  
0001 Continuous 2359  
Work scheduled by: NYPA

SCH - HQ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

**475 MW**

1025 MW

1500 MW

REV (Export)

**1000 MW**

0 MW

1000 MW

### MASSENA\_-MARCY\_\_\_765\_MSU1

Wed 10/14/2026 to Wed 10/28/2026  
0001 Continuous 2359  
Work scheduled by: NYPA

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

**500 MW**

2650 MW

3150 MW

REV (Export)

### MASSENA\_-MARCY\_\_\_765\_MSU1

Wed 10/14/2026 to Wed 10/28/2026  
0001 Continuous 2359  
Work scheduled by: NYPA

CENTRAL EAST - VC

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

**2595 MW**

1130 MW

3725 MW

REV (Export)

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Thursday, July 24, 2025 to Saturday, January 23, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MOSES__-MASSENA_230_MMS2 , MOSES__-MASSENA_230_MMS1				FWD (Import)	REV (Export)
Wed 10/14/2026	to	Wed 10/28/2026	SCH - HQ_CEDARS	<b>90 MW</b>	
0001		2359	Impacts Total Transfer Capability	180 MW	
Work scheduled by:			TTC with All Lines In Service	270 MW	
MOSES__-MASSENA_230_MMS2 , MOSES__-MASSENA_230_MMS1				FWD (Import)	REV (Export)
Wed 10/14/2026	to	Wed 10/28/2026	SCH - HQ - NY	<b>850 MW</b>	<b>0 MW</b>
0001		2359	Impacts Total Transfer Capability	650 MW	1000 MW
Work scheduled by:			TTC with All Lines In Service	1500 MW	1000 MW
EDIC__-FRASER_345_EF24-40				FWD (Import)	REV (Export)
Mon 11/30/2026	to	Sun 12/06/2026	CENTRAL EAST - VC	<b>3225 MW</b>	
0700	Continuous	1530	Impacts Total Transfer Capability	500 MW	
Work scheduled by: NYPA			TTC with All Lines In Service	3725 MW	
SAND_BAR-PLATSBRG_115_PV20				FWD (Import)	REV (Export)
Mon 12/07/2026	to	Fri 12/11/2026	SCH - NE - NY		
0900	Continuous	1630	Impacts Total Transfer Capability		
Work scheduled by: NYPA			TTC with All Lines In Service		
SAND_BAR-PLATSBRG_115_PV20				FWD (Import)	REV (Export)
Mon 12/07/2026	to	Fri 12/11/2026	CENTRAL EAST - VC	<b>3625 MW</b>	
0900	Continuous	1630	Impacts Total Transfer Capability	100 MW	
Work scheduled by: NYPA			TTC with All Lines In Service	3725 MW	