

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Friday, July 25, 2025 to Sunday, January 24, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### HUDSONP\_-FARRAGUT\_345\_B3402

FWD (Import) REV (Export)

Mon 01/15/2018 to Sat 11/01/2025  
0001 Continuous 0100  
Work scheduled by: ConEd

EXT FORCED by ConEd 03/11/2024 11:26

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

### MARION\_-FARRAGUT\_345\_C3403

FWD (Import) REV (Export)

Mon 01/15/2018 to Sat 11/01/2025  
0001 Continuous 0100  
Work scheduled by: ConEd

EXT FORCED by ConEd 03/11/2024 11:26

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

### MARION\_-FARRAGUT\_345\_C3403 , HUDSONP\_-FARRAGUT\_345\_B3402

FWD (Import) REV (Export)

Mon 01/15/2018 to Sat 11/01/2025  
0001 0100  
Work scheduled by:

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

**2000 MW** **1050 MW**  
200 MW 150 MW  
2200 MW 1200 MW

### OSWEGO\_COMPLEX\_AVR\_O/S

FWD (Import) REV (Export)

Wed 01/29/2025 to Sun 09/13/2026  
0001 Continuous 2359  
Work scheduled by: NGrid

FORCED by NGrid 01/27/2025 10:33

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

**3640 MW**  
85 MW  
3725 MW

### DOVER\_-CRICKVLY\_345\_Y17

FWD (Import) REV (Export)

Wed 02/12/2025 to Sun 11/23/2025  
1220 Continuous 2300  
Work scheduled by: NYISO

UPDATED by NYISO 05/27/2025 11:59

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

### DOVER\_-CRICKVLY\_345\_Y17

FWD (Import) REV (Export)

Wed 02/12/2025 to Sun 11/23/2025  
1220 Continuous 2300  
Work scheduled by: NYISO

UPDATED by NYISO 05/27/2025 11:59

SCH - NPX\_1385  
Impacts Total Transfer Capability  
TTC with All Lines In Service

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Friday, July 25, 2025 to Sunday, January 24, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### LONG\_MTN-DOVER\_\_\_345\_398

Wed 02/12/2025 to Sun 11/23/2025  
1221 Continuous 2300  
Work scheduled by: NYISO

UPDATED by NYISO 05/27/2025 11:59

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### LONG\_MTN-DOVER\_\_\_345\_398

Wed 02/12/2025 to Sun 11/23/2025  
1221 Continuous 2300  
Work scheduled by: NYISO

UPDATED by NYISO 05/27/2025 11:59

SCH - NPX\_1385  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### SCH-NYISO-HQ\_CEDARS\_LIMIT\_40

Tue 06/03/2025 to Fri 08/01/2025  
0001 Continuous 0000  
Work scheduled by: HQ

FORCED by HQ 06/02/2025 15:40

SCH - HQ\_CEDARS  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**40 MW**  
60 MW  
100 MW

### SCH-NYISO-HQ\_LIMIT\_0

Fri 07/25/2025 to Fri 07/25/2025  
0500 Continuous 1900  
Work scheduled by: HQ

SCH - HQ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**0 MW**  
1000 MW  
1000 MW

### SCH-HQ-NYISO\_LIMIT\_1400

Fri 07/25/2025 to Fri 07/25/2025  
0600 Continuous 1900  
Work scheduled by: HQ

CANCELLED by TO 07/23/2025 16:23

SCH - HQ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**1400 MW**  
100 MW  
1500 MW

### SCH-NYISO-HQ\_LIMIT\_750

Mon 07/28/2025 to Tue 07/29/2025  
0600 Continuous 1900  
Work scheduled by: HQ

CANCELLED by NYISO 07/24/2025 11:23

SCH - HQ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**750 MW**  
250 MW  
1000 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Friday, July 25, 2025 to Sunday, January 24, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### DYSINGER-STA\_255\_345\_DH2

Wed 07/30/2025 to Sun 08/10/2025  
0500 Continuous 1900  
Work scheduled by: NYPA

UPDATED by NYPA 07/22/2025 13:35

DYSINGER EAST  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**2850 MW**  
350 MW  
3200 MW

### HOMRC-NY-MAINS\_NY\_345\_47

Wed 07/30/2025 to Fri 08/08/2025  
0700 Continuous 1500  
Work scheduled by: NYSEG

UPDATED by NYSEG 07/22/2025 11:30

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### W49TH\_ST\_345KV\_6

Sat 08/02/2025 to Sat 08/02/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

SCH - PJM\_HTP  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**300 MW**  
360 MW  
660 MW

### CEDARS\_-ROSEMNTA\_115\_1/11

Tue 08/05/2025 to Wed 08/06/2025  
0700 Continuous 1800  
Work scheduled by: HQ

SCH - HQ\_CEDARS  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**95 MW 40 MW**  
175 MW 60 MW  
270 MW 100 MW

### DENNISON-ROSEMNTA\_115\_1/11

Tue 08/05/2025 to Wed 08/06/2025  
0700 Continuous 1800  
Work scheduled by: HQ

SCH - HQ\_CEDARS  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**95 MW 40 MW**  
175 MW 60 MW  
270 MW 100 MW

### SAND\_BAR-PLATSBRG\_115\_PV20

Tue 08/05/2025 to Fri 08/08/2025  
0700 Continuous 1630  
Work scheduled by: NYPA

UPDATED by NYPA 03/13/2025 13:53

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Friday, July 25, 2025 to Sunday, January 24, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SAND\_BAR-PLATSBRG\_115\_PV20

Tue 08/05/2025 to Fri 08/08/2025  
0700 Continuous 1630  
Work scheduled by: NYPA

UPDATED by NYPA 03/13/2025 13:53

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3625 MW**  
100 MW  
3725 MW

### SCH-HQ\_CEDARS-NYISO\_LIMIT\_80

Tue 08/05/2025 to Wed 08/06/2025  
0700 Continuous 1800  
Work scheduled by: HQ

SCH - HQ\_CEDARS  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**80 MW**  
190 MW  
270 MW

### BECK\_\_-NIAGARA\_345\_PA301

Tue 08/05/2025 to Fri 08/08/2025  
0800 Continuous 1600  
Work scheduled by: IESO

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1000 MW** **850 MW**  
1000 MW 750 MW  
2000 MW 1600 MW

### EDIC\_\_-GORDONRD\_345\_14

Sat 08/09/2025 to Sun 08/10/2025  
0630 Continuous 1700  
Work scheduled by: NGrid

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**2770 MW**  
955 MW  
3725 MW

### EDIC\_\_-FRASER\_345\_EF24-40

Mon 08/11/2025 to Fri 08/15/2025  
0830 Continuous 1400  
Work scheduled by: NYSEG

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3225 MW**  
500 MW  
3725 MW

### ADIRNDCK-CHASLAKE\_230\_13

Wed 08/13/2025 to Wed 08/13/2025  
0700 Daily(No Weekends) 1600  
Work scheduled by: NGrid

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**2100 MW**  
1050 MW  
3150 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Friday, July 25, 2025 to Sunday, January 24, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### CEDARS\_-ROSEMNTB\_115\_2/22

Wed 08/13/2025 to Thu 08/14/2025  
0700 Continuous 1800  
Work scheduled by: HQ

SCH - HQ_CEDARS	FWD (Import)	REV (Export)
	<b>95 MW</b>	<b>40 MW</b>
Impacts Total Transfer Capability	175 MW	60 MW
TTC with All Lines In Service	270 MW	100 MW

### DENNISON-ROSEMNTB\_115\_2/22

Wed 08/13/2025 to Thu 08/14/2025  
0700 Continuous 1800  
Work scheduled by: HQ

SCH - HQ_CEDARS	FWD (Import)	REV (Export)
	<b>95 MW</b>	<b>40 MW</b>
Impacts Total Transfer Capability	175 MW	60 MW
TTC with All Lines In Service	270 MW	100 MW

### SCH-HQ\_CEDARS-NYISO\_LIMIT\_80

Wed 08/13/2025 to Thu 08/14/2025  
0700 Continuous 1800  
Work scheduled by: HQ

SCH - HQ_CEDARS	FWD (Import)	REV (Export)
	<b>80 MW</b>	
Impacts Total Transfer Capability	190 MW	
TTC with All Lines In Service	270 MW	

### ADIRNDCK-CHASLAKE\_230\_13

Thu 08/14/2025 to Thu 08/14/2025  
0700 Daily(No Weekends) 1600  
Work scheduled by: NGrid

MOSES SOUTH	FWD (Import)	REV (Export)
	<b>2100 MW</b>	
Impacts Total Transfer Capability	1050 MW	
TTC with All Lines In Service	3150 MW	

### ADIRNDCK-CHASLAKE\_230\_13

Fri 08/15/2025 to Fri 08/15/2025  
0700 Daily(No Weekends) 1600  
Work scheduled by: NGrid

MOSES SOUTH	FWD (Import)	REV (Export)
	<b>2100 MW</b>	
Impacts Total Transfer Capability	1050 MW	
TTC with All Lines In Service	3150 MW	

### W49TH\_ST\_345KV\_5

Sat 08/16/2025 to Mon 08/18/2025  
0001 Continuous 0100  
Work scheduled by: ConEd

SCH - PJM_HTP	FWD (Import)	REV (Export)
	<b>460 MW</b>	
Impacts Total Transfer Capability	200 MW	
TTC with All Lines In Service	660 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Friday, July 25, 2025 to Sunday, January 24, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### W49TH\_ST\_345KV\_7

Sat 08/16/2025 to Mon 08/18/2025  
0001 Continuous 0100  
Work scheduled by: ConEd

SCH - PJM\_HTP

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**460 MW**

200 MW

660 MW

### ADIRNDCK-CHASLAKE\_230\_13

Mon 08/18/2025 to Mon 08/18/2025  
0700 Daily(No Weekends) 1600  
Work scheduled by: NGrid

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**2100 MW**

1050 MW

3150 MW

### ADIRNDCK-CHASLAKE\_230\_13

Tue 08/19/2025 to Tue 08/19/2025  
0700 Daily(No Weekends) 1600  
Work scheduled by: NGrid

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**2100 MW**

1050 MW

3150 MW

### ADIRNDCK-CHASLAKE\_230\_13

Wed 08/20/2025 to Wed 08/20/2025  
0700 Daily(No Weekends) 1600  
Work scheduled by: NGrid

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**2100 MW**

1050 MW

3150 MW

### ADIRNDCK-CHASLAKE\_230\_13

Thu 08/21/2025 to Thu 08/21/2025  
0700 Daily(No Weekends) 1600  
Work scheduled by: NGrid

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**2100 MW**

1050 MW

3150 MW

### ADIRNDCK-CHASLAKE\_230\_13

Fri 08/22/2025 to Fri 08/22/2025  
0700 Daily(No Weekends) 1600  
Work scheduled by: NGrid

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**2100 MW**

1050 MW

3150 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Friday, July 25, 2025 to Sunday, January 24, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### BUCHAN\_S-MILLWOOD\_345\_W98

Sat 08/23/2025 to Sun 08/24/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **8015 MW**  
REV (Export) 35 MW  
8050 MW

### WOOD\_ST-PLSNTVLE\_345\_Y86

Mon 09/01/2025 to Wed 09/03/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **7475 MW**  
REV (Export) 575 MW  
8050 MW

### DYSINGER-STA\_255\_345\_DH1

Tue 09/02/2025 to Mon 09/15/2025  
0500 Continuous 2100  
Work scheduled by: NYPA

DYSINGER EAST  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **2850 MW**  
REV (Export) 350 MW  
3200 MW

### MOSES\_\_-ADIRNDCK\_230\_MA1

Tue 09/02/2025 to Sun 10/12/2025  
0700 Continuous 1730  
Work scheduled by: NYPA

UPDATED by NYPA 05/20/2025 13:57

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **2100 MW**  
REV (Export) 1050 MW  
3150 MW

### MARCY\_\_-N.SCTLND\_345\_18

Wed 09/03/2025 to Wed 09/03/2025  
0830 Continuous 1130  
Work scheduled by: NGrid

ARR: 19

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **2665 MW**  
REV (Export) 1060 MW  
3725 MW

### W49TH\_ST\_345KV\_6

Fri 09/05/2025 to Fri 09/05/2025  
0001 Continuous 0030  
Work scheduled by: ConEd

SCH - PJM\_HTP  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **300 MW**  
REV (Export) 360 MW  
660 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Friday, July 25, 2025 to Sunday, January 24, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### W49TH\_ST\_345KV\_8

Fri 09/05/2025 to Fri 09/05/2025  
0001 Continuous 0030  
Work scheduled by: ConEd

SCH - PJM\_HTP

FWD (Import) REV (Export)

Impacts Total Transfer Capability

**350 MW**

TTC with All Lines In Service

310 MW

660 MW

### W49TH\_ST\_345KV\_6

Fri 09/05/2025 to Fri 09/05/2025  
2130 Continuous 2200  
Work scheduled by: ConEd

SCH - PJM\_HTP

FWD (Import) REV (Export)

Impacts Total Transfer Capability

**300 MW**

TTC with All Lines In Service

360 MW

660 MW

### W49TH\_ST\_345KV\_8

Fri 09/05/2025 to Fri 09/05/2025  
2130 Continuous 2200  
Work scheduled by: ConEd

SCH - PJM\_HTP

FWD (Import) REV (Export)

Impacts Total Transfer Capability

**350 MW**

TTC with All Lines In Service

310 MW

660 MW

### HOMRC\_NY-MAINS\_NY\_345\_47

Mon 09/08/2025 to Mon 10/06/2025  
0800 Continuous 1600  
Work scheduled by: NYSEG

SCH - PJ - NY

FWD (Import) REV (Export)

Impacts Total Transfer Capability

TTC with All Lines In Service

### GORDONRD-ROTTDAM\_230\_30

Tue 09/09/2025 to Wed 09/10/2025  
0830 Continuous 1430  
Work scheduled by: NGrid

CENTRAL EAST - VC

FWD (Import) REV (Export)

Impacts Total Transfer Capability

TTC with All Lines In Service

**3690 MW**

35 MW

3725 MW

### SCH-NE-NYISO\_LIMIT\_900

Fri 09/12/2025 to Fri 09/12/2025  
0800 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY

FWD (Import) REV (Export)

Impacts Total Transfer Capability

TTC with All Lines In Service

**1100 MW**

300 MW

1400 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Friday, July 25, 2025 to Sunday, January 24, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_1000

Fri 09/12/2025 to Sat 09/13/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1200 MW**  
200 MW  
1400 MW

### MILLWOOD-EASTVIEW\_345\_W82

Sat 09/13/2025 to Sat 09/13/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**7810 MW**  
240 MW  
8050 MW

### SPRNBK\_345KV\_RNS4

Sat 09/13/2025 to Sat 09/13/2025  
0001 Continuous 0030  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3200 MW**  
1400 MW  
4600 MW

### SCH-NE-NYISO\_LIMIT\_900

Sat 09/13/2025 to Sat 09/13/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1100 MW**  
300 MW  
1400 MW

### SPRNBK\_345KV\_RNS4

Sat 09/13/2025 to Sat 09/13/2025  
2130 Continuous 2200  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3200 MW**  
1400 MW  
4600 MW

### SCH-NE-NYISO\_LIMIT\_1000

Sat 09/13/2025 to Sun 09/14/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1200 MW**  
200 MW  
1400 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Friday, July 25, 2025 to Sunday, January 24, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_900

Sun 09/14/2025 to Sun 09/14/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)  
Impacts Total Transfer Capability **1100 MW**  
TTC with All Lines In Service 300 MW  
1400 MW

### SCH-NE-NYISO\_LIMIT\_1000

Sun 09/14/2025 to Mon 09/15/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY FWD (Import) REV (Export)  
Impacts Total Transfer Capability **1200 MW**  
TTC with All Lines In Service 200 MW  
1400 MW

### RAMAPO\_-BUCHAN\_N\_345\_Y94

Mon 09/15/2025 to Wed 09/17/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

UPDATED by ConEd 06/18/2025 12:30

UPNY CONED FWD (Import) REV (Export)  
Impacts Total Transfer Capability **7755 MW**  
TTC with All Lines In Service 295 MW  
8050 MW

### SPRNBK\_345KV\_RNS4

Mon 09/15/2025 to Thu 10/02/2025  
0001 Continuous 0200  
Work scheduled by: ConEd

SPR/DUN-SOUTH FWD (Import) REV (Export)  
Impacts Total Transfer Capability **3200 MW**  
TTC with All Lines In Service 1400 MW  
4600 MW

### SPRNBK\_-W49TH\_ST\_345\_M52

Mon 09/15/2025 to Thu 10/02/2025  
0001 Continuous 0200  
Work scheduled by: ConEd

SPR/DUN-SOUTH FWD (Import) REV (Export)  
Impacts Total Transfer Capability **3200 MW**  
TTC with All Lines In Service 1400 MW  
4600 MW

### W49TH\_ST\_345KV\_5

Mon 09/15/2025 to Mon 09/15/2025  
0001 Continuous 0030  
Work scheduled by: ConEd

SCH - PJM\_HTP FWD (Import) REV (Export)  
Impacts Total Transfer Capability **460 MW**  
TTC with All Lines In Service 200 MW  
660 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Friday, July 25, 2025 to Sunday, January 24, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### GOETHALS\_345KV\_5

Mon 09/15/2025 to Mon 09/15/2025  
0230 Continuous 0300  
Work scheduled by: ConEd

STATEN ISLAND  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### ADIRNDCK-PORTER\_\_230\_12

Mon 09/15/2025 to Sun 10/12/2025  
0600 Continuous 1700  
Work scheduled by: NGrid

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**2100 MW**  
1050 MW  
3150 MW

### MARCY\_\_345KV\_CSC

Mon 09/15/2025 to Wed 09/24/2025  
0600 Continuous 1730  
Work scheduled by: NYPA

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**3650 MW**  
75 MW  
3725 MW

### DOVER\_\_CRICKVLY\_345\_Y17 , NRTH1385-NORHBR\_\_138\_601

Mon 09/15/2025 to Fri 10/10/2025  
0700 1500  
Work scheduled by:

SCH - NPX\_1385  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### DOVER\_\_CRICKVLY\_345\_Y17 , NRTH1385-NORHBR\_\_138\_602

Mon 09/15/2025 to Fri 10/10/2025  
0700 1500  
Work scheduled by:

SCH - NPX\_1385  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### DOVER\_\_CRICKVLY\_345\_Y17 , NRTH1385-NORHBR\_\_138\_603

Mon 09/15/2025 to Fri 10/10/2025  
0700 1500  
Work scheduled by:

SCH - NPX\_1385  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Friday, July 25, 2025 to Sunday, January 24, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>LONG_MTN-DOVER___345_398 , NRTH1385-NORHBR__138_601</b>				FWD (Import)	REV (Export)
Mon 09/15/2025	to	Fri 10/10/2025	SCH - NPX_1385		
0700		1500	Impacts Total Transfer Capability		
Work scheduled by:			TTC with All Lines In Service		
<b>LONG_MTN-DOVER___345_398 , NRTH1385-NORHBR__138_602</b>				FWD (Import)	REV (Export)
Mon 09/15/2025	to	Fri 10/10/2025	SCH - NPX_1385		
0700		1500	Impacts Total Transfer Capability		
Work scheduled by:			TTC with All Lines In Service		
<b>LONG_MTN-DOVER___345_398 , NRTH1385-NORHBR__138_603</b>				FWD (Import)	REV (Export)
Mon 09/15/2025	to	Fri 10/10/2025	SCH - NPX_1385		
0700		1500	Impacts Total Transfer Capability		
Work scheduled by:			TTC with All Lines In Service		
<b>NRTH1385-NOR HBR__138_601</b>				FWD (Import)	REV (Export)
Mon 09/15/2025	to	Fri 10/10/2025	SCH - NPX_1385	<b>25 MW</b>	<b>25 MW</b>
0700	Continuous	1500	Impacts Total Transfer Capability	100 MW	100 MW
Work scheduled by: LI			TTC with All Lines In Service	125 MW	125 MW
<b>NRTH1385-NOR HBR__138_602</b>				FWD (Import)	REV (Export)
Mon 09/15/2025	to	Fri 10/10/2025	SCH - NPX_1385	<b>25 MW</b>	<b>25 MW</b>
0700	Continuous	1500	Impacts Total Transfer Capability	100 MW	100 MW
Work scheduled by: LI			TTC with All Lines In Service	125 MW	125 MW
<b>NRTH1385-NOR HBR__138_603</b>				FWD (Import)	REV (Export)
Mon 09/15/2025	to	Fri 10/10/2025	SCH - NPX_1385	<b>25 MW</b>	<b>25 MW</b>
0700	Continuous	1500	Impacts Total Transfer Capability	100 MW	100 MW
Work scheduled by: LI			TTC with All Lines In Service	125 MW	125 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Friday, July 25, 2025 to Sunday, January 24, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>NRTH1385-NORHBR_138_601 , NRTH1385-NORHBR_138_602</b>				FWD (Import)	REV (Export)
Mon 09/15/2025	to	Fri 10/10/2025	SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
0700		1500	Impacts Total Transfer Capability	125 MW	125 MW
Work scheduled by:			TTC with All Lines In Service	125 MW	125 MW
<b>NRTH1385-NORHBR_138_601 , NRTH1385-NORHBR_138_603</b>				FWD (Import)	REV (Export)
Mon 09/15/2025	to	Fri 10/10/2025	SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
0700		1500	Impacts Total Transfer Capability	125 MW	125 MW
Work scheduled by:			TTC with All Lines In Service	125 MW	125 MW
<b>NRTH1385-NORHBR_138_602 , NRTH1385-NORHBR_138_603</b>				FWD (Import)	REV (Export)
Mon 09/15/2025	to	Fri 10/10/2025	SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
0700		1500	Impacts Total Transfer Capability	125 MW	125 MW
Work scheduled by:			TTC with All Lines In Service	125 MW	125 MW
<b>NRTH1385-NRTHPORT_138_NNC</b>				FWD (Import)	REV (Export)
Mon 09/15/2025	to	Fri 10/10/2025	SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
0700	Continuous	1500	Impacts Total Transfer Capability	125 MW	125 MW
Work scheduled by: LI			TTC with All Lines In Service	125 MW	125 MW
<b>SCH-NE-NYISO_LIMIT_900</b>				FWD (Import)	REV (Export)
Mon 09/15/2025	to	Mon 09/15/2025	SCH - NE - NY	<b>1100 MW</b>	
0700	Daily	2259	Impacts Total Transfer Capability	300 MW	
Work scheduled by: ISONE			TTC with All Lines In Service	1400 MW	
<b>SCH-NE-NYISO_LIMIT_1000</b>				FWD (Import)	REV (Export)
Mon 09/15/2025	to	Tue 09/16/2025	SCH - NE - NY	<b>1200 MW</b>	
2300	Daily	0659	Impacts Total Transfer Capability	200 MW	
Work scheduled by: ISONE			TTC with All Lines In Service	1400 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Friday, July 25, 2025 to Sunday, January 24, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### DYSINGER-STA\_255\_345\_DH2

Tue 09/16/2025 to Tue 10/28/2025  
0500 Continuous 1900  
Work scheduled by: NYPA

DYSINGER EAST  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>2850 MW</b>	
350 MW	
3200 MW	

### SCH-NE-NYISO\_LIMIT\_900

Tue 09/16/2025 to Tue 09/16/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>1100 MW</b>	
300 MW	
1400 MW	

### SCH-NE-NYISO\_LIMIT\_1000

Tue 09/16/2025 to Wed 09/17/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>1200 MW</b>	
200 MW	
1400 MW	

### SCH-NE-NYISO\_LIMIT\_900

Wed 09/17/2025 to Wed 09/17/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>1100 MW</b>	
300 MW	
1400 MW	

### SCH-NE-NYISO\_LIMIT\_1000

Wed 09/17/2025 to Thu 09/18/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>1200 MW</b>	
200 MW	
1400 MW	

### RAMAPO\_-BUCHAN\_N\_345\_Y94

Thu 09/18/2025 to Sat 09/20/2025  
0001 Continuous 0259  
Work scheduled by: ConEd

EXTENDED by ConEd 06/12/2025 10:19

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>7755 MW</b>	
295 MW	
8050 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Friday, July 25, 2025 to Sunday, January 24, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_900

Thu 09/18/2025 to Thu 09/18/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1100 MW**  
300 MW  
1400 MW

### SCH-NE-NYISO\_LIMIT\_1000

Thu 09/18/2025 to Fri 09/19/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1200 MW**  
200 MW  
1400 MW

### SCH-NE-NYISO\_LIMIT\_900

Fri 09/19/2025 to Fri 09/19/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1100 MW**  
300 MW  
1400 MW

### SCH-NE-NYISO\_LIMIT\_1000

Fri 09/19/2025 to Sat 09/20/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1200 MW**  
200 MW  
1400 MW

### SCH-NE-NYISO\_LIMIT\_900

Sat 09/20/2025 to Sat 09/20/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1100 MW**  
300 MW  
1400 MW

### SCH-NE-NYISO\_LIMIT\_1000

Sat 09/20/2025 to Sun 09/21/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1200 MW**  
200 MW  
1400 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Friday, July 25, 2025 to Sunday, January 24, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_900

Sun 09/21/2025 to Sun 09/21/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1100 MW**  
300 MW  
1400 MW

### SCH-NE-NYISO\_LIMIT\_1000

Sun 09/21/2025 to Mon 09/22/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1200 MW**  
200 MW  
1400 MW

### WOOD\_ST\_PLSNTVLE\_345\_Y86

Mon 09/22/2025 to Fri 09/26/2025  
0001 Continuous 0200  
Work scheduled by: ConEd

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**7475 MW**  
575 MW  
8050 MW

### SCH-NE-NYISO\_LIMIT\_900

Mon 09/22/2025 to Mon 09/22/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1100 MW**  
300 MW  
1400 MW

### SCH-NE-NYISO\_LIMIT\_1000

Mon 09/22/2025 to Tue 09/23/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1200 MW**  
200 MW  
1400 MW

### SCH-NE-NYISO\_LIMIT\_900

Tue 09/23/2025 to Tue 09/23/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1100 MW**  
300 MW  
1400 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Friday, July 25, 2025 to Sunday, January 24, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_1000

Tue 09/23/2025 to Wed 09/24/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1200 MW**  
200 MW  
1400 MW

### SCH-NE-NYISO\_LIMIT\_900

Wed 09/24/2025 to Wed 09/24/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1100 MW**  
300 MW  
1400 MW

### SCH-NE-NYISO\_LIMIT\_1000

Wed 09/24/2025 to Thu 09/25/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1200 MW**  
200 MW  
1400 MW

### MARCY\_\_FRASANNX\_345\_UCC2-41

Thu 09/25/2025 to Fri 10/17/2025  
0700 Continuous 1730  
Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3225 MW**  
500 MW  
3725 MW

### SCH-NE-NYISO\_LIMIT\_900

Thu 09/25/2025 to Thu 09/25/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1100 MW**  
300 MW  
1400 MW

### SCH-NE-NYISO\_LIMIT\_1000

Thu 09/25/2025 to Fri 09/26/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1200 MW**  
200 MW  
1400 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Friday, July 25, 2025 to Sunday, January 24, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_900

Fri 09/26/2025 to Fri 09/26/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1100 MW**  
300 MW  
1400 MW

### SCH-NE-NYISO\_LIMIT\_600

Fri 09/26/2025 to Sat 09/27/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**800 MW**  
600 MW  
1400 MW

### SCH-NE-NYISO\_LIMIT\_900

Sat 09/27/2025 to Sat 09/27/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1100 MW**  
300 MW  
1400 MW

### SCH-NE-NYISO\_LIMIT\_600

Sat 09/27/2025 to Sun 09/28/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**800 MW**  
600 MW  
1400 MW

### SCH-NE-NYISO\_LIMIT\_900

Sun 09/28/2025 to Sun 09/28/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1100 MW**  
300 MW  
1400 MW

### SCH-NE-NYISO\_LIMIT\_600

Sun 09/28/2025 to Mon 09/29/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**800 MW**  
600 MW  
1400 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Friday, July 25, 2025 to Sunday, January 24, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### PANNELL\_CLAY\_345\_1

Mon 09/29/2025 to Fri 10/03/2025  
0700 Continuous 1530  
Work scheduled by: NYPA

WEST CENTRAL  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 1300 MW  
REV (Export) 950 MW  
2250 MW

### SCH-NE-NYISO\_LIMIT\_900

Mon 09/29/2025 to Mon 09/29/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 1100 MW  
REV (Export) 300 MW  
1400 MW

### SCH-NE-NYISO\_LIMIT\_600

Mon 09/29/2025 to Tue 09/30/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 800 MW  
REV (Export) 600 MW  
1400 MW

### SCH-NE-NYISO\_LIMIT\_900

Tue 09/30/2025 to Tue 09/30/2025  
0700 Daily 0800  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 1100 MW  
REV (Export) 300 MW  
1400 MW

### DUNWODIE\_345KV\_6

Wed 10/01/2025 to Sat 10/04/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 3800 MW  
REV (Export) 800 MW  
4600 MW

### DUNWODIE\_345KV\_8

Wed 10/01/2025 to Sat 10/04/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 3800 MW  
REV (Export) 800 MW  
4600 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Friday, July 25, 2025 to Sunday, January 24, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### W49TH\_ST\_345KV\_5

Thu 10/02/2025 to Thu 10/02/2025  
0130 Continuous 0200  
Work scheduled by: ConEd

SCH - PJM\_HTP

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**460 MW**

200 MW

660 MW

### PANNELL-CLAY\_345\_2

Mon 10/06/2025 to Fri 10/10/2025  
0700 Continuous 1530  
Work scheduled by: NYPA

WEST CENTRAL

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**1300 MW**

950 MW

2250 MW

### ROCHESTR-PANNELL\_345\_RP2

Mon 10/06/2025 to Wed 10/08/2025  
0730 Continuous 1500  
Work scheduled by: RGE

DYSINGER EAST

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**2300 MW**

900 MW

3200 MW

### MILLWOOD-EASTVIEW\_345\_W85

Fri 10/10/2025 to Sun 10/19/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

UPNY CONED

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**7810 MW**

240 MW

8050 MW

### SPRNBK\_345KV\_RNS3

Fri 10/10/2025 to Fri 10/10/2025  
0001 Continuous 0030  
Work scheduled by: ConEd

SPR/DUN-SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**3800 MW**

800 MW

4600 MW

### DUNWODIE\_345KV\_3

Mon 10/13/2025 to Mon 10/13/2025  
0001 Continuous 0030  
Work scheduled by: ConEd

SPR/DUN-SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**3800 MW**

800 MW

4600 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Friday, July 25, 2025 to Sunday, January 24, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### DUNWODIE\_345KV\_5

Mon 10/13/2025 to Mon 10/13/2025  
0001 Continuous 0030  
Work scheduled by: ConEd

SPR/DUN-SOUTH FWD (Import) REV (Export)  
Impacts Total Transfer Capability **3800 MW**  
TTC with All Lines In Service 800 MW  
4600 MW

### DUNWODIE-MOTTHAVN\_345\_71

Mon 10/13/2025 to Tue 10/14/2025  
0001 Continuous 0200  
Work scheduled by: ConEd

SPR/DUN-SOUTH FWD (Import) REV (Export)  
Impacts Total Transfer Capability **3800 MW**  
TTC with All Lines In Service 800 MW  
4600 MW

### NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE

Mon 10/13/2025 to Thu 10/16/2025  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE FWD (Import) REV (Export)  
Impacts Total Transfer Capability **0 MW**  
TTC with All Lines In Service 660 MW  
660 MW

### NEWBRDGE\_345\_138\_BK\_1

Mon 10/13/2025 to Thu 10/16/2025  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE FWD (Import) REV (Export)  
Impacts Total Transfer Capability **375 MW**  
TTC with All Lines In Service 285 MW  
660 MW

### NEWBRDGE\_345\_138\_BK\_2

Mon 10/13/2025 to Thu 10/16/2025  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE FWD (Import) REV (Export)  
Impacts Total Transfer Capability **375 MW**  
TTC with All Lines In Service 285 MW  
660 MW

### NEWBRDGE-DUFFYAVE\_345\_501

Mon 10/13/2025 to Thu 10/16/2025  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE FWD (Import) REV (Export)  
Impacts Total Transfer Capability **0 MW**  
TTC with All Lines In Service 660 MW  
660 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Friday, July 25, 2025 to Sunday, January 24, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MOSES\_\_ADIRNDCK\_230\_MA2

Mon 10/13/2025 to Sat 11/15/2025  
0700 Continuous 1730  
Work scheduled by: NYPA

UPDATED by NYPA 02/21/2025 15:57

MOSES SOUTH  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

FWD (Import) REV (Export)

### DUNWODIE\_345KV\_3

Tue 10/14/2025 to Tue 10/14/2025  
0130 Continuous 0200  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

### DUNWODIE\_345KV\_5

Tue 10/14/2025 to Tue 10/14/2025  
0130 Continuous 0200  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

### EDIC\_\_PRINCTWN\_345\_351

Tue 10/14/2025 to Fri 10/17/2025  
0600 Continuous 1830  
Work scheduled by: NGrid

CENTRAL EAST - VC  
Impacts Total Transfer Capability 390 MW  
TTC with All Lines In Service 3725 MW

FWD (Import) REV (Export)

### MARCY\_\_765\_345\_AT2

Wed 10/15/2025 to Wed 10/15/2025  
0500 Continuous 1730  
Work scheduled by: NYPA

UPDATED by NYPA 04/22/2025 12:32

ARR: 19

MOSES SOUTH  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

FWD (Import) REV (Export)

### SPRNBK\_345KV\_RNS3

Sun 10/19/2025 to Sun 10/19/2025  
2130 Continuous 2200  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Friday, July 25, 2025 to Sunday, January 24, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### E13THSTA-FARRAGUT\_345\_45

Mon 10/20/2025 to Sat 10/25/2025  
0001 Continuous 0159  
Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

### W49TH\_ST-E13THSTA\_345\_M54

Mon 10/20/2025 to Sat 10/25/2025  
0001 Continuous 0159  
Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

### GOETHALS\_345KV\_5

Wed 10/22/2025 to Thu 10/23/2025  
0001 Continuous 0200  
Work scheduled by: ConEd

EXTENDED by ConEd 05/27/2025 11:13

STATEN ISLAND  
Impacts Total Transfer Capability  
TTC with All Lines In Service

### HUDSONP\_FARRAGUT\_345\_B3402 , LINDEN\_GOETHALS\_230\_A2253

Wed 10/22/2025 to Thu 10/23/2025  
0001 0200  
Work scheduled by:

SCH - PJ - NY **2000 MW** **1000 MW**  
Impacts Total Transfer Capability 200 MW 200 MW  
TTC with All Lines In Service 2200 MW 1200 MW

### LINDEN\_GOETHALS\_230\_A2253

Wed 10/22/2025 to Thu 10/23/2025  
0001 Continuous 0200  
Work scheduled by: ConEd

EXTENDED by ConEd 05/27/2025 11:13

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

### LONG\_MTN-CRICKVLY\_345\_398

Wed 10/22/2025 to Fri 11/21/2025  
0001 Continuous 2300  
Work scheduled by: ConEd

UPDATED by ConEd 07/23/2025 12:25

SCH - NPX\_1385 **25 MW** **25 MW**  
Impacts Total Transfer Capability 100 MW 100 MW  
TTC with All Lines In Service 125 MW 125 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Friday, July 25, 2025 to Sunday, January 24, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### LONG\_MTN-CRICKVLY\_345\_398

Wed 10/22/2025 to Fri 11/21/2025  
0001 Continuous 2300  
Work scheduled by: ConEd

UPDATED by ConEd 07/23/2025 12:25

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>800 MW</b>	<b>1200 MW</b>
600 MW	400 MW
1400 MW	1600 MW

### MARION\_-FARRAGUT\_345\_C3403 , HUDSONP\_-FARRAGUT\_345\_B3402 , LINDEN\_-GOETHALS\_230\_A2253

Wed 10/22/2025 to Thu 10/23/2025  
0001 0200  
Work scheduled by:

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>2000 MW</b>	<b>1000 MW</b>
200 MW	200 MW
2200 MW	1200 MW

### MARION\_-FARRAGUT\_345\_C3403 , LINDEN\_-GOETHALS\_230\_A2253

Wed 10/22/2025 to Thu 10/23/2025  
0001 0200  
Work scheduled by:

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>2000 MW</b>	<b>1000 MW</b>
200 MW	200 MW
2200 MW	1200 MW

### SCH-NE-NYISO\_LIMIT\_500

Wed 10/22/2025 to Fri 11/21/2025  
0001 Continuous 2300  
Work scheduled by: ConEd

UPDATED by ConEd 07/23/2025 12:25

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>700 MW</b>	
700 MW	
1400 MW	

### RAMAPO\_-BUCHAN\_N\_345\_Y94

Fri 10/24/2025 to Fri 10/24/2025  
0001 Continuous 0030  
Work scheduled by: ConEd

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>7755 MW</b>	
295 MW	
8050 MW	

### SPRNBK\_-TREMONT\_345\_X28

Sat 10/25/2025 to Sun 10/26/2025  
0001 Continuous 0200  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>4200 MW</b>	
400 MW	
4600 MW	



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Friday, July 25, 2025 to Sunday, January 24, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### RAMAPO\_\_-BUCHAN\_N\_345\_Y94

Sat 10/25/2025 to Sat 10/25/2025  
0130 Continuous 0200  
Work scheduled by: ConEd

UPNY CONED  
Impacts Total Transfer Capability 295 MW  
TTC with All Lines In Service 8050 MW

FWD (Import) REV (Export)

**7755 MW**

### SPRNBK\_-TREMONT\_345\_X28

Mon 10/27/2025 to Fri 10/31/2025  
0001 Continuous 1800  
Work scheduled by: ConEd

UPDATED by ConEd 04/09/2025 09:25

SPR/DUN-SOUTH  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

**4200 MW**

### FROST\_BR-LONG\_MTN\_345\_352

Mon 10/27/2025 to Wed 10/29/2025  
0830 Continuous 1500  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability 250 MW  
TTC with All Lines In Service 1400 MW

FWD (Import) REV (Export)

**1150 MW**

### EDIC\_\_-GORDONRD\_345\_14

Tue 10/28/2025 to Tue 10/28/2025  
0800 Daily 0900  
Work scheduled by: NGrid

CENTRAL EAST - VC  
Impacts Total Transfer Capability 955 MW  
TTC with All Lines In Service 3725 MW

FWD (Import) REV (Export)

**2770 MW**

### BECK\_\_-NIAGARA\_345\_PA302

Tue 10/28/2025 to Tue 10/28/2025  
0900 Continuous 1700  
Work scheduled by: IESO

SCH - OH - NY  
Impacts Total Transfer Capability 1000 MW 750 MW  
TTC with All Lines In Service 2000 MW 1600 MW

FWD (Import) REV (Export)

**1000 MW**

**850 MW**

### LINDN\_CG-LNDVFT\_\_345\_V-3022

Mon 11/03/2025 to Thu 11/06/2025  
0800 Continuous 1500  
Work scheduled by: PJM

SCH - PJM\_VFT  
Impacts Total Transfer Capability 315 MW 315 MW  
TTC with All Lines In Service 315 MW 315 MW

FWD (Import) REV (Export)

**0 MW**

**0 MW**

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Friday, July 25, 2025 to Sunday, January 24, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MOTTHAVN-RAINEY\_\_345\_Q11

Wed 11/05/2025 to Wed 12/17/2025  
0001 Continuous 0100  
Work scheduled by: ConEd

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

### LINDN\_CG-LNDVFT\_\_345\_V-3022

Thu 11/13/2025 to Thu 11/13/2025  
1500 Continuous 1800  
Work scheduled by: PJM

SCH - PJM_VFT	FWD (Import)	REV (Export)
	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	315 MW	315 MW
TTC with All Lines In Service	315 MW	315 MW

### CHATGUAY-MASSENA\_765\_7040

Sun 11/16/2025 to Sun 11/30/2025  
0001 Continuous 2359  
Work scheduled by: NYPA

SCH - HQ - NY	FWD (Import)	REV (Export)
	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	1500 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

### CHATGUAY-MASSENA\_765\_7040

Sun 11/16/2025 to Sun 11/30/2025  
0001 Continuous 2359  
Work scheduled by: NYPA

MOSES SOUTH	FWD (Import)	REV (Export)
	<b>1550 MW</b>	
Impacts Total Transfer Capability	1600 MW	
TTC with All Lines In Service	3150 MW	

### CHATGUAY-MASSENA\_765\_7040 , MASSENA-MARCY\_\_765\_MSU1

Sun 11/16/2025 to Sun 11/30/2025  
0001 2359  
Work scheduled by:

MOSES SOUTH	FWD (Import)	REV (Export)
	<b>500 MW</b>	
Impacts Total Transfer Capability	2650 MW	
TTC with All Lines In Service	3150 MW	

### MARCY\_\_765\_345\_AT1

Sun 11/16/2025 to Sun 11/30/2025 UPDATED by NYPA 02/21/2025 15:46  
0001 Continuous 2359  
Work scheduled by: NYPA

ARR: 19

MOSES SOUTH	FWD (Import)	REV (Export)
	<b>1750 MW</b>	
Impacts Total Transfer Capability	1400 MW	
TTC with All Lines In Service	3150 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Friday, July 25, 2025 to Sunday, January 24, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MARCY\_\_\_765\_345\_AT2

Sun 11/16/2025 to Sun 11/30/2025  
0001 Continuous 2359  
Work scheduled by: NYPA

UPDATED by NYPA 02/21/2025 15:46  
ARR: 19

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1700 MW**  
1450 MW  
3150 MW

### MASSENA\_-MARCY\_\_\_765\_MSU1

Sun 11/16/2025 to Sun 11/30/2025  
0001 Continuous 2359  
Work scheduled by: NYPA

UPDATED by NYPA 02/21/2025 15:46

SCH - HQ\_CEDARS  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**90 MW**  
189 MW  
279 MW

### MASSENA\_-MARCY\_\_\_765\_MSU1

Sun 11/16/2025 to Sun 11/30/2025  
0001 Continuous 2359  
Work scheduled by: NYPA

UPDATED by NYPA 02/21/2025 15:46

SCH - HQ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**475 MW 1000 MW**  
1025 MW 0 MW  
1500 MW 1000 MW

### MASSENA\_-MARCY\_\_\_765\_MSU1

Sun 11/16/2025 to Sun 11/30/2025  
0001 Continuous 2359  
Work scheduled by: NYPA

UPDATED by NYPA 02/21/2025 15:46

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**500 MW**  
2650 MW  
3150 MW

### MASSENA\_-MARCY\_\_\_765\_MSU1

Sun 11/16/2025 to Sun 11/30/2025  
0001 Continuous 2359  
Work scheduled by: NYPA

UPDATED by NYPA 02/21/2025 15:46

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**2595 MW**  
1130 MW  
3725 MW

### MOSES\_\_-MASSENA\_230\_MMS2 , MOSES\_\_-MASSENA\_230\_MMS1

Sun 11/16/2025 to Sun 11/30/2025  
0001 2359  
Work scheduled by:

SCH - HQ\_CEDARS  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**90 MW**  
189 MW  
279 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Friday, July 25, 2025 to Sunday, January 24, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MOSES\_\_-MASSENA\_230\_MMS2 , MOSES\_\_-MASSENA\_230\_MMS1

Sun 11/16/2025 to Sun 11/30/2025  
0001 2359  
Work scheduled by:

SCH - HQ - NY	FWD (Import)	REV (Export)
	<b>850 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	650 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

### RAMAPO\_-BUCHAN\_N\_345\_Y94

Mon 11/17/2025 to Mon 11/17/2025  
0201 Continuous 0230  
Work scheduled by: ConEd

UPNY CONED	FWD (Import)	REV (Export)
	<b>7755 MW</b>	
Impacts Total Transfer Capability	295 MW	
TTC with All Lines In Service	8050 MW	

### RAMAPO\_-BUCHAN\_N\_345\_Y94

Tue 11/18/2025 to Tue 11/18/2025  
0130 Continuous 0200  
Work scheduled by: ConEd

UPNY CONED	FWD (Import)	REV (Export)
	<b>7755 MW</b>	
Impacts Total Transfer Capability	295 MW	
TTC with All Lines In Service	8050 MW	

### BECK\_\_-NIAGARA\_230\_PA27

Thu 11/20/2025 to Thu 11/20/2025  
0800 Continuous 1600  
Work scheduled by: IESO

SCH - OH - NY	FWD (Import)	REV (Export)
	<b>2050 MW</b>	
Impacts Total Transfer Capability	450 MW	
TTC with All Lines In Service	2500 MW	

### MILLWOOD-EASTVIEW\_345\_W82

Wed 12/10/2025 to Fri 12/19/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

UPNY CONED	FWD (Import)	REV (Export)
	<b>7810 MW</b>	
Impacts Total Transfer Capability	240 MW	
TTC with All Lines In Service	8050 MW	

### SPRNBK\_345KV\_RNS4

Wed 12/10/2025 to Wed 12/10/2025  
0001 Continuous 0030  
Work scheduled by: ConEd

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	<b>3200 MW</b>	
Impacts Total Transfer Capability	1400 MW	
TTC with All Lines In Service	4600 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Friday, July 25, 2025 to Sunday, January 24, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SPRNBK\_345KV\_RNS4

Fri 12/19/2025 to Fri 12/19/2025  
2130 Continuous 2200  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 3200 MW  
REV (Export) 1400 MW  
4600 MW

### MILLWOOD-EASTVIEW\_345\_W99

Mon 12/22/2025 to Mon 12/22/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 7810 MW  
REV (Export) 240 MW  
8050 MW

### MILLWOOD-EASTVIEW\_345\_W99

Tue 12/23/2025 to Thu 12/25/2025  
0001 Continuous 0259  
Work scheduled by: ConEd

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 7810 MW  
REV (Export) 240 MW  
8050 MW

### SPRNBK\_345KV\_RNS5

Tue 12/23/2025 to Thu 12/25/2025  
0001 Continuous 0259  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 3200 MW  
REV (Export) 1400 MW  
4600 MW

### E13THSTA-FARRAGUT\_345\_46

Wed 01/07/2026 to Fri 01/09/2026  
0301 Continuous 0300  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 3800 MW  
REV (Export) 800 MW  
4600 MW

### E13THSTA-FARRAGUT\_345\_46

Sat 01/31/2026 to Thu 02/05/2026  
0001 Continuous 0300  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 3800 MW  
REV (Export) 800 MW  
4600 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Friday, July 25, 2025 to Sunday, January 24, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MARCY\_\_-N.SCTLND\_345\_18

Mon 02/09/2026 to Fri 02/13/2026  
0700 Continuous 1530  
Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC

Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**2665 MW**  
1060 MW  
3725 MW

### NIAGARA\_-DYSINGER\_345\_ND1

Thu 02/12/2026 to Thu 02/12/2026  
0500 Continuous 1900  
Work scheduled by: NYPA

DYSINGER EAST

Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**2700 MW**  
500 MW  
3200 MW

### DUNWODIE\_345KV\_7

Sun 03/01/2026 to Sun 03/01/2026  
0001 Continuous 0030  
Work scheduled by: ConEd

SPR/DUN-SOUTH

Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**3800 MW**  
800 MW  
4600 MW

### DUNWODIE\_345KV\_8

Sun 03/01/2026 to Sun 03/01/2026  
0001 Continuous 0030  
Work scheduled by: ConEd

SPR/DUN-SOUTH

Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**3800 MW**  
800 MW  
4600 MW

### DUNWODIE-MOTTHAVN\_345\_72

Sun 03/01/2026 to Mon 04/13/2026  
0001 Continuous 0259  
Work scheduled by: ConEd

SPR/DUN-SOUTH

Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**3800 MW**  
800 MW  
4600 MW

### DYSINGER-STA\_255\_345\_DH2

Mon 03/02/2026 to Sun 03/15/2026  
0500 Continuous 1900  
Work scheduled by: NYPA

EXTENDED by NYPA 06/17/2025 15:09

DYSINGER EAST

Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**2850 MW**  
350 MW  
3200 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Friday, July 25, 2025 to Sunday, January 24, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### DYSINGER-STA\_255\_345\_DH1

Mon 03/16/2026 to Tue 04/07/2026  
0500 Continuous 2100  
Work scheduled by: NYPA

DYSINGER EAST	FWD (Import)	REV (Export)
	<b>2850 MW</b>	
Impacts Total Transfer Capability	350 MW	
TTC with All Lines In Service	3200 MW	

### BECK\_\_\_-NIAGARA\_345\_PA302

Mon 03/16/2026 to Fri 03/20/2026  
0630 Continuous 1600  
Work scheduled by: IESO

SCH - OH - NY	FWD (Import)	REV (Export)
	<b>1150 MW</b>	<b>1000 MW</b>
Impacts Total Transfer Capability	1350 MW	850 MW
TTC with All Lines In Service	2500 MW	1850 MW

### DYSINGER-STA\_255\_345\_DH2

Wed 04/08/2026 to Mon 04/20/2026  
0500 Continuous 2100  
Work scheduled by: NYPA

DYSINGER EAST	FWD (Import)	REV (Export)
	<b>2850 MW</b>	
Impacts Total Transfer Capability	350 MW	
TTC with All Lines In Service	3200 MW	

### DUNWODIE\_345KV\_7

Mon 04/13/2026 to Mon 04/13/2026  
0230 Continuous 0259  
Work scheduled by: ConEd

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

### DUNWODIE\_345KV\_8

Mon 04/13/2026 to Mon 04/13/2026  
0230 Continuous 0259  
Work scheduled by: ConEd

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

### STLAWRNC-MOSES\_230\_L34P

Mon 04/13/2026 to Fri 04/17/2026  
0600 Continuous 1630  
Work scheduled by: NYPA

SCH - OH - NY	FWD (Import)	REV (Export)
Impacts Total Transfer Capability		
TTC with All Lines In Service		

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Friday, July 25, 2025 to Sunday, January 24, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### ROSETON\_EFISHKIL\_345\_RFK305

Mon 04/13/2026 to Fri 04/24/2026  
0700 Continuous 1530  
Work scheduled by: NYPA

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**7215 MW**  
835 MW  
8050 MW

### STLAWRNC-MOSES\_\_230\_L33P

Mon 04/20/2026 to Fri 04/24/2026  
0600 Continuous 1630  
Work scheduled by: NYPA

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### DYSINGER-STA\_255\_345\_DH1

Tue 04/21/2026 to Fri 05/01/2026  
0500 Continuous 2100  
Work scheduled by: NYPA

DYSINGER EAST  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**2850 MW**  
350 MW  
3200 MW

### BECK\_\_-NIAGARA\_345\_PA301

Mon 04/27/2026 to Fri 05/01/2026  
0630 Continuous 1600  
Work scheduled by: IESO

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1150 MW** **1000 MW**  
1350 MW 850 MW  
2500 MW 1850 MW

### GOETHALS\_345KV\_5

Fri 05/01/2026 to Thu 05/07/2026  
0001 Continuous 0300  
Work scheduled by: ConEd

UPDATED by ConEd 03/04/2025 07:30

STATEN ISLAND  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### DYSINGER-STA\_255\_345\_DH2

Sat 05/02/2026 to Mon 05/11/2026  
0500 Continuous 2100  
Work scheduled by: NYPA

DYSINGER EAST  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**2850 MW**  
350 MW  
3200 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Friday, July 25, 2025 to Sunday, January 24, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### INGHAM\_C\_115\_115\_PAR 2

Mon 05/04/2026 to Fri 05/22/2026  
0600 Continuous 1600  
Work scheduled by: NGrid

CENTRAL EAST - VC  
Impacts Total Transfer Capability 120 MW  
TTC with All Lines In Service 3725 MW

FWD (Import) REV (Export)

### MARCY\_-\_FRASANNX\_345\_UCC2-41

Wed 05/06/2026 to Fri 05/22/2026  
0700 Continuous 1530  
Work scheduled by: NYPA ARR: 19

CENTRAL EAST - VC  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 3725 MW

FWD (Import) REV (Export)

### NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE

Mon 05/11/2026 to Fri 05/15/2026  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

### NEWBRDGE\_345\_138\_BK\_1

Mon 05/11/2026 to Fri 05/15/2026  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

### NEWBRDGE\_345\_138\_BK\_2

Mon 05/11/2026 to Fri 05/15/2026  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

### NEWBRDGE-DUFFYAVE\_345\_501

Mon 05/11/2026 to Fri 05/15/2026  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Friday, July 25, 2025 to Sunday, January 24, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### BECK\_\_\_-PACKARD\_230\_BP76

Mon 05/11/2026 to Fri 05/15/2026  
0630 Continuous 1600  
Work scheduled by: IESO

SCH - OH - NY	FWD (Import)	REV (Export)
	<b>1600 MW</b>	<b>1050 MW</b>
Impacts Total Transfer Capability	400 MW	550 MW
TTC with All Lines In Service	2000 MW	1600 MW

### DYSINGER-STA\_255\_345\_DH1

Tue 05/12/2026 to Mon 05/25/2026  
0500 Continuous 2100  
Work scheduled by: NYPA

DYSINGER EAST	FWD (Import)	REV (Export)
	<b>2850 MW</b>	
Impacts Total Transfer Capability	350 MW	
TTC with All Lines In Service	3200 MW	

### W49TH\_ST\_345KV\_5

Fri 05/15/2026 to Fri 05/15/2026  
0001 Continuous 0030  
Work scheduled by: ConEd

SCH - PJM_HTP	FWD (Import)	REV (Export)
	<b>460 MW</b>	
Impacts Total Transfer Capability	200 MW	
TTC with All Lines In Service	660 MW	

### W49TH\_ST\_345KV\_7

Fri 05/15/2026 to Fri 05/15/2026  
0001 Continuous 0030  
Work scheduled by: ConEd

SCH - PJM_HTP	FWD (Import)	REV (Export)
	<b>460 MW</b>	
Impacts Total Transfer Capability	200 MW	
TTC with All Lines In Service	660 MW	

### W49TH\_ST\_345KV\_5

Fri 05/15/2026 to Fri 05/15/2026  
1430 Continuous 1500  
Work scheduled by: ConEd

SCH - PJM_HTP	FWD (Import)	REV (Export)
	<b>460 MW</b>	
Impacts Total Transfer Capability	200 MW	
TTC with All Lines In Service	660 MW	

### W49TH\_ST\_345KV\_7

Fri 05/15/2026 to Fri 05/15/2026  
1430 Continuous 1500  
Work scheduled by: ConEd

SCH - PJM_HTP	FWD (Import)	REV (Export)
	<b>460 MW</b>	
Impacts Total Transfer Capability	200 MW	
TTC with All Lines In Service	660 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Friday, July 25, 2025 to Sunday, January 24, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### W49TH\_ST\_345KV\_5

Sat 05/16/2026 to Sat 05/16/2026  
0001 Continuous 0030  
Work scheduled by: ConEd

SCH - PJM\_HTP

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**460 MW**

200 MW

660 MW

### W49TH\_ST\_345KV\_7

Sat 05/16/2026 to Sat 05/16/2026  
0001 Continuous 0030  
Work scheduled by: ConEd

SCH - PJM\_HTP

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**460 MW**

200 MW

660 MW

### W49TH\_ST\_345KV\_5

Mon 05/18/2026 to Mon 05/18/2026  
0030 Continuous 0100  
Work scheduled by: ConEd

SCH - PJM\_HTP

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**460 MW**

200 MW

660 MW

### W49TH\_ST\_345KV\_7

Mon 05/18/2026 to Mon 05/18/2026  
0030 Continuous 0100  
Work scheduled by: ConEd

SCH - PJM\_HTP

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**460 MW**

200 MW

660 MW

### NIAGARA\_345\_230\_AT4

Tue 05/26/2026 to Sat 05/30/2026  
0500 Continuous 1900  
Work scheduled by: NYPA

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**1200 MW**

400 MW

1600 MW

### MARCY\_345KV\_CSC

Mon 06/01/2026 to Sun 06/14/2026  
0700 Continuous 1530  
Work scheduled by: NYPA

CENTRAL EAST - VC

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**3650 MW**

75 MW

3725 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Friday, July 25, 2025 to Sunday, January 24, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MARCY\_\_\_765\_345\_AT1

Wed 09/09/2026 to Thu 09/10/2026  
0700 Continuous 1530  
Work scheduled by: NYPA

ARR: 19

MOSES SOUTH

Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**1750 MW**  
1400 MW  
3150 MW

### MARCY\_\_\_765\_345\_AT2

Fri 09/11/2026 to Sat 09/12/2026  
0700 Continuous 1530  
Work scheduled by: NYPA

ARR: 19

MOSES SOUTH

Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**1700 MW**  
1450 MW  
3150 MW

### MOTTHAVN-RAINEY\_\_345\_Q12

Tue 09/15/2026 to Sun 10/25/2026  
0201 Continuous 0400  
Work scheduled by: ConEd

SPR/DUN-SOUTH

Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**3800 MW**  
800 MW  
4600 MW

### MARCY\_\_\_FRASANNX\_345\_UCC2-41

Tue 09/15/2026 to Tue 09/29/2026  
0700 Continuous 1530  
Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC

Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**3225 MW**  
500 MW  
3725 MW

### PANNELL\_-CLAY\_\_\_345\_1

Mon 09/28/2026 to Fri 10/02/2026  
0700 Continuous 1530  
Work scheduled by: NYPA

WEST CENTRAL

Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**1300 MW**  
950 MW  
2250 MW

### SAND\_BAR-PLATSBRG\_115\_PV20

Mon 09/28/2026 to Fri 10/02/2026  
0900 Continuous 1630  
Work scheduled by: NYPA

SCH - NE - NY

Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Friday, July 25, 2025 to Sunday, January 24, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SAND\_BAR-PLATSBRG\_115\_PV20

Mon 09/28/2026 to Fri 10/02/2026  
0900 Continuous 1630  
Work scheduled by: NYPA

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **3625 MW**  
100 MW  
3725 MW

### PANNELL-CLAY\_345\_2

Mon 10/05/2026 to Fri 10/09/2026  
0700 Continuous 1530  
Work scheduled by: NYPA

WEST CENTRAL  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **1300 MW**  
950 MW  
2250 MW

### NEPTUNE-DUFFYAVE\_345\_NEPTUNE

Mon 10/12/2026 to Thu 10/15/2026  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **0 MW**  
660 MW  
660 MW

### NEWBRDGE\_345\_138\_BK\_1

Mon 10/12/2026 to Thu 10/15/2026  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **375 MW**  
285 MW  
660 MW

### NEWBRDGE\_345\_138\_BK\_2

Mon 10/12/2026 to Thu 10/15/2026  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **375 MW**  
285 MW  
660 MW

### NEWBRDGE-DUFFYAVE\_345\_501

Mon 10/12/2026 to Thu 10/15/2026  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **0 MW**  
660 MW  
660 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Friday, July 25, 2025 to Sunday, January 24, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### CHATGUAY-MASSENA\_\_765\_7040

Wed 10/14/2026 to Wed 10/28/2026  
0001 Continuous 2359  
Work scheduled by: NYPA

SCH - HQ - NY	FWD (Import)	REV (Export)
	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	1500 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

### CHATGUAY-MASSENA\_\_765\_7040

Wed 10/14/2026 to Wed 10/28/2026  
0001 Continuous 2359  
Work scheduled by: NYPA

MOSES SOUTH	FWD (Import)	REV (Export)
	<b>1550 MW</b>	
Impacts Total Transfer Capability	1600 MW	
TTC with All Lines In Service	3150 MW	

### CHATGUAY-MASSENA\_\_765\_7040 , MASSENA-MARCY\_\_765\_MSU1

Wed 10/14/2026 to Wed 10/28/2026  
0001 2359  
Work scheduled by:

MOSES SOUTH	FWD (Import)	REV (Export)
	<b>500 MW</b>	
Impacts Total Transfer Capability	2650 MW	
TTC with All Lines In Service	3150 MW	

### MARCY\_\_765\_345\_AT1

Wed 10/14/2026 to Wed 10/28/2026  
0001 Continuous 2359  
Work scheduled by: NYPA

ARR: 19

MOSES SOUTH	FWD (Import)	REV (Export)
	<b>1750 MW</b>	
Impacts Total Transfer Capability	1400 MW	
TTC with All Lines In Service	3150 MW	

### MARCY\_\_765\_345\_AT2

Wed 10/14/2026 to Wed 10/28/2026  
0001 Continuous 2359  
Work scheduled by: NYPA

ARR: 19

MOSES SOUTH	FWD (Import)	REV (Export)
	<b>1700 MW</b>	
Impacts Total Transfer Capability	1450 MW	
TTC with All Lines In Service	3150 MW	

### MASSENA-MARCY\_\_765\_MSU1

Wed 10/14/2026 to Wed 10/28/2026  
0001 Continuous 2359  
Work scheduled by: NYPA

SCH - HQ_CEDARS	FWD (Import)	REV (Export)
	<b>90 MW</b>	
Impacts Total Transfer Capability	180 MW	
TTC with All Lines In Service	270 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Friday, July 25, 2025 to Sunday, January 24, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MASSENA\_MARCY\_\_765\_MSU1

Wed 10/14/2026 to Wed 10/28/2026  
0001 Continuous 2359  
Work scheduled by: NYPA

SCH - HQ - NY	FWD (Import)	REV (Export)
	<b>475 MW</b>	<b>1000 MW</b>
Impacts Total Transfer Capability	1025 MW	0 MW
TTC with All Lines In Service	1500 MW	1000 MW

### MASSENA\_MARCY\_\_765\_MSU1

Wed 10/14/2026 to Wed 10/28/2026  
0001 Continuous 2359  
Work scheduled by: NYPA

MOSES SOUTH	FWD (Import)	REV (Export)
	<b>500 MW</b>	
Impacts Total Transfer Capability	2650 MW	
TTC with All Lines In Service	3150 MW	

### MASSENA\_MARCY\_\_765\_MSU1

Wed 10/14/2026 to Wed 10/28/2026  
0001 Continuous 2359  
Work scheduled by: NYPA

CENTRAL EAST - VC	FWD (Import)	REV (Export)
	<b>2595 MW</b>	
Impacts Total Transfer Capability	1130 MW	
TTC with All Lines In Service	3725 MW	

### MOSES\_\_MASSENA\_230\_MMS2 , MOSES\_\_MASSENA\_230\_MMS1

Wed 10/14/2026 to Wed 10/28/2026  
0001 2359  
Work scheduled by:

SCH - HQ_CEDARS	FWD (Import)	REV (Export)
	<b>90 MW</b>	
Impacts Total Transfer Capability	180 MW	
TTC with All Lines In Service	270 MW	

### MOSES\_\_MASSENA\_230\_MMS2 , MOSES\_\_MASSENA\_230\_MMS1

Wed 10/14/2026 to Wed 10/28/2026  
0001 2359  
Work scheduled by:

SCH - HQ - NY	FWD (Import)	REV (Export)
	<b>850 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	650 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

### EDIC\_\_FRASER\_345\_EF24-40

Mon 11/30/2026 to Sun 12/06/2026  
0700 Continuous 1530  
Work scheduled by: NYPA

CENTRAL EAST - VC	FWD (Import)	REV (Export)
	<b>3225 MW</b>	
Impacts Total Transfer Capability	500 MW	
TTC with All Lines In Service	3725 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits		Friday, July 25, 2025 to Sunday, January 24, 2027			
CENTRAL EAST	7550 MW	<b>The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.</b>			
CENTRAL EAST - VC	3725 MW				
TOTAL EAST	7550 MW				
UPNY CONED	8050 MW				
SPR/DUN-SOUTH	4600 MW				
DYSINGER EAST	3200 MW				
MOSES SOUTH	3150 MW				
<hr/>					
SAND_BAR-PLATSBRG_115_PV20				FWD (Import)	REV (Export)
Mon 12/07/2026	to	Fri 12/11/2026			
0900	Continuous	1630	SCH - NE - NY		
Work scheduled by: NYPA			Impacts Total Transfer Capability		
			TTC with All Lines In Service		
<hr/>					
SAND_BAR-PLATSBRG_115_PV20				FWD (Import)	REV (Export)
Mon 12/07/2026	to	Fri 12/11/2026			
0900	Continuous	1630	CENTRAL EAST - VC		
Work scheduled by: NYPA			Impacts Total Transfer Capability		
			TTC with All Lines In Service		