

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, July 26, 2025 to Monday, January 25, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### HUDSONP\_-FARRAGUT\_345\_B3402

FWD (Import) REV (Export)

Mon 01/15/2018 to Sat 11/01/2025  
0001 Continuous 0100  
Work scheduled by: ConEd

EXT FORCED by ConEd 03/11/2024 11:26

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

### MARION\_-FARRAGUT\_345\_C3403

FWD (Import) REV (Export)

Mon 01/15/2018 to Sat 11/01/2025  
0001 Continuous 0100  
Work scheduled by: ConEd

EXT FORCED by ConEd 03/11/2024 11:26

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

### MARION\_-FARRAGUT\_345\_C3403 , HUDSONP\_-FARRAGUT\_345\_B3402

FWD (Import) REV (Export)

Mon 01/15/2018 to Sat 11/01/2025  
0001 0100  
Work scheduled by:

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

**2000 MW** **1050 MW**  
200 MW 150 MW  
2200 MW 1200 MW

### OSWEGO\_COMPLEX\_AVR\_O/S

FWD (Import) REV (Export)

Wed 01/29/2025 to Sun 09/13/2026  
0001 Continuous 2359  
Work scheduled by: NGrid

FORCED by NGrid 01/27/2025 10:33

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

**3640 MW**  
85 MW  
3725 MW

### DOVER\_-CRICKVLY\_345\_Y17

FWD (Import) REV (Export)

Wed 02/12/2025 to Sun 11/23/2025  
1220 Continuous 2300  
Work scheduled by: NYISO

UPDATED by NYISO 05/27/2025 11:59

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

### DOVER\_-CRICKVLY\_345\_Y17

FWD (Import) REV (Export)

Wed 02/12/2025 to Sun 11/23/2025  
1220 Continuous 2300  
Work scheduled by: NYISO

UPDATED by NYISO 05/27/2025 11:59

SCH - NPX\_1385  
Impacts Total Transfer Capability  
TTC with All Lines In Service

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, July 26, 2025 to Monday, January 25, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### LONG\_MTN-DOVER\_\_345\_398

Wed 02/12/2025 to Sun 11/23/2025  
1221 Continuous 2300  
Work scheduled by: NYISO

UPDATED by NYISO 05/27/2025 11:59

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### LONG\_MTN-DOVER\_\_345\_398

Wed 02/12/2025 to Sun 11/23/2025  
1221 Continuous 2300  
Work scheduled by: NYISO

UPDATED by NYISO 05/27/2025 11:59

SCH - NPX\_1385  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### SCH-NYISO-HQ\_CEDARS\_LIMIT\_40

Tue 06/03/2025 to Fri 08/01/2025  
0001 Continuous 0000  
Work scheduled by: HQ

FORCED by HQ 06/02/2025 15:40

SCH - HQ\_CEDARS  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**40 MW**  
60 MW  
100 MW

### SCH-NYISO-HQ\_LIMIT\_750

Mon 07/28/2025 to Tue 07/29/2025  
0600 Continuous 1900  
Work scheduled by: HQ

CANCELLED by NYISO 07/24/2025 11:23

SCH - HQ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**750 MW**  
250 MW  
1000 MW

### DYSINGER-STA\_255\_345\_DH2

Wed 07/30/2025 to Sun 08/10/2025  
0500 Continuous 1900  
Work scheduled by: NYPA

UPDATED by NYPA 07/22/2025 13:35

DYSINGER EAST  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**2850 MW**  
350 MW  
3200 MW

### HOMRC-NY-MAINS\_NY\_345\_47

Wed 07/30/2025 to Fri 08/08/2025  
0700 Continuous 1500  
Work scheduled by: NYSEG

UPDATED by NYSEG 07/22/2025 11:30

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, July 26, 2025 to Monday, January 25, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### W49TH\_ST\_345KV\_6

Sat 08/02/2025 to Sat 08/02/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

SCH - PJM\_HTP

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

**300 MW**

360 MW

660 MW

REV (Export)

### CEDARS\_\_ROSEMNTA\_115\_1/11

Tue 08/05/2025 to Wed 08/06/2025  
0700 Continuous 1800  
Work scheduled by: HQ

SCH - HQ\_CEDARS

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

**95 MW**

175 MW

270 MW

REV (Export)

**40 MW**

60 MW

100 MW

### DENNISON-ROSEMNTA\_115\_1/11

Tue 08/05/2025 to Wed 08/06/2025  
0700 Continuous 1800  
Work scheduled by: HQ

SCH - HQ\_CEDARS

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

**95 MW**

175 MW

270 MW

REV (Export)

**40 MW**

60 MW

100 MW

### SAND\_BAR-PLATSBRG\_115\_PV20

Tue 08/05/2025 to Fri 08/08/2025  
0700 Continuous 1630  
Work scheduled by: NYPA

UPDATED by NYPA 03/13/2025 13:53

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

### SAND\_BAR-PLATSBRG\_115\_PV20

Tue 08/05/2025 to Fri 08/08/2025  
0700 Continuous 1630  
Work scheduled by: NYPA

UPDATED by NYPA 03/13/2025 13:53

CENTRAL EAST - VC

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

**3625 MW**

100 MW

3725 MW

REV (Export)

### SCH-HQ\_CEDARS-NYISO\_LIMIT\_80

Tue 08/05/2025 to Wed 08/06/2025  
0700 Continuous 1800  
Work scheduled by: HQ

SCH - HQ\_CEDARS

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

**80 MW**

190 MW

270 MW

REV (Export)

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, July 26, 2025 to Monday, January 25, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### BECK\_\_-NIAGARA\_345\_PA301

Tue 08/05/2025 to Fri 08/08/2025  
0800 Continuous 1600  
Work scheduled by: IESO

SCH - OH - NY	FWD (Import)	REV (Export)
	<b>1000 MW</b>	<b>850 MW</b>
Impacts Total Transfer Capability	1000 MW	750 MW
TTC with All Lines In Service	2000 MW	1600 MW

### EDIC\_\_-GORDONRD\_345\_14

Sat 08/09/2025 to Sun 08/10/2025  
0630 Continuous 1700  
Work scheduled by: NGrid

CENTRAL EAST - VC	FWD (Import)	REV (Export)
	<b>2770 MW</b>	
Impacts Total Transfer Capability	955 MW	
TTC with All Lines In Service	3725 MW	

### EDIC\_\_-FRASER\_345\_EF24-40

Mon 08/11/2025 to Fri 08/15/2025  
0830 Continuous 1400  
Work scheduled by: NYSEG

CENTRAL EAST - VC	FWD (Import)	REV (Export)
	<b>3225 MW</b>	
Impacts Total Transfer Capability	500 MW	
TTC with All Lines In Service	3725 MW	

### ADIRNDCK-CHASLAKE\_230\_13

Wed 08/13/2025 to Wed 08/13/2025  
0700 Daily(No Weekends) 1600  
Work scheduled by: NGrid

MOSES SOUTH	FWD (Import)	REV (Export)
	<b>2100 MW</b>	
Impacts Total Transfer Capability	1050 MW	
TTC with All Lines In Service	3150 MW	

### CEDARS\_\_-ROSEMNTB\_115\_2/22

Wed 08/13/2025 to Thu 08/14/2025  
0700 Continuous 1800  
Work scheduled by: HQ

SCH - HQ_CEDARS	FWD (Import)	REV (Export)
	<b>95 MW</b>	<b>40 MW</b>
Impacts Total Transfer Capability	175 MW	60 MW
TTC with All Lines In Service	270 MW	100 MW

### DENNISON-ROSEMNTB\_115\_2/22

Wed 08/13/2025 to Thu 08/14/2025  
0700 Continuous 1800  
Work scheduled by: HQ

SCH - HQ_CEDARS	FWD (Import)	REV (Export)
	<b>95 MW</b>	<b>40 MW</b>
Impacts Total Transfer Capability	175 MW	60 MW
TTC with All Lines In Service	270 MW	100 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, July 26, 2025 to Monday, January 25, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-HQ\_CEDARS-NYISO\_LIMIT\_80

Wed 08/13/2025 to Thu 08/14/2025  
0700 Continuous 1800  
Work scheduled by: HQ

SCH - HQ\_CEDARS  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) **80 MW**  
190 MW  
270 MW

### ADIRNDCK-CHASLAKE\_230\_13

Thu 08/14/2025 to Thu 08/14/2025  
0700 Daily(No Weekends) 1600  
Work scheduled by: NGrid

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) **2100 MW**  
1050 MW  
3150 MW

### ADIRNDCK-CHASLAKE\_230\_13

Fri 08/15/2025 to Fri 08/15/2025  
0700 Daily(No Weekends) 1600  
Work scheduled by: NGrid

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) **2100 MW**  
1050 MW  
3150 MW

### W49TH\_ST\_345KV\_5

Sat 08/16/2025 to Mon 08/18/2025  
0001 Continuous 0100  
Work scheduled by: ConEd

SCH - PJM\_HTP  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) **460 MW**  
200 MW  
660 MW

### W49TH\_ST\_345KV\_7

Sat 08/16/2025 to Mon 08/18/2025  
0001 Continuous 0100  
Work scheduled by: ConEd

SCH - PJM\_HTP  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) **460 MW**  
200 MW  
660 MW

### ADIRNDCK-CHASLAKE\_230\_13

Mon 08/18/2025 to Mon 08/18/2025  
0700 Daily(No Weekends) 1600  
Work scheduled by: NGrid

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) **2100 MW**  
1050 MW  
3150 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, July 26, 2025 to Monday, January 25, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### ADIRNDCK-CHASLAKE\_230\_13

Tue 08/19/2025 to Tue 08/19/2025  
0700 Daily(No Weekends) 1600  
Work scheduled by: NGrid

MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

### ADIRNDCK-CHASLAKE\_230\_13

Wed 08/20/2025 to Wed 08/20/2025  
0700 Daily(No Weekends) 1600  
Work scheduled by: NGrid

MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

### ADIRNDCK-CHASLAKE\_230\_13

Thu 08/21/2025 to Thu 08/21/2025  
0700 Daily(No Weekends) 1600  
Work scheduled by: NGrid

MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

### ADIRNDCK-CHASLAKE\_230\_13

Fri 08/22/2025 to Fri 08/22/2025  
0700 Daily(No Weekends) 1600  
Work scheduled by: NGrid

MOSES SOUTH **2100 MW**  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

### BUCHAN\_S-MILLWOOD\_345\_W98

Sat 08/23/2025 to Sun 08/24/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

UPNY CONED **8015 MW**  
Impacts Total Transfer Capability 35 MW  
TTC with All Lines In Service 8050 MW

### WOOD\_ST-PLSNTVLE\_345\_Y86

Mon 09/01/2025 to Wed 09/03/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

UPNY CONED **7475 MW**  
Impacts Total Transfer Capability 575 MW  
TTC with All Lines In Service 8050 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, July 26, 2025 to Monday, January 25, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### DYSINGER-STA\_255\_345\_DH1

Tue 09/02/2025 to Mon 09/15/2025  
0500 Continuous 2100  
Work scheduled by: NYPA

DYSINGER EAST  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>2850 MW</b>	
350 MW	
3200 MW	

### MOSES\_\_-ADIRNDCK\_230\_MA1

Tue 09/02/2025 to Sun 10/12/2025  
0700 Continuous 1730  
Work scheduled by: NYPA

UPDATED by NYPA 05/20/2025 13:57

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>2100 MW</b>	
1050 MW	
3150 MW	

### MARCY\_\_-N.SCTLND\_345\_18

Wed 09/03/2025 to Wed 09/03/2025  
0830 Continuous 1130  
Work scheduled by: NGrid

ARR: 19

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>2665 MW</b>	
1060 MW	
3725 MW	

### W49TH\_ST\_345KV\_6

Fri 09/05/2025 to Fri 09/05/2025  
0001 Continuous 0030  
Work scheduled by: ConEd

SCH - PJM\_HTP  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>300 MW</b>	
360 MW	
660 MW	

### W49TH\_ST\_345KV\_8

Fri 09/05/2025 to Fri 09/05/2025  
0001 Continuous 0030  
Work scheduled by: ConEd

SCH - PJM\_HTP  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>350 MW</b>	
310 MW	
660 MW	

### W49TH\_ST\_345KV\_6

Fri 09/05/2025 to Fri 09/05/2025  
2130 Continuous 2200  
Work scheduled by: ConEd

SCH - PJM\_HTP  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>300 MW</b>	
360 MW	
660 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, July 26, 2025 to Monday, January 25, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### W49TH\_ST\_345KV\_8

Fri 09/05/2025 to Fri 09/05/2025  
2130 Continuous 2200  
Work scheduled by: ConEd

SCH - PJM\_HTP

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**350 MW**

310 MW

660 MW

### HOMRC\_NY-MAINS\_NY\_345\_47

Mon 09/08/2025 to Mon 10/06/2025  
0800 Continuous 1600  
Work scheduled by: NYSEG

SCH - PJ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**350 MW**

310 MW

660 MW

### GORDONRD-ROTTRDAM\_230\_30

Tue 09/09/2025 to Wed 09/10/2025  
0830 Continuous 1430  
Work scheduled by: NGrid

CENTRAL EAST - VC

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**3690 MW**

35 MW

3725 MW

### SCH-NE-NYISO\_LIMIT\_900

Fri 09/12/2025 to Fri 09/12/2025  
0800 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**1100 MW**

300 MW

1400 MW

### SCH-NE-NYISO\_LIMIT\_1000

Fri 09/12/2025 to Sat 09/13/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**1200 MW**

200 MW

1400 MW

### MILLWOOD-EASTVIEW\_345\_W82

Sat 09/13/2025 to Sat 09/13/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

UPNY CONED

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**7810 MW**

240 MW

8050 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, July 26, 2025 to Monday, January 25, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SPRNBK\_345KV\_RNS4

Sat 09/13/2025 to Sat 09/13/2025  
0001 Continuous 0030  
Work scheduled by: ConEd

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	<b>3200 MW</b>	
Impacts Total Transfer Capability	1400 MW	
TTC with All Lines In Service	4600 MW	

### SCH-NE-NYISO\_LIMIT\_900

Sat 09/13/2025 to Sat 09/13/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>1100 MW</b>	
Impacts Total Transfer Capability	300 MW	
TTC with All Lines In Service	1400 MW	

### SPRNBK\_345KV\_RNS4

Sat 09/13/2025 to Sat 09/13/2025  
2130 Continuous 2200  
Work scheduled by: ConEd

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	<b>3200 MW</b>	
Impacts Total Transfer Capability	1400 MW	
TTC with All Lines In Service	4600 MW	

### SCH-NE-NYISO\_LIMIT\_1000

Sat 09/13/2025 to Sun 09/14/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>1200 MW</b>	
Impacts Total Transfer Capability	200 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NE-NYISO\_LIMIT\_900

Sun 09/14/2025 to Sun 09/14/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>1100 MW</b>	
Impacts Total Transfer Capability	300 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NE-NYISO\_LIMIT\_1000

Sun 09/14/2025 to Mon 09/15/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>1200 MW</b>	
Impacts Total Transfer Capability	200 MW	
TTC with All Lines In Service	1400 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, July 26, 2025 to Monday, January 25, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### RAMAPO\_-BUCHAN\_N\_345\_Y94

Mon 09/15/2025 to Wed 09/17/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

UPDATED by ConEd 06/18/2025 12:30

UPNY CONED  
Impacts Total Transfer Capability 295 MW  
TTC with All Lines In Service 8050 MW

FWD (Import) REV (Export)

### SPRNBK\_345KV\_RNS4

Mon 09/15/2025 to Thu 10/02/2025  
0001 Continuous 0200  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

### SPRNBK\_-W49TH\_ST\_345\_M52

Mon 09/15/2025 to Thu 10/02/2025  
0001 Continuous 0200  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

### W49TH\_ST\_345KV\_5

Mon 09/15/2025 to Mon 09/15/2025  
0001 Continuous 0030  
Work scheduled by: ConEd

SCH - PJM\_HTP  
Impacts Total Transfer Capability 200 MW  
TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

### GOETHALS\_345KV\_5

Mon 09/15/2025 to Mon 09/15/2025  
0230 Continuous 0300  
Work scheduled by: ConEd

STATEN ISLAND  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### ADIRNDCK-PORTER\_230\_12

Mon 09/15/2025 to Sun 10/12/2025  
0600 Continuous 1700  
Work scheduled by: NGrid

MOSES SOUTH  
Impacts Total Transfer Capability 1050 MW  
TTC with All Lines In Service 3150 MW

FWD (Import) REV (Export)

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, July 26, 2025 to Monday, January 25, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MARCY\_\_345KV\_CSC

Mon 09/15/2025 to Wed 09/24/2025  
0600 Continuous 1730  
Work scheduled by: NYPA

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3650 MW**  
75 MW  
3725 MW

### DOVER\_\_CRICKVLY\_345\_Y17 , NRTH1385-NORHBR\_138\_601

Mon 09/15/2025 to Fri 10/10/2025  
0700 1500  
Work scheduled by:

SCH - NPX\_1385  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### DOVER\_\_CRICKVLY\_345\_Y17 , NRTH1385-NORHBR\_138\_602

Mon 09/15/2025 to Fri 10/10/2025  
0700 1500  
Work scheduled by:

SCH - NPX\_1385  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### DOVER\_\_CRICKVLY\_345\_Y17 , NRTH1385-NORHBR\_138\_603

Mon 09/15/2025 to Fri 10/10/2025  
0700 1500  
Work scheduled by:

SCH - NPX\_1385  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### LONG\_MTN-DOVER\_\_345\_398 , NRTH1385-NORHBR\_138\_601

Mon 09/15/2025 to Fri 10/10/2025  
0700 1500  
Work scheduled by:

SCH - NPX\_1385  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### LONG\_MTN-DOVER\_\_345\_398 , NRTH1385-NORHBR\_138\_602

Mon 09/15/2025 to Fri 10/10/2025  
0700 1500  
Work scheduled by:

SCH - NPX\_1385  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, July 26, 2025 to Monday, January 25, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LONG_MTN-DOVER__345_398 , NRTH1385-NORHBR_138_603				FWD (Import)	REV (Export)
Mon 09/15/2025	to	Fri 10/10/2025	SCH - NPX_1385		
0700		1500	Impacts Total Transfer Capability		
Work scheduled by:			TTC with All Lines In Service		
NRTH1385-NOR HBR_138_601				FWD (Import)	REV (Export)
Mon 09/15/2025	to	Fri 10/10/2025	SCH - NPX_1385	25 MW	25 MW
0700	Continuous	1500	Impacts Total Transfer Capability	100 MW	100 MW
Work scheduled by: LI			TTC with All Lines In Service	125 MW	125 MW
NRTH1385-NOR HBR_138_602				FWD (Import)	REV (Export)
Mon 09/15/2025	to	Fri 10/10/2025	SCH - NPX_1385	25 MW	25 MW
0700	Continuous	1500	Impacts Total Transfer Capability	100 MW	100 MW
Work scheduled by: LI			TTC with All Lines In Service	125 MW	125 MW
NRTH1385-NOR HBR_138_603				FWD (Import)	REV (Export)
Mon 09/15/2025	to	Fri 10/10/2025	SCH - NPX_1385	25 MW	25 MW
0700	Continuous	1500	Impacts Total Transfer Capability	100 MW	100 MW
Work scheduled by: LI			TTC with All Lines In Service	125 MW	125 MW
NRTH1385-NORHBR_138_601 , NRTH1385-NORHBR_138_602				FWD (Import)	REV (Export)
Mon 09/15/2025	to	Fri 10/10/2025	SCH - NPX_1385	0 MW	0 MW
0700		1500	Impacts Total Transfer Capability	125 MW	125 MW
Work scheduled by:			TTC with All Lines In Service	125 MW	125 MW
NRTH1385-NORHBR_138_601 , NRTH1385-NORHBR_138_603				FWD (Import)	REV (Export)
Mon 09/15/2025	to	Fri 10/10/2025	SCH - NPX_1385	0 MW	0 MW
0700		1500	Impacts Total Transfer Capability	125 MW	125 MW
Work scheduled by:			TTC with All Lines In Service	125 MW	125 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, July 26, 2025 to Monday, January 25, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### NRTH1385-NORHBR\_138\_602 , NRTH1385-NORHBR\_138\_603

Mon 09/15/2025 to Fri 10/10/2025  
0700 1500  
Work scheduled by:

SCH - NPX\_1385

FWD (Import) REV (Export)

Impacts Total Transfer Capability

0 MW 0 MW

TTC with All Lines In Service

125 MW 125 MW

125 MW 125 MW

### NRTH1385-NRTHPORT\_138\_NNC

Mon 09/15/2025 to Fri 10/10/2025  
0700 Continuous 1500  
Work scheduled by: LI

SCH - NPX\_1385

FWD (Import) REV (Export)

Impacts Total Transfer Capability

0 MW 0 MW

TTC with All Lines In Service

125 MW 125 MW

125 MW 125 MW

### SCH-NE-NYISO\_LIMIT\_900

Mon 09/15/2025 to Mon 09/15/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY

FWD (Import) REV (Export)

Impacts Total Transfer Capability

1100 MW

TTC with All Lines In Service

300 MW

1400 MW

### SCH-NE-NYISO\_LIMIT\_1000

Mon 09/15/2025 to Tue 09/16/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY

FWD (Import) REV (Export)

Impacts Total Transfer Capability

1200 MW

TTC with All Lines In Service

200 MW

1400 MW

### DYSINGER-STA\_255\_345\_DH2

Tue 09/16/2025 to Tue 10/28/2025  
0500 Continuous 1900  
Work scheduled by: NYPA

DYSINGER EAST

FWD (Import) REV (Export)

Impacts Total Transfer Capability

2850 MW

TTC with All Lines In Service

350 MW

3200 MW

### SCH-NE-NYISO\_LIMIT\_900

Tue 09/16/2025 to Tue 09/16/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY

FWD (Import) REV (Export)

Impacts Total Transfer Capability

1100 MW

TTC with All Lines In Service

300 MW

1400 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, July 26, 2025 to Monday, January 25, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_1000

Tue 09/16/2025 to Wed 09/17/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) **1200 MW**  
200 MW  
1400 MW

### SCH-NE-NYISO\_LIMIT\_900

Wed 09/17/2025 to Wed 09/17/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) **1100 MW**  
300 MW  
1400 MW

### SCH-NE-NYISO\_LIMIT\_1000

Wed 09/17/2025 to Thu 09/18/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) **1200 MW**  
200 MW  
1400 MW

### RAMAPO\_-BUCHAN\_N\_345\_Y94

Thu 09/18/2025 to Sat 09/20/2025  
0001 Continuous 0259  
Work scheduled by: ConEd

EXTENDED by ConEd 06/12/2025 10:19

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) **7755 MW**  
295 MW  
8050 MW

### SCH-NE-NYISO\_LIMIT\_900

Thu 09/18/2025 to Thu 09/18/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) **1100 MW**  
300 MW  
1400 MW

### SCH-NE-NYISO\_LIMIT\_1000

Thu 09/18/2025 to Fri 09/19/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) **1200 MW**  
200 MW  
1400 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, July 26, 2025 to Monday, January 25, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_900

Fri 09/19/2025 to Fri 09/19/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1100 MW**  
300 MW  
1400 MW

### SCH-NE-NYISO\_LIMIT\_1000

Fri 09/19/2025 to Sat 09/20/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1200 MW**  
200 MW  
1400 MW

### SCH-NE-NYISO\_LIMIT\_900

Sat 09/20/2025 to Sat 09/20/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1100 MW**  
300 MW  
1400 MW

### SCH-NE-NYISO\_LIMIT\_1000

Sat 09/20/2025 to Sun 09/21/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1200 MW**  
200 MW  
1400 MW

### SCH-NE-NYISO\_LIMIT\_900

Sun 09/21/2025 to Sun 09/21/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1100 MW**  
300 MW  
1400 MW

### SCH-NE-NYISO\_LIMIT\_1000

Sun 09/21/2025 to Mon 09/22/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1200 MW**  
200 MW  
1400 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, July 26, 2025 to Monday, January 25, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### WOOD\_ST\_PLSNTVLE\_345\_Y86

Mon 09/22/2025 to Fri 09/26/2025  
0001 Continuous 0200  
Work scheduled by: ConEd

UPNY CONED  
Impacts Total Transfer Capability 575 MW  
TTC with All Lines In Service 8050 MW

FWD (Import) REV (Export)

### SCH-NE-NYISO\_LIMIT\_900

Mon 09/22/2025 to Mon 09/22/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 1400 MW

FWD (Import) REV (Export)

### SCH-NE-NYISO\_LIMIT\_1000

Mon 09/22/2025 to Tue 09/23/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability 200 MW  
TTC with All Lines In Service 1400 MW

FWD (Import) REV (Export)

### SCH-NE-NYISO\_LIMIT\_900

Tue 09/23/2025 to Tue 09/23/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 1400 MW

FWD (Import) REV (Export)

### SCH-NE-NYISO\_LIMIT\_1000

Tue 09/23/2025 to Wed 09/24/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability 200 MW  
TTC with All Lines In Service 1400 MW

FWD (Import) REV (Export)

### SCH-NE-NYISO\_LIMIT\_900

Wed 09/24/2025 to Wed 09/24/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 1400 MW

FWD (Import) REV (Export)



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, July 26, 2025 to Monday, January 25, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_1000

Wed 09/24/2025 to Thu 09/25/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1200 MW**  
200 MW  
1400 MW

### MARCY\_\_FRASANNX\_345\_UCC2-41

Thu 09/25/2025 to Fri 10/17/2025  
0700 Continuous 1730  
Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3225 MW**  
500 MW  
3725 MW

### SCH-NE-NYISO\_LIMIT\_900

Thu 09/25/2025 to Thu 09/25/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1100 MW**  
300 MW  
1400 MW

### SCH-NE-NYISO\_LIMIT\_1000

Thu 09/25/2025 to Fri 09/26/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1200 MW**  
200 MW  
1400 MW

### SCH-NE-NYISO\_LIMIT\_900

Fri 09/26/2025 to Fri 09/26/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1100 MW**  
300 MW  
1400 MW

### SCH-NE-NYISO\_LIMIT\_600

Fri 09/26/2025 to Sat 09/27/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**800 MW**  
600 MW  
1400 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, July 26, 2025 to Monday, January 25, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_900

Sat 09/27/2025 to Sat 09/27/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1100 MW**  
300 MW  
1400 MW

### SCH-NE-NYISO\_LIMIT\_600

Sat 09/27/2025 to Sun 09/28/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**800 MW**  
600 MW  
1400 MW

### SCH-NE-NYISO\_LIMIT\_900

Sun 09/28/2025 to Sun 09/28/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1100 MW**  
300 MW  
1400 MW

### SCH-NE-NYISO\_LIMIT\_600

Sun 09/28/2025 to Mon 09/29/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**800 MW**  
600 MW  
1400 MW

### PANNELL\_-CLAY\_\_\_345\_1

Mon 09/29/2025 to Fri 10/03/2025  
0700 Continuous 1530  
Work scheduled by: NYPA

WEST CENTRAL  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1300 MW**  
950 MW  
2250 MW

### SCH-NE-NYISO\_LIMIT\_900

Mon 09/29/2025 to Mon 09/29/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1100 MW**  
300 MW  
1400 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, July 26, 2025 to Monday, January 25, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_600

Mon 09/29/2025 to Tue 09/30/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability 600 MW  
TTC with All Lines In Service 1400 MW

FWD (Import) REV (Export)

**800 MW**

### SCH-NE-NYISO\_LIMIT\_900

Tue 09/30/2025 to Tue 09/30/2025  
0700 Daily 0800  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability 300 MW  
TTC with All Lines In Service 1400 MW

FWD (Import) REV (Export)

**1100 MW**

### DUNWODIE\_345KV\_6

Wed 10/01/2025 to Sat 10/04/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

**3800 MW**

### DUNWODIE\_345KV\_8

Wed 10/01/2025 to Sat 10/04/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

**3800 MW**

### W49TH\_ST\_345KV\_5

Thu 10/02/2025 to Thu 10/02/2025  
0130 Continuous 0200  
Work scheduled by: ConEd

SCH - PJM\_HTP  
Impacts Total Transfer Capability 200 MW  
TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

**460 MW**

### PANNELL\_-CLAY\_345\_2

Mon 10/06/2025 to Fri 10/10/2025  
0700 Continuous 1530  
Work scheduled by: NYPA

WEST CENTRAL  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

FWD (Import) REV (Export)

**1300 MW**

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, July 26, 2025 to Monday, January 25, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### ROCHESTR-PANNELL\_345\_RP2

Mon 10/06/2025 to Wed 10/08/2025  
0730 Continuous 1500  
Work scheduled by: RGE

DYSINGER EAST  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) REV (Export)  
**2300 MW**  
900 MW  
3200 MW

### MILLWOOD-EASTVIEW\_345\_W85

Fri 10/10/2025 to Sun 10/19/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) REV (Export)  
**7810 MW**  
240 MW  
8050 MW

### SPRNBK\_345KV\_RNS3

Fri 10/10/2025 to Fri 10/10/2025  
0001 Continuous 0030  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) REV (Export)  
**3800 MW**  
800 MW  
4600 MW

### DUNWODIE\_345KV\_3

Mon 10/13/2025 to Mon 10/13/2025  
0001 Continuous 0030  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) REV (Export)  
**3800 MW**  
800 MW  
4600 MW

### DUNWODIE\_345KV\_5

Mon 10/13/2025 to Mon 10/13/2025  
0001 Continuous 0030  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) REV (Export)  
**3800 MW**  
800 MW  
4600 MW

### DUNWODIE-MOTTHAVN\_345\_71

Mon 10/13/2025 to Tue 10/14/2025  
0001 Continuous 0200  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) REV (Export)  
**3800 MW**  
800 MW  
4600 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, July 26, 2025 to Monday, January 25, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### NEPTUNE\_DUFFYAVE\_345\_NEPTUNE

Mon 10/13/2025 to Thu 10/16/2025  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**0 MW**  
660 MW  
660 MW

### NEWBRDGE\_345\_138\_BK\_1

Mon 10/13/2025 to Thu 10/16/2025  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**375 MW**  
285 MW  
660 MW

### NEWBRDGE\_345\_138\_BK\_2

Mon 10/13/2025 to Thu 10/16/2025  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**375 MW**  
285 MW  
660 MW

### NEWBRDGE-DUFFYAVE\_345\_501

Mon 10/13/2025 to Thu 10/16/2025  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**0 MW**  
660 MW  
660 MW

### MOSES\_\_ADIRNDCK\_230\_MA2

Mon 10/13/2025 to Sat 11/15/2025  
0700 Continuous 1730  
Work scheduled by: NYPA

UPDATED by NYPA 02/21/2025 15:57

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**2100 MW**  
1050 MW  
3150 MW

### DUNWODIE\_345KV\_3

Tue 10/14/2025 to Tue 10/14/2025  
0130 Continuous 0200  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3800 MW**  
800 MW  
4600 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, July 26, 2025 to Monday, January 25, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### DUNWODIE\_345KV\_5

Tue 10/14/2025 to Tue 10/14/2025  
0130 Continuous 0200  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

### EDIC\_\_-PRINCTWN\_345\_351

Tue 10/14/2025 to Fri 10/17/2025  
0600 Continuous 1830  
Work scheduled by: NGrid

CENTRAL EAST - VC  
Impacts Total Transfer Capability 390 MW  
TTC with All Lines In Service 3725 MW

FWD (Import) REV (Export)

### MARCY\_\_765\_345\_AT2

Wed 10/15/2025 to Wed 10/15/2025  
0500 Continuous 1730  
Work scheduled by: NYPA

UPDATED by NYPA 04/22/2025 12:32

ARR: 19

MOSES SOUTH  
Impacts Total Transfer Capability 1450 MW  
TTC with All Lines In Service 3150 MW

FWD (Import) REV (Export)

### SPRNBK\_345KV\_RNS3

Sun 10/19/2025 to Sun 10/19/2025  
2130 Continuous 2200  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

### E13THSTA-FARRAGUT\_345\_45

Mon 10/20/2025 to Sat 10/25/2025  
0001 Continuous 0159  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

### W49TH\_ST-E13THSTA\_345\_M54

Mon 10/20/2025 to Sat 10/25/2025  
0001 Continuous 0159  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, July 26, 2025 to Monday, January 25, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### GOETHALS\_345KV\_5

Wed 10/22/2025 to Thu 10/23/2025  
0001 Continuous 0200  
Work scheduled by: ConEd

EXTENDED by ConEd 05/27/2025 11:13

STATEN ISLAND  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### HUDSONP\_-FARRAGUT\_345\_B3402 , LINDEN\_-GOETHALS\_230\_A2253

Wed 10/22/2025 to Thu 10/23/2025  
0001 0200  
Work scheduled by:

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**2000 MW** **1000 MW**  
200 MW 200 MW  
2200 MW 1200 MW

### LINDEN\_-GOETHALS\_230\_A2253

Wed 10/22/2025 to Thu 10/23/2025  
0001 Continuous 0200  
Work scheduled by: ConEd

EXTENDED by ConEd 05/27/2025 11:13

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### LONG\_MTN-CRICKVLY\_345\_398

Wed 10/22/2025 to Fri 11/21/2025  
0001 Continuous 2300  
Work scheduled by: ConEd

UPDATED by ConEd 07/23/2025 12:25

SCH - NPX\_1385  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**25 MW** **25 MW**  
100 MW 100 MW  
125 MW 125 MW

### LONG\_MTN-CRICKVLY\_345\_398

Wed 10/22/2025 to Fri 11/21/2025  
0001 Continuous 2300  
Work scheduled by: ConEd

UPDATED by ConEd 07/23/2025 12:25

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**800 MW** **1200 MW**  
600 MW 400 MW  
1400 MW 1600 MW

### MARION\_-FARRAGUT\_345\_C3403 , HUDSONP\_-FARRAGUT\_345\_B3402 , LINDEN\_-GOETHALS\_230\_A2253

Wed 10/22/2025 to Thu 10/23/2025  
0001 0200  
Work scheduled by:

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**2000 MW** **1000 MW**  
200 MW 200 MW  
2200 MW 1200 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, July 26, 2025 to Monday, January 25, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MARION\_-FARRAGUT\_345\_C3403 , LINDEN\_-GOETHALS\_230\_A2253

Wed 10/22/2025 to Thu 10/23/2025  
0001 0200  
Work scheduled by:

SCH - PJ - NY	FWD (Import)	REV (Export)
	<b>2000 MW</b>	<b>1000 MW</b>
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	2200 MW	1200 MW

### SCH-NE-NYISO\_LIMIT\_500

Wed 10/22/2025 to Fri 11/21/2025  
0001 Continuous 2300  
Work scheduled by: ConEd

UPDATED by ConEd 07/23/2025 12:25

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>700 MW</b>	
Impacts Total Transfer Capability	700 MW	
TTC with All Lines In Service	1400 MW	

### RAMAPO\_-BUCHAN\_N\_345\_Y94

Fri 10/24/2025 to Fri 10/24/2025  
0001 Continuous 0030  
Work scheduled by: ConEd

UPNY CONED	FWD (Import)	REV (Export)
	<b>7755 MW</b>	
Impacts Total Transfer Capability	295 MW	
TTC with All Lines In Service	8050 MW	

### SPRNBK\_-TREMONT\_345\_X28

Sat 10/25/2025 to Sun 10/26/2025  
0001 Continuous 0200  
Work scheduled by: ConEd

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	<b>4200 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	4600 MW	

### RAMAPO\_-BUCHAN\_N\_345\_Y94

Sat 10/25/2025 to Sat 10/25/2025  
0130 Continuous 0200  
Work scheduled by: ConEd

UPNY CONED	FWD (Import)	REV (Export)
	<b>7755 MW</b>	
Impacts Total Transfer Capability	295 MW	
TTC with All Lines In Service	8050 MW	

### SPRNBK\_-TREMONT\_345\_X28

Mon 10/27/2025 to Fri 10/31/2025  
0001 Continuous 1800  
Work scheduled by: ConEd

UPDATED by ConEd 04/09/2025 09:25

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	<b>4200 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	4600 MW	



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, July 26, 2025 to Monday, January 25, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### FROST\_BR-LONG\_MTN\_345\_352

Mon 10/27/2025 to Wed 10/29/2025  
0830 Continuous 1500  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **1150 MW**  
250 MW  
1400 MW

### EDIC\_\_GORDONRD\_345\_14

Tue 10/28/2025 to Tue 10/28/2025  
0800 Daily 0900  
Work scheduled by: NGrid

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **2770 MW**  
955 MW  
3725 MW

### BECK\_\_NIAGARA\_345\_PA302

Tue 10/28/2025 to Tue 10/28/2025  
0900 Continuous 1700  
Work scheduled by: IESO

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **1000 MW**  
1000 MW  
2000 MW  
REV (Export) **850 MW**  
750 MW  
1600 MW

### LINDN\_CG-LNDVFT\_\_345\_V-3022

Mon 11/03/2025 to Thu 11/06/2025  
0800 Continuous 1500  
Work scheduled by: PJM

SCH - PJM\_VFT  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **0 MW**  
315 MW  
315 MW  
REV (Export) **0 MW**  
315 MW  
315 MW

### MOTHAVN-RAINEY\_\_345\_Q11

Wed 11/05/2025 to Wed 12/17/2025  
0001 Continuous 0100  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **3800 MW**  
800 MW  
4600 MW  
REV (Export)

### LINDN\_CG-LNDVFT\_\_345\_V-3022

Thu 11/13/2025 to Thu 11/13/2025  
1500 Continuous 1800  
Work scheduled by: PJM

SCH - PJM\_VFT  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **0 MW**  
315 MW  
315 MW  
REV (Export) **0 MW**  
315 MW  
315 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, July 26, 2025 to Monday, January 25, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### CHATGUAY-MASSENA\_\_765\_7040

Sun 11/16/2025 to Sun 11/30/2025  
0001 Continuous 2359  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - HQ - NY	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	1500 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

### CHATGUAY-MASSENA\_\_765\_7040

Sun 11/16/2025 to Sun 11/30/2025  
0001 Continuous 2359  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
MOSES SOUTH	<b>1550 MW</b>	
Impacts Total Transfer Capability	1600 MW	
TTC with All Lines In Service	3150 MW	

### CHATGUAY-MASSENA\_\_765\_7040 , MASSENA-MARCY\_\_765\_MSU1

Sun 11/16/2025 to Sun 11/30/2025  
0001 2359  
Work scheduled by:

	FWD (Import)	REV (Export)
MOSES SOUTH	<b>500 MW</b>	
Impacts Total Transfer Capability	2650 MW	
TTC with All Lines In Service	3150 MW	

### MARCY\_\_765\_345\_AT1

Sun 11/16/2025 to Sun 11/30/2025 UPDATED by NYPA 02/21/2025 15:46  
0001 Continuous 2359  
Work scheduled by: NYPA

ARR: 19

	FWD (Import)	REV (Export)
MOSES SOUTH	<b>1750 MW</b>	
Impacts Total Transfer Capability	1400 MW	
TTC with All Lines In Service	3150 MW	

### MARCY\_\_765\_345\_AT2

Sun 11/16/2025 to Sun 11/30/2025 UPDATED by NYPA 02/21/2025 15:46  
0001 Continuous 2359  
Work scheduled by: NYPA

ARR: 19

	FWD (Import)	REV (Export)
MOSES SOUTH	<b>1700 MW</b>	
Impacts Total Transfer Capability	1450 MW	
TTC with All Lines In Service	3150 MW	

### MASSENA-MARCY\_\_765\_MSU1

Sun 11/16/2025 to Sun 11/30/2025 UPDATED by NYPA 02/21/2025 15:46  
0001 Continuous 2359  
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS	<b>90 MW</b>	
Impacts Total Transfer Capability	189 MW	
TTC with All Lines In Service	279 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, July 26, 2025 to Monday, January 25, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MASSENA\_MARCY\_\_765\_MSU1

Sun 11/16/2025 to Sun 11/30/2025  
0001 Continuous 2359  
Work scheduled by: NYPA

UPDATED by NYPA 02/21/2025 15:46

SCH - HQ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**475 MW 1000 MW**

1025 MW 0 MW

1500 MW 1000 MW

### MASSENA\_MARCY\_\_765\_MSU1

Sun 11/16/2025 to Sun 11/30/2025  
0001 Continuous 2359  
Work scheduled by: NYPA

UPDATED by NYPA 02/21/2025 15:46

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**500 MW**

2650 MW

3150 MW

### MASSENA\_MARCY\_\_765\_MSU1

Sun 11/16/2025 to Sun 11/30/2025  
0001 Continuous 2359  
Work scheduled by: NYPA

UPDATED by NYPA 02/21/2025 15:46

CENTRAL EAST - VC

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**2595 MW**

1130 MW

3725 MW

### MOSES\_\_-MASSENA\_230\_MMS2 , MOSES\_\_-MASSENA\_230\_MMS1

Sun 11/16/2025 to Sun 11/30/2025  
0001 2359  
Work scheduled by:

SCH - HQ\_CEDARS

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**90 MW**

189 MW

279 MW

### MOSES\_\_-MASSENA\_230\_MMS2 , MOSES\_\_-MASSENA\_230\_MMS1

Sun 11/16/2025 to Sun 11/30/2025  
0001 2359  
Work scheduled by:

SCH - HQ - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**850 MW**

650 MW

1500 MW

**0 MW**

1000 MW

1000 MW

### RAMAPO\_\_-BUCHAN\_N\_345\_Y94

Mon 11/17/2025 to Mon 11/17/2025  
0201 Continuous 0230  
Work scheduled by: ConEd

UPNY CONED

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**7755 MW**

295 MW

8050 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, July 26, 2025 to Monday, January 25, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### RAMAPO\_\_BUCHAN\_N\_345\_Y94

Tue 11/18/2025 to Tue 11/18/2025  
0130 Continuous 0200  
Work scheduled by: ConEd

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) REV (Export)  
**7755 MW**  
295 MW  
8050 MW

### BECK\_\_-NIAGARA\_230\_PA27

Thu 11/20/2025 to Thu 11/20/2025  
0800 Continuous 1600  
Work scheduled by: IESO

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) REV (Export)  
**2050 MW**  
450 MW  
2500 MW

### MILLWOOD-EASTVIEW\_345\_W82

Wed 12/10/2025 to Fri 12/19/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) REV (Export)  
**7810 MW**  
240 MW  
8050 MW

### SPRNBK\_345KV\_RNS4

Wed 12/10/2025 to Wed 12/10/2025  
0001 Continuous 0030  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) REV (Export)  
**3200 MW**  
1400 MW  
4600 MW

### SPRNBK\_345KV\_RNS4

Fri 12/19/2025 to Fri 12/19/2025  
2130 Continuous 2200  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) REV (Export)  
**3200 MW**  
1400 MW  
4600 MW

### MILLWOOD-EASTVIEW\_345\_W99

Mon 12/22/2025 to Mon 12/22/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) REV (Export)  
**7810 MW**  
240 MW  
8050 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, July 26, 2025 to Monday, January 25, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MILLWOOD-EASTVIEW\_345\_W99

Tue 12/23/2025 to Thu 12/25/2025  
0001 Continuous 0259  
Work scheduled by: ConEd

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**7810 MW**  
240 MW  
8050 MW

### SPRNBK\_345KV\_RNS5

Tue 12/23/2025 to Thu 12/25/2025  
0001 Continuous 0259  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3200 MW**  
1400 MW  
4600 MW

### E13THSTA-FARRAGUT\_345\_46

Wed 01/07/2026 to Fri 01/09/2026  
0301 Continuous 0300  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3800 MW**  
800 MW  
4600 MW

### E13THSTA-FARRAGUT\_345\_46

Sat 01/31/2026 to Thu 02/05/2026  
0001 Continuous 0300  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3800 MW**  
800 MW  
4600 MW

### MARCY\_\_N.SCTLND\_345\_18

Mon 02/09/2026 to Fri 02/13/2026  
0700 Continuous 1530  
Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**2665 MW**  
1060 MW  
3725 MW

### NIAGARA\_-DYSINGER\_345\_ND1

Thu 02/12/2026 to Thu 02/12/2026  
0500 Continuous 1900  
Work scheduled by: NYPA

DYSINGER EAST  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**2700 MW**  
500 MW  
3200 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, July 26, 2025 to Monday, January 25, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### DUNWODIE\_345KV\_7

Sun 03/01/2026 to Sun 03/01/2026  
0001 Continuous 0030  
Work scheduled by: ConEd

SPR/DUN-SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

**3800 MW**

800 MW

4600 MW

REV (Export)

### DUNWODIE\_345KV\_8

Sun 03/01/2026 to Sun 03/01/2026  
0001 Continuous 0030  
Work scheduled by: ConEd

SPR/DUN-SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

**3800 MW**

800 MW

4600 MW

REV (Export)

### DUNWODIE-MOTTHAVN\_345\_72

Sun 03/01/2026 to Mon 04/13/2026  
0001 Continuous 0259  
Work scheduled by: ConEd

SPR/DUN-SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

**3800 MW**

800 MW

4600 MW

REV (Export)

### DYSINGER-STA\_255\_345\_DH2

Mon 03/02/2026 to Sun 03/15/2026  
0500 Continuous 1900  
Work scheduled by: NYPA

EXTENDED by NYPA 06/17/2025 15:09

DYSINGER EAST

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

**2850 MW**

350 MW

3200 MW

REV (Export)

### DYSINGER-STA\_255\_345\_DH1

Mon 03/16/2026 to Tue 04/07/2026  
0500 Continuous 2100  
Work scheduled by: NYPA

DYSINGER EAST

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

**2850 MW**

350 MW

3200 MW

REV (Export)

### BECK\_\_-NIAGARA\_345\_PA302

Mon 03/16/2026 to Fri 03/20/2026  
0630 Continuous 1600  
Work scheduled by: IESO

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

**1150 MW**

1350 MW

2500 MW

REV (Export)

**1000 MW**

850 MW

1850 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, July 26, 2025 to Monday, January 25, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### DYSINGER-STA\_255\_345\_DH2

Wed 04/08/2026 to Mon 04/20/2026  
0500 Continuous 2100  
Work scheduled by: NYPA

DYSINGER EAST  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**2850 MW**  
350 MW  
3200 MW

### DUNWODIE\_345KV\_7

Mon 04/13/2026 to Mon 04/13/2026  
0230 Continuous 0259  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3800 MW**  
800 MW  
4600 MW

### DUNWODIE\_345KV\_8

Mon 04/13/2026 to Mon 04/13/2026  
0230 Continuous 0259  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3800 MW**  
800 MW  
4600 MW

### STLAWRNC-MOSES\_\_230\_L34P

Mon 04/13/2026 to Fri 04/17/2026  
0600 Continuous 1630  
Work scheduled by: NYPA

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### ROSETON\_EFISHKIL\_345\_RFK305

Mon 04/13/2026 to Fri 04/24/2026  
0700 Continuous 1530  
Work scheduled by: NYPA

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**7215 MW**  
835 MW  
8050 MW

### STLAWRNC-MOSES\_\_230\_L33P

Mon 04/20/2026 to Fri 04/24/2026  
0600 Continuous 1630  
Work scheduled by: NYPA

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, July 26, 2025 to Monday, January 25, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### DYSINGER-STA\_255\_345\_DH1

Tue 04/21/2026 to Fri 05/01/2026  
0500 Continuous 2100  
Work scheduled by: NYPA

DYSINGER EAST  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>2850 MW</b>	
350 MW	
3200 MW	

### BECK\_\_\_-NIAGARA\_345\_PA301

Mon 04/27/2026 to Fri 05/01/2026  
0630 Continuous 1600  
Work scheduled by: IESO

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>1150 MW</b>	<b>1000 MW</b>
1350 MW	850 MW
2500 MW	1850 MW

### GOETHALS\_345KV\_5

Fri 05/01/2026 to Thu 05/07/2026  
0001 Continuous 0300  
Work scheduled by: ConEd

UPDATED by ConEd 03/04/2025 07:30

STATEN ISLAND  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)

### DYSINGER-STA\_255\_345\_DH2

Sat 05/02/2026 to Mon 05/11/2026  
0500 Continuous 2100  
Work scheduled by: NYPA

DYSINGER EAST  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>2850 MW</b>	
350 MW	
3200 MW	

### INGHAM\_C\_115\_115\_PAR 2

Mon 05/04/2026 to Fri 05/22/2026  
0600 Continuous 1600  
Work scheduled by: NGrid

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>3605 MW</b>	
120 MW	
3725 MW	

### MARCY\_\_\_FRASANNX\_345\_UCC2-41

Wed 05/06/2026 to Fri 05/22/2026  
0700 Continuous 1530  
Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>3225 MW</b>	
500 MW	
3725 MW	



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, July 26, 2025 to Monday, January 25, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### NEPTUNE\_DUFFYAVE\_345\_NEPTUNE

Mon 05/11/2026 to Fri 05/15/2026  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**0 MW**

660 MW

660 MW

### NEWBRDGE\_345\_138\_BK\_1

Mon 05/11/2026 to Fri 05/15/2026  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**375 MW**

285 MW

660 MW

### NEWBRDGE\_345\_138\_BK\_2

Mon 05/11/2026 to Fri 05/15/2026  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**375 MW**

285 MW

660 MW

### NEWBRDGE-DUFFYAVE\_345\_501

Mon 05/11/2026 to Fri 05/15/2026  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**0 MW**

660 MW

660 MW

### BECK\_\_-PACKARD\_230\_BP76

Mon 05/11/2026 to Fri 05/15/2026  
0630 Continuous 1600  
Work scheduled by: IESO

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**1600 MW**

400 MW

2000 MW

**1050 MW**

550 MW

1600 MW

### DYSINGER-STA\_255\_345\_DH1

Tue 05/12/2026 to Mon 05/25/2026  
0500 Continuous 2100  
Work scheduled by: NYPA

DYSINGER EAST

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**2850 MW**

350 MW

3200 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, July 26, 2025 to Monday, January 25, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### W49TH\_ST\_345KV\_5

Fri 05/15/2026 to Fri 05/15/2026  
0001 Continuous 0030  
Work scheduled by: ConEd

SCH - PJM\_HTP

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**460 MW**

200 MW

660 MW

### W49TH\_ST\_345KV\_7

Fri 05/15/2026 to Fri 05/15/2026  
0001 Continuous 0030  
Work scheduled by: ConEd

SCH - PJM\_HTP

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**460 MW**

200 MW

660 MW

### W49TH\_ST\_345KV\_5

Fri 05/15/2026 to Fri 05/15/2026  
1430 Continuous 1500  
Work scheduled by: ConEd

SCH - PJM\_HTP

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**460 MW**

200 MW

660 MW

### W49TH\_ST\_345KV\_7

Fri 05/15/2026 to Fri 05/15/2026  
1430 Continuous 1500  
Work scheduled by: ConEd

SCH - PJM\_HTP

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**460 MW**

200 MW

660 MW

### W49TH\_ST\_345KV\_5

Sat 05/16/2026 to Sat 05/16/2026  
0001 Continuous 0030  
Work scheduled by: ConEd

SCH - PJM\_HTP

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**460 MW**

200 MW

660 MW

### W49TH\_ST\_345KV\_7

Sat 05/16/2026 to Sat 05/16/2026  
0001 Continuous 0030  
Work scheduled by: ConEd

SCH - PJM\_HTP

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**460 MW**

200 MW

660 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, July 26, 2025 to Monday, January 25, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### W49TH\_ST\_345KV\_5

Mon 05/18/2026 to Mon 05/18/2026  
0030 Continuous 0100  
Work scheduled by: ConEd

SCH - PJM\_HTP

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**460 MW**

200 MW

660 MW

### W49TH\_ST\_345KV\_7

Mon 05/18/2026 to Mon 05/18/2026  
0030 Continuous 0100  
Work scheduled by: ConEd

SCH - PJM\_HTP

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**460 MW**

200 MW

660 MW

### NIAGARA\_345\_230\_AT4

Tue 05/26/2026 to Sat 05/30/2026  
0500 Continuous 1900  
Work scheduled by: NYPA

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**1200 MW**

400 MW

1600 MW

### MARCY\_\_345KV\_CSC

Mon 06/01/2026 to Sun 06/14/2026  
0700 Continuous 1530  
Work scheduled by: NYPA

CENTRAL EAST - VC

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**3650 MW**

75 MW

3725 MW

### MARCY\_\_765\_345\_AT1

Wed 09/09/2026 to Thu 09/10/2026  
0700 Continuous 1530  
Work scheduled by: NYPA

ARR: 19

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**1750 MW**

1400 MW

3150 MW

### MARCY\_\_765\_345\_AT2

Fri 09/11/2026 to Sat 09/12/2026  
0700 Continuous 1530  
Work scheduled by: NYPA

ARR: 19

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**1700 MW**

1450 MW

3150 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, July 26, 2025 to Monday, January 25, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MOTTHAVN-RAINEY\_\_345\_Q12

Tue 09/15/2026 to Sun 10/25/2026  
0201 Continuous 0400  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

### MARCY\_\_FRASANNX\_345\_UCC2-41

Tue 09/15/2026 to Tue 09/29/2026  
0700 Continuous 1530  
Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC  
Impacts Total Transfer Capability 500 MW  
TTC with All Lines In Service 3725 MW

FWD (Import) REV (Export)

### PANNELL\_-CLAY\_\_345\_1

Mon 09/28/2026 to Fri 10/02/2026  
0700 Continuous 1530  
Work scheduled by: NYPA

WEST CENTRAL  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

FWD (Import) REV (Export)

### SAND\_BAR-PLATSBRG\_115\_PV20

Mon 09/28/2026 to Fri 10/02/2026  
0900 Continuous 1630  
Work scheduled by: NYPA

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### SAND\_BAR-PLATSBRG\_115\_PV20

Mon 09/28/2026 to Fri 10/02/2026  
0900 Continuous 1630  
Work scheduled by: NYPA

CENTRAL EAST - VC  
Impacts Total Transfer Capability 100 MW  
TTC with All Lines In Service 3725 MW

FWD (Import) REV (Export)

### PANNELL\_-CLAY\_\_345\_2

Mon 10/05/2026 to Fri 10/09/2026  
0700 Continuous 1530  
Work scheduled by: NYPA

WEST CENTRAL  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

FWD (Import) REV (Export)

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, July 26, 2025 to Monday, January 25, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### NEPTUNE\_DUFFYAVE\_345\_NEPTUNE

Mon 10/12/2026 to Thu 10/15/2026  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE

FWD (Import) REV (Export)

**0 MW**  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

### NEWBRDGE\_345\_138\_BK\_1

Mon 10/12/2026 to Thu 10/15/2026  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE

FWD (Import) REV (Export)

**375 MW**  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 660 MW

### NEWBRDGE\_345\_138\_BK\_2

Mon 10/12/2026 to Thu 10/15/2026  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE

FWD (Import) REV (Export)

**375 MW**  
Impacts Total Transfer Capability 285 MW  
TTC with All Lines In Service 660 MW

### NEWBRDGE-DUFFYAVE\_345\_501

Mon 10/12/2026 to Thu 10/15/2026  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE

FWD (Import) REV (Export)

**0 MW**  
Impacts Total Transfer Capability 660 MW  
TTC with All Lines In Service 660 MW

### CHATGUAY-MASSENA\_765\_7040

Wed 10/14/2026 to Wed 10/28/2026  
0001 Continuous 2359  
Work scheduled by: NYPA

SCH - HQ - NY

FWD (Import) REV (Export)

**0 MW** **0 MW**  
Impacts Total Transfer Capability 1500 MW 1000 MW  
TTC with All Lines In Service 1500 MW 1000 MW

### CHATGUAY-MASSENA\_765\_7040

Wed 10/14/2026 to Wed 10/28/2026  
0001 Continuous 2359  
Work scheduled by: NYPA

MOSES SOUTH

FWD (Import) REV (Export)

**1550 MW**  
Impacts Total Transfer Capability 1600 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, July 26, 2025 to Monday, January 25, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### CHATGUAY-MASSENA\_\_765\_7040 , MASSENA-MARCY\_\_765\_MSU1

Wed 10/14/2026 to Wed 10/28/2026  
0001 2359  
Work scheduled by:

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **500 MW**  
2650 MW  
3150 MW

### MARCY\_\_765\_345\_AT1

Wed 10/14/2026 to Wed 10/28/2026  
0001 Continuous 2359  
Work scheduled by: NYPA ARR: 19

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **1750 MW**  
1400 MW  
3150 MW

### MARCY\_\_765\_345\_AT2

Wed 10/14/2026 to Wed 10/28/2026  
0001 Continuous 2359  
Work scheduled by: NYPA ARR: 19

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **1700 MW**  
1450 MW  
3150 MW

### MASSENA-MARCY\_\_765\_MSU1

Wed 10/14/2026 to Wed 10/28/2026  
0001 Continuous 2359  
Work scheduled by: NYPA

SCH - HQ\_CEDARS  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **90 MW**  
180 MW  
270 MW

### MASSENA-MARCY\_\_765\_MSU1

Wed 10/14/2026 to Wed 10/28/2026  
0001 Continuous 2359  
Work scheduled by: NYPA

SCH - HQ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **475 MW** **1000 MW**  
1025 MW 0 MW  
1500 MW 1000 MW

### MASSENA-MARCY\_\_765\_MSU1

Wed 10/14/2026 to Wed 10/28/2026  
0001 Continuous 2359  
Work scheduled by: NYPA

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **500 MW**  
2650 MW  
3150 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Saturday, July 26, 2025 to Monday, January 25, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MASSENA\_MARCY\_\_\_765\_MSU1

Wed 10/14/2026 to Wed 10/28/2026  
0001 Continuous 2359  
Work scheduled by: NYPA

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>2595 MW</b>	
1130 MW	
3725 MW	

### MOSES\_\_-MASSENA\_230\_MMS2 , MOSES\_\_-MASSENA\_230\_MMS1

Wed 10/14/2026 to Wed 10/28/2026  
0001 2359  
Work scheduled by:

SCH - HQ\_CEDARS  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>90 MW</b>	
180 MW	
270 MW	

### MOSES\_\_-MASSENA\_230\_MMS2 , MOSES\_\_-MASSENA\_230\_MMS1

Wed 10/14/2026 to Wed 10/28/2026  
0001 2359  
Work scheduled by:

SCH - HQ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>850 MW</b>	<b>0 MW</b>
650 MW	1000 MW
1500 MW	1000 MW

### EDIC\_\_-FRASER\_\_345\_EF24-40

Mon 11/30/2026 to Sun 12/06/2026  
0700 Continuous 1530  
Work scheduled by: NYPA

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>3225 MW</b>	
500 MW	
3725 MW	

### SAND\_BAR-PLATSBURG\_115\_PV20

Mon 12/07/2026 to Fri 12/11/2026  
0900 Continuous 1630  
Work scheduled by: NYPA

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)

### SAND\_BAR-PLATSBURG\_115\_PV20

Mon 12/07/2026 to Fri 12/11/2026  
0900 Continuous 1630  
Work scheduled by: NYPA

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>3625 MW</b>	
100 MW	
3725 MW	