

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, September 3, 2025 to Tuesday, March 2, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### HUDSONP\_-FARRAGUT\_345\_B3402

FWD (Import) REV (Export)

Mon 01/15/2018 to Sat 11/01/2025  
0001 Continuous 0100  
Work scheduled by: ConEd

EXT FORCED by ConEd 03/11/2024 11:26

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

### MARION\_-FARRAGUT\_345\_C3403

FWD (Import) REV (Export)

Mon 01/15/2018 to Sat 11/01/2025  
0001 Continuous 0100  
Work scheduled by: ConEd

EXT FORCED by ConEd 03/11/2024 11:26

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

### MARION\_-FARRAGUT\_345\_C3403 , HUDSONP\_-FARRAGUT\_345\_B3402

FWD (Import) REV (Export)

Mon 01/15/2018 to Sat 11/01/2025  
0001 0100  
Work scheduled by:

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

**2000 MW** **1050 MW**  
200 MW 150 MW  
2200 MW 1200 MW

### OSWEGO\_COMPLEX\_AVR\_O/S

FWD (Import) REV (Export)

Wed 01/29/2025 to Sun 09/13/2026  
0001 Continuous 2359  
Work scheduled by: NGrid

FORCED by NGrid 01/27/2025 10:33

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

**3640 MW**  
85 MW  
3725 MW

### DOVER\_-CRICKVLY\_345\_Y17

FWD (Import) REV (Export)

Wed 02/12/2025 to Sun 11/23/2025  
1220 Continuous 2300  
Work scheduled by: NYISO

UPDATED by NYISO 05/27/2025 11:59

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

### DOVER\_-CRICKVLY\_345\_Y17

FWD (Import) REV (Export)

Wed 02/12/2025 to Sun 11/23/2025  
1220 Continuous 2300  
Work scheduled by: NYISO

UPDATED by NYISO 05/27/2025 11:59

SCH - NPX\_1385  
Impacts Total Transfer Capability  
TTC with All Lines In Service

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, September 3, 2025 to Tuesday, March 2, 2027

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 7550 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### LONG\_MTN-DOVER\_\_345\_398

Wed 02/12/2025 to Sun 11/23/2025  
1221 Continuous 2300  
Work scheduled by: NYISO

UPDATED by NYISO 05/27/2025 11:59

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### LONG\_MTN-DOVER\_\_345\_398

Wed 02/12/2025 to Sun 11/23/2025  
1221 Continuous 2300  
Work scheduled by: NYISO

UPDATED by NYISO 05/27/2025 11:59

SCH - NPX\_1385  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### ROSETON\_EFISHKIL\_345\_RFK305

Sun 08/17/2025 to Fri 09/05/2025  
1250 Continuous 2359  
Work scheduled by: CHGE

UPDATED by CHGE 08/27/2025 15:38

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**7215 MW**  
835 MW  
8050 MW

### SCH-NYISO-IMO\_NIAGARA\_CB\_3102

Sun 08/31/2025 to Fri 10/03/2025  
1109 Continuous 2100  
Work scheduled by: NYPA

FORCED by NYPA 08/31/2025 15:01

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**1950 MW** **1400 MW**  
50 MW 200 MW  
2000 MW 1600 MW

### WOOD\_ST\_PLSNTVLE\_345\_Y86

Mon 09/01/2025 to Wed 09/03/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

CANCELLED by TO 08/31/2025 15:10

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**7475 MW**  
575 MW  
8050 MW

### DYSINGER-STA\_255\_345\_DH1

Tue 09/02/2025 to Mon 09/15/2025  
0500 Continuous 2100  
Work scheduled by: NYPA

DYSINGER EAST  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**2850 MW**  
350 MW  
3200 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, September 3, 2025 to Tuesday, March 2, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NYISO-IMO\_NIAGARA\_CB\_3002

Tue 09/02/2025 to Fri 09/05/2025  
 0500 Continuous 1800  
 Work scheduled by: NYPA

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**1350 MW 1200 MW**

650 MW 400 MW

2000 MW 1600 MW

### CEDARS\_\_ROSEMNTB\_115\_2/22

Tue 09/02/2025 to Thu 09/11/2025  
 0700 Continuous 1830  
 Work scheduled by: HQ

SCH - HQ\_CEDARS

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**95 MW 40 MW**

175 MW 60 MW

270 MW 100 MW

### DENNISON-ROSEMNTB\_115\_2/22

Tue 09/02/2025 to Thu 09/11/2025  
 0700 Continuous 1830  
 Work scheduled by: HQ

SCH - HQ\_CEDARS

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**95 MW 40 MW**

175 MW 60 MW

270 MW 100 MW

### MOSES\_\_ADIRNDCK\_230\_MA1

Tue 09/02/2025 to Wed 12/31/2025  
 0700 Continuous 2359  
 Work scheduled by: NYPA

UPDATED by NYPA 05/20/2025 13:57

MOSES SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**2100 MW**

1050 MW

3150 MW

### SCH-HQ\_CEDARS-NYISO\_LIMIT\_80

Tue 09/02/2025 to Thu 09/11/2025  
 0700 Continuous 1830  
 Work scheduled by: HQ

SCH - HQ\_CEDARS

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**80 MW**

190 MW

270 MW

### SCH-NE-NYISO\_LIMIT\_900

Wed 09/03/2025 to Wed 09/03/2025  
 0801 Continuous 2259  
 Work scheduled by: ISONE

UPDATED by ISONE 08/30/2025 15:28

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**1100 MW**

300 MW

1400 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, September 3, 2025 to Tuesday, March 2, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MARCY\_\_-N.SCTLND\_345\_18

Wed 09/03/2025 to Wed 09/03/2025  
0830 Continuous 1530  
Work scheduled by: NGrid

ARR: 19

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**2665 MW**  
1060 MW  
3725 MW

### SCH-NE-NYISO\_LIMIT\_400

Wed 09/03/2025 to Thu 09/04/2025  
2300 Continuous 0659  
Work scheduled by: ISONE

UPDATED by ISONE 08/30/2025 15:28

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**600 MW**  
800 MW  
1400 MW

### W49TH\_ST\_345KV\_6

Thu 09/04/2025 to Thu 09/04/2025  
0001 Continuous 0030  
Work scheduled by: ConEd

SCH - PJM\_HTP  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**300 MW**  
360 MW  
660 MW

### W49TH\_ST\_345KV\_8

Thu 09/04/2025 to Thu 09/04/2025  
0001 Continuous 0030  
Work scheduled by: ConEd

SCH - PJM\_HTP  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**350 MW**  
310 MW  
660 MW

### SCH-NE-NYISO\_LIMIT\_900

Thu 09/04/2025 to Thu 09/04/2025  
0700 Continuous 0800  
Work scheduled by: ISONE

UPDATED by ISONE 08/30/2025 15:28

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1100 MW**  
300 MW  
1400 MW

### SCH-NE-NYISO\_LIMIT\_800

Thu 09/04/2025 to Thu 09/04/2025  
0801 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1000 MW**  
400 MW  
1400 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, September 3, 2025 to Tuesday, March 2, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_500

Thu 09/04/2025 to Fri 09/05/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability 700 MW  
TTC with All Lines In Service 1400 MW

FWD (Import) REV (Export)

### SCH-NE-NYISO\_LIMIT\_800

Fri 09/05/2025 to Fri 09/05/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 1400 MW

FWD (Import) REV (Export)

### SCH-NE-NYISO\_LIMIT\_500

Fri 09/05/2025 to Sat 09/06/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability 700 MW  
TTC with All Lines In Service 1400 MW

FWD (Import) REV (Export)

### W49TH\_ST\_345KV\_6

Sat 09/06/2025 to Sat 09/06/2025  
0130 Continuous 0200  
Work scheduled by: ConEd

SCH - PJM\_HTP  
Impacts Total Transfer Capability 360 MW  
TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

### W49TH\_ST\_345KV\_8

Sat 09/06/2025 to Sat 09/06/2025  
0130 Continuous 0200  
Work scheduled by: ConEd

SCH - PJM\_HTP  
Impacts Total Transfer Capability 310 MW  
TTC with All Lines In Service 660 MW

FWD (Import) REV (Export)

### SCH-NE-NYISO\_LIMIT\_800

Sat 09/06/2025 to Sat 09/06/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 1400 MW

FWD (Import) REV (Export)

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, September 3, 2025 to Tuesday, March 2, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_500

Sat 09/06/2025 to Sun 09/07/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**700 MW**  
700 MW  
1400 MW

### SCH-NE-NYISO\_LIMIT\_800

Sun 09/07/2025 to Sun 09/07/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1000 MW**  
400 MW  
1400 MW

### SCH-NE-NYISO\_LIMIT\_500

Sun 09/07/2025 to Mon 09/08/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**700 MW**  
700 MW  
1400 MW

### SCH-IMO-NYISO\_NIAG\_CB\_3008\_W/BB

Mon 09/08/2025 to Sat 09/20/2025  
0500 Continuous 1900  
Work scheduled by: NYPA

UPDATED by NYPA 07/02/2025 11:44

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1900 MW 1200 MW**  
100 MW 400 MW  
2000 MW 1600 MW

### SCH-NYISO-HQ\_LIMIT\_0

Mon 09/08/2025 to Mon 09/08/2025  
0600 Continuous 0759  
Work scheduled by: HQ

SCH - HQ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**0 MW**  
1000 MW  
1000 MW

### SCH-NE-NYISO\_LIMIT\_800

Mon 09/08/2025 to Mon 09/08/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1000 MW**  
400 MW  
1400 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, September 3, 2025 to Tuesday, March 2, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### HOMRC\_NY-MAINS\_NY\_345\_47

Mon 09/08/2025 to Mon 10/06/2025  
 0800 Continuous 1600  
 Work scheduled by: NYSEG

SCH - PJ - NY	FWD (Import)	REV (Export)
	<b>2000 MW</b>	<b>1050 MW</b>
Impacts Total Transfer Capability	200 MW	150 MW
TTC with All Lines In Service	2200 MW	1200 MW

### SCH-NYISO-HQ\_LIMIT\_300

Mon 09/08/2025 to Mon 09/08/2025  
 0800 Continuous 1959  
 Work scheduled by: HQ

SCH - HQ - NY	FWD (Import)	REV (Export)
		<b>300 MW</b>
Impacts Total Transfer Capability		700 MW
TTC with All Lines In Service		1000 MW

### SCH-NYISO-HQ\_LIMIT\_0

Mon 09/08/2025 to Tue 09/09/2025  
 2000 Continuous 0759  
 Work scheduled by: HQ

SCH - HQ - NY	FWD (Import)	REV (Export)
		<b>0 MW</b>
Impacts Total Transfer Capability		1000 MW
TTC with All Lines In Service		1000 MW

### SCH-NE-NYISO\_LIMIT\_500

Mon 09/08/2025 to Tue 09/09/2025  
 2300 Daily 0659  
 Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>700 MW</b>	
Impacts Total Transfer Capability	700 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NE-NYISO\_LIMIT\_800

Tue 09/09/2025 to Tue 09/09/2025  
 0700 Daily 2259  
 Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>1000 MW</b>	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NYISO-HQ\_LIMIT\_300

Tue 09/09/2025 to Tue 09/09/2025  
 0800 Continuous 1959  
 Work scheduled by: HQ

SCH - HQ - NY	FWD (Import)	REV (Export)
		<b>300 MW</b>
Impacts Total Transfer Capability		700 MW
TTC with All Lines In Service		1000 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, September 3, 2025 to Tuesday, March 2, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### GORDONRD-ROTTRDAM\_230\_30

Tue 09/09/2025 to Wed 09/10/2025  
0830 Continuous 1430  
Work scheduled by: NGrid

UPDATED by LS 07/30/2025 14:16

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3690 MW**  
35 MW  
3725 MW

### SCH-NYISO-HQ\_LIMIT\_0

Tue 09/09/2025 to Wed 09/10/2025  
2000 Continuous 0759  
Work scheduled by: HQ

SCH - HQ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**0 MW**  
1000 MW  
1000 MW

### SCH-NE-NYISO\_LIMIT\_500

Tue 09/09/2025 to Wed 09/10/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**700 MW**  
700 MW  
1400 MW

### SCH-NE-NYISO\_LIMIT\_800

Wed 09/10/2025 to Wed 09/10/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1000 MW**  
400 MW  
1400 MW

### SCH-NYISO-HQ\_LIMIT\_300

Wed 09/10/2025 to Wed 09/10/2025  
0800 Continuous 1959  
Work scheduled by: HQ

SCH - HQ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**300 MW**  
700 MW  
1000 MW

### SCH-NYISO-HQ\_LIMIT\_0

Wed 09/10/2025 to Thu 09/11/2025  
2000 Continuous 0759  
Work scheduled by: HQ

SCH - HQ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**0 MW**  
1000 MW  
1000 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, September 3, 2025 to Tuesday, March 2, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_500

Wed 09/10/2025 to Thu 09/11/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	<b>700 MW</b>	
TTC with All Lines In Service	700 MW	
	1400 MW	

### SCH-NE-NYISO\_LIMIT\_800

Thu 09/11/2025 to Thu 09/11/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	<b>1000 MW</b>	
TTC with All Lines In Service	400 MW	
	1400 MW	

### SCH-NYISO-HQ\_LIMIT\_300

Thu 09/11/2025 to Thu 09/11/2025  
0800 Continuous 1959  
Work scheduled by: HQ

SCH - HQ - NY	FWD (Import)	REV (Export)
Impacts Total Transfer Capability		<b>300 MW</b>
TTC with All Lines In Service		700 MW
		1000 MW

### SCH-NYISO-HQ\_LIMIT\_0

Thu 09/11/2025 to Fri 09/12/2025  
2000 Continuous 0759  
Work scheduled by: HQ

SCH - HQ - NY	FWD (Import)	REV (Export)
Impacts Total Transfer Capability		<b>0 MW</b>
TTC with All Lines In Service		1000 MW
		1000 MW

### SCH-NE-NYISO\_LIMIT\_500

Thu 09/11/2025 to Fri 09/12/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	<b>700 MW</b>	
TTC with All Lines In Service	700 MW	
	1400 MW	

### DENNISON-ROSEMNTA\_115\_1/11

Fri 09/12/2025 to Mon 09/15/2025  
0600 Continuous 0659  
Work scheduled by: NGrid

SCH - HQ_CEDARS	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	<b>95 MW</b>	<b>40 MW</b>
TTC with All Lines In Service	175 MW	60 MW
	270 MW	100 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, September 3, 2025 to Tuesday, March 2, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_800

Fri 09/12/2025 to Fri 09/12/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1000 MW**  
400 MW  
1400 MW

### SCH-NYISO-HQ\_LIMIT\_300

Fri 09/12/2025 to Fri 09/12/2025  
0800 Continuous 1959  
Work scheduled by: HQ

SCH - HQ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**300 MW**  
700 MW  
1000 MW

### SCH-NYISO-HQ\_LIMIT\_0

Fri 09/12/2025 to Sat 09/13/2025  
2000 Continuous 0759  
Work scheduled by: HQ

SCH - HQ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**0 MW**  
1000 MW  
1000 MW

### SCH-NE-NYISO\_LIMIT\_500

Fri 09/12/2025 to Sat 09/13/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**700 MW**  
700 MW  
1400 MW

### MILLWOOD-EASTVIEW\_345\_W82

Sat 09/13/2025 to Sat 09/13/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**7810 MW**  
240 MW  
8050 MW

### SCH-NE-NYISO\_LIMIT\_800

Sat 09/13/2025 to Sat 09/13/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1000 MW**  
400 MW  
1400 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, September 3, 2025 to Tuesday, March 2, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NYISO-HQ\_LIMIT\_300

Sat 09/13/2025 to Sat 09/13/2025  
0800 Continuous 1959  
Work scheduled by: HQ

SCH - HQ - NY

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

**300 MW**

TTC with All Lines In Service

700 MW

1000 MW

### SCH-NYISO-HQ\_LIMIT\_0

Sat 09/13/2025 to Sun 09/14/2025  
2000 Continuous 0759  
Work scheduled by: HQ

SCH - HQ - NY

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

**0 MW**

TTC with All Lines In Service

1000 MW

1000 MW

### SCH-NE-NYISO\_LIMIT\_500

Sat 09/13/2025 to Sun 09/14/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

**700 MW**

TTC with All Lines In Service

700 MW

1400 MW

### SCH-NE-NYISO\_LIMIT\_800

Sun 09/14/2025 to Sun 09/14/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

**1000 MW**

TTC with All Lines In Service

400 MW

1400 MW

### SCH-NYISO-HQ\_LIMIT\_300

Sun 09/14/2025 to Sun 09/14/2025  
0800 Continuous 1959  
Work scheduled by: HQ

SCH - HQ - NY

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

**300 MW**

TTC with All Lines In Service

700 MW

1000 MW

### SCH-NYISO-HQ\_LIMIT\_0

Sun 09/14/2025 to Mon 09/15/2025  
2000 Continuous 0759  
Work scheduled by: HQ

SCH - HQ - NY

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

**0 MW**

TTC with All Lines In Service

1000 MW

1000 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, September 3, 2025 to Tuesday, March 2, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_500

Sun 09/14/2025 to Mon 09/15/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**700 MW**  
700 MW  
1400 MW

### RAMAPO\_-BUCHAN\_N\_345\_Y94

Mon 09/15/2025 to Wed 09/17/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

UPDATED by ConEd 06/18/2025 12:30

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**7755 MW**  
295 MW  
8050 MW

### SPRNBK\_345KV\_RNS4

Mon 09/15/2025 to Thu 10/02/2025  
0001 Continuous 0200  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3200 MW**  
1400 MW  
4600 MW

### SPRNBK\_-W49TH\_ST\_345\_M52

Mon 09/15/2025 to Thu 10/02/2025  
0001 Continuous 0200  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3200 MW**  
1400 MW  
4600 MW

### W49TH\_ST\_345KV\_5

Mon 09/15/2025 to Mon 09/15/2025  
0001 Continuous 0030  
Work scheduled by: ConEd

SCH - PJM\_HTP  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**460 MW**  
200 MW  
660 MW

### GOETHALS\_345KV\_5

Mon 09/15/2025 to Mon 09/15/2025  
0230 Continuous 0300  
Work scheduled by: ConEd

CANCELLED by TO 09/02/2025 15:19

STATEN ISLAND  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, September 3, 2025 to Tuesday, March 2, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### ADIRNDCK-PORTER\_\_230\_12

Mon 09/15/2025 to Wed 12/31/2025  
0600 Continuous 2359  
Work scheduled by: NGrid

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **2100 MW**  
REV (Export) 1050 MW  
3150 MW

### MARCY\_\_345KV\_CSC

Mon 09/15/2025 to Wed 09/24/2025  
0600 Continuous 1730  
Work scheduled by: NYPA

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **3650 MW**  
REV (Export) 75 MW  
3725 MW

### CEDARS\_\_ROSEMNTA\_115\_1/11

Mon 09/15/2025 to Thu 09/18/2025  
0700 Continuous 1600  
Work scheduled by: HQ

SCH - HQ\_CEDARS  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **95 MW**  
REV (Export) **40 MW**  
175 MW 60 MW  
270 MW 100 MW

### DENNISON-ROSEMNTA\_115\_1/11

Mon 09/15/2025 to Thu 09/18/2025  
0700 Continuous 1600  
Work scheduled by: HQ

SCH - HQ\_CEDARS  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) **95 MW**  
REV (Export) **40 MW**  
175 MW 60 MW  
270 MW 100 MW

### DOVER\_\_CRICKVLY\_345\_Y17 , NRTH1385-NORHBR\_138\_601

Mon 09/15/2025 to Fri 10/10/2025  
0700 1500  
Work scheduled by:

SCH - NPX\_1385  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) REV (Export)

### DOVER\_\_CRICKVLY\_345\_Y17 , NRTH1385-NORHBR\_138\_602

Mon 09/15/2025 to Fri 10/10/2025  
0700 1500  
Work scheduled by:

SCH - NPX\_1385  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) REV (Export)

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, September 3, 2025 to Tuesday, March 2, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### DOVER\_\_CRICKVLY\_345\_Y17 , NRTH1385-NORHBR\_138\_603

Mon 09/15/2025 to Fri 10/10/2025  
0700 1500  
Work scheduled by:

SCH - NPX\_1385  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### LONG\_MTN-DOVER\_\_345\_398 , NRTH1385-NORHBR\_138\_601

Mon 09/15/2025 to Fri 10/10/2025  
0700 1500  
Work scheduled by:

SCH - NPX\_1385  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### LONG\_MTN-DOVER\_\_345\_398 , NRTH1385-NORHBR\_138\_602

Mon 09/15/2025 to Fri 10/10/2025  
0700 1500  
Work scheduled by:

SCH - NPX\_1385  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### LONG\_MTN-DOVER\_\_345\_398 , NRTH1385-NORHBR\_138\_603

Mon 09/15/2025 to Fri 10/10/2025  
0700 1500  
Work scheduled by:

SCH - NPX\_1385  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### NRTH1385-NOR HBR\_138\_601

Mon 09/15/2025 to Fri 10/10/2025  
0700 Continuous 1500  
Work scheduled by: LI

SCH - NPX\_1385  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**25 MW** **25 MW**  
100 MW 100 MW  
125 MW 125 MW

### NRTH1385-NOR HBR\_138\_602

Mon 09/15/2025 to Fri 10/10/2025  
0700 Continuous 1500  
Work scheduled by: LI

SCH - NPX\_1385  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**25 MW** **25 MW**  
100 MW 100 MW  
125 MW 125 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, September 3, 2025 to Tuesday, March 2, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>NRTH1385-NOR HBR_138_603</b>					FWD (Import)	REV (Export)
Mon 09/15/2025	to	Fri 10/10/2025		SCH - NPX_1385	<b>25 MW</b>	<b>25 MW</b>
0700	Continuous	1500		Impacts Total Transfer Capability	100 MW	100 MW
Work scheduled by: LI				TTC with All Lines In Service	125 MW	125 MW
<b>NRTH1385-NORHBR_138_601 , NRTH1385-NORHBR_138_602</b>					FWD (Import)	REV (Export)
Mon 09/15/2025	to	Fri 10/10/2025		SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
0700		1500		Impacts Total Transfer Capability	125 MW	125 MW
Work scheduled by:				TTC with All Lines In Service	125 MW	125 MW
<b>NRTH1385-NORHBR_138_601 , NRTH1385-NORHBR_138_603</b>					FWD (Import)	REV (Export)
Mon 09/15/2025	to	Fri 10/10/2025		SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
0700		1500		Impacts Total Transfer Capability	125 MW	125 MW
Work scheduled by:				TTC with All Lines In Service	125 MW	125 MW
<b>NRTH1385-NORHBR_138_602 , NRTH1385-NORHBR_138_603</b>					FWD (Import)	REV (Export)
Mon 09/15/2025	to	Fri 10/10/2025		SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
0700		1500		Impacts Total Transfer Capability	125 MW	125 MW
Work scheduled by:				TTC with All Lines In Service	125 MW	125 MW
<b>NRTH1385-NRTHPORT_138_NNC</b>					FWD (Import)	REV (Export)
Mon 09/15/2025	to	Fri 10/10/2025		SCH - NPX_1385	<b>0 MW</b>	<b>0 MW</b>
0700	Continuous	1500		Impacts Total Transfer Capability	125 MW	125 MW
Work scheduled by: LI				TTC with All Lines In Service	125 MW	125 MW
<b>SCH-HQ_CEDARS-NYISO_LIMIT_220</b>					FWD (Import)	REV (Export)
Mon 09/15/2025	to	Thu 10/09/2025		SCH - HQ_CEDARS	<b>220 MW</b>	
0700	Continuous	2000		Impacts Total Transfer Capability	50 MW	
Work scheduled by: HQ				TTC with All Lines In Service	270 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, September 3, 2025 to Tuesday, March 2, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-HQ\_CEDARS-NYISO\_LIMIT\_40

Mon 09/15/2025 to Thu 09/18/2025  
0700 Continuous 1600  
Work scheduled by: HQ

SCH - HQ_CEDARS	<b>40 MW</b>	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	230 MW		
TTC with All Lines In Service	270 MW		

### SCH-NE-NYISO\_LIMIT\_800

Mon 09/15/2025 to Mon 09/15/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY	<b>1000 MW</b>	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	400 MW		
TTC with All Lines In Service	1400 MW		

### SCH-NYISO-HQ\_CEDARS\_LIMIT\_0

Mon 09/15/2025 to Thu 10/09/2025  
0700 Continuous 2000  
Work scheduled by: HQ

SCH - HQ_CEDARS	<b>0 MW</b>	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	100 MW		
TTC with All Lines In Service	100 MW		

### SCH-NYISO-HQ\_LIMIT\_300

Mon 09/15/2025 to Mon 09/15/2025  
0800 Continuous 1959  
Work scheduled by: HQ

SCH - HQ - NY	<b>300 MW</b>	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	700 MW		
TTC with All Lines In Service	1000 MW		

### SCH-NYISO-HQ\_LIMIT\_0

Mon 09/15/2025 to Tue 09/16/2025  
2000 Continuous 0759  
Work scheduled by: HQ

SCH - HQ - NY	<b>0 MW</b>	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	1000 MW		
TTC with All Lines In Service	1000 MW		

### SCH-NE-NYISO\_LIMIT\_500

Mon 09/15/2025 to Tue 09/16/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY	<b>700 MW</b>	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	700 MW		
TTC with All Lines In Service	1400 MW		



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, September 3, 2025 to Tuesday, March 2, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### DYSINGER-STA\_255\_345\_DH2

Tue 09/16/2025 to Tue 10/28/2025  
0500 Continuous 1900  
Work scheduled by: NYPA

DYSINGER EAST  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**2850 MW**  
350 MW  
3200 MW

### SCH-NE-NYISO\_LIMIT\_800

Tue 09/16/2025 to Tue 09/16/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1000 MW**  
400 MW  
1400 MW

### SCH-NYISO-HQ\_LIMIT\_300

Tue 09/16/2025 to Tue 09/16/2025  
0800 Continuous 1959  
Work scheduled by: HQ

SCH - HQ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**300 MW**  
700 MW  
1000 MW

### SCH-NYISO-HQ\_LIMIT\_0

Tue 09/16/2025 to Wed 09/17/2025  
2000 Continuous 0759  
Work scheduled by: HQ

SCH - HQ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**0 MW**  
1000 MW  
1000 MW

### SCH-NE-NYISO\_LIMIT\_500

Tue 09/16/2025 to Wed 09/17/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**700 MW**  
700 MW  
1400 MW

### GOETHALS\_345KV\_5

Wed 09/17/2025 to Wed 09/17/2025  
0301 Continuous 0330  
Work scheduled by: ConEd

STATEN ISLAND  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, September 3, 2025 to Tuesday, March 2, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_800

Wed 09/17/2025 to Wed 09/17/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1000 MW**  
400 MW  
1400 MW

### SCH-NYISO-HQ\_LIMIT\_300

Wed 09/17/2025 to Wed 09/17/2025  
0800 Continuous 1959  
Work scheduled by: HQ

SCH - HQ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**300 MW**  
700 MW  
1000 MW

### SCH-NYISO-HQ\_LIMIT\_0

Wed 09/17/2025 to Thu 09/18/2025  
2000 Continuous 0759  
Work scheduled by: HQ

SCH - HQ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**0 MW**  
1000 MW  
1000 MW

### SCH-NE-NYISO\_LIMIT\_500

Wed 09/17/2025 to Thu 09/18/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**700 MW**  
700 MW  
1400 MW

### RAMAPO\_-BUCHAN\_N\_345\_Y94

Thu 09/18/2025 to Sat 09/20/2025  
0001 Continuous 0259  
Work scheduled by: ConEd

EXTENDED by ConEd 06/12/2025 10:19

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**7755 MW**  
295 MW  
8050 MW

### SCH-NE-NYISO\_LIMIT\_800

Thu 09/18/2025 to Thu 09/18/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1000 MW**  
400 MW  
1400 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, September 3, 2025 to Tuesday, March 2, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NYISO-HQ\_LIMIT\_300

Thu 09/18/2025 to Thu 09/18/2025  
0800 Continuous 0900  
Work scheduled by: HQ

SCH - HQ - NY

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

**300 MW**

TTC with All Lines In Service

700 MW

1000 MW

### DENNISON-ROSEMNTA\_115\_1/11

Thu 09/18/2025 to Sat 10/04/2025  
1601 Continuous 1830  
Work scheduled by: NGrid

SCH - HQ\_CEDARS

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

**95 MW**

**40 MW**

TTC with All Lines In Service

175 MW

60 MW

270 MW

100 MW

### SCH-NE-NYISO\_LIMIT\_500

Thu 09/18/2025 to Fri 09/19/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

**700 MW**

TTC with All Lines In Service

700 MW

1400 MW

### SCH-NE-NYISO\_LIMIT\_800

Fri 09/19/2025 to Fri 09/19/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

**1000 MW**

TTC with All Lines In Service

400 MW

1400 MW

### SCH-NE-NYISO\_LIMIT\_500

Fri 09/19/2025 to Sat 09/20/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

**700 MW**

TTC with All Lines In Service

700 MW

1400 MW

### SCH-NE-NYISO\_LIMIT\_800

Sat 09/20/2025 to Sat 09/20/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY

FWD (Import)

REV (Export)

Impacts Total Transfer Capability

**1000 MW**

TTC with All Lines In Service

400 MW

1400 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, September 3, 2025 to Tuesday, March 2, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_500

Sat 09/20/2025 to Sun 09/21/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability 700 MW  
TTC with All Lines In Service 1400 MW

FWD (Import) REV (Export)

### SCH-NE-NYISO\_LIMIT\_800

Sun 09/21/2025 to Sun 09/21/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 1400 MW

FWD (Import) REV (Export)

### SCH-NE-NYISO\_LIMIT\_500

Sun 09/21/2025 to Mon 09/22/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability 700 MW  
TTC with All Lines In Service 1400 MW

FWD (Import) REV (Export)

### WOOD\_ST\_PLSNTVLE\_345\_Y86

Mon 09/22/2025 to Fri 09/26/2025  
0001 Continuous 0200  
Work scheduled by: ConEd

UPNY CONED  
Impacts Total Transfer Capability 575 MW  
TTC with All Lines In Service 8050 MW

FWD (Import) REV (Export)

### SCH-NE-NYISO\_LIMIT\_800

Mon 09/22/2025 to Mon 09/22/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability 400 MW  
TTC with All Lines In Service 1400 MW

FWD (Import) REV (Export)

### SCH-NE-NYISO\_LIMIT\_500

Mon 09/22/2025 to Tue 09/23/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability 700 MW  
TTC with All Lines In Service 1400 MW

FWD (Import) REV (Export)

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, September 3, 2025 to Tuesday, March 2, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_800

Tue 09/23/2025 to Tue 09/23/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1000 MW**  
400 MW  
1400 MW

### CHAT\_DC\_GC1

Tue 09/23/2025 to Tue 09/23/2025  
1301 Continuous 1359  
Work scheduled by: HQ

UPDATED by HQ, 08/21/2025 15:12

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**2850 MW**  
300 MW  
3150 MW

### CHAT\_DC\_GC1

Tue 09/23/2025 to Tue 09/23/2025  
1301 Continuous 1359  
Work scheduled by: HQ

UPDATED by HQ, 08/21/2025 15:12

SCH - HQ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**500 MW**  
500 MW  
1000 MW

### CHAT\_DC\_GC1 , CHAT\_DC\_GC2

Tue 09/23/2025 to Tue 09/23/2025  
1301 1359  
Work scheduled by:

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**2550 MW**  
600 MW  
3150 MW

### CHAT\_DC\_GC1 , CHAT\_DC\_GC2

Tue 09/23/2025 to Tue 09/23/2025  
1301 1359  
Work scheduled by:

SCH - HQ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1370 MW** **0 MW**  
130 MW 1000 MW  
1500 MW 1000 MW

### CHAT\_DC\_GC2

Tue 09/23/2025 to Tue 09/23/2025  
1301 Continuous 1359  
Work scheduled by: HQ

UPDATED by HQ, 08/21/2025 15:12

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**2850 MW**  
300 MW  
3150 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, September 3, 2025 to Tuesday, March 2, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### CHAT\_DC\_GC2

Tue 09/23/2025 to Tue 09/23/2025  
1301 Continuous 1359  
Work scheduled by: HQ

UPDATED by HQ 08/21/2025 15:12

SCH - HQ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**500 MW**  
500 MW  
1000 MW

### SCH-HQ-NYISO\_LIMIT\_1200

Tue 09/23/2025 to Tue 09/23/2025  
1301 Continuous 1359  
Work scheduled by: HQ

UPDATED by HQ 08/21/2025 15:12

SCH - HQ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1200 MW**  
300 MW  
1500 MW

### SCH-NE-NYISO\_LIMIT\_500

Tue 09/23/2025 to Wed 09/24/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**700 MW**  
700 MW  
1400 MW

### GOETHALS\_345KV\_5

Wed 09/24/2025 to Wed 09/24/2025  
0230 Continuous 0300  
Work scheduled by: ConEd

STATEN ISLAND  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**700 MW**  
700 MW  
1400 MW

### SCH-NE-NYISO\_LIMIT\_800

Wed 09/24/2025 to Wed 09/24/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1000 MW**  
400 MW  
1400 MW

### SCH-NE-NYISO\_LIMIT\_500

Wed 09/24/2025 to Thu 09/25/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**700 MW**  
700 MW  
1400 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, September 3, 2025 to Tuesday, March 2, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MARCY\_\_FRASANNX\_345\_UCC2-41

Thu 09/25/2025 to Fri 10/17/2025  
0700 Continuous 1730  
Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3225 MW**  
500 MW  
3725 MW

### SCH-NE-NYISO\_LIMIT\_800

Thu 09/25/2025 to Thu 09/25/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1000 MW**  
400 MW  
1400 MW

### SCH-NE-NYISO\_LIMIT\_500

Thu 09/25/2025 to Fri 09/26/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**700 MW**  
700 MW  
1400 MW

### W49TH\_ST\_345KV\_5

Fri 09/26/2025 to Sat 09/27/2025  
0001 Continuous 0100  
Work scheduled by: ConEd

SCH - PJM\_HTP  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**460 MW**  
200 MW  
660 MW

### SCH-NE-NYISO\_LIMIT\_800

Fri 09/26/2025 to Fri 09/26/2025  
0700 Daily 1559  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1000 MW**  
400 MW  
1400 MW

### SCH-NE-NYISO\_LIMIT\_900

Fri 09/26/2025 to Fri 09/26/2025  
1600 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1100 MW**  
300 MW  
1400 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, September 3, 2025 to Tuesday, March 2, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-NE-NYISO\_LIMIT\_600

Fri 09/26/2025 to Sat 09/27/2025  
 2300 Daily 0659  
 Work scheduled by: ISONE

SCH - NE - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**800 MW**  
 600 MW  
 1400 MW

### BUCHAN\_S-MILLWOOD\_345\_W98

Sat 09/27/2025 to Sun 09/28/2025  
 0001 Continuous 2230  
 Work scheduled by: ConEd

UPNY CONED  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**8015 MW**  
 35 MW  
 8050 MW

### SCH-NE-NYISO\_LIMIT\_900

Sat 09/27/2025 to Sat 09/27/2025  
 0700 Daily 2259  
 Work scheduled by: ISONE

SCH - NE - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**1100 MW**  
 300 MW  
 1400 MW

### SCH-NE-NYISO\_LIMIT\_600

Sat 09/27/2025 to Sun 09/28/2025  
 2300 Daily 0659  
 Work scheduled by: ISONE

SCH - NE - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**800 MW**  
 600 MW  
 1400 MW

### SCH-NE-NYISO\_LIMIT\_900

Sun 09/28/2025 to Sun 09/28/2025  
 0700 Daily 2259  
 Work scheduled by: ISONE

SCH - NE - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**1100 MW**  
 300 MW  
 1400 MW

### SCH-NE-NYISO\_LIMIT\_600

Sun 09/28/2025 to Mon 09/29/2025  
 2300 Daily 0659  
 Work scheduled by: ISONE

SCH - NE - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**800 MW**  
 600 MW  
 1400 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, September 3, 2025 to Tuesday, March 2, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### PANNELL\_-CLAY\_\_\_345\_1

Mon 09/29/2025 to Fri 10/03/2025  
0700 Continuous 1530  
Work scheduled by: NYPA

WEST CENTRAL	FWD (Import)	REV (Export)
	<b>1300 MW</b>	
Impacts Total Transfer Capability	950 MW	
TTC with All Lines In Service	2250 MW	

### SCH-NE-NYISO\_LIMIT\_900

Mon 09/29/2025 to Mon 09/29/2025  
0700 Daily 2259  
Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>1100 MW</b>	
Impacts Total Transfer Capability	300 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NE-NYISO\_LIMIT\_600

Mon 09/29/2025 to Tue 09/30/2025  
2300 Daily 0659  
Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>800 MW</b>	
Impacts Total Transfer Capability	600 MW	
TTC with All Lines In Service	1400 MW	

### SCH-NE-NYISO\_LIMIT\_900

Tue 09/30/2025 to Tue 09/30/2025  
0700 Daily 0800  
Work scheduled by: ISONE

SCH - NE - NY	FWD (Import)	REV (Export)
	<b>1100 MW</b>	
Impacts Total Transfer Capability	300 MW	
TTC with All Lines In Service	1400 MW	

### DUNWODIE\_345KV\_6

Wed 10/01/2025 to Thu 10/02/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

### DUNWODIE\_345KV\_8

Wed 10/01/2025 to Thu 10/02/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, September 3, 2025 to Tuesday, March 2, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### W49TH\_ST\_345KV\_5

Thu 10/02/2025 to Thu 10/02/2025  
0130 Continuous 0200  
Work scheduled by: ConEd

SCH - PJM\_HTP

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**460 MW**

200 MW

660 MW

### W49TH\_ST\_345KV\_6

Thu 10/02/2025 to Thu 10/02/2025  
0201 Continuous 0231  
Work scheduled by: ConEd

SCH - PJM\_HTP

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**300 MW**

360 MW

660 MW

### W49TH\_ST\_345KV\_8

Thu 10/02/2025 to Thu 10/02/2025  
0201 Continuous 0231  
Work scheduled by: ConEd

SCH - PJM\_HTP

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**350 MW**

310 MW

660 MW

### WOOD\_ST\_PLSNTVLE\_345\_Y87

Fri 10/03/2025 to Sun 10/05/2025  
2200 Continuous 0259  
Work scheduled by: ConEd

UPNY CONED

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**7470 MW**

580 MW

8050 MW

### W49TH\_ST\_345KV\_6

Mon 10/06/2025 to Mon 10/06/2025  
0030 Continuous 0100  
Work scheduled by: ConEd

SCH - PJM\_HTP

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**300 MW**

360 MW

660 MW

### W49TH\_ST\_345KV\_8

Mon 10/06/2025 to Mon 10/06/2025  
0030 Continuous 0100  
Work scheduled by: ConEd

SCH - PJM\_HTP

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**350 MW**

310 MW

660 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, September 3, 2025 to Tuesday, March 2, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SCH-IMO\_NY\_NIAG\_CB\_3122\_W/BB

Mon 10/06/2025 to Wed 10/08/2025  
0500 Continuous 1800  
Work scheduled by: NYPA

SCH - OH - NY	FWD (Import)	REV (Export)
	<b>1950 MW</b>	<b>1400 MW</b>
Impacts Total Transfer Capability	50 MW	200 MW
TTC with All Lines In Service	2000 MW	1600 MW

### PANNELL-CLAY\_345\_2

Mon 10/06/2025 to Fri 10/10/2025  
0700 Continuous 1530  
Work scheduled by: NYPA

WEST CENTRAL	FWD (Import)	REV (Export)
	<b>1300 MW</b>	
Impacts Total Transfer Capability	950 MW	
TTC with All Lines In Service	2250 MW	

### ROCHESTR-PANNELL\_345\_RP2

Mon 10/06/2025 to Wed 10/08/2025  
0730 Continuous 1500  
Work scheduled by: RGE

DYSINGER EAST	FWD (Import)	REV (Export)
	<b>2300 MW</b>	
Impacts Total Transfer Capability	900 MW	
TTC with All Lines In Service	3200 MW	

### MILLWOOD-EASTVIEW\_345\_W85

Fri 10/10/2025 to Sun 10/19/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

UPNY CONED	FWD (Import)	REV (Export)
	<b>7810 MW</b>	
Impacts Total Transfer Capability	240 MW	
TTC with All Lines In Service	8050 MW	

### SPRNBK\_345KV\_RNS3

Fri 10/10/2025 to Fri 10/10/2025  
0001 Continuous 0030  
Work scheduled by: ConEd

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

### DUNWODIE\_345KV\_3

Mon 10/13/2025 to Mon 10/13/2025  
0001 Continuous 0030  
Work scheduled by: ConEd

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, September 3, 2025 to Tuesday, March 2, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### DUNWODIE\_345KV\_5

Mon 10/13/2025 to Mon 10/13/2025  
0001 Continuous 0030  
Work scheduled by: ConEd

SPR/DUN-SOUTH FWD (Import) REV (Export)  
Impacts Total Transfer Capability **3800 MW** 800 MW  
TTC with All Lines In Service 4600 MW

### DUNWODIE-MOTTHAVN\_345\_71

Mon 10/13/2025 to Tue 10/14/2025  
0001 Continuous 0200  
Work scheduled by: ConEd

SPR/DUN-SOUTH FWD (Import) REV (Export)  
Impacts Total Transfer Capability **3800 MW** 800 MW  
TTC with All Lines In Service 4600 MW

### UNIONDHB\_345\_138\_AT1

Mon 10/13/2025 to Mon 10/13/2025  
0001 Continuous 2359  
Work scheduled by: LI

CONED - LIPA FWD (Import) REV (Export)  
Impacts Total Transfer Capability **1250 MW** 250 MW  
TTC with All Lines In Service 1500 MW

### W49TH\_ST\_345KV\_5

Mon 10/13/2025 to Tue 10/14/2025  
0001 Continuous 1800  
Work scheduled by: ConEd

SCH - PJM\_HTP FWD (Import) REV (Export)  
Impacts Total Transfer Capability **460 MW** 200 MW  
TTC with All Lines In Service 660 MW

### W49TH\_ST\_345KV\_7

Mon 10/13/2025 to Sat 10/18/2025  
0001 Continuous 0200  
Work scheduled by: ConEd

SCH - PJM\_HTP FWD (Import) REV (Export)  
Impacts Total Transfer Capability **460 MW** 200 MW  
TTC with All Lines In Service 660 MW

### ADIRNDCK-CHASLAKE\_230\_13

Mon 10/13/2025 to Wed 12/31/2025  
0530 Continuous 2359  
Work scheduled by: NGrid

MOSES SOUTH FWD (Import) REV (Export)  
Impacts Total Transfer Capability **2100 MW** 1050 MW  
TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, September 3, 2025 to Tuesday, March 2, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>ADIRNDCK-PORTER__230_12 , ADIRNDCK-CHASLAKE_230_13</b>				FWD (Import)	REV (Export)
Mon 10/13/2025	to	Wed 12/31/2025	SCH - HQ_CEDARS	<b>140 MW</b>	
0530		2359	Impacts Total Transfer Capability	130 MW	
Work scheduled by:			TTC with All Lines In Service	270 MW	
<b>ADIRNDCK-PORTER__230_12 , ADIRNDCK-CHASLAKE_230_13</b>				FWD (Import)	REV (Export)
Mon 10/13/2025	to	Wed 12/31/2025	MOSES SOUTH	<b>500 MW</b>	
0530		2359	Impacts Total Transfer Capability	2650 MW	
Work scheduled by:			TTC with All Lines In Service	3150 MW	
<b>ADIRNDCK-PORTER__230_12 , CHASLAKE-PORTER__230_11</b>				FWD (Import)	REV (Export)
Mon 10/13/2025	to	Wed 12/31/2025	SCH - HQ_CEDARS	<b>140 MW</b>	
0530		2359	Impacts Total Transfer Capability	130 MW	
Work scheduled by:			TTC with All Lines In Service	270 MW	
<b>ADIRNDCK-PORTER__230_12 , CHASLAKE-PORTER__230_11</b>				FWD (Import)	REV (Export)
Mon 10/13/2025	to	Wed 12/31/2025	MOSES SOUTH	<b>500 MW</b>	
0530		2359	Impacts Total Transfer Capability	2650 MW	
Work scheduled by:			TTC with All Lines In Service	3150 MW	
<b>CHASLAKE-PORTER__230_11</b>				FWD (Import)	REV (Export)
Mon 10/13/2025	to	Wed 12/31/2025	MOSES SOUTH	<b>2100 MW</b>	
0530	Continuous	2359	Impacts Total Transfer Capability	1050 MW	
Work scheduled by: NGrid			TTC with All Lines In Service	3150 MW	
<b>NEPTUNE_DUFFYAVE_345_NEPTUNE</b>				FWD (Import)	REV (Export)
Mon 10/13/2025	to	Fri 10/17/2025	SCH - PJM_NEPTUNE	<b>0 MW</b>	
0600	Continuous	1600	Impacts Total Transfer Capability	660 MW	
Work scheduled by: LI			TTC with All Lines In Service	660 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, September 3, 2025 to Tuesday, March 2, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### NEWBRDGE\_345\_138\_BK\_1

Mon 10/13/2025 to Fri 10/17/2025  
 0600 Continuous 1600  
 Work scheduled by: LI

SCH - PJM\_NEPTUNE **375 MW**  
 Impacts Total Transfer Capability 285 MW  
 TTC with All Lines In Service 660 MW

### NEWBRDGE\_345\_138\_BK\_2

Mon 10/13/2025 to Fri 10/17/2025  
 0600 Continuous 1600  
 Work scheduled by: LI

SCH - PJM\_NEPTUNE **375 MW**  
 Impacts Total Transfer Capability 285 MW  
 TTC with All Lines In Service 660 MW

### NEWBRDGE-DUFFYAVE\_345\_501

Mon 10/13/2025 to Fri 10/17/2025  
 0600 Continuous 1600  
 Work scheduled by: LI

SCH - PJM\_NEPTUNE **0 MW**  
 Impacts Total Transfer Capability 660 MW  
 TTC with All Lines In Service 660 MW

### MOSES\_\_-ADIRNDCK\_230\_MA1 , MOSES\_\_-ADIRNDCK\_230\_MA2

Mon 10/13/2025 to Wed 12/31/2025  
 0700 2359  
 Work scheduled by:

MOSES SOUTH **500 MW**  
 Impacts Total Transfer Capability 2650 MW  
 TTC with All Lines In Service 3150 MW

### MOSES\_\_-ADIRNDCK\_230\_MA1 , MOSES\_\_-ADIRNDCK\_230\_MA2

Mon 10/13/2025 to Wed 12/31/2025  
 0700 2359  
 Work scheduled by:

SCH - HQ\_CEDARS **140 MW**  
 Impacts Total Transfer Capability 130 MW  
 TTC with All Lines In Service 270 MW

### MOSES\_\_-ADIRNDCK\_230\_MA2

Mon 10/13/2025 to Wed 12/31/2025  
 0700 Continuous 2359  
 Work scheduled by: NYPA

UPDATED by NYPA 02/21/2025 15:57

MOSES SOUTH **2100 MW**  
 Impacts Total Transfer Capability 1050 MW  
 TTC with All Lines In Service 3150 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, September 3, 2025 to Tuesday, March 2, 2027

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 7550 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### WATRCURE-OAKDALE\_345\_31

Mon 10/13/2025 to Fri 10/24/2025  
0700 Continuous 1500  
Work scheduled by: NYSEG

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
2000 MW	1050 MW
200 MW	150 MW
2200 MW	1200 MW

### DUNWODIE\_345KV\_3

Tue 10/14/2025 to Tue 10/14/2025  
0130 Continuous 0200  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
3800 MW	
800 MW	
4600 MW	

### DUNWODIE\_345KV\_5

Tue 10/14/2025 to Tue 10/14/2025  
0130 Continuous 0200  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
3800 MW	
800 MW	
4600 MW	

### EDIC\_\_PRINCTWN\_345\_351

Tue 10/14/2025 to Fri 10/17/2025  
0600 Continuous 1830  
Work scheduled by: NGrid

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
3335 MW	
390 MW	
3725 MW	

### MARCY\_\_765\_345\_AT2

Wed 10/15/2025 to Wed 10/15/2025  
0500 Continuous 1730  
Work scheduled by: NYPA

UPDATED by NYPA 04/22/2025 12:32

ARR: 19

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
1700 MW	
1450 MW	
3150 MW	

### W49TH\_ST\_345KV\_5

Thu 10/16/2025 to Thu 10/16/2025  
0130 Continuous 0159  
Work scheduled by: ConEd

SCH - PJM\_HTP  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
460 MW	
200 MW	
660 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, September 3, 2025 to Tuesday, March 2, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### W49TH\_ST\_345KV\_5

Sat 10/18/2025 to Sat 10/18/2025  
0130 Continuous 0159  
Work scheduled by: ConEd

SCH - PJM\_HTP

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**460 MW**

200 MW

660 MW

### SPRNBK\_345KV\_RNS3

Sun 10/19/2025 to Sun 10/19/2025  
2130 Continuous 2200  
Work scheduled by: ConEd

SPR/DUN-SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**3800 MW**

800 MW

4600 MW

### LONG\_MTN-CRICKVLY\_345\_398

Wed 10/22/2025 to Fri 11/21/2025  
0001 Continuous 2300  
Work scheduled by: ConEd

UPDATED by ConEd 07/23/2025 12:25

SCH - NPX\_1385

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**25 MW**

100 MW

125 MW

**25 MW**

100 MW

125 MW

### LONG\_MTN-CRICKVLY\_345\_398

Wed 10/22/2025 to Fri 11/21/2025  
0001 Continuous 2300  
Work scheduled by: ConEd

UPDATED by ConEd 07/23/2025 12:25

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**800 MW**

600 MW

1400 MW

**1200 MW**

400 MW

1600 MW

### SCH-NE-NYISO\_LIMIT\_500

Wed 10/22/2025 to Fri 11/21/2025  
0001 Continuous 2300  
Work scheduled by: ConEd

UPDATED by ConEd 07/23/2025 12:25

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**700 MW**

700 MW

1400 MW

### SPRNBK\_-TREMONT\_345\_X28

Sat 10/25/2025 to Sun 10/26/2025  
0001 Continuous 0200  
Work scheduled by: ConEd

SPR/DUN-SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**4200 MW**

400 MW

4600 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, September 3, 2025 to Tuesday, March 2, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### GOETHALS\_345KV\_5

Mon 10/27/2025 to Tue 10/28/2025  
0001 Continuous 0200  
Work scheduled by: ConEd

EXTENDED by ConEd 05/27/2025 11:13

STATEN ISLAND  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### HUDSONP\_-FARRAGUT\_345\_B3402 , LINDEN\_-GOETHALS\_230\_A2253

Mon 10/27/2025 to Tue 10/28/2025  
0001 0200  
Work scheduled by:

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**2000 MW** **1050 MW**  
200 MW 150 MW  
2200 MW 1200 MW

### LINDEN\_-GOETHALS\_230\_A2253

Mon 10/27/2025 to Tue 10/28/2025  
0001 Continuous 0200  
Work scheduled by: ConEd

EXTENDED by ConEd 05/27/2025 11:13

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### MARION\_-FARRAGUT\_345\_C3403 , HUDSONP\_-FARRAGUT\_345\_B3402 , LINDEN\_-GOETHALS\_230\_A2253

Mon 10/27/2025 to Tue 10/28/2025  
0001 0200  
Work scheduled by:

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**2000 MW** **1050 MW**  
200 MW 150 MW  
2200 MW 1200 MW

### MARION\_-FARRAGUT\_345\_C3403 , LINDEN\_-GOETHALS\_230\_A2253

Mon 10/27/2025 to Tue 10/28/2025  
0001 0200  
Work scheduled by:

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**2000 MW** **1050 MW**  
200 MW 150 MW  
2200 MW 1200 MW

### SPRNBK\_-TREMONT\_345\_X28

Mon 10/27/2025 to Fri 10/31/2025  
0001 Continuous 1800  
Work scheduled by: ConEd

UPDATED by ConEd 04/09/2025 09:25

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**4200 MW**  
400 MW  
4600 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, September 3, 2025 to Tuesday, March 2, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### HUDSONTP-W49TH\_ST\_345\_Y56

Mon 10/27/2025 to Thu 10/30/2025  
 0601 Continuous 1559  
 Work scheduled by: ConEd

SCH - PJM\_HTP

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**0 MW**

660 MW

660 MW

### FROST\_BR-LONG\_MTN\_345\_352

Mon 10/27/2025 to Wed 10/29/2025  
 0830 Continuous 1500  
 Work scheduled by: ISONE

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**1150 MW**

250 MW

1400 MW

### EDIC\_\_-GORDONRD\_345\_14

Tue 10/28/2025 to Tue 10/28/2025  
 0800 Daily 0900  
 Work scheduled by: NGrid

CENTRAL EAST - VC

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**2770 MW**

955 MW

3725 MW

### BECK\_\_-NIAGARA\_345\_PA302

Tue 10/28/2025 to Tue 10/28/2025  
 0900 Continuous 1700  
 Work scheduled by: IESO

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**1000 MW**

1000 MW

2000 MW

**850 MW**

750 MW

1600 MW

### LINDN\_CG-LNDVFT\_\_345\_V-3022

Mon 11/03/2025 to Thu 11/06/2025  
 0800 Continuous 1500  
 Work scheduled by: PJM

SCH - PJM\_VFT

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**0 MW**

315 MW

315 MW

**0 MW**

315 MW

315 MW

### MOTHAVN-RAINEY\_\_345\_Q11

Wed 11/05/2025 to Wed 12/17/2025  
 0001 Continuous 0100  
 Work scheduled by: ConEd

SPR/DUN-SOUTH

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import)

REV (Export)

**3800 MW**

800 MW

4600 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, September 3, 2025 to Tuesday, March 2, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MARCY\_\_FRASANNX\_345\_UCC2-41

Wed 11/05/2025 to Thu 11/13/2025  
0600 Continuous 2000  
Work scheduled by: NGrid

ARR: 19

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3225 MW**  
500 MW  
3725 MW

### W49TH\_ST\_345KV\_5

Fri 11/07/2025 to Sun 11/09/2025  
0001 Continuous 0100  
Work scheduled by: ConEd

SCH - PJM\_HTP  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**300 MW**  
360 MW  
660 MW

### W49TH\_ST\_345KV\_7

Fri 11/07/2025 to Sun 11/09/2025  
0001 Continuous 0100  
Work scheduled by: ConEd

SCH - PJM\_HTP  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**300 MW**  
360 MW  
660 MW

### SHOR\_NPX-SHOREHAM\_138\_CSC

Fri 11/07/2025 to Sat 11/22/2025  
0830 Continuous 1600  
Work scheduled by: ISONE

SCH - NPX\_CSC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**0 MW** **0 MW**  
330 MW 330 MW  
330 MW 330 MW

### WATRCURE-OAKDALE\_345\_31

Mon 11/10/2025 to Fri 11/14/2025  
0800 Continuous 1500  
Work scheduled by: NYSEG

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### LINDN\_CG-LNDVFT\_\_345\_V-3022

Thu 11/13/2025 to Thu 11/13/2025  
1500 Continuous 1800  
Work scheduled by: PJM

SCH - PJM\_VFT  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**0 MW** **0 MW**  
315 MW 315 MW  
315 MW 315 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, September 3, 2025 to Tuesday, March 2, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### ADIRNDCK-CHASLAKE\_230\_13 , MOSES\_\_-MASSENA\_230\_MMS2 , MOSES\_\_-MASSENA\_230\_MMS1

Sun 11/16/2025 to Sun 11/30/2025  
0001 2359  
Work scheduled by:

SCH - HQ\_CEDARS  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**90 MW**  
189 MW  
279 MW

### ADIRNDCK-PORTER\_230\_12 , MOSES\_\_-MASSENA\_230\_MMS2 , MOSES\_\_-MASSENA\_230\_MMS1

Sun 11/16/2025 to Sun 11/30/2025  
0001 2359  
Work scheduled by:

SCH - HQ\_CEDARS  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**90 MW**  
189 MW  
279 MW

### CHASLAKE-PORTER\_230\_11 , MOSES\_\_-MASSENA\_230\_MMS2 , MOSES\_\_-MASSENA\_230\_MMS1

Sun 11/16/2025 to Sun 11/30/2025  
0001 2359  
Work scheduled by:

SCH - HQ\_CEDARS  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**90 MW**  
189 MW  
279 MW

### CHATGUAY-MASSENA\_765\_7040

Sun 11/16/2025 to Sun 11/30/2025  
0001 Continuous 2359  
Work scheduled by: NYPA

SCH - HQ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**0 MW** **0 MW**  
1500 MW 1000 MW  
1500 MW 1000 MW

### CHATGUAY-MASSENA\_765\_7040

Sun 11/16/2025 to Sun 11/30/2025  
0001 Continuous 2359  
Work scheduled by: NYPA

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1550 MW**  
1600 MW  
3150 MW

### MARCY\_\_765\_345\_AT1

Sun 11/16/2025 to Sun 11/30/2025  
0001 Continuous 2359  
Work scheduled by: NYPA

UPDATED by NYPA 02/21/2025 15:46

ARR: 19

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1750 MW**  
1400 MW  
3150 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, September 3, 2025 to Tuesday, March 2, 2027

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 7550 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MARCY\_\_\_765\_345\_AT2

Sun 11/16/2025 to Sun 11/30/2025  
0001 Continuous 2359  
Work scheduled by: NYPA

UPDATED by NYPA 02/21/2025 15:46  
ARR: 19

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1700 MW**  
1450 MW  
3150 MW

### MASSENA\_MARCY\_\_\_765\_MSU1

Sun 11/16/2025 to Sun 11/30/2025  
0001 Continuous 2359  
Work scheduled by: NYPA

UPDATED by NYPA 02/21/2025 15:46

SCH - HQ\_CEDARS  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**90 MW**  
189 MW  
279 MW

### MASSENA\_MARCY\_\_\_765\_MSU1

Sun 11/16/2025 to Sun 11/30/2025  
0001 Continuous 2359  
Work scheduled by: NYPA

UPDATED by NYPA 02/21/2025 15:46

SCH - HQ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**475 MW 1000 MW**  
1025 MW 0 MW  
1500 MW 1000 MW

### MASSENA\_MARCY\_\_\_765\_MSU1

Sun 11/16/2025 to Sun 11/30/2025  
0001 Continuous 2359  
Work scheduled by: NYPA

UPDATED by NYPA 02/21/2025 15:46

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**500 MW**  
2650 MW  
3150 MW

### MASSENA\_MARCY\_\_\_765\_MSU1

Sun 11/16/2025 to Sun 11/30/2025  
0001 Continuous 2359  
Work scheduled by: NYPA

UPDATED by NYPA 02/21/2025 15:46

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**2595 MW**  
1130 MW  
3725 MW

### MASSENA\_MARCY\_\_\_765\_MSU1 , ADIRNDCK-CHASLAKE\_230\_13

Sun 11/16/2025 to Sun 11/30/2025  
0001 2359  
Work scheduled by:

SCH - HQ\_CEDARS  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**90 MW**  
189 MW  
279 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, September 3, 2025 to Tuesday, March 2, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

<b>MASSENA_MARCY__765_MSU1 , ADIRNDCK-PORTER__230_12</b>				FWD (Import)	REV (Export)
Sun 11/16/2025	to	Sun 11/30/2025	SCH - HQ_CEDARS	<b>90 MW</b>	
0001		2359	Impacts Total Transfer Capability	189 MW	
Work scheduled by:			TTC with All Lines In Service	279 MW	
<b>MASSENA_MARCY__765_MSU1 , ADIRNDCK-PORTER__230_12 , ADIRNDCK-CHASLAKE_230_13</b>				FWD (Import)	REV (Export)
Sun 11/16/2025	to	Sun 11/30/2025	SCH - HQ_CEDARS	<b>0 MW</b>	
0001		2359	Impacts Total Transfer Capability	279 MW	
Work scheduled by:			TTC with All Lines In Service	279 MW	
<b>MASSENA_MARCY__765_MSU1 , ADIRNDCK-PORTER__230_12 , ADIRNDCK-CHASLAKE_230_13</b>				FWD (Import)	REV (Export)
Sun 11/16/2025	to	Sun 11/30/2025	MOSES SOUTH	<b>100 MW</b>	
0001		2359	Impacts Total Transfer Capability	3050 MW	
Work scheduled by:			TTC with All Lines In Service	3150 MW	
<b>MASSENA_MARCY__765_MSU1 , ADIRNDCK-PORTER__230_12 , CHASLAKE-PORTER__230_11</b>				FWD (Import)	REV (Export)
Sun 11/16/2025	to	Sun 11/30/2025	SCH - HQ_CEDARS	<b>0 MW</b>	
0001		2359	Impacts Total Transfer Capability	279 MW	
Work scheduled by:			TTC with All Lines In Service	279 MW	
<b>MASSENA_MARCY__765_MSU1 , ADIRNDCK-PORTER__230_12 , CHASLAKE-PORTER__230_11</b>				FWD (Import)	REV (Export)
Sun 11/16/2025	to	Sun 11/30/2025	MOSES SOUTH	<b>100 MW</b>	
0001		2359	Impacts Total Transfer Capability	3050 MW	
Work scheduled by:			TTC with All Lines In Service	3150 MW	
<b>MASSENA_MARCY__765_MSU1 , CHASLAKE-PORTER__230_11</b>				FWD (Import)	REV (Export)
Sun 11/16/2025	to	Sun 11/30/2025	SCH - HQ_CEDARS	<b>90 MW</b>	
0001		2359	Impacts Total Transfer Capability	189 MW	
Work scheduled by:			TTC with All Lines In Service	279 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, September 3, 2025 to Tuesday, March 2, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MASSENA\_MARCY\_\_765\_MSU1 , CHATGUAY-MASSENA\_765\_7040

Sun 11/16/2025 to Sun 11/30/2025  
 0001 2359  
 Work scheduled by:

MOSES SOUTH	FWD (Import)	REV (Export)
	<b>500 MW</b>	
Impacts Total Transfer Capability	2650 MW	
TTC with All Lines In Service	3150 MW	

### MASSENA\_MARCY\_\_765\_MSU1 , MOSES\_\_-ADIRNDCK\_230\_MA1

Sun 11/16/2025 to Sun 11/30/2025  
 0001 2359  
 Work scheduled by:

SCH - HQ_CEDARS	FWD (Import)	REV (Export)
	<b>90 MW</b>	
Impacts Total Transfer Capability	189 MW	
TTC with All Lines In Service	279 MW	

### MASSENA\_MARCY\_\_765\_MSU1 , MOSES\_\_-ADIRNDCK\_230\_MA1 , MOSES\_\_-ADIRNDCK\_230\_MA2

Sun 11/16/2025 to Sun 11/30/2025  
 0001 2359  
 Work scheduled by:

SCH - HQ_CEDARS	FWD (Import)	REV (Export)
	<b>0 MW</b>	
Impacts Total Transfer Capability	279 MW	
TTC with All Lines In Service	279 MW	

### MASSENA\_MARCY\_\_765\_MSU1 , MOSES\_\_-ADIRNDCK\_230\_MA1 , MOSES\_\_-ADIRNDCK\_230\_MA2

Sun 11/16/2025 to Sun 11/30/2025  
 0001 2359  
 Work scheduled by:

MOSES SOUTH	FWD (Import)	REV (Export)
	<b>100 MW</b>	
Impacts Total Transfer Capability	3050 MW	
TTC with All Lines In Service	3150 MW	

### MASSENA\_MARCY\_\_765\_MSU1 , MOSES\_\_-ADIRNDCK\_230\_MA2

Sun 11/16/2025 to Sun 11/30/2025  
 0001 2359  
 Work scheduled by:

SCH - HQ_CEDARS	FWD (Import)	REV (Export)
	<b>90 MW</b>	
Impacts Total Transfer Capability	189 MW	
TTC with All Lines In Service	279 MW	

### MOSES\_\_-ADIRNDCK\_230\_MA1 , MOSES\_\_-MASSENA\_230\_MMS2 , MOSES\_\_-MASSENA\_230\_MMS1

Sun 11/16/2025 to Sun 11/30/2025  
 0001 2359  
 Work scheduled by:

SCH - HQ_CEDARS	FWD (Import)	REV (Export)
	<b>90 MW</b>	
Impacts Total Transfer Capability	189 MW	
TTC with All Lines In Service	279 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, September 3, 2025 to Tuesday, March 2, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MOSES\_\_-ADIRNDCK\_230\_MA2 , MOSES\_\_-MASSENA\_230\_MMS2 , MOSES\_\_-MASSENA\_230\_MMS1

Sun 11/16/2025 to Sun 11/30/2025  
0001 2359  
Work scheduled by:

SCH - HQ_CEDARS	FWD (Import)	REV (Export)
	<b>90 MW</b>	
Impacts Total Transfer Capability	189 MW	
TTC with All Lines In Service	279 MW	

### MOSES\_\_-MASSENA\_230\_MMS2 , MOSES\_\_-MASSENA\_230\_MMS1

Sun 11/16/2025 to Sun 11/30/2025  
0001 2359  
Work scheduled by:

SCH - HQ_CEDARS	FWD (Import)	REV (Export)
	<b>90 MW</b>	
Impacts Total Transfer Capability	189 MW	
TTC with All Lines In Service	279 MW	

### MOSES\_\_-MASSENA\_230\_MMS2 , MOSES\_\_-MASSENA\_230\_MMS1

Sun 11/16/2025 to Sun 11/30/2025  
0001 2359  
Work scheduled by:

SCH - HQ - NY	FWD (Import)	REV (Export)
	<b>850 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	650 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

### BECK\_\_-NIAGARA\_230\_PA27

Thu 11/20/2025 to Thu 11/20/2025  
0800 Continuous 1600  
Work scheduled by: IESO

SCH - OH - NY	FWD (Import)	REV (Export)
	<b>2050 MW</b>	
Impacts Total Transfer Capability	450 MW	
TTC with All Lines In Service	2500 MW	

### MILLWOOD-EASTVIEW\_345\_W82

Wed 12/10/2025 to Fri 12/19/2025  
0001 Continuous 2200  
Work scheduled by: ConEd

UPNY CONED	FWD (Import)	REV (Export)
	<b>7810 MW</b>	
Impacts Total Transfer Capability	240 MW	
TTC with All Lines In Service	8050 MW	

### SPRNBK\_345KV\_RNS4

Wed 12/10/2025 to Wed 12/10/2025  
0001 Continuous 0030  
Work scheduled by: ConEd

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	<b>3200 MW</b>	
Impacts Total Transfer Capability	1400 MW	
TTC with All Lines In Service	4600 MW	



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, September 3, 2025 to Tuesday, March 2, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SPRNBK\_345KV\_RNS4

Fri 12/19/2025 to Fri 12/19/2025  
 2130 Continuous 2200  
 Work scheduled by: ConEd

SPR/DUN-SOUTH  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**3200 MW**  
 1400 MW  
 4600 MW

### MILLWOOD-EASTVIEW\_345\_W99

Mon 12/22/2025 to Mon 12/22/2025  
 0001 Continuous 2200  
 Work scheduled by: ConEd

UPNY CONED  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**7810 MW**  
 240 MW  
 8050 MW

### E13THSTA-FARRAGUT\_345\_46

Wed 01/07/2026 to Fri 01/09/2026  
 0301 Continuous 0300  
 Work scheduled by: ConEd

SPR/DUN-SOUTH  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**3800 MW**  
 800 MW  
 4600 MW

### RAMAPO\_-BUCHAN\_N\_345\_Y94

Sun 01/18/2026 to Sun 01/18/2026  
 0201 Continuous 0230  
 Work scheduled by: ConEd

UPNY CONED  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**7755 MW**  
 295 MW  
 8050 MW

### RAMAPO\_-BUCHAN\_N\_345\_Y94

Mon 01/19/2026 to Mon 01/19/2026  
 0130 Continuous 0159  
 Work scheduled by: ConEd

UPNY CONED  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**7755 MW**  
 295 MW  
 8050 MW

### E13THSTA-FARRAGUT\_345\_46

Sat 01/31/2026 to Thu 02/05/2026  
 0001 Continuous 0300  
 Work scheduled by: ConEd

SPR/DUN-SOUTH  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**3800 MW**  
 800 MW  
 4600 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, September 3, 2025 to Tuesday, March 2, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MARCY\_\_N.SCTLND\_345\_18

Mon 02/09/2026 to Fri 02/13/2026  
 0700 Continuous 1530  
 Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC

Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**2665 MW**  
 1060 MW  
 3725 MW

### NIAGARA\_-DYSINGER\_345\_ND1

Thu 02/12/2026 to Thu 02/12/2026  
 0500 Continuous 1900  
 Work scheduled by: NYPA

DYSINGER EAST

Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**2700 MW**  
 500 MW  
 3200 MW

### RAMAPO\_-BUCHAN\_N\_345\_Y94

Mon 02/16/2026 to Mon 02/16/2026  
 0001 Continuous 0030  
 Work scheduled by: ConEd

UPNY CONED

Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**7755 MW**  
 295 MW  
 8050 MW

### RAMAPO\_-BUCHAN\_N\_345\_Y94

Fri 02/20/2026 to Fri 02/20/2026  
 2130 Continuous 2200  
 Work scheduled by: ConEd

UPNY CONED

Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**7755 MW**  
 295 MW  
 8050 MW

### HOPATCON-RAMAPO\_\_500\_5018

Mon 02/23/2026 to Wed 02/25/2026  
 0001 Continuous 2159  
 Work scheduled by: ConEd

SCH - PJ - NY

Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**1400 MW 1200 MW**  
 1200 MW 1500 MW  
 2600 MW 2700 MW

### HOPATCON-RAMAPO\_\_500\_5018

Mon 02/23/2026 to Wed 02/25/2026  
 0001 Continuous 2159  
 Work scheduled by: ConEd

UPNY CONED

Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**7795 MW**  
 255 MW  
 8050 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, September 3, 2025 to Tuesday, March 2, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### HOPATCON-RAMAPO\_\_500\_5018

Mon 02/23/2026 to Wed 02/25/2026  
0001 Continuous 2159  
Work scheduled by: ConEd

TOTAL EAST	FWD (Import)	REV (Export)
	<b>6800 MW</b>	
Impacts Total Transfer Capability	750 MW	
TTC with All Lines In Service	7550 MW	

### RAMAPO\_\_345\_345\_PAR3500

Mon 02/23/2026 to Wed 02/25/2026  
0001 Continuous 2159  
Work scheduled by: ConEd

SCH - PJ - NY	FWD (Import)	REV (Export)
	<b>2550 MW</b>	<b>1250 MW</b>
Impacts Total Transfer Capability	50 MW	1450 MW
TTC with All Lines In Service	2600 MW	2700 MW

### RAMAPO\_\_345\_345\_PAR4500

Mon 02/23/2026 to Wed 02/25/2026  
0001 Continuous 2159  
Work scheduled by: ConEd

SCH - PJ - NY	FWD (Import)	REV (Export)
	<b>2550 MW</b>	<b>1250 MW</b>
Impacts Total Transfer Capability	50 MW	1450 MW
TTC with All Lines In Service	2600 MW	2700 MW

### RAMAPO\_\_500\_345\_BK 1500

Mon 02/23/2026 to Wed 02/25/2026  
0001 Continuous 2159  
Work scheduled by: ConEd

SCH - PJ - NY	FWD (Import)	REV (Export)
	<b>1400 MW</b>	<b>1200 MW</b>
Impacts Total Transfer Capability	1200 MW	1500 MW
TTC with All Lines In Service	2600 MW	2700 MW

### RAMAPO\_\_500\_345\_BK 1500

Mon 02/23/2026 to Wed 02/25/2026  
0001 Continuous 2159  
Work scheduled by: ConEd

UPNY CONED	FWD (Import)	REV (Export)
	<b>7795 MW</b>	
Impacts Total Transfer Capability	255 MW	
TTC with All Lines In Service	8050 MW	

### DUNWODIE\_345KV\_7

Sun 03/01/2026 to Sun 03/01/2026  
0001 Continuous 0030  
Work scheduled by: ConEd

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, September 3, 2025 to Tuesday, March 2, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### DUNWODIE\_345KV\_8

Sun 03/01/2026 to Sun 03/01/2026  
 0001 Continuous 0030  
 Work scheduled by: ConEd

SPR/DUN-SOUTH  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>3800 MW</b>	
800 MW	
4600 MW	

### DUNWODIE-MOTTHAVN\_345\_72

Sun 03/01/2026 to Mon 04/13/2026  
 0001 Continuous 0259  
 Work scheduled by: ConEd

SPR/DUN-SOUTH  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>3800 MW</b>	
800 MW	
4600 MW	

### DYSINGER-STA\_255\_345\_DH2

Mon 03/02/2026 to Sun 03/15/2026  
 0500 Continuous 1900  
 Work scheduled by: NYPA

EXTENDED by NYPA 06/17/2025 15:09

DYSINGER EAST  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>2850 MW</b>	
350 MW	
3200 MW	

### DYSINGER-STA\_255\_345\_DH1

Mon 03/16/2026 to Tue 04/07/2026  
 0500 Continuous 2100  
 Work scheduled by: NYPA

DYSINGER EAST  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>2850 MW</b>	
350 MW	
3200 MW	

### BECK\_\_-NIAGARA\_345\_PA302

Mon 03/16/2026 to Fri 03/20/2026  
 0630 Continuous 1600  
 Work scheduled by: IESO

SCH - OH - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>1150 MW</b>	<b>1000 MW</b>
1350 MW	850 MW
2500 MW	1850 MW

### DYSINGER-STA\_255\_345\_DH2

Wed 04/08/2026 to Mon 04/20/2026  
 0500 Continuous 2100  
 Work scheduled by: NYPA

DYSINGER EAST  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>2850 MW</b>	
350 MW	
3200 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, September 3, 2025 to Tuesday, March 2, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### DUNWODIE\_345KV\_7

Mon 04/13/2026 to Mon 04/13/2026  
0230 Continuous 0259  
Work scheduled by: ConEd

SPR/DUN-SOUTH FWD (Import) REV (Export)  
Impacts Total Transfer Capability **3800 MW**  
TTC with All Lines In Service 800 MW  
4600 MW

### DUNWODIE\_345KV\_8

Mon 04/13/2026 to Mon 04/13/2026  
0230 Continuous 0259  
Work scheduled by: ConEd

SPR/DUN-SOUTH FWD (Import) REV (Export)  
Impacts Total Transfer Capability **3800 MW**  
TTC with All Lines In Service 800 MW  
4600 MW

### ROSETON\_EFISHKIL\_345\_RFK305

Mon 04/13/2026 to Fri 04/24/2026  
0700 Continuous 1530  
Work scheduled by: NYPA

UPNY CONED FWD (Import) REV (Export)  
Impacts Total Transfer Capability **7215 MW**  
TTC with All Lines In Service 835 MW  
8050 MW

### DYSINGER-STA\_255\_345\_DH1

Tue 04/21/2026 to Fri 05/01/2026  
0500 Continuous 2100  
Work scheduled by: NYPA

DYSINGER EAST FWD (Import) REV (Export)  
Impacts Total Transfer Capability **2850 MW**  
TTC with All Lines In Service 350 MW  
3200 MW

### BECK\_\_-NIAGARA\_345\_PA301

Mon 04/27/2026 to Fri 05/01/2026  
0630 Continuous 1600  
Work scheduled by: IESO

SCH - OH - NY FWD (Import) REV (Export)  
Impacts Total Transfer Capability **1150 MW** **1000 MW**  
TTC with All Lines In Service 1350 MW 850 MW  
2500 MW 1850 MW

### GOETHALS\_345KV\_5

Fri 05/01/2026 to Thu 05/07/2026  
0001 Continuous 0300  
Work scheduled by: ConEd

UPDATED by ConEd 03/04/2025 07:30

STATEN ISLAND FWD (Import) REV (Export)  
Impacts Total Transfer Capability  
TTC with All Lines In Service

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, September 3, 2025 to Tuesday, March 2, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### DYSINGER-STA\_255\_345\_DH2

Sat 05/02/2026 to Mon 05/11/2026  
 0500 Continuous 2100  
 Work scheduled by: NYPA

DYSINGER EAST  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>2850 MW</b>	
350 MW	
3200 MW	

### INGHAM\_C\_115\_115\_PAR 2

Mon 05/04/2026 to Fri 05/22/2026  
 0600 Continuous 1600  
 Work scheduled by: NGrid

CENTRAL EAST - VC  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>3605 MW</b>	
120 MW	
3725 MW	

### MARCY\_-FRASANNX\_345\_UCC2-41

Wed 05/06/2026 to Fri 05/22/2026  
 0700 Continuous 1530  
 Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>3225 MW</b>	
500 MW	
3725 MW	

### NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE

Mon 05/11/2026 to Fri 05/15/2026  
 0600 Continuous 1600  
 Work scheduled by: LI

SCH - PJM\_NEPTUNE  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>0 MW</b>	
660 MW	
660 MW	

### NEWBRDGE\_345\_138\_BK\_1

Mon 05/11/2026 to Fri 05/15/2026  
 0600 Continuous 1600  
 Work scheduled by: LI

SCH - PJM\_NEPTUNE  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>375 MW</b>	
285 MW	
660 MW	

### NEWBRDGE\_345\_138\_BK\_2

Mon 05/11/2026 to Fri 05/15/2026  
 0600 Continuous 1600  
 Work scheduled by: LI

SCH - PJM\_NEPTUNE  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>375 MW</b>	
285 MW	
660 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, September 3, 2025 to Tuesday, March 2, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### NEWBRDGE-DUFFYAVE\_345\_501

Mon 05/11/2026 to Fri 05/15/2026  
0600 Continuous 1600  
Work scheduled by: LI

SCH - PJM\_NEPTUNE  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**0 MW**  
660 MW  
660 MW

### BECK\_\_-PACKARD\_230\_BP76

Mon 05/11/2026 to Fri 05/15/2026  
0630 Continuous 1600  
Work scheduled by: IESO

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1600 MW** **1050 MW**  
400 MW 550 MW  
2000 MW 1600 MW

### DYSINGER-STA\_255\_345\_DH1

Tue 05/12/2026 to Mon 05/25/2026  
0500 Continuous 2100  
Work scheduled by: NYPA

DYSINGER EAST  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**2850 MW**  
350 MW  
3200 MW

### W49TH\_ST\_345KV\_5

Fri 05/15/2026 to Fri 05/15/2026  
0001 Continuous 0030  
Work scheduled by: ConEd

SCH - PJM\_HTP  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**460 MW**  
200 MW  
660 MW

### W49TH\_ST\_345KV\_7

Fri 05/15/2026 to Fri 05/15/2026  
0001 Continuous 0030  
Work scheduled by: ConEd

SCH - PJM\_HTP  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**460 MW**  
200 MW  
660 MW

### W49TH\_ST\_345KV\_5

Fri 05/15/2026 to Fri 05/15/2026  
1430 Continuous 1500  
Work scheduled by: ConEd

SCH - PJM\_HTP  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**460 MW**  
200 MW  
660 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, September 3, 2025 to Tuesday, March 2, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### W49TH\_ST\_345KV\_7

Fri 05/15/2026 to Fri 05/15/2026  
1430 Continuous 1500  
Work scheduled by: ConEd

SCH - PJM\_HTP  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**460 MW**  
200 MW  
660 MW

### MILLWOOD-EASTVIEW\_345\_W99

Sat 05/16/2026 to Mon 05/18/2026  
0001 Continuous 0259  
Work scheduled by: ConEd

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**7810 MW**  
240 MW  
8050 MW

### SPRNBK\_345KV\_RNS5

Sat 05/16/2026 to Mon 05/18/2026  
0001 Continuous 0259  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3200 MW**  
1400 MW  
4600 MW

### W49TH\_ST\_345KV\_5

Sat 05/16/2026 to Sat 05/16/2026  
0001 Continuous 0030  
Work scheduled by: ConEd

SCH - PJM\_HTP  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**460 MW**  
200 MW  
660 MW

### W49TH\_ST\_345KV\_7

Sat 05/16/2026 to Sat 05/16/2026  
0001 Continuous 0030  
Work scheduled by: ConEd

SCH - PJM\_HTP  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**460 MW**  
200 MW  
660 MW

### W49TH\_ST\_345KV\_5

Mon 05/18/2026 to Mon 05/18/2026  
0030 Continuous 0100  
Work scheduled by: ConEd

SCH - PJM\_HTP  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**460 MW**  
200 MW  
660 MW



# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, September 3, 2025 to Tuesday, March 2, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### W49TH\_ST\_345KV\_7

Mon 05/18/2026 to Mon 05/18/2026  
 0030 Continuous 0100  
 Work scheduled by: ConEd

SCH - PJM\_HTP

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**460 MW**

200 MW

660 MW

### NIAGARA\_345\_230\_AT4

Tue 05/26/2026 to Sat 05/30/2026  
 0500 Continuous 1900  
 Work scheduled by: NYPA

SCH - OH - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**1900 MW**

**1200 MW**

100 MW

400 MW

2000 MW

1600 MW

### MARCY\_345KV\_CSC

Mon 06/01/2026 to Sun 06/14/2026  
 0700 Continuous 1530  
 Work scheduled by: NYPA

CENTRAL EAST - VC

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**3650 MW**

75 MW

3725 MW

### SAND\_BAR-PLATSBRG\_115\_PV20

Mon 06/22/2026 to Fri 06/26/2026  
 0900 Continuous 1630  
 Work scheduled by: NYPA

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

### SAND\_BAR-PLATSBRG\_115\_PV20

Mon 06/22/2026 to Fri 06/26/2026  
 0900 Continuous 1630  
 Work scheduled by: NYPA

CENTRAL EAST - VC

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

**3625 MW**

100 MW

3725 MW

### SAND\_BAR-PLATSBRG\_115\_PV20

Mon 07/06/2026 to Fri 07/10/2026  
 0900 Continuous 1630  
 Work scheduled by: NYPA

SCH - NE - NY

Impacts Total Transfer Capability

TTC with All Lines In Service

FWD (Import) REV (Export)

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, September 3, 2025 to Tuesday, March 2, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SAND\_BAR-PLATSBRG\_115\_PV20

Mon 07/06/2026 to Fri 07/10/2026  
0900 Continuous 1630  
Work scheduled by: NYPA

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3625 MW**  
100 MW  
3725 MW

### MARCY\_\_765\_345\_AT1

Wed 09/09/2026 to Thu 09/10/2026  
0700 Continuous 1530  
Work scheduled by: NYPA

ARR: 19

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1750 MW**  
1400 MW  
3150 MW

### MARCY\_\_765\_345\_AT2

Fri 09/11/2026 to Sat 09/12/2026  
0700 Continuous 1530  
Work scheduled by: NYPA

ARR: 19

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**1700 MW**  
1450 MW  
3150 MW

### STLAWRNC-MOSES\_\_230\_L33P

Mon 09/14/2026 to Fri 09/18/2026  
0600 Continuous 1630  
Work scheduled by: NYPA

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

### MOTHAVN-RAINEY\_\_345\_Q12

Tue 09/15/2026 to Sun 10/25/2026  
0201 Continuous 0400  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3800 MW**  
800 MW  
4600 MW

### MARCY\_\_FRASANNX\_345\_UCC2-41

Tue 09/15/2026 to Tue 09/29/2026  
0700 Continuous 1530  
Work scheduled by: NYPA

ARR: 19

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)  
**3225 MW**  
500 MW  
3725 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, September 3, 2025 to Tuesday, March 2, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### PANNELL\_-CLAY\_\_\_345\_1

Mon 09/28/2026 to Fri 10/02/2026  
 0700 Continuous 1530  
 Work scheduled by: NYPA

WEST CENTRAL	FWD (Import)	REV (Export)
	<b>1300 MW</b>	
Impacts Total Transfer Capability	950 MW	
TTC with All Lines In Service	2250 MW	

### PANNELL\_-CLAY\_\_\_345\_2

Mon 10/05/2026 to Fri 10/09/2026  
 0700 Continuous 1530  
 Work scheduled by: NYPA

WEST CENTRAL	FWD (Import)	REV (Export)
	<b>1300 MW</b>	
Impacts Total Transfer Capability	950 MW	
TTC with All Lines In Service	2250 MW	

### NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE

Mon 10/12/2026 to Thu 10/15/2026  
 0600 Continuous 1600  
 Work scheduled by: LI

SCH - PJM_NEPTUNE	FWD (Import)	REV (Export)
	<b>0 MW</b>	
Impacts Total Transfer Capability	660 MW	
TTC with All Lines In Service	660 MW	

### NEWBRDGE\_345\_138\_BK\_1

Mon 10/12/2026 to Thu 10/15/2026  
 0600 Continuous 1600  
 Work scheduled by: LI

SCH - PJM_NEPTUNE	FWD (Import)	REV (Export)
	<b>375 MW</b>	
Impacts Total Transfer Capability	285 MW	
TTC with All Lines In Service	660 MW	

### NEWBRDGE\_345\_138\_BK\_2

Mon 10/12/2026 to Thu 10/15/2026  
 0600 Continuous 1600  
 Work scheduled by: LI

SCH - PJM_NEPTUNE	FWD (Import)	REV (Export)
	<b>375 MW</b>	
Impacts Total Transfer Capability	285 MW	
TTC with All Lines In Service	660 MW	

### NEWBRDGE-DUFFYAVE\_345\_501

Mon 10/12/2026 to Thu 10/15/2026  
 0600 Continuous 1600  
 Work scheduled by: LI

SCH - PJM_NEPTUNE	FWD (Import)	REV (Export)
	<b>0 MW</b>	
Impacts Total Transfer Capability	660 MW	
TTC with All Lines In Service	660 MW	

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, September 3, 2025 to Tuesday, March 2, 2027

CENTRAL EAST 7550 MW  
CENTRAL EAST - VC 3725 MW  
TOTAL EAST 7550 MW  
UPNY CONED 8050 MW  
SPR/DUN-SOUTH 4600 MW  
DYSINGER EAST 3200 MW  
MOSES SOUTH 3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### MASSENA\_MARCY\_\_765\_MSU1

Wed 10/14/2026 to Wed 10/28/2026  
0001 Continuous 2359  
Work scheduled by: NYPA

SCH - HQ\_CEDARS  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 90 MW  
REV (Export) 180 MW  
270 MW

### MASSENA\_MARCY\_\_765\_MSU1

Wed 10/14/2026 to Wed 10/28/2026  
0001 Continuous 2359  
Work scheduled by: NYPA

SCH - HQ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 475 MW  
REV (Export) 1000 MW  
1025 MW  
0 MW  
1500 MW  
1000 MW

### MASSENA\_MARCY\_\_765\_MSU1

Wed 10/14/2026 to Wed 10/28/2026  
0001 Continuous 2359  
Work scheduled by: NYPA

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 500 MW  
REV (Export) 2650 MW  
3150 MW

### MASSENA\_MARCY\_\_765\_MSU1

Wed 10/14/2026 to Wed 10/28/2026  
0001 Continuous 2359  
Work scheduled by: NYPA

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 2595 MW  
REV (Export) 1130 MW  
3725 MW

### STLAWRNC-MOSES\_\_230\_L34P

Mon 11/16/2026 to Fri 11/20/2026  
0600 Continuous 1630  
Work scheduled by: NYPA

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import)  
REV (Export)

### EDIC\_\_FRASER\_\_345\_EF24-40

Mon 11/30/2026 to Sun 12/06/2026  
0700 Continuous 1530  
Work scheduled by: NYPA

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service  
FWD (Import) 3225 MW  
REV (Export) 500 MW  
3725 MW

# NYISO TRANSFER LIMITATIONS

## Seasonal Limits

Wednesday, September 3, 2025 to Tuesday, March 2, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8050 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3150 MW

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

### SPRNBK\_345KV\_RS4 , SPRNBK\_345KV\_RS3

Mon 02/08/2027 to Tue 02/09/2027  
 0001 0200  
 Work scheduled by:

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

### SPRNBK\_345KV\_RNS5

Tue 02/09/2027 to Fri 02/19/2027  
 0201 Continuous 0200  
 Work scheduled by: ConEd

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	<b>3200 MW</b>	
Impacts Total Transfer Capability	1400 MW	
TTC with All Lines In Service	4600 MW	

### SPRNBK\_-W49TH\_ST\_345\_M51

Tue 02/09/2027 to Fri 02/19/2027  
 0201 Continuous 0200  
 Work scheduled by: ConEd

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	<b>3200 MW</b>	
Impacts Total Transfer Capability	1400 MW	
TTC with All Lines In Service	4600 MW	

### BUCHAN\_S-MILLWOOD\_345\_W97

Mon 03/01/2027 to Wed 03/03/2027  
 0001 Continuous 0200  
 Work scheduled by: ConEd

UPNY CONED	FWD (Import)	REV (Export)
	<b>8015 MW</b>	
Impacts Total Transfer Capability	35 MW	
TTC with All Lines In Service	8050 MW	