NYISO Operator Initiated Commitment

Insert Time	Event Start Time	Event End Time	PTID	Resource Name	Requestor	Commitment Type	Load Zone of Resource	Commitment Reason	ARR	UOL/ USL(MWh)/ POI INJ (MW)	MW Committed/ LSL(MWh)/POI WDL (MW)
22-Oct-2026 05:01:36	23-Oct-2026 00:00:00	23-Oct-2026 23:59:59	23545	BARRETT___1	TO	DARU	LONGIL	Voltage Support	28	145	40
22-Oct-2026 05:01:36	23-Oct-2026 09:00:00	23-Oct-2026 09:59:59	323624	CAITHNESS_CC_1	TO	DARU	LONGIL	Voltage Support	-	337.5	244.4
22-Oct-2026 05:01:36	23-Oct-2026 23:00:00	23-Oct-2026 23:59:59	323624	CAITHNESS_CC_1	TO	DARU	LONGIL	Voltage Support	-	342.4	248.3
22-Oct-2026 05:01:36	23-Oct-2026 22:00:00	23-Oct-2026 22:59:59	323624	CAITHNESS_CC_1	TO	DARU	LONGIL	Voltage Support	-	342.3	248.2
22-Oct-2026 05:01:36	23-Oct-2026 00:00:00	23-Oct-2026 23:59:59	23650	NORTHPORT___4	TO	DARU	LONGIL	Voltage Support	28	363	100
22-Oct-2026 05:01:36	23-Oct-2026 00:00:00	23-Oct-2026 00:59:59	323624	CAITHNESS_CC_1	TO	DARU	LONGIL	Voltage Support	-	333.6	241.5
22-Oct-2026 05:01:36	23-Oct-2026 01:00:00	23-Oct-2026 01:59:59	323624	CAITHNESS_CC_1	TO	DARU	LONGIL	Voltage Support	-	335.4	242.7
22-Oct-2026 05:01:36	23-Oct-2026 02:00:00	23-Oct-2026 02:59:59	323624	CAITHNESS_CC_1	TO	DARU	LONGIL	Voltage Support	-	336.4	243.5
22-Oct-2026 05:01:36	23-Oct-2026 03:00:00	23-Oct-2026 03:59:59	323624	CAITHNESS_CC_1	TO	DARU	LONGIL	Voltage Support	-	337.4	244.3
22-Oct-2026 05:01:36	23-Oct-2026 04:00:00	23-Oct-2026 04:59:59	323624	CAITHNESS_CC_1	TO	DARU	LONGIL	Voltage Support	-	338.3	245
22-Oct-2026 05:01:36	23-Oct-2026 05:00:00	23-Oct-2026 05:59:59	323624	CAITHNESS_CC_1	TO	DARU	LONGIL	Voltage Support	-	339.3	245.7
22-Oct-2026 05:01:36	23-Oct-2026 06:00:00	23-Oct-2026 06:59:59	323624	CAITHNESS_CC_1	TO	DARU	LONGIL	Voltage Support	-	339.5	245.9
22-Oct-2026 05:01:36	23-Oct-2026 07:00:00	23-Oct-2026 07:59:59	323624	CAITHNESS_CC_1	TO	DARU	LONGIL	Voltage Support	-	340.5	246.7
22-Oct-2026 05:01:36	23-Oct-2026 08:00:00	23-Oct-2026 08:59:59	323624	CAITHNESS_CC_1	TO	DARU	LONGIL	Voltage Support	-	339.3	245.8
22-Oct-2026 05:01:36	23-Oct-2026 10:00:00	23-Oct-2026 10:59:59	323624	CAITHNESS_CC_1	TO	DARU	LONGIL	Voltage Support	-	336.8	244
22-Oct-2026 05:01:36	23-Oct-2026 11:00:00	23-Oct-2026 11:59:59	323624	CAITHNESS_CC_1	TO	DARU	LONGIL	Voltage Support	-	336.1	243.5
22-Oct-2026 05:01:36	23-Oct-2026 12:00:00	23-Oct-2026 12:59:59	323624	CAITHNESS_CC_1	TO	DARU	LONGIL	Voltage Support	-	334.4	242.3
22-Oct-2026 05:01:36	23-Oct-2026 13:00:00	23-Oct-2026 14:59:59	323624	CAITHNESS_CC_1	TO	DARU	LONGIL	Voltage Support	-	332.7	241.2
22-Oct-2026 05:01:36	23-Oct-2026 15:00:00	23-Oct-2026 15:59:59	323624	CAITHNESS_CC_1	TO	DARU	LONGIL	Voltage Support	-	332	240.7
22-Oct-2026 05:01:36	23-Oct-2026 16:00:00	23-Oct-2026 16:59:59	323624	CAITHNESS_CC_1	TO	DARU	LONGIL	Voltage Support	-	332.1	240.8
22-Oct-2026 05:01:36	23-Oct-2026 17:00:00	23-Oct-2026 17:59:59	323624	CAITHNESS_CC_1	TO	DARU	LONGIL	Voltage Support	-	333	241.4
22-Oct-2026 05:01:36	23-Oct-2026 18:00:00	23-Oct-2026 18:59:59	323624	CAITHNESS_CC_1	TO	DARU	LONGIL	Voltage Support	-	335.8	243.3
22-Oct-2026 05:01:36	23-Oct-2026 19:00:00	23-Oct-2026 19:59:59	323624	CAITHNESS_CC_1	TO	DARU	LONGIL	Voltage Support	-	339.1	245.6
22-Oct-2026 05:01:36	23-Oct-2026 20:00:00	23-Oct-2026 20:59:59	323624	CAITHNESS_CC_1	TO	DARU	LONGIL	Voltage Support	-	340.7	246.9
22-Oct-2026 05:01:36	23-Oct-2026 21:00:00	23-Oct-2026 21:59:59	323624	CAITHNESS_CC_1	TO	DARU	LONGIL	Voltage Support	-	341.4	247.5
22-Oct-2026 10:41:38	24-Oct-2026 00:00:00	27-Oct-2026 23:00:00	23545	BARRETT___1	TO	Received Advisory DARU	LONGIL	Voltage Support	28	0	0
22-Oct-2026 10:42:52	24-Oct-2026 00:00:00	27-Oct-2026 23:00:00	323624	CAITHNESS_CC_1	TO	Received Advisory DARU	LONGIL	Voltage Support	-	0	0
22-Oct-2026 10:43:14	24-Oct-2026 00:00:00	27-Oct-2026 23:00:00	23650	NORTHPORT___4	TO	Received Advisory DARU	LONGIL	Voltage Support	28	0	0