

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Tuesday, June 23, 2026 to Wednesday, December 22, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

<b>SPRNBRK_345KV_R5S3_BYPASS , DUNWODIE_345KV_10_BYPASS ,                  DUNWODIE_345KV_9_BYPASS , SPRNBRK_345KV_R4S3_BYPASS</b>				FWD (Import)	REV (Export)
Sun 02/01/2015	to	Fri 02/01/2030			
0000		0000	SPR/DUN-SOUTH	<b>4350 MW</b>	
Work scheduled by:				Impacts Total Transfer Capability	250 MW
				TTC with All Lines In Service	4600 MW
<b>SPRNBRK_345KV_R5S3_BYPASS , DUNWODIE_345KV_10_BYPASS ,                  DUNWODIE_345KV_9_BYPASS , SPRNBRK_345KV_R4S3_BYPASS</b>				FWD (Import)	REV (Export)
Sun 02/01/2015	to	Fri 02/01/2030			
0000		0000	UPNY CONED	<b>7505 MW</b>	
Work scheduled by:				Impacts Total Transfer Capability	705 MW
				TTC with All Lines In Service	8210 MW
<b>HUDSONP_-FARRAGUT_345_B3402</b>				FWD (Import)	REV (Export)
Mon 01/15/2018	to	Sat 08/01/2026			
0001	Continuous	2359	<u>EXT FORCED by ConEd 03/11/2024 11:26</u>	SCH - PJ - NY	
Work scheduled by: ConEd				Impacts Total Transfer Capability	
				TTC with All Lines In Service	
<b>MARION_-FARRAGUT_345_C3403</b>				FWD (Import)	REV (Export)
Mon 01/15/2018	to	Sat 08/01/2026			
0001	Continuous	2359	<u>EXT FORCED by ConEd 03/11/2024 11:26</u>	SCH - PJ - NY	
Work scheduled by: ConEd				Impacts Total Transfer Capability	
				TTC with All Lines In Service	
<b>MARION_-FARRAGUT_345_C3403 , HUDSONP_-FARRAGUT_345_B3402</b>				FWD (Import)	REV (Export)
Mon 01/15/2018	to	Sat 08/01/2026			
0001		2359	SCH - PJ - NY	<b>1950 MW</b>	<b>1050 MW</b>
Work scheduled by:				Impacts Total Transfer Capability	150 MW
				TTC with All Lines In Service	2100 MW
					1200 MW
<b>DYSINGER-GRAHAM_345_DG1</b>				FWD (Import)	REV (Export)
Tue 02/10/2026	to	Wed 09/30/2026			
1122	Continuous	2100	<u>FORCED by NYISO 03/21/2026 14:33</u>	DYSINGER EAST	
Work scheduled by: NYISO				Impacts Total Transfer Capability	
				TTC with All Lines In Service	

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Tuesday, June 23, 2026 to Wednesday, December 22, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**GRAHAM\_-STA\_255\_345\_GH1-43**

Tue 02/10/2026 to Wed 09/30/2026  
1122 Continuous 2100  
Work scheduled by: NYISO

FORCED by NYISO 03/21/2026 14:33

DYSINGER EAST  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**OSWEGO\_COMPLEX\_AVR\_O/S**

Sat 04/04/2026 to Sun 09/13/2026  
0800 Continuous 0000  
Work scheduled by: NGrid

FORCED by NGrid 01/27/2025 10:33

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**3640 MW**  
85 MW  
3725 MW

**SCH-NYISO-HQ\_CEDARS\_LIMIT\_0**

Fri 04/17/2026 to Wed 07/01/2026  
1900 Continuous 2359  
Work scheduled by: HQ

EXT FORCED by HQ, 04/22/2026 14:24

SCH - HQ\_CEDARS  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**0 MW**  
100 MW  
100 MW

**SCH-HQ\_CEDARS-NYISO\_LIMIT\_220**

Tue 04/21/2026 to Wed 07/01/2026  
1900 Continuous 2359  
Work scheduled by: HQ

EXT FORCED by HQ, 04/22/2026 14:24

SCH - HQ\_CEDARS  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**220 MW**  
50 MW  
270 MW

**SPRBRK\_345KV\_RNS5**

Fri 05/01/2026 to Sun 06/28/2026  
0554 Continuous 2359  
Work scheduled by: ConEd

EXT FORCED by ConEd 05/03/2026 11:29

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**3200 MW**  
1400 MW  
4600 MW

**SPRBRK\_-W49TH\_ST\_345\_M51**

Fri 05/01/2026 to Sun 06/28/2026  
0554 Continuous 2359  
Work scheduled by: ConEd

EXT FORCED by ConEd 05/03/2026 11:29

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**3200 MW**  
1400 MW  
4600 MW

# NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, June 23, 2026 to Wednesday, December 22, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**LEEDS\_\_HURLYAVE\_345\_301**

Mon 06/15/2026 to Fri 07/03/2026  
 0800 Continuous 1600  
 Work scheduled by: CHGE

EXT FORCED by CHGE 06/01/2026 09:42

UPNY CONED  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**8120 MW**  
 90 MW  
 8210 MW

**SCH-HQ\_CEDARS-NYISO\_LIMIT\_180**

Mon 06/22/2026 to Fri 06/26/2026  
 0400 Continuous 1800  
 Work scheduled by: HQ

SCH - HQ\_CEDARS  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**180 MW**  
 90 MW  
 270 MW

**SAND\_BAR-PLATSBRG\_115\_PV20**

Mon 06/22/2026 to Fri 06/26/2026  
 0900 Continuous 1630  
 Work scheduled by: NYPA

SCH - NE - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**3625 MW**  
 100 MW  
 3725 MW

**SAND\_BAR-PLATSBRG\_115\_PV20**

Mon 06/22/2026 to Fri 06/26/2026  
 0900 Continuous 1630  
 Work scheduled by: NYPA

CENTRAL EAST - VC  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**8045 MW**  
 165 MW  
 8210 MW

**KNICRBKR-PLSNTVLY\_345\_Y57**

Mon 06/22/2026 to Tue 06/23/2026  
 1237 Continuous 2300  
 Work scheduled by: NGrid

FORCED by NGrid 06/23/2026 09:08

UPNY CONED  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**3650 MW**  
 75 MW  
 3725 MW

**MARCY\_\_345KV\_CSC**

Mon 06/22/2026 to Wed 06/24/2026  
 1237 Continuous 2359  
 Work scheduled by: NYPA

EXT FORCED by NYPA 06/23/2026 15:49

CENTRAL EAST - VC  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**3650 MW**  
 75 MW  
 3725 MW

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Tuesday, June 23, 2026 to Wednesday, December 22, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**CHAT\_DC\_GC2**

Tue 06/23/2026 to Tue 06/23/2026  
0600 Continuous 2000  
Work scheduled by: HQ

SCH - HQ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)    REV (Export)  
**500 MW**  
500 MW  
1000 MW

**GOETHALS\_345KV\_5**

Wed 06/24/2026 to Wed 06/24/2026  
0001 Continuous 0030  
Work scheduled by: ConEd

UPDATED by ConEd 06/03/2026 10:21

STATEN ISLAND  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)    REV (Export)  
**500 MW**  
500 MW  
1000 MW

**FROST\_BR-LONG\_MTN\_345\_352**

Wed 06/24/2026 to Wed 06/24/2026  
0730 Continuous 0759  
Work scheduled by: ISONE

FORCED by ISONE 06/23/2026 14:37

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)    REV (Export)  
**1350 MW**  
50 MW  
1400 MW

**SCH-NE-NYISO\_LIMIT\_1000**

Wed 06/24/2026 to Wed 06/24/2026  
0730 Continuous 0759  
Work scheduled by: ISONE

FORCED by ISONE 06/23/2026 14:37

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)    REV (Export)  
**1200 MW**  
200 MW  
1400 MW

**FROST\_BR-LONG\_MTN\_345\_352**

Wed 06/24/2026 to Wed 06/24/2026  
1500 Continuous 1530  
Work scheduled by: ISONE

FORCED by ISONE 06/23/2026 14:37

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)    REV (Export)  
**1350 MW**  
50 MW  
1400 MW

**SCH-NE-NYISO\_LIMIT\_1000**

Wed 06/24/2026 to Wed 06/24/2026  
1500 Continuous 1530  
Work scheduled by: ISONE

FORCED by ISONE 06/23/2026 14:37

SCH - NE - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)    REV (Export)  
**1200 MW**  
200 MW  
1400 MW

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Tuesday, June 23, 2026 to Wednesday, December 22, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**GOETHALS\_345KV\_5**

Tue 06/30/2026 to Tue 06/30/2026  
 0230 Continuous 0300  
 Work scheduled by: ConEd

UPDATED by ConEd 06/03/2026 10:21

STATEN ISLAND  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)    REV (Export)

**SCH-NYISO-HQ\_LIMIT\_700**

Sun 07/05/2026 to Thu 07/09/2026  
 0500 Continuous 1800  
 Work scheduled by: HQ

SCH - HQ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)    REV (Export)

**700 MW**  
 300 MW  
 1000 MW

**NIAGARA\_-ROBNSNRD\_230\_64**

Mon 07/06/2026 to Wed 07/08/2026  
 0700 Continuous 1500  
 Work scheduled by: NYSEG

UPDATED by NYSEG 06/22/2026 14:22

SCH - OH - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)    REV (Export)

**1500 MW**  
 100 MW  
 1600 MW

**SAND\_BAR-PLATSBRG\_115\_PV20**

Mon 07/06/2026 to Fri 07/10/2026  
 0900 Continuous 1630  
 Work scheduled by: NYPA

SCH - NE - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)    REV (Export)

**SAND\_BAR-PLATSBRG\_115\_PV20**

Mon 07/06/2026 to Fri 07/10/2026  
 0900 Continuous 1630  
 Work scheduled by: NYPA

CENTRAL EAST - VC  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)    REV (Export)

**3625 MW**  
 100 MW  
 3725 MW

**CHAT\_DC\_GC1**

Sun 07/12/2026 to Thu 07/16/2026  
 0100 Continuous 2359  
 Work scheduled by: HQ

SCH - HQ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)    REV (Export)

**500 MW**  
 500 MW  
 1000 MW

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Tuesday, June 23, 2026 to Wednesday, December 22, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**CHAT\_DC\_GC2**

Sun 07/12/2026 to Thu 07/16/2026  
 0100 Continuous 2359  
 Work scheduled by: HQ

SCH - HQ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)	REV (Export)
	<b>500 MW</b>
	500 MW
	1000 MW

**CHAT\_DC\_GC2 , CHAT\_DC\_GC1**

Sun 07/12/2026 to Thu 07/16/2026  
 0100 2359  
 Work scheduled by:

SCH - HQ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>1370 MW</b>	<b>0 MW</b>
130 MW	1000 MW
1500 MW	1000 MW

**SCH-HQ-NYISO\_LIMIT\_900**

Sun 07/12/2026 to Thu 07/16/2026  
 0100 Continuous 2359  
 Work scheduled by: HQ

SCH - HQ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>900 MW</b>	
600 MW	
1500 MW	

**FIVEMILE-LIMELAKE\_345\_49**

Mon 07/13/2026 to Sun 08/16/2026  
 0600 Continuous 1700  
 Work scheduled by: NGrid

SCH - PJ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>1950 MW</b>	<b>1050 MW</b>
150 MW	150 MW
2100 MW	1200 MW

**LIMELAKE-ESTOLERD\_345\_29**

Mon 07/13/2026 to Sun 08/16/2026  
 0600 Continuous 1700  
 Work scheduled by: NGrid

SCH - PJ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>1950 MW</b>	<b>1050 MW</b>
150 MW	150 MW
2100 MW	1200 MW

**SAND\_BAR-PLATSBRG\_115\_PV20**

Tue 07/21/2026 to Tue 07/21/2026  
 1200 Continuous 1600  
 Work scheduled by: ISONE

SCH - NE - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import)	REV (Export)
--------------	--------------

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Tuesday, June 23, 2026 to Wednesday, December 22, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**SAND\_BAR-PLATSBRG\_115\_PV20**

Tue 07/21/2026 to Tue 07/21/2026  
 1200 Continuous 1600  
 Work scheduled by: ISONE

CENTRAL EAST - VC **3625 MW**  
 Impacts Total Transfer Capability 100 MW  
 TTC with All Lines In Service 3725 MW

FWD (Import) REV (Export)

**SAND\_BAR-PLATSBRG\_115\_PV20**

Wed 07/22/2026 to Fri 07/24/2026  
 0700 Continuous 1500  
 Work scheduled by: ISONE

SCH - NE - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**SAND\_BAR-PLATSBRG\_115\_PV20**

Wed 07/22/2026 to Fri 07/24/2026  
 0700 Continuous 1500  
 Work scheduled by: ISONE

CENTRAL EAST - VC **3625 MW**  
 Impacts Total Transfer Capability 100 MW  
 TTC with All Lines In Service 3725 MW

FWD (Import) REV (Export)

**SAND\_BAR-PLATSBRG\_115\_PV20**

Tue 07/28/2026 to Fri 07/31/2026  
 0700 Continuous 1500  
 Work scheduled by: ISONE

SCH - NE - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**SAND\_BAR-PLATSBRG\_115\_PV20**

Tue 07/28/2026 to Fri 07/31/2026  
 0700 Continuous 1500  
 Work scheduled by: ISONE

CENTRAL EAST - VC **3625 MW**  
 Impacts Total Transfer Capability 100 MW  
 TTC with All Lines In Service 3725 MW

FWD (Import) REV (Export)

**VOLNEY\_-MARCY\_345\_19**

Mon 08/03/2026 to Mon 08/10/2026  
 0800 Continuous 1600  
 Work scheduled by: NGrid

UPDATED by NGrid 06/18/2026 13:12

ARR: 19

OSWEGO EXPORT **5250 MW**  
 Impacts Total Transfer Capability 0 MW  
 TTC with All Lines In Service 5250 MW

FWD (Import) REV (Export)

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Tuesday, June 23, 2026 to Wednesday, December 22, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**VOLNEY\_-MARCY\_345\_19**

Mon 08/03/2026 to Mon 08/10/2026  
 0800 Continuous 1600  
 Work scheduled by: NGrid

UPDATED by NGrid 06/18/2026 13:12

ARR: 19

CENTRAL EAST - VC  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**3525 MW**  
 200 MW  
 3725 MW

**ROCHESTR-PANNELL\_345\_RP2**

Mon 08/10/2026 to Wed 08/12/2026  
 0700 Continuous 1500  
 Work scheduled by: RGE

DYSINGER EAST  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**2300 MW**  
 900 MW  
 3200 MW

**BECK\_-NIAGARA\_230\_PA27**

Wed 08/12/2026 to Wed 08/12/2026  
 0800 Continuous 1600  
 Work scheduled by: IESO

SCH - OH - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**1900 MW**  
 100 MW  
 2000 MW

**GOETHALS\_345KV\_5**

Sat 08/15/2026 to Sat 08/15/2026  
 0301 Continuous 0330  
 Work scheduled by: ConEd

STATEN ISLAND  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**GOETHALS\_345KV\_5**

Mon 08/17/2026 to Mon 08/17/2026  
 0630 Continuous 0700  
 Work scheduled by: ConEd

STATEN ISLAND  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**HOMR\_NYW-PIERC\_NY\_345\_48**

Mon 08/17/2026 to Fri 08/28/2026  
 0700 Continuous 1500  
 Work scheduled by: NYSEG

SCH - PJ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**1950 MW 1050 MW**  
 150 MW 150 MW  
 2100 MW 1200 MW

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Tuesday, June 23, 2026 to Wednesday, December 22, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**FIVEMILE-LIMELAKE\_345\_49**

Mon 08/31/2026 to Tue 09/15/2026  
0800 Continuous 2359  
Work scheduled by: NGrid

UPDATED by NGrid 05/07/2026 15:12

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>1950 MW</b>	<b>1050 MW</b>
150 MW	150 MW
2100 MW	1200 MW

**LIMELAKE-ESTOLERD\_345\_29**

Mon 08/31/2026 to Tue 09/15/2026  
0800 Continuous 2359  
Work scheduled by: NGrid

UPDATED by NGrid 05/07/2026 15:12

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>1950 MW</b>	<b>1050 MW</b>
150 MW	150 MW
2100 MW	1200 MW

**MARION\_-FARRAGUT\_345\_C3403**

Sat 09/05/2026 to Sat 09/05/2026  
0201 Continuous 2359  
Work scheduled by: ConEd

CANCELLED by TO 06/23/2026 11:56

SCH - PJ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)

**E13THSTA-FARRAGUT\_345\_45**

Mon 09/07/2026 to Sat 09/12/2026  
0001 Continuous 0200  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>3800 MW</b>	
800 MW	
4600 MW	

**W49TH\_ST-E13THSTA\_345\_M54**

Mon 09/07/2026 to Sat 09/12/2026  
0001 Continuous 0200  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>3800 MW</b>	
800 MW	
4600 MW	

**NRTH1385-NOR HBR\_138\_601**

Tue 09/08/2026 to Sat 09/19/2026  
0800 Continuous 1000  
Work scheduled by: ISONE

SCH - NPX\_1385  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>100 MW</b>	<b>100 MW</b>
25 MW	25 MW
125 MW	125 MW

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Tuesday, June 23, 2026 to Wednesday, December 22, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**MARCY\_\_765\_345\_AT1**

Wed 09/09/2026 to Thu 09/10/2026  
0700 Continuous 1530  
Work scheduled by: NYPA

ARR: 19

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>1750 MW</b>	
1650 MW	
3400 MW	

**MARCY\_\_765\_345\_AT2**

Fri 09/11/2026 to Sat 09/12/2026  
0700 Continuous 1530  
Work scheduled by: NYPA

ARR: 19

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>1700 MW</b>	
1700 MW	
3400 MW	

**HUDSONTP-W49TH\_ST\_345\_Y56**

Sat 09/12/2026 to Sat 09/12/2026  
0001 Continuous 2300  
Work scheduled by: ConEd

SCH - PJM\_HTP  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>0 MW</b>	
660 MW	
660 MW	

**W49TH\_ST\_345KV\_7**

Sat 09/12/2026 to Sat 09/12/2026  
0001 Continuous 2300  
Work scheduled by: ConEd

SCH - PJM\_HTP  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>300 MW</b>	
360 MW	
660 MW	

**W49TH\_ST\_345KV\_8**

Sat 09/12/2026 to Sat 09/12/2026  
0001 Continuous 2300  
Work scheduled by: ConEd

SCH - PJM\_HTP  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>300 MW</b>	
360 MW	
660 MW	

**HUDSONTP-W49TH\_ST\_345\_Y56**

Sun 09/13/2026 to Sun 09/13/2026  
0101 Continuous 0130  
Work scheduled by: ConEd

SCH - PJM\_HTP  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>0 MW</b>	
660 MW	
660 MW	

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Tuesday, June 23, 2026 to Wednesday, December 22, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**W49TH\_ST\_345KV\_5**

Sun 09/13/2026 to Sat 12/19/2026  
 0101 Continuous 2359  
 Work scheduled by: ConEd

SCH - PJM\_HTP  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**300 MW**  
 360 MW  
 660 MW

**W49TH\_ST\_345KV\_7**

Sun 09/13/2026 to Wed 12/30/2026  
 0101 Continuous 0200  
 Work scheduled by: ConEd

SCH - PJM\_HTP  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**300 MW**  
 360 MW  
 660 MW

**W49TH\_ST\_345KV\_8**

Sun 09/13/2026 to Sun 09/13/2026  
 0101 Continuous 0130  
 Work scheduled by: ConEd

SCH - PJM\_HTP  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**300 MW**  
 360 MW  
 660 MW

**DUNWODIE\_345KV\_7**

Mon 09/14/2026 to Tue 09/15/2026  
 0001 Continuous 0200  
 Work scheduled by: ConEd

UPDATED by ConEd 12/04/2025 14:30

SPR/DUN-SOUTH  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**3800 MW**  
 800 MW  
 4600 MW

**DUNWODIE\_345KV\_8**

Mon 09/14/2026 to Tue 09/15/2026  
 0001 Continuous 0200  
 Work scheduled by: ConEd

UPDATED by ConEd 12/04/2025 14:30

SPR/DUN-SOUTH  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**3800 MW**  
 800 MW  
 4600 MW

**DUNWODIE-MOTTHAVN\_345\_72**

Mon 09/14/2026 to Thu 10/29/2026  
 0001 Continuous 0200  
 Work scheduled by: ConEd

UPDATED by ConEd 12/04/2025 14:30

SPR/DUN-SOUTH  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)  
**3800 MW**  
 800 MW  
 4600 MW

# NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, June 23, 2026 to Wednesday, December 22, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**STLAWRNC-MOSES\_230\_L34P**

Mon 09/14/2026 to Fri 09/18/2026  
 0600 Continuous 1630  
 Work scheduled by: NYPA

SCH - OH - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**BECK\_-NIAGARA\_230\_PA27**

Tue 09/15/2026 to Tue 11/17/2026  
 0500 Continuous 2330  
 Work scheduled by: NYPA

SCH - OH - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**1900 MW**  
 100 MW  
 2000 MW

**MARCY\_-FRASANNX\_345\_UCC2-41**

Tue 09/15/2026 to Tue 09/29/2026  
 0700 Continuous 1530  
 Work scheduled by: NYPA

CENTRAL EAST - VC  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**3225 MW**  
 500 MW  
 3725 MW

**FIVEMILE-LIMELAKE\_345\_49**

Wed 09/16/2026 to Sat 10/10/2026  
 0001 Continuous 1600  
 Work scheduled by: NGrid

SCH - PJ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**1950 MW 1050 MW**  
 150 MW 150 MW  
 2100 MW 1200 MW

**LIMELAKE-ESTOLERD\_345\_29**

Wed 09/16/2026 to Sat 10/10/2026  
 0001 Continuous 1600  
 Work scheduled by: NGrid

SCH - PJ - NY  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**1950 MW 1050 MW**  
 150 MW 150 MW  
 2100 MW 1200 MW

**E13THSTA-FARRAGUT\_345\_45**

Wed 09/16/2026 to Wed 09/16/2026  
 0130 Continuous 0200  
 Work scheduled by: ConEd

SPR/DUN-SOUTH  
 Impacts Total Transfer Capability  
 TTC with All Lines In Service

FWD (Import) REV (Export)

**3800 MW**  
 800 MW  
 4600 MW

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Tuesday, June 23, 2026 to Wednesday, December 22, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**DYSINGER-STA\_255\_345\_DH1**

Wed 09/16/2026 to Wed 09/30/2026  
 0500 Continuous 2100  
 Work scheduled by: NYPA

DYSINGER EAST	FWD (Import)	REV (Export)
	<b>2850 MW</b>	
Impacts Total Transfer Capability	350 MW	
TTC with All Lines In Service	3200 MW	

**MILLWOOD-EASTVIEW\_345\_W99**

Fri 09/18/2026 to Sun 09/27/2026  
 0001 Continuous 2200  
 Work scheduled by: ConEd

UPNY CONED	FWD (Import)	REV (Export)
	<b>8015 MW</b>	
Impacts Total Transfer Capability	195 MW	
TTC with All Lines In Service	8210 MW	

**SPRNBK\_345KV\_RNS5**

Fri 09/18/2026 to Fri 09/18/2026  
 0001 Continuous 0030  
 Work scheduled by: ConEd

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	<b>3200 MW</b>	
Impacts Total Transfer Capability	1400 MW	
TTC with All Lines In Service	4600 MW	

**HOMRC\_NY-MAINS\_NY\_345\_47**

Tue 09/22/2026 to Thu 09/24/2026  
 0800 Continuous 1700  
 Work scheduled by: PJM

SCH - PJ - NY	FWD (Import)	REV (Export)
	<b>1700 MW</b>	<b>1050 MW</b>
Impacts Total Transfer Capability	400 MW	150 MW
TTC with All Lines In Service	2100 MW	1200 MW

**NRTH1385-NOR\_HBR\_138\_602**

Wed 09/23/2026 to Wed 10/07/2026  
 0800 Continuous 1000  
 Work scheduled by: ISONE

SCH - NPX_1385	FWD (Import)	REV (Export)
	<b>100 MW</b>	<b>100 MW</b>
Impacts Total Transfer Capability	25 MW	25 MW
TTC with All Lines In Service	125 MW	125 MW

**SPRNBK\_345KV\_RNS5**

Sun 09/27/2026 to Sun 09/27/2026  
 2130 Continuous 2200  
 Work scheduled by: ConEd

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	<b>3200 MW</b>	
Impacts Total Transfer Capability	1400 MW	
TTC with All Lines In Service	4600 MW	

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Tuesday, June 23, 2026 to Wednesday, December 22, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**E13THSTA-FARRAGUT\_345\_45**

Mon 09/28/2026 to Wed 09/30/2026  
0001 Continuous 0100  
Work scheduled by: ConEd

SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

**GOETHALS\_345KV\_5**

Mon 09/28/2026 to Sat 10/03/2026  
0001 Continuous 0300  
Work scheduled by: ConEd

STATEN ISLAND  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**PANNELL\_-CLAY\_\_\_345\_1**

Mon 09/28/2026 to Fri 10/02/2026  
0700 Continuous 1530  
Work scheduled by: NYPA

WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

FWD (Import) REV (Export)

**DYSINGER-BYRON\_\_\_345\_DB2**

Thu 10/01/2026 to Mon 10/26/2026  
0500 Continuous 1900  
Work scheduled by: NYPA

DYSINGER EAST **2850 MW**  
Impacts Total Transfer Capability 350 MW  
TTC with All Lines In Service 3200 MW

FWD (Import) REV (Export)

**FITZPTRK-EDIC\_\_\_345\_FE-1**

Sun 10/04/2026 to Sun 10/04/2026  
2200 Continuous 2359  
Work scheduled by: NYPA

CENTRAL EAST - VC **3520 MW**  
Impacts Total Transfer Capability 205 MW  
TTC with All Lines In Service 3725 MW

FWD (Import) REV (Export)

**PANNELL\_-CLAY\_\_\_345\_2**

Mon 10/05/2026 to Fri 10/09/2026  
0700 Continuous 1530  
Work scheduled by: NYPA

WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

FWD (Import) REV (Export)

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Tuesday, June 23, 2026 to Wednesday, December 22, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**HERTELHQ-ASTANNEX\_345\_G180**

Mon 10/12/2026 to Wed 10/14/2026  
 0001 Continuous 1800  
 Work scheduled by: ConEd

SCH - HQ_CHPE	<b>0 MW</b>	FWD (Import) REV (Export)
Impacts Total Transfer Capability	1250 MW	
TTC with All Lines In Service	1250 MW	

**NEPTUNE\_DUFFYAVE\_345\_NEPTUNE**

Mon 10/12/2026 to Fri 10/16/2026  
 0600 Continuous 1600  
 Work scheduled by: LI

SCH - PJM_NEPTUNE	<b>0 MW</b>	FWD (Import) REV (Export)
Impacts Total Transfer Capability	660 MW	
TTC with All Lines In Service	660 MW	

**NEWBRDGE\_345\_138\_BK\_1**

Mon 10/12/2026 to Fri 10/16/2026  
 0600 Continuous 1600  
 Work scheduled by: LI

SCH - PJM_NEPTUNE	<b>375 MW</b>	FWD (Import) REV (Export)
Impacts Total Transfer Capability	285 MW	
TTC with All Lines In Service	660 MW	

**NEWBRDGE\_345\_138\_BK\_2**

Mon 10/12/2026 to Fri 10/16/2026  
 0600 Continuous 1600  
 Work scheduled by: LI

SCH - PJM_NEPTUNE	<b>375 MW</b>	FWD (Import) REV (Export)
Impacts Total Transfer Capability	285 MW	
TTC with All Lines In Service	660 MW	

**NEWBRDGE-DUFFYAVE\_345\_501**

Mon 10/12/2026 to Fri 10/16/2026  
 0600 Continuous 1600  
 Work scheduled by: LI

SCH - PJM_NEPTUNE	<b>0 MW</b>	FWD (Import) REV (Export)
Impacts Total Transfer Capability	660 MW	
TTC with All Lines In Service	660 MW	

**HOMR\_NYW-PIERC\_NY\_345\_48**

Mon 10/12/2026 to Fri 10/16/2026  
 0800 Continuous 1500  
 Work scheduled by: NYSEG

UPDATED by PJM 06/03/2026 14:01

SCH - PJ - NY	<b>1950 MW</b>	FWD (Import) REV (Export)
Impacts Total Transfer Capability	150 MW	150 MW
TTC with All Lines In Service	2100 MW	1200 MW

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Tuesday, June 23, 2026 to Wednesday, December 22, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**NRTH1385-NOR HBR\_138\_603**

Mon 10/12/2026 to Fri 10/23/2026  
 0800 Continuous 1000  
 Work scheduled by: ISONE

SCH - NPX\_1385

FWD (Import) REV (Export)

**100 MW 100 MW**

Impacts Total Transfer Capability

25 MW 25 MW

TTC with All Lines In Service

125 MW 125 MW

**CHATGUAY-MASSENA\_765\_7040**

Wed 10/14/2026 to Wed 10/28/2026  
 0001 Continuous 2359  
 Work scheduled by: NYPA

SCH - HQ - NY

FWD (Import) REV (Export)

**0 MW 0 MW**

Impacts Total Transfer Capability

1500 MW 1000 MW

TTC with All Lines In Service

1500 MW 1000 MW

**CHATGUAY-MASSENA\_765\_7040**

Wed 10/14/2026 to Wed 10/28/2026  
 0001 Continuous 2359  
 Work scheduled by: NYPA

MOSES SOUTH

FWD (Import) REV (Export)

**1750 MW**

Impacts Total Transfer Capability

1650 MW

TTC with All Lines In Service

3400 MW

**MARCY\_765\_345\_AT1**

Wed 10/14/2026 to Wed 10/28/2026  
 0001 Continuous 2359  
 Work scheduled by: NYPA

ARR: 19

MOSES SOUTH

FWD (Import) REV (Export)

**1750 MW**

Impacts Total Transfer Capability

1650 MW

TTC with All Lines In Service

3400 MW

**MARCY\_765\_345\_AT2**

Wed 10/14/2026 to Wed 10/28/2026  
 0001 Continuous 2359  
 Work scheduled by: NYPA

ARR: 19

MOSES SOUTH

FWD (Import) REV (Export)

**1700 MW**

Impacts Total Transfer Capability

1700 MW

TTC with All Lines In Service

3400 MW

**MASSENA\_MARCY\_765\_MSU1**

Wed 10/14/2026 to Wed 10/28/2026  
 0001 Continuous 2359  
 Work scheduled by: NYPA

SCH - HQ - NY

FWD (Import) REV (Export)

**475 MW 1000 MW**

Impacts Total Transfer Capability

1025 MW 0 MW

TTC with All Lines In Service

1500 MW 1000 MW

# NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, June 23, 2026 to Wednesday, December 22, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**MASSENA\_MARCY\_\_765\_MSU1**

Wed 10/14/2026 to Wed 10/28/2026  
 0001 Continuous 2359  
 Work scheduled by: NYPA

	FWD (Import)	REV (Export)
CENTRAL EAST - VC	<b>2595 MW</b>	
Impacts Total Transfer Capability	1130 MW	
TTC with All Lines In Service	3725 MW	

**MASSENA\_MARCY\_\_765\_MSU1**

Wed 10/14/2026 to Wed 10/28/2026  
 0001 Continuous 2359  
 Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS	<b>190 MW</b>	
Impacts Total Transfer Capability	80 MW	
TTC with All Lines In Service	270 MW	

**MASSENA\_MARCY\_\_765\_MSU1**

Wed 10/14/2026 to Wed 10/28/2026  
 0001 Continuous 2359  
 Work scheduled by: NYPA

	FWD (Import)	REV (Export)
MOSES SOUTH	<b>500 MW</b>	
Impacts Total Transfer Capability	2900 MW	
TTC with All Lines In Service	3400 MW	

**MASSENA\_MARCY\_\_765\_MSU1 , CHATGUAY-MASSENA\_765\_7040**

Wed 10/14/2026 to Wed 10/28/2026  
 0001 2359  
 Work scheduled by:

	FWD (Import)	REV (Export)
MOSES SOUTH	<b>500 MW</b>	
Impacts Total Transfer Capability	2900 MW	
TTC with All Lines In Service	3400 MW	

**MOSES\_\_-MASSENA\_230\_MMS2 , MOSES\_\_-MASSENA\_230\_MMS1**

Wed 10/14/2026 to Wed 10/28/2026  
 0001 2359  
 Work scheduled by:

	FWD (Import)	REV (Export)
SCH - HQ - NY	<b>850 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	650 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

**MOSES\_\_-MASSENA\_230\_MMS2 , MOSES\_\_-MASSENA\_230\_MMS1**

Wed 10/14/2026 to Wed 10/28/2026  
 0001 2359  
 Work scheduled by:

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS	<b>190 MW</b>	
Impacts Total Transfer Capability	80 MW	
TTC with All Lines In Service	270 MW	

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Tuesday, June 23, 2026 to Wednesday, December 22, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**FIVEMILE-LIMELAKE\_345\_49**

Mon 10/19/2026 to Tue 12/22/2026  
 0700 Continuous 1700  
 Work scheduled by: NGrid

SCH - PJ - NY	FWD (Import)	REV (Export)
	<b>1950 MW</b>	<b>1050 MW</b>
Impacts Total Transfer Capability	150 MW	150 MW
TTC with All Lines In Service	2100 MW	1200 MW

**PIERCBRK-FIVEMILE\_345\_37**

Mon 10/19/2026 to Fri 11/06/2026  
 1200 Continuous 1600  
 Work scheduled by: PJM

SCH - PJ - NY	FWD (Import)	REV (Export)
	<b>1800 MW</b>	<b>1050 MW</b>
Impacts Total Transfer Capability	300 MW	150 MW
TTC with All Lines In Service	2100 MW	1200 MW

**ROSETON\_EFISHKIL\_345\_RFK305**

Mon 10/26/2026 to Fri 11/06/2026  
 0700 Continuous 1530  
 Work scheduled by: NYPA

UPNY CONED	FWD (Import)	REV (Export)
	<b>7470 MW</b>	
Impacts Total Transfer Capability	740 MW	
TTC with All Lines In Service	8210 MW	

**DYSINGER-GRAHAM\_345\_DG1**

Tue 10/27/2026 to Sat 11/21/2026  
 0500 Continuous 2100  
 Work scheduled by: NYPA

DYSINGER EAST	FWD (Import)	REV (Export)
Impacts Total Transfer Capability		
TTC with All Lines In Service		

**DUNWODIE\_345KV\_7**

Wed 10/28/2026 to Thu 10/29/2026  
 0001 Continuous 0200  
 Work scheduled by: ConEd

UPDATED by ConEd 12/04/2025 14:30

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

**DUNWODIE\_345KV\_8**

Wed 10/28/2026 to Thu 10/29/2026  
 0001 Continuous 0200  
 Work scheduled by: ConEd

UPDATED by ConEd 12/04/2025 14:30

SPR/DUN-SOUTH	FWD (Import)	REV (Export)
	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Tuesday, June 23, 2026 to Wednesday, December 22, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**MILLWOOD-EASTVIEW\_345\_W82**

Thu 10/29/2026 to Sat 11/07/2026  
0300 Continuous 2300  
Work scheduled by: ConEd

UPNY CONED **8015 MW**  
Impacts Total Transfer Capability 195 MW  
TTC with All Lines In Service 8210 MW

FWD (Import) REV (Export)

**SPRNBRK\_345KV\_RNS4**

Thu 10/29/2026 to Thu 10/29/2026  
0300 Continuous 0330  
Work scheduled by: ConEd

SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

**STLAWRNC-MOSES\_230\_L34P**

Thu 10/29/2026 to Fri 11/13/2026  
0900 Continuous 1600  
Work scheduled by: IESO

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import) REV (Export)

**SPRNBRK\_345KV\_RNS4**

Fri 10/30/2026 to Fri 10/30/2026  
0300 Continuous 0330  
Work scheduled by: ConEd

SPR/DUN-SOUTH **3200 MW**  
Impacts Total Transfer Capability 1400 MW  
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

**DUNWODIE\_345KV\_3**

Mon 11/02/2026 to Mon 11/02/2026  
0001 Continuous 2200  
Work scheduled by: ConEd

UPDATED by ConEd 03/27/2026 13:56

SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

**DUNWODIE\_345KV\_5**

Mon 11/02/2026 to Mon 11/02/2026  
0001 Continuous 2200  
Work scheduled by: ConEd

UPDATED by ConEd 03/27/2026 13:56

SPR/DUN-SOUTH **3800 MW**  
Impacts Total Transfer Capability 800 MW  
TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Tuesday, June 23, 2026 to Wednesday, December 22, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**DUNWODIE-MOTTHAVN\_345\_71**

Mon 11/02/2026 to Mon 12/14/2026  
0001 Continuous 0200  
Work scheduled by: ConEd

UPDATED by ConEd 03/27/2026 13:56

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>3800 MW</b>	
800 MW	
4600 MW	

**LINDN\_CG-LNDVFT\_\_345\_V-3022**

Mon 11/02/2026 to Sat 11/07/2026  
0800 Continuous 1900  
Work scheduled by: PJM

SCH - PJM\_VFT  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>0 MW</b>	<b>0 MW</b>
315 MW	315 MW
315 MW	315 MW

**ROSETON\_EFISHKIL\_345\_RFK305**

Fri 11/06/2026 to Fri 11/13/2026  
1600 Continuous 1600  
Work scheduled by: CHGE

UPDATED by ConEd 06/05/2026 08:04

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>7470 MW</b>	
740 MW	
8210 MW	

**MILLWOOD-EASTVIEW\_345\_W99**

Mon 11/09/2026 to Mon 11/09/2026  
0001 Continuous 0030  
Work scheduled by: ConEd

UPNY CONED  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>8015 MW</b>	
195 MW	
8210 MW	

**SPRNBK\_345KV\_RNS5**

Mon 11/09/2026 to Mon 11/09/2026  
0001 Continuous 0030  
Work scheduled by: ConEd

SPR/DUN-SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>3200 MW</b>	
1400 MW	
4600 MW	

**STLAWRNC-MOSES\_\_230\_L33P**

Mon 11/16/2026 to Fri 11/20/2026  
0600 Continuous 1630  
Work scheduled by: NYPA

SCH - OH - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Tuesday, June 23, 2026 to Wednesday, December 22, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**BECK\_\_-NIAGARA\_230\_PA27**

Mon 11/23/2026 to Fri 11/27/2026  
0630 Continuous 1600  
Work scheduled by: IESO

SCH - OH - NY	<b>2050 MW</b>	FWD (Import) REV (Export)
Impacts Total Transfer Capability	450 MW	
TTC with All Lines In Service	2500 MW	

**EDIC\_\_-FRASER\_345\_EF24-40**

Mon 11/30/2026 to Sun 12/06/2026  
0700 Continuous 1530  
Work scheduled by: NYPA

CENTRAL EAST - VC	<b>3225 MW</b>	FWD (Import) REV (Export)
Impacts Total Transfer Capability	500 MW	
TTC with All Lines In Service	3725 MW	

**DUNWODIE\_345KV\_3**

Fri 12/04/2026 to Fri 12/04/2026  
0001 Continuous 0030  
Work scheduled by: ConEd

UPDATED by ConEd 03/27/2026 13:56

SPR/DUN-SOUTH	<b>3800 MW</b>	FWD (Import) REV (Export)
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

**DUNWODIE\_345KV\_3**

Sat 12/12/2026 to Mon 12/14/2026  
0001 Continuous 0200  
Work scheduled by: ConEd

UPDATED by ConEd 03/27/2026 13:56

SPR/DUN-SOUTH	<b>3800 MW</b>	FWD (Import) REV (Export)
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

**DUNWODIE\_345KV\_5**

Sat 12/12/2026 to Mon 12/14/2026  
0001 Continuous 0200  
Work scheduled by: ConEd

UPDATED by ConEd 03/27/2026 13:56

SPR/DUN-SOUTH	<b>3800 MW</b>	FWD (Import) REV (Export)
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

**HUDSONTP-W49TH\_ST\_345\_Y56**

Sat 12/19/2026 to Wed 12/30/2026  
0001 Continuous 0200  
Work scheduled by: ConEd

SCH - PJM_HTP	<b>0 MW</b>	FWD (Import) REV (Export)
Impacts Total Transfer Capability	660 MW	
TTC with All Lines In Service	660 MW	

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Tuesday, June 23, 2026 to Wednesday, December 22, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**W49TH\_ST\_345KV\_8**

Sat 12/19/2026 to Wed 12/30/2026  
0001 Continuous 0200  
Work scheduled by: ConEd

SCH - PJM\_HTP

FWD (Import) REV (Export)

**300 MW**

Impacts Total Transfer Capability

360 MW

TTC with All Lines In Service

660 MW

**MILLWOOD-EASTVIEW\_345\_W99**

Wed 12/23/2026 to Wed 12/23/2026  
2130 Continuous 2200  
Work scheduled by: ConEd

UPNY CONED

FWD (Import) REV (Export)

**8015 MW**

Impacts Total Transfer Capability

195 MW

TTC with All Lines In Service

8210 MW

**SPRNBK\_345KV\_RNS5**

Wed 12/23/2026 to Wed 12/23/2026  
2130 Continuous 2200  
Work scheduled by: ConEd

SPR/DUN-SOUTH

FWD (Import) REV (Export)

**3200 MW**

Impacts Total Transfer Capability

1400 MW

TTC with All Lines In Service

4600 MW

**STLAWRNC-MOSES\_\_230\_L34P**

Fri 12/25/2026 to Fri 12/25/2026  
0800 Continuous 1600  
Work scheduled by: IESO

SCH - OH - NY

FWD (Import) REV (Export)

Impacts Total Transfer Capability

TTC with All Lines In Service

**SPRNBK\_345KV\_RS4 , SPRNBK\_345KV\_RS3**

Mon 02/08/2027 to Tue 02/09/2027  
0001 0200  
Work scheduled by:

SPR/DUN-SOUTH

FWD (Import) REV (Export)

**3800 MW**

Impacts Total Transfer Capability

800 MW

TTC with All Lines In Service

4600 MW

**SPRNBK\_345KV\_RNS5**

Tue 02/09/2027 to Fri 02/19/2027  
0201 Continuous 0200  
Work scheduled by: ConEd

SPR/DUN-SOUTH

FWD (Import) REV (Export)

**3200 MW**

Impacts Total Transfer Capability

1400 MW

TTC with All Lines In Service

4600 MW

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Tuesday, June 23, 2026 to Wednesday, December 22, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**SPRNBK\_W49TH\_ST\_345\_M51**

Tue 02/09/2027 to Fri 02/19/2027  
 0201 Continuous 0200  
 Work scheduled by: ConEd

SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

**BUCHAN\_S-MILLWOOD\_345\_W97**

Mon 03/01/2027 to Wed 03/03/2027  
 0001 Continuous 0200  
 Work scheduled by: ConEd

UPNY CONED **8175 MW**  
 Impacts Total Transfer Capability 35 MW  
 TTC with All Lines In Service 8210 MW

FWD (Import) REV (Export)

**SPRNBK\_345KV\_RS4 , SPRNBK\_345KV\_RS3**

Thu 03/11/2027 to Sun 03/14/2027  
 0001 0100  
 Work scheduled by:

SPR/DUN-SOUTH **3800 MW**  
 Impacts Total Transfer Capability 800 MW  
 TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

**SPRNBK\_345KV\_RNS5**

Sun 03/14/2027 to Wed 03/17/2027  
 0101 Continuous 0200  
 Work scheduled by: ConEd

SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

**SPRNBK\_W49TH\_ST\_345\_M51**

Sun 03/14/2027 to Wed 03/17/2027  
 0101 Continuous 0200  
 Work scheduled by: ConEd

SPR/DUN-SOUTH **3200 MW**  
 Impacts Total Transfer Capability 1400 MW  
 TTC with All Lines In Service 4600 MW

FWD (Import) REV (Export)

**BUCHAN\_S-MILLWOOD\_345\_W97**

Sun 04/04/2027 to Sun 04/04/2027  
 0001 Continuous 0200  
 Work scheduled by: ConEd

UPNY CONED **8175 MW**  
 Impacts Total Transfer Capability 35 MW  
 TTC with All Lines In Service 8210 MW

FWD (Import) REV (Export)

# NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, June 23, 2026 to Wednesday, December 22, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**BUCHAN\_S-MILLWOOD\_345\_W97**

Sun 04/04/2027 to Wed 04/07/2027  
 0201 Continuous 0200  
 Work scheduled by: ConEd

UPNY CONED	<b>FWD (Import)</b>	REV (Export)
	<b>8175 MW</b>	
Impacts Total Transfer Capability	35 MW	
TTC with All Lines In Service	8210 MW	

**DUNWODIE\_345KV\_4**

Mon 04/12/2027 to Sat 04/24/2027  
 0001 Continuous 0200  
 Work scheduled by: ConEd

SPR/DUN-SOUTH	<b>FWD (Import)</b>	REV (Export)
	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

**DUNWODIE\_345KV\_6**

Mon 04/12/2027 to Sat 04/24/2027  
 0001 Continuous 0200  
 Work scheduled by: ConEd

SPR/DUN-SOUTH	<b>FWD (Import)</b>	REV (Export)
	<b>3800 MW</b>	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

**DUNWODIE-SHORE\_RD\_345\_Y50**

Mon 04/12/2027 to Sat 04/24/2027  
 0001 Continuous 0200  
 Work scheduled by: ConEd

CONED - LIPA	<b>FWD (Import)</b>	REV (Export)
	<b>800 MW</b>	
Impacts Total Transfer Capability	700 MW	
TTC with All Lines In Service	1500 MW	

**PLSNTVLY-WOOD\_ST\_345\_F30**

Mon 04/12/2027 to Sat 05/22/2027  
 0001 Continuous 0200  
 Work scheduled by: ConEd

UPNY CONED	<b>FWD (Import)</b>	REV (Export)
	<b>7780 MW</b>	
Impacts Total Transfer Capability	430 MW	
TTC with All Lines In Service	8210 MW	

**SHORE\_RD\_345\_138\_BK 1**

Mon 04/12/2027 to Sat 04/24/2027  
 0001 Continuous 0200  
 Work scheduled by: ConEd

CONED - LIPA	<b>FWD (Import)</b>	REV (Export)
	<b>1350 MW</b>	
Impacts Total Transfer Capability	150 MW	
TTC with All Lines In Service	1500 MW	

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Tuesday, June 23, 2026 to Wednesday, December 22, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**SHORE\_RD\_345\_138\_BK 2**

Mon 04/12/2027 to Sat 04/24/2027  
 0001 Continuous 0200  
 Work scheduled by: ConEd

CONED - LIPA	FWD (Import)	REV (Export)
	<b>1350 MW</b>	
Impacts Total Transfer Capability	150 MW	
TTC with All Lines In Service	1500 MW	

**NEPTUNE\_DUFFYAVE\_345\_NEPTUNE**

Mon 05/10/2027 to Fri 05/14/2027  
 0600 Continuous 1600  
 Work scheduled by: LI

SCH - PJM_NEPTUNE	FWD (Import)	REV (Export)
	<b>0 MW</b>	
Impacts Total Transfer Capability	660 MW	
TTC with All Lines In Service	660 MW	

**NEWBRDGE\_345\_138\_BK\_1**

Mon 05/10/2027 to Fri 05/14/2027  
 0600 Continuous 1600  
 Work scheduled by: LI

SCH - PJM_NEPTUNE	FWD (Import)	REV (Export)
	<b>375 MW</b>	
Impacts Total Transfer Capability	285 MW	
TTC with All Lines In Service	660 MW	

**NEWBRDGE\_345\_138\_BK\_2**

Mon 05/10/2027 to Fri 05/14/2027  
 0600 Continuous 1600  
 Work scheduled by: LI

SCH - PJM_NEPTUNE	FWD (Import)	REV (Export)
	<b>375 MW</b>	
Impacts Total Transfer Capability	285 MW	
TTC with All Lines In Service	660 MW	

**NEWBRDGE-DUFFYAVE\_345\_501**

Mon 05/10/2027 to Fri 05/14/2027  
 0600 Continuous 1600  
 Work scheduled by: LI

SCH - PJM_NEPTUNE	FWD (Import)	REV (Export)
	<b>0 MW</b>	
Impacts Total Transfer Capability	660 MW	
TTC with All Lines In Service	660 MW	

**CHATGUAY-MASSENA\_765\_7040**

Mon 05/24/2027 to Sat 05/29/2027  
 0001 Continuous 0130  
 Work scheduled by: NYPA

UPDATED by NYPA 06/05/2026 15:18

SCH - HQ - NY	FWD (Import)	REV (Export)
	<b>0 MW</b>	<b>0 MW</b>
Impacts Total Transfer Capability	1500 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

# NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, June 23, 2026 to Wednesday, December 22, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**CHATGUAY-MASSENA\_765\_7040**

Mon 05/24/2027 to Sat 05/29/2027  
0001 Continuous 0130  
Work scheduled by: NYPA

UPDATED by NYPA 06/05/2026 15:18

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>1750 MW</b>	
1650 MW	
3400 MW	

**MARCY\_765\_345\_AT1**

Mon 05/24/2027 to Sat 05/29/2027  
0001 Continuous 0130  
Work scheduled by: NYPA

UPDATED by NYPA 06/05/2026 15:18

ARR: 19

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>1750 MW</b>	
1650 MW	
3400 MW	

**MARCY\_765\_345\_AT2**

Mon 05/24/2027 to Sat 05/29/2027  
0001 Continuous 0130  
Work scheduled by: NYPA

UPDATED by NYPA 06/05/2026 15:18

ARR: 19

MOSES SOUTH  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>1700 MW</b>	
1700 MW	
3400 MW	

**MASSENA -MARCY\_765\_MSU1**

Mon 05/24/2027 to Sat 05/29/2027  
0001 Continuous 0130  
Work scheduled by: NYPA

UPDATED by NYPA 06/05/2026 15:18

SCH - HQ - NY  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>475 MW</b>	<b>1000 MW</b>
1025 MW	0 MW
1500 MW	1000 MW

**MASSENA -MARCY\_765\_MSU1**

Mon 05/24/2027 to Sat 05/29/2027  
0001 Continuous 0130  
Work scheduled by: NYPA

UPDATED by NYPA 06/05/2026 15:18

CENTRAL EAST - VC  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>2595 MW</b>	
1130 MW	
3725 MW	

**MASSENA -MARCY\_765\_MSU1**

Mon 05/24/2027 to Sat 05/29/2027  
0001 Continuous 0130  
Work scheduled by: NYPA

UPDATED by NYPA 06/05/2026 15:18

SCH - HQ\_CEDARS  
Impacts Total Transfer Capability  
TTC with All Lines In Service

FWD (Import)	REV (Export)
<b>190 MW</b>	
80 MW	
270 MW	

# NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, June 23, 2026 to Wednesday, December 22, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**MASSENA\_MARCY\_\_765\_MSU1**

Mon 05/24/2027 to Sat 05/29/2027  
0001 Continuous 0130  
Work scheduled by: NYPA

UPDATED by NYPA 06/05/2026 15:18

MOSES SOUTH **500 MW**  
Impacts Total Transfer Capability 2900 MW  
TTC with All Lines In Service 3400 MW

FWD (Import) REV (Export)

**MASSENA\_MARCY\_\_765\_MSU1 , CHATGUAY-MASSENA\_765\_7040**

Mon 05/24/2027 to Sat 05/29/2027  
0001 0130  
Work scheduled by:

MOSES SOUTH **500 MW**  
Impacts Total Transfer Capability 2900 MW  
TTC with All Lines In Service 3400 MW

FWD (Import) REV (Export)

**MOSES\_\_-MASSENA\_230\_MMS2 , MOSES\_\_-MASSENA\_230\_MMS1**

Mon 05/24/2027 to Sat 05/29/2027  
0001 0130  
Work scheduled by:

SCH - HQ - NY **850 MW 0 MW**  
Impacts Total Transfer Capability 650 MW 1000 MW  
TTC with All Lines In Service 1500 MW 1000 MW

FWD (Import) REV (Export)

**MOSES\_\_-MASSENA\_230\_MMS2 , MOSES\_\_-MASSENA\_230\_MMS1**

Mon 05/24/2027 to Sat 05/29/2027  
0001 0130  
Work scheduled by:

SCH - HQ\_CEDARS **190 MW**  
Impacts Total Transfer Capability 80 MW  
TTC with All Lines In Service 270 MW

FWD (Import) REV (Export)

**PANNELL\_-CLAY\_\_345\_1**

Mon 09/13/2027 to Fri 09/17/2027  
0700 Continuous 1730  
Work scheduled by: NYPA

WEST CENTRAL **1300 MW**  
Impacts Total Transfer Capability 950 MW  
TTC with All Lines In Service 2250 MW

FWD (Import) REV (Export)

**INGHAM\_C\_115\_115\_PAR 2**

Fri 09/17/2027 to Fri 10/29/2027  
0600 Continuous 1600  
Work scheduled by: NGrid

CENTRAL EAST - VC **3605 MW**  
Impacts Total Transfer Capability 120 MW  
TTC with All Lines In Service 3725 MW

FWD (Import) REV (Export)

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Tuesday, June 23, 2026 to Wednesday, December 22, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

<b>MARCY__FRASANNX_345_UCC2-41</b>				FWD (Import)	REV (Export)
Sat 09/18/2027	to	Sat 10/30/2027	CENTRAL EAST - VC	<b>3225 MW</b>	
0700	Continuous	1730	Impacts Total Transfer Capability	500 MW	
Work scheduled by: NYPA			TTC with All Lines In Service	3725 MW	
<b>BUCHAN_S-MILLWOOD_345_W97</b>				FWD (Import)	REV (Export)
Mon 09/20/2027	to	Mon 09/20/2027	UPNY CONED	<b>8175 MW</b>	
0001	Continuous	0030	Impacts Total Transfer Capability	35 MW	
Work scheduled by: ConEd			TTC with All Lines In Service	8210 MW	
<b>PANNELL_-CLAY__345_2</b>				FWD (Import)	REV (Export)
Mon 09/20/2027	to	Fri 09/24/2027	WEST CENTRAL	<b>1300 MW</b>	
0700	Continuous	1730	Impacts Total Transfer Capability	950 MW	
Work scheduled by: NYPA			TTC with All Lines In Service	2250 MW	
<b>BUCHAN_S-MILLWOOD_345_W97</b>				FWD (Import)	REV (Export)
Tue 09/21/2027	to	Tue 09/21/2027	UPNY CONED	<b>8175 MW</b>	
0130	Continuous	0200	Impacts Total Transfer Capability	35 MW	
Work scheduled by: ConEd			TTC with All Lines In Service	8210 MW	
<b>WOOD_ST_-PLSNTVLE_345_Y87</b>				FWD (Import)	REV (Export)
Mon 10/04/2027	to	Sat 10/16/2027	UPNY CONED	<b>7795 MW</b>	
0001	Continuous	0200	Impacts Total Transfer Capability	415 MW	
Work scheduled by: ConEd			TTC with All Lines In Service	8210 MW	
<b>SPRNBK_-UNIONHBS_345_Y49</b>				FWD (Import)	REV (Export)
Mon 10/04/2027	to	Fri 05/26/2028	CONED - LIPA	<b>775 MW</b>	
0800	Continuous	1530	Impacts Total Transfer Capability	725 MW	
Work scheduled by: NYPA			TTC with All Lines In Service	1500 MW	

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Tuesday, June 23, 2026 to Wednesday, December 22, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**UNIONDHB\_345\_138\_AT1**

Mon 10/04/2027 to Fri 05/26/2028  
 0800 Continuous 1530  
 Work scheduled by: NYPA

CONED - LIPA	FWD (Import)	REV (Export)
	<b>1250 MW</b>	
Impacts Total Transfer Capability	250 MW	
TTC with All Lines In Service	1500 MW	

**UNIONDHB\_345\_138\_AT2**

Mon 10/04/2027 to Fri 05/26/2028  
 0800 Continuous 1530  
 Work scheduled by: NYPA

CONED - LIPA	FWD (Import)	REV (Export)
	<b>1250 MW</b>	
Impacts Total Transfer Capability	250 MW	
TTC with All Lines In Service	1500 MW	

**NEPTUNE\_-DUFFYAVE\_345\_NEPTUNE**

Mon 10/11/2027 to Thu 10/14/2027  
 0600 Continuous 1600  
 Work scheduled by: LI

SCH - PJM_NEPTUNE	FWD (Import)	REV (Export)
	<b>0 MW</b>	
Impacts Total Transfer Capability	660 MW	
TTC with All Lines In Service	660 MW	

**NEWBRDGE\_345\_138\_BK\_1**

Mon 10/11/2027 to Thu 10/14/2027  
 0600 Continuous 1600  
 Work scheduled by: LI

SCH - PJM_NEPTUNE	FWD (Import)	REV (Export)
	<b>375 MW</b>	
Impacts Total Transfer Capability	285 MW	
TTC with All Lines In Service	660 MW	

**NEWBRDGE\_345\_138\_BK\_2**

Mon 10/11/2027 to Thu 10/14/2027  
 0600 Continuous 1600  
 Work scheduled by: LI

SCH - PJM_NEPTUNE	FWD (Import)	REV (Export)
	<b>375 MW</b>	
Impacts Total Transfer Capability	285 MW	
TTC with All Lines In Service	660 MW	

**NEWBRDGE-DUFFYAVE\_345\_501**

Mon 10/11/2027 to Thu 10/14/2027  
 0600 Continuous 1600  
 Work scheduled by: LI

SCH - PJM_NEPTUNE	FWD (Import)	REV (Export)
	<b>0 MW</b>	
Impacts Total Transfer Capability	660 MW	
TTC with All Lines In Service	660 MW	

# NYISO TRANSFER LIMITATIONS

Seasonal Limits

Tuesday, June 23, 2026 to Wednesday, December 22, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**BUCHAN\_S-MILLWOOD\_345\_W97**

Sun 10/24/2027 to Wed 10/27/2027  
 0001 Continuous 0200  
 Work scheduled by: ConEd

UPNY CONED	<b>8175 MW</b>	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	35 MW		
TTC with All Lines In Service	8210 MW		

**SPRNBRK\_345KV\_RNS4**

Wed 12/01/2027 to Wed 12/01/2027  
 0001 Continuous 0030  
 Work scheduled by: ConEd

SPR/DUN-SOUTH	<b>3200 MW</b>	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	1400 MW		
TTC with All Lines In Service	4600 MW		

**SPRNBRK\_-W49TH\_ST\_345\_M52**

Wed 12/01/2027 to Wed 12/15/2027  
 0001 Continuous 0200  
 Work scheduled by: ConEd

SPR/DUN-SOUTH	<b>3200 MW</b>	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	1400 MW		
TTC with All Lines In Service	4600 MW		

**W49TH\_ST\_345KV\_5**

Wed 12/01/2027 to Wed 12/15/2027  
 0001 Continuous 0200  
 Work scheduled by: ConEd

SCH - PJM_HTP	<b>200 MW</b>	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	460 MW		
TTC with All Lines In Service	660 MW		

**SPRNBRK\_345KV\_RNS4**

Wed 12/15/2027 to Wed 12/15/2027  
 0130 Continuous 0200  
 Work scheduled by: ConEd

SPR/DUN-SOUTH	<b>3200 MW</b>	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	1400 MW		
TTC with All Lines In Service	4600 MW		

**W49TH\_ST\_345KV\_5**

Wed 12/15/2027 to Tue 02/22/2028  
 0201 Continuous 0200  
 Work scheduled by: ConEd

SCH - PJM_HTP	<b>200 MW</b>	FWD (Import)	REV (Export)
Impacts Total Transfer Capability	460 MW		
TTC with All Lines In Service	660 MW		

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits**

Tuesday, June 23, 2026 to Wednesday, December 22, 2027

CENTRAL EAST	7550 MW
CENTRAL EAST - VC	3725 MW
TOTAL EAST	7550 MW
UPNY CONED	8210 MW
SPR/DUN-SOUTH	4600 MW
DYSINGER EAST	3200 MW
MOSES SOUTH	3400 MW

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**W49TH\_ST\_345KV\_7**

Wed 12/15/2027                      to                      Tue 02/22/2028  
 0201                                      Continuous                      0200  
 Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - PJM_HTP	<b>200 MW</b>	
Impacts Total Transfer Capability	460 MW	
TTC with All Lines In Service	660 MW	