NYISO TRANSFER LIMITATIONS

Seasonal Limits — **Friday, October 2, 2026 to Saturday, April 1, 2028**

CENTRAL EAST	**7550 MW**
CENTRAL EAST - VC	**3725 MW**
TOTAL EAST	**7550 MW**
UPNY CONED	**8210 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3400 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBRK__345KV_R5S3_BYPASS , SPRNBRK__345KV_R4S3_BYPASS , DUNWODIE_345KV_10_BYPASS , DUNWODIE_345KV_9_BYPASS

Sun 02/01/2015 to Fri 02/01/2030
0000 0000
Work scheduled by:

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	**4350 MW**	
Impacts Total Transfer Capability	250 MW	
TTC with All Lines In Service	4600 MW	

SPRNBRK__345KV_R5S3_BYPASS , SPRNBRK__345KV_R4S3_BYPASS , DUNWODIE_345KV_10_BYPASS , DUNWODIE_345KV_9_BYPASS

Sun 02/01/2015 to Fri 02/01/2030
0000 0000
Work scheduled by:

	FWD (Import)	REV (Export)
UPNY CONED	**7505 MW**	
Impacts Total Transfer Capability	705 MW	
TTC with All Lines In Service	8210 MW	

HUDSONP_-FARRAGUT_345_B3402

Mon 01/15/2018 to Mon 02/01/2027
0001 Continuous 2359
Work scheduled by: ConEd

EXT FORCED by ConEd 06/25/2026 13:42

	FWD (Import)	REV (Export)
SCH - PJ - NY		
Impacts Total Transfer Capability		
TTC with All Lines In Service		

MARION__-FARRAGUT_345_C3403

Mon 01/15/2018 to Mon 02/01/2027
0001 Continuous 2359
Work scheduled by: ConEd

EXT FORCED by ConEd 06/25/2026 13:42

	FWD (Import)	REV (Export)
SCH - PJ - NY		
Impacts Total Transfer Capability		
TTC with All Lines In Service		

MARION__-FARRAGUT_345_C3403 , HUDSONP_-FARRAGUT_345_B3402

Mon 01/15/2018 to Mon 02/01/2027
0001 2359
Work scheduled by:

	FWD (Import)	REV (Export)
SCH - PJ - NY	**1950 MW**	**1050 MW**
Impacts Total Transfer Capability	150 MW	150 MW
TTC with All Lines In Service	2100 MW	1200 MW

DYSINGER-GRAHAM__345_DG1

Tue 02/10/2026 to Sat 11/21/2026
1122 Continuous 2100
Work scheduled by: NYISO

FORCED by NYISO 03/21/2026 14:33

	FWD (Import)	REV (Export)
DYSINGER EAST		
Impacts Total Transfer Capability		
TTC with All Lines In Service		

NYISO TRANSFER LIMITATIONS

Seasonal Limits — **Friday, October 2, 2026 to Saturday, April 1, 2028**

CENTRAL EAST	**7550 MW**
CENTRAL EAST - VC	**3725 MW**
TOTAL EAST	**7550 MW**
UPNY CONED	**8210 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3400 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

GRAHAM__-STA_255__345_GH1-43

Tue 02/10/2026 to Sat 11/21/2026
1122 Continuous 2100
Work scheduled by: NYISO

FORCED by NYISO 03/21/2026 14:33

	FWD (Import)	REV (Export)
DYSINGER EAST		
Impacts Total Transfer Capability		
TTC with All Lines In Service		

SCH-NYISO-HQ_CEDARS_LIMIT_0

Fri 04/17/2026 to Mon 11/30/2026
1900 Continuous 1700
Work scheduled by: HQ

EXT FORCED by HQ 09/23/2026 15:42

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS		**0 MW**
Impacts Total Transfer Capability		100 MW
TTC with All Lines In Service		100 MW

SCH-HQ_CEDARS-NYISO_LIMIT_220

Tue 04/21/2026 to Mon 11/30/2026
1900 Continuous 1700
Work scheduled by: HQ

EXT FORCED by HQ 09/23/2026 15:42

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS	**220 MW**	
Impacts Total Transfer Capability	50 MW	
TTC with All Lines In Service	270 MW	

BECK___-NIAGARA__230_PA27

Tue 09/15/2026 to Tue 11/17/2026
0500 Continuous 2330
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - OH - NY	**1900 MW**	
Impacts Total Transfer Capability	100 MW	
TTC with All Lines In Service	2000 MW	

HOMRC_NY-MAINS_NY_345_47

Tue 09/15/2026 to Fri 10/09/2026
0700 Continuous 1500
Work scheduled by: PJM

	FWD (Import)	REV (Export)
SCH - PJ - NY	**1700 MW**	**1050 MW**
Impacts Total Transfer Capability	400 MW	150 MW
TTC with All Lines In Service	2100 MW	1200 MW

FIVEMILE-LIMELAKE_345_49

Wed 09/16/2026 to Sat 10/10/2026
0700 Continuous 1600
Work scheduled by: NGrid

UPDATED by NGrid 05/07/2026 15:12

	FWD (Import)	REV (Export)
SCH - PJ - NY	**1950 MW**	**1050 MW**
Impacts Total Transfer Capability	150 MW	150 MW
TTC with All Lines In Service	2100 MW	1200 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits — **Friday, October 2, 2026 to Saturday, April 1, 2028**

CENTRAL EAST	**7550 MW**
CENTRAL EAST - VC	**3725 MW**
TOTAL EAST	**7550 MW**
UPNY CONED	**8210 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3400 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LIMELAKE-ESTOLERD_345_29

Wed 09/16/2026 to Sat 10/10/2026
0700 Continuous 1600
Work scheduled by: NGrid

UPDATED by NGrid 05/07/2026 15:12

	FWD (Import)	REV (Export)
SCH - PJ - NY	**1950 MW**	**1050 MW**
Impacts Total Transfer Capability	150 MW	150 MW
TTC with All Lines In Service	2100 MW	1200 MW

DUNWODIE_345KV_7

Wed 09/23/2026 to Wed 10/21/2026
0201 Continuous 0200
Work scheduled by: ConEd

UPDATED by ConEd 09/26/2026 09:41

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	**3800 MW**	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

DUNWODIE_345KV_8

Wed 09/23/2026 to Wed 10/21/2026
0201 Continuous 0200
Work scheduled by: ConEd

UPDATED by ConEd 09/26/2026 09:41

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	**3800 MW**	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

DUNWODIE-MOTTHAVN_345_72

Wed 09/23/2026 to Sat 11/07/2026
0201 Continuous 0159
Work scheduled by: ConEd

UPDATED by ConEd 09/26/2026 09:41

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	**3800 MW**	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

W49TH_ST_345KV_7

Wed 09/23/2026 to Fri 01/22/2027
0201 Continuous 0200
Work scheduled by: ConEd

EXTENDED by ConEd 09/23/2026 15:39

	FWD (Import)	REV (Export)
SCH - PJM_HTP	**300 MW**	
Impacts Total Transfer Capability	360 MW	
TTC with All Lines In Service	660 MW	

W49TH_ST_345KV_5

Thu 09/24/2026 to Wed 01/06/2027
0101 Continuous 0200
Work scheduled by: ConEd

UPDATED by ConEd 09/29/2026 14:03

	FWD (Import)	REV (Export)
SCH - PJM_HTP	**300 MW**	
Impacts Total Transfer Capability	360 MW	
TTC with All Lines In Service	660 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits — **Friday, October 2, 2026 to Saturday, April 1, 2028**

CENTRAL EAST	**7550 MW**
CENTRAL EAST - VC	**3725 MW**
TOTAL EAST	**7550 MW**
UPNY CONED	**8210 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3400 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FITZPTRK-EDIC____345_FE-1

Sun 09/27/2026 to Sun 10/04/2026
1201 Continuous 2159
Work scheduled by: NYPA

EXT FORCED by NYPA 10/02/2026 16:24

	FWD (Import)	REV (Export)
CENTRAL EAST - VC	**3520 MW**	
Impacts Total Transfer Capability	205 MW	
TTC with All Lines In Service	3725 MW	

FITZPTRK-EDIC____345_FE-1

Sun 09/27/2026 to Sun 10/04/2026
1201 Continuous 2159
Work scheduled by: NYPA

EXT FORCED by NYPA 10/02/2026 16:24

	FWD (Import)	REV (Export)
OSWEGO EXPORT	**5350 MW**	
Impacts Total Transfer Capability	250 MW	
TTC with All Lines In Service	5600 MW	

SCH-IMO-NYISO_LIMIT_1400

Mon 09/28/2026 to Fri 10/09/2026
0600 Continuous 1930
Work scheduled by: IESO

	FWD (Import)	REV (Export)
SCH - OH - NY	**1750 MW**	
Impacts Total Transfer Capability	250 MW	
TTC with All Lines In Service	2000 MW	

SCH-NYISO-IMO_LIMIT_1100

Mon 09/28/2026 to Fri 10/09/2026
0600 Continuous 1930
Work scheduled by: IESO

	FWD (Import)	REV (Export)
SCH - OH - NY		**1450 MW**
Impacts Total Transfer Capability		150 MW
TTC with All Lines In Service		1600 MW

STLAWRNC-MOSES___230_L33P

Mon 09/28/2026 to Fri 10/09/2026
0600 Continuous 1930
Work scheduled by: IESO

	FWD (Import)	REV (Export)
SCH - OH - NY		
Impacts Total Transfer Capability		
TTC with All Lines In Service		

CLAY___-EDIC____345_1-16

Mon 09/28/2026 to Fri 10/02/2026
0700 Continuous 1730
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
OSWEGO EXPORT	**5450 MW**	
Impacts Total Transfer Capability	150 MW	
TTC with All Lines In Service	5600 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits — **Friday, October 2, 2026 to Saturday, April 1, 2028**

CENTRAL EAST	**7550 MW**
CENTRAL EAST - VC	**3725 MW**
TOTAL EAST	**7550 MW**
UPNY CONED	**8210 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3400 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

LOVETT__-BUCHAN_S_345_Y88

Wed 09/30/2026 to Fri 10/02/2026
0001 Continuous 2300
Work scheduled by: ConEd

UPDATED by ORU 10/02/2026 08:53

	FWD (Import)	REV (Export)
UPNY CONED	**7960 MW**	
Impacts Total Transfer Capability	250 MW	
TTC with All Lines In Service	8210 MW	

RAMAPO__-BUCHAN_N_345_Y94

Wed 09/30/2026 to Wed 10/07/2026
0001 Continuous 0130
Work scheduled by: ConEd

UPDATED by ORU 10/02/2026 08:53

	FWD (Import)	REV (Export)
UPNY CONED	**7795 MW**	
Impacts Total Transfer Capability	415 MW	
TTC with All Lines In Service	8210 MW	

UNIONDHB_345_138_AT2

Wed 09/30/2026 to Thu 10/08/2026
0100 Continuous 2359
Work scheduled by: LI

UPDATED by LI 09/28/2026 09:51

	FWD (Import)	REV (Export)
CONED - LIPA	**1250 MW**	
Impacts Total Transfer Capability	250 MW	
TTC with All Lines In Service	1500 MW	

KNICRBKR-ALPS____345_6

Sat 10/03/2026 to Sat 10/03/2026
0630 Daily 1600
Work scheduled by: NGrid

UPDATED by ISONE 10/01/2026 14:28

	FWD (Import)	REV (Export)
SCH - NE - NY	**700 MW**	
Impacts Total Transfer Capability	700 MW	
TTC with All Lines In Service	1400 MW	

KNICRBKR-ALPS____345_6

Sat 10/03/2026 to Sat 10/03/2026
0630 Daily 1600
Work scheduled by: NGrid

UPDATED by ISONE 10/01/2026 14:28

	FWD (Import)	REV (Export)
SCH - NPX_1385	**100 MW**	**100 MW**
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

SCH-NYISO-NE_LIMIT_1100

Sat 10/03/2026 to Sat 10/03/2026
0630 Daily 0700
Work scheduled by: NGrid

UPDATED by ISONE 10/01/2026 14:28

	FWD (Import)	REV (Export)
SCH - NE - NY		**1300 MW**
Impacts Total Transfer Capability		300 MW
TTC with All Lines In Service		1600 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits — **Friday, October 2, 2026 to Saturday, April 1, 2028**

CENTRAL EAST	**7550 MW**
CENTRAL EAST - VC	**3725 MW**
TOTAL EAST	**7550 MW**
UPNY CONED	**8210 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3400 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-NE_LIMIT_800

Sat 10/03/2026 to Sat 10/03/2026
0700 Daily 1600
Work scheduled by: NGrid

UPDATED by ISONE 10/01/2026 14:28

	FWD (Import)	REV (Export)
SCH - NE - NY		**1000 MW**
Impacts Total Transfer Capability		600 MW
TTC with All Lines In Service		1600 MW

LADENTWN-LOVETT___345_Y66

Sun 10/04/2026 to Tue 10/06/2026
0001 Continuous 2300
Work scheduled by: ConEd

UPDATED by ORU 10/02/2026 08:53

	FWD (Import)	REV (Export)
UPNY CONED	**8095 MW**	
Impacts Total Transfer Capability	115 MW	
TTC with All Lines In Service	8210 MW	

SCH-NPX_1385-NYISO_LIMIT_50

Sun 10/04/2026 to Fri 10/09/2026
2030 Continuous 1600
Work scheduled by: ISONE

	FWD (Import)	REV (Export)
SCH - NPX_1385	**50 MW**	
Impacts Total Transfer Capability	150 MW	
TTC with All Lines In Service	200 MW	

SCH-NYISO-NPX_1385_LIMIT_50

Sun 10/04/2026 to Fri 10/09/2026
2030 Continuous 1600
Work scheduled by: ISONE

	FWD (Import)	REV (Export)
SCH - NPX_1385		**50 MW**
Impacts Total Transfer Capability		150 MW
TTC with All Lines In Service		200 MW

FITZPTRK-EDIC____345_FE-1

Sun 10/04/2026 to Sun 10/04/2026
2200 Continuous 2359
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
CENTRAL EAST - VC	**3520 MW**	
Impacts Total Transfer Capability	205 MW	
TTC with All Lines In Service	3725 MW	

FITZPTRK-EDIC____345_FE-1

Sun 10/04/2026 to Sun 10/04/2026
2200 Continuous 2359
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
OSWEGO EXPORT	**5350 MW**	
Impacts Total Transfer Capability	250 MW	
TTC with All Lines In Service	5600 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits — **Friday, October 2, 2026 to Saturday, April 1, 2028**

CENTRAL EAST	**7550 MW**
CENTRAL EAST - VC	**3725 MW**
TOTAL EAST	**7550 MW**
UPNY CONED	**8210 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3400 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CRICKVLY-PLSNTVLY_345_F84

Mon 10/05/2026 0300 to Wed 10/07/2026 0259
Continuous
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - NE - NY	**1350 MW**	
Impacts Total Transfer Capability	50 MW	
TTC with All Lines In Service	1400 MW	

CRICKVLY-PLSNTVLY_345_F84

Mon 10/05/2026 0300 to Wed 10/07/2026 0259
Continuous
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - NPX_1385	**100 MW**	**100 MW**
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

SCH-NYISO-HQ_LIMIT_0

Mon 10/05/2026 0400 to Tue 10/06/2026 0100
Continuous
Work scheduled by: HQ

UPDATED by HQ 10/02/2026 11:10

	FWD (Import)	REV (Export)
SCH - HQ - NY		**0 MW**
Impacts Total Transfer Capability		1000 MW
TTC with All Lines In Service		1000 MW

CLAY___-EDIC____345_2-15

Mon 10/05/2026 0700 to Fri 10/09/2026 1730
Continuous
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
OSWEGO EXPORT	**5450 MW**	
Impacts Total Transfer Capability	150 MW	
TTC with All Lines In Service	5600 MW	

SCH-NYISO-HQ_LIMIT_0

Tue 10/06/2026 0800 to Tue 10/06/2026 1700
Continuous
Work scheduled by: HQ

UPDATED by HQ 10/02/2026 11:10

	FWD (Import)	REV (Export)
SCH - HQ - NY		**0 MW**
Impacts Total Transfer Capability		1000 MW
TTC with All Lines In Service		1000 MW

SPRNBRK__345KV_RS4 , SPRNBRK__345KV_RS3

Wed 10/07/2026 0301 to Sat 10/10/2026 0259
Work scheduled by:

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	**3200 MW**	
Impacts Total Transfer Capability	1400 MW	
TTC with All Lines In Service	4600 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits — **Friday, October 2, 2026 to Saturday, April 1, 2028**

CENTRAL EAST	**7550 MW**
CENTRAL EAST - VC	**3725 MW**
TOTAL EAST	**7550 MW**
UPNY CONED	**8210 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3400 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SCH-NYISO-HQ_LIMIT_800

Wed 10/07/2026 to Sun 10/11/2026
0600 Continuous 1800
Work scheduled by: HQ

	FWD (Import)	REV (Export)
SCH - HQ - NY		**800 MW**
Impacts Total Transfer Capability		200 MW
TTC with All Lines In Service		1000 MW

SCH-IMO-NYISO_LIMIT_1550

Fri 10/09/2026 to Sun 10/18/2026
1931 Continuous 0630
Work scheduled by: IESO

UPDATED by IESO 10/02/2026 16:54

	FWD (Import)	REV (Export)
SCH - OH - NY	**1900 MW**	
Impacts Total Transfer Capability	100 MW	
TTC with All Lines In Service	2000 MW	

KNICRBKR-PLSNTVLY_345_Y57

Sat 10/10/2026 to Sat 10/24/2026
0001 Continuous 2100
Work scheduled by: NGrid

UPDATED by NGrid 09/23/2026 08:34

ARR: 78

	FWD (Import)	REV (Export)
UPNY CONED	**8045 MW**	
Impacts Total Transfer Capability	165 MW	
TTC with All Lines In Service	8210 MW	

HERTELHQ-ASTANNEX_345_G180

Mon 10/12/2026 to Fri 10/16/2026
0001 Continuous 1800
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - HQ_CHPE	**0 MW**	
Impacts Total Transfer Capability	1250 MW	
TTC with All Lines In Service	1250 MW	

NEPTUNE_-DUFFYAVE_345_NEPTUNE

Mon 10/12/2026 to Fri 10/16/2026
0600 Continuous 1600
Work scheduled by: LI

	FWD (Import)	REV (Export)
SCH - PJM_NEPTUNE	**0 MW**	
Impacts Total Transfer Capability	660 MW	
TTC with All Lines In Service	660 MW	

NEWBRDGE_345_138_BK_1

Mon 10/12/2026 to Fri 10/16/2026
0600 Continuous 1600
Work scheduled by: LI

	FWD (Import)	REV (Export)
SCH - PJM_NEPTUNE	**375 MW**	
Impacts Total Transfer Capability	285 MW	
TTC with All Lines In Service	660 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits — **Friday, October 2, 2026 to Saturday, April 1, 2028**

CENTRAL EAST	**7550 MW**
CENTRAL EAST - VC	**3725 MW**
TOTAL EAST	**7550 MW**
UPNY CONED	**8210 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3400 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEWBRDGE_345_138_BK_2

Mon 10/12/2026 to Fri 10/16/2026
0600 Continuous 1600
Work scheduled by: LI

	FWD (Import)	REV (Export)
SCH - PJM_NEPTUNE	**375 MW**	
Impacts Total Transfer Capability	285 MW	
TTC with All Lines In Service	660 MW	

NEWBRDGE-DUFFYAVE_345_501

Mon 10/12/2026 to Fri 10/16/2026
0600 Continuous 1600
Work scheduled by: LI

	FWD (Import)	REV (Export)
SCH - PJM_NEPTUNE	**0 MW**	
Impacts Total Transfer Capability	660 MW	
TTC with All Lines In Service	660 MW	

HOMR_NYW-PIERC_NY_345_48

Mon 10/12/2026 to Fri 10/16/2026
0800 Continuous 1500
Work scheduled by: NYSEG

UPDATED by PJM 06/03/2026 14:01

	FWD (Import)	REV (Export)
SCH - PJ - NY	**1950 MW**	**1050 MW**
Impacts Total Transfer Capability	150 MW	150 MW
TTC with All Lines In Service	2100 MW	1200 MW

SCH-HQ-NYISO_LIMIT_1100

Mon 10/12/2026 to Mon 11/30/2026
2200 Continuous 1600
Work scheduled by: HQ

	FWD (Import)	REV (Export)
SCH - HQ - NY	**1100 MW**	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	1500 MW	

CHATGUAY-MASSENA__765_7040

Tue 10/13/2026 to Fri 11/06/2026
0400 Continuous 1900
Work scheduled by: NYPA

UPDATED by HQ 08/13/2026 11:24

	FWD (Import)	REV (Export)
SCH - HQ - NY	**0 MW**	**0 MW**
Impacts Total Transfer Capability	1500 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

CHATGUAY-MASSENA__765_7040

Tue 10/13/2026 to Fri 11/06/2026
0400 Continuous 1900
Work scheduled by: NYPA

UPDATED by HQ 08/13/2026 11:24

	FWD (Import)	REV (Export)
MOSES SOUTH	**1750 MW**	
Impacts Total Transfer Capability	1650 MW	
TTC with All Lines In Service	3400 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits — **Friday, October 2, 2026 to Saturday, April 1, 2028**

CENTRAL EAST	**7550 MW**
CENTRAL EAST - VC	**3725 MW**
TOTAL EAST	**7550 MW**
UPNY CONED	**8210 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3400 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___765_345_AT1

Wed 10/14/2026 to Wed 10/28/2026
0001 Continuous 2359
Work scheduled by: NYPA

UPDATED by HQ 08/13/2026 11:24

ARR: 19

	FWD (Import)	REV (Export)
MOSES SOUTH	**1750 MW**	
Impacts Total Transfer Capability	1650 MW	
TTC with All Lines In Service	3400 MW	

MARCY___765_345_AT2

Wed 10/14/2026 to Wed 11/04/2026
0001 Continuous 1900
Work scheduled by: NYPA

UPDATED by HQ 08/13/2026 11:24

ARR: 19

	FWD (Import)	REV (Export)
MOSES SOUTH	**1700 MW**	
Impacts Total Transfer Capability	1700 MW	
TTC with All Lines In Service	3400 MW	

MASSENA_-MARCY___765_MSU1

Wed 10/14/2026 to Wed 10/28/2026
0001 Continuous 2359
Work scheduled by: NYPA

UPDATED by HQ 08/13/2026 11:24

	FWD (Import)	REV (Export)
SCH - HQ - NY	**475 MW**	**1000 MW**
Impacts Total Transfer Capability	1025 MW	0 MW
TTC with All Lines In Service	1500 MW	1000 MW

MASSENA_-MARCY___765_MSU1

Wed 10/14/2026 to Wed 10/28/2026
0001 Continuous 2359
Work scheduled by: NYPA

UPDATED by HQ 08/13/2026 11:24

	FWD (Import)	REV (Export)
CENTRAL EAST - VC	**2595 MW**	
Impacts Total Transfer Capability	1130 MW	
TTC with All Lines In Service	3725 MW	

MASSENA_-MARCY___765_MSU1

Wed 10/14/2026 to Wed 10/28/2026
0001 Continuous 2359
Work scheduled by: NYPA

UPDATED by HQ 08/13/2026 11:24

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS	**190 MW**	
Impacts Total Transfer Capability	80 MW	
TTC with All Lines In Service	270 MW	

MASSENA_-MARCY___765_MSU1

Wed 10/14/2026 to Wed 10/28/2026
0001 Continuous 2359
Work scheduled by: NYPA

UPDATED by HQ 08/13/2026 11:24

	FWD (Import)	REV (Export)
MOSES SOUTH	**500 MW**	
Impacts Total Transfer Capability	2900 MW	
TTC with All Lines In Service	3400 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits — **Friday, October 2, 2026 to Saturday, April 1, 2028**

CENTRAL EAST	**7550 MW**
CENTRAL EAST - VC	**3725 MW**
TOTAL EAST	**7550 MW**
UPNY CONED	**8210 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3400 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA_-MARCY___765_MSU1 , CHATGUAY-MASSENA__765_7040

Wed 10/14/2026 to Wed 10/28/2026
0001 2359
Work scheduled by:

	FWD (Import)	REV (Export)
MOSES SOUTH	**500 MW**	
Impacts Total Transfer Capability	2900 MW	
TTC with All Lines In Service	3400 MW	

MOSES__-MASSENA__230_MMS2 , MOSES__-MASSENA__230_MMS1

Wed 10/14/2026 to Wed 10/28/2026
0001 2359
Work scheduled by:

	FWD (Import)	REV (Export)
SCH - HQ - NY	**850 MW**	**0 MW**
Impacts Total Transfer Capability	650 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

MOSES__-MASSENA__230_MMS2 , MOSES__-MASSENA__230_MMS1

Wed 10/14/2026 to Wed 10/28/2026
0001 2359
Work scheduled by:

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS	**190 MW**	
Impacts Total Transfer Capability	80 MW	
TTC with All Lines In Service	270 MW	

INGHAM_C_115_115_PAR 2

Wed 10/14/2026 to Wed 10/14/2026
0830 Daily(No Weekends) 1059
Work scheduled by: NGrid

	FWD (Import)	REV (Export)
CENTRAL EAST - VC	**3605 MW**	
Impacts Total Transfer Capability	120 MW	
TTC with All Lines In Service	3725 MW	

INGHAM_C_115_115_PAR 2

Wed 10/14/2026 to Wed 10/14/2026
1130 Daily(No Weekends) 1400
Work scheduled by: NGrid

	FWD (Import)	REV (Export)
CENTRAL EAST - VC	**3605 MW**	
Impacts Total Transfer Capability	120 MW	
TTC with All Lines In Service	3725 MW	

NRTH1385-NOR HBR__138_601

Mon 10/19/2026 to Tue 10/20/2026
0600 Continuous 1500
Work scheduled by: LI

	FWD (Import)	REV (Export)
SCH - NPX_1385	**100 MW**	**100 MW**
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits **Friday, October 2, 2026 to Saturday, April 1, 2028**

CENTRAL EAST	**7550 MW**
CENTRAL EAST - VC	**3725 MW**
TOTAL EAST	**7550 MW**
UPNY CONED	**8210 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3400 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NRTH1385-NOR HBR__138_602

Mon 10/19/2026 to Tue 10/20/2026
0600 Continuous 1500
Work scheduled by: LI

	FWD (Import)	REV (Export)
SCH - NPX_1385	**100 MW**	**100 MW**
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

NRTH1385-NOR HBR__138_603

Mon 10/19/2026 to Tue 10/20/2026
0600 Continuous 1500
Work scheduled by: LI

	FWD (Import)	REV (Export)
SCH - NPX_1385	**100 MW**	**100 MW**
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

NRTH1385-NORHBR__138_601 , NRTH1385-NORHBR__138_602

Mon 10/19/2026 to Tue 10/20/2026
0600 1500
Work scheduled by:

	FWD (Import)	REV (Export)
SCH - NPX_1385	**0 MW**	**0 MW**
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

NRTH1385-NORHBR__138_601 , NRTH1385-NORHBR__138_603

Mon 10/19/2026 to Tue 10/20/2026
0600 1500
Work scheduled by:

	FWD (Import)	REV (Export)
SCH - NPX_1385	**0 MW**	**0 MW**
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

NRTH1385-NORHBR__138_602 , NRTH1385-NORHBR__138_603

Mon 10/19/2026 to Tue 10/20/2026
0600 1500
Work scheduled by:

	FWD (Import)	REV (Export)
SCH - NPX_1385	**0 MW**	**0 MW**
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

NRTH1385-NRTHPORT_138_NNC

Mon 10/19/2026 to Tue 10/20/2026
0600 Continuous 1500
Work scheduled by: LI

	FWD (Import)	REV (Export)
SCH - NPX_1385	**0 MW**	**0 MW**
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits — **Friday, October 2, 2026 to Saturday, April 1, 2028**

CENTRAL EAST	**7550 MW**
CENTRAL EAST - VC	**3725 MW**
TOTAL EAST	**7550 MW**
UPNY CONED	**8210 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3400 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SHOR_NPX-SHOREHAM_138_CSC

Mon 10/19/2026 to Sat 10/31/2026
0900 Continuous 1800
Work scheduled by: ISONE

	FWD (Import)	REV (Export)
SCH - NPX_CSC	**0 MW**	**0 MW**
Impacts Total Transfer Capability	330 MW	330 MW
TTC with All Lines In Service	330 MW	330 MW

PIERCBRK-FIVEMILE_345_37

Mon 10/19/2026 to Fri 11/06/2026
1200 Continuous 1600
Work scheduled by: PJM

CANCELLED by NYISO 09/29/2026 16:02

	FWD (Import)	REV (Export)
SCH - PJ - NY	**1800 MW**	**1050 MW**
Impacts Total Transfer Capability	300 MW	150 MW
TTC with All Lines In Service	2100 MW	1200 MW

ROSETON_-EFISHKIL_345_RFK305

Mon 10/26/2026 to Fri 11/06/2026
0001 Continuous 1559
Work scheduled by: NYPA

UPDATED by ConEd 07/23/2026 08:38

	FWD (Import)	REV (Export)
UPNY CONED	**7470 MW**	
Impacts Total Transfer Capability	740 MW	
TTC with All Lines In Service	8210 MW	

DYSINGER-STA_255__345_DH1

Tue 10/27/2026 to Sat 11/21/2026
0500 Continuous 2100
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
DYSINGER EAST	**2850 MW**	
Impacts Total Transfer Capability	350 MW	
TTC with All Lines In Service	3200 MW	

MILLWOOD-EASTVIEW_345_W82

Thu 10/29/2026 to Sat 11/07/2026
0300 Continuous 2300
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
UPNY CONED	**8015 MW**	
Impacts Total Transfer Capability	195 MW	
TTC with All Lines In Service	8210 MW	

SPRNBRK__345KV_RNS4

Thu 10/29/2026 to Thu 10/29/2026
0300 Continuous 0330
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	**3200 MW**	
Impacts Total Transfer Capability	1400 MW	
TTC with All Lines In Service	4600 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits — **Friday, October 2, 2026 to Saturday, April 1, 2028**

CENTRAL EAST	**7550 MW**
CENTRAL EAST - VC	**3725 MW**
TOTAL EAST	**7550 MW**
UPNY CONED	**8210 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3400 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

STLAWRNC-MOSES___230_L34P

Thu 10/29/2026 to Fri 11/13/2026
0700 Continuous 1930
Work scheduled by: IESO

	FWD (Import)	REV (Export)
SCH - OH - NY		
Impacts Total Transfer Capability		
TTC with All Lines In Service		

SPRNBRK__345KV_RNS4

Fri 10/30/2026 to Fri 10/30/2026
0300 Continuous 0330
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	**3200 MW**	
Impacts Total Transfer Capability	1400 MW	
TTC with All Lines In Service	4600 MW	

PANNELL_-CLAY____345_1

Mon 11/02/2026 to Fri 11/06/2026
0700 Continuous 1730
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
WEST CENTRAL	**1300 MW**	
Impacts Total Transfer Capability	950 MW	
TTC with All Lines In Service	2250 MW	

LINDN_CG-LNDVFT___345_V-3022

Mon 11/02/2026 to Sat 11/07/2026
0800 Continuous 1900
Work scheduled by: PJM

	FWD (Import)	REV (Export)
SCH - PJM_VFT	**0 MW**	**0 MW**
Impacts Total Transfer Capability	315 MW	315 MW
TTC with All Lines In Service	315 MW	315 MW

HOMRC_NY-MAINS_NY_345_47

Tue 11/03/2026 to Fri 11/06/2026
0800 Continuous 1700
Work scheduled by: PJM

	FWD (Import)	REV (Export)
SCH - PJ - NY	**2400 MW**	**2400 MW**
Impacts Total Transfer Capability	100 MW	250 MW
TTC with All Lines In Service	2500 MW	2650 MW

DUNWODIE_345KV_3

Wed 11/04/2026 to Sun 12/06/2026
0201 Continuous 0200
Work scheduled by: ConEd

UPDATED by ConEd 03/27/2026 13:56

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	**3800 MW**	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits — **Friday, October 2, 2026 to Saturday, April 1, 2028**

CENTRAL EAST	**7550 MW**
CENTRAL EAST - VC	**3725 MW**
TOTAL EAST	**7550 MW**
UPNY CONED	**8210 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3400 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_5

Wed 11/04/2026 to Sun 12/06/2026
0201 Continuous 0200
Work scheduled by: ConEd

UPDATED by ConEd 03/27/2026 13:56

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	**3800 MW**	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

DUNWODIE-MOTTHAVN_345_71

Wed 11/04/2026 to Tue 12/15/2026
0201 Continuous 0259
Work scheduled by: ConEd

UPDATED by ConEd 03/27/2026 13:56

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	**3800 MW**	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

VOLNEY__-MARCY___345_19

Wed 11/04/2026 to Thu 11/05/2026
0630 Continuous 1700
Work scheduled by: NGrid

ARR: 19

	FWD (Import)	REV (Export)
OSWEGO EXPORT	**5250 MW**	
Impacts Total Transfer Capability	350 MW	
TTC with All Lines In Service	5600 MW	

VOLNEY__-MARCY___345_19

Wed 11/04/2026 to Thu 11/05/2026
0630 Continuous 1700
Work scheduled by: NGrid

ARR: 19

	FWD (Import)	REV (Export)
CENTRAL EAST - VC	**3525 MW**	
Impacts Total Transfer Capability	200 MW	
TTC with All Lines In Service	3725 MW	

LEEDS___345_LEEDS SVC

Wed 11/04/2026 to Thu 11/05/2026
0800 Continuous 1500
Work scheduled by: NGrid

	FWD (Import)	REV (Export)
CENTRAL EAST - VC	**3675 MW**	
Impacts Total Transfer Capability	50 MW	
TTC with All Lines In Service	3725 MW	

ROSETON_-EFISHKIL_345_RFK305

Fri 11/06/2026 to Fri 11/13/2026
1600 Continuous 1600
Work scheduled by: CHGE

UPDATED by ConEd 06/05/2026 08:04

	FWD (Import)	REV (Export)
UPNY CONED	**7470 MW**	
Impacts Total Transfer Capability	740 MW	
TTC with All Lines In Service	8210 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits — **Friday, October 2, 2026 to Saturday, April 1, 2028**

CENTRAL EAST	**7550 MW**
CENTRAL EAST - VC	**3725 MW**
TOTAL EAST	**7550 MW**
UPNY CONED	**8210 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3400 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_7

Sat 11/07/2026 to Sat 11/07/2026
0130 Continuous 0159
Work scheduled by: ConEd

UPDATED by ConEd 09/26/2026 09:41

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	**3800 MW**	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

DUNWODIE_345KV_8

Sat 11/07/2026 to Sat 11/07/2026
0130 Continuous 0159
Work scheduled by: ConEd

UPDATED by ConEd 09/26/2026 09:41

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	**3800 MW**	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

DYSINGER-GRAHAM__345_DG1 , NIAGARA_-DYSINGER_345_ND1

Mon 11/09/2026 to Fri 11/13/2026
0600 1700
Work scheduled by:

	FWD (Import)	REV (Export)
DYSINGER EAST		
Impacts Total Transfer Capability		
TTC with All Lines In Service		

DYSINGER-STA_255__345_DH1 , NIAGARA_-DYSINGER_345_ND1

Mon 11/09/2026 to Fri 11/13/2026
0600 1700
Work scheduled by:

	FWD (Import)	REV (Export)
DYSINGER EAST	**2500 MW**	
Impacts Total Transfer Capability	700 MW	
TTC with All Lines In Service	3200 MW	

GRAHAM__-STA_255__345_GH1-43 , NIAGARA_-DYSINGER_345_ND1

Mon 11/09/2026 to Fri 11/13/2026
0600 1700
Work scheduled by:

	FWD (Import)	REV (Export)
DYSINGER EAST		
Impacts Total Transfer Capability		
TTC with All Lines In Service		

NIAGARA_-DYSINGER_345_ND1

Mon 11/09/2026 to Fri 11/13/2026
0600 Continuous 1700
Work scheduled by: NT

	FWD (Import)	REV (Export)
DYSINGER EAST	**2700 MW**	
Impacts Total Transfer Capability	500 MW	
TTC with All Lines In Service	3200 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits — **Friday, October 2, 2026 to Saturday, April 1, 2028**

CENTRAL EAST	**7550 MW**
CENTRAL EAST - VC	**3725 MW**
TOTAL EAST	**7550 MW**
UPNY CONED	**8210 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3400 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

FIVEMILE-LIMELAKE_345_49

Mon 11/09/2026 to Tue 12/22/2026
0700 Continuous 1700
Work scheduled by: NGrid

	FWD (Import)	REV (Export)
SCH - PJ - NY	**2400 MW**	**2300 MW**
Impacts Total Transfer Capability	100 MW	350 MW
TTC with All Lines In Service	2500 MW	2650 MW

LIMELAKE-ESTOLERD_345_29

Mon 11/09/2026 to Tue 12/22/2026
0700 Continuous 1700
Work scheduled by: NGrid

	FWD (Import)	REV (Export)
SCH - PJ - NY	**2400 MW**	**2300 MW**
Impacts Total Transfer Capability	100 MW	350 MW
TTC with All Lines In Service	2500 MW	2650 MW

OSWEGO__-VOLNEY__345_12

Tue 11/10/2026 to Thu 11/12/2026
0800 Continuous 1600
Work scheduled by: NGrid

	FWD (Import)	REV (Export)
OSWEGO EXPORT	**5550 MW**	
Impacts Total Transfer Capability	50 MW	
TTC with All Lines In Service	5600 MW	

NRTH1385-NOR HBR__138_601

Wed 11/11/2026 to Fri 11/20/2026
0800 Continuous 1000
Work scheduled by: ISONE

	FWD (Import)	REV (Export)
SCH - NPX_1385	**100 MW**	**100 MW**
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

CRICKVLY-PLSNTVLY_345_F83

Sat 11/14/2026 to Mon 11/16/2026
0001 Continuous 0259
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - NPX_1385	**100 MW**	**100 MW**
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

CRICKVLY-PLSNTVLY_345_F83

Sat 11/14/2026 to Mon 11/16/2026
0001 Continuous 0259
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - NE - NY	**1200 MW**	
Impacts Total Transfer Capability	200 MW	
TTC with All Lines In Service	1400 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits **Friday, October 2, 2026 to Saturday, April 1, 2028**

CENTRAL EAST	**7550 MW**
CENTRAL EAST - VC	**3725 MW**
TOTAL EAST	**7550 MW**
UPNY CONED	**8210 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3400 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NRTH1385-NORHBR__138_601 , CRICKVLY-PLSNTVLY_345_F83

Sat 11/14/2026 to Mon 11/16/2026
0001 0259
Work scheduled by:

	FWD (Import)	REV (Export)
SCH - NPX_1385	**0 MW**	**0 MW**
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

PANNELL_-CLAY____345_2

Mon 11/16/2026 to Fri 11/20/2026
0700 Continuous 1730
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
WEST CENTRAL	**1300 MW**	
Impacts Total Transfer Capability	950 MW	
TTC with All Lines In Service	2250 MW	

STLAWRNC-MOSES___230_L33P

Mon 11/16/2026 to Fri 11/20/2026
0700 Continuous 1630
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - OH - NY	**2300 MW**	
Impacts Total Transfer Capability	200 MW	
TTC with All Lines In Service	2500 MW	

BERKSHIR-ALPS____345_393

Tue 11/17/2026 to Thu 11/19/2026
0700 Continuous 1700
Work scheduled by: NGrid

ARR: 78

	FWD (Import)	REV (Export)
SCH - NPX_1385	**100 MW**	**100 MW**
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

BERKSHIR-ALPS____345_393

Tue 11/17/2026 to Thu 11/19/2026
0700 Continuous 1700
Work scheduled by: NGrid

ARR: 78

	FWD (Import)	REV (Export)
SCH - NE - NY	**1000 MW**	**1600 MW**
Impacts Total Transfer Capability	400 MW	200 MW
TTC with All Lines In Service	1400 MW	1800 MW

BERKSHIR-ALPS____345_393 , NRTH1385-NORHBR__138_601

Tue 11/17/2026 to Thu 11/19/2026
0700 1700
Work scheduled by:

ARR: 78

	FWD (Import)	REV (Export)
SCH - NPX_1385	**0 MW**	**0 MW**
Impacts Total Transfer Capability	200 MW	200 MW
TTC with All Lines In Service	200 MW	200 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits — **Friday, October 2, 2026 to Saturday, April 1, 2028**

CENTRAL EAST	**7550 MW**
CENTRAL EAST - VC	**3725 MW**
TOTAL EAST	**7550 MW**
UPNY CONED	**8210 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3400 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY-WOOD_ST__345_F30

Wed 11/18/2026 to Wed 11/18/2026
0001 Continuous 1830
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
UPNY CONED	**7780 MW**	
Impacts Total Transfer Capability	430 MW	
TTC with All Lines In Service	8210 MW	

DOVER___-CRICKVLY_345_Y17

Sat 11/21/2026 to Tue 11/24/2026
0830 Continuous 1600
Work scheduled by: ISONE

	FWD (Import)	REV (Export)
SCH - NE - NY	**800 MW**	**1200 MW**
Impacts Total Transfer Capability	600 MW	600 MW
TTC with All Lines In Service	1400 MW	1800 MW

DOVER___-CRICKVLY_345_Y17

Sat 11/21/2026 to Tue 11/24/2026
0830 Continuous 1600
Work scheduled by: ISONE

	FWD (Import)	REV (Export)
SCH - NPX_1385	**100 MW**	**100 MW**
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

LONG_MTN-DOVER___345_398

Sat 11/21/2026 to Tue 11/24/2026
0830 Continuous 1600
Work scheduled by: ISONE

	FWD (Import)	REV (Export)
SCH - NPX_1385	**100 MW**	**100 MW**
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

LONG_MTN-DOVER___345_398

Sat 11/21/2026 to Tue 11/24/2026
0830 Continuous 1600
Work scheduled by: ISONE

	FWD (Import)	REV (Export)
SCH - NE - NY	**800 MW**	**1200 MW**
Impacts Total Transfer Capability	600 MW	600 MW
TTC with All Lines In Service	1400 MW	1800 MW

BECK___-NIAGARA__230_PA27

Mon 11/23/2026 to Fri 11/27/2026
0630 Continuous 1600
Work scheduled by: IESO

	FWD (Import)	REV (Export)
SCH - OH - NY	**2050 MW**	
Impacts Total Transfer Capability	450 MW	
TTC with All Lines In Service	2500 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits **Friday, October 2, 2026 to Saturday, April 1, 2028**

CENTRAL EAST	**7550 MW**
CENTRAL EAST - VC	**3725 MW**
TOTAL EAST	**7550 MW**
UPNY CONED	**8210 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3400 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

EDIC___-GORDONRD_345_14

Tue 11/24/2026 to Tue 11/24/2026
0845 Daily(No Weekends) 0930
Work scheduled by: NGrid

	FWD (Import)	REV (Export)
CENTRAL EAST - VC	**2770 MW**	
Impacts Total Transfer Capability	955 MW	
TTC with All Lines In Service	3725 MW	

EDIC___-FRASER__345_EF24-40

Mon 11/30/2026 to Sun 12/06/2026
0700 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
CENTRAL EAST - VC	**3225 MW**	
Impacts Total Transfer Capability	500 MW	
TTC with All Lines In Service	3725 MW	

NRTH1385-NOR HBR__138_602

Mon 11/30/2026 to Tue 12/08/2026
0800 Continuous 1000
Work scheduled by: ISONE

	FWD (Import)	REV (Export)
SCH - NPX_1385	**100 MW**	**100 MW**
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

SAND_BAR-PLATSBRG_115_PV20

Mon 11/30/2026 to Fri 12/04/2026
0800 Continuous 1630
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - NE - NY		
Impacts Total Transfer Capability		
TTC with All Lines In Service		

SAND_BAR-PLATSBRG_115_PV20

Mon 11/30/2026 to Fri 12/04/2026
0800 Continuous 1630
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
CENTRAL EAST - VC	**3625 MW**	
Impacts Total Transfer Capability	100 MW	
TTC with All Lines In Service	3725 MW	

GORDONRD-ROTTRDAM_230_31

Thu 12/03/2026 to Thu 12/03/2026
0830 Daily(No Weekends) 1100
Work scheduled by: NGrid

	FWD (Import)	REV (Export)
CENTRAL EAST - VC	**3690 MW**	
Impacts Total Transfer Capability	35 MW	
TTC with All Lines In Service	3725 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits — **Friday, October 2, 2026 to Saturday, April 1, 2028**

CENTRAL EAST	**7550 MW**
CENTRAL EAST - VC	**3725 MW**
TOTAL EAST	**7550 MW**
UPNY CONED	**8210 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3400 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NRTH1385-NOR HBR__138_603

Thu 12/10/2026 to Sat 12/19/2026
0800 Continuous 1000
Work scheduled by: ISONE

	FWD (Import)	REV (Export)
SCH - NPX_1385	**100 MW**	**100 MW**
Impacts Total Transfer Capability	100 MW	100 MW
TTC with All Lines In Service	200 MW	200 MW

DUNWODIE_345KV_3

Sat 12/12/2026 to Mon 12/14/2026
0001 Continuous 0200
Work scheduled by: ConEd

UPDATED by ConEd 03/27/2026 13:56

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	**3800 MW**	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

DUNWODIE_345KV_5

Sat 12/12/2026 to Mon 12/14/2026
0001 Continuous 0200
Work scheduled by: ConEd

UPDATED by ConEd 03/27/2026 13:56

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	**3800 MW**	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

DUNWODIE_345KV_6

Tue 12/15/2026 to Tue 12/15/2026
0001 Continuous 0030
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	**3800 MW**	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

DUNWODIE_345KV_8

Tue 12/15/2026 to Tue 12/15/2026
0001 Continuous 0030
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	**3800 MW**	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

PLSNTVLY-EFISHKIL_345_F37

Tue 12/15/2026 to Thu 12/17/2026
0001 Continuous 0200
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
UPNY CONED	**8195 MW**	
Impacts Total Transfer Capability	15 MW	
TTC with All Lines In Service	8210 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits — **Friday, October 2, 2026 to Saturday, April 1, 2028**

CENTRAL EAST	**7550 MW**
CENTRAL EAST - VC	**3725 MW**
TOTAL EAST	**7550 MW**
UPNY CONED	**8210 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3400 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

WOOD_ST_-PLSNTVLE_345_Y87

Tue 12/15/2026 to Fri 01/22/2027
0001 Continuous 0200
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
UPNY CONED	**7795 MW**	
Impacts Total Transfer Capability	415 MW	
TTC with All Lines In Service	8210 MW	

DUNWODIE_345KV_3

Tue 12/15/2026 to Tue 12/15/2026
0230 Continuous 0259
Work scheduled by: ConEd

UPDATED by ConEd 03/27/2026 13:56

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	**3800 MW**	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

DUNWODIE_345KV_5

Tue 12/15/2026 to Tue 12/15/2026
0230 Continuous 0259
Work scheduled by: ConEd

UPDATED by ConEd 03/27/2026 13:56

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	**3800 MW**	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

DUNWODIE_345KV_6

Wed 12/16/2026 to Wed 12/16/2026
0130 Continuous 0200
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	**3800 MW**	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

DUNWODIE_345KV_8

Wed 12/16/2026 to Wed 12/16/2026
0130 Continuous 0200
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	**3800 MW**	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

STLAWRNC-MOSES___230_L34P

Fri 12/25/2026 to Fri 12/25/2026
0800 Continuous 1600
Work scheduled by: IESO

	FWD (Import)	REV (Export)
SCH - OH - NY	**2300 MW**	
Impacts Total Transfer Capability	200 MW	
TTC with All Lines In Service	2500 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits — **Friday, October 2, 2026 to Saturday, April 1, 2028**

CENTRAL EAST	**7550 MW**
CENTRAL EAST - VC	**3725 MW**
TOTAL EAST	**7550 MW**
UPNY CONED	**8210 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3400 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

HUDSONTP-W49TH_ST_345_Y56

Sat 12/26/2026 to Wed 01/06/2027
0001 Continuous 0200
Work scheduled by: ConEd

UPDATED by ConEd 09/29/2026 14:03

	FWD (Import)	REV (Export)
SCH - PJM_HTP	**0 MW**	
Impacts Total Transfer Capability	660 MW	
TTC with All Lines In Service	660 MW	

W49TH_ST_345KV_8

Sat 12/26/2026 to Wed 01/06/2027
0001 Continuous 0200
Work scheduled by: ConEd

UPDATED by ConEd 09/29/2026 14:03

	FWD (Import)	REV (Export)
SCH - PJM_HTP	**300 MW**	
Impacts Total Transfer Capability	360 MW	
TTC with All Lines In Service	660 MW	

MAINESBG-WATRCURE_345_30

Mon 12/28/2026 to Thu 12/31/2026
0600 Continuous 1800
Work scheduled by: NYSEG

	FWD (Import)	REV (Export)
SCH - PJ - NY	**1800 MW**	**2400 MW**
Impacts Total Transfer Capability	700 MW	250 MW
TTC with All Lines In Service	2500 MW	2650 MW

SPRNBRK__345KV_RNS4

Wed 12/30/2026 to Wed 12/30/2026
0001 Continuous 0030
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	**3200 MW**	
Impacts Total Transfer Capability	1400 MW	
TTC with All Lines In Service	4600 MW	

SPRNBRK_-W49TH_ST_345_M52

Wed 12/30/2026 to Sat 01/09/2027
0001 Continuous 0200
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	**3200 MW**	
Impacts Total Transfer Capability	1400 MW	
TTC with All Lines In Service	4600 MW	

W49TH_ST_345KV_5

Wed 12/30/2026 to Sat 01/09/2027
0001 Continuous 0200
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - PJM_HTP	**300 MW**	
Impacts Total Transfer Capability	360 MW	
TTC with All Lines In Service	660 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits — **Friday, October 2, 2026 to Saturday, April 1, 2028**

CENTRAL EAST	**7550 MW**
CENTRAL EAST - VC	**3725 MW**
TOTAL EAST	**7550 MW**
UPNY CONED	**8210 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3400 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBRK__345KV_RNS4

Sat 01/09/2027 to Sat 01/09/2027
0130 Continuous 0200
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	**3200 MW**	
Impacts Total Transfer Capability	1400 MW	
TTC with All Lines In Service	4600 MW	

PLSNTVLY-EFISHKIL_345_F37

Sun 01/10/2027 to Sat 01/16/2027
0001 Continuous 0200
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
UPNY CONED	**8195 MW**	
Impacts Total Transfer Capability	15 MW	
TTC with All Lines In Service	8210 MW	

SPRNBRK_-TREMONT__345_X28

Mon 01/11/2027 to Mon 01/11/2027
0001 Continuous 1800
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	**4200 MW**	
Impacts Total Transfer Capability	400 MW	
TTC with All Lines In Service	4600 MW	

W49TH_ST-E13THSTA_345_M54

Tue 01/12/2027 to Tue 01/12/2027
0001 Continuous 0030
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	**3800 MW**	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

DUNWODIE_345KV_6

Sun 01/17/2027 to Fri 01/22/2027
0001 Continuous 0200
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	**3800 MW**	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

DUNWODIE_345KV_8

Sun 01/17/2027 to Fri 01/22/2027
0001 Continuous 0200
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	**3800 MW**	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits — **Friday, October 2, 2026 to Saturday, April 1, 2028**

CENTRAL EAST	**7550 MW**
CENTRAL EAST - VC	**3725 MW**
TOTAL EAST	**7550 MW**
UPNY CONED	**8210 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3400 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

W49TH_ST-E13THSTA_345_M54

Mon 01/18/2027 to Mon 01/18/2027
0130 Continuous 0200
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	**3800 MW**	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

W49TH_ST_345KV_5

Tue 01/19/2027 to Fri 01/22/2027
2301 Continuous 0100
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - PJM_HTP	**300 MW**	
Impacts Total Transfer Capability	360 MW	
TTC with All Lines In Service	660 MW	

SPRNBRK__345KV_RS4 , SPRNBRK__345KV_RS3

Sat 01/30/2027 to Sat 01/30/2027
0001 2359
Work scheduled by:

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	**3800 MW**	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

SPRNBRK__345KV_RNS5

Sun 01/31/2027 to Wed 02/10/2027
0201 Continuous 0200
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	**3200 MW**	
Impacts Total Transfer Capability	1400 MW	
TTC with All Lines In Service	4600 MW	

SPRNBRK_-W49TH_ST_345_M51

Sun 01/31/2027 to Wed 02/10/2027
0201 Continuous 0200
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	**3200 MW**	
Impacts Total Transfer Capability	1400 MW	
TTC with All Lines In Service	4600 MW	

SCRIBA__-VOLNEY__345_20

Sat 02/20/2027 to Tue 04/20/2027
0700 Continuous 0900
Work scheduled by: NGrid

	FWD (Import)	REV (Export)
OSWEGO EXPORT	**5400 MW**	
Impacts Total Transfer Capability	200 MW	
TTC with All Lines In Service	5600 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits — **Friday, October 2, 2026 to Saturday, April 1, 2028**

CENTRAL EAST	**7550 MW**
CENTRAL EAST - VC	**3725 MW**
TOTAL EAST	**7550 MW**
UPNY CONED	**8210 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3400 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA_-ROBNSNRD_230_64

Mon 03/01/2027 to Fri 05/28/2027
0500 Continuous 2300
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - OH - NY		
Impacts Total Transfer Capability		
TTC with All Lines In Service		

AUSTINRD-ADIRNDCK_345_13

Mon 03/01/2027 to Thu 03/11/2027
0600 Continuous 1830
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
MOSES SOUTH	**2300 MW**	
Impacts Total Transfer Capability	1100 MW	
TTC with All Lines In Service	3400 MW	

HAVERSTK-ADIRNDCK_345_HA1

Mon 03/01/2027 to Thu 03/11/2027
0600 Continuous 1830
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
MOSES SOUTH	**2300 MW**	
Impacts Total Transfer Capability	1100 MW	
TTC with All Lines In Service	3400 MW	

SPRNBRK__345KV_RNS5

Thu 03/04/2027 to Sun 03/07/2027
0101 Continuous 0200
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	**3200 MW**	
Impacts Total Transfer Capability	1400 MW	
TTC with All Lines In Service	4600 MW	

SPRNBRK_-W49TH_ST_345_M51

Thu 03/04/2027 to Sun 03/07/2027
0101 Continuous 0200
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	**3200 MW**	
Impacts Total Transfer Capability	1400 MW	
TTC with All Lines In Service	4600 MW	

SPRNBRK__345KV_RS4 , SPRNBRK__345KV_RS3

Sun 03/07/2027 to Wed 03/10/2027
0001 0100
Work scheduled by:

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	**3800 MW**	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits — **Friday, October 2, 2026 to Saturday, April 1, 2028**

CENTRAL EAST	**7550 MW**
CENTRAL EAST - VC	**3725 MW**
TOTAL EAST	**7550 MW**
UPNY CONED	**8210 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3400 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MARCY___-EDIC____345_UE1-7

Tue 03/09/2027 to Wed 03/10/2027
0500 Continuous 1730
Work scheduled by: NYPA

ARR: 16 & 19

	FWD (Import)	REV (Export)
OSWEGO EXPORT	**5300 MW**	
Impacts Total Transfer Capability	300 MW	
TTC with All Lines In Service	5600 MW	

BUCHAN_S-MILLWOOD_345_W97

Sun 04/04/2027 to Wed 04/07/2027
0201 Continuous 0200
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
UPNY CONED	**8175 MW**	
Impacts Total Transfer Capability	35 MW	
TTC with All Lines In Service	8210 MW	

ROCHESTR-PANNELL__345_RP1

Mon 04/05/2027 to Fri 04/09/2027
0500 Continuous 1700
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
DYSINGER EAST	**2300 MW**	
Impacts Total Transfer Capability	900 MW	
TTC with All Lines In Service	3200 MW	

MARCY___345KV_CSC

Mon 04/05/2027 to Sat 04/17/2027
0700 Continuous 1730
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
CENTRAL EAST - VC	**3650 MW**	
Impacts Total Transfer Capability	75 MW	
TTC with All Lines In Service	3725 MW	

PRINCTWN-N.SCTLND_345_361

Tue 04/06/2027 to Thu 04/08/2027
0800 Continuous 1700
Work scheduled by: LS

	FWD (Import)	REV (Export)
CENTRAL EAST - VC	**3640 MW**	
Impacts Total Transfer Capability	85 MW	
TTC with All Lines In Service	3725 MW	

LINDN_CG-LNDVFT___345_V-3022

Sun 04/11/2027 to Sat 04/17/2027
1200 Continuous 1200
Work scheduled by: PJM

	FWD (Import)	REV (Export)
SCH - PJM_VFT	**0 MW**	**0 MW**
Impacts Total Transfer Capability	315 MW	315 MW
TTC with All Lines In Service	315 MW	315 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits — **Friday, October 2, 2026 to Saturday, April 1, 2028**

CENTRAL EAST	**7550 MW**
CENTRAL EAST - VC	**3725 MW**
TOTAL EAST	**7550 MW**
UPNY CONED	**8210 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3400 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

DUNWODIE_345KV_4

Mon 04/12/2027 to Sat 04/24/2027
0001 Continuous 0200
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	**3800 MW**	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

DUNWODIE_345KV_6

Mon 04/12/2027 to Sat 04/24/2027
0001 Continuous 0200
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	**3800 MW**	
Impacts Total Transfer Capability	800 MW	
TTC with All Lines In Service	4600 MW	

DUNWODIE-SHORE_RD_345_Y50

Mon 04/12/2027 to Sat 04/24/2027
0001 Continuous 0200
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
CONED - LIPA	**800 MW**	
Impacts Total Transfer Capability	700 MW	
TTC with All Lines In Service	1500 MW	

PLSNTVLY-WOOD_ST__345_F30

Mon 04/12/2027 to Sat 05/22/2027
0001 Continuous 0200
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
UPNY CONED	**7780 MW**	
Impacts Total Transfer Capability	430 MW	
TTC with All Lines In Service	8210 MW	

SHORE_RD_345_138_BK 1

Mon 04/12/2027 to Sat 04/24/2027
0001 Continuous 0200
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
CONED - LIPA	**1350 MW**	
Impacts Total Transfer Capability	150 MW	
TTC with All Lines In Service	1500 MW	

SHORE_RD_345_138_BK 2

Mon 04/12/2027 to Sat 04/24/2027
0001 Continuous 0200
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
CONED - LIPA	**1350 MW**	
Impacts Total Transfer Capability	150 MW	
TTC with All Lines In Service	1500 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits — **Friday, October 2, 2026 to Saturday, April 1, 2028**

CENTRAL EAST	**7550 MW**
CENTRAL EAST - VC	**3725 MW**
TOTAL EAST	**7550 MW**
UPNY CONED	**8210 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3400 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NIAGARA__345_230_AT4

Mon 04/12/2027 to Fri 04/30/2027
0500 Continuous 2300
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - OH - NY	**2250 MW**	**1550 MW**
Impacts Total Transfer Capability	250 MW	300 MW
TTC with All Lines In Service	2500 MW	1850 MW

ROCHESTR-PANNELL__345_RP2

Mon 04/12/2027 to Fri 04/16/2027
0500 Continuous 1700
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
DYSINGER EAST	**2300 MW**	
Impacts Total Transfer Capability	900 MW	
TTC with All Lines In Service	3200 MW	

PRINCTWN-N.SCTLND_345_362

Tue 04/13/2027 to Thu 04/15/2027
0800 Continuous 1700
Work scheduled by: LS

	FWD (Import)	REV (Export)
CENTRAL EAST - VC	**3640 MW**	
Impacts Total Transfer Capability	85 MW	
TTC with All Lines In Service	3725 MW	

PANNELL_-CLAY____345_1

Mon 04/19/2027 to Fri 04/23/2027
0700 Continuous 1730
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
WEST CENTRAL	**1300 MW**	
Impacts Total Transfer Capability	950 MW	
TTC with All Lines In Service	2250 MW	

PRINCTWN-N.SCTLND_345_55

Tue 04/20/2027 to Thu 04/22/2027
0800 Continuous 1700
Work scheduled by: LS

	FWD (Import)	REV (Export)
CENTRAL EAST - VC	**3645 MW**	
Impacts Total Transfer Capability	80 MW	
TTC with All Lines In Service	3725 MW	

MARCY___-FRASANNX_345_UCC2-41

Mon 04/26/2027 to Sun 05/16/2027
0700 Continuous 1730
Work scheduled by: NYPA

ARR: 19

	FWD (Import)	REV (Export)
CENTRAL EAST - VC	**3225 MW**	
Impacts Total Transfer Capability	500 MW	
TTC with All Lines In Service	3725 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits — **Friday, October 2, 2026 to Saturday, April 1, 2028**

CENTRAL EAST	**7550 MW**
CENTRAL EAST - VC	**3725 MW**
TOTAL EAST	**7550 MW**
UPNY CONED	**8210 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3400 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PANNELL_-CLAY____345_2

Mon 04/26/2027 to Fri 04/30/2027
0700 Continuous 1730
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
WEST CENTRAL	**1300 MW**	
Impacts Total Transfer Capability	950 MW	
TTC with All Lines In Service	2250 MW	

EDIC___-PRINCTWN_345_351

Tue 04/27/2027 to Thu 04/29/2027
0800 Continuous 1700
Work scheduled by: LS

	FWD (Import)	REV (Export)
CENTRAL EAST - VC	**3335 MW**	
Impacts Total Transfer Capability	390 MW	
TTC with All Lines In Service	3725 MW	

HAVERSTK-ADIRNDCK_345_HA2

Mon 05/03/2027 to Wed 05/05/2027
0600 Continuous 1630
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
MOSES SOUTH	**2100 MW**	
Impacts Total Transfer Capability	1300 MW	
TTC with All Lines In Service	3400 MW	

EDIC___-PRINCTWN_345_352

Tue 05/04/2027 to Thu 05/06/2027
0800 Continuous 1700
Work scheduled by: LS

	FWD (Import)	REV (Export)
CENTRAL EAST - VC	**3335 MW**	
Impacts Total Transfer Capability	390 MW	
TTC with All Lines In Service	3725 MW	

AUSTINRD-ADIRNDCK_345_13

Thu 05/06/2027 to Fri 05/07/2027
0600 Continuous 1630
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
MOSES SOUTH	**2100 MW**	
Impacts Total Transfer Capability	1300 MW	
TTC with All Lines In Service	3400 MW	

NEPTUNE_-DUFFYAVE_345_NEPTUNE

Mon 05/10/2027 to Fri 05/14/2027
0600 Continuous 1600
Work scheduled by: LI

	FWD (Import)	REV (Export)
SCH - PJM_NEPTUNE	**0 MW**	
Impacts Total Transfer Capability	660 MW	
TTC with All Lines In Service	660 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits — **Friday, October 2, 2026 to Saturday, April 1, 2028**

CENTRAL EAST	**7550 MW**
CENTRAL EAST - VC	**3725 MW**
TOTAL EAST	**7550 MW**
UPNY CONED	**8210 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3400 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

NEWBRDGE_345_138_BK_1

Mon 05/10/2027 to Fri 05/14/2027
0600 Continuous 1600
Work scheduled by: LI

	FWD (Import)	REV (Export)
SCH - PJM_NEPTUNE	**375 MW**	
Impacts Total Transfer Capability	285 MW	
TTC with All Lines In Service	660 MW	

NEWBRDGE_345_138_BK_2

Mon 05/10/2027 to Fri 05/14/2027
0600 Continuous 1600
Work scheduled by: LI

	FWD (Import)	REV (Export)
SCH - PJM_NEPTUNE	**375 MW**	
Impacts Total Transfer Capability	285 MW	
TTC with All Lines In Service	660 MW	

NEWBRDGE-DUFFYAVE_345_501

Mon 05/10/2027 to Fri 05/14/2027
0600 Continuous 1600
Work scheduled by: LI

	FWD (Import)	REV (Export)
SCH - PJM_NEPTUNE	**0 MW**	
Impacts Total Transfer Capability	660 MW	
TTC with All Lines In Service	660 MW	

DYSINGER-GRAHAM__345_DG1

Thu 05/13/2027 to Mon 05/24/2027
0500 Continuous 2330
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
DYSINGER EAST		
Impacts Total Transfer Capability		
TTC with All Lines In Service		

SPRNBRK__345KV_RNS5

Sat 05/15/2027 to Sat 05/15/2027
0201 Continuous 0230
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	**3200 MW**	
Impacts Total Transfer Capability	1400 MW	
TTC with All Lines In Service	4600 MW	

SPRNBRK_-W49TH_ST_345_M51

Sat 05/15/2027 to Tue 06/01/2027
0201 Continuous 0200
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	**3200 MW**	
Impacts Total Transfer Capability	1400 MW	
TTC with All Lines In Service	4600 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits — **Friday, October 2, 2026 to Saturday, April 1, 2028**

CENTRAL EAST	**7550 MW**
CENTRAL EAST - VC	**3725 MW**
TOTAL EAST	**7550 MW**
UPNY CONED	**8210 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3400 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

CHATGUAY-MASSENA__765_7040

Mon 05/24/2027 to Sat 05/29/2027
0001 Continuous 0130
Work scheduled by: NYPA

UPDATED by NYPA 06/05/2026 15:18

	FWD (Import)	REV (Export)
SCH - HQ - NY	**0 MW**	**0 MW**
Impacts Total Transfer Capability	1500 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

CHATGUAY-MASSENA__765_7040

Mon 05/24/2027 to Sat 05/29/2027
0001 Continuous 0130
Work scheduled by: NYPA

UPDATED by NYPA 06/05/2026 15:18

	FWD (Import)	REV (Export)
MOSES SOUTH	**1750 MW**	
Impacts Total Transfer Capability	1650 MW	
TTC with All Lines In Service	3400 MW	

MARCY___765_345_AT1

Mon 05/24/2027 to Sat 05/29/2027
0001 Continuous 0130
Work scheduled by: NYPA

UPDATED by NYPA 06/05/2026 15:18

ARR: 19

	FWD (Import)	REV (Export)
MOSES SOUTH	**1750 MW**	
Impacts Total Transfer Capability	1650 MW	
TTC with All Lines In Service	3400 MW	

MARCY___765_345_AT2

Mon 05/24/2027 to Sat 05/29/2027
0001 Continuous 0130
Work scheduled by: NYPA

UPDATED by NYPA 06/05/2026 15:18

ARR: 19

	FWD (Import)	REV (Export)
MOSES SOUTH	**1700 MW**	
Impacts Total Transfer Capability	1700 MW	
TTC with All Lines In Service	3400 MW	

MASSENA_-MARCY___765_MSU1

Mon 05/24/2027 to Sat 05/29/2027
0001 Continuous 0130
Work scheduled by: NYPA

UPDATED by NYPA 06/05/2026 15:18

	FWD (Import)	REV (Export)
SCH - HQ - NY	**475 MW**	**1000 MW**
Impacts Total Transfer Capability	1025 MW	0 MW
TTC with All Lines In Service	1500 MW	1000 MW

MASSENA_-MARCY___765_MSU1

Mon 05/24/2027 to Sat 05/29/2027
0001 Continuous 0130
Work scheduled by: NYPA

UPDATED by NYPA 06/05/2026 15:18

	FWD (Import)	REV (Export)
CENTRAL EAST - VC	**2595 MW**	
Impacts Total Transfer Capability	1130 MW	
TTC with All Lines In Service	3725 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits — **Friday, October 2, 2026 to Saturday, April 1, 2028**

CENTRAL EAST	**7550 MW**
CENTRAL EAST - VC	**3725 MW**
TOTAL EAST	**7550 MW**
UPNY CONED	**8210 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3400 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

MASSENA_-MARCY___765_MSU1

Mon 05/24/2027 to Sat 05/29/2027
0001 Continuous 0130
Work scheduled by: NYPA

UPDATED by NYPA 06/05/2026 15:18

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS	**190 MW**	
Impacts Total Transfer Capability	80 MW	
TTC with All Lines In Service	270 MW	

MASSENA_-MARCY___765_MSU1

Mon 05/24/2027 to Sat 05/29/2027
0001 Continuous 0130
Work scheduled by: NYPA

UPDATED by NYPA 06/05/2026 15:18

	FWD (Import)	REV (Export)
MOSES SOUTH	**500 MW**	
Impacts Total Transfer Capability	2900 MW	
TTC with All Lines In Service	3400 MW	

MASSENA_-MARCY___765_MSU1 , CHATGUAY-MASSENA__765_7040

Mon 05/24/2027 to Sat 05/29/2027
0001 0130
Work scheduled by:

	FWD (Import)	REV (Export)
MOSES SOUTH	**500 MW**	
Impacts Total Transfer Capability	2900 MW	
TTC with All Lines In Service	3400 MW	

MOSES___-MASSENA__230_MMS2 , MOSES___-MASSENA__230_MMS1

Mon 05/24/2027 to Sat 05/29/2027
0001 0130
Work scheduled by:

	FWD (Import)	REV (Export)
SCH - HQ - NY	**850 MW**	**0 MW**
Impacts Total Transfer Capability	650 MW	1000 MW
TTC with All Lines In Service	1500 MW	1000 MW

MOSES___-MASSENA__230_MMS2 , MOSES___-MASSENA__230_MMS1

Mon 05/24/2027 to Sat 05/29/2027
0001 0130
Work scheduled by:

	FWD (Import)	REV (Export)
SCH - HQ_CEDARS	**190 MW**	
Impacts Total Transfer Capability	80 MW	
TTC with All Lines In Service	270 MW	

SPRNBRK__345KV_RNS5

Sat 05/29/2027 to Mon 05/31/2027
0001 Continuous 0100
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	**3200 MW**	
Impacts Total Transfer Capability	1400 MW	
TTC with All Lines In Service	4600 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits — **Friday, October 2, 2026 to Saturday, April 1, 2028**

CENTRAL EAST	**7550 MW**
CENTRAL EAST - VC	**3725 MW**
TOTAL EAST	**7550 MW**
UPNY CONED	**8210 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3400 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBRK__345KV_RNS5

Tue 06/01/2027 to Tue 06/01/2027
0130 Continuous 0200
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	**3200 MW**	
Impacts Total Transfer Capability	1400 MW	
TTC with All Lines In Service	4600 MW	

MARION__-FARRAGUT_345_C3403

Mon 06/07/2027 to Thu 06/10/2027
0001 Continuous 2200
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - PJ - NY		
Impacts Total Transfer Capability		
TTC with All Lines In Service		

GORDONRD-PRINCTWN_345_371

Tue 06/08/2027 to Thu 06/10/2027
0800 Continuous 1700
Work scheduled by: LS

	FWD (Import)	REV (Export)
CENTRAL EAST - VC	**3405 MW**	
Impacts Total Transfer Capability	320 MW	
TTC with All Lines In Service	3725 MW	

NIAGARA_-PACKARD__230_61

Fri 09/10/2027 to Fri 09/10/2027
0500 Continuous 2300
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - OH - NY	**1900 MW**	**1450 MW**
Impacts Total Transfer Capability	100 MW	150 MW
TTC with All Lines In Service	2000 MW	1600 MW

PANNELL_-CLAY____345_1

Mon 09/13/2027 to Fri 09/17/2027
0700 Continuous 1730
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
WEST CENTRAL	**1300 MW**	
Impacts Total Transfer Capability	950 MW	
TTC with All Lines In Service	2250 MW	

NIAGARA_-PACKARD__230_62

Wed 09/15/2027 to Tue 11/30/2027
0500 Continuous 2300
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - OH - NY	**1650 MW**	**1550 MW**
Impacts Total Transfer Capability	350 MW	50 MW
TTC with All Lines In Service	2000 MW	1600 MW

NYISO TRANSFER LIMITATIONS

Seasonal Limits — **Friday, October 2, 2026 to Saturday, April 1, 2028**

CENTRAL EAST	**7550 MW**
CENTRAL EAST - VC	**3725 MW**
TOTAL EAST	**7550 MW**
UPNY CONED	**8210 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3400 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

INGHAM_C_115_115_PAR 2

Fri 09/17/2027 to Fri 10/29/2027
0600 Continuous 1600
Work scheduled by: NGrid

	FWD (Import)	REV (Export)
CENTRAL EAST - VC	**3605 MW**	
Impacts Total Transfer Capability	120 MW	
TTC with All Lines In Service	3725 MW	

MARCY___-FRASANNX_345_UCC2-41

Sat 09/18/2027 to Sat 10/30/2027
0700 Continuous 1730
Work scheduled by: NYPA

ARR: 19

	FWD (Import)	REV (Export)
CENTRAL EAST - VC	**3225 MW**	
Impacts Total Transfer Capability	500 MW	
TTC with All Lines In Service	3725 MW	

BUCHAN_S-MILLWOOD_345_W97

Mon 09/20/2027 to Mon 09/20/2027
0001 Continuous 0030
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
UPNY CONED	**8175 MW**	
Impacts Total Transfer Capability	35 MW	
TTC with All Lines In Service	8210 MW	

PANNELL_-CLAY____345_2

Mon 09/20/2027 to Fri 09/24/2027
0700 Continuous 1730
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
WEST CENTRAL	**1300 MW**	
Impacts Total Transfer Capability	950 MW	
TTC with All Lines In Service	2250 MW	

BUCHAN_S-MILLWOOD_345_W97

Tue 09/21/2027 to Tue 09/21/2027
0130 Continuous 0200
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
UPNY CONED	**8175 MW**	
Impacts Total Transfer Capability	35 MW	
TTC with All Lines In Service	8210 MW	

CLAY___-EDIC____345_1-16

Mon 09/27/2027 to Fri 10/01/2027
0700 Continuous 1730
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
OSWEGO EXPORT	**5450 MW**	
Impacts Total Transfer Capability	150 MW	
TTC with All Lines In Service	5600 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits — **Friday, October 2, 2026 to Saturday, April 1, 2028**

CENTRAL EAST	**7550 MW**
CENTRAL EAST - VC	**3725 MW**
TOTAL EAST	**7550 MW**
UPNY CONED	**8210 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3400 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SAND_BAR-PLATSBRG_115_PV20

Mon 09/27/2027 to Fri 10/01/2027
0800 Continuous 1630
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
SCH - NE - NY		
Impacts Total Transfer Capability		
TTC with All Lines In Service		

SAND_BAR-PLATSBRG_115_PV20

Mon 09/27/2027 to Fri 10/01/2027
0800 Continuous 1630
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
CENTRAL EAST - VC	**3625 MW**	
Impacts Total Transfer Capability	100 MW	
TTC with All Lines In Service	3725 MW	

WOOD_ST_-PLSNTVLE_345_Y87

Mon 10/04/2027 to Sat 10/16/2027
0001 Continuous 0200
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
UPNY CONED	**7795 MW**	
Impacts Total Transfer Capability	415 MW	
TTC with All Lines In Service	8210 MW	

CLAY___-EDIC____345_2-15

Mon 10/04/2027 to Fri 10/08/2027
0700 Continuous 1730
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
OSWEGO EXPORT	**5450 MW**	
Impacts Total Transfer Capability	150 MW	
TTC with All Lines In Service	5600 MW	

SPRNBRK_-UNIONHBS_345_Y49

Mon 10/04/2027 to Fri 05/26/2028
0800 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
CONED - LIPA	**775 MW**	
Impacts Total Transfer Capability	725 MW	
TTC with All Lines In Service	1500 MW	

UNIONDHB_345_138_AT1

Mon 10/04/2027 to Fri 05/26/2028
0800 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
CONED - LIPA	**1250 MW**	
Impacts Total Transfer Capability	250 MW	
TTC with All Lines In Service	1500 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits — **Friday, October 2, 2026 to Saturday, April 1, 2028**

CENTRAL EAST	**7550 MW**
CENTRAL EAST - VC	**3725 MW**
TOTAL EAST	**7550 MW**
UPNY CONED	**8210 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3400 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

UNIONDHB_345_138_AT2

Mon 10/04/2027 to Fri 05/26/2028
0800 Continuous 1530
Work scheduled by: NYPA

	FWD (Import)	REV (Export)
CONED - LIPA	**1250 MW**	
Impacts Total Transfer Capability	250 MW	
TTC with All Lines In Service	1500 MW	

NEPTUNE_-DUFFYAVE_345_NEPTUNE

Mon 10/11/2027 to Thu 10/14/2027
0600 Continuous 1600
Work scheduled by: LI

	FWD (Import)	REV (Export)
SCH - PJM_NEPTUNE	**0 MW**	
Impacts Total Transfer Capability	660 MW	
TTC with All Lines In Service	660 MW	

NEWBRDGE_345_138_BK_1

Mon 10/11/2027 to Thu 10/14/2027
0600 Continuous 1600
Work scheduled by: LI

	FWD (Import)	REV (Export)
SCH - PJM_NEPTUNE	**375 MW**	
Impacts Total Transfer Capability	285 MW	
TTC with All Lines In Service	660 MW	

NEWBRDGE_345_138_BK_2

Mon 10/11/2027 to Thu 10/14/2027
0600 Continuous 1600
Work scheduled by: LI

	FWD (Import)	REV (Export)
SCH - PJM_NEPTUNE	**375 MW**	
Impacts Total Transfer Capability	285 MW	
TTC with All Lines In Service	660 MW	

NEWBRDGE-DUFFYAVE_345_501

Mon 10/11/2027 to Thu 10/14/2027
0600 Continuous 1600
Work scheduled by: LI

	FWD (Import)	REV (Export)
SCH - PJM_NEPTUNE	**0 MW**	
Impacts Total Transfer Capability	660 MW	
TTC with All Lines In Service	660 MW	

BUCHAN_S-MILLWOOD_345_W97

Sun 10/24/2027 to Wed 10/27/2027
0001 Continuous 0200
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
UPNY CONED	**8175 MW**	
Impacts Total Transfer Capability	35 MW	
TTC with All Lines In Service	8210 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits — **Friday, October 2, 2026 to Saturday, April 1, 2028**

CENTRAL EAST	**7550 MW**
CENTRAL EAST - VC	**3725 MW**
TOTAL EAST	**7550 MW**
UPNY CONED	**8210 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3400 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

SPRNBRK__345KV_RNS4

Wed 12/01/2027 to Wed 12/01/2027
0001 Continuous 0030
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	**3200 MW**	
Impacts Total Transfer Capability	1400 MW	
TTC with All Lines In Service	4600 MW	

SPRNBRK_-W49TH_ST_345_M52

Wed 12/01/2027 to Wed 12/15/2027
0001 Continuous 0200
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	**3200 MW**	
Impacts Total Transfer Capability	1400 MW	
TTC with All Lines In Service	4600 MW	

W49TH_ST_345KV_5

Wed 12/01/2027 to Wed 12/15/2027
0001 Continuous 0200
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - PJM_HTP	**300 MW**	
Impacts Total Transfer Capability	360 MW	
TTC with All Lines In Service	660 MW	

SPRNBRK__345KV_RNS4

Wed 12/15/2027 to Wed 12/15/2027
0130 Continuous 0200
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	**3200 MW**	
Impacts Total Transfer Capability	1400 MW	
TTC with All Lines In Service	4600 MW	

W49TH_ST_345KV_5

Wed 12/15/2027 to Tue 02/22/2028
0201 Continuous 0200
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - PJM_HTP	**300 MW**	
Impacts Total Transfer Capability	360 MW	
TTC with All Lines In Service	660 MW	

W49TH_ST_345KV_7

Wed 12/15/2027 to Tue 02/22/2028
0201 Continuous 0200
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - PJM_HTP	**300 MW**	
Impacts Total Transfer Capability	360 MW	
TTC with All Lines In Service	660 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits — **Friday, October 2, 2026 to Saturday, April 1, 2028**

CENTRAL EAST	**7550 MW**
CENTRAL EAST - VC	**3725 MW**
TOTAL EAST	**7550 MW**
UPNY CONED	**8210 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3400 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

PLSNTVLY-WOOD_ST__345_F30

Thu 02/03/2028 to Sun 02/13/2028
0001 Continuous 2200
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
UPNY CONED	**7780 MW**	
Impacts Total Transfer Capability	430 MW	
TTC with All Lines In Service	8210 MW	

SPRNBRK__345KV_RNS4

Tue 02/22/2028 to Tue 02/22/2028
0201 Continuous 0231
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	**3200 MW**	
Impacts Total Transfer Capability	1400 MW	
TTC with All Lines In Service	4600 MW	

SPRNBRK_-W49TH_ST_345_M52

Tue 02/22/2028 to Fri 04/07/2028
0201 Continuous 0200
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SPR/DUN-SOUTH	**3200 MW**	
Impacts Total Transfer Capability	1400 MW	
TTC with All Lines In Service	4600 MW	

W49TH_ST_345KV_5

Tue 02/22/2028 to Fri 04/07/2028
0201 Continuous 0200
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
SCH - PJM_HTP	**300 MW**	
Impacts Total Transfer Capability	360 MW	
TTC with All Lines In Service	660 MW	

PLSNTVLY-WOOD_ST__345_F30

Mon 03/06/2028 to Thu 03/09/2028
0001 Continuous 2200
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
UPNY CONED	**7780 MW**	
Impacts Total Transfer Capability	430 MW	
TTC with All Lines In Service	8210 MW	

PLSNTVLY-EFISHKIL_345_F37

Tue 03/14/2028 to Wed 04/19/2028
0001 Continuous 0200
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
UPNY CONED	**8195 MW**	
Impacts Total Transfer Capability	15 MW	
TTC with All Lines In Service	8210 MW	

NYISO TRANSFER LIMITATIONS

Seasonal Limits — **Friday, October 2, 2026 to Saturday, April 1, 2028**

CENTRAL EAST	**7550 MW**
CENTRAL EAST - VC	**3725 MW**
TOTAL EAST	**7550 MW**
UPNY CONED	**8210 MW**
SPR/DUN-SOUTH	**4600 MW**
DYSINGER EAST	**3200 MW**
MOSES SOUTH	**3400 MW**

The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.

WOOD_ST_-PLSNTVLE_345_Y87

Tue 03/14/2028 to Tue 03/14/2028
0001 Continuous 0030
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
UPNY CONED	**7795 MW**	
Impacts Total Transfer Capability	415 MW	
TTC with All Lines In Service	8210 MW	

WOOD_ST_-PLSNTVLE_345_Y87

Thu 03/16/2028 to Thu 03/16/2028
0130 Continuous 0200
Work scheduled by: ConEd

	FWD (Import)	REV (Export)
UPNY CONED	**7795 MW**	
Impacts Total Transfer Capability	415 MW	
TTC with All Lines In Service	8210 MW	