# NYISO TRANSFER LIMITATIONS

**Seasonal Limits** — **Tuesday, October 13, 2026 to Wednesday, April 12, 2028**

| | |
|---|---|
| **CENTRAL EAST** | **7550 MW** |
| **CENTRAL EAST - VC** | **3725 MW** |
| **TOTAL EAST** | **7550 MW** |
| **UPNY CONED** | **8210 MW** |
| **SPR/DUN-SOUTH** | **4600 MW** |
| **DYSINGER EAST** | **3200 MW** |
| **MOSES SOUTH** | **3400 MW** |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

---

**HUDSONP_-FARRAGUT_345_B3402**

Mon 01/15/2018 to Mon 02/01/2027
0001 Continuous 2359
Work scheduled by: ConEd

EXT FORCED by ConEd 06/25/2026 13:42

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - PJ - NY | | |
| Impacts Total Transfer Capability | | |
| TTC with All Lines In Service | | |

---

**MARION__-FARRAGUT_345_C3403**

Mon 01/15/2018 to Mon 02/01/2027
0001 Continuous 2359
Work scheduled by: ConEd

EXT FORCED by ConEd 06/25/2026 13:42

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - PJ - NY | | |
| Impacts Total Transfer Capability | | |
| TTC with All Lines In Service | | |

---

**MARION__-FARRAGUT_345_C3403 , HUDSONP_-FARRAGUT_345_B3402**

Mon 01/15/2018 to Mon 02/01/2027
0001 2359
Work scheduled by:

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - PJ - NY | **1950 MW** | **1050 MW** |
| Impacts Total Transfer Capability | 150 MW | 150 MW |
| TTC with All Lines In Service | 2100 MW | 1200 MW |

---

**DYSINGER-GRAHAM__345_DG1**

Tue 02/10/2026 to Sat 11/21/2026
1122 Continuous 2100
Work scheduled by: NYISO

FORCED by NYISO 03/21/2026 14:33

| | FWD (Import) | REV (Export) |
|---|---|---|
| DYSINGER EAST | | |
| Impacts Total Transfer Capability | | |
| TTC with All Lines In Service | | |

---

**GRAHAM__-STA_255__345_GH1-43**

Tue 02/10/2026 to Sat 11/21/2026
1122 Continuous 2100
Work scheduled by: NYISO

FORCED by NYISO 03/21/2026 14:33

| | FWD (Import) | REV (Export) |
|---|---|---|
| DYSINGER EAST | | |
| Impacts Total Transfer Capability | | |
| TTC with All Lines In Service | | |

---

**SCH-NYISO-HQ_CEDARS_LIMIT_0**

Fri 04/17/2026 to Mon 11/30/2026
1900 Continuous 1700
Work scheduled by: HQ

EXT FORCED by HQ 09/23/2026 15:42

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - HQ_CEDARS | | **0 MW** |
| Impacts Total Transfer Capability | | 100 MW |
| TTC with All Lines In Service | | 100 MW |

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits** — **Tuesday, October 13, 2026 to Wednesday, April 12, 2028**

| | |
|---|---|
| **CENTRAL EAST** | **7550 MW** |
| **CENTRAL EAST - VC** | **3725 MW** |
| **TOTAL EAST** | **7550 MW** |
| **UPNY CONED** | **8210 MW** |
| **SPR/DUN-SOUTH** | **4600 MW** |
| **DYSINGER EAST** | **3200 MW** |
| **MOSES SOUTH** | **3400 MW** |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

---

**SCH-HQ_CEDARS-NYISO_LIMIT_220**

Tue 04/21/2026 to Mon 11/30/2026
1900 Continuous 1700
Work scheduled by: HQ

EXT FORCED by HQ 09/23/2026 15:42

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - HQ_CEDARS | **220 MW** | |
| Impacts Total Transfer Capability | 50 MW | |
| TTC with All Lines In Service | 270 MW | |

---

**BECK___-NIAGARA__230_PA27**

Tue 09/15/2026 to Tue 11/17/2026
0500 Continuous 2330
Work scheduled by: NYPA

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - OH - NY | **1900 MW** | |
| Impacts Total Transfer Capability | 100 MW | |
| TTC with All Lines In Service | 2000 MW | |

---

**HOMRC_NY-MAINS_NY_345_47**

Tue 09/15/2026 to Wed 10/14/2026
0700 Continuous 0700
Work scheduled by: PJM

EXT FORCED by PJM 10/11/2026 15:36

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - PJ - NY | **1700 MW** | **1050 MW** |
| Impacts Total Transfer Capability | 400 MW | 150 MW |
| TTC with All Lines In Service | 2100 MW | 1200 MW |

---

**FIVEMILE-LIMELAKE_345_49**

Wed 09/16/2026 to Mon 10/19/2026
0700 Continuous 1700
Work scheduled by: NGrid

EXT FORCED by NGrid 10/06/2026 10:34

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - PJ - NY | **1950 MW** | **1050 MW** |
| Impacts Total Transfer Capability | 150 MW | 150 MW |
| TTC with All Lines In Service | 2100 MW | 1200 MW |

---

**LIMELAKE-ESTOLERD_345_29**

Wed 09/16/2026 to Mon 10/19/2026
0700 Continuous 1700
Work scheduled by: NGrid

EXT FORCED by NGrid 10/06/2026 10:34

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - PJ - NY | **1950 MW** | **1050 MW** |
| Impacts Total Transfer Capability | 150 MW | 150 MW |
| TTC with All Lines In Service | 2100 MW | 1200 MW |

---

**DUNWODIE_345KV_7**

Wed 09/23/2026 to Fri 10/23/2026
0201 Continuous 0200
Work scheduled by: ConEd

UPDATED by ConEd 09/26/2026 09:41

| | FWD (Import) | REV (Export) |
|---|---|---|
| SPR/DUN-SOUTH | **3800 MW** | |
| Impacts Total Transfer Capability | 800 MW | |
| TTC with All Lines In Service | 4600 MW | |

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits** — **Tuesday, October 13, 2026 to Wednesday, April 12, 2028**

| | |
|---|---|
| **CENTRAL EAST** | **7550 MW** |
| **CENTRAL EAST - VC** | **3725 MW** |
| **TOTAL EAST** | **7550 MW** |
| **UPNY CONED** | **8210 MW** |
| **SPR/DUN-SOUTH** | **4600 MW** |
| **DYSINGER EAST** | **3200 MW** |
| **MOSES SOUTH** | **3400 MW** |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

---

**DUNWODIE_345KV_8**

Wed 09/23/2026 to Fri 10/23/2026
0201 Continuous 0200
Work scheduled by: ConEd

UPDATED by ConEd 09/26/2026 09:41

| | FWD (Import) | REV (Export) |
|---|---|---|
| SPR/DUN-SOUTH | **3800 MW** | |
| Impacts Total Transfer Capability | 800 MW | |
| TTC with All Lines In Service | 4600 MW | |

---

**DUNWODIE-MOTTHAVN_345_72**

Wed 09/23/2026 to Sat 11/07/2026
0201 Continuous 0159
Work scheduled by: ConEd

UPDATED by ConEd 09/26/2026 09:41

| | FWD (Import) | REV (Export) |
|---|---|---|
| SPR/DUN-SOUTH | **3800 MW** | |
| Impacts Total Transfer Capability | 800 MW | |
| TTC with All Lines In Service | 4600 MW | |

---

**W49TH_ST_345KV_7**

Wed 09/23/2026 to Fri 01/22/2027
0201 Continuous 0200
Work scheduled by: ConEd

EXTENDED by ConEd 09/23/2026 15:39

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - PJM_HTP | **300 MW** | |
| Impacts Total Transfer Capability | 360 MW | |
| TTC with All Lines In Service | 660 MW | |

---

**W49TH_ST_345KV_5**

Thu 09/24/2026 to Wed 01/06/2027
0101 Continuous 0200
Work scheduled by: ConEd

UPDATED by ConEd 09/29/2026 14:03

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - PJM_HTP | **300 MW** | |
| Impacts Total Transfer Capability | 360 MW | |
| TTC with All Lines In Service | 660 MW | |

---

**SCH-IMO-NYISO_LIMIT_1550**

Fri 10/09/2026 to Sun 10/18/2026
1931 Continuous 0630
Work scheduled by: IESO

UPDATED by IESO 10/02/2026 16:54

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - OH - NY | **1900 MW** | |
| Impacts Total Transfer Capability | 100 MW | |
| TTC with All Lines In Service | 2000 MW | |

---

**KNICRBKR-PLSNTVLY_345_Y57**

Sat 10/10/2026 to Sat 10/24/2026
0001 Continuous 2100
Work scheduled by: NGrid

UPDATED by NGrid 09/23/2026 08:34

ARR: 78

| | FWD (Import) | REV (Export) |
|---|---|---|
| UPNY CONED | **8045 MW** | |
| Impacts Total Transfer Capability | 165 MW | |
| TTC with All Lines In Service | 8210 MW | |

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits** — **Tuesday, October 13, 2026 to Wednesday, April 12, 2028**

| | |
|---|---|
| **CENTRAL EAST** | **7550 MW** |
| **CENTRAL EAST - VC** | **3725 MW** |
| **TOTAL EAST** | **7550 MW** |
| **UPNY CONED** | **8210 MW** |
| **SPR/DUN-SOUTH** | **4600 MW** |
| **DYSINGER EAST** | **3200 MW** |
| **MOSES SOUTH** | **3400 MW** |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

---

**HERTELHQ-ASTANNEX_345_G180**

Mon 10/12/2026 to Fri 10/16/2026
0001 Continuous 1800
Work scheduled by: ConEd

UPDATED by ConEd 10/11/2026 10:31

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - HQ_CHPE | **0 MW** | |
| Impacts Total Transfer Capability | 1250 MW | |
| TTC with All Lines In Service | 1250 MW | |

---

**NEPTUNE_-DUFFYAVE_345_NEPTUNE**

Mon 10/12/2026 to Fri 10/16/2026
0600 Continuous 1600
Work scheduled by: LI

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - PJM_NEPTUNE | **0 MW** | |
| Impacts Total Transfer Capability | 660 MW | |
| TTC with All Lines In Service | 660 MW | |

---

**NEWBRDGE-DUFFYAVE_345_501**

Mon 10/12/2026 to Fri 10/16/2026
0600 Continuous 1600
Work scheduled by: LI

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - PJM_NEPTUNE | **0 MW** | |
| Impacts Total Transfer Capability | 660 MW | |
| TTC with All Lines In Service | 660 MW | |

---

**SCH-HQ-NYISO_LIMIT_1100**

Mon 10/12/2026 to Mon 11/30/2026
2200 Continuous 1600
Work scheduled by: HQ

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - HQ - NY | **1100 MW** | |
| Impacts Total Transfer Capability | 400 MW | |
| TTC with All Lines In Service | 1500 MW | |

---

**CHAT_DC_GC1**

Tue 10/13/2026 to Fri 11/06/2026
0400 Continuous 1900
Work scheduled by: NYPA

UPDATED by NYPA 10/05/2026 14:10

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - HQ - NY | | **500 MW** |
| Impacts Total Transfer Capability | | 500 MW |
| TTC with All Lines In Service | | 1000 MW |

---

**CHAT_DC_GC1 , CHAT_DC_GC2**

Tue 10/13/2026 to Fri 11/06/2026
0400 1900
Work scheduled by:

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - HQ - NY | **1370 MW** | **0 MW** |
| Impacts Total Transfer Capability | 130 MW | 1000 MW |
| TTC with All Lines In Service | 1500 MW | 1000 MW |

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits** — **Tuesday, October 13, 2026 to Wednesday, April 12, 2028**

| | |
|---|---|
| **CENTRAL EAST** | **7550 MW** |
| **CENTRAL EAST - VC** | **3725 MW** |
| **TOTAL EAST** | **7550 MW** |
| **UPNY CONED** | **8210 MW** |
| **SPR/DUN-SOUTH** | **4600 MW** |
| **DYSINGER EAST** | **3200 MW** |
| **MOSES SOUTH** | **3400 MW** |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

---

**CHAT_DC_GC2**

Tue 10/13/2026 to Fri 11/06/2026
0400 Continuous 1900
Work scheduled by: NYPA

UPDATED by NYPA 10/05/2026 14:10

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - HQ - NY | | **500 MW** |
| Impacts Total Transfer Capability | | 500 MW |
| TTC with All Lines In Service | | 1000 MW |

---

**CHATGUAY-MASSENA__765_7040**

Tue 10/13/2026 to Fri 11/06/2026
0400 Continuous 1900
Work scheduled by: NYPA

UPDATED by NYPA 10/05/2026 14:10

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - HQ - NY | **0 MW** | **0 MW** |
| Impacts Total Transfer Capability | 1500 MW | 1000 MW |
| TTC with All Lines In Service | 1500 MW | 1000 MW |

---

**CHATGUAY-MASSENA__765_7040**

Tue 10/13/2026 to Fri 11/06/2026
0400 Continuous 1900
Work scheduled by: NYPA

UPDATED by NYPA 10/05/2026 14:10

| | FWD (Import) | REV (Export) |
|---|---|---|
| MOSES SOUTH | **1750 MW** | |
| Impacts Total Transfer Capability | 1650 MW | |
| TTC with All Lines In Service | 3400 MW | |

---

**MARCY___765_345_AT1**

Wed 10/14/2026 to Wed 10/28/2026
0001 Continuous 2359
Work scheduled by: NYPA

UPDATED by NYPA 10/05/2026 14:10

ARR: 19

| | FWD (Import) | REV (Export) |
|---|---|---|
| MOSES SOUTH | **1750 MW** | |
| Impacts Total Transfer Capability | 1650 MW | |
| TTC with All Lines In Service | 3400 MW | |

---

**MARCY___765_345_AT2**

Wed 10/14/2026 to Wed 11/04/2026
0001 Continuous 1900
Work scheduled by: NYPA

UPDATED by NYPA 10/05/2026 14:10

ARR: 19

| | FWD (Import) | REV (Export) |
|---|---|---|
| MOSES SOUTH | **1700 MW** | |
| Impacts Total Transfer Capability | 1700 MW | |
| TTC with All Lines In Service | 3400 MW | |

---

**MASSENA_-MARCY___765_MSU1**

Wed 10/14/2026 to Wed 10/28/2026
0001 Continuous 2359
Work scheduled by: NYPA

UPDATED by NYPA 10/05/2026 14:10

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - HQ - NY | **475 MW** | **1000 MW** |
| Impacts Total Transfer Capability | 1025 MW | 0 MW |
| TTC with All Lines In Service | 1500 MW | 1000 MW |

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits** — **Tuesday, October 13, 2026 to Wednesday, April 12, 2028**

| | |
|---|---|
| **CENTRAL EAST** | **7550 MW** |
| **CENTRAL EAST - VC** | **3725 MW** |
| **TOTAL EAST** | **7550 MW** |
| **UPNY CONED** | **8210 MW** |
| **SPR/DUN-SOUTH** | **4600 MW** |
| **DYSINGER EAST** | **3200 MW** |
| **MOSES SOUTH** | **3400 MW** |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

---

**MASSENA_-MARCY___765_MSU1**

Wed 10/14/2026 to Wed 10/28/2026
0001 Continuous 2359
Work scheduled by: NYPA

UPDATED by NYPA 10/05/2026 14:10

| | FWD (Import) | REV (Export) |
|---|---|---|
| CENTRAL EAST - VC | **2595 MW** | |
| Impacts Total Transfer Capability | 1130 MW | |
| TTC with All Lines In Service | 3725 MW | |

---

**MASSENA_-MARCY___765_MSU1**

Wed 10/14/2026 to Wed 10/28/2026
0001 Continuous 2359
Work scheduled by: NYPA

UPDATED by NYPA 10/05/2026 14:10

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - HQ_CEDARS | **190 MW** | |
| Impacts Total Transfer Capability | 80 MW | |
| TTC with All Lines In Service | 270 MW | |

---

**MASSENA_-MARCY___765_MSU1**

Wed 10/14/2026 to Wed 10/28/2026
0001 Continuous 2359
Work scheduled by: NYPA

UPDATED by NYPA 10/05/2026 14:10

| | FWD (Import) | REV (Export) |
|---|---|---|
| MOSES SOUTH | **500 MW** | |
| Impacts Total Transfer Capability | 2900 MW | |
| TTC with All Lines In Service | 3400 MW | |

---

**MASSENA_-MARCY___765_MSU1 , CHATGUAY-MASSENA__765_7040**

Wed 10/14/2026 to Wed 10/28/2026
0001 2359
Work scheduled by:

| | FWD (Import) | REV (Export) |
|---|---|---|
| MOSES SOUTH | **500 MW** | |
| Impacts Total Transfer Capability | 2900 MW | |
| TTC with All Lines In Service | 3400 MW | |

---

**MOSES__-MASSENA__230_MMS2 , MOSES__-MASSENA__230_MMS1**

Wed 10/14/2026 to Wed 10/28/2026
0001 2359
Work scheduled by:

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - HQ - NY | **850 MW** | **0 MW** |
| Impacts Total Transfer Capability | 650 MW | 1000 MW |
| TTC with All Lines In Service | 1500 MW | 1000 MW |

---

**MOSES__-MASSENA__230_MMS2 , MOSES__-MASSENA__230_MMS1**

Wed 10/14/2026 to Wed 10/28/2026
0001 2359
Work scheduled by:

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - HQ_CEDARS | **190 MW** | |
| Impacts Total Transfer Capability | 80 MW | |
| TTC with All Lines In Service | 270 MW | |

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits** — **Tuesday, October 13, 2026 to Wednesday, April 12, 2028**

| | |
|---|---|
| **CENTRAL EAST** | **7550 MW** |
| **CENTRAL EAST - VC** | **3725 MW** |
| **TOTAL EAST** | **7550 MW** |
| **UPNY CONED** | **8210 MW** |
| **SPR/DUN-SOUTH** | **4600 MW** |
| **DYSINGER EAST** | **3200 MW** |
| **MOSES SOUTH** | **3400 MW** |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

---

**INGHAM_C_115_115_PAR 2**

Thu 10/15/2026 to Thu 10/15/2026
0830 Daily(No Weekends) 1059
Work scheduled by: NGrid

| | FWD (Import) | REV (Export) |
|---|---|---|
| CENTRAL EAST - VC | **3605 MW** | |
| Impacts Total Transfer Capability | 120 MW | |
| TTC with All Lines In Service | 3725 MW | |

---

**BECK___-NIAGARA__345_PA301**

Thu 10/15/2026 to Thu 10/15/2026
0915 Continuous 0930
Work scheduled by: IESO

UPDATED by IESO 10/13/2026 15:48

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - OH - NY | **1000 MW** | **850 MW** |
| Impacts Total Transfer Capability | 1000 MW | 750 MW |
| TTC with All Lines In Service | 2000 MW | 1600 MW |

---

**BECK___-NIAGARA__345_PA301 , BECK___-NIAGARA__230_PA27**

Thu 10/15/2026 to Thu 10/15/2026
0915 0930
Work scheduled by:

| | FWD (Import) | REV (Export) |
|---|---|---|
| WESTERN_NY_EXPORT | **1100 MW** | |
| Impacts Total Transfer Capability | 1200 MW | |
| TTC with All Lines In Service | 2300 MW | |

---

**SCH-IMO-NYISO_LIMIT_1050**

Thu 10/15/2026 to Wed 10/28/2026
0915 Continuous 1700
Work scheduled by: IESO

UPDATED by IESO 10/13/2026 15:48

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - OH - NY | **1400 MW** | |
| Impacts Total Transfer Capability | 600 MW | |
| TTC with All Lines In Service | 2000 MW | |

---

**SCH-NYISO-IMO_LIMIT_900**

Thu 10/15/2026 to Wed 10/28/2026
0915 Continuous 1700
Work scheduled by: IESO

UPDATED by IESO 10/13/2026 15:48

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - OH - NY | | **1250 MW** |
| Impacts Total Transfer Capability | | 350 MW |
| TTC with All Lines In Service | | 1600 MW |

---

**INGHAM_C_115_115_PAR 2**

Thu 10/15/2026 to Thu 10/15/2026
1130 Daily(No Weekends) 1400
Work scheduled by: NGrid

| | FWD (Import) | REV (Export) |
|---|---|---|
| CENTRAL EAST - VC | **3605 MW** | |
| Impacts Total Transfer Capability | 120 MW | |
| TTC with All Lines In Service | 3725 MW | |

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits** — **Tuesday, October 13, 2026 to Wednesday, April 12, 2028**

| | |
|---|---|
| **CENTRAL EAST** | **7550 MW** |
| **CENTRAL EAST - VC** | **3725 MW** |
| **TOTAL EAST** | **7550 MW** |
| **UPNY CONED** | **8210 MW** |
| **SPR/DUN-SOUTH** | **4600 MW** |
| **DYSINGER EAST** | **3200 MW** |
| **MOSES SOUTH** | **3400 MW** |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**NRTH1385-NOR HBR__138_601**

Mon 10/19/2026 to Tue 10/20/2026
0600 Continuous 1500
Work scheduled by: LI

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - NPX_1385 | **100 MW** | **100 MW** |
| Impacts Total Transfer Capability | 100 MW | 100 MW |
| TTC with All Lines In Service | 200 MW | 200 MW |

**NRTH1385-NOR HBR__138_602**

Mon 10/19/2026 to Tue 10/20/2026
0600 Continuous 1500
Work scheduled by: LI

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - NPX_1385 | **100 MW** | **100 MW** |
| Impacts Total Transfer Capability | 100 MW | 100 MW |
| TTC with All Lines In Service | 200 MW | 200 MW |

**NRTH1385-NOR HBR__138_603**

Mon 10/19/2026 to Tue 10/20/2026
0600 Continuous 1500
Work scheduled by: LI

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - NPX_1385 | **100 MW** | **100 MW** |
| Impacts Total Transfer Capability | 100 MW | 100 MW |
| TTC with All Lines In Service | 200 MW | 200 MW |

**NRTH1385-NORHBR__138_601 , NRTH1385-NORHBR__138_602**

Mon 10/19/2026 to Tue 10/20/2026
0600 1500
Work scheduled by:

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - NPX_1385 | **0 MW** | **0 MW** |
| Impacts Total Transfer Capability | 200 MW | 200 MW |
| TTC with All Lines In Service | 200 MW | 200 MW |

**NRTH1385-NORHBR__138_601 , NRTH1385-NORHBR__138_603**

Mon 10/19/2026 to Tue 10/20/2026
0600 1500
Work scheduled by:

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - NPX_1385 | **0 MW** | **0 MW** |
| Impacts Total Transfer Capability | 200 MW | 200 MW |
| TTC with All Lines In Service | 200 MW | 200 MW |

**NRTH1385-NORHBR__138_602 , NRTH1385-NORHBR__138_603**

Mon 10/19/2026 to Tue 10/20/2026
0600 1500
Work scheduled by:

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - NPX_1385 | **0 MW** | **0 MW** |
| Impacts Total Transfer Capability | 200 MW | 200 MW |
| TTC with All Lines In Service | 200 MW | 200 MW |

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits** — **Tuesday, October 13, 2026 to Wednesday, April 12, 2028**

| | |
|---|---|
| **CENTRAL EAST** | **7550 MW** |
| **CENTRAL EAST - VC** | **3725 MW** |
| **TOTAL EAST** | **7550 MW** |
| **UPNY CONED** | **8210 MW** |
| **SPR/DUN-SOUTH** | **4600 MW** |
| **DYSINGER EAST** | **3200 MW** |
| **MOSES SOUTH** | **3400 MW** |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

---

**NRTH1385-NRTHPORT_138_NNC**

Mon 10/19/2026 to Tue 10/20/2026
0600 Continuous 1500
Work scheduled by: LI

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - NPX_1385 | **0 MW** | **0 MW** |
| Impacts Total Transfer Capability | 200 MW | 200 MW |
| TTC with All Lines In Service | 200 MW | 200 MW |

---

**SHOR_NPX-SHOREHAM_138_CSC**

Mon 10/19/2026 to Sat 10/31/2026
0900 Continuous 1800
Work scheduled by: ISONE

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - NPX_CSC | **0 MW** | **0 MW** |
| Impacts Total Transfer Capability | 330 MW | 330 MW |
| TTC with All Lines In Service | 330 MW | 330 MW |

---

**ROSETON_-EFISHKIL_345_RFK305**

Mon 10/26/2026 to Fri 11/06/2026
0001 Continuous 1559
Work scheduled by: NYPA

UPDATED by ConEd 07/23/2026 08:38

| | FWD (Import) | REV (Export) |
|---|---|---|
| UPNY CONED | **7470 MW** | |
| Impacts Total Transfer Capability | 740 MW | |
| TTC with All Lines In Service | 8210 MW | |

---

**HOMR_NYW-PIERC_NY_345_48**

Mon 10/26/2026 to Fri 10/30/2026
0800 Continuous 1500
Work scheduled by: NYSEG

UPDATED by NYSEG 10/06/2026 15:31

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - PJ - NY | **1950 MW** | **1050 MW** |
| Impacts Total Transfer Capability | 150 MW | 150 MW |
| TTC with All Lines In Service | 2100 MW | 1200 MW |

---

**DYSINGER-STA_255__345_DH1**

Tue 10/27/2026 to Sat 11/21/2026
0500 Continuous 2100
Work scheduled by: NYPA

| | FWD (Import) | REV (Export) |
|---|---|---|
| DYSINGER EAST | **2850 MW** | |
| Impacts Total Transfer Capability | 350 MW | |
| TTC with All Lines In Service | 3200 MW | |

---

**MILLWOOD-EASTVIEW_345_W82**

Thu 10/29/2026 to Sat 11/07/2026
0300 Continuous 2300
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|---|---|---|
| UPNY CONED | **8015 MW** | |
| Impacts Total Transfer Capability | 195 MW | |
| TTC with All Lines In Service | 8210 MW | |

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits** — **Tuesday, October 13, 2026 to Wednesday, April 12, 2028**

| | |
|---|---|
| **CENTRAL EAST** | **7550 MW** |
| **CENTRAL EAST - VC** | **3725 MW** |
| **TOTAL EAST** | **7550 MW** |
| **UPNY CONED** | **8210 MW** |
| **SPR/DUN-SOUTH** | **4600 MW** |
| **DYSINGER EAST** | **3200 MW** |
| **MOSES SOUTH** | **3400 MW** |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

---

**SPRNBRK__345KV_RNS4**

Thu 10/29/2026 to Thu 10/29/2026
0300 Continuous 0330
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|---|---|---|
| SPR/DUN-SOUTH | **3200 MW** | |
| Impacts Total Transfer Capability | 1400 MW | |
| TTC with All Lines In Service | 4600 MW | |

---

**STLAWRNC-MOSES___230_L34P**

Thu 10/29/2026 to Fri 11/13/2026
0700 Continuous 1930
Work scheduled by: IESO

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - OH - NY | | |
| Impacts Total Transfer Capability | | |
| TTC with All Lines In Service | | |

---

**SPRNBRK__345KV_RNS4**

Fri 10/30/2026 to Fri 10/30/2026
0300 Continuous 0330
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|---|---|---|
| SPR/DUN-SOUTH | **3200 MW** | |
| Impacts Total Transfer Capability | 1400 MW | |
| TTC with All Lines In Service | 4600 MW | |

---

**PANNELL_-CLAY____345_1**

Mon 11/02/2026 to Fri 11/06/2026
0700 Continuous 1730
Work scheduled by: NYPA

| | FWD (Import) | REV (Export) |
|---|---|---|
| WEST CENTRAL | **1300 MW** | |
| Impacts Total Transfer Capability | 950 MW | |
| TTC with All Lines In Service | 2250 MW | |

---

**LINDN_CG-LNDVFT___345_V-3022**

Mon 11/02/2026 to Sat 11/07/2026
0800 Continuous 1900
Work scheduled by: PJM

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - PJM_VFT | **0 MW** | **0 MW** |
| Impacts Total Transfer Capability | 315 MW | 315 MW |
| TTC with All Lines In Service | 315 MW | 315 MW |

---

**HOMRC_NY-MAINS_NY_345_47**

Tue 11/03/2026 to Fri 11/06/2026
0800 Continuous 1700
Work scheduled by: PJM

EXT FORCED by PJM 10/11/2026 15:36

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - PJ - NY | **2400 MW** | **2400 MW** |
| Impacts Total Transfer Capability | 100 MW | 250 MW |
| TTC with All Lines In Service | 2500 MW | 2650 MW |

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits** — **Tuesday, October 13, 2026 to Wednesday, April 12, 2028**

| | |
|---|---|
| **CENTRAL EAST** | **7550 MW** |
| **CENTRAL EAST - VC** | **3725 MW** |
| **TOTAL EAST** | **7550 MW** |
| **UPNY CONED** | **8210 MW** |
| **SPR/DUN-SOUTH** | **4600 MW** |
| **DYSINGER EAST** | **3200 MW** |
| **MOSES SOUTH** | **3400 MW** |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

---

**VOLNEY__-MARCY___345_19**

Wed 11/04/2026 to Thu 11/05/2026
0630 Continuous 1700
Work scheduled by: NGrid

ARR: 19

| | FWD (Import) | REV (Export) |
|---|---|---|
| OSWEGO EXPORT | **5250 MW** | |
| Impacts Total Transfer Capability | 350 MW | |
| TTC with All Lines In Service | 5600 MW | |

---

**VOLNEY__-MARCY___345_19**

Wed 11/04/2026 to Thu 11/05/2026
0630 Continuous 1700
Work scheduled by: NGrid

ARR: 19

| | FWD (Import) | REV (Export) |
|---|---|---|
| CENTRAL EAST - VC | **3525 MW** | |
| Impacts Total Transfer Capability | 200 MW | |
| TTC with All Lines In Service | 3725 MW | |

---

**LEEDS___345_LEEDS SVC**

Wed 11/04/2026 to Thu 11/05/2026
0800 Continuous 1500
Work scheduled by: NGrid

| | FWD (Import) | REV (Export) |
|---|---|---|
| CENTRAL EAST - VC | **3675 MW** | |
| Impacts Total Transfer Capability | 50 MW | |
| TTC with All Lines In Service | 3725 MW | |

---

**ROSETON_-EFISHKIL_345_RFK305**

Fri 11/06/2026 to Fri 11/13/2026
1600 Continuous 1600
Work scheduled by: CHGE

UPDATED by ConEd 06/05/2026 08:04

| | FWD (Import) | REV (Export) |
|---|---|---|
| UPNY CONED | **7470 MW** | |
| Impacts Total Transfer Capability | 740 MW | |
| TTC with All Lines In Service | 8210 MW | |

---

**DUNWODIE_345KV_7**

Sat 11/07/2026 to Sat 11/07/2026
0130 Continuous 0159
Work scheduled by: ConEd

UPDATED by ConEd 09/26/2026 09:41

| | FWD (Import) | REV (Export) |
|---|---|---|
| SPR/DUN-SOUTH | **3800 MW** | |
| Impacts Total Transfer Capability | 800 MW | |
| TTC with All Lines In Service | 4600 MW | |

---

**DUNWODIE_345KV_8**

Sat 11/07/2026 to Sat 11/07/2026
0130 Continuous 0159
Work scheduled by: ConEd

UPDATED by ConEd 09/26/2026 09:41

| | FWD (Import) | REV (Export) |
|---|---|---|
| SPR/DUN-SOUTH | **3800 MW** | |
| Impacts Total Transfer Capability | 800 MW | |
| TTC with All Lines In Service | 4600 MW | |

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits** — **Tuesday, October 13, 2026 to Wednesday, April 12, 2028**

| | |
|---|---|
| **CENTRAL EAST** | **7550 MW** |
| **CENTRAL EAST - VC** | **3725 MW** |
| **TOTAL EAST** | **7550 MW** |
| **UPNY CONED** | **8210 MW** |
| **SPR/DUN-SOUTH** | **4600 MW** |
| **DYSINGER EAST** | **3200 MW** |
| **MOSES SOUTH** | **3400 MW** |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

---

**DUNWODIE_345KV_3**

Sat 11/07/2026 0201 to Wed 12/09/2026 0200 — Continuous

Work scheduled by: ConEd

UPDATED by ConEd 03/27/2026 13:56

| | FWD (Import) | REV (Export) |
|---|---|---|
| SPR/DUN-SOUTH | **3800 MW** | |
| Impacts Total Transfer Capability | 800 MW | |
| TTC with All Lines In Service | 4600 MW | |

---

**DUNWODIE_345KV_5**

Sat 11/07/2026 0201 to Wed 12/09/2026 0200 — Continuous

Work scheduled by: ConEd

UPDATED by ConEd 03/27/2026 13:56

| | FWD (Import) | REV (Export) |
|---|---|---|
| SPR/DUN-SOUTH | **3800 MW** | |
| Impacts Total Transfer Capability | 800 MW | |
| TTC with All Lines In Service | 4600 MW | |

---

**DUNWODIE-MOTTHAVN_345_71**

Sat 11/07/2026 0201 to Fri 12/18/2026 0259 — Continuous

Work scheduled by: ConEd

UPDATED by ConEd 03/27/2026 13:56

| | FWD (Import) | REV (Export) |
|---|---|---|
| SPR/DUN-SOUTH | **3800 MW** | |
| Impacts Total Transfer Capability | 800 MW | |
| TTC with All Lines In Service | 4600 MW | |

---

**DYSINGER-GRAHAM__345_DG1 , NIAGARA_-DYSINGER_345_ND1**

Mon 11/09/2026 0600 to Fri 11/13/2026 1700

Work scheduled by:

| | FWD (Import) | REV (Export) |
|---|---|---|
| DYSINGER EAST | | |
| Impacts Total Transfer Capability | | |
| TTC with All Lines In Service | | |

---

**DYSINGER-STA_255__345_DH1 , NIAGARA_-DYSINGER_345_ND1**

Mon 11/09/2026 0600 to Fri 11/13/2026 1700

Work scheduled by:

| | FWD (Import) | REV (Export) |
|---|---|---|
| DYSINGER EAST | **2500 MW** | |
| Impacts Total Transfer Capability | 700 MW | |
| TTC with All Lines In Service | 3200 MW | |

---

**GRAHAM__-STA_255__345_GH1-43 , NIAGARA_-DYSINGER_345_ND1**

Mon 11/09/2026 0600 to Fri 11/13/2026 1700

Work scheduled by:

| | FWD (Import) | REV (Export) |
|---|---|---|
| DYSINGER EAST | | |
| Impacts Total Transfer Capability | | |
| TTC with All Lines In Service | | |

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits** — **Tuesday, October 13, 2026 to Wednesday, April 12, 2028**

| | |
|---|---|
| **CENTRAL EAST** | **7550 MW** |
| **CENTRAL EAST - VC** | **3725 MW** |
| **TOTAL EAST** | **7550 MW** |
| **UPNY CONED** | **8210 MW** |
| **SPR/DUN-SOUTH** | **4600 MW** |
| **DYSINGER EAST** | **3200 MW** |
| **MOSES SOUTH** | **3400 MW** |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**NIAGARA_-DYSINGER_345_ND1**

Mon 11/09/2026 to Fri 11/13/2026
0600 Continuous 1700
Work scheduled by: NT

| | FWD (Import) | REV (Export) |
|---|---|---|
| DYSINGER EAST | **2700 MW** | |
| Impacts Total Transfer Capability | 500 MW | |
| TTC with All Lines In Service | 3200 MW | |

**FIVEMILE-LIMELAKE_345_49**

Mon 11/09/2026 to Tue 12/22/2026
0700 Continuous 1700
Work scheduled by: NGrid

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - PJ - NY | **2400 MW** | **2300 MW** |
| Impacts Total Transfer Capability | 100 MW | 350 MW |
| TTC with All Lines In Service | 2500 MW | 2650 MW |

**LIMELAKE-ESTOLERD_345_29**

Mon 11/09/2026 to Tue 12/22/2026
0700 Continuous 1700
Work scheduled by: NGrid

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - PJ - NY | **2400 MW** | **2300 MW** |
| Impacts Total Transfer Capability | 100 MW | 350 MW |
| TTC with All Lines In Service | 2500 MW | 2650 MW |

**OSWEGO__-VOLNEY___345_12**

Tue 11/10/2026 to Thu 11/12/2026
0800 Continuous 1600
Work scheduled by: NGrid

| | FWD (Import) | REV (Export) |
|---|---|---|
| OSWEGO EXPORT | **5550 MW** | |
| Impacts Total Transfer Capability | 50 MW | |
| TTC with All Lines In Service | 5600 MW | |

**NRTH1385-NOR HBR__138_601**

Wed 11/11/2026 to Fri 11/20/2026
0800 Continuous 1000
Work scheduled by: ISONE

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - NPX_1385 | **100 MW** | **100 MW** |
| Impacts Total Transfer Capability | 100 MW | 100 MW |
| TTC with All Lines In Service | 200 MW | 200 MW |

**CRICKVLY-PLSNTVLY_345_F83**

Sat 11/14/2026 to Mon 11/16/2026
0001 Continuous 0259
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - NPX_1385 | **100 MW** | **100 MW** |
| Impacts Total Transfer Capability | 100 MW | 100 MW |
| TTC with All Lines In Service | 200 MW | 200 MW |

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits** — **Tuesday, October 13, 2026 to Wednesday, April 12, 2028**

| | |
|---|---|
| **CENTRAL EAST** | **7550 MW** |
| **CENTRAL EAST - VC** | **3725 MW** |
| **TOTAL EAST** | **7550 MW** |
| **UPNY CONED** | **8210 MW** |
| **SPR/DUN-SOUTH** | **4600 MW** |
| **DYSINGER EAST** | **3200 MW** |
| **MOSES SOUTH** | **3400 MW** |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

---

**CRICKVLY-PLSNTVLY_345_F83**

Sat 11/14/2026 to Mon 11/16/2026
0001 Continuous 0259
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - NE - NY | **1200 MW** | |
| Impacts Total Transfer Capability | 200 MW | |
| TTC with All Lines In Service | 1400 MW | |

---

**NRTH1385-NORHBR__138_601 , CRICKVLY-PLSNTVLY_345_F83**

Sat 11/14/2026 to Mon 11/16/2026
0001 0259
Work scheduled by:

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - NPX_1385 | **0 MW** | **0 MW** |
| Impacts Total Transfer Capability | 200 MW | 200 MW |
| TTC with All Lines In Service | 200 MW | 200 MW |

---

**PANNELL_-CLAY____345_2**

Mon 11/16/2026 to Fri 11/20/2026
0700 Continuous 1730
Work scheduled by: NYPA

| | FWD (Import) | REV (Export) |
|---|---|---|
| WEST CENTRAL | **1300 MW** | |
| Impacts Total Transfer Capability | 950 MW | |
| TTC with All Lines In Service | 2250 MW | |

---

**STLAWRNC-MOSES___230_L33P**

Mon 11/16/2026 to Fri 11/20/2026
0700 Continuous 1630
Work scheduled by: NYPA

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - OH - NY | **2300 MW** | |
| Impacts Total Transfer Capability | 200 MW | |
| TTC with All Lines In Service | 2500 MW | |

---

**BERKSHIR-ALPS____345_393**

Tue 11/17/2026 to Thu 11/19/2026
0700 Continuous 1700
Work scheduled by: NGrid

ARR: 78

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - NPX_1385 | **100 MW** | **100 MW** |
| Impacts Total Transfer Capability | 100 MW | 100 MW |
| TTC with All Lines In Service | 200 MW | 200 MW |

---

**BERKSHIR-ALPS____345_393**

Tue 11/17/2026 to Thu 11/19/2026
0700 Continuous 1700
Work scheduled by: NGrid

ARR: 78

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - NE - NY | **1000 MW** | **1600 MW** |
| Impacts Total Transfer Capability | 400 MW | 200 MW |
| TTC with All Lines In Service | 1400 MW | 1800 MW |

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits** — **Tuesday, October 13, 2026 to Wednesday, April 12, 2028**

| | |
|---|---|
| **CENTRAL EAST** | **7550 MW** |
| **CENTRAL EAST - VC** | **3725 MW** |
| **TOTAL EAST** | **7550 MW** |
| **UPNY CONED** | **8210 MW** |
| **SPR/DUN-SOUTH** | **4600 MW** |
| **DYSINGER EAST** | **3200 MW** |
| **MOSES SOUTH** | **3400 MW** |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

---

**BERKSHIR-ALPS____345_393 , NRTH1385-NORHBR__138_601**

Tue 11/17/2026 to Thu 11/19/2026
0700 1700
Work scheduled by:

ARR: 78

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - NPX_1385 | **0 MW** | **0 MW** |
| Impacts Total Transfer Capability | 200 MW | 200 MW |
| TTC with All Lines In Service | 200 MW | 200 MW |

---

**PLSNTVLY-WOOD_ST__345_F30**

Wed 11/18/2026 to Wed 11/18/2026
0001 Continuous 1830
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|---|---|---|
| UPNY CONED | **7780 MW** | |
| Impacts Total Transfer Capability | 430 MW | |
| TTC with All Lines In Service | 8210 MW | |

---

**DOVER___-CRICKVLY_345_Y17**

Sat 11/21/2026 to Tue 11/24/2026
0830 Continuous 1600
Work scheduled by: ISONE

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - NE - NY | **800 MW** | **1200 MW** |
| Impacts Total Transfer Capability | 600 MW | 600 MW |
| TTC with All Lines In Service | 1400 MW | 1800 MW |

---

**DOVER___-CRICKVLY_345_Y17**

Sat 11/21/2026 to Tue 11/24/2026
0830 Continuous 1600
Work scheduled by: ISONE

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - NPX_1385 | **100 MW** | **100 MW** |
| Impacts Total Transfer Capability | 100 MW | 100 MW |
| TTC with All Lines In Service | 200 MW | 200 MW |

---

**LONG_MTN-DOVER___345_398**

Sat 11/21/2026 to Tue 11/24/2026
0830 Continuous 1600
Work scheduled by: ISONE

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - NPX_1385 | **100 MW** | **100 MW** |
| Impacts Total Transfer Capability | 100 MW | 100 MW |
| TTC with All Lines In Service | 200 MW | 200 MW |

---

**LONG_MTN-DOVER___345_398**

Sat 11/21/2026 to Tue 11/24/2026
0830 Continuous 1600
Work scheduled by: ISONE

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - NE - NY | **800 MW** | **1200 MW** |
| Impacts Total Transfer Capability | 600 MW | 600 MW |
| TTC with All Lines In Service | 1400 MW | 1800 MW |

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits** — **Tuesday, October 13, 2026 to Wednesday, April 12, 2028**

| | |
|---|---|
| **CENTRAL EAST** | **7550 MW** |
| **CENTRAL EAST - VC** | **3725 MW** |
| **TOTAL EAST** | **7550 MW** |
| **UPNY CONED** | **8210 MW** |
| **SPR/DUN-SOUTH** | **4600 MW** |
| **DYSINGER EAST** | **3200 MW** |
| **MOSES SOUTH** | **3400 MW** |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

---

**BECK___-NIAGARA__230_PA27**

Mon 11/23/2026 to Fri 11/27/2026
0630 Continuous 1600
Work scheduled by: IESO

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - OH - NY | **2050 MW** | |
| Impacts Total Transfer Capability | 450 MW | |
| TTC with All Lines In Service | 2500 MW | |

---

**EDIC___-GORDONRD_345_14**

Tue 11/24/2026 to Tue 11/24/2026
0845 Daily(No Weekends) 0930
Work scheduled by: NGrid

| | FWD (Import) | REV (Export) |
|---|---|---|
| CENTRAL EAST - VC | **2770 MW** | |
| Impacts Total Transfer Capability | 955 MW | |
| TTC with All Lines In Service | 3725 MW | |

---

**EDIC___-FRASER__345_EF24-40**

Mon 11/30/2026 to Sun 12/06/2026
0700 Continuous 1530
Work scheduled by: NYPA

| | FWD (Import) | REV (Export) |
|---|---|---|
| CENTRAL EAST - VC | **3225 MW** | |
| Impacts Total Transfer Capability | 500 MW | |
| TTC with All Lines In Service | 3725 MW | |

---

**NRTH1385-NOR HBR__138_602**

Mon 11/30/2026 to Tue 12/08/2026
0800 Continuous 1000
Work scheduled by: ISONE

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - NPX_1385 | **100 MW** | **100 MW** |
| Impacts Total Transfer Capability | 100 MW | 100 MW |
| TTC with All Lines In Service | 200 MW | 200 MW |

---

**SAND_BAR-PLATSBRG_115_PV20**

Mon 11/30/2026 to Fri 12/04/2026
0800 Continuous 1630
Work scheduled by: NYPA

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - NE - NY | | |
| Impacts Total Transfer Capability | | |
| TTC with All Lines In Service | | |

---

**SAND_BAR-PLATSBRG_115_PV20**

Mon 11/30/2026 to Fri 12/04/2026
0800 Continuous 1630
Work scheduled by: NYPA

| | FWD (Import) | REV (Export) |
|---|---|---|
| CENTRAL EAST - VC | **3625 MW** | |
| Impacts Total Transfer Capability | 100 MW | |
| TTC with All Lines In Service | 3725 MW | |

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits** — **Tuesday, October 13, 2026 to Wednesday, April 12, 2028**

| | |
|---|---|
| **CENTRAL EAST** | **7550 MW** |
| **CENTRAL EAST - VC** | **3725 MW** |
| **TOTAL EAST** | **7550 MW** |
| **UPNY CONED** | **8210 MW** |
| **SPR/DUN-SOUTH** | **4600 MW** |
| **DYSINGER EAST** | **3200 MW** |
| **MOSES SOUTH** | **3400 MW** |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

---

**GORDONRD-ROTTRDAM_230_31**

Thu 12/03/2026 to Thu 12/03/2026
0830 Daily(No Weekends) 1100
Work scheduled by: NGrid

| | FWD (Import) | REV (Export) |
|---|---|---|
| CENTRAL EAST - VC | **3690 MW** | |
| Impacts Total Transfer Capability | 35 MW | |
| TTC with All Lines In Service | 3725 MW | |

---

**NRTH1385-NOR HBR__138_603**

Thu 12/10/2026 to Sat 12/19/2026
0800 Continuous 1000
Work scheduled by: ISONE

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - NPX_1385 | **100 MW** | **100 MW** |
| Impacts Total Transfer Capability | 100 MW | 100 MW |
| TTC with All Lines In Service | 200 MW | 200 MW |

---

**DUNWODIE_345KV_3**

Sat 12/12/2026 to Mon 12/14/2026
0001 Continuous 0200
Work scheduled by: ConEd

UPDATED by ConEd 03/27/2026 13:56

| | FWD (Import) | REV (Export) |
|---|---|---|
| SPR/DUN-SOUTH | **3800 MW** | |
| Impacts Total Transfer Capability | 800 MW | |
| TTC with All Lines In Service | 4600 MW | |

---

**DUNWODIE_345KV_5**

Sat 12/12/2026 to Mon 12/14/2026
0001 Continuous 0200
Work scheduled by: ConEd

UPDATED by ConEd 03/27/2026 13:56

| | FWD (Import) | REV (Export) |
|---|---|---|
| SPR/DUN-SOUTH | **3800 MW** | |
| Impacts Total Transfer Capability | 800 MW | |
| TTC with All Lines In Service | 4600 MW | |

---

**DUNWODIE_345KV_6**

Tue 12/15/2026 to Tue 12/15/2026
0001 Continuous 0030
Work scheduled by: ConEd

UPDATED by ConEd 10/07/2026 13:07

| | FWD (Import) | REV (Export) |
|---|---|---|
| SPR/DUN-SOUTH | **3800 MW** | |
| Impacts Total Transfer Capability | 800 MW | |
| TTC with All Lines In Service | 4600 MW | |

---

**DUNWODIE_345KV_8**

Tue 12/15/2026 to Tue 12/15/2026
0001 Continuous 0030
Work scheduled by: ConEd

UPDATED by ConEd 10/07/2026 13:07

| | FWD (Import) | REV (Export) |
|---|---|---|
| SPR/DUN-SOUTH | **3800 MW** | |
| Impacts Total Transfer Capability | 800 MW | |
| TTC with All Lines In Service | 4600 MW | |

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits** — **Tuesday, October 13, 2026 to Wednesday, April 12, 2028**

| | |
|---|---|
| **CENTRAL EAST** | **7550 MW** |
| **CENTRAL EAST - VC** | **3725 MW** |
| **TOTAL EAST** | **7550 MW** |
| **UPNY CONED** | **8210 MW** |
| **SPR/DUN-SOUTH** | **4600 MW** |
| **DYSINGER EAST** | **3200 MW** |
| **MOSES SOUTH** | **3400 MW** |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

---

**PLSNTVLY-EFISHKIL_345_F37**

Tue 12/15/2026 to Thu 12/17/2026
0001 Continuous 0200
Work scheduled by: ConEd

UPDATED by ConEd 10/07/2026 13:07

| | FWD (Import) | REV (Export) |
|---|---|---|
| UPNY CONED | **8195 MW** | |
| Impacts Total Transfer Capability | 15 MW | |
| TTC with All Lines In Service | 8210 MW | |

---

**WOOD_ST_-PLSNTVLE_345_Y87**

Tue 12/15/2026 to Fri 01/22/2027
0001 Continuous 0200
Work scheduled by: ConEd

UPDATED by ConEd 10/07/2026 13:07

| | FWD (Import) | REV (Export) |
|---|---|---|
| UPNY CONED | **7795 MW** | |
| Impacts Total Transfer Capability | 415 MW | |
| TTC with All Lines In Service | 8210 MW | |

---

**DUNWODIE_345KV_6**

Wed 12/16/2026 to Wed 12/16/2026
0130 Continuous 0200
Work scheduled by: ConEd

UPDATED by ConEd 10/07/2026 13:07

| | FWD (Import) | REV (Export) |
|---|---|---|
| SPR/DUN-SOUTH | **3800 MW** | |
| Impacts Total Transfer Capability | 800 MW | |
| TTC with All Lines In Service | 4600 MW | |

---

**DUNWODIE_345KV_8**

Wed 12/16/2026 to Wed 12/16/2026
0130 Continuous 0200
Work scheduled by: ConEd

UPDATED by ConEd 10/07/2026 13:07

| | FWD (Import) | REV (Export) |
|---|---|---|
| SPR/DUN-SOUTH | **3800 MW** | |
| Impacts Total Transfer Capability | 800 MW | |
| TTC with All Lines In Service | 4600 MW | |

---

**DUNWODIE_345KV_3**

Fri 12/18/2026 to Fri 12/18/2026
0230 Continuous 0259
Work scheduled by: ConEd

UPDATED by ConEd 03/27/2026 13:56

| | FWD (Import) | REV (Export) |
|---|---|---|
| SPR/DUN-SOUTH | **3800 MW** | |
| Impacts Total Transfer Capability | 800 MW | |
| TTC with All Lines In Service | 4600 MW | |

---

**DUNWODIE_345KV_5**

Fri 12/18/2026 to Fri 12/18/2026
0230 Continuous 0259
Work scheduled by: ConEd

UPDATED by ConEd 03/27/2026 13:56

| | FWD (Import) | REV (Export) |
|---|---|---|
| SPR/DUN-SOUTH | **3800 MW** | |
| Impacts Total Transfer Capability | 800 MW | |
| TTC with All Lines In Service | 4600 MW | |

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits** — **Tuesday, October 13, 2026 to Wednesday, April 12, 2028**

| | |
|---|---|
| **CENTRAL EAST** | **7550 MW** |
| **CENTRAL EAST - VC** | **3725 MW** |
| **TOTAL EAST** | **7550 MW** |
| **UPNY CONED** | **8210 MW** |
| **SPR/DUN-SOUTH** | **4600 MW** |
| **DYSINGER EAST** | **3200 MW** |
| **MOSES SOUTH** | **3400 MW** |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

---

**STLAWRNC-MOSES___230_L34P**

Fri 12/25/2026 to Fri 12/25/2026
0800 Continuous 1600
Work scheduled by: IESO

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - OH - NY | **2300 MW** | |
| Impacts Total Transfer Capability | 200 MW | |
| TTC with All Lines In Service | 2500 MW | |

---

**HUDSONTP-W49TH_ST_345_Y56**

Sat 12/26/2026 to Wed 01/06/2027
0001 Continuous 0200
Work scheduled by: ConEd

UPDATED by ConEd 09/29/2026 14:03

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - PJM_HTP | **0 MW** | |
| Impacts Total Transfer Capability | 660 MW | |
| TTC with All Lines In Service | 660 MW | |

---

**W49TH_ST_345KV_8**

Sat 12/26/2026 to Wed 01/06/2027
0001 Continuous 0200
Work scheduled by: ConEd

UPDATED by ConEd 09/29/2026 14:03

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - PJM_HTP | **300 MW** | |
| Impacts Total Transfer Capability | 360 MW | |
| TTC with All Lines In Service | 660 MW | |

---

**MAINESBG-WATRCURE_345_30**

Mon 12/28/2026 to Thu 12/31/2026
0600 Continuous 1800
Work scheduled by: NYSEG

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - PJ - NY | **1800 MW** | **2400 MW** |
| Impacts Total Transfer Capability | 700 MW | 250 MW |
| TTC with All Lines In Service | 2500 MW | 2650 MW |

---

**SPRNBRK__345KV_RNS4**

Wed 12/30/2026 to Wed 12/30/2026
0001 Continuous 0030
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|---|---|---|
| SPR/DUN-SOUTH | **3200 MW** | |
| Impacts Total Transfer Capability | 1400 MW | |
| TTC with All Lines In Service | 4600 MW | |

---

**SPRNBRK_-W49TH_ST_345_M52**

Wed 12/30/2026 to Sat 01/09/2027
0001 Continuous 0200
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|---|---|---|
| SPR/DUN-SOUTH | **3200 MW** | |
| Impacts Total Transfer Capability | 1400 MW | |
| TTC with All Lines In Service | 4600 MW | |

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits** — **Tuesday, October 13, 2026 to Wednesday, April 12, 2028**

| | |
|---|---|
| **CENTRAL EAST** | **7550 MW** |
| **CENTRAL EAST - VC** | **3725 MW** |
| **TOTAL EAST** | **7550 MW** |
| **UPNY CONED** | **8210 MW** |
| **SPR/DUN-SOUTH** | **4600 MW** |
| **DYSINGER EAST** | **3200 MW** |
| **MOSES SOUTH** | **3400 MW** |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

---

**W49TH_ST_345KV_5**

Wed 12/30/2026 to Sat 01/09/2027
0001 Continuous 0200
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - PJM_HTP | **300 MW** | |
| Impacts Total Transfer Capability | 360 MW | |
| TTC with All Lines In Service | 660 MW | |

---

**SPRNBRK__345KV_RNS4**

Sat 01/09/2027 to Sat 01/09/2027
0130 Continuous 0200
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|---|---|---|
| SPR/DUN-SOUTH | **3200 MW** | |
| Impacts Total Transfer Capability | 1400 MW | |
| TTC with All Lines In Service | 4600 MW | |

---

**PLSNTVLY-EFISHKIL_345_F37**

Sun 01/10/2027 to Sat 01/16/2027
0001 Continuous 0200
Work scheduled by: ConEd

UPDATED by ConEd 10/07/2026 13:07

| | FWD (Import) | REV (Export) |
|---|---|---|
| UPNY CONED | **8195 MW** | |
| Impacts Total Transfer Capability | 15 MW | |
| TTC with All Lines In Service | 8210 MW | |

---

**SPRNBRK_-TREMONT__345_X28**

Mon 01/11/2027 to Mon 01/11/2027
0001 Continuous 1800
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|---|---|---|
| SPR/DUN-SOUTH | **4200 MW** | |
| Impacts Total Transfer Capability | 400 MW | |
| TTC with All Lines In Service | 4600 MW | |

---

**W49TH_ST-E13THSTA_345_M54**

Tue 01/12/2027 to Tue 01/12/2027
0001 Continuous 0030
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|---|---|---|
| SPR/DUN-SOUTH | **3800 MW** | |
| Impacts Total Transfer Capability | 800 MW | |
| TTC with All Lines In Service | 4600 MW | |

---

**DUNWODIE_345KV_6**

Sun 01/17/2027 to Fri 01/22/2027
0001 Continuous 0200
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|---|---|---|
| SPR/DUN-SOUTH | **3800 MW** | |
| Impacts Total Transfer Capability | 800 MW | |
| TTC with All Lines In Service | 4600 MW | |

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits** — **Tuesday, October 13, 2026 to Wednesday, April 12, 2028**

| | |
|---|---|
| **CENTRAL EAST** | **7550 MW** |
| **CENTRAL EAST - VC** | **3725 MW** |
| **TOTAL EAST** | **7550 MW** |
| **UPNY CONED** | **8210 MW** |
| **SPR/DUN-SOUTH** | **4600 MW** |
| **DYSINGER EAST** | **3200 MW** |
| **MOSES SOUTH** | **3400 MW** |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

---

**DUNWODIE_345KV_8**

Sun 01/17/2027 to Fri 01/22/2027
0001 Continuous 0200
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|---|---|---|
| SPR/DUN-SOUTH | **3800 MW** | |
| Impacts Total Transfer Capability | 800 MW | |
| TTC with All Lines In Service | 4600 MW | |

---

**W49TH_ST-E13THSTA_345_M54**

Mon 01/18/2027 to Mon 01/18/2027
0130 Continuous 0200
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|---|---|---|
| SPR/DUN-SOUTH | **3800 MW** | |
| Impacts Total Transfer Capability | 800 MW | |
| TTC with All Lines In Service | 4600 MW | |

---

**W49TH_ST_345KV_5**

Tue 01/19/2027 to Fri 01/22/2027
2301 Continuous 0100
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - PJM_HTP | **300 MW** | |
| Impacts Total Transfer Capability | 360 MW | |
| TTC with All Lines In Service | 660 MW | |

---

**BECK___-NIAGARA__345_PA302**

Sun 01/24/2027 to Fri 02/05/2027
0800 Continuous 1600
Work scheduled by: IESO

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - OH - NY | **1150 MW** | **1000 MW** |
| Impacts Total Transfer Capability | 1350 MW | 850 MW |
| TTC with All Lines In Service | 2500 MW | 1850 MW |

---

**SPRNBRK__345KV_RS4 , SPRNBRK__345KV_RS3**

Sat 01/30/2027 to Sat 01/30/2027
0001 2359
Work scheduled by:

| | FWD (Import) | REV (Export) |
|---|---|---|
| SPR/DUN-SOUTH | **3800 MW** | |
| Impacts Total Transfer Capability | 800 MW | |
| TTC with All Lines In Service | 4600 MW | |

---

**SPRNBRK__345KV_RNS5**

Sun 01/31/2027 to Wed 02/10/2027
0201 Continuous 0200
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|---|---|---|
| SPR/DUN-SOUTH | **3200 MW** | |
| Impacts Total Transfer Capability | 1400 MW | |
| TTC with All Lines In Service | 4600 MW | |

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits** — **Tuesday, October 13, 2026 to Wednesday, April 12, 2028**

| | |
|---|---|
| **CENTRAL EAST** | **7550 MW** |
| **CENTRAL EAST - VC** | **3725 MW** |
| **TOTAL EAST** | **7550 MW** |
| **UPNY CONED** | **8210 MW** |
| **SPR/DUN-SOUTH** | **4600 MW** |
| **DYSINGER EAST** | **3200 MW** |
| **MOSES SOUTH** | **3400 MW** |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

---

**SPRNBRK_-W49TH_ST_345_M51**

Sun 01/31/2027 to Wed 02/10/2027
0201 Continuous 0200
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|---|---|---|
| SPR/DUN-SOUTH | **3200 MW** | |
| Impacts Total Transfer Capability | 1400 MW | |
| TTC with All Lines In Service | 4600 MW | |

---

**BECK___-NIAGARA__345_PA301**

Sun 02/07/2027 to Thu 02/18/2027
0800 Continuous 1600
Work scheduled by: IESO

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - OH - NY | **1150 MW** | **1000 MW** |
| Impacts Total Transfer Capability | 1350 MW | 850 MW |
| TTC with All Lines In Service | 2500 MW | 1850 MW |

---

**NIAGARA_-ROBNSNRD_230_64**

Mon 03/01/2027 to Fri 05/28/2027
0500 Continuous 2300
Work scheduled by: NYPA

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - OH - NY | | |
| Impacts Total Transfer Capability | | |
| TTC with All Lines In Service | | |

---

**AUSTINRD-ADIRNDCK_345_13**

Mon 03/01/2027 to Thu 03/11/2027
0600 Continuous 1830
Work scheduled by: NYPA

| | FWD (Import) | REV (Export) |
|---|---|---|
| MOSES SOUTH | **2300 MW** | |
| Impacts Total Transfer Capability | 1100 MW | |
| TTC with All Lines In Service | 3400 MW | |

---

**HAVERSTK-ADIRNDCK_345_HA1**

Mon 03/01/2027 to Thu 03/11/2027
0600 Continuous 1830
Work scheduled by: NYPA

| | FWD (Import) | REV (Export) |
|---|---|---|
| MOSES SOUTH | **2300 MW** | |
| Impacts Total Transfer Capability | 1100 MW | |
| TTC with All Lines In Service | 3400 MW | |

---

**SPRNBRK__345KV_RNS5**

Thu 03/04/2027 to Sun 03/07/2027
0101 Continuous 0200
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|---|---|---|
| SPR/DUN-SOUTH | **3200 MW** | |
| Impacts Total Transfer Capability | 1400 MW | |
| TTC with All Lines In Service | 4600 MW | |

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits** — **Tuesday, October 13, 2026 to Wednesday, April 12, 2028**

| | |
|---|---|
| **CENTRAL EAST** | **7550 MW** |
| **CENTRAL EAST - VC** | **3725 MW** |
| **TOTAL EAST** | **7550 MW** |
| **UPNY CONED** | **8210 MW** |
| **SPR/DUN-SOUTH** | **4600 MW** |
| **DYSINGER EAST** | **3200 MW** |
| **MOSES SOUTH** | **3400 MW** |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

---

**SPRNBRK_-W49TH_ST_345_M51**

Thu 03/04/2027 to Sun 03/07/2027
0101 Continuous 0200
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|---|---|---|
| SPR/DUN-SOUTH | **3200 MW** | |
| Impacts Total Transfer Capability | 1400 MW | |
| TTC with All Lines In Service | 4600 MW | |

---

**SPRNBRK__345KV_RS4 , SPRNBRK__345KV_RS3**

Sun 03/07/2027 to Wed 03/10/2027
0001 0100
Work scheduled by:

| | FWD (Import) | REV (Export) |
|---|---|---|
| SPR/DUN-SOUTH | **3800 MW** | |
| Impacts Total Transfer Capability | 800 MW | |
| TTC with All Lines In Service | 4600 MW | |

---

**MARCY___-EDIC____345_UE1-7**

Tue 03/09/2027 to Wed 03/10/2027
0500 Continuous 1730
Work scheduled by: NYPA

ARR: 16 & 19

| | FWD (Import) | REV (Export) |
|---|---|---|
| OSWEGO EXPORT | **5300 MW** | |
| Impacts Total Transfer Capability | 300 MW | |
| TTC with All Lines In Service | 5600 MW | |

---

**BUCHAN_S-MILLWOOD_345_W97**

Sun 04/04/2027 to Wed 04/07/2027
0201 Continuous 0200
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|---|---|---|
| UPNY CONED | **8175 MW** | |
| Impacts Total Transfer Capability | 35 MW | |
| TTC with All Lines In Service | 8210 MW | |

---

**ROCHESTR-PANNELL__345_RP1**

Mon 04/05/2027 to Fri 04/09/2027
0500 Continuous 1700
Work scheduled by: NYPA

| | FWD (Import) | REV (Export) |
|---|---|---|
| DYSINGER EAST | **2300 MW** | |
| Impacts Total Transfer Capability | 900 MW | |
| TTC with All Lines In Service | 3200 MW | |

---

**MARCY___345KV_CSC**

Mon 04/05/2027 to Sat 04/17/2027
0700 Continuous 1730
Work scheduled by: NYPA

| | FWD (Import) | REV (Export) |
|---|---|---|
| CENTRAL EAST - VC | **3650 MW** | |
| Impacts Total Transfer Capability | 75 MW | |
| TTC with All Lines In Service | 3725 MW | |

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits** — **Tuesday, October 13, 2026 to Wednesday, April 12, 2028**

| | |
|---|---|
| **CENTRAL EAST** | **7550 MW** |
| **CENTRAL EAST - VC** | **3725 MW** |
| **TOTAL EAST** | **7550 MW** |
| **UPNY CONED** | **8210 MW** |
| **SPR/DUN-SOUTH** | **4600 MW** |
| **DYSINGER EAST** | **3200 MW** |
| **MOSES SOUTH** | **3400 MW** |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

---

**PRINCTWN-N.SCTLND_345_361**

Tue 04/06/2027 to Thu 04/08/2027
0800 Continuous 1700
Work scheduled by: LS

| | FWD (Import) | REV (Export) |
|---|---|---|
| CENTRAL EAST - VC | **3640 MW** | |
| Impacts Total Transfer Capability | 85 MW | |
| TTC with All Lines In Service | 3725 MW | |

---

**LINDN_CG-LNDVFT__345_V-3022**

Sun 04/11/2027 to Sat 04/17/2027
1200 Continuous 1200
Work scheduled by: PJM

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - PJM_VFT | **0 MW** | **0 MW** |
| Impacts Total Transfer Capability | 315 MW | 315 MW |
| TTC with All Lines In Service | 315 MW | 315 MW |

---

**DUNWODIE_345KV_4**

Mon 04/12/2027 to Sat 04/24/2027
0001 Continuous 0200
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|---|---|---|
| SPR/DUN-SOUTH | **3800 MW** | |
| Impacts Total Transfer Capability | 800 MW | |
| TTC with All Lines In Service | 4600 MW | |

---

**DUNWODIE_345KV_6**

Mon 04/12/2027 to Sat 04/24/2027
0001 Continuous 0200
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|---|---|---|
| SPR/DUN-SOUTH | **3800 MW** | |
| Impacts Total Transfer Capability | 800 MW | |
| TTC with All Lines In Service | 4600 MW | |

---

**DUNWODIE-SHORE_RD_345_Y50**

Mon 04/12/2027 to Sat 04/24/2027
0001 Continuous 0200
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|---|---|---|
| CONED - LIPA | **800 MW** | |
| Impacts Total Transfer Capability | 700 MW | |
| TTC with All Lines In Service | 1500 MW | |

---

**PLSNTVLY-WOOD_ST__345_F30**

Mon 04/12/2027 to Sat 05/22/2027
0001 Continuous 0200
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|---|---|---|
| UPNY CONED | **7780 MW** | |
| Impacts Total Transfer Capability | 430 MW | |
| TTC with All Lines In Service | 8210 MW | |

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits** — **Tuesday, October 13, 2026 to Wednesday, April 12, 2028**

| | |
|---|---|
| **CENTRAL EAST** | **7550 MW** |
| **CENTRAL EAST - VC** | **3725 MW** |
| **TOTAL EAST** | **7550 MW** |
| **UPNY CONED** | **8210 MW** |
| **SPR/DUN-SOUTH** | **4600 MW** |
| **DYSINGER EAST** | **3200 MW** |
| **MOSES SOUTH** | **3400 MW** |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

---

**SHORE_RD_345_138_BK 1**

Mon 04/12/2027 to Sat 04/24/2027
0001 Continuous 0200
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|---|---|---|
| CONED - LIPA | **1350 MW** | |
| Impacts Total Transfer Capability | 150 MW | |
| TTC with All Lines In Service | 1500 MW | |

---

**SHORE_RD_345_138_BK 2**

Mon 04/12/2027 to Sat 04/24/2027
0001 Continuous 0200
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|---|---|---|
| CONED - LIPA | **1350 MW** | |
| Impacts Total Transfer Capability | 150 MW | |
| TTC with All Lines In Service | 1500 MW | |

---

**NIAGARA__345_230_AT4**

Mon 04/12/2027 to Fri 04/30/2027
0500 Continuous 2300
Work scheduled by: NYPA

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - OH - NY | **2250 MW** | **1550 MW** |
| Impacts Total Transfer Capability | 250 MW | 300 MW |
| TTC with All Lines In Service | 2500 MW | 1850 MW |

---

**ROCHESTR-PANNELL__345_RP2**

Mon 04/12/2027 to Fri 04/16/2027
0500 Continuous 1700
Work scheduled by: NYPA

| | FWD (Import) | REV (Export) |
|---|---|---|
| DYSINGER EAST | **2300 MW** | |
| Impacts Total Transfer Capability | 900 MW | |
| TTC with All Lines In Service | 3200 MW | |

---

**PRINCTWN-N.SCTLND_345_362**

Tue 04/13/2027 to Thu 04/15/2027
0800 Continuous 1700
Work scheduled by: LS

| | FWD (Import) | REV (Export) |
|---|---|---|
| CENTRAL EAST - VC | **3640 MW** | |
| Impacts Total Transfer Capability | 85 MW | |
| TTC with All Lines In Service | 3725 MW | |

---

**PANNELL_-CLAY____345_1**

Mon 04/19/2027 to Fri 04/23/2027
0700 Continuous 1730
Work scheduled by: NYPA

| | FWD (Import) | REV (Export) |
|---|---|---|
| WEST CENTRAL | **1300 MW** | |
| Impacts Total Transfer Capability | 950 MW | |
| TTC with All Lines In Service | 2250 MW | |

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits** — **Tuesday, October 13, 2026 to Wednesday, April 12, 2028**

| | |
|---|---|
| **CENTRAL EAST** | **7550 MW** |
| **CENTRAL EAST - VC** | **3725 MW** |
| **TOTAL EAST** | **7550 MW** |
| **UPNY CONED** | **8210 MW** |
| **SPR/DUN-SOUTH** | **4600 MW** |
| **DYSINGER EAST** | **3200 MW** |
| **MOSES SOUTH** | **3400 MW** |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

---

**PRINCTWN-N.SCTLND_345_55**

Tue 04/20/2027 to Thu 04/22/2027
0800 Continuous 1700
Work scheduled by: LS

| | FWD (Import) | REV (Export) |
|---|---|---|
| CENTRAL EAST - VC | **3645 MW** | |
| Impacts Total Transfer Capability | 80 MW | |
| TTC with All Lines In Service | 3725 MW | |

---

**MARCY___-FRASANNX_345_UCC2-41**

Mon 04/26/2027 to Sun 05/16/2027
0700 Continuous 1730
Work scheduled by: NYPA

ARR: 19

| | FWD (Import) | REV (Export) |
|---|---|---|
| CENTRAL EAST - VC | **3225 MW** | |
| Impacts Total Transfer Capability | 500 MW | |
| TTC with All Lines In Service | 3725 MW | |

---

**PANNELL_-CLAY____345_2**

Mon 04/26/2027 to Fri 04/30/2027
0700 Continuous 1730
Work scheduled by: NYPA

| | FWD (Import) | REV (Export) |
|---|---|---|
| WEST CENTRAL | **1300 MW** | |
| Impacts Total Transfer Capability | 950 MW | |
| TTC with All Lines In Service | 2250 MW | |

---

**EDIC___-PRINCTWN_345_351**

Tue 04/27/2027 to Thu 04/29/2027
0800 Continuous 1700
Work scheduled by: LS

| | FWD (Import) | REV (Export) |
|---|---|---|
| CENTRAL EAST - VC | **3335 MW** | |
| Impacts Total Transfer Capability | 390 MW | |
| TTC with All Lines In Service | 3725 MW | |

---

**HAVERSTK-ADIRNDCK_345_HA2**

Mon 05/03/2027 to Wed 05/05/2027
0600 Continuous 1630
Work scheduled by: NYPA

| | FWD (Import) | REV (Export) |
|---|---|---|
| MOSES SOUTH | **2100 MW** | |
| Impacts Total Transfer Capability | 1300 MW | |
| TTC with All Lines In Service | 3400 MW | |

---

**EDIC___-PRINCTWN_345_352**

Tue 05/04/2027 to Thu 05/06/2027
0800 Continuous 1700
Work scheduled by: LS

| | FWD (Import) | REV (Export) |
|---|---|---|
| CENTRAL EAST - VC | **3335 MW** | |
| Impacts Total Transfer Capability | 390 MW | |
| TTC with All Lines In Service | 3725 MW | |

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits** — **Tuesday, October 13, 2026 to Wednesday, April 12, 2028**

| | |
|---|---|
| **CENTRAL EAST** | **7550 MW** |
| **CENTRAL EAST - VC** | **3725 MW** |
| **TOTAL EAST** | **7550 MW** |
| **UPNY CONED** | **8210 MW** |
| **SPR/DUN-SOUTH** | **4600 MW** |
| **DYSINGER EAST** | **3200 MW** |
| **MOSES SOUTH** | **3400 MW** |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

---

**AUSTINRD-ADIRNDCK_345_13**

Thu 05/06/2027 to Fri 05/07/2027
0600 Continuous 1630
Work scheduled by: NYPA

| | FWD (Import) | REV (Export) |
|---|---|---|
| MOSES SOUTH | **2100 MW** | |
| Impacts Total Transfer Capability | 1300 MW | |
| TTC with All Lines In Service | 3400 MW | |

---

**NEPTUNE_-DUFFYAVE_345_NEPTUNE**

Mon 05/10/2027 to Fri 05/14/2027
0600 Continuous 1600
Work scheduled by: LI

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - PJM_NEPTUNE | **0 MW** | |
| Impacts Total Transfer Capability | 660 MW | |
| TTC with All Lines In Service | 660 MW | |

---

**NEWBRDGE_345_138_BK_1**

Mon 05/10/2027 to Fri 05/14/2027
0600 Continuous 1600
Work scheduled by: LI

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - PJM_NEPTUNE | **375 MW** | |
| Impacts Total Transfer Capability | 285 MW | |
| TTC with All Lines In Service | 660 MW | |

---

**NEWBRDGE_345_138_BK_2**

Mon 05/10/2027 to Fri 05/14/2027
0600 Continuous 1600
Work scheduled by: LI

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - PJM_NEPTUNE | **375 MW** | |
| Impacts Total Transfer Capability | 285 MW | |
| TTC with All Lines In Service | 660 MW | |

---

**NEWBRDGE-DUFFYAVE_345_501**

Mon 05/10/2027 to Fri 05/14/2027
0600 Continuous 1600
Work scheduled by: LI

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - PJM_NEPTUNE | **0 MW** | |
| Impacts Total Transfer Capability | 660 MW | |
| TTC with All Lines In Service | 660 MW | |

---

**GORDONRD-ROTTRDAM_230_30**

Mon 05/10/2027 to Fri 05/14/2027
0800 Continuous 1700
Work scheduled by: LS

| | FWD (Import) | REV (Export) |
|---|---|---|
| CENTRAL EAST - VC | **3690 MW** | |
| Impacts Total Transfer Capability | 35 MW | |
| TTC with All Lines In Service | 3725 MW | |

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits** — **Tuesday, October 13, 2026 to Wednesday, April 12, 2028**

| | |
|---|---|
| **CENTRAL EAST** | **7550 MW** |
| **CENTRAL EAST - VC** | **3725 MW** |
| **TOTAL EAST** | **7550 MW** |
| **UPNY CONED** | **8210 MW** |
| **SPR/DUN-SOUTH** | **4600 MW** |
| **DYSINGER EAST** | **3200 MW** |
| **MOSES SOUTH** | **3400 MW** |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

---

**DYSINGER-GRAHAM__345_DG1**

Thu 05/13/2027 to Mon 05/24/2027
0500 Continuous 2330
Work scheduled by: NYPA

| | FWD (Import) | REV (Export) |
|---|---|---|
| DYSINGER EAST | | |
| Impacts Total Transfer Capability | | |
| TTC with All Lines In Service | | |

---

**SPRNBRK__345KV_RNS5**

Sat 05/15/2027 to Sat 05/15/2027
0201 Continuous 0230
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|---|---|---|
| SPR/DUN-SOUTH | **3200 MW** | |
| Impacts Total Transfer Capability | 1400 MW | |
| TTC with All Lines In Service | 4600 MW | |

---

**SPRNBRK_-W49TH_ST_345_M51**

Sat 05/15/2027 to Tue 06/01/2027
0201 Continuous 0200
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|---|---|---|
| SPR/DUN-SOUTH | **3200 MW** | |
| Impacts Total Transfer Capability | 1400 MW | |
| TTC with All Lines In Service | 4600 MW | |

---

**CHATGUAY-MASSENA__765_7040**

Mon 05/24/2027 to Sat 05/29/2027
0001 Continuous 0130
Work scheduled by: NYPA

UPDATED by NYPA 06/05/2026 15:18

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - HQ - NY | **0 MW** | **0 MW** |
| Impacts Total Transfer Capability | 1500 MW | 1000 MW |
| TTC with All Lines In Service | 1500 MW | 1000 MW |

---

**CHATGUAY-MASSENA__765_7040**

Mon 05/24/2027 to Sat 05/29/2027
0001 Continuous 0130
Work scheduled by: NYPA

UPDATED by NYPA 06/05/2026 15:18

| | FWD (Import) | REV (Export) |
|---|---|---|
| MOSES SOUTH | **1750 MW** | |
| Impacts Total Transfer Capability | 1650 MW | |
| TTC with All Lines In Service | 3400 MW | |

---

**MARCY___765_345_AT1**

Mon 05/24/2027 to Sat 05/29/2027
0001 Continuous 0130
Work scheduled by: NYPA

UPDATED by NYPA 06/05/2026 15:18

ARR: 19

| | FWD (Import) | REV (Export) |
|---|---|---|
| MOSES SOUTH | **1750 MW** | |
| Impacts Total Transfer Capability | 1650 MW | |
| TTC with All Lines In Service | 3400 MW | |

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits** — **Tuesday, October 13, 2026 to Wednesday, April 12, 2028**

| | |
|---|---|
| **CENTRAL EAST** | **7550 MW** |
| **CENTRAL EAST - VC** | **3725 MW** |
| **TOTAL EAST** | **7550 MW** |
| **UPNY CONED** | **8210 MW** |
| **SPR/DUN-SOUTH** | **4600 MW** |
| **DYSINGER EAST** | **3200 MW** |
| **MOSES SOUTH** | **3400 MW** |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

---

**MARCY___765_345_AT2**

Mon 05/24/2027 to Sat 05/29/2027
0001 Continuous 0130
Work scheduled by: NYPA

UPDATED by NYPA 06/05/2026 15:18

ARR: 19

| | FWD (Import) | REV (Export) |
|---|---|---|
| MOSES SOUTH | **1700 MW** | |
| Impacts Total Transfer Capability | 1700 MW | |
| TTC with All Lines In Service | 3400 MW | |

---

**MASSENA_-MARCY___765_MSU1**

Mon 05/24/2027 to Sat 05/29/2027
0001 Continuous 0130
Work scheduled by: NYPA

UPDATED by NYPA 06/05/2026 15:18

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - HQ - NY | **475 MW** | **1000 MW** |
| Impacts Total Transfer Capability | 1025 MW | 0 MW |
| TTC with All Lines In Service | 1500 MW | 1000 MW |

---

**MASSENA_-MARCY___765_MSU1**

Mon 05/24/2027 to Sat 05/29/2027
0001 Continuous 0130
Work scheduled by: NYPA

UPDATED by NYPA 06/05/2026 15:18

| | FWD (Import) | REV (Export) |
|---|---|---|
| CENTRAL EAST - VC | **2595 MW** | |
| Impacts Total Transfer Capability | 1130 MW | |
| TTC with All Lines In Service | 3725 MW | |

---

**MASSENA_-MARCY___765_MSU1**

Mon 05/24/2027 to Sat 05/29/2027
0001 Continuous 0130
Work scheduled by: NYPA

UPDATED by NYPA 06/05/2026 15:18

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - HQ_CEDARS | **190 MW** | |
| Impacts Total Transfer Capability | 80 MW | |
| TTC with All Lines In Service | 270 MW | |

---

**MASSENA_-MARCY___765_MSU1**

Mon 05/24/2027 to Sat 05/29/2027
0001 Continuous 0130
Work scheduled by: NYPA

UPDATED by NYPA 06/05/2026 15:18

| | FWD (Import) | REV (Export) |
|---|---|---|
| MOSES SOUTH | **500 MW** | |
| Impacts Total Transfer Capability | 2900 MW | |
| TTC with All Lines In Service | 3400 MW | |

---

**MASSENA_-MARCY___765_MSU1 , CHATGUAY-MASSENA__765_7040**

Mon 05/24/2027 to Sat 05/29/2027
0001 0130
Work scheduled by:

| | FWD (Import) | REV (Export) |
|---|---|---|
| MOSES SOUTH | **500 MW** | |
| Impacts Total Transfer Capability | 2900 MW | |
| TTC with All Lines In Service | 3400 MW | |

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits** — **Tuesday, October 13, 2026 to Wednesday, April 12, 2028**

| | |
|---|---|
| **CENTRAL EAST** | **7550 MW** |
| **CENTRAL EAST - VC** | **3725 MW** |
| **TOTAL EAST** | **7550 MW** |
| **UPNY CONED** | **8210 MW** |
| **SPR/DUN-SOUTH** | **4600 MW** |
| **DYSINGER EAST** | **3200 MW** |
| **MOSES SOUTH** | **3400 MW** |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**MOSES__-MASSENA__230_MMS2 , MOSES__-MASSENA__230_MMS1**

Mon 05/24/2027 to Sat 05/29/2027
0001 0130
Work scheduled by:

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - HQ - NY | **850 MW** | **0 MW** |
| Impacts Total Transfer Capability | 650 MW | 1000 MW |
| TTC with All Lines In Service | 1500 MW | 1000 MW |

**MOSES__-MASSENA__230_MMS2 , MOSES__-MASSENA__230_MMS1**

Mon 05/24/2027 to Sat 05/29/2027
0001 0130
Work scheduled by:

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - HQ_CEDARS | **190 MW** | |
| Impacts Total Transfer Capability | 80 MW | |
| TTC with All Lines In Service | 270 MW | |

**SPRNBRK__345KV_RNS5**

Sat 05/29/2027 to Mon 05/31/2027
0001 Continuous 0100
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|---|---|---|
| SPR/DUN-SOUTH | **3200 MW** | |
| Impacts Total Transfer Capability | 1400 MW | |
| TTC with All Lines In Service | 4600 MW | |

**SPRNBRK__345KV_RNS5**

Tue 06/01/2027 to Tue 06/01/2027
0130 Continuous 0200
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|---|---|---|
| SPR/DUN-SOUTH | **3200 MW** | |
| Impacts Total Transfer Capability | 1400 MW | |
| TTC with All Lines In Service | 4600 MW | |

**MARION__-FARRAGUT_345_C3403**

Mon 06/07/2027 to Thu 06/10/2027
0001 Continuous 2200
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - PJ - NY | | |
| Impacts Total Transfer Capability | | |
| TTC with All Lines In Service | | |

**GORDONRD-PRINCTWN_345_371**

Tue 06/08/2027 to Thu 06/10/2027
0800 Continuous 1700
Work scheduled by: LS

| | FWD (Import) | REV (Export) |
|---|---|---|
| CENTRAL EAST - VC | **3405 MW** | |
| Impacts Total Transfer Capability | 320 MW | |
| TTC with All Lines In Service | 3725 MW | |

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits** — **Tuesday, October 13, 2026 to Wednesday, April 12, 2028**

| | |
|---|---|
| **CENTRAL EAST** | **7550 MW** |
| **CENTRAL EAST - VC** | **3725 MW** |
| **TOTAL EAST** | **7550 MW** |
| **UPNY CONED** | **8210 MW** |
| **SPR/DUN-SOUTH** | **4600 MW** |
| **DYSINGER EAST** | **3200 MW** |
| **MOSES SOUTH** | **3400 MW** |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**NIAGARA_-PACKARD__230_61**

Fri 09/10/2027 to Fri 09/10/2027
0500 Continuous 2300
Work scheduled by: NYPA

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - OH - NY | **1900 MW** | **1450 MW** |
| Impacts Total Transfer Capability | 100 MW | 150 MW |
| TTC with All Lines In Service | 2000 MW | 1600 MW |

**PANNELL_-CLAY____345_1**

Mon 09/13/2027 to Fri 09/17/2027
0700 Continuous 1730
Work scheduled by: NYPA

| | FWD (Import) | REV (Export) |
|---|---|---|
| WEST CENTRAL | **1300 MW** | |
| Impacts Total Transfer Capability | 950 MW | |
| TTC with All Lines In Service | 2250 MW | |

**NIAGARA_-PACKARD__230_62**

Wed 09/15/2027 to Tue 11/30/2027
0500 Continuous 2300
Work scheduled by: NYPA

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - OH - NY | **1650 MW** | **1550 MW** |
| Impacts Total Transfer Capability | 350 MW | 50 MW |
| TTC with All Lines In Service | 2000 MW | 1600 MW |

**INGHAM_C_115_115_PAR 2**

Fri 09/17/2027 to Fri 10/29/2027
0600 Continuous 1600
Work scheduled by: NGrid

| | FWD (Import) | REV (Export) |
|---|---|---|
| CENTRAL EAST - VC | **3605 MW** | |
| Impacts Total Transfer Capability | 120 MW | |
| TTC with All Lines In Service | 3725 MW | |

**MARCY___-FRASANNX_345_UCC2-41**

Sat 09/18/2027 to Sat 10/30/2027
0700 Continuous 1730
Work scheduled by: NYPA

ARR: 19

| | FWD (Import) | REV (Export) |
|---|---|---|
| CENTRAL EAST - VC | **3225 MW** | |
| Impacts Total Transfer Capability | 500 MW | |
| TTC with All Lines In Service | 3725 MW | |

**BUCHAN_S-MILLWOOD_345_W97**

Mon 09/20/2027 to Mon 09/20/2027
0001 Continuous 0030
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|---|---|---|
| UPNY CONED | **8175 MW** | |
| Impacts Total Transfer Capability | 35 MW | |
| TTC with All Lines In Service | 8210 MW | |

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits** — **Tuesday, October 13, 2026 to Wednesday, April 12, 2028**

| | |
|---|---|
| **CENTRAL EAST** | **7550 MW** |
| **CENTRAL EAST - VC** | **3725 MW** |
| **TOTAL EAST** | **7550 MW** |
| **UPNY CONED** | **8210 MW** |
| **SPR/DUN-SOUTH** | **4600 MW** |
| **DYSINGER EAST** | **3200 MW** |
| **MOSES SOUTH** | **3400 MW** |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

---

**PANNELL_-CLAY____345_2**

Mon 09/20/2027 to Fri 09/24/2027
0700 Continuous 1730
Work scheduled by: NYPA

| | FWD (Import) | REV (Export) |
|---|---|---|
| WEST CENTRAL | **1300 MW** | |
| Impacts Total Transfer Capability | 950 MW | |
| TTC with All Lines In Service | 2250 MW | |

---

**BUCHAN_S-MILLWOOD_345_W97**

Tue 09/21/2027 to Tue 09/21/2027
0130 Continuous 0200
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|---|---|---|
| UPNY CONED | **8175 MW** | |
| Impacts Total Transfer Capability | 35 MW | |
| TTC with All Lines In Service | 8210 MW | |

---

**CLAY___-EDIC____345_1-16**

Mon 09/27/2027 to Fri 10/01/2027
0700 Continuous 1730
Work scheduled by: NYPA

| | FWD (Import) | REV (Export) |
|---|---|---|
| OSWEGO EXPORT | **5450 MW** | |
| Impacts Total Transfer Capability | 150 MW | |
| TTC with All Lines In Service | 5600 MW | |

---

**SAND_BAR-PLATSBRG_115_PV20**

Mon 09/27/2027 to Fri 10/01/2027
0800 Continuous 1630
Work scheduled by: NYPA

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - NE - NY | | |
| Impacts Total Transfer Capability | | |
| TTC with All Lines In Service | | |

---

**SAND_BAR-PLATSBRG_115_PV20**

Mon 09/27/2027 to Fri 10/01/2027
0800 Continuous 1630
Work scheduled by: NYPA

| | FWD (Import) | REV (Export) |
|---|---|---|
| CENTRAL EAST - VC | **3625 MW** | |
| Impacts Total Transfer Capability | 100 MW | |
| TTC with All Lines In Service | 3725 MW | |

---

**WOOD_ST_-PLSNTVLE_345_Y87**

Mon 10/04/2027 to Sat 10/16/2027
0001 Continuous 0200
Work scheduled by: ConEd

CANCELLED by TO 10/13/2026 16:23

| | FWD (Import) | REV (Export) |
|---|---|---|
| UPNY CONED | **7795 MW** | |
| Impacts Total Transfer Capability | 415 MW | |
| TTC with All Lines In Service | 8210 MW | |

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits** — **Tuesday, October 13, 2026 to Wednesday, April 12, 2028**

| | |
|---|---|
| **CENTRAL EAST** | **7550 MW** |
| **CENTRAL EAST - VC** | **3725 MW** |
| **TOTAL EAST** | **7550 MW** |
| **UPNY CONED** | **8210 MW** |
| **SPR/DUN-SOUTH** | **4600 MW** |
| **DYSINGER EAST** | **3200 MW** |
| **MOSES SOUTH** | **3400 MW** |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**CLAY___-EDIC____345_2-15**

Mon 10/04/2027 to Fri 10/08/2027
0700 Continuous 1730
Work scheduled by: NYPA

| | FWD (Import) | REV (Export) |
|---|---|---|
| OSWEGO EXPORT | **5450 MW** | |
| Impacts Total Transfer Capability | 150 MW | |
| TTC with All Lines In Service | 5600 MW | |

**SPRNBRK_-UNIONHBS_345_Y49**

Mon 10/04/2027 to Fri 05/26/2028
0800 Continuous 1530
Work scheduled by: NYPA

| | FWD (Import) | REV (Export) |
|---|---|---|
| CONED - LIPA | **775 MW** | |
| Impacts Total Transfer Capability | 725 MW | |
| TTC with All Lines In Service | 1500 MW | |

**UNIONDHB_345_138_AT1**

Mon 10/04/2027 to Fri 05/26/2028
0800 Continuous 1530
Work scheduled by: NYPA

| | FWD (Import) | REV (Export) |
|---|---|---|
| CONED - LIPA | **1250 MW** | |
| Impacts Total Transfer Capability | 250 MW | |
| TTC with All Lines In Service | 1500 MW | |

**UNIONDHB_345_138_AT2**

Mon 10/04/2027 to Fri 05/26/2028
0800 Continuous 1530
Work scheduled by: NYPA

| | FWD (Import) | REV (Export) |
|---|---|---|
| CONED - LIPA | **1250 MW** | |
| Impacts Total Transfer Capability | 250 MW | |
| TTC with All Lines In Service | 1500 MW | |

**NEPTUNE_-DUFFYAVE_345_NEPTUNE**

Mon 10/11/2027 to Thu 10/14/2027
0600 Continuous 1600
Work scheduled by: LI

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - PJM_NEPTUNE | **0 MW** | |
| Impacts Total Transfer Capability | 660 MW | |
| TTC with All Lines In Service | 660 MW | |

**NEWBRDGE_345_138_BK_1**

Mon 10/11/2027 to Thu 10/14/2027
0600 Continuous 1600
Work scheduled by: LI

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - PJM_NEPTUNE | **375 MW** | |
| Impacts Total Transfer Capability | 285 MW | |
| TTC with All Lines In Service | 660 MW | |

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits** — **Tuesday, October 13, 2026 to Wednesday, April 12, 2028**

| | |
|---|---|
| **CENTRAL EAST** | **7550 MW** |
| **CENTRAL EAST - VC** | **3725 MW** |
| **TOTAL EAST** | **7550 MW** |
| **UPNY CONED** | **8210 MW** |
| **SPR/DUN-SOUTH** | **4600 MW** |
| **DYSINGER EAST** | **3200 MW** |
| **MOSES SOUTH** | **3400 MW** |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

**NEWBRDGE_345_138_BK_2**

Mon 10/11/2027 to Thu 10/14/2027
0600 Continuous 1600
Work scheduled by: LI

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - PJM_NEPTUNE | **375 MW** | |
| Impacts Total Transfer Capability | 285 MW | |
| TTC with All Lines In Service | 660 MW | |

**NEWBRDGE-DUFFYAVE_345_501**

Mon 10/11/2027 to Thu 10/14/2027
0600 Continuous 1600
Work scheduled by: LI

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - PJM_NEPTUNE | **0 MW** | |
| Impacts Total Transfer Capability | 660 MW | |
| TTC with All Lines In Service | 660 MW | |

**BUCHAN_S-MILLWOOD_345_W97**

Sun 10/24/2027 to Wed 10/27/2027
0001 Continuous 0200
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|---|---|---|
| UPNY CONED | **8175 MW** | |
| Impacts Total Transfer Capability | 35 MW | |
| TTC with All Lines In Service | 8210 MW | |

**SPRNBRK__345KV_RNS4**

Wed 12/01/2027 to Wed 12/01/2027
0001 Continuous 0030
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|---|---|---|
| SPR/DUN-SOUTH | **3200 MW** | |
| Impacts Total Transfer Capability | 1400 MW | |
| TTC with All Lines In Service | 4600 MW | |

**SPRNBRK_-W49TH_ST_345_M52**

Wed 12/01/2027 to Wed 12/15/2027
0001 Continuous 0200
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|---|---|---|
| SPR/DUN-SOUTH | **3200 MW** | |
| Impacts Total Transfer Capability | 1400 MW | |
| TTC with All Lines In Service | 4600 MW | |

**W49TH_ST_345KV_5**

Wed 12/01/2027 to Wed 12/15/2027
0001 Continuous 0200
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - PJM_HTP | **300 MW** | |
| Impacts Total Transfer Capability | 360 MW | |
| TTC with All Lines In Service | 660 MW | |

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits** — **Tuesday, October 13, 2026 to Wednesday, April 12, 2028**

| | |
|---|---|
| **CENTRAL EAST** | **7550 MW** |
| **CENTRAL EAST - VC** | **3725 MW** |
| **TOTAL EAST** | **7550 MW** |
| **UPNY CONED** | **8210 MW** |
| **SPR/DUN-SOUTH** | **4600 MW** |
| **DYSINGER EAST** | **3200 MW** |
| **MOSES SOUTH** | **3400 MW** |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

---

**SPRNBRK__345KV_RNS4**

Wed 12/15/2027 to Wed 12/15/2027
0130 Continuous 0200
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|---|---|---|
| SPR/DUN-SOUTH | **3200 MW** | |
| Impacts Total Transfer Capability | 1400 MW | |
| TTC with All Lines In Service | 4600 MW | |

---

**W49TH_ST_345KV_5**

Wed 12/15/2027 to Tue 02/22/2028
0201 Continuous 0200
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - PJM_HTP | **300 MW** | |
| Impacts Total Transfer Capability | 360 MW | |
| TTC with All Lines In Service | 660 MW | |

---

**W49TH_ST_345KV_7**

Wed 12/15/2027 to Tue 02/22/2028
0201 Continuous 0200
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - PJM_HTP | **300 MW** | |
| Impacts Total Transfer Capability | 360 MW | |
| TTC with All Lines In Service | 660 MW | |

---

**GORDONRD-ROTTRDAM_230_30**

Mon 01/03/2028 to Fri 04/07/2028
0700 Continuous 1700
Work scheduled by: NGrid

| | FWD (Import) | REV (Export) |
|---|---|---|
| CENTRAL EAST - VC | **3690 MW** | |
| Impacts Total Transfer Capability | 35 MW | |
| TTC with All Lines In Service | 3725 MW | |

---

**PLSNTVLY-WOOD_ST__345_F30**

Thu 02/03/2028 to Sun 02/13/2028
0001 Continuous 2200
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|---|---|---|
| UPNY CONED | **7780 MW** | |
| Impacts Total Transfer Capability | 430 MW | |
| TTC with All Lines In Service | 8210 MW | |

---

**SPRNBRK__345KV_RNS4**

Tue 02/22/2028 to Tue 02/22/2028
0201 Continuous 0231
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|---|---|---|
| SPR/DUN-SOUTH | **3200 MW** | |
| Impacts Total Transfer Capability | 1400 MW | |
| TTC with All Lines In Service | 4600 MW | |

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits** — **Tuesday, October 13, 2026 to Wednesday, April 12, 2028**

| | |
|---|---|
| **CENTRAL EAST** | **7550 MW** |
| **CENTRAL EAST - VC** | **3725 MW** |
| **TOTAL EAST** | **7550 MW** |
| **UPNY CONED** | **8210 MW** |
| **SPR/DUN-SOUTH** | **4600 MW** |
| **DYSINGER EAST** | **3200 MW** |
| **MOSES SOUTH** | **3400 MW** |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

---

**SPRNBRK_-W49TH_ST_345_M52**

Tue 02/22/2028 to Fri 04/07/2028
0201 Continuous 0200
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|---|---|---|
| SPR/DUN-SOUTH | **3200 MW** | |
| Impacts Total Transfer Capability | 1400 MW | |
| TTC with All Lines In Service | 4600 MW | |

---

**W49TH_ST_345KV_5**

Tue 02/22/2028 to Fri 04/07/2028
0201 Continuous 0200
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|---|---|---|
| SCH - PJM_HTP | **300 MW** | |
| Impacts Total Transfer Capability | 360 MW | |
| TTC with All Lines In Service | 660 MW | |

---

**PLSNTVLY-WOOD_ST__345_F30**

Mon 03/06/2028 to Thu 03/09/2028
0001 Continuous 2200
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|---|---|---|
| UPNY CONED | **7780 MW** | |
| Impacts Total Transfer Capability | 430 MW | |
| TTC with All Lines In Service | 8210 MW | |

---

**PLSNTVLY-EFISHKIL_345_F37**

Tue 03/14/2028 to Wed 04/19/2028
0001 Continuous 0200
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|---|---|---|
| UPNY CONED | **8195 MW** | |
| Impacts Total Transfer Capability | 15 MW | |
| TTC with All Lines In Service | 8210 MW | |

---

**WOOD_ST_-PLSNTVLE_345_Y87**

Tue 03/14/2028 to Tue 03/14/2028
0001 Continuous 0030
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|---|---|---|
| UPNY CONED | **7795 MW** | |
| Impacts Total Transfer Capability | 415 MW | |
| TTC with All Lines In Service | 8210 MW | |

---

**WOOD_ST_-PLSNTVLE_345_Y87**

Thu 03/16/2028 to Thu 03/16/2028
0130 Continuous 0200
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|---|---|---|
| UPNY CONED | **7795 MW** | |
| Impacts Total Transfer Capability | 415 MW | |
| TTC with All Lines In Service | 8210 MW | |

# NYISO TRANSFER LIMITATIONS

**Seasonal Limits** — **Tuesday, October 13, 2026 to Wednesday, April 12, 2028**

| | |
|---|---|
| **CENTRAL EAST** | **7550 MW** |
| **CENTRAL EAST - VC** | **3725 MW** |
| **TOTAL EAST** | **7550 MW** |
| **UPNY CONED** | **8210 MW** |
| **SPR/DUN-SOUTH** | **4600 MW** |
| **DYSINGER EAST** | **3200 MW** |
| **MOSES SOUTH** | **3400 MW** |

**The Total Transfer Capabilities (TTCs) indicated in this report represent predicted values of transfer capability between NYISO LBMP zones as limited by either interface stability limits, voltage transfer limits, or individual transmission facility thermal limitations. Only those transmission facility outages that significantly impact NYISO transfer capability are reported. The DAM and HAM values of TTC may differ from the values indicated in this report due to unanticipated NYISO or external control area limitations.**

---

**SPRNBRK__345KV_RNS4**

Fri 04/07/2028 to Fri 04/07/2028
0130 Continuous 0200
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|---|---|---|
| SPR/DUN-SOUTH | **3200 MW** | |
| Impacts Total Transfer Capability | 1400 MW | |
| TTC with All Lines In Service | 4600 MW | |

---

**SPRNBRK__345KV_RS4 , SPRNBRK__345KV_RS3**

Sun 04/09/2028 to Sun 05/14/2028
0001 0200
Work scheduled by:

| | FWD (Import) | REV (Export) |
|---|---|---|
| SPR/DUN-SOUTH | **3800 MW** | |
| Impacts Total Transfer Capability | 800 MW | |
| TTC with All Lines In Service | 4600 MW | |

---

**SPRNBRK_-TREMONT__345_X28**

Sun 04/09/2028 to Sun 05/14/2028
0001 Continuous 0200
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|---|---|---|
| SPR/DUN-SOUTH | **4200 MW** | |
| Impacts Total Transfer Capability | 400 MW | |
| TTC with All Lines In Service | 4600 MW | |

---

**WOOD_ST_-PLSNTVLE_345_Y87**

Tue 04/11/2028 to Tue 04/11/2028
0001 Continuous 0030
Work scheduled by: ConEd

| | FWD (Import) | REV (Export) |
|---|---|---|
| UPNY CONED | **7795 MW** | |
| Impacts Total Transfer Capability | 415 MW | |
| TTC with All Lines In Service | 8210 MW | |